20 JUL 20 1998

ENGINEERING DATA TRANSMITTAL

Page 1 of 1
1. EDT 622266

2. To: (Receiving Organization) Distribution		3. From: (Originating Organization) TWRS Projects/SST Retrieval		4. Related EDT No.: n/a	
5. Proj./Prog./Dept./Div.: W-320 TWRS/TCPN # D2991		6. Design Authority/ Design Agent/Cog. Engr.: JW Bailey, NHC		7. Purchase Order No.: n/a	
8. Originator Remarks: For approval and release of a new supporting document. This document has been generated to ensure retrievability of the Project W-320 "Construction Specification W-320-C1".				9. Equip./Component No.: n/a	
				10. System/Bldg./Facility: 241-C-106	
11. Receiver Remarks: 11A. Design Baseline Document? [X] Yes [] No				12. Major Assm. Dwg. No.: n/a	
				13. Permit/Permit Application No.: n/a	
				14. Required Response Date:	

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Transmittal	Originator Disposition	Receiver Disposition
1	HNF-2532	-	0	Project W-320, 241-C-106 Sluicing, Construction Specification W-320-C1	NA			-

16. KEY		
Approval Designator (F)	Reason for Transmittal (G)	Disposition (H) & (I)
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)	1. Approval 2. Release 3. Information 4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)	1. Approved 2. Approved w/comment 3. Disapproved w/comment 4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)									
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature
2	1	Design Authority	JW Bailey	7/18/98	S2-48				
		Design Agent							
2	1	Cog. Eng	MC [Signature]	7/18/98	S2-48				
2	1	Cog. Mgr	JW Bailey	7/18/98	S2-48				
		QA							
		Safety							
		Env.							

18. Signature of EDT Originator M.C. [Signature] 7/18/98		19. Authorized Representative Date for Receiving Organization		20. Signature of Cognizant Manager J.W. Bailey 7/18/98		21. DOE APPROVAL (if required) Ctrl. No. ☐ Approved ☐ Approved w/comments ☐ Disapproved w/comments	
---	--	---	--	---	--	--	--

Project W-320, 241-C-106 Sluicing, Construction Specification, W-320-C1

John W. Bailey
Numatec Hanford Co., Richland, WA 99352
U.S. Department of Energy Contract DE-AC09-96RL13200

EDT/ECN: 622266 UC: 506
Org Code: 8C452 Charge Code: D2991/HANA0600
B&R Code: EW3130010 Total Pages: 135

Key Words: W-320, Sluicing, Tank 241-C-106, Tank 241-AY-102,
WRSS, Specifications, Construction.

Abstract: This supporting document has been prepared to make the
construction specifications for Project W-320, readily available.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

Release Approval

Date

Approved for Public Release

ENGINEERING CHANGE NOTICE

Page 1 of 2
 1. ECN 649179
 Proj. ECN W-320-805

2. ECN Category (mark one) Supplemental ☐ Direct Revision ☒ Change ECN ☐ Temporary Standby ☐ Supersedeure ☐ Cancel/Void ☐	3. Originator's Name, Organization, MSIN, and Telephone No. DL. Evans, FDNW, S2-47, 373-2688	4. USQ Required? ☐ Yes ☒ No <u>9/16/98</u> (See Work 14b) <u>6/25/98</u>	5. Date 6/25/98
	6. Project Title/No./Work Order No. W320 Waste Retrieval for Tank 241-C-106 /W320 / Pkg 1	7. Bldg./Sys./Fac. No. Tanks 241-AY-102 & 241-C-106	8. Approval Designator SQ/SC
	9. Document Numbers Changed by this ECN (includes sheet no. and rev.) W-320-C1, Rev 0	10. Related ECN No(s). None	11. Related PO No. NA

12a. Modification Work ☐ Yes (fill out Blk. 12b) ☒ No (NA Blks. 12b, 12c, 12d)	12b. Work Package No. NA	12c. Modification Work Complete NA Design Authority/Cog. Engineer Signature & Date	12d. Restored to Original Condition (Temp. or Standby ECN only) NA Design Authority/Cog. Engineer Signature & Date
---	-----------------------------	--	--

13a. Description of Change

13b. Design Baseline Document? ☒ Yes ☐ No

GS

As-Built and General Revisions of the construction specification W-320-C1. Changes to include:

Section 15493

1.3.3 change "Safety Class 2" to "Safety Significant products"

Table PIPE CODE M-5 pages 14 & 15 change "(Safety Class 3)" to "(General Service)"

Table PIPE CODE M-7 page 16 change "(Safety Class 3)" to "(General Service)"

Table PIPE CODE M-9 page 17 change "(Safety Class 2)" to "(Safety Significant)"

Table PIPE CODE M-26a page 18 change "(Safety Class 3)" to "(General Service)"

14a. Justification (mark one)

Criteria Change ☐	Design Improvement ☐	Environmental ☐	Facility Deactivation ☐
As-Found ☒	Facilitate Const ☐	Const. Error/Omission ☐	Design Error/Omission ☐

14b. Justification Details

As-Built construction specification for project turnover.

No USQ required because categorical exclusion (TF-96-0690, Rev 2) applies.

No project calculations are affected by this work.

An independent review of this design change was performed by FDNW in accordance with HNF-PRO-445.

15. Distribution (include name, MSIN, and no. of copies)

CDC, S2-53, 1
TJ Kasnick, S2-47, 1JW Bailey, S2-48, 1
RL Powers, S5-13, 1

Project Files, R1-29,

RELEASE STAMP

DATE:

STA: 4HANFORD
RELEASE

ID:

2.

JUL 08 1998

ENGINEERING CHANGE NOTICE

Page 2 of 2

1. ECN (use no. from pg. 1)

W-320-805

16. Design Verification Required

☒ Yes
☐ No

17. Cost Impact

ENGINEERING

Additional ☐ \$ NA
Savings ☐ \$

CONSTRUCTION

Additional ☐ \$ NA
Savings ☐ \$

18. Schedule Impact (days)

Improvement ☐ NA
Delay ☐

19. Change Impact Review: Indicate the related documents (other than the engineering documents identified on Side 1) that will be affected by the change described in Block 13. Enter the affected document number in Block 20.

SDO/DDO	☐	Seismic/Stress Analysis	☐	Tank Calibration Manual	☐
Functional Design Criteria	☐	Stress/Design Report	☐	Health Physics Procedure	☐
Operating Specification	☐	Interface Control Drawing	☐	Spares Multiple Unit Listing	☐
Criticality Specification	☐	Calibration Procedure	☐	Test Procedures/Specification	☐
Conceptual Design Report	☐	Installation Procedure	☐	Component Index	☐
Equipment Spec.	☐	Maintenance Procedure	☐	ASME Coded Item	☐
Const. Spec.	☐	Engineering Procedure	☐	Human Factor Consideration	☐
Procurement Spec.	☐	Operating Instruction	☐	Computer Software	☐
Vendor Information	☐	Operating Procedure	☐	Electric Circuit Schedule	☐
OM Manual	☐	Operational Safety Requirement	☐	ICRS Procedure	☐
FSAR/SAR	☐	IEFD Drawing	☐	Process Control Manual/Plan	☐
Safety Equipment List	☐	Cell Arrangement Drawing	☐	Process Flow Chart	☐
Radiation Work Permit	☐	Essential Material Specification	☐	Purchase Requisition	☐
Environmental Impact Statement	☐	Fac. Proc. Samp. Schedule	☐	Tickler File	☐
Environmental Report	☐	Inspection Plan	☐	None <i>6/25/98</i>	☐
Environmental Permit	☐	Inventory Adjustment Request	☐		☐

20. Other Affected Documents: (NOTE: Documents listed below will not be revised by this ECN.) Signatures below indicate that the signing organization has been notified of other affected documents listed below.

Document Number/Revision

Document Number/Revision

Document Number Revision

NA

21. Approvals

Design Authority

Cog. Eng.

Cog. Mgr.

QA

Safety

Environ.

Other

Date

6/24/98

6/29/98

6/23/98

6-29-98

7-1-98

07-06-98

Design Agent

PE

QA - NA

Safety - NA

Design - DL Evans

Environ. - NA

Checker

Other

Signature

Danny Lee Evans

[Signature]

[Signature]

[Signature]

[Signature]

[Signature]

[Signature]

[Signature]

Date

6/25/98

6-29-98

NA

NA

6/25/98

NA

6/25/98

NA

DEPARTMENT OF ENERGY

Signature or a Control Number that tracks the Approval Signature

ADDITIONAL

EXPIRES: 7/21/00

HN-2532, Rev.0

Page ii

AS-BUILT REV 1

TANK 241-C-106 SLUICING
Sitework/Interfarm Piping System

Original Issue: 11/07/94

Prepared By

Fluor Daniel Northwest
Richland, Washington

For

Numatec Hanford Corporation

Contract 651005

Client Concurrence6/29/98

Date

Project Manager06-25-98

Date

Lead Engineer6/25/98

Date

Field Concurrence6/25/98

Date

Checked By6/25/98

Date

Prepared By6/25/98

Date

The ECNs affecting specification are as follows:

HNF-2532, Rev.0
Page v

ECN W-320-084
03300-2, 3

ECN W-320-085
15493-1, 2, 4, 6, 7, 8,
9, 12, 13, 17, 21

ECN W-320-805
15493-3, 14, 15, 16,
17, 18

ECN W-320-108
02650-2

ECN W-320-111
02200-1
02225-2, 4

ECN W-320-112
15493-7, 15

ECN W-320-127
15493-10, 11, 16, 18, 21

ECN W-320-133
02650-1, 2, 3
15493-7, 14

ECN W-320-145
15493-3

ECN W-320-159
16640-6, 11, 12

ECN W-320-178
02225-2

ECN W-320-197
15500-2

ECN W-320-201
15493-10

ECN W-320-286
15500-4, 5

ECN W-320-389
03300-2

ECN W-320-413
15493-8, 19, 20, 21, 22

ECN W-320-701
TOC iii
02513-1, 2, 3, 4, 5

ECN W-320-805
15493-3, 14, 15, 16, 17, 18

CONSTRUCTION SPECIFICATION

TANK 241-C-106 SLUICING
Package I - Sitework/Interfarm Piping System

Work Order ER4319

Prepared By
ICF Kaiser Hanford Company
Richland, WashingtonFor the US Department of Energy
Contract DE-AC06-93RL12359

OFFICIAL RELEASE

BY WHC

DATE

NOV 07 1994

10 #10

APPROVED

ICF Kaiser Hanford Company (ICF KH)

P.E. #28260

Principal Lead Engineer

9/29/94
DateM.A. Fischer
Technical Documents9-28-94
Date

Safety

9/30/94
DateR.E. Manning
Environmental Engineering9-27-94
Date

Quality Engineering

9-30-94
DateJ.D. Wilson
Construction9-30-94
Date

Project Management

9/30/94
Date

Westinghouse Hanford Company (WHC)

Projects Department WHC

10/13/94
Date

RELEASED FOR CONSTRUCTION

N/A
US Department of Energy

Date

KAISER ENGINEERS HANFORD
CONTROLLED DOCUMENT
STATION NO.35

DIST

DATE NOV 09 1994

PROJ / WO W-320

NO PIE-1

CONSTRUCTION SPECIFICATION
TANK 241-C-106 SLUICING

HNF-2532, Rev.0
Page a-ii

Package I - Sitework/Interfarm Piping System

Prepared by
ICF Kaiser Hanford Company
Richland, Washington

CERTIFICATION

I certify that the indicated sections of this Specification were prepared by me or under my supervision and that I am a registered professional engineer under the laws of the State of Washington.

EXPIRES 5/3/96

Carroll Dean Jones, P.E.
Piping
Sections 15493

EXPIRES 9-3-96

Ronald W. Davidson, P.E.
Civil/Structural
Sections 02200, 02225, 02235,
02512, 02650, 02720, 03300,
05500, 09900, 13121

EXPIRES 11/18/94

Timothy J. Kasnick, P.E.
Electrical
Section 16400

EXPIRES 3/11/96

Peter H. Langowski, P.E.
HVAC
Section 15500

EXPIRES 6-1-96

Charles L. Sublett, P.E.
Cathodic
Section 16640

TABLE OF CONTENTS

HNF-2532, Rev.0
Page a-iii

Title and Approval Page	i
Certification Page	ii
Table of Contents	iii

Total Pages

DIVISION 1 - GENERAL REQUIREMENTS

Section 01010 through Section 01720 Under Separate Cover (W-030-G2)

DIVISION 2 - SITEWORK

Section 02200	Earthwork	6	
Section 02225	Excavating, Backfilling, and Compacting for Utilities	7	
Section 02235	Road Subgrade and Granular Base	5	
Section 02512	Hot-Laid Asphaltic Concrete Paving	3	
Section 02513	Cold-Laid Asphaltic Concrete Paving	5	ECN-701
Section 02650	Piped Utilities	3	
Section 02720	Storm Sewerage	1	

DIVISION 3 - CONCRETE

Section 03300	Cast-In-Place Concrete	7
---------------	------------------------	---

DIVISION 5 - METALS

Section 05500	Metal Fabrications	5
---------------	--------------------	---

DIVISION 9 - FINISHES

Section 09900	Painting	3
---------------	----------	---

DIVISION 13 - SPECIAL CONSTRUCTION

Section 13121	Metal Building Systems	8
---------------	------------------------	---

DIVISION 15 - MECHANICAL

Section 15493	Chemical Process Piping Systems	26
Appendix A	Identification of Piping Systems	2
Section 15500	Heating, Ventilating, and Air Conditioning	5

DIVISION 16 - ELECTRICAL

Section 16400	Service and Distribution	11
Section 16640	Cathodic Protection	15
Appendix A	Functional Test of Reference Electrodes	2

SECTION 02200

EARTHWORK

PART 1 - GENERAL

1.1 REFERENCES

1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.

1.1.1.1 American Society for Testing and Materials (ASTM)

D 653-90 Standard Terminology Relating to Soil, Rock, and Contained Fluids

1.1.1.2 Washington State Department of Transportation (WSDOT)

M 41-01-93 Construction Manual

M 41-10-94 Road, Bridge, and Municipal Construction

1.2 SUBMITTALS

1.2.1 See Section 01300 of W-030-G2 for submittal procedures.

1.2.2 Approval Required

1.2.2.1 Damage prevention procedure: Before excavation, submit a proposed procedure to prevent overstressing existing structures, or interrupting service to existing facilities.

1.2.3 Approval Not Required: None

PART 2 - PRODUCTS

2.1 MATERIALS

2.1.1 Obtain specified soils from excavation or other designated locations. Obtain onsite ICF KH approval for soils.

2.1.2 Fill or Backfill

2.1.2.1 Structural: Well graded soil mixtures which may contain cobbles up to 3 inches in greatest dimension if uniformly distributed and not constituting more than 20% of volume of fill.

2.1.2.2 Common: Well graded soil mixtures containing cobbles up to 8 inches in greatest dimension if uniformly distributed and not constituting more than 40% of volume of fill.

2.1.3 Stabilization: Crushed rock, with a maximum fragment size of 3/4-inch for walkways, and under 2 inches for other areas.

ECN-111

PART 3 - EXECUTION

3.1 EXCAVATION

- 3.1.1 Obtain an excavation permit before performing excavation. Excavation permits will be provided by ICF KH as specified in Section 01065 of W-030-G2. For additional requirements see Section 01110 of W-030-G2.
- 3.1.2 If cultural properties (eg, bones, artifacts) are encountered during excavation, stop work and notify ICF KH. ICF KH and the Hanford Cultural Resources Laboratory will assess the significance of the find.
- 3.1.3 Locate and expose underground utilities by hand tools. Use of heavy equipment and machinery requires approval by ICF KH.
- 3.1.4 Wherever slopes of excavations will intersect existing underground lines or structures such as building foundations, underground piping, electrical ducts or direct buried electrical lines, install shoring or other means of support to prevent overstressing existing structure or underground lines or to prevent interrupting service to existing buildings.
- 3.1.5 Footings and Foundations
 - 3.1.5.1 Make excavations for footings to depth shown on the Drawings or additional depth necessary to provide undisturbed surface to receive footing. Make excavations to proper width with allowances made for forms and bracing. Make bottom of excavations compact, level, true, and free of loose material.
 - 3.1.5.2 If over-excavation occurs where footings are designed to be placed on undisturbed earth, correct at time of placing concrete by extending concrete down to undisturbed earth, or by placement of backfill, compacted as specified in 3.2.1.2b, Method C.
- 3.1.6 In Situ Soils
 - 3.1.6.1 Salvage in situ stabilization material and reuse for backfilling and compacting. Contact ICF KH acceptability for backfill material, if required.
 - 3.1.6.2 In-place density tests will be conducted by ICF KH on in situ soils, using nuclear density gage, during excavation. Results of tests will be used by ICF KH for testing compaction of backfill.
 - 3.1.6.3 Excavated material containing concentrations of radioactive materials that can be detected by portable survey instruments normally used for performing radiation surveys is considered contaminated, and shall be sampled and analyzed for content.
 - 3.1.6.4 Excavated material containing radioactive contamination shall be packaged. ICF KH will dispose of the packaged, contaminated soil.

- 3.1.7 Where stabilization is required, finish subgrade 3 inches below elevations shown on the Drawings. Stabilize berm as shown on the Drawings.
- 3.2 PLACEMENT
- 3.2.1 Fill and Backfill
- 3.2.1.1 General:
- a. Backfill Permit: Do not start fill or backfill without an approved permit as required by Section 01065 of W-030-G2.
 - b. Remove debris and organic matter from the area to be filled or backfilled.
 - c. Use only specified materials for fill or backfill. Keep materials free of frozen particles, lumps, organic matter, and trash.
 - d. Do not place fill or backfill on frozen ground.
 - e. Filling or backfilling by sluicing or flooding with water will not be permitted.
 - f. Bring fill or backfill up evenly on sides of walls, structures, and utility lines to avoid unbalanced loading.
 - g. Do not place fill or backfill against concrete structure or foundation wall less than 14 days after completion of structure or wall unless written permission from ICF KH is obtained. Provide wall support, where noted on the Drawings, before filling or backfilling.
- 3.2.1.2 Compaction:
- a. Before placement of fill or backfill, demonstrate to ICF KH by physical test at the worksite, that the procedure proposed for placement and compaction of soils will provide the degree of compaction specified. Prepare "Soil Compaction Procedure," Form KEH-0382, in accordance with the instructions.
 - b. Place backfill in accordance with WSDOT M 41-10, Section 2-03.3(14)C and approved procedure as follows.
 - 1) Use Method C under foundations and slabs.
 - 2) Use Method B under pavements and roads, and within 5 feet of buildings, fences, other structures, or poles supporting electric lines or pipe.
 - 3) Use method specified in 3.2.1.3 to the height specified on the Project Drawings for the berm.
 - c. Compaction control tests will be in accordance with WSDOT M 41-10, Section 2-03.3(14)D.

3.2.1.3 Common:

- a. Place fill or backfill in layers not more than 12 inches thick, loose measurement.
- b. Compact each layer, full width, by at least 1 pass of vibratory or rammer type compactor, pneumatic-tired roller, loaded scraper wheel, grader wheel, or power roller.
- c. Mound over top layer of backfill to depth of 1 inch for each 12 inches of trench depth to maximum mound height of 6 inches.

3.2.1.4 In situ soils:

- a. Compact backfill by depositing soils in 8 inch layers and compacting to density equal to in situ density determined by tests made during excavation. Maintain uniformity of compaction throughout backfill.
- b. Do not use soils containing rocks larger than 3 inches in greatest dimension for compacted backfill.

3.2.2 Finish Grading and Stabilization

- 3.2.2.1 Rake areas disturbed by work, remove surface stones larger than 6 inches and dispose of excess material and debris at an area designated by ICF KH.
- 3.2.2.2 Stabilize areas disturbed by work with a 3-inch course of crushed rock specified in 2.1.3. Finish stabilization course to elevations shown on the Drawings.

3.3 FIELD QUALITY CONTROL

- 3.3.1 Soil Compaction Tests: Sampling and testing of compacted fill and backfill will be performed by ICF KH. Frequency of testing shall be in accordance with WSDOT M 41-01, page 9-52.

SOIL COMPACTION PROCEDURE

(KEH-382)

HNF-2532, Rev.0
Page 5

INSTRUCTIONS

(KEH-382R)

END OF SECTION

SECTION 02225

EXCAVATING, BACKFILLING, AND COMPACTING FOR UTILITIES

PART 1 - GENERAL

1.1 REFERENCES

1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.

1.1.1.1 American Society for Testing and Materials (ASTM)

D 653-90

Standard Terminology Relating to Soil,
Rock, and Contained Fluids

1.1.1.2 Washington State Department of Transportation (WSDOT)

M 41-01-93

Construction Manual

M 41-10-94

Road, Bridge, and Municipal
Construction

1.2 SUBMITTALS

1.2.1 See Section 01300 of W-030-G2 for submittal procedures.

1.2.2 Approval Required

1.2.2.1 Damage prevention procedure: Before excavation, submit a proposed procedure to prevent overstressing existing structures, or interrupting service to existing facilities.

1.2.3 Approval Not Required: None

PART 2 - PRODUCTS

2.1 MATERIALS

2.1.1 Obtain specified soils from excavation or other designated locations. Obtain onsite ICF KH approval for soils.

2.1.2 Fill or Backfill

2.1.2.1 Structural: Well graded soil mixtures which may contain cobbles up to 3 inches in greatest dimension if uniformly distributed and not constituting more than 20% of volume of fill.

2.1.2.2 Common: Well graded soil mixtures containing cobbles up to 8 inches in greatest dimension if uniformly distributed and not constituting more than 40% of volume of fill.

- 2.1.3 Bedding for Underground Pipe, Conduit, Cable, and Culvert: Sand as defined in ASTM D 653, or excavated sandy material having less than 20% gravel particles, with those particles having a maximum dimension of 1/2-inch.
- 2.1.4 Stabilization: Crushed rock, with a maximum fragment size of 3/4-inch for walkways, and under 2 inches for other areas. ECN-111
- 2.1.5 ~~Plastic Sheet Marker: 6 inch wide nonductile tape imprinted with a warning, such as "CAUTION - BURIED INSTALLATION BELOW", at intervals of 4 feet maximum; Reef Industries "Terra Tape."~~ ECN-178
ECN-178
- 2.1.5 Plastic Sheet Marker: 2-inch wide, minimum, detectable tape imprinted with a warning, such as "CAUTION - BURIED WATER LINE BELOW" OR "CAUTION - BURIED PIPELINE BELOW" at intervals of 4 feet maximum; Seton Identification Products, or approved substitute. ECN-178
ECN-178

PART 3 - EXECUTION

3.1 EXCAVATION

- 3.1.1 Obtain an excavation permit before performing excavation. Excavation permits will be provided by ICF KH as specified in Section 01065 of W-030-G2. For additional requirements see Section 01110 of W-030-G2.
- 3.1.2 If cultural properties (eg, bones, artifacts) are encountered during excavation, stop work and notify ICF KH. ICF KH and the Hanford Cultural Resources Laboratory will assess the significance of the find.
- 3.1.3 Locate and expose underground utilities by hand tools. Use of heavy equipment and machinery requires approval by ICF KH.
- 3.1.4 Where slopes of excavations will intersect existing underground lines or structures such as building foundations, underground piping, electrical ducts or direct buried electrical lines, install shoring or other means of support to prevent overstressing existing structures or underground lines or prevent interrupting service to existing buildings.
- 3.1.5 Make excavations to line and grade shown on the Drawings and wide enough to make connections. Excavate with near vertical sides from bottom of trench up to 1 foot above pipe, conduit, cable, and culvert. Excavate trench deep enough to permit placement of compacted bedding, 4 inches minimum thickness, beneath pipe, conduit, cable, and culvert except where excavation is in undisturbed sand which will serve as bedding or where lines are to be encased in concrete. Pare holes in trench bottoms for pipe couplings so pipe will bear full length of barrel or section. Excavate Trench for Transfer Lines deep enough for 6 inches of compacted bedding.
- 3.1.6 Install shoring to hold materials and surcharge pressure for full depth of trench.
- 3.1.7 Keep trenches free of standing water when laying is in progress.

3.1.8

If over-excavation occurs, correct by placement of structural backfill.

3.1.9 In Situ Soils

- 3.1.9.1 Salvage in-situ stabilization material and reuse for backfilling and compacting. Do not use or reuse contaminated material. Contact ICF KH for backfill material, if required.
- 3.1.9.2 In-place density tests will be conducted by ICF KH on in-situ soils, using nuclear density gage, during excavation. Results of tests will be used by ICF KH for testing compaction of backfill.
- 3.1.9.3 Excavated material containing concentrations of radioactive materials that can be detected by portable survey instruments normally used for performing radiation surveys is considered contaminated, and shall be sampled and analyzed for content.
- 3.1.9.4 Excavated material containing radioactive contamination shall be packaged. ICF KH will dispose of the packaged, contaminated soil.
- 3.1.10 Where stabilization is required, finish subgrade 3 inches below elevations shown on the Drawings.

3.2 PLACEMENT

3.2.1 Fill and Backfill

3.2.1.1 General:

- a. Backfill Permit: Do not start fill or backfill without an approved permit as required by Section 01065 of W-030-G2.
- b. Remove debris and organic matter from the area to be filled or backfilled.
- c. Use only select materials for fill or backfill. Keep materials free of frozen particles, lumps, organic matter, and trash.
- d. Do not place fill or backfill on frozen ground.
- e. Filling or backfilling by sluicing or flooding with water will not be permitted.
- f. Bring fill or backfill up evenly on sides of walls, structures, and utility lines to avoid unbalanced loading.
- g. Backfill the Transfer Line Trench by pushing material parallel to the trench; not by side filling. Backfilling from the side is permissible after the ICF KH has demonstrated that a sufficient depth of backfill has been placed to prevent lateral pipe movement, and damage.

3.2.1.2 Compaction:

- a. Before placement of fill or backfill, demonstrate to ICF KH by physical test at the worksite, that the procedure proposed for placement and compaction of soils will provide the degree of compaction specified.

Prepare "Soil Compaction Procedure", Form KEH-0382, in accordance with the instructions.

b. Place backfill in accordance with WSDOT M 41-10, Section 2-03.3(14)C and approved procedure as follows.

1) Use Method C under pipelines.

2) Use Method B within 5 feet of buildings, fences, other structures, or poles supporting electric lines or pipes.

c. Compaction control tests will be in accordance with WSDOT M 41-10, Section 2-03.3(14)D.

3.2.1.3 Common:

a. Place fill or backfill in layers not more than 12 inches thick, loose measurement.

b. Compact each layer, full width, by at least 1 pass of vibratory or rammer type compactor, pneumatic-tired roller, loaded scraper wheel, grader wheel, or power roller.

c. Mound over top layer of backfill to depth of 1 inch for each 12 inches of trench depth to maximum mound height of 6 inches.

3.2.1.4 Underground piping, conduit, cable, and culvert trenches:

a. Bedding placed beneath pipe, conduit, cable, and culvert in trenches shall be material specified in 2.1.3. ~~Place an additional 6 inches of bedding above Transfer Lines.~~

ECN-111
ECN-111

b. Place and compact bedding in trench prepared as specified in 3.1.5 before laying pipes, conduits, cables, and culverts. Compact bedding as specified for structural backfill. Compact bedding and backfill materials of Transfer Lines to 98% 95% of WSDOT 46-01, Section 600, Test Method 606. Do not compact within 5 feet of any buried utility of unknown type or any utility which may be susceptible to damage from compaction efforts. This pertains primarily to process lines, identified on the Drawings.

ECN-111

c. Place backfill over joints in underground pipes only after pressure testing of line has been completed.

d. Backfill under conduit and haunches of pipe, around sides, and up to 1 foot above top of pipe, conduit, cable, and culvert using bedding material specified in 2.1.3. Place and compact material same as specified for structural backfill. Compact with care, to avoid misalignment of pipe and provide uniform bearing along barrel of pipe.

ECN-111

e. Backfill trenches from elevation 1 foot above top of pipe, conduit, cable, and culvert as follows.

- 1) Use structural fill or backfill in locations specified in 3.2.1.2.
- 2) Use common fill or backfill as specified in 3.2.1.3 for other locations.

f. Do not allow heavy construction equipment to pass over buried lines until at least 2 feet of backfill has been placed over the line or until bridging has been placed across trenching and approved by ICF KH.

3.2.1.5 In situ soils:

a. Compact backfill by depositing soils in 8 inch layers and compacting to density equal to in-situ density determined by tests made during excavation. Maintain uniformity of compaction throughout backfill.

b. Do not use soils containing rocks larger than 3 inches in greatest dimension for compacted backfill.

3.2.2 Plastic Sheet Marker: Place continuously and directly over buried utility lines, 1 foot below finish grade. Place markers over each outside line of multiple lines, if spacing permits. Place intermediate markers spaced 4 feet maximum.

3.3 FIELD QUALITY CONTROL

3.3.1 Soil Compaction Tests: Sampling and testing of compacted fill and backfill will be performed by ICF KH. Frequency of testing shall be in accordance with WSDOT M 41-01, page 9-52.

SOIL COMPACTION PROCEDURE

(KEH-382)

HNF-2532, Rev.0

Page 13

INSTRUCTIONS

(KEH-382R)

END OF SECTION

SECTION 02235

ROAD SUBGRADE AND GRANULAR BASE

PART 1 - GENERAL

1.1 REFERENCES

1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.

1.1.1.1 Washington State Department of Transportation (WSDOT)

M 41-01-93 Construction Manual

M 41-10-94 Road, Bridge, and Municipal
Construction

1.2 SUBMITTALS: Not Used

PART 2 - PRODUCTS

2.1 MATERIALS

2.1.1 Subgrade Fill and Backfill

2.1.1.1 Obtain specified soils from excavation or other designated locations. Obtain onsite ICF KH approval for soils.

2.1.1.2 Fill or backfill: Well graded soil mixtures which may contain cobbles up to 3 inches in greatest dimension if uniformly distributed and not constituting more than 20% of volume of fill.

2.1.2 Granular Base

2.1.2.1 Base course: WSDOT M 41-10, Section 9-03.9(3), Base Course Classification.

2.1.2.2 Leveling course: WSDOT M 41-10, Section 9-03.9(3), Top Course Classification.

2.1.2.3 Crushed gravel shoulder: Same as leveling course.

PART 3 - EXECUTION

3.1 EXCAVATION

3.1.1 Before performing excavation, obtain an excavation permit. Excavation permits will be provided by ICF KH in accordance with Section 01065 of W-030-G2.

3.1.2 If cultural properties (eg, bones, artifacts) are encountered during excavation, stop work and notify ICF KH. ICF KH and the Hanford Cultural Resources Laboratory will assess the significance of the find.

- 3.1.3 If over-excavation occurs, correct by placement of backfill.
- 3.2 PLACEMENT
 - 3.2.1 Subgrade Filling and Backfilling
 - 3.2.1.1 Remove debris and organic matter from area to be filled or backfilled.
 - 3.2.1.2 Use only specified materials for fill or backfill. Keep materials free of frozen particles, lumps, organic matter and trash.
 - 3.2.1.3 Do not place fill or backfill on frozen ground.
 - 3.2.1.4 Filling or backfilling by sluicing or flooding with water will not be permitted.
 - 3.2.2 Fill or Backfill
 - 3.2.2.1 Before placement of fill or backfill, demonstrate to ICF KH by physical test at the worksite, that the procedure proposed for placement and compaction of soils will provide the degree of compaction specified. Prepare "Soil Compaction Procedure" Form KEH-0382, in accordance with the instructions.
 - 3.2.2.2 Place backfill under roads in accordance with WSDOT M 41-10, Section 2-03.3(14)C, Method B and approved procedure.
 - 3.2.3 Granular Base
 - 3.2.3.1 Before placement of granular base, demonstrate to ICF KH by physical test at the worksite, that the procedure proposed for placement and compaction of base will provide the degree of compaction specified. Prepare "Soil Compaction Procedure" Form KEH-0382, in accordance with the instructions.
 - 3.2.3.2 Construction Requirements: Construction shall be in accordance with following sections of WSDOT M 41-10.
 - a. Subgrade: Section 2-06.3.
 - b. Equipment: Section 4-04.3(1).
 - c. Mixing: Section 4-04.3(3).
 - d. Placing and spreading: Section 4-04.3(4).
 - e. Miscellaneous requirements: Section 4-04.3(7).
 - f. Weather limitations: Section 4-04.3(8).
 - g. Hauling: Section 4-04.3(9).

3.2.3.3 Shaping and Compacting:

- a. Final shaping before compacting shall be accomplished using approved equipment.
- b. Compaction control tests will be in accordance with WSDOT M 41-10, Section 2-03.3(14)D.

3.2.3.4 Shoulders: Construct shoulders, of width shown on the Drawings, after placement of asphaltic wearing course.

3.2.4 Finish Grading and Stabilization: Rake area disturbed by work, remove surface stones larger than 6 inches and dispose of excess material and debris at area designated by ICF KH.

3.3 FIELD QUALITY CONTROL

3.3.1 Sampling and testing of compacted fill and backfill will be performed by ICF KH. Frequency of testing shall be in accordance with WSDOT M 41-01, page 9-52.

SOIL COMPACTION PROCEDURE
(KEH-382)

INSTRUCTIONS

(KEH-382R)

END OF SECTION

SECTION 02512

HOT-LAID ASPHALTIC CONCRETE PAVING

PART 1 - GENERAL

1.1 REFERENCES

1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.

1.1.1.1 American National Standards Institute (ANSI)

D6.1-1988

Manual on Uniform Traffic
Control Devices for Streets and
Highways

1.1.1.2 Washington State Department of Transportation (WSDOT)

M 41-10-94

Road, Bridge, and Municipal
Construction

1.2 SUBMITTALS

1.2.1 See Section 01300 of W-030-G2 for submittal procedures.

1.2.2 Approval Required

1.2.2.1 Laboratory reports: Before delivery, submit laboratory test reports for the following.

a. Asphalt: Show that asphalt used meets the requirements of AR-4000W in accordance with WSDOT M 41-10, Section 9-02.1(4).

b. Aggregate: Show that aggregate used meets the requirements of Sections 9-03.8(2) and 9-03.8(6). Include rice density as established by WSDOT M 41-10, Method 705.

1.2.3 Approval Not Required: None

PART 2 - PRODUCTS

2.1 MATERIALS

2.1.1 Asphalt: In accordance with WSDOT M 41-10, Sections 9-02.1(2) and 9-02.1(4). Grade of paving asphalt for use in asphaltic concrete mixture shall be AR-4000W. Grade of liquid asphalt for prime coat shall be MC-250.

2.1.2 Aggregate: Class "B" in accordance with WSDOT M 41-10, Section 9-03.8(1), (2), and (3)B.

2.1.3 Blending Sand: In accordance with WSDOT M 41-10, Section 9-03.8(4).

2.1.4 Mineral Filler: In accordance with WSDOT M 41-10, Section 9-03.8(5). Page 21

2.2 MIXES

2.2.1 Proportioning of Asphalt Concrete Materials: In accordance with WSDOT M 41-10, Section 9-03.8(6) Class "B" asphalt concrete.

PART 3 - EXECUTION

3.1 APPLICATION

3.1.1 Perform work in accordance with the following sections of WSDOT M 41-10.

3.1.1.1 Asphalt mixing plants: Section 5-04.3(1).

3.1.1.2 Hauling equipment: Section 5-04.3(2).

3.1.1.3 Asphalt pavers: Section 5-04.3(3).

3.1.1.4 Rollers: Section 5-04.3(4).

3.1.1.5 Existing surface conditioning: Section 5-04.3(5).

3.1.1.6 Asphalt material heating: Section 5-04.3(6).

3.1.1.7 Aggregate preparation: Section 5-04.3(7).

3.1.1.8 Mixing: Section 5-04.3(8).

3.1.1.9 Spreading and finishing: Section 5-04.3(9).

3.1.1.10 Compaction: Section 5-04.3(10).

3.1.1.11 Joints: Section 5-04.3(11).

3.1.1.12 Samples: Section 5-04.3(12).

3.1.1.13 Surface smoothness: Section 5-04.3(13).

3.1.1.14 Heating-planing bituminous pavement: Section 5-04.3(14).

3.1.1.15 Weather limitations: Section 5-04.3(16).

3.1.1.16 Asphalt change in grade: Section 5-04.3(18).

3.1.1.17 Driving surface sealing: Section 5-04.3(19).

3.1.2 Permanent Signing: In accordance with ANSI D6.1, Section II and WSDOT M 41-10, Section 8-21.

3.1.3 Pavement Marking: In accordance with ANSI D6.1, Section III and WSDOT M 41-10, Section 8-22.

3.2 FIELD QUALITY CONTROL

3.2.1 Sampling and testing of pavement will be performed by ICF KH. Frequency of sampling shall be in accordance with WSDOT M 41-01, page 9-52.

3.3 PROTECTION

3.3.1 Traffic Control: Institute and maintain in accordance with WSDOT M 41-10, Section 1-07.23, Subsections (1) through (4).

END OF SECTION.

SECTION 02513

ECN-701

COLD-LAID ASPHALTIC CONCRETE PAVING

PART 1 - GENERAL

1.1 REFERENCES

1.1.1 The following documents and other referenced therein form part of Contract to extent designated this Section.

1.1.1.1 American National Standards Institute (ANSI)

D6.1-1998

Manual on Uniform Traffic
Control Devices for Streets
and Highways

1.1.1.2 American Society for Testing and Materials (ASTM)

D 4318-93

Test Method for Liquid Limit,
Plastic Limit, and Plasticity
Index of Soils

1.1.1.3 Fluor Daniel Northwest (FDNW) TWRS Project Procedures Manual
(PPM)

Section 2.10

Technical Document Control

1.1.1.4 Washington State Department of Transportation (WSDOT)

M 41-10-94

Road, Bridge, and Municipal
Construction

1.2 SUBMITTALS

1.2.1 See FDNW PPM Section 2.10 for submittal procedures.

1.2.2 Approval Required

1.2.2.1 Asphalt mix certification: Before mixing, submit certification that asphalt mix is in accordance with WSDOT M 41-10 for each car load or other lot of asphalt at time of delivery.

1.2.3 Approval Not Required: None

1.3 SITE CONDITIONS

1.3.1 Install asphaltic mixture only when weather is clearing or fair. Ensure that surface receiving asphaltic mixture is 50 °F or greater.

PART 2 - PRODUCTS

2.1 MATERIALS

ECN-701

- 2.1.1 Aggregate: WSDOT M 41-10, Section 9-03.8. Ensure that at least 50% contains fractured face. Grade aggregate as follows.

<u>Sieve</u>	<u>Percentage by Weight Passing Sieves</u>
5/8 inch square openings	100
1/2 inch square opening	90-100
1/4 inch square opening	55-75
US No. 10	32-48
US No. 200	3-7
Asphalt	2.5-5.5

- 2.1.2 Asphalt: WSDOT M 41-10. Section 9-02.1(2). MC-250.

- 2.1.3 Binder

- 2.1.3.1 Use silica sand or crushed stone. Ensure the following gradation.

<u>Sieve</u>	<u>Percentage by Weight Passing Sieves</u>
3/8 inch square openings	100
1/4 inch square opening	90-100
US No. 200	10-15

- 2.1.3.2 Portion passing US No. 40 sieve shall have liquid limit of 30 or less and plasticity index of 3 or less when tested in accordance with ASTM D 4318.

- 2.2 MIXES

- 2.2.1 Proportioning: Contractor shall proportion asphaltic mixture.

- 2.2.2 Preparation of Material

- 2.2.2.1 Before proportioning materials, heat aggregate to temperature of 175 to 275 °F. Use rotary heater or drier. Ensure that heater or drier is equipped with fan and dust collector for excess dust removal.

- 2.2.2.2 Heat asphalt to temperature of 93 to 116 °C (200 to 240 °F). Use insulated tank, kettle, or sump. Ensure that tank, kettle, or sump is designed to provide controlled, uniform heating. Prevent flame from coming into contact with tank, kettle, or sump.

- 2.2.3 Mixing

- 2.2.3.1 Mix in pug mill.

- 2.2.3.2 Place hot aggregate in mixer. After placement of aggregate, add hot asphalt and mix for 30 seconds or as much longer as necessary to produce blended mixture.
- 2.2.3.3 Maintain batch weight within mixer's rated capacity.
- 2.2.4 Hauling and Stockpiling
 - 2.2.4.1 Use dump trucks for hauling. Before loading mixture, lubricate sides and bottoms of trucks with mixture of water and either light oil or diesel oil. Ensure that truck is free of excess water and oil.
 - 2.2.4.2 Clear stockpile sites of vegetation, trees, brush, rocks, and other debris. Make uniform ground surface before depositing material.

PART 3 - EXECUTION

3.1 PREPARATION

- 3.1.1 Sweep asphaltic surfaces which will receive mixture. Remove loose materials from holes and raveled areas. Cut back overhanging and irregular edges to stable material to form straight lines.
 - 3.1.1.2 Backfill trenches and large holes extending through pavement to base and leveling courses. Use backfill material which is equal to existing construction. Compact backfill materials to density equal to adjacent, undisturbed material as determined by Construction Engineer.
 - 3.1.1.3 Add water to secure compaction. Leave allowance for placement of asphaltic mixture equal to existing surface depth, or 2 inches, whichever is greater.
 - 3.1.1.4 Before application, obtain approval of compaction.

3.2 APPLICATION

- 3.2.1 Asphalt Mix
 - 3.1.2.1 Spread mixture by motor grader or spreader box of design approved by Construction Engineer.
 - 3.1.2.2 Ensure that mixture is in plastic, workable condition when applied to repair area.
 - 3.1.2.3 Where segregation of larger pieces of aggregate occurs on surface, correct after first rolling of pavement.
 - 3.1.2.4 Use hand methods to install and finish areas which are inaccessible to grader or spreader box.

3.1.2.5 Compaction:

- a. Immediately the following spreading, compact by rolling with 3-wheeled or tandem power roller weighing at least 8 tons. Compression wheels on 3-wheeled rollers shall be at least 20 inches wide and be shaped or set so rolling surfaces conform with crown specified for finished pavement. Start rolling at edges and proceed toward center of pavement. Overlap on successive trips by 1/2 to 3/4 width of 3-wheel roller near wheel. Alternate trips of roller shall be slightly different lengths. Continue rolling until roller marks are eliminated. Roll pavement diagonally in at least 1 direction with tandem roller of sizes described above.
- b. Roll areas not accessible to roller of sizes specified in this Section with smaller power roller having weight on rear wheel(s) of at least 175 lb/in² of roller width. Roll as specified above except that diagonal rolling may be omitted where impracticable.
- c. Rollers shall be capable of reversing without backlash and kept in continuous motion, as nearly as practicable, so all parts of pavement receive equal compression. Rollers shall not be left standing on freshly rolled asphaltic mixture.
- d. Surface of mixture after compression shall be smooth and true to establish section and grade. Mixture showing excess or deficiency of cement, or uneven distribution of cement due to insufficient mixing, or becomes mixed with dirt or defective, shall be removed and replaced with fresh mixture, and immediately compacted to conform with adjacent surfacing. Compact areas inaccessible to rollers by tamping with iron tampers.
- e. Complete rolling of mixture before dark, therefore deposit no mixture on roadway that cannot be rolled before dark.
- f. When required by Construction Engineer, backroll previous day's work.

3.1.2.6 Surface smoothness:

- a. Surface of finished wearing course shall be of uniform texture, smooth, true to crown and grade, and free of defects, and shall blend smoothly into existing surface. Maximum deviation of surface when tested with 10-foot straight edge parallel to centerline of roadway, shall not exceed 1/4 inch. No portion of finished pavement shall be more than 1/4 inch below template cut to crown of existing surfacing, or cross-section drawings showing required corrections, placed on course at right angles to centerline.

- b. Deviations in excess of tolerances shall be corrected by addition or removal of asphaltic material and rolling or tamping.

3.1.3 Road Shoulders: If roadway repair raises pavement edge, add shoulder material to restor shoulders flush with pavement edge. Slope shoulders to match existing shoulder slope and compact shoulders to firm, unyielding surface.

3.3 PROTECTION

3.3.1 When ordered by Construction Engineer, erect suitable signs and barricades meeting requirements of ANSI D6.1 Part VI. Maintain signs and barricades in place until material has set sufficiently to allow traffic. Obtain approval of Construction Engineer before removing signs and barricades.

END OF SECTION

ECN-701

SECTION 02650
PIPED UTILITIES

PART 1 - GENERAL

1.1 REFERENCES

1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.

1.1.1.1 American National Standards Institute (ANSI)

Z535.1-1991 Safety Color Code for Marking Physical Hazards

1.1.1.2 American Water Works Association (AWWA)

~~C203-91 Coal Tar Protective Coatings and Linings for Steel Water Pipelines~~ ECN-133
~~Enamel and Tape Hot Applied~~ ECN-133

C209-84 Cold-Applied Tape Coating for the Exterior of Special Sections, Connections, and Fittings for Steel Water Pipelines ECN-133
ECN-133

C500-86 Gate Valves for Water and Sewerage Systems

C600-87 Installation of Ductile-Iron Water Mains and Appurtenances

1.1.1.3 Federal Specifications (FS)

TT-E-489H Enamel, Alkyd, Gloss, Low VOC Content

TT-P-645B Primer, Paint, Zinc-Molybdate Alkyd Type

1.1.1.4 International Association of Plumbing and Mechanical Officials (IAPMO)

UPC Uniform Plumbing Code

1.1.1.5 Steel Structures Painting Council (SSPC)

SP 3-91 Power Tool Cleaning

SP 6-85 Commercial Blast Cleaning ECN-133

1.2 SUBMITTALS

1.2.1 See Section 01300 of W-030-G2 for submittal procedures.

1.2.2 Approval Required

1.2.2.1 Leak/Pressure test procedures: Before testing, submit procedures outlining proposed methods of testing joints in piping systems.

1.2.3 Approval Not Required: None

1.3 QUALITY ASSURANCE

1.3.1 Misrepresented Products: See Section 01400 of W-030-G2 for required measures to prevent the use of misrepresented products.

1.3.2 Deliverable Documentation: See Section 15493.

1.4 DELIVERY, STORAGE, AND HANDLING

1.4.1 See Section 01610 of W-030-G2 for general requirements.

PART 2 - PRODUCTS

2.1 SUBSTITUTES

2.1.1 See Section 01630 of W-030-G2 for substitution approvals.

2.2 MATERIALS

2.2.1 ~~Pipe and Fittings: See Section 15493. Pipe and Fittings:~~
~~See Pipe Code M-5, Section 15493 and details on drawings.~~

ECN-133
ECN-133

2.2.1.1 *Coating for carbon steel piping exposed to earth backfill: Meet or exceed the requirements of AWWA C209 exterior protective coating, consisting of cold-applied primer and Type III prefabricated tape.*

ECN-133
ECN-133

2.2.2 Post Indicator Valve (PIV)

2.2.2.1 ~~Gate Valve: AWWA C500, nonrising stem, with indicator post gland, iron body, 0 ring seals, 175 lb/in² minimum cold water working pressure, 350 lb/in² minimum hydraulic test pressure. Tapping Valve: AWWA C500, flange by flange, resilient wedge, nonrising stem, with indicator post gland, iron body, 0-ring seals, 175 lb/in² minimum cold water working pressure, 350 lb/in² minimum hydraulic test pressure.~~

ECN-108
ECN-108

2.2.2.2 Indicator post: Adjustable, telescoping barrel type with locking handle and clearly visible, position indicator sign plates, protected by nonbreakable plastic windows. Post shall be matched for assembly to gate valve.

2.2.2.3 Valve position supervisory limit switch for installation on post indicator valve: Tamperproof and designed for use intended. Switch shall be operated during first 2 revolutions of handle in closing direction.

2.2.2.4 Tapping Sleeve: 12 by 4 inch epoxy coated steel, Mueller No. H-616.

2.2.3 Pipe Joint Sealant for Threaded Joints: Pipe compound with Teflon by Bostik Manufacturing, part No. NPBT-8.

2.2.4 Exterior Protective Coating: AWWA C209 9.

ECN-133

2.2.5 Primer: FS TT-P-645; National Lead No. 200-41.

2.2.6 Paint: FS TT-E-489, Class A, Composition G. Colors in accordance with ANSI Z535.1

PART 3 - EXECUTION

3.1 INSTALLATION

3.1.1 General

3.1.1.1 Install piping and piping accessories in accordance with the IAPMO UPC, the Pipe Codes, the Drawings, and this Section.

3.1.1.2 Keep piping systems clean during work. Once fabrication has started on length of pipe, plug or cap open ends when installation is not in progress.

3.1.1.3 Where piping is laid in trench, trench shall be free of frost or frozen earth and standing water.

3.1.2 Carbon Steel Pipe

3.1.2.1 After cutting, ream pipe to nominal inside diameter. Remove burrs from mating threads in threaded piping before assembly.

3.1.2.2 Close or butt nipples are not permitted.

3.1.2.3 Make joints in threaded piping systems with specified joint sealant. Apply sealant to male threads only.

3.1.3 ~~Exterior Protective Coating: See Section 15493.~~ Exterior Protective Coating:

ECN-133

ECN-133

3.1.3.1 Prepare carbon steel surfaces by sandblasting in accordance with SSPC SP 6. Where blasting is impracticable, as determined by the Construction Engineer, clean by power wire brushing in accordance with SSPC SP 3.

ECN-133

ECN-133

3.1.3.2 Apply exterior protective coating consisting of cold-applied primer and prefabricated tape to joints, fittings, and lengths of carbon steel pipe which will be buried in accordance with AWWA C209 and manufacturer's instructions.

ECN-133

ECN-133

3.1.3.3 After application, test field-applied exterior protective coating materials.

ECN-133

a. Use electric holiday detector in accordance with AWWA C209, Section 4.4.2.

b. Repair damage to coating such as missed places of holidays in accordance with AWWA C209, Section 3.4.

ECN-133

3.1.4 Install PIV in accordance with AWWA C600, the Drawings, and this Section.

3.1.5 Install post barricades around post indicator valve in accordance with the Drawing and this Section.

3.1.6 Painting and Marking

3.1.6.1 Surface preparation of materials receiving paint shall be in accordance with SSPC-SP3.

3.1.6.2 Paint upper barrel of indicator post with 1 coat of primer and 2 coats of yellow enamel.

3.1.6.3 Paint entire length of each barricade post with primer and above grade portion with 2 coats of yellow enamel.

3.1.6.4 Color: In accordance with ANSI Z53.1.

3.1.6.5 Painting of instrument air line stub-ups will be done by others.

3.2 FIELD QUALITY CONTROL

3.2.1 Flushing: See Section 15493.

3.2.2 Hydrostatic Pressure Testing: See Section 15493.

END OF SECTION

SECTION 02720

STORM SEWERAGE

PART 1 - GENERAL

1.1 REFERENCES

1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.

1.1.1.1 Washington State Department of Transportation (WSDOT)

M 41-10-94 Road, Bridge, and Municipal Construction

1.2 SUBMITTALS: Not Used

PART 2 - PRODUCTS

2.1 MATERIALS

2.1.1 Culvert Pipe: WSDOT M 41-10, Section 9-05.4, steel pipe and arch.

2.1.2 Drainage Structures

2.1.2.1 Precast concrete catch basins: WSDOT M 41-10, Section 9-12.5.

PART 3 - EXECUTION

3.1 INSTALLATION

3.1.1 Culverts

3.1.1.1 Placing steel: In accordance with WSDOT M 41-10, Section 7-02.3(1)B.

3.1.2 Drainage Structures

3.1.2.1 Inlets and catch basins in accordance with WSDOT M 41-10, Section 7-05.3.

3.1.2.2 Adjust catch basins to grade in accordance with WSDOT M 41-10, Section 7-05.3(1).

END OF SECTION

SECTION 03300
CAST-IN-PLACE CONCRETE

PART 1 - GENERAL

1.1 REFERENCES

1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.

1.1.1.1 American Concrete Institute (ACI)

117-90	Tolerances for Concrete Construction and Materials
301-89	Structural Concrete for Buildings
306.1-90	Cold Weather Concreting
318-89 (Revised 1992)	Building Code Requirements for Reinforced Concrete
SP-66-88	ACI Detailing Manual

1.1.1.2 American Society for Testing and Materials (ASTM)

A 615-92b	Deformed and Plain Billet-Steel Bars for Concrete Reinforcement
A 853-91	Steel Wire, Carbon, for General Use
C 33-92a	Concrete Aggregates
C 94-92a	Ready-Mixed Concrete
C 150-92	Portland Cement
C 260-86	Air-Entraining Admixtures for Concrete
C 1107-91a	Packaged Dry, Hydraulic-Cement Grout (Nonshrink)
D 994-71 (1982)	Preformed Expansion Joint Filler for Concrete (Bituminous Type)

1.1.1.3 Code of Federal Regulations (CFR)

Title 40	Protection of Environment
Part 249	Guideline for Federal Procurement of Cement and Concrete Containing Fly Ash

1.1.1.4 Federal Specifications (FS)

SS-SS-1996

Sealer, Water and Weather Resistant for Asphalt, Concrete and Masonry Surfaces

1.1.1.5 National Ready Mixed Concrete Association (NRMCA)

Certificate of Conformance for Concrete Production Facilities

Certification of Ready Mixed Concrete Production Facilities

1.1.1.6 Washington State Department of Transportation (WSDOT)

M 41-10-94

Road, Bridge, and Municipal Construction

1.2 SUBMITTALS

1.2.1 See Section 01300 of W-030-G2 for submittal procedures.

1.2.2 Approval Required

1.2.2.1 Formwork: Before installation, submit fabrication drawings in accordance with ACI 301, Sections 4.1 and 4.2. Formwork design and details shall meet the requirements of ACI 301, Chapter 4.

~~1.2.2.2 Block Diagram: Before installation of forms, submit block diagram of scheduled concrete pours. Identify pours.~~

ECN-389

ECN-389

~~1.2.2.3 2 Certified Material Test Reports: Before delivery, submit manufacturer's certified test reports showing chemical analysis and physical tests made on the particular heat or heats of steel from which reinforcement was manufactured. Furnish separate certificates for each group of items furnished by each supplier.~~

ECN-084

ECN-084

~~1.2.2.4 Drawings: Before delivery, submit complete reinforcing steel fabrication and installation drawings based on the block diagram, in accordance with ACI 301, Section 5.1, including splices not shown on the Drawings. Reinforcement details shall comply with ACI 318 and SP-66.~~

ECN-389

ECN-389

1.2.2.53 2 Facility Certification: Before mixing, submit a current legible copy of the NRMCA "Certificate of Conformance for Concrete Production Facilities." The Certificate shall be validated by the signature and seal of a registered Civil Engineer, and the signature of the principal company executive.

ECN-84

1.2.2.64 3 Concrete Data: Before mixing, submit concrete materials, mix design, and mix proportions, in accordance with ACI 301, Sections 3.8 and 16.7.3. Identify each material to be used in concrete, including the amount, by weight, to be utilized in each yd³ of plastic mix.

ECN-84

1.2.2.75 4 Curing Procedure: Before mixing, submit a description of materials and methods of curing, in accordance with ACI 301, Section 12.2.

ECN-84

1.2.2.86 5 Cold Weather Concreting: Before placement, submit the procedure specified in 3.2.2.5, if concrete will be placed during cold weather. If it will not, submit a statement to that effect. ECN-84

1.2.2.97 6 Hot Weather Concreting: Before placement, submit the procedure specified in 3.2.2.5, if concrete will be placed during hot weather. If it will not, submit a statement to that effect. ECN-84

1.2.3 Approval Not Required: *None* ECN-84

~~1.2.3.1 Curing Procedure: Before mixing, submit a description of materials and methods of curing, in accordance with ACI 301, Section 12.2.~~ ECN-84
ECN-84

1.3 QUALITY ASSURANCE

1.3.1 Contractor's Quality Assurance Program: See Section 01400 of W-030-G2.

1.3.2 Misrepresented Products: See Section 01400 of W-030-G2 for required measures to prevent the use of misrepresented products.

1.3.3 Deliverable Documentation: The following documents and records, required by this Section, shall be delivered to ICF KH in accordance with Section 01720 of W-030-G2.

Document

Paragraph

Pour Slip and Trip Tickets

3.2.2.2

1.4 DELIVERY, STORAGE, AND HANDLING

1.4.1 See Section 01610 of W-030-G2 for general requirements.

PART 2 - PRODUCTS

2.1 SUBSTITUTES

2.1.1 See Section 01630 of W-030-G2 for substitution approvals.

2.2 MATERIALS

2.2.1 Concrete

2.2.1.1 Cement: ASTM C 150, Type II (low alkali). Fly Ash content is allowable in accordance with the recommendations of 40 CFR 249.12 and 249.13.

2.2.1.2 Aggregates: ASTM C 33, 3/4 inch maximum size.

2.2.1.3 Air-entraining admixture: ASTM C 260; Sika Chemical Company "SIKA AER", Chem-Masters Corporation "Adz-Air", or Protex Industries "AES."

2.2.1.4 Properties:

a. Minimum allowable compressive strength: 4000 lb/in² at 28 days.

- b. Slump: 4 inches in accordance with ACI 301, Section 3.5.
 - c. Air content: In accordance with ACI 301, Table 3.4.1.
 - d. Proportions: In accordance with ACI 301, Sections 3.8 and 3.9.
- 2.2.1.5 Mixing: In accordance with ASTM C 94.
 - 2.2.1.6 Delivery: In accordance with ASTM C 94.
 - 2.2.2 Reinforcing Steel
 - 2.2.2.1 Steel bars: ASTM A 615, deformed, Grade 60.
 - 2.2.2.2 Tie wire: ASTM A 853 carbon steel, 0.062-inch (16-gage) minimum, annealed.
 - 2.2.3 Joint Materials
 - 2.2.3.1 Epoxy resin: In accordance with WSDOT M 41-10, Section 9-26, Type II, Grade 2, Class B or C; QCM Company EASB Class A, Adhesive Engineering "Concresive 1001 LPL," or Protex Industries "Probond 822."
 - 2.2.3.2 Expansion joint filler: ASTM D 994.
 - 2.2.3.3 Sealant: FS TT-S-00230, Type II.
 - 2.2.4 Nonshrink Grout: ASTM C 1107; Sika Corporation "Sika Grout 212," or Master Builders "Masterflow 713."
 - 2.2.5 Forms: Wood, steel, plywood, or Masonite Corporation "Concrete Form Presdwood", as required for various specified finishes.
 - 2.2.6 Form Coating Materials: Symons Corporation "Magic Kote," AC Horn Incorporated "Form Shield," or Burke Company "Burke Release No. 1."

PART 3 - EXECUTION

3.1 PREPARATION

3.1.1 Form Construction

- 3.1.1.1 Install formwork in accordance with ACI 301, Section 4.2 and approved submittals. Interior shape and rigidity shall be such that finished concrete will meet the requirements of the Drawings within tolerances specified in ACI 117, Section 4.
- 3.1.1.2 Prepare form surfaces in accordance with ACI 301, Section 4.4 using specified form coating materials, or as described below.
- 3.1.1.3 Forms for surfaces which will be permanently concealed from view may be saturated with water, before placing concrete, instead of other treatment. In freezing weather forms shall be treated with oil or stearate.

3.1.1.4 Clean forms of foreign material before placing concrete.

3.2 INSTALLATION

3.2.1 Reinforcing Steel

3.2.1.1 Fabricate bars to dimensions shown on the Drawings, within tolerances shown in ACI 301, Section 5.6.

3.2.1.2 Tag in accordance with the bar list.

3.2.1.3 Place as shown on approved drawings, within tolerances specified in ACI 117, Section 2.2.

3.2.1.4 Tie to prevent displacement during placement of concrete.

3.2.1.5 Do not force into concrete after initial set has started.

3.2.1.6 Place with the concrete protection dimension equal to the minimum given in ACI 301, Section 5.7, except where shown otherwise on the Drawings.

3.2.2 Concrete

3.2.2.1 Before batching, obtain approval of form work and reinforcement by ICF KH.

3.2.2.2 Before placing:

a. Obtain ICF KH approval of the "Pour Slip." The "Pour Slip" shall include identification of sections of structure to be placed, maximum size of coarse aggregate, and design strength. Obtain "Pour Slip" forms from ICF KH.

b. For each truck load, deliver the "Trip Ticket" to ICF KH. "Trip Tickets" shall contain information listed in ASTM C 94, Paragraphs 16.1.1 through 16.1.10, and the water/cement ratio.

3.2.2.3 Place in accordance with ACI 301, Sections 8.1, 8.2, and 8.3. Do not drop (free fall) more than 5 feet. Insert vibrator, vertically if possible, into concrete and reach small distance into concrete in next lower layer. Do not insert vibrators into lower courses that have reached initial set. Take care to avoid allowing head of vibrator to come in contact with forms, reinforcement, or embedded items.

3.2.2.4 Temper only as permitted in ACI 301, Section 7.5.

3.2.2.5 Place nonshrink grout where shown on the Drawings, in accordance with manufacturer's recommendations.

3.2.2.6 Weather conditions: Protect concrete during placement in accordance with ACI 301, Sections 7.6 and 8.4. Cold weather concreting procedure shall be in accordance with ACI 306.1.

- 3.2.2.7 Construction joints: Make in accordance with ACI 301, Section 6.1, and as detailed on the Drawings. Coat joints with epoxy resin, where shown on the Drawings, in accordance with manufacturer's recommendations.
- 3.2.2.8 Embedded items: Install in accordance with ACI 301, Sections 6.4 and 6.5.
- 3.2.2.9 Expansion joints: Make in accordance with ACI 301, Section 6.2 and details on the Drawings.
- 3.2.2.10 Placing concrete against earth: Place on or against firm, damp surfaces free of frost, ice and free water. Do not place until required compaction has been obtained. Dampen earth surfaces to receive fresh concrete.
- 3.2.2.11 Consolidation: Consolidate concrete slabs in accordance with ACI 301, Section 11.6.
- 3.2.3 Form Removal and Concrete Repair
- 3.2.3.1 Form removal: Remove in accordance with ACI 301, Section 4.5.
- 3.2.3.2 Cut back form ties and examine concrete surfaces for defects. Repair only after permission for patching is given by ICF KH.
- 3.2.3.3 Place concrete repair mortar within one hour after mixing. Do not retemper mortar.
- 3.2.3.4 Repair surface defects in accordance with ACI 301, Sections 9.1, 9.2, and 9.3. Cure concrete repairs the same as new concrete.
- 3.2.4 Concrete Finishes and Tolerances
- 3.2.4.1 Formed surfaces: Start finishing following concrete repair and complete within 96 hours after forms have been removed. Finish in accordance with the following ACI 301 sections.
a. Surfaces exposed to earth backfill	Section 10.2.1
b. Interior surfaces	Section 10.2.2
c. Exterior surfaces exposed to weather	Section 10.2.2
d. Related unformed surfaces	Section 10.5
e. Surfaces to receive special protective coating	Section 10.3.2
- 3.2.4.2 Unformed surfaces: Finish in accordance with the following ACI 301 sections.
a. Interior floors	Section 11.7.3

b. Exterior equipment slabs

c. Exterior slabs subject to
foot traffic

Section 11.7.4

3.2.5 Sealant

3.2.5.1 Perform sealing using specified materials and proper tools in accordance with the manufacturer's recommendations.

3.2.5.2 Do not apply exterior sealing material when ambient temperature is below 40 or above 100°F.

3.2.5.3 Apply materials with guns having proper size nozzles. Use sufficient pressure to fill spaces and voids. Where use of gun is impractical, approved hand tools may be used.

3.3 CURING

3.3.1 Cure concrete in accordance with ACI 301, Section 12.2. Clear curing compounds shall be tinted or applied to surfaces marked to show the extent of spraying.

3.3.2 Do not use curing compound on surfaces to receive flooring or special protective coating.

3.4 FIELD QUALITY CONTROL

3.4.1 Concrete Testing: ICF KH will sample and test concrete to ACI 301, Sections 16.3.4, 16.3.5, 16.3.6 and 16.3.8.

3.5 PROTECTION

3.5.1 Protect concrete during extreme weather conditions in accordance with ACI 301, Section 12.3.

3.5.2 Protect concrete from mechanical damage in accordance with ACI 301, Section 12.4.

END OF SECTION

SECTION 05500

METAL FABRICATIONS

PART 1 - GENERAL

1.1 REFERENCES

1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.

1.1.1.1 American Society of Mechanical Engineers (ASME)

B&PVC

Boiler and Pressure Vessel Code,
1992 Edition

Section IX

Welding and Brazing Qualifications

1.1.1.2 American Society for Testing and Materials (ASTM)

A 36-91

Structural Steel

A 106-91

Seamless Carbon Steel Pipe for
High-Temperature Service

A 193-92

Alloy-Steel and Stainless Steel Bolting
Materials for High-Temperature Service

A 194-92a

Carbon and Alloy Steel Nuts for Bolts
for High-Pressure and High-Temperature
Service

A 240-92b

Heat-Resisting Chromium and
Chromium-Nickel Stainless Steel Plate,
Sheet and Strip for Pressure Vessels

A 276-92

Stainless and Heat-Resisting Steel Bars
and Shapes

A 307-92a

Carbon Steel Bolts and Studs, 60 000
PSI Tensile Strength

A 500-90a

Cold-Formed Welded and Seamless Carbon
Steel Structural Tubing in Rounds and
Shapes

A 563-92a

Carbon and Alloy Steel Nuts

A 569-91a

Steel, Carbon, Hot-Rolled Sheet and
Strip Commercial Quality

F 436-92

Hardened Steel Washers

F 844-90

Washers, Steel, Plain (Flat),
Unhardened for General Use

1.1.1.3 American Welding Society (AWS)

A2.4-93

Symbols for Welding, Brazing, and
Nondestructive Examination

D1.1-92

Structural Welding Code - Steel

1.2 SUBMITTALS

1.2.1 See Section 01300 of W-030-G2 for submittal procedures.

1.2.2 Approval Required

1.2.2.1 Drawings: For metal fabrications not shown on manufacturer's data sheets submit fabrication drawings and bill of materials prior to fabrication. Include plans, elevations, details, sections, and connections. Show thickness, type, grade, class of metal, fasteners, anchorage, and accessory items where applicable. Welding and examination symbols shall be in accordance with AWS A2.4

1.2.2.2 Manufacturer's data: Before delivery, submit copies of manufacturer's specifications, dimensioned diagrams, anchor details, and installation instructions for manufactured items.

1.2.3 Approval Not Required

1.2.3.1 Commercial Grade Item Documentation: Before fabrication/ installation, submit reports of inspections and tests of items specified in 2.3.1.

1.3 QUALITY ASSURANCE

1.3.1 Contractor's Quality Assurance Program: See Section 01400 of W-030-G2.

1.3.2 Misrepresented Products: See Section 01400 of W-030-G2 for required measures to prevent the use of misrepresented products.

1.3.3 Welding Qualification

1.3.3.1 Qualification of welding personnel and procedures: Personnel and procedures for welding structural steel shall have been qualified in accordance with AWS D1.1 before welding. Qualification in accordance with ASME Section IX may be substituted for this requirement.

1.3.3.2 Extent of application: The above qualification requirements also apply for preliminary fabrication of parts, from materials specified in 2.2, when fabrication is accomplished in shops other than the material suppliers shops, but not necessarily at the worksite.

- 1.3.4 Deliverable Documentation: The following documents and records, required by this Section, shall be delivered to ICF KH in accordance with Section 01720 of W-030-G2.

DocumentParagraph

Expansion Anchor Inspection Results 3.5.2

1.4 DELIVERY, STORAGE, AND HANDLING

- 1.4.1 See Section 01610 of W-030-G2 for general requirements.

PART 2 - PRODUCTS

2.1 SUBSTITUTES

- 2.1.1 See Section 01630 of W-030-G2 for substitution approvals.

2.2 MATERIALS

- 2.2.1 Rolled Steel Shapes, Plates, and Bars: ASTM A 36.

- 2.2.2 Steel Pipe: ASTM A 106, Grade B, Schedule 80.

- 2.2.3 Steel Tubing: ASTM A 500, Grade B.

- 2.2.4 Steel Sheet and Strip: ASTM A 569.

- 2.2.5 Stainless Steel Plate, Sheet, and Strip: ASTM A 240 TP 304L.

- 2.2.6 Stainless Steel Bars and Shapes: ASTM A 276 TP 304L.

- 2.2.7 Fasteners

- 2.2.7.1 Bolts: ASTM A 307, Grade A or B.

- 2.2.7.2 Nuts: ASTM A 563, Grade A, heavy hex.

- 2.2.7.3 Washers: ASTM F 844, circular.

- 2.2.7.4 High Strength Bolts: ASTM A 193, Grade B8.

- 2.2.7.5 High Strength Nuts: ASTM A 194, Grade 8F.

- 2.2.7.6 High Strength Washers: ASTM F 436.

- 2.2.7.7 Expansion anchors: Hilti Fastening Systems "Kwik-Bolt II," or ITW-Ramset "Trubolt Wedge Anchor."

- 2.2.8 Welding Electrodes: E70XX.

- 2.2.9 Nonshrink Grout: See Section 03300.

- 2.2.10 Paint: See Section 09900.

- 2.2.11 Zinc-rich coating: Southern Coating Incorporated "Galvicon", or ZRC Products Company "ZRC."
- 2.2.12 Isolating Tape: Inmont Corporation No. 162.03 Elastic Compound Tape, or Products Research and Chemical Corporation "Kling-Felt No. 213."
- 2.2.13 Supports: Interchangeable channels, channel spring nuts, and bolts; Unistrut Corporation "Unistrut."
- 2.2.13.1 Channels: Sizes as specified on Drawings.
- 2.2.13.2 Channel spring nuts: Manufacturer's standard.
- 2.2.13.3 Bolts (for use with channel spring nuts): Manufacturer's standard.
- 2.2.14 Support Clamps (for rigid steel conduit): Manufacturer's standard.
- 2.3 FABRICATION
 - 2.3.1 General
 - 2.3.1.1 Verify measurements and take field measurements necessary before fabrication. Provide miscellaneous bolts and anchors, supports, braces, and connections necessary for completion of metal fabrications. Cut, reinforce, drill, and tap metal fabrications shown to receive finish hardware and similar items. Weld or bolt connections as shown on the Drawings.
 - 2.3.1.2 Workmanship: Form metal fabrications to shape and size, with sharp lines, angles, and true curves. Drilling and punching shall produce clean, true lines and surfaces. Execute and finish work in accordance with fabrication drawings.
 - 2.3.1.3 Jointing and intersections: Accurately made, tightly fitted, and in true planes with adequate fastenings.
 - 2.3.1.4 Perform welding of steel connections in accordance with AWS D1.1.
 - 2.3.2 Miscellaneous Steel Items: Supply required clips, frames, equipment supports, and other fabrications not specified, but shown on the Drawings. Fabricate parts from standard structural sections or shapes, to sizes required. Wherever miscellaneous parts are exposed, grind edges, corners, and rough cuts smooth and free of snags. Shop paint parts except those to be embedded in concrete or masonry, or those which require other specific finishes.
 - 2.3.3 Finishes
 - 2.3.3.1 Prime ferrous metal in accordance with Section 09900. Do not coat members to be embedded in concrete or masonry, surfaces and edges to be field welded, or items to be galvanized.

PART 3 - EXECUTION

3.1 EXAMINATION

- 3.1.1 Examine areas where metal fabrications are to be installed and notify ICF KH in writing of conditions detrimental to proper and timely completion of work. Do not proceed with work until unsatisfactory conditions have been corrected.

3.2 PREPARATION

- 3.2.1 Prepare setting drawings, diagrams, templates, and instructions for installation of anchorages, such as concrete inserts, anchor bolts, and miscellaneous items having integral anchors, to be embedded in concrete or masonry construction.

3.3 INSTALLATION

- 3.3.1 Install expansion anchors in accordance with the manufacturer's recommendations.
- 3.3.2 Install metal fabrications plumb, level or as shown on the Drawings.
- 3.3.3 Make field connections as neatly as possible with joints flush and smooth. Grind smooth exposed field welds and polish before field painting. Repair welds in galvanized work with 2 coats of zinc-rich coating.
- 3.3.4 Where dissimilar metals are in contact, or where aluminum is in contact with concrete, mortar, masonry, wet or pressure-treated wood, or absorptive materials subject to wetting, protect surfaces with isolating tape to prevent galvanic or corrosive action.
- 3.3.6 Torque bolts used with channel spring nuts in support channels and clamps as follows.

Bolt size, inches	Torque, ft-lb
1/4	6 - 9
5/16	11 - 17
3/8	19 - 30
1/2	50 - 75

3.4 APPLICATION

- 3.4.1 After installation has been approved, clean and paint connections with primer. Touch-up shop prime coat wherever damaged.

3.5 FIELD QUALITY CONTROL

- 3.5.1 Expansion Anchor Installations: ICF KH will inspect safety class 1 and 2 installations and randomly inspect Safety Class 3 and 4 installations.

END OF SECTION

SECTION 09900

PAINTING

PART 1 - GENERAL

1.1 REFERENCES

1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.

1.1.1.1 Painting and Decorating Contractors of America (PDCA)

Architectural Specification 1984
Manual

1.2 SUBMITTALS

1.2.1 See Section 01300 of W-030-G2 for submittal procedures.

1.2.2 Approval Required

1.2.2.1 List of materials: Before delivery, submit list including manufacturers' names, specifications, recommendations, and other data necessary to show compliance with requirements.

1.2.2.2 Color samples: Before delivery, submit samples in form of 3 by 5-inch color chips. Describe coating material, manufacturer, and color identification on reverse face of each chip. Colors will be selected by ICF KH. Retain one set of approved samples at site for use as quality standard of final finishes.

1.2.3 Approval Not Required: None

1.3 QUALITY ASSURANCE

1.3.1 Use manufacturers and products listed in the PDCA Architectural Specification Manual, Chapter 7.

1.4 DELIVERY, STORAGE, AND HANDLING

1.4.1 See Section 01610 of W-030-G2 for general requirements. Store materials indoors.

1.5 PROJECT CONDITIONS

1.5.1 Environmental Requirements

1.5.1.1 Temperature: Unless otherwise recommended by paint manufacturer, apply coatings when ambient and surface temperatures are 45 to 95°F, except for water-thinned paints and other special coatings.

a. Apply water-thinned paints when ambient and surface temperature is 50 to 90°F.

b. Provide temporary heat as required until specified surface and air temperatures exist for required time periods. Maintain temporary heat for 24 hours after paint and finish application.

1.5.1.2 Weather: Do no exterior work on unprotected surfaces if it is raining or moisture from other source is present or expected before applied finishes can dry or attain proper cure without damage.

a. Allow surfaces to dry and attain required temperatures and conditions specified before proceeding with work or continuation of previously started work.

b. Do not apply finish in areas where dust is being generated.

c. Humidity: Follow manufacturer's directions for extremes.

1.5.1.3 Ventilation: Provide adequate continuous ventilation required for drying various materials as recommended by the manufacturer.

1.5.1.4 Illumination: Provide temporary lighting to attain minimum surface lighting level of 15 fc/ft².

PART 2 - PRODUCTS

2.1 SUBSTITUTES

2.1.1 See Section 01630 of W-030-G2 for substitution approvals.

2.2 MATERIALS

2.2.1 Furnish materials identified in PDCA Architectural Specification Manual, Chapters 5, 6, and 7 for systems scheduled in 3.5.

2.2.2 Furnish ready-mixed materials.

PART 3 - EXECUTION

3.1 EXAMINATION

3.1.1 Examine surfaces scheduled to receive finish for conditions that will adversely affect execution, permanence, or quality of work and which cannot be put into acceptable condition through preparatory work specified in 3.2.

3.1.2 Report conditions that may affect proper application of finish, in writing, to ICF KH. Do not begin surface preparation or coating application until defects have been corrected, and conditions are made suitable.

3.2 PREPARATION

3.2.1 Protection

3.2.1.1 Protect finished work of other trades and the following.

a. Metal siding on walls.

b. Materials having complete factory finish, such as electrical switchplates, lighting fixtures, and finish hardware.

3.2.1.2 As work proceeds, and upon completion of work, promptly remove spills, splashes, or splatters from products by methods not damaging to affected surfaces.

3.2.1.3 Repair or replace surfaces damaged by painting work as directed by ICF KH.

3.2.2 Surface Preparation

3.2.2.1 Prepare surfaces for finish systems specified in accordance with recommendations of finish material manufacturers, the PDCA Architectural Specification Manual, Chapters 3 and 3R.

3.2.2.2 Obtain written approval for dry or liquid abrasive blasting from ICF KH.

3.3 APPLICATION

3.3.1 Do not open containers until approved by ICF KH.

3.3.2 Mix materials in an ambient temperature above 45°F in a well ventilated and heated area, in accordance with the manufacturer's recommendations.

3.3.3 Perform work in accordance with manufacturers instructions, PDCA Architectural Specification Manual, and this Section.

3.3.4 Take precautions to prevent fire hazards and spontaneous combustion. Place cotton waste, cloths, and hazardous materials in containers and remove from the worksite daily.

3.4 FIELD QUALITY CONTROL

3.4.1 Inspection and testing will be performed by ICF KH.

3.4.2 Meet the requirements of PDCA Architectural Manual for "CUSTOM" material and work, unless otherwise specified.

3.5 SCHEDULES

3.5.1 Color: Unless otherwise noted, colors for incidental items not specifically scheduled will be selected by ICF KH.

3.5.2 Interior Paint and Finish: Exposed ferrous metal, light and ordinary exposers, Int 12-A, Custom Grade, semigloss.

END OF SECTION

SECTION 13121

METAL BUILDING SYSTEMS

PART 1 - GENERAL

1.1 REFERENCES

1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.

1.1.1.1 American Institute of Steel Construction, Inc (AISC)

ASD Allowable Stress Design (Manual of Steel Construction)

1.1.1.2 American Iron and Steel Institute (AISI)

Design of Cold-Formed Steel Structural Members

1.1.1.3 American Society of Civil Engineers (ASCE)

7-88 Minimum Design Loads for Buildings and Other Structures

1.1.1.4 American Society for Testing and Materials (ASTM)

A 446-91 Steel Sheet, Zinc-Coated (Galvanized) by the Hot-Dip Process, Structural (Physical) Quality

A 525-91b Steel Sheet, Zinc-Coated (Galvanized) by the Hot-Dip Process

C 665-91 Mineral-Fiber Blanket Thermal Insulation for Light Frame Construction and Manufactured Housing

E 90-90 Test Method for Laboratory Measurement of Airborne Sound Transmission Loss of Building Partitions

E 283-84 Test Method for Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors

E 331-86 Test Method for Water Penetration of Exterior Windows, Curtain Walls, and Doors by Uniform Static Air Pressure Difference

E 413-87 Classification for Rating Sound Insulation

- 1.1.1.5 American Welding Society (AWS)
 - A2.4-93 Symbols for Welding, Brazing, and Nondestructive Examinations
 - D1.1-92 Structural Welding Code-Steel
- 1.1.1.6 Builders Hardware Manufacturers Association (BHMA)
 - A156.1-1988 Butts and Hinges
 - A156.2-1989 Bored and Preassembled Locks and Latches
 - A156.4-1986 Door Controls--Closers
 - A156.6-1986 Architectural Door Trim
 - A156.18-1987 Materials and Finishes
- 1.1.1.7 International Conference of Building Officials (ICBO)
 - UBC (1991 Edition) Uniform Building Code
- 1.1.1.8 Metal Building Manufacturers Association (MBMA)
 - Low Rise Building Systems Manual (1986 Edition)
- 1.1.1.9 Society of Automotive Engineers (SAE)
 - AMS 5036G-85 Aerospace Material Specification; Steel Sheet and Strip, Aluminum Coated, Low Carbon
- 1.1.1.10 Underwriters Laboratories (UL)
 - Building Materials Directory (1993 Edition)
- 1.2 SUBMITTALS
 - 1.2.1 See Section 01300 of W-030-G2 for submittal procedures.
 - 1.2.2 Approval Required
 - 1.2.2.1 Erection instructions and diagrams: Before delivery, submit documentation necessary to erect building and install components. Documentation shall include the following.
 - a. Anchor bolt layouts and sizes.
 - b. Structural connections.
 - c. Roofing and siding connections.

- d. Joint sealing and calking.
- e. Door frame installation.
- f. Wall penetration frame installation.
- g. Flashings.
- h. Accessory installation.
- i. Details and instructions necessary for assembly.
- j. Fabrication drawings necessary to supplement instructions and diagrams. Welding and examination symbols shall be in accordance with AWS A2.4.
- k. Separate hardware list for each door.

1.2.2.2 Samples: Before delivery, submit color samples from the manufacturer's standard selection.

1.2.3 Approval Not Required

1.2.3.1 Certificate of compliance: With delivery, submit a certificate from manufacturer attesting that materials meet requirements of this Section and referenced documents.

1.3 SYSTEM DESCRIPTION

1.3.1 Metal Building: Single span structure, rigid frame, beam and column type.

1.3.1.1 Primary framing: Rigid frame of rafter beams and columns, braced end frames, end wall columns and wind bracing.

1.3.1.2 Secondary framing: Purlins, girts, eave struts, flange bracing, sill supports, clips and other items required for complete installation.

1.3.1.3 Wall and roof system: Preformed metal panels of vertical profile, insulation, liner sheets, and accessory components.

1.3.2 Design Criteria: Building and component design shall be in accordance with applicable sections of AISC ASD, AISI Design Specification, the MBMA Manual, and the ICBO UBC.

1.3.2.1 Basic design shall include live, dead, snow, wind, and seismic loads. Other design loads, either static or dynamic, shall be considered auxiliary loads.

1.3.2.2 Vertical live and snow loads:

- a. Design roof covering for either a 50 lb/ft² uniformly distributed load, or 200 pound concentrated live load over a 1 by 1 foot area located at the center of maximum roof panel span, whichever produces greater stress.

b. Design primary framing and purlins for 20 lb/ft² snow or live load uniformly distributed over supported roof area.

1.3.2.3 Wind loads: Design in accordance with ASCE 7-88, Section 6, using following criteria.

a. Basic wind speed: 70 mi/h.

b. Importance factor: $I=1.07$ (for 100 year recurrence level).

c. Exposure category: C.

1.3.2.4 Seismic loads: Based on seismic accelerations of the ICBO UBC, Section 2312, for Seismic Zone 2B.

1.3.2.5 Auxiliary loads: Design roof framing for an auxiliary load of 10 lb/ft² to accommodate loads imposed on the building from piping, lighting fixtures, heating units, and equipment, including the automatic fire sprinkler system.

1.3.2.6 Maximum deflection in roofing or roof panels shall not exceed 1/180th of spans, and maximum deflection in siding or wall panels shall not exceed 1/90th of spans.

1.3.2.7 Provide drainage to exterior for water entering or condensation occurring within cladding system.

1.3.2.8 Thermal resistance:

a. Wall system: R value of 11.

b. Roof system: R value of 19.

1.3.2.9 Weld steel in accordance with AWS D1.1.

1.4 DELIVERY, STORAGE, AND HANDLING

1.4.1 See Section 01610 of W-030-G2 for general requirements.

1.4.2 Damaged or defaced components may be repaired, if repairs are acceptable to ICF KH.

1.4.3 Store hardware items separately with fasteners and instructions, for individual use.

1.5 WARRANTY

1.5.1 Buildings shall be warranted against water leaks, caused by normal atmospheric exposure, for a period of 5 years.

1.5.2 Warranty shall start upon final acceptance of Work, or the date the Operating Contractor takes possession, whichever is earlier.

PART 2 - PRODUCTS

2.1 SUBSTITUTES

2.1.1 See Section 01630 of W-030-G2 for substitution approvals.

2.2 MANUFACTURED UNITS

2.2.1 Wall, Roof, and Soffit Systems

2.2.1.1 Sheet steel stock: ASTM A 446, galvanized to ASTM A 525 G 90. Factory color finished.

2.2.1.2 Wall system: 0.0217-inch (26-gage), exposed fastening panels.

2.2.1.3 Roof system: 0.0276-inch (24-gage), concealed fastening, standing seam configuration.

2.2.2 Insulation and Vapor Barriers

2.2.2.1 Blanket and batt insulation: ASTM C 665. Insulation containing asbestos is not acceptable. Insulation shall be listed in the UL Building Materials Directory, and have a "flame spread" of 25 maximum, and "smoke developed" of 50 maximum.

a. Wall insulation: Type II batts, with minimum thermal resistance of R-11, faced with aluminum foil vapor barrier covering on one side. Insulation shall be capable of fitting into available space without compressing more than 10% in thickness.

b. Roof insulation: Type II batts, with minimum thermal resistance of R-19, faced with aluminum foil vapor barrier covering on one side.

2.2.2.2 Vapor barrier for unfaced batt insulation: Polyethylene sheets, 4 mils thick. Vapor barrier shall be listed in the UL Building Materials Directory, and have a "flame spread" of 25 maximum, and "smoke developed" of 50 maximum.

2.2.3 Wall Liner

2.2.3.1 Minimum thickness: 0.0217-inch (26-gage) flush panels, maximum 1 inch profile, zinc-coated (galvanized) to ASTM A 525, G90 with factory precoated finish.

2.2.3.2 Liner shall extend from floor to ceiling. Provide matching metal trim at base of wall liner, top of wall liner, around openings in walls and roof and over interior and exterior corners.

2.2.4 Sealant: Manufacturer's standard elastomeric, nonstaining type.

2.2.5 Fasteners: Manufacturer's standard type, finished to match adjacent surface when exterior exposed.

- 2.2.6 Accessories: Flashing, trim, caps, and similar metal accessories shall be of same thickness, material and finish used for adjacent wall or roof coverings.
- 2.2.7 Closure Strips: Formed of compressed rubber, synthetic rubber, bituminous impregnated materials, or metal of same respective type as roof and wall panels, and standard with manufacturer. Molded closure strips shall be free of open voids and shall not absorb or retain water. Closure strips shall be formed to match corrugations or configurations of roofing or siding being used and provided, where shown and necessary, for weathertight construction.
- 2.2.8 Doors, Frames, and Hardware
- 2.2.8.1 Doors: Minimum thickness; 1-3/4 inches thick, constructed of 0.0396-inch (20-gage) hot dipped galvanized steel, economy type, meeting STC 34 as tested according to ASTM E 90 and E 413. Air infiltration shall meet ASTM E 283. Water infiltration shall meet ASTM E 331.
- 2.2.8.2 Door leaf: Full flush (plain).
- 2.2.8.3 Door frame: 0.0516-inch (18-gage) galvanized steel. Door frame shall consist of door posts, door jamb, door header, header reinforcement, sill plate, clips and extensions as required. Door frame shall be knock down type with upper ends of members butted to provide square and solid joints for threaded fastener attachments.
- 2.2.8.4 Door jambs: 5-3/4 inches deep with unequal rabbets (1-15/16 inch, 1-9/16 inch). Face width shall be 2 inches with double return. Jambs shall be retained at floor line by a sill plate with slips welded at each end. Jambs shall have brackets welded at fixed locations for attachment of door posts.
- 2.2.8.5 Door and frame finish: Manufacturer's standard.
- 2.2.8.6 Threshold and weatherstripping: Threshold shall be BHMA A156.6 aluminum extrusion with mill finish drilled and countersunk for attachment to floor and shall have notched ends to fit the door jamb rabbets; Pemko. Weatherstripping shall be a concealed door sweep of EPDM material. Perimeter weatherstripping shall be an adhesive backed press-on flexible black TPE material, factory installed on the frame, astragal or mullion.
- 2.2.8.7 Door hardware: Closer shall conform to BHMA A156.4, Type C02063; Corbin or an approved substitute. Closer reinforcement shall be 0.1084-inch (12-gage) galvanized steel, field installed in door header. Hinges shall be BHMA A156.1, two 1-1/2 pair of 4-1/2 by 4-1/2 inch steel hinges, full mortise 0.134-inch thick, plain bearing action, with nonremovable button-tip pin; Stanley or an approved substitute. Hinges shall be primed and painted in accordance with the manufacturer's standard.
- 2.2.8.8 Lock set: BHMA A156.2, Series 1000, Grade 1. Lock set function shall be latch bolt retracted by key in the outside knob only. Corbin or an approved substitute.

- 2.2.8.9 Lock cylinders: Furnish 5-pin tumbler cylinders with Corbin 67 keyway and 2 keys for each lock set. Key locks to match existing master-key system as directed by ICF KH.
- 2.2.8.10 Fasteners: Furnish necessary screws, bolts, or other fasteners of suitable size and type to anchor hardware in position. Match hardware finish. Furnish with expansion shields, toggle bolts, or other appropriate anchors.
- 2.2.8.11 Hardware finish: BHMA A156.18, 26D dull chrome finish, unless otherwise noted.
- 2.2.9 Ventilator (Louver): End wall, ventilator/louver openings to be provided complete with framing and weather flashing in preparation for the installation of the end wall ventilators by others. Construction of the framed openings shall be in accordance with the manufacturer's standard details. The location of openings and all other requirements shall be in accordance with the Project drawings.
- 2.2.10 Nonshrink Grout: See Section 03300.
- 2.2.11 Finish: Precoated enamel on steel with color selected from manufacturer's standards by ICF KH. Provide one quart of each color used to the Operating Contractor along with recommended application instructions.

PART 3 - EXECUTION

3.1 INSTALLATION

- 3.1.1 Erect in accordance with manufacturer's approved erection instructions and diagrams.
- 3.1.2 Set structural elements on nonshrink grout.
- 3.1.3 Insulate dissimilar materials, not compatible when in contact, from each other by gaskets or insulating compounds.
- 3.1.4 Wall and Roof Systems
- 3.1.4.1 Exercise care when cutting prefinished material to ensure cuttings do not remain on finish surface.
- 3.1.4.2 Fasten cladding system to structural supports, aligned level and plumb.
- 3.1.4.3 Use concealed fasteners for roof system and exposed fasteners for wall system.
- 3.1.4.4 Apply sealant or gasket materials to prevent weather penetration.
- 3.1.4.5 Installed systems shall be free of rattles, noise due to thermal movement, and wind whistles.
- 3.1.5 Attach louvers and ventilators to supporting construction to assure rain-tight installation.

- 3.1.6 Anchor doors and windows, including frames and hardware, to supporting construction, install plumb and true, and adjust to provide proper operation.
- 3.1.7 Insulation: Except as otherwise shown on the Drawings or approved, install insulation against covering and between supporting members to present neat appearance. Lap and fasten blanket insulation facing to provide tight joints.
- 3.1.8 Fasten wall liner into place to present neat appearance.
- 3.1.9 Field Painting
 - 3.1.9.1 Upon detection, wire brush and touch-up abraded or corroded spots on shop-painted surfaces with the same material used for the shop coat.
 - 3.1.9.2 Paint exposed, shop primed ferrous surfaces on building exterior, and shop primed door and window surfaces with 2 coats of approved exterior enamel.
 - 3.1.9.3 Touch-up factory color finished surfaces, with manufacturer's recommended touch-up paint, as necessary.

END OF SECTION

SECTION 15493

CHEMICAL PROCESS PIPING SYSTEMS

PART 1 - GENERAL

1.1 REFERENCES

1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.

1.1.1.1 American National Standards Institute (ANSI)

A13.1-1981 (R 1985) Scheme for the Identification of Piping Systems

1.1.1.2 American Society of Mechanical Engineers (ASME)

B16.3-1992 Malleable Iron Threaded Fittings, Classes 150 and 300

B16.5-1988 Pipe Flanges and Flanged Fittings

B16.9-1993 Factory-Made Wrought Steel Butt Welding Fittings

B31.3-1993 Chemical Plant and Petroleum Refinery Piping

NQA-1-~~1989~~ 1994 Quality Assurance Program Requirements ECN-85
for Nuclear Facilities Facility
Applications ECN-85

1.1.1.3 American Society for Nondestructive Testing (ASNT)

SNT-TC-1A Recommended Practice (December 1988 Edition)

1.1.1.4 American Society for Testing and Materials (ASTM)

A 47-90 Malleable Iron Castings

A 53-90b Pipe, Steel, Black and Hot-Dipped, Zinc-Coated Welded and Seamless

A 105-92 Forgings, Carbon Steel, for Piping Components

A 106-91 Seamless Carbon Steel Pipe for High-Temperature Service

A 197-87 (1992) Cupola Malleable Iron

A 234-92a	Piping Fittings of Wrought Carbon Steel and Alloy Steel for Moderate and Elevated Temperatures	
A 307-92a	Carbon Steel Bolts and Studs, 60000 psi Tensile Strength	
A 312-92a	Seamless and Welded Austenitic Stainless Steel Pipes	
A 403-91	Wrought Austenitic Stainless Steel Piping Fittings	
A 563-92a	Carbon Alloy Steel Nuts	
B 62-93	Composition Bronze or Ounce Metal Castings	
1.1.1.5	American Waterworks Association (AWWA)	
C213-91	Fusion Bonded Epoxy Coating for the Interior and Exterior of Steel Water Pipelines	
1.1.1.6	Instrument Society of America (ISA)	
S20-1981	Specification Forms for Process Measurement and Control Instruments, Primary Elements and Control Valves	
1.1.1.7	Manufacturers Standardization Society of the Valve and Fittings Industry (MSS)	
SP 43	Wrought Stainless Steel Fittings	ECN-85
SP-58, 1988	Pipe Hangers and Supports - Materials, Design and Manufacture	
SP-69, 1991	Pipe Hangers and Supports - Selection and Application	
SP-89	Pipe Hangers and Supports - Fabrication and Installation Practices	
1.1.1.8	Steel Structures Painting Council (SSPC)	
SP 3-82	Power Tool Cleaning	
SP 6-85	Commercial Blast Cleaning	
1.1.1.9	American National Standards Institute (ANSI)	ECN-85
A13.1-1993	Identification of Piping Systems	ECN-85

1.1.1.10 Federal Standard (Fed. Std.)

FED-STD-595

Colors Used in Government Procurement

1.1.1.11 Federal Specification (FS)

TT-E-489

Enamel, Alkyd, Gloss, Low VOC Content ECN-85

1.2 SUBMITTALS

1.2.1 See Section 01300 of W-030-G2 for submittal procedures.

1.2.2 Approval Required

1.2.2.1 Approval data: Before delivery, submit information listed in the Approval Data List in this Section.

1.2.2.2 Certified material test reports (*CNTRs*): Before delivery, submit legible reports, certified by responsible manufacturer of materials used in the fabrication of pipe, fittings, flanges, bolting and weld rods for pipe codes below. Report shall present results of chemical analysis and physical test specified by ASME and ASTM Codes and standard specifications for production lots and heats of materials. Submit separate reports for the following: ECN-145

a. Pipe Code M-9; Service, Supernate (SN) and Slurry (SL) lines

b. Pipe Code M-26a; Service, Supernate (SN) and Slurry (SL) line encasements

Material traceability shall to be maintained through fabrication for materials requiring reports *CNTRs*.

ECN-145
ECN-145

1.2.3 Approval not required

1.2.3.1 Vendor information: Before installation, submit information listed in the Vendor Information List in this Section.

1.3 QUALITY ASSURANCE

1.3.1 Contractor's Quality Assurance Program: See Section 01400 of W-030-G2. (EXCEPTION: For paragraph 1.7 [Schedule of Hold and Witness Points] only 15493-3 [Leak/Pressure Testing] applies.)

1.3.2 Misrepresented Products: See Section 01400 of W-030-G2 for required measures to prevent the use of misrepresented products.

1.3.3 Safety related products: ~~Safety class 2~~ *Safety Significant products* shall be procured from qualified suppliers. These suppliers shall have a quality assurance program meeting the ASME NQA-1 Basic Requirements 1, 2, 4, 6, 7, 8, 11 through 15 and 17. ECN-805

1.3.4 Welding Qualification

1.3.4.1 Qualification of Welding Personnel and Procedures: Personnel and procedures for welding pressure retaining components along with attachments thereto, and pipe supports, shall have been qualified in accordance with ASME B31.3, Paragraph 328.2 (A 328.2) before welding.

1.3.4.2. Qualification of Nondestructive Examination (NDE) Personnel:

ECN-85

a. Visual weld examinations shall be performed *in accordance with ASME B31.3, and appropriate documentation prepared by Certified Welding Inspectors (CWI) who have received certification in accordance with AWS QC1. Certified Associate Welding Inspectors (CAWI), certified in accordance with the above standard, may perform examinations when under immediate direction of CWIs.*

b. ~~Welding-related examination documentation shall be signed, or stamped by individual performing examination. Where CAWIs perform examinations, documentation shall be signed or stamped by both CAWI and CWI under whom examinations were performed.~~

eb. Personnel performing other NDE shall be certified in accordance with Contractor's written practice, which shall meet the requirements of ASNT SNT-TC-1A. *Use Level III to interpret test results.*

~~1.3.4.3 Extent of Application: The above qualification requirements also apply for preliminary fabrication of parts, from materials specified in 2.2, when fabrication is accomplished in shops other than the material suppliers shops, but not necessarily at the worksite.~~

ECN-85

1.3.5 Deliverable Documentation: The following documents and records, required by this Section, shall be delivered to ICF KH in accordance with Section 01720 of W-030-G2.

Document

Paragraph

Flushing/Mechanical Cleaning Verification

3.2.2.5

Welding Examination Documentation

3.2.1

Leak/Pressure Test Certification

3.2.3.1b

1.4 DELIVERY, STORAGE, AND HANDLING

1.4.1 See Section 01610 of W-030-G2 for general requirements.

PART 2 - PRODUCTS

2.1 SUBSTITUTES

2.1.1 See Section 01630 of W-030-G2 for substitution approvals.

2.2 MATERIALS

2.2.1 Piping and Fittings: See the Pipe Codes in this Section and details on the Drawings.

2.2.1.1 When approved by the Construction Engineer, integrally reinforced branch connections may be used on 2-inch and larger welded main lines instead of butt welding tees noted in pipe codes. Material and weight shall correspond to pipe code for particular piping system.

- 2.2.1.2 Close or butt nipples are not permitted, unless shown on the Drawings.
- 2.2.2 Pipe Joint Sealant (Lubricant) for Threaded Joints: For design temperatures up to 500°F, use nonhardening teflon paste: Chesterton "Goldend" No. 7298, Federal Process Company "JC-30", or Lake Chemical Company "Slic-Tite."
- 2.2.3 Protective coating for piping in contact with earth or concrete.
- 2.2.3.1 Carbon steel piping: Factory and field applied exterior protective coating; AWWA C213, fusion bonded epoxy coating of 14 mils minimum thickness, Scotchkote 206N or an approved substitute.
- 2.2.4 Paint: See Section 09900, with piping identification as specified in Appendix A.
- 2.2.5 Nonshrink grout: See Section 03300.
- 2.2.6 Pipe supports: Pipe supports shall be as shown on the drawings with standard components selected in accordance with MSS SP-69, that satisfy the criteria of MSS SP-58.

2.3 EQUIPMENT

- 2.3.1 Valves, duplex strainer and back flow preventer: Specified in Pipe Codes, unless shown otherwise on the Drawings.
- 2.3.2 Flow meter: See the Data Sheet Y-0101.

PART 3 - EXECUTION

3.1 INSTALLATION

3.1.1 General

- 3.1.1.1 Fabricate and install pipe in accordance with ASME B31.3 (for normal service), Drawings, and this Section.
- 3.1.1.2 Cut pipe using methods which result in clean, straight cuts.
- 3.1.1.3 Ream pipe to nominal inside diameter after cutting. Remove burrs from threads before assembly.
- 3.1.1.4 Tools marked for stainless steel shall be used on stainless steel only.
- 3.1.1.5 Bend pipe in accordance with ASME B31.3, and meet tolerances given in ASME B31.3. Use methods and equipment which produce bends free of wrinkles, bulges, or kinks. When wall thickness, diameter, and bend radius indicate possibility of wall collapse during bending, fill pipe with clean silica sand or fusible material similar to Cerro-bend, manufactured by Cerro Corporation.

a. Application of heat to facilitate a pipe bend shall be brought to the attention of the Responsible Engineer for disposition and direction.

b. Cold springing pipe permitted only if specified on the Drawings.

3.1.1.6 Make joints in threaded piping systems with joint sealant specified. Apply sealant to male threads only.

3.1.1.7 Carbon steel embedded in concrete shall be bare.

3.1.1.8 Piping systems shall be kept clean. Piping systems shall be inspected and checked to be free of debris and foreign materials before, during and after installation.

3.1.1.8.1 Once fabrication has started, plug or cap ends of piping when installation is not in progress to prevent entry of dirt and other foreign material. Cap or plug openings in fabricated pipe spool assemblies until installation in piping system. Leave ends of spare lines capped or blind flanged when installation has been completed.

3.1.1.9 *High point vents shall not be provided on SN and SL lines.* Provide drain taps at low points to ensure complete drainage and drying in piping systems using water for cleaning and leak/pressure testing. Venting may be provided by loosening flanges having minimum of 4

bolts.

3.1.1.10 Pipe supports: Install as shown on the Drawings, in accordance with manufacturer's instructions, and applicable recommended procedures of MSS SP-89.

3.1.1.11 Direction shall be obtained from the Operating Contractor for disposal of waste flushing and testing water.

3.1.2 Underground piping

3.1.2.1 Trenches: Excavate, backfill, and compact in accordance with Section 02225.

3.1.2.2 Place piping supports on undisturbed soil or backfill placed and compacted in accordance with Sections 02200 and 02225.

3.1.2.3 Survey piping systems for elevation and location. Complete placement of supports and meet specification and drawing requirements before survey. Elevation and location shall be in accordance with the Drawings. Piping system shall be surveyed for final acceptance.

3.1.3 Welding

3.1.3.1 Weld piping, attachments to pressure retaining components, and pipe supports in accordance with ASME B31.3 and Project Drawings.

3.1.3.2 Protect outdoor welding operation from rain and wind by using barriers to protect welder and weld joint.

- 3.1.3.3 Complete piping welds before tie-in welds to pits, or fixed items. ECN-112
- 3.1.3.4 Remove backing strips if used. ECN-112
- 3.1.3.5 *Gas Tungsten Arc Welding (GTAW) process shall be used for root pass welds of carbon steel encasement pipes where stainless steel inner pipes cannot be protected from weld splatter.* ECN-112
- 3.1.4 Weld Identification
- 3.1.4.1 Prepare weld maps using Project Drawings or Sketches identification drawings, isometric or spool, which show relative position of each pressure containing weld and each attachment weld to pressure retaining components. ECN-85
- 3.1.4.2 Assign and record weld number to each pressure containing weld and each attachment weld to pressure retaining components as made. Record weld number on weld maps identification drawings as weld is made. ECN-85
- 3.1.4.3 Place the welder identification symbol and weld number adjacent to each weld upon completion. Place the identification symbol approximately every 3 feet on long seams or large weldments, using one of the marking methods specified in Section 01610.
- 3.1.4.4 Do not reuse weld numbers. If weld is completely replaced, assign new number.
- 3.1.4.5 Show heat/lot numbers on weld maps identification drawings for materials requiring Certified Material Test Reports. ECN-85
- 3.1.5 Perform NDE, flushing, leak/pressure testing specified in 3.2, before coating application.
- 3.1.6 Exterior Protective Coating
- 3.1.6.1 Piping in the water service building shall be painted as specified in Section 09900 and identified as specified in Appendix A.
- 3.1.6.2 Protect carbon steel pipe and fittings exposed to earth backfill with specified coating. See Section 02650 for underground raw water service exterior protective coating. ECN-133
- a. Clean carbon steel surfaces to white metal by sandblasting in accordance with SSPC SP 6. Where blasting is impracticable, clean by power wire brushing in accordance with SSPC SP 3.
- b. Apply specified coating in accordance with AWWA C213 and manufacturer's instructions.
- 3.1.6.3 After installation, examine carbon steel pipe having factory applied exterior protective coating, and joints, fittings, and short lengths of pipe having field applied exterior protective coating materials.
- a. Use electrical holiday detector in accordance with AWWA C213.

b. Repair damage to coating in accordance with AWWA C213.

3.1.7

Piping Identification: Identify exposed piping systems as to fluid carried and direction of flow as specified in Appendix A.

3.1.8 ~~Turbine Flowmeter: Install Flow Element FE 1361 as shown on the Drawings. Turn over the secondary instrument FQIT 1361 shown on the Data Sheet Y 01010 to ICF KH for installation.~~ ECN-473
ECN-413

3.2 FIELD QUALITY CONTROL

3.2.1 Nondestructive Examination (NDE) of welds shall be performed to the extent defined in ASME B31.3, Paragraph 341.4. ECN-85
ECN-85

3.2.1.1 Perform NDE for each pipe code listed in the schedule in 3.3.

3.2.1.2 Visual examination: Perform in accordance with ASME B31.3, Paragraph 344.2. Acceptance criteria shall be per ASME B31.3, Table 341.3.2A. ECN-85
ECN-85

3.2.1.3 ~~Liquid penetrant (dye penetrant) examination (PT):~~ Perform in ~~-process examination~~ in accordance with ASME B31.3, Paragraph 344.4 344.7. ECN-85
ECN-85

3.2.1.4 Radiographic examination (RT): Perform in accordance with ASME B31.3, Paragraph 344.5. Acceptance criteria shall be per ASME B31.3, Table 341.3.2A. ECN-85
ECN-85

a. Identify radiographic film with weld identification number and project or work order number assigned to work covered by this Section.

b. Prepare radiographic examination reports as follows:

1) List each radiographic exposure location (0-1, 1-2, ...) individually on radiographic examination report.

2) Indicate location acceptability or rejectability and note discontinuities whether rejectable or not.

3) When report includes radiographs of welds which have been repaired, indicate which welds are repair welds and how many times each weld has been repaired.

c. If additional welding is performed on weld area which has already been examined radiographically, this area is repair area. Identify subsequent radiographs by "R-1, R-2", etc.

3.2.1.5 Perform random visual examination of piping supports welds Safety Class 3 systems in accordance with ASME B31.3, Paragraph 344.2. ECN-85
ECN-85

3.2.1.6 ~~Perform 100 percent visual examination of piping supports for Safety Class 2 systems in accordance with ASME B31.3, Paragraph 344.2.~~ ECN-85
ECN-85

3.2.1.76 NDE documentation: ECN-85

a. Document examination of pressure containment welds and welds to pressure containing components for piping systems on NDE/Weld Record Form KEH-0433. See Form KEH-0433 for instructions for recording weld

identification drawings, weld numbers, welder identification, welding
procedure numbers, weld filler material, visual examinations, Page 68
nondestructive examinations, and for noting satisfactory completion
of leak/pressure testing.

b. Required NDE shall be completed and documented before start of leak/pressure testing.

c. NDE/Weld record information and weld maps identification drawings specified in 3.1.4 may be incorporated on a single format or traveler for a specific work package.

ECN-85

d. Document examination of pipe supports by recording on sketches or NDE/Weld Record form.

3.2.2 Cleaning and Flushing

3.2.2.1 After NDE is complete and before leak/pressure testing system, or before connecting system into existing system, clean piping internal surfaces mechanically or by flushing.

3.2.2.2 Mechanical cleaning: Remove loose dirt, scale, and debris by brushing, wiping, high pressure water jetting, or other mechanical method approved by Construction Engineer.

a. When high pressure water jetting or other mechanical cleaning method utilizing water is used, and leak/pressure testing will not be performed immediately after cleaning, dry piping systems by blowing dry oil-free air or nitrogen through lines.

b. Dry until the relative humidity of discharge air is equal to that of inlet air. Use drain taps at low points of piping system to ensure complete drainage and drying. Cap lines or reconnect to system to maintain cleanliness.

3.2.2.3 Water flushing:

a. Remove strainer screens before flushing, except those protecting control equipment. Clean screens protecting control equipment before flushing, if necessary, and after flushing is complete.

b. Flush piping with water for 1 minute minimum, and until effluent is clean and contains no visible particulate matter. Flushing pressure shall not exceed maximum operating pressure specified in pipe codes. Flushing water supply shall have sufficient capacity to produce a flow velocity of 4 to 6 ft/s in largest pipe size, with pipe full. Provide flow measurement in flushing water supply line to be used as basis for verification of flow velocities in piping system by Construction Engineer.

c. When leak/pressure testing will not be performed immediately after flushing, dry tabulated piping systems by blowing dry, oil-free air or nitrogen through lines. Dry until the relative humidity of discharge air is equal to that of inlet air. Use drain taps at low points of piping systems to ensure complete drainage and drying. Cap lines or reconnect to the systems.

3.2.2.4 Pneumatic flushing for instrument air (IA) and encasements (ENCs) ~~Form 127~~ piping only:

- a. Isolate instruments by valving, plugging or disconnecting.
- b. Blow lines clean with dry, oil-free air or nitrogen at 20 to 30 lb/in² gage, until discharge air has no visible particulate matter or for 5 minutes minimum. If pipe code maximum operating pressure are lower, use those pressures.
- c. If leak/pressure testing is not performed immediately after flushing, cap lines or reconnect to system to maintain cleanliness.

3.2.2.5 Provide documented evidence that flushing or mechanical cleaning has been performed as specified in this Section.

3.2.3 Leak/Pressure Testing

3.2.3.1 General:

- a. After completion of flushing, perform leak/pressure testing of pipe in accordance with ASME B31.3 and this Section. Use calibrated gages with ranges 1-1/2 to 2 4 times the test pressure. ECN-201
- b. Document testing of each piping system on "Leak/Pressure Test Certification" Form KEH-1757. Use separate forms to describe and record each piping system. Under "Description" describe piping system in enough detail for correlation to weld identification drawings, shop fabrication drawings, or Project Drawings as applicable. For systems tested segmentally, indicate continuity in "Description" to assure that entire systems have been tested.
- c. Pipe joints, fittings, and other potential leak sources to be tested shall be visible and accessible during tests.
- d. Install one temporary relief valve during testing. Relief valve shall have a discharge capacity of 125% of capacity of the pressurizing device, and be set to operate at 1-1/3 maximum of the test pressure for hydrostatic testing and not higher than test pressure plus the lesser of 50 lb/in² or 10% of the test pressure for pneumatic testing. Tag each relief valve used to show serial number, inspector, date, and pressure setting.
- e. Install necessary restraining devices, before applying test pressure, to prevent distortion or displacement of piping.
- f. Isolate instruments and other items which could be damaged by test pressures.
- g. Continuously maintain test pressure for 10 minutes minimum. Examine joints and connections. Piping system shall show no visual evidence of weeping or leaking.

h. Visually examine piping joints, fittings, and other potential leak sources, including welds which attach wear plates, anchors, etc to piping systems, during testing.

i. Complete testing of piping before field application of protective coating. Pipe with factory applied protective coating shall be considered as having been tested before protective coating application.

3.2.3.2 Hydrostatic pressure testing:

a. Perform in accordance with ASME B31.3, Paragraph 345.4.

b. Purge air from piping systems during filling, before applying pressure.

c. Coat welded piping joints, fittings, and other potential leak sources, including welds attaching wear plates, anchors, etc, to piping systems, with a mixture of powdered blue chalk and water or isopropyl alcohol. Allow to dry before filling piping with water and inspecting for leaks.

d. Remove water from piping systems after testing and dry by blowing dry, oil-free air or nitrogen through lines. Dry until the relative humidity of discharge air is equal to that of inlet air. Use drain taps at low points of piping systems to ensure complete drainage and drying.

3.2.3.3

Pneumatic pressure testing: (for instrument air [IA] and encasement [ENC] lines only).

a. Perform in accordance with ASME B31.3, Paragraph 345.5.

b. Perform testing with dry, oil-free air or nitrogen on piping systems.

ECN-127

ECN-127

3.3

SCHEDULES

3.3.1

Schedule of Pipe Weld NDE/Testing

Pipe Codes	M-5	M-7	M-9	M-26a				
NDE/NDT Method								
Visual								
Fitup	(F)	(F)	(G)(D)(E)	(G)				
Root Pass			(G)(D)(E)					
Cover Pass	(G) (C)(D)	(G) (C)(D)	(G)(D)(E) (C)(D)	(G) (C)(D)				
Liquid Penetrant								
Root pass			(H)					
Cover Pass			(H)	(J)				
Magnetic Particle								
Cover Pass								
Radiographic								
Completed Weld	(E)(B)	(E)(B)	(H) (E)(B)	(H)				
Leak/Pressure								
Completed Weld	(A)	(A)	(A)	(A)				
Other								

ECN-85

ECN-85

- Legend:
- A. Requires witnessing and acceptance by ICF KH Title III Acceptance Inspection prior to recording.
 - B. Requires acceptance of radiographs and documentation by KEH Title III Acceptance Inspection prior to recording.
 - ~~C. Circumferential and longitudinal butt welds.~~
 - ~~D. Full penetration welds on branch connections.~~
 - ~~E. Attachment welds to pipe.~~
 - FC. Random visual examination for 5% of all longitudinal and circumferential welds, full penetration welds on branch connections and attachment welds to pipe.
 - GD. 100% visual examination of longitudinal and circumferential butt welds.
 - ~~H. Liquid penetrant examine all welds that are not radiographed.~~
 - IE. Random radiography for 5% of primary all circumferential butt welds. In-process examination may be performed in lieu of radiography.
 - ~~J. Random liquid penetrant for 10% of welds not radiographed.~~

ECN-85

ECN-85

ECN-805

PIPE CODE M-5 (Safety Class 3) (General Service)			
Service	Max Operating Pressure	Test Pressure	Max Operating Temp
Raw Water (Raw)	160 psig	240 psig	100°F
Sizes	2" and smaller		
Pipe	Black steel, ASTM A 53, Type E, Grade B or ASTM A 106, Grade B.		
Wall Thickness	Schedule 40, <i>minimum</i>		
Nipples	Same schedule as pipe, close or butt not permitted.		
Fittings (†)	Class 150 malleable iron, ASTM A 47, Grade 32510 or 35018 or ASTM A 197 threaded in accordance with ASME B16.3.		
Unions	Class 150 malleable iron, ASTM A 47, Grade 32510 or 35018 or ASTM A 197 threaded in accordance with ASME B16.3, bronze to iron seat. (No buried unions.)		
Flanges	Class 150 forged steel, ASTM A 105, raised face, weld neck, in accordance with ASME B16.5. Bore to match pipe ID. Use flanges for pipe sizes 8" and larger. Use flat face where mating to flat face flanges.		
Bolting	Alloy steel studs, ASTM A 307, Grade B, and heavy hex nuts, ASTM A 563, Grade A.		
Gaskets	Compressed fiber, nonasbestos, 1/16" thick sheet; Garlock "Blue-Gard" Style 3100. Use full face gaskets with flat face flanges.		
(†) For inaccessible or underground lines use wrought steel butt welding in accordance with ASME B16.9, material in accordance with ASTM A 234, Grade WPB, wall thickness to match pipe.			

ECN-133

ECN-133

ECN-133

ECN-133

ECN-805

PIPE CODE M-5 (~~Safety Class 3~~ General Service)

Ball Valves	Class 150, ASTM B 62, brass body, threaded ends, 316 stainless steel ball, teflon seats and body seal. Powell Fig. 4301T Whitey 60 Series Worcester No. 416TSE
Check	<i>Threaded in cap, Y-pattern, swing, composition disc.</i>
Strainer	Duplex, basket, Class 150, carbon steel, manual selection, stainless steel basket, 9/64" perforation with 40 mesh liner. Hayward Model No. 50
Backflow Preventer	175 psi, screwed bronze body with ball type block valves. The unit must be approved by the Washington State Board of Health. Watts Regulator Series 909-QT

ECN-112

ECN-112

ECN-805

ECN-127

PIPE CODE M-7 (Safety Class 3 General Service)			
Service	Max Operating Pressure	Test Pressure	Max Operating Temp
Instrument Air (IA)	100 psig	150 110 psig	100°F
Sizes	1-1/2" and smaller		
Pipe	Carbon steel, ASTM A 53, Type E, Grade B or ASTM A 106, Grade B.		
Wall Thickness	Schedule 40		
Nipples	Schedule 40, close or butt not permitted.		
Fittings (1)	Class 150 malleable iron, ASTM A 47, Grade 32510 or 35018 or ASTM A 197 threaded in accordance with ASME B16.3.		
Unions	Class 150 malleable iron, ASTM A 47, Grade 32510 or 35018 or ASTM A 197 threaded in accordance with ASME B16.3, bronze to iron seat. (No buried unions.)		
(1) For inaccessible or underground lines use wrought steel butt welding in accordance with ASME B16.9, material in accordance with ASTM A 234, Grade WPB, wall thickness to match pipe.			

PIPE CODE M-9 (Safety Class 2 Safety Significant)			
Service	Max Operating Pressure		180°F
	Test Pressure	480 psig	
Supernate (SN) and Slurry (SL)		320 psig	
Sizes		4" and smaller	
Pipe		Stainless steel, ASTM A 312, Grade TP 304L, seamless.	
Wall Thickness		Schedule 40S	
Fittings		Stainless steel, ASTM A 403, Class WP 304L, buttwelding in accordance with MSS-SP 43 B16.9, wall thickness to match pipe.	

ECN-085

ECN-805

ECN-127

PIPE CODE M-26a (Safety Class 3 General Service)			
Service	Max. Operating Pressure	Test Pressure	Max. Operating Temperature
Supernate line Encasement (ENC) and Slurry Line Encasement (ENC)	320 Psig	480 352 Psig	180°F
Size	All		
Pipe	Carbon steel, ASTM A 106, Grade B		
Wall Thickness	Schedule 40		
Fittings	Wrought carbon steel, ASTM A 234, Grade WPB, butt welding in accordance with ANSI B16.9 (schedule to match pipe).		

TURBINE FLOWMETERS
(Based on ISA S20.24)

METER

1. Tag Number:	FE 1361			
2. Service:	WATER FLOW TOTALIZER			
3. Meter Location:	2" RAW M5			
4. Line Size:	2"			
5. End Connections:	2" 300 LB RF			
6. Body Rating:	250 PSIG/250 °F			
7. Nominal Flow	8 305 GPM			
8. Accuracy:	1/ 1% FS			
12. Matl, Body:	CAST IRON			
13. Support:	MFG STD			
14. Shaft:	MFG STD			
15. Flanges:	MFG STD			
16. Rotor:	POLYAMID			
17. Bearings, Type:	MFG STD			
18. Bearing Material:	MFG STD			
19. Max Speed:	51.1 MZ/Sec			
20. Min Output Voltage:	MFG STD			
21. Pickoff Type:	MFG STD			
22. Enclosure Class:	NEMA 12			

FLUID DATA

24. Fluid:	WATER			
25. Min/Max Flow Rate:	8 to 305 GPM			
26. Normal Flow:	200 GPM			
27. Oper Pressure:	160 Psig			
29. Min/Max Oper Temp:	40 100 °F			
30. Operating Sp Gr:	1.0 at 60°F			

ECN-413

POSITIVE DISPLACEMENT METERS
 (Based on ISA S20.25)

1. Tag Number:	FE/FT-1361	
2. Service:	RAW WATER	
3. Line/Vessel No.:	2" RAW-601-M5	

METER

4. Type of Element:	Disk	
5. Size:	2"	
6. End Connections:	Female NPT	
7. Rating, Temp.	70° F	
Press.	150 psig maximum	
8. Flow Rate Range:	8 to 150 gpm (nominal)	
9. Totalized Units:	Gallons	
10. Enclosure Class:	NEMA 4 Watertight	
12. Materials		
Outer Housing:	Bronze	
13. Main Body Cover:	Mfr Std	
14. Rotating Element:	Mfr Std	
15. Shaft:	Mfr Std	
16. Blades:	Mfr Std	
17. Bearings, Type:	Mfr Std	
Matl:	Mfr Std	
18. Packing:	Mfr Std	
19. Type of Coupling:	Mfr Std	

FLUID DATA

27. Fluid:	RAW WATER	
28. Min Flow Rate:	0 gpm	
Max Flow Rate:	150 gpm	
29. Normal Flow:	8 gpm	
30. Opr Press:	150 psig	
Temp:	70° F	
31. Opr Sp Gr:	1.0	
32. Opr Viscosity:	1 cp	
33. Coef of Expansion:	N/A	

OPTIONS

34. Flow Units:	Gallons	
38. Transmitter Type:	Frequency converter	
39. Transmitter		
Output:	4-20 mA dc & pulse output (open collector transistor)	
42. Enclosure:	NEMA 4 Watertight	

ECN-413

Y 0101

ECN-413

Sheet 2 of 2

TURBINE FLOWMETERS
(Based on ISA S20.24)

SECONDARY INSTRUMENT

34. Tag Number: F01T 1361

36. Function: TOTALIZER

37. Mounting: WALL MTD

38. Power Supply: 115 V ac, 60 Hz

39. Scale Range: MFG STD

40. Output Range: 4-20 mA

OPTIONS

41. Totalizer Type: See Note 2

44. Enclosure Class: MFG STD

49. Manufacturer: Hersey Instrument or an approved substitute

50. Meter Model Number: 211/840/860

51. Ind/Totalizer

Mod No.: 1030W/115

- NOTES: 1. Items 9 through 11, 23, 28, 31 through 33, 35, 42, 43 and 45 through 48 are not required.
2. Electronic alpha numeric display, 10 digit with user selectable flow units (gallons, liters), resettable.

ECN-413

Sheet 2 of 2

POSITIVE DISPLACEMENT METERS
(Based on ISA S20.25)

43. Mounting:	Integral with meter	
44. Electrical Conn:	1/2" NPT	
45. Manufacturer:	Badger Meter Inc/Industrial	
46. Model Number:	M-120 W/PFT420	

NOTES: 1. Items 3, 11, 20 through 26, 35 through 37, 40 and 41 are not required.

2. Accuracy: $\pm 2\%$ of full scale.

ECN-413

Project No. W-320

Project Title Tank 241-C-106 Sluicing

Specification Section 15493

APPROVAL DATA LIST ("X" Indicates Required Data)

1	2	3	4	5	DATA							6		
EPI IDENTIFICATION	DESCRIPTION	REFERENCE DRAWING	SPECIFICATION PARAGRAPH	Dimensional	Drawings	Equipment Weights	Specifications	Material Description	Performance	Circuit or Control Diagrams	Data Sheets	Illustrative Cuts	Installation Instructions	REMARKS
45-1341 and 4412-1341 FE/FT-1361	Turbine Meter and Turbine Meter Totalizer Positive Displacement Meter		Y-0101	X			X			X	X	X		ECN-413
	Ball Valves		Pipe Code M-5	X		X	X	X			X	X	X	ECN-413
	Duplex Strainers		Pipe Code M-5	X		X	X	X			X	X	X	ECN-127
	Backflow Preventer		Pipe Code M-5	X		X	X	X			X	X	X	ECN-127
	Gaskets		Pipe Code M-5											X (MSDS) ECN-085
	Protective Coating		3-1-6											X (MSDS) ECN-085

[illegible]

NDE/WELD RECORD

(KEH-0433.00)

HNF-2532, Rev. 0

Page 85

NONDESTRUCTIVE EXAMINATION/TESTING REQUIREMENTS FOR PIPING SYSTEMS

(KEH-0433.00R)

HNF-2532, Rev. 0

Page 86

LEAK/PRESSURE TEST CERTIFICATION

(KEH-1757.01)

Page 1 of 2
HNF-2532, Rev. 0
Page 87

LEAK/PRESSURE TEST CERTIFICATION

(KEH-1757.02)

Page 2 of 2
HNF-2532, Rev. 0
Page 88

END OF SECTION

APPENDIX A - IDENTIFICATION OF PIPING SYSTEMS

1. GENERAL

The identification of piping systems shall be in accordance with the American Standard Scheme for the Identification of Piping Systems, ANSI A13.1, as supplemented herein.

2. LOCATION

a. Except as provided below, identification shall be located adjacent to outlets, valves, flanges, unions, changes-in-direction, where pipes pass through walls, floors, or ceilings, and along an uninterrupted length of pipe at maximum intervals of 50 feet. Each line or branch in a room shall have at least one identification.

b. Where a number of outlets, valves, flanges, unions, or changes of direction make identification at each item impracticable, they may be spaced at approximate 6 foot intervals, preferably adjacent to valves.

c. Legend shall be located on the pipe so that it can be read easily from the operator's normal viewing position. Labels shall be placed on the readily visible lower quadrant of overhead pipes, and on an upper quadrant of pipes below normal eye level. Above ceilings, labels shall be placed in locations most readily visible from access positions.

3. LEGEND

a. Positive identification of a piping system content shall be by lettered legend giving the name of the content in full or abbreviated form. Legends may also be as specified on drawings or in other specifications.

b. Abbreviation of words in the legend may be used only where unavoidable due to space limitations.

c. The legend shall include the nominal operating pressure for steam, compressed air, and when specified, the pressure or temperature for other materials.

d. An arrow indicating the direction of flow shall be placed near the legend on pipes normally having a flow in one direction only. The color and size of the arrow shall be consistent with the color and size of the legend letters.

e. Legend shall be located on or adjacent to the classification color band.

4. APPROVED LABELS

a. Legend and color classification may be accomplished by the use of approved labels conforming to this Standard and which are suitable for the temperature of the surface to which they are to be applied. Approved labels include the following.

ALL-TEMPERATURE PIPE MARKERS
W. H. Brady Company
727 West Glendale Avenue
Milwaukee, Wisconsin 53201

TEL-A-PIPES
Westline Products Division
Thomas & Betts Company
220 South Rose Street
Los Angeles, California 90012

b. Single-word labels may be combined to form complete legends. Individual-letter labels shall not be so combined.

c. Labels shall be installed after painting is complete.

5. CLASSIFICATION COLOR

a. When use of classification colors is specified, they shall conform to Table 1.

Table 1			
Classification	Band or Label Color	Legend/Arrow Color	Approximate Color No. (FED-STD-595)
Dangerous	Yellow	Black (17038)	13655 (yellow)
Safe	Green	Black (17038)	14260 (green)

b. Paint, if used, shall conform to FS TT-E-489, Class A, for synthetic gloss enamel.

c. Classification colors shall conform to Table 2.

Table 2. Classification Colors.	
Material	Color
Steam	Yellow
Sanitary Water (SW)	Green
Process Sodium Hydroxide (NaOH)	Yellow
Raw Water (RW)	Green

END OF APPENDIX

SECTION 15500

HEATING, VENTILATING, AND AIR CONDITIONING

PART 1 - GENERAL

1.1 REFERENCES

1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.

1.1.1.1 Air Movement and Control Association (AMCA)
210-85 Laboratory Methods of Testing Fans for
Rating Purposes

1.1.1.2 Underwriters Laboratories (UL)
Building Materials Directory 1993

1.2 SUBMITTALS

1.2.1 See Section 01300 of W-030-G2 for submittal procedures.

1.2.2 Approval Required

1.2.2.1 Approval data: Before delivery, submit information listed in the Approval Data List in this Section.

1.2.3 Approval Not Required

1.2.3.1 Vendor information: Before installation, submit information listed in the Vendor Information List in this Section.

1.2.3.2 Test data: Within 10 days after completion, submit the test data report specified in 3.2.1, dated and signed by the contractor who performed testing.

1.3 QUALITY ASSURANCE

1.3.1 Contractor's Quality Assurance Program: See Section 01400 of W-030-G2. Hold and Witness Point Schedule para 1.7 is not applicable to this Section 15500 work.

1.4 DELIVERY, STORAGE, AND HANDLING

1.4.1 See Section 01610 of W-030-G2 for general requirements.

1.4.2 Damaged or defaced equipment may be repaired, if repairs are acceptable to ICF KH.

PART 2 - PRODUCTS

2.1 SUBSTITUTES

2.1.1 See Section 01630 of W-030-G2 for substitution approvals.

2.2 EQUIPMENT

2.2.1 Centrifugal Wall Ventilator (FN-1363): 1/8 hp, 1640 rpm, 478 ft³/min minimum at 3/8 inH₂O. The ventilator shall be the direct drive type. The motor shall be Class 1, Group D, explosion proof. Bearings shall be permanently lubricated and sealed. The ventilator shall be AMCA certified, licensed to bear the AMCA seal, and UL listed. COOK Type ACW-D Model No. 100W15DM with bird screen, or an approved substitute.

2.2.2 Exhaust Damper: Frame shall be 21 by 21 inches, 0.0516-inch (18-gage) galvanized steel, flangeless for indoor ductwork, with an adjustable return spring. Greenheck Model WD-400 or an approved substitute.

2.2.3 Electric Thermostat (TC 13629 8): Adjustable between ~~60~~ 40 and ~~120~~ 90°F; Chromalox Model WR-80EP or an approved substitute. ECN-197
ECN-197

2.2.4 Intake Damper: Operated by pressure differential to open, and adjusted to open when pressure differential in building drops below 0.1 inH₂O. Damper frames shall be 18-gage galvanized steel with prepunched mounting holes. Unit shall be 16 inches wide by 16 inches high. Frame shall include 16 inches high by 16 inches wide by 7 inch extension. Extension will provide filter sleeve, equipped with a 2 inch Farr 30/30 filter (F-1366), or approved substitute, with filter access door and snap latches. Blades shall be 0.025 roll formed aluminum with vinyl seals on the closing edges. Axles shall be 3/16-inch diameter zinc plated steel mounted in acetal bushings. Greenheck Model WD-400 or an approved substitute.

2.2.5 Wall Mounted Space Heater (HC-1363): UL listed, 120 V, 2 KW, with adjustable thermostat that can be set from ~~40~~ 55 to ~~90~~ 105°F. ECN-197
Chromalox Type HVT-24XX or an approved substitute.

2.2.6 Air Inlet Louver: Stationary type, 16 by 16 inches with flange. Each factory assembled louver section shall have been designed to withstand 25 lb/ft² wind loading. Louver shall be equipped with a framed, removable, rear mounted screen of 3/4- by 0.051-inch expanded, flattened aluminum, and have a standard mill finish. Greenheck Model ESJ-201 or an approved substitute.

2.2.7 Equipment nameplates: Laminated plastic, 1/16-inch thick with white surface and black core. Edges beveled and smooth. Engraved nomenclature sharp and clear. Provide nameplates for FN-1363, TC-13616, and HC-1363.

- 2.2.8 Nameplate Attachments: Use screws or rivets where drilling will not cause damage, otherwise use cement. If plastic nameplate is not suitable for installation directly on equipment, use twisted wire, using enough wire to produce 1-inch minimum installed lengths.

PART 3 - EXECUTION

3.1 INSTALLATION

- 3.1.1 Install equipment where shown on the Drawings, in accordance with manufacturer's instructions.

- 3.1.2 Wire the thermostat to the ventilator.

3.2 FIELD QUALITY CONTROL

3.2.1 Testing HVAC Systems

- 3.2.1.1 Before operating equipment perform a thorough check verifying that systems have been properly cleaned and equipment has been properly installed, lubricated, and serviced.

- 3.2.1.2 After the ventilator fan system is installed, place ventilator in operation in accordance with manufacturer's instructions. Verify ventilator is fully operational by resetting the temperature set point so that ventilator is in operation. After verification, return the temperature setpoint to 85°F.

- 3.2.1.3 After Electric Heater is installed, adjust thermostat control and verify unit is fully operational. After verification, return the thermostat control setpoint to 50°F.

- 3.2.1.4 Prepare a test data report.

[illegible]

Specification Section 15500

VENDOR INFORMATION LIST
("X" Indicates Required Data)

[illegible]

SECTION 16400
SERVICE AND DISTRIBUTION

PART I - GENERAL

1.1 REFERENCES

- 1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.
- 1.1.1.1 American National Standards Institute (ANSI)
C80.1-1990	Rigid Steel Conduit--Zinc Coated
C80.3-1983	Electrical Metallic Tubing-Zinc Coated
C82.1c-1990	Fluorescent Lamp Ballasts
- 1.1.1.2 Factory Mutual System (FM)
Approval Guide	1993 Edition
- 1.1.1.3 Federal Specifications (FS)
W-C-375B/
NOT 1	Circuit Breakers, Molded Case; Branch
Circuit And Service
W-F-406E	Fittings For Cable, Power, Electrical
And Conduit, Metal, Flexible
W-S-896E
AMD 2
NOT 1	Switches, Toggle (Toggle And Locks),
Flush Mounted (General Specification)
TT-S-00230	Sealing Compound: Elastomeric Type,
Single Component (For Calking, Sealing,
And Glazing In Buildings And Other
Structures)
WW-C-566C	Conduit, Metal, Flexible
- 1.1.1.4 Institute of Electrical and Electronic Engineers (IEEE)
587-1980	Guide for Surge Voltages in Low-Voltage
AC Power Circuits |
|----------|--|
- 1.1.1.5 National Electrical Manufacturers Association (NEMA)
FB 1-1988	Fittings, Cast Metal Boxes,
and Conduit Bodies for Conduit and
Cable Assemblies
FU 1-1986	Low Voltage Cartridge Fuses

ICS 6-1988
Rev. 1

Enclosures for Industrial
Controls and Systems

KS 1-1990

Enclosed Switches

RN 1-1989

Polyvinyl-Chloride (PVC)
Externally Coated Galvanized Rigid
Steel Conduit and Intermediate Metal
Conduit

ST 20-1986

Dry-Type Transformers for General
Applications

WD 1-1983 (R 1989)

General Requirements for Wiring Devices

1.1.1.6 National Fire Protection Association (NFPA)

70 (1993)

National Electrical Code

101 (1994)

Code for Safety to Life From Fire in
Buildings and Structures

1.1.1.7 Underwriters Laboratories (UL)

Electrical Appliance and
Utilization Equipment Directory

1993

Electrical Construction
Materials Directory

1993

Fire Resistance Directory

1993 (Vol I & II)

797-1993

Electrical Metallic Tubing

1.2 SUBMITTALS

1.2.1 See Section 01300 of W-030-G2 for submittal procedures.

1.2.2 Approval Required: None

1.2.3 Approval Not Required

1.2.3.1 Vendor information: Before installation, submit information listed in the Vendor Information List in this Section.

1.3 QUALITY ASSURANCE

1.3.1 Contractor's Quality Assurance Program: See Section 01400 of W-030-G2.

1.3.2 Electrical/Electronic Product Acceptability

1.3.2.1 Products shall be identified (listed) for their intended use in one of the following, and bear the organization's label.

a. UL Electrical Construction Materials Directory

- b. UL Electrical Appliance and Utilization Equipment Directory
- c. FM Approval Guide

In the absence of a label, submit documentation that verifies product listing.

- 1.3.2.2 When products with one of the above listings are not available, products tested and certified by another agency are acceptable, provided that the following conditions are satisfied.
 - a. The agency has been qualified for product testing in accordance with a national code or standard, and is nationally recognized.
 - b. Product testing was accomplished in accordance with a national code or standard.
- 1.3.3 Misrepresented Products: See Section 01400 of W-030-G2 for required measures to prevent the use of misrepresented products.
- 1.3.4 Deliverable Documentation: The following documents and records, required by this Section, shall be delivered to ICF KH in accordance with Section 01720 of W-030-G2.

Document

Paragraph

Electrical Test Results

3.3.1.1

1.4 DELIVERY, STORAGE, AND HANDLING

- 1.4.1 See Section 01610 of W-030-G2 for general requirements.

PART 2 - PRODUCTS

2.1 SUBSTITUTES

- 2.1.1 See Section 01630 of W-030-G2 for substitution approvals.

2.2 MATERIALS

- 2.2.1 Solderless Connectors and Terminal Lugs: Pressure type, rated for use with copper or aluminum conductors, with insulating caps or covers rated for system utilization voltage. Connectors shall be types specified below.

- 2.2.1.1 For conductors No. 8 AWG and smaller:

- a. Ideal Industries, Incorporated "Wire-Nuts."
- b. Thomas and Betts Company "Sta-Kon."
- c. 3M Company "Scotchlok."

2.2.1.2 For conductors No. 6 AWG and larger:

- a. Burndy Engineering Company "Screw Pressure Connectors" or "Hydent."
- b. Thomas and Betts Company "Lock-tite."

2.2.2 Conduit, Fittings, and Boxes

2.2.2.1 Conduit: ANSI C80.1, C80.3, FS WW-C-566C, and UL 797.

2.2.2.2 PVC coating on rigid steel conduit: NEMA RN 1, Type A-40, factory applied.

2.2.2.3 Flexible metal conduit shall have an integral ground conductor.

2.2.2.4 Fittings for rigid steel and EMT conduit: NEMA FB 1. Use compression type, threadless fittings with EMT.

2.2.2.5 Fittings for flexible metal conduit: FS W-F-406E, squeeze type.

2.2.2.6 Use "Myers" type watertight fittings, or sealing type locknuts, for conduit entries into side or top of the NEMA ICS 6 Type 4 enclosure.

2.2.2.7 Interior lighting fixture outlet boxes: 4-inch octagonal pressed steel.

2.2.2.8 Exterior lighting fixture outlet boxes: Cast with threaded hubs.

2.2.2.9 Interior light switch and receptacle boxes: 4 by 2-1/8 by 2-1/8-inches deep steel box, with conduit knockouts; Steel City Model No. 58371- $\frac{3}{4}$ (WESCO No. 78-5991-17955).

2.2.3 Conductors: Stranded copper with Type THWN/THHN or XHHW insulation, of type and AWG size specified on the Drawings.

2.2.4 Wiremarkers: Imprinted tubular plastic.

2.2.5 Wire Pulling Compound: Electro Compound Company "Y-er Eas," or American Polywater Corporation "Polywater."

2.2.6 Tape

2.2.6.1 Plastic insulating tape: 3M Company "Scotch No. 33+."

2.2.6.2 Conduit protection tape: 3M Company "Scotchrap No. 50."

2.2.7 Insulating Putty: 3M Company "Scotchfil," General Electric Company No. 8389, or Kearney Company "Airseal."

2.2.8 Duct Sealing Compound: Porcelain Products Company "Sealex."

2.2.9 Penetration Sealants: RTV Silicone foam; Semco "PR855 RTV", Dow Corning "Type 3-6548 RTV", or General Electric "Type RTV 800."

- 2.2.10 Supports
 - 2.2.10.1 Individual conduit hangers: Factory made springable wrought steel clamps, or malleable iron split and hinged rings.
 - 2.2.10.2 Lighting fixture and equipment supports: 1-1/2-inch channel; Unistrut or Kindorf.
 - 2.2.10.3 Expansion Anchors: Hilti Fastening Systems "Kwik-Bolt II", or ITW-Ramset "Trubolt Wedge Anchor."
 - 2.2.11 Equipment Nameplates: Laminated plastic, 1/16-inch thick with white surface and black core. Edges beveled and smooth. Engraved nomenclature sharp and clear.
- 2.3 EQUIPMENT
 - 2.3.1 Electrical equipment shall be PCB free.
 - 2.3.2 Equipment enclosures: NEMA ICS 6 Type 3, 3R or 4 as shown on the Drawings.
 - 2.3.3 Mini-Power Center: Rated as shown on the drawings, with manufacturer's standard full capacity taps and insulation, in accordance with UL 1062. Surface mounted as shown on the Drawings.
 - 2.3.3.1 Provide with main circuit breaker.
 - 2.3.3.2 Branch circuit breakers: FS W-C-375B molded case manufacturer's type, with thermal magnetic trips. Number, rating, and arrangement are shown on the Drawings.
 - a. Permanently number branch circuits. Number tabs shall not be attached to, or be part of, circuit breaker.
 - b. Branch circuit breaker positions marked "space": Bussed for future circuit breakers. Provide removable single pole filler plates for spaces shown on drawings.
 - c. Provide a directory card holder and card for branch circuit load identification.
 - 2.3.4 Disconnect Switches: NEMA KS 1, fusible heavy duty Type HD, horsepower rated for 600 V ac as noted on the Drawings. Building Service Disconnect shall be 3-pole with grounding lug and solid neutral assembly in NEMA 4 enclosure and rated as service entrance equipment.

2.3.5 Lighting Fixtures: Furnish with parts and fittings necessary to install in accordance with manufacturer's instructions.

2.3.5.1 Fixture types:

- a. Indoor: Industrial type fluorescent fixture with two 40 W lamps, rapid start ballast, and gasketed acrylic prismatic lens suitable for use in wet or corrosive atmospheres, as shown on the Drawings.
- b. Outdoor: Low Pressure Sodium lamp with 120 V ballast, globe, guard and bracket mounting as shown on the Drawings.

2.3.5.2 Photoelectric cell controls: Diecast aluminum weatherproof housing with hermetically sealed light sensitive element, having manually adjustable light level slide with turn-on range of 2 foot-candles.

2.3.6 Receptacles: NEMA WD 1 Designation 5-15R, duplex, ivory, GFCI, weatherproof, rated 15 A, 120 V, 3-wire, grounding type, with screw terminals arranged for side wiring. Self-grounding receptacles may be used.

2.3.7 Toggle Switches: FS W-S-896E, weatherproof, rated 20 A, 277 V, with conventional handles, and screw terminals arranged for side wiring; Perfect Line Model No. SW20-1 (WESCO No. 78-5055-20062).

2.3.8 Receptacle Plates: Vertical device mount cover, for GFI single receptacle; Red Dot Model No. CCGV (WESCO No. 04-2269-35022).

PART 3 - EXECUTION

3.1 PREPARATION

3.1.1 Field Measurements: Drawings show desired approximate locations of equipment. Actual locations, distances, and levels shall be governed by field conditions.

3.2 INSTALLATION

3.2.1 General

3.2.1.1 Perform work in accordance with NFPA 70.

3.2.1.2 Fasten equipment to structural members of building or metal supports attached to structure, or to concrete surfaces.

- a. Use clamping devices for attaching to structural steel, or, when clamping is impracticable, obtain written permission from ICF KH to weld, drill, or cut structural members for attachments.

- b. Fasten equipment to concrete or masonry with expansion anchors.

- c. Attach to drywall by screws into studs, and to metal wall panels by weld studs, bolts, or self-tapping metal screws.

d. Locate equipment, boxes, and conduit approximately where shown in relation to equipment served.

e. Do not install conduit raceways and boxes in positions that interfere with work done by other trades.

f. Identify components with nameplates bearing legends shown on the Drawings.

g. Attach nameplates on or near equipment, with metal screws. Attach panelboard nameplate on front, above door.

3.2.1.3 Use appropriate calibrated special tools, recommended by manufacturers, when installing unusual or unique devices or systems.

3.2.2 Grounding Systems

3.2.2.1 Underground conductors, electrodes, and connections: Install in accordance with the Drawings. Make joints connecting copper and galvanized steel conductors above grade and in dry locations. Connections may be made with exothermic welds or ground rod clamps.

3.2.2.2 System and equipment grounding: Solidly ground the neutral conductor of 3-wire, 1-phase and 4-wire, 3-phase, wye-connected distribution systems. Ground equipment in accordance with NFPA 70.

3.2.2.3 Static grounding: Ground steel building columns to the grid, as shown on the Drawings.

3.2.3 Conduit

3.2.3.1 Use rigid steel where subject to mechanical damage, or installed in concrete floors and walls, or exposed to weather. Electrical metallic tubing may be used elsewhere.

3.2.3.2 Install concealed conduits as directly as possible and with bend radii as long as possible. Install exposed conduit parallel with or at right angles to building lines.

3.2.3.3 Make elbows, offsets, and bends uniform and symmetrical. Bend conduit with approved bending devices.

3.2.3.4 Cut conduit ends square, ream, and remove burrs. Conduit shall be clean, dry, and free of debris. Immediately after installation, plug or cap exposed ends with standard accessories until wires are installed.

3.2.3.5 Use 1-hole clamps equipped with clampbacks, or Unistrut with clamps, to secure conduits.

3.2.3.6 Flexible conduit:

a. Use to make connections to motors and other equipment subject to vibration. Use liquidtight flexible metal conduit where conduit and fittings are installed outdoors or exposed to moisture or chemical fumes indoors.

b. Use in 4 foot maximum lengths for other equipment, with approval of ICF KH.

c. Use for fluorescent lighting fixtures in lengths up to 6 feet.

- 3.2.3.7 Seal openings around conduit at exterior wall penetrations and penetrations of walls which form boundaries between adjoining ventilation zones, using specified sealant. Make seals waterproof, and finish sealant flush with surrounding wall surfaces.
- 3.2.3.8 Where routing is parallel with hot water or steam pipes, maintain 6 inches minimum clearance from pipe covering. Where not run parallel with pipe, it is acceptable to run closer than 6 inches, providing conduit does not touch pipe covering.
- 3.2.3.9 Install PVC coated conduit in accordance with manufacturer's recommendations. Repair coating, damaged during handling or installation using PVC paint recommended by conduit manufacturer.
- 3.2.4 Boxes, Enclosures, and Wiring Devices
- 3.2.4.1 Install boxes firmly in position and plumb.
- 3.2.4.2 Install extension ring with blank cover on flush mounted junction boxes where box serves permanently installed equipment.
- 3.2.4.3 Flush mount junction boxes served by concealed conduit.
- 3.2.4.4 Install dust covers on junction, pull, and outlet boxes, and other types of wiring outlets at initial installation. Replace with permanent covers or devices after wires are installed.
- 3.2.5 Conductors
- 3.2.5.1 Do not bend cables installed in wireways to less than manufacturer's recommended minimum bending radii. Bind power and control circuits separately with nylon cable ties, at 18-inch intervals. Lay cables in wireways in straight parallel lines, and avoid crossing.
- 3.2.5.2 Identify conductors, by wire numbers shown on the Drawings, with wiremarkers. Attach wiremarkers at termination points within 2 inches of wire terminations. Marker nomenclature shall be visible without moving wires or markers.
- 3.2.5.3 Paint or pressure-sensitive colored tape may be used for coding conductors instead of colored insulation on No. 8 AWG and larger wire for phase (ungrounded) conductors, and No. 4 AWG and larger wire for neutral (grounded) conductors and equipment grounding conductors only. Maintain phase color coding, in accordance with the following table, for branch and feeder circuits up to and including equipment connections. Use colored tape to properly code existing conductors whose color does not comply.

Conductor Origin	Conductor	Insulation Color
480Y/277 V, 3-phase systems, transformers, panels	Phase A Phase B Phase C Neutral Equipment ground	Red Orange Black White or Gray Green (or bare)
120/240 V, single-phase transformers, panels, switchboards, etc.	Hot Number 1 Hot Number 2 Neutral Equipment ground	Black Red White or Gray Green (or bare)

- 3.2.5.4 Use lubricant recommended by the cable manufacturer, or wire pulling compound specified, when pulling wire and cable through conduit.
- 3.2.5.5 Do not install or handle wires with thermoplastic insulation or jacket when ambient temperature is 15°F or below.
- 3.2.5.6 Install and mark direct burial cable in accordance with the Drawings.
- 3.2.6 Splices, Taps, and Cable Terminations
 - 3.2.6.1 Make splices and taps in building wire with solderless connectors specified in 2.2.1. Use connectors in accordance with the manufacturer's instructions.
 - 3.2.6.2 Use plastic insulating tape for uninsulated splices and taps. Apply tape to thickness at least equal to conductor insulation. Where bolted splice or connection presents irregular surface, apply insulating putty to joints before taping.
 - 3.2.6.3 Use crimp-on type ring or spade lugs with turned up legs for wire terminations of stranded conductors to binder screw or stud type terminals. Lugs shall have insulated sleeves.
- 3.2.7 Lighting Fixtures: Mount suspended fixtures as shown on the Drawings. Use fixture stud if lighting fixture is suspended from outlet box.
- 3.2.8 Motor Operated Equipment: Connect fan in accordance with the Drawings, this Section, and manufacturer's instructions. Install wiring to devices which do not appear on the Drawings, but are included in installation shown on the manufacturer's drawings.
- 3.3 FIELD QUALITY CONTROL
 - 3.3.1 Testing
 - 3.3.1.1 Furnish equipment and instruments required to perform testing.
 - 3.3.1.2 Test equipment and wiring for continuity and unintentional grounds, and verify proper phase sequence and voltage at equipment served before attempts are made to operate equipment. Notify ICF KH before start of tests. Record the results.

a. Megger conductors rated 600 V and used for services, feeders or branch circuits over 150 V to ground, phase-to-phase, and phase-to-ground. Minimum acceptable value of insulation resistance is 200 megohms. The megger manufacturer's instruction booklet, furnished with megger, shall be used for conducting tests. Disconnect devices not capable of withstanding voltage or current of megger test, such as indicating instruments, relays and lamps, before test is made. Voltage output of megger shall be 1000 V dc nominal.

b. Test wiring operating at less than 150 V to ground for continuity and unintentional ground. Resistance shall not exceed 1 ohm on continuity checks.

3.3.1.3 Motors: Check for correct rotation.

3.3.2 Reconnect devices disconnected during testing.

Specification Section 16400

("X" Indicates Required Data)

[illegible]Page 106
HNF-25B2, Rev. 0

SECTION 16640
CATHODIC PROTECTION

PART 1 - GENERAL

1.1 REFERENCES

- 1.1.1 The following documents, including others referenced therein, form part of this Section to the extent designated herein.
- 1.1.1.1 American National Standards Institute (ANSI)
C80.1-1990 Rigid Steel Conduit--Zinc Coated
- 1.1.1.2 American Society for Testing and Materials (ASTM)
- B 8-90 Concentric-Lay-Stranded Copper Conductors, Hard, Medium-Hard, or Soft
- C 518-91 Test Method for Steady-State Heat Flux Measurements and Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus
- D 1621-73 (1979) Test Method for Compressive Properties of Rigid Cellular Plastics
- D 1622-88 Test Method for Apparent Density of Rigid Cellular Plastics
- D 2842-69 (1990) Test Method for Water Absorption of Rigid Cellular Plastics
- D 2856-87 Test Method for Open Cell Content of Rigid Cellular Plastics by the Air Pycnometer
- 1.1.1.3 Factory Mutual System (FM)
Approval Guide 1993 Addition
- 1.1.1.4 Federal Specifications (FS)
- W-C-1094A Conduit And Conduit Fittings Plastic, Rigid
- W-F-406E Fittings For Cable, Power, Electrical And Conduit, Metal, Flexible

TT-S-00230C
AMD 2

Sealing Compound: Elastomeric
Type, Single Component (For Caulking,
Sealing, And Glazing In Buildings And
Other Structures)

WW-C-566C

Conduit, Metal, Flexible

1.1.1.5 National Electrical Manufacturers Association (NEMA)

FB 1-1988

Fittings, Cast Metal Boxes,
and Conduit Bodies for Conduit and
Cable Assemblies

FU 1-1986

Low Voltage Cartridge Fuses

ICS 6-1988
Rev. 1

Enclosures for Industrial
Controls and Systems

KS 1-1990

Enclosed Switches

RN 1-1989

Polyvinyl-Chloride (PVC)
Externally Coated Galvanized Rigid
Steel Conduit and Intermediate Metal
Conduit

WC 5-1973 (R 1985)

Thermoplastic-Insulated Wire and Cable
for the Transmission and Distribution
of Electrical Energy

1.1.1.6 National Fire Protection Association (NFPA)

70 (1993)

National Electrical Code

1.1.1.7 Underwriters Laboratories (UL)

Electrical Appliance and 1993
Utilization Equipment Directory

Electrical Construction 1993
Materials Directory

1.2 SUBMITTALS

1.2.1 See Section 01300 of W-030-G2 for submittal procedures.

1.2.2 Approval Required

1.2.2.1 Approval data: Before delivery, submit information listed in the
Approval Data List in this Section.

1.2.2.2 Test Station Sketches: Before installation, submit sketches required in
3.2.3.3.

1.2.3 Approval Not Required

1.2.3.1 Vendor information: Before installation, submit information listed in the Vendor Information List in this Section.

1.3 QUALITY ASSURANCE

1.3.1 Contractor's Quality Assurance Program: See Section 01400 of W-030-G2.

1.3.2 Electrical/Electronic Product Acceptability

1.3.2.1 Products shall be identified (listed) for their intended use in one of the following, and bear the organization's label.

- a. UL Electrical Construction Materials Directory
- b. UL Electrical Appliance and Utilization Equipment Directory
- c. FM Approval Guide

In the absence of a label, submit documentation that verifies product listing.

1.3.2.2 When products with one of the above listings are not available, products tested and certified by another agency are acceptable, provided that the following conditions are satisfied.

- a. The agency has been qualified for product testing in accordance with a national code or standard, and is nationally recognized.
- b. Product testing was accomplished in accordance with a national code or standard.

1.3.3 Misrepresented Products: See Section 01400 of W-030-G2 for required measures to prevent the use of misrepresented products.

1.3.4 Deliverable Documentation: The following documents and records, required by this Section, shall be delivered to Construction Document Control in accordance with Section 01720 of W-030-G2.

<u>Document</u>	<u>Paragraph</u>
Existing Pipe Exothermic Weld Documents	3.2.6.1c
New Pipe Exothermic Weld Documents	3.2.6.2c
Functional Test of Reference Electrodes	Appendix A

1.4 DELIVERY, STORAGE, AND HANDLING

1.4.1 See Section 01610 of W-030-G2 for general requirements.

PART 2 - PRODUCTS

2.1 SUBSTITUTES

2.1.1 See Section 01630 of W-030-G2 for substitution approvals.

2.2 MATERIALS

2.2.1 Terminal Lugs: Crimp type with ring tongue and insulated sleeve, for wire sizes No. 10 AWG and smaller, non-insulated sleeve for No. 8 AWG and larger, rated for use with copper conductors.

2.2.2 Compression Splice Connectors: For use with cable splice or cable tap, size as required. Burndy Company "Crimpfit."

2.2.3 Exothermic Fusion Weld Mold, Low Emission Type with electric starter, Erico Products "Cadweld," Part Number XLB971A1.

2.2.3.1 Existing Pipe: For connection of pipe test conductors. Size and type as required, Erico Products "Cadweld" or an approved substitute.

a. Exothermic weld metal: Low-emission type as recommended by the weld mold manufacturer.

2.2.3.2 New pipe: For connection of pipe test conductors, bonding jumpers, and negative return cables. Erico Products "Cadweld," Mold Part No. XLLMCEG1H.

a. Exothermic weld metal: Low-emission type, "Cadweld" No. XL No. 90 with igniters and filters.

b. Sleeve for use with No. 8 AWG conductor: "Cadweld" No. CAB-133 1L.

2.2.4 Pipe Ground Clamp Connector: Bronze, size as required, Teledyne Penn-Union, Catalog No. GPL.

2.2.5 Conduit and Fittings

2.2.5.1 Outdoor above ground: ANSI C80.1.

2.2.5.2 Underground power: ANSI C80.1, PVC coated in accordance with NEMA RN 1, Type A-40, factory applied.

2.2.5.3 Underground: For use with test stations and anode junction boxes, FS W-C-1094A, Type II PVC (Schedule 40), 6 inch.

2.2.5.4 Flexible metal and fittings: FS WW-C-566 and FS W-F-406.

2.2.5.5 Fittings for rigid steel conduit: NEMA FB 1.

- 2.2.6 Conductors
 - 2.2.6.1 Direct current (dc): ASTM B 8 and NEMA WC 5 stranded copper, 600 V rating, high molecular weight low density polyethylene, Type "CP." Size as specified on the Drawings.
 - 2.2.6.2 Alternating current (ac): Stranded copper, 600 V rating, Type THHN/THWN insulation. Size as specified on the Drawings.
 - 2.2.6.3 Grounding: Bare solid copper, No. 6 AWG.
 - 2.2.7 Ground Rod: Galvanized steel, 5/8 inch by 8 foot minimum.
 - 2.2.8 Conductor Splice Kit: Scotchcast Brand, Catalog No. 82-B1 and 90-B1.
 - 2.2.9 Tape
 - 2.2.9.1 Plastic insulating: 3/4 inch wide, Scotch No. 88, 3M Company.
 - 2.2.9.2 Electrical splice insulating: Self-vulcanizing rubber, 3/4 inch wide.
 - 2.2.10 Plastic Sheet Marker: Yellow warning tape, 6 inches wide, no printing on tape, Reef Industries.
 - 2.2.11 Insulating Boot: Splice insulator, Thomas and Betts, Type MSC.
 - 2.2.12 Wiremarkers: Tubular plastic, imprinted or typed with indelible ink, or plastic tags typed with indelible ink, fastened securely to wire with plastic wire ties.
 - 2.2.13 Cable Marker: Metal auger, flush with grade type, 17-inch long by 6-inch circular top with raised words "CATHODIC PROTECTION." A.B. Chance Company, Catalog No. C554-0001 with installation tool, Catalog No. CWFA.
 - 2.2.14 Rigid Polyurethane Insulation: Sprayed foam-in-place 2-component system with minimum apparent overall density of 2.4 lb/ft³ in accordance with ASTM D 1622, approximately 95% closed cells in accordance with ASTM D 2856, water absorption approximately 0.05 lb/ft² of surface area in accordance with ASTM D 2842, "k" factor of approximately 0.15 Btu·in/h·ft²·°F at 75°F after aging 10 days at 140°F in accordance with ASTM C 518, and minimum compressive strength of 45 lb/in² parallel to rise and 27 lb/in² perpendicular to rise when tested in accordance with ASTM D 1621. Polythane Systems, Incorporated urethane foam PSI-S200-25 systems, Polymer Development Laboratories, Incorporated 110 system, 3 lb/ft³ density, or Burtin Urethane Corporation "Buc 114", 3 lb/ft³ density.
 - 2.2.15 PVC conduit coating touch-up compound: "Plastic-Bond."
 - 2.2.16 Survey Marker Nameplate: Brass, 2-inch diameter, 5/8-inch by 2-1/2-inch shank, Surveyors Service Company.
 - 2.2.17 Sealant: FS TT-S-00230, clear RTV silicone.

- 2.2.18 Connector: Split bolt. (For use in anode junction boxes.)
- 2.2.19 Duct Sealing Compound: "Sealex," Porcelain Products Company.
- 2.2.20 Equipment Nameplates: Laminated plastic, 1/16-inch thick with white surface and black core. Edges beveled and smooth. Engraved nomenclature sharp and clear.

- 2.2.21 *Liquid epoxy coating, Scotchkote 312 by 3M Company or approved substitute.*

ECN-159
ECN-159

2.3 EQUIPMENT

- 2.3.1 Electrical equipment shall be PCB free.

- 2.3.2 Anodes: High silicon, chromium iron, 2-3/16 by 24 inch with No. 8 AWG stranded copper lead wire having high molecular weight, polyethylene (HMW PE) insulation. Lead length 20 feet. Anodes prepackaged in 8 by 48 inch steel canister with coke breeze backfill. Durichlor 51 Anode Company, Type TAB.

- 2.3.3 Disconnect Switch: NEMA KS 1, heavy duty type, fusible, 240 V ac, 30 A rating, 2-pole with NEMA ICS 6 Type 3R enclosure. Fuses shall be in accordance with NEMA FU 1, cartridge type, dual element, UL Class RK5. Provide with one 15 A fuse and slug for neutral fuse clip.

- 2.3.4 Test station, high impact plastic housing, 9 terminal removable plastic terminal board, removable green cover, 7-3/4 inches in diameter, 5 inches high, Street Fink CP Test Station, manufactured by Cott Manufacturing Company or an approved substitute.

- 2.3.5 Anode Junction Box: Same as Test Station, except terminal board not required.

- 2.3.6 Permanent Underground Reference Electrode: Saturated gelled copper-copper sulfate with cotton bag and backfill mix, 30 year design life, EI Electrochemical Devices, Incorporated, EDI Model UL-CUG-LW020 or an approved substitute. Provide with 20 feet of No. 14 AWG HMW/PE insulated lead wire.

- 2.3.7 Rectifier

- 2.3.7.1 General requirements: Rectifier and associated equipment shall operate and deliver rated capacity, without exceeding temperature limitations specified, when operating in following environment.

a. Operating Environment

- 1) Location: Outdoors in direct sunlight.
- 2) Ambient temperature range: -20 to 131°F.
- 3) Relative humidity: 100%.

- 4) Dust: Exposure to dust particulate (sandstorm).

- 5) Precipitation: Driving rainstorm.
- 6) Snow: Accumulation of sleet or snow.

2.3.7.2 Design Requirements

a. Rating

- 1) Line input voltage: 120 V ac.
- 2) Line frequency: 60 Hz.
- 3) Number of phases: Single-phase.
- 4) Output voltage: 24 V dc.
- 5) Output current: 12 A.

b. Oil-immersed type.

c. Suitable for mounting on concrete slab.

d. Transformer: Separate primary and secondary windings fully rated for maximum capacity. Electrostatic shield between primary and secondary windings.

e. Silicon stacks: Connected in full wave bridge circuit configuration, and rated a minimum of 800 peak inverse volts. Provide voltage surge protection with ac and dc lightning arresters and metal varistors across secondary lines to the stack, and across the dc output of the rectifier. Provide heat sinks sized to keep diode junction and case temperatures below temperatures that could cause failure.

f. Efficiency filter: Incorporate in rectifier to increase efficiency of unit.

g. Enclosure: NEMA ICS 6, Type 4.

h. Current carrying pressure connections, such as terminal studs and current shunt connections, shall have thin layer of conductive grease applied to contact surfaces to prevent oxidation.

2.3.7.3 Construction requirements

a. Construct to permit transformer, stacks and other internal components to be immersed in oil. Inside of enclosure shall be accessible through cover mounted on top. Attach cover to cabinet by hinges and provide with quick-release clamps and padlock clasp or other means of locking cabinet. Provide stop to limit swing of lid when opened. Provide positive, oil-resistant, compressible sealing lid gasket. Cork and sponge materials are not acceptable. Gasket joints shall not have gaps.

- b. Provide panel for mounting terminals, circuit breakers, shunts, etc. Board inside panel shall be micarta or similar insulating material, supported on 4 edges.
- c. Enclosure and appurtenances: Approved for use in specified environmental conditions. Materials and methods used in construction and fabrication of rectifier shall be in accordance with NEMA requirements for specified service. Internal components and connections of rectifier shall be immersed under 3 inches of oil, minimum.
- d. Enclosure shall be steel, provided with oil drain plug. Oil level shall be clearly marked.
- e. Finish enclosure inside and outside with 1 coat of epoxy red oxide primer and 2 coats of gray baked enamel.
- f. Provide engraved, manufacturer's standard nameplates on rectifier. Nameplate information shall include specified rating data.

2.3.7.4 Instrumentation

- a. Combination digital volt-ammeter or separate digital voltmeter and ammeter, rectangular. Scale shall be linear, and range from 0 to 125% minimum of rated voltage and current.
- b. Meter circuit shall have momentary-off-momentary disconnect switch which may be closed by operator when readings are being taken.
- c. Ammeter shunt: Size in accordance with ampere rating of the rectifier.

2.3.7.5 Voltage and current control

- a. Output voltage manually controlled. Transformer taps shall have tap-changing devices for manual operation to permit 18 equal steps minimum of adjustment.
- b. Power supply pulse generator for instant-off potential measurements, 115 V ac, 60 A rating, with terminal lugs sized for No. 4 AWG minimum conductors. MC Miller Company, Catalog No. WFA005 (mount in rectifier control panel).

2.3.7.6 Protection: Furnish with following protective devices and equipment.

- a. AC thermal magnetic input circuit breaker: Mounted within control panel to provide short-circuit and overload protection.
- b. DC fuse: Installed in positive lead. Fuse shall be accessible from front of panel.
- c. DC valve-type arrester: For 150 V maximum line-to-ground fault voltage.

d. AC input surge (lightning) arresters.

e. Ground lug: Installed on cabinet so cabinet may be connected to grounding system. Size ground lug for No. 6 AWG copper ground cable.

2.3.7.7 Output terminals

a. 2 negative and 4 positive stud type terminals mounted on front of control panel, appropriately marked.

b. External shunts on output (positive and negative) circuits indicated above. Output shunts of same rating as ammeter external shunt.

2.4 SOURCE QUALITY CONTROL

2.4.1 Factory test and inspect the rectifier specified in 2.3.6 to establish that design and construction are in accordance with this Section and applicable standards, and to determine that equipment is free from electrical or mechanical defects.

PART 3 - EXECUTION

3.1 PREPARATION

3.1.1 Field Measurements: Scale dimensions on the Drawings show desired and approximate location of equipment, actual locations, distances, and levels shall be governed by field conditions.

3.2 INSTALLATION

3.2.1 General

3.2.1.1 Perform work in accordance with NFPA 70.

3.2.1.2 Use appropriate calibrated special tools when installing devices for which special installation tools are recommended by manufacturer.

3.2.2 Anodes: Install to depth of 7 feet, $\pm$ 6 inches.

3.2.2.1 Use subsurface radar scanning machine to locate underground structures before auguring. Hand auger holes for anodes that are located above or within 4 feet from underground tanks or structures. Power auger may be used for other anodes. Maximum auger size, 12 inches.

3.2.2.2 Lower anodes to bottom of holes by rope, and center within holes. Do not use lead wires to lower anodes. If temporary casings have been used, slowly withdraw casings while backfilling.

3.2.2.3 Backfill by sluicing with water.

3.2.2.4 Repair damaged anode lead wire insulation by encapsulation with epoxy resin using conductor splice kit.

- 3.2.2.5 Connect anode lead conductor to anode header cable using compression splice connector and conductor splice kit.
- 3.2.3 Test Station or Anode Junction Box: Install where shown on the Drawings. Stamp or engrave survey marker nameplate, using 3/16 inch minimum letters, TEST STATION T (numbers shown on the Drawings) or ANODE JUNCTION BOX AJB (number shown on the Drawings).
- 3.2.3.1 Identify terminals in the test station with nameplates. Engrave with pipe designation or words "Reference Electrode." Character height 1/8 inch. Secure nameplates to the terminal board by use of clear RTV silicone sealant.
- 3.2.3.2 Place the test station or anode junction box in the 6-inch PVC conduit, and seal as shown on the Drawings.
- 3.2.3.3 A field sketch of each test station shall be made to show the configuration of new pipes, and existing pipes exposed by the excavation. This sketch shall also show the proposed connection of pipe test conductors, the location of pipe bonding jumpers (if required by the Drawings) and the location of the reference electrode.
- 3.2.4 Permanent Underground Reference Electrode: (See Appendix A for testing before installation.)
- 3.2.4.1 Follow manufacturer's installation instructions. Do not allow the reference electrode to freeze.
- 3.2.4.2 Install reference electrode horizontally, 6 to 12 inches below the outer surface of pipe. For configuration of 2 parallel pipes, install in center of configuration, and not adjacent to or touching any pipelines. The Construction Engineer will assist in positioning reference electrodes if required.
- 3.2.4.3 Bring lead wire to top of hole for termination in test station and install wire marker with words: REFERENCE ELECTRODE.
- 3.2.4.4 Repair damaged lead wire insulation using conductor splice kit.
- 3.2.4.5 Backfill in accordance with Section 02225.
- 3.2.5 Pipe Test Conductors, Bonding Jumpers and Negative Return Cables
- 3.2.5.1 Existing pipes
 - a. Before work commences, have the Construction Engineer verify usage of each pipe to which conductors are to be connected. If pipes are coated, cut window in coating large enough to accommodate exothermic weld mold. Wire brush each pipe and file to bright metal surface, free of oil and dirt. Make exothermic welds of conductors to pipe in accordance with approved manufacturer's instructions, or use ground clamp connectors on nonprotected piping as directed by the Construction Engineer. If ground clamp connectors are used, coat connections using the same materials and installation methods as for exothermic welds. Install bonding jumpers across mechanical pipe joints (such as threaded

couplings or bell and spigot connections) that have test conductors attached with No. 4 AWG copper wire and exothermic welds. Extend bonds to a point 50 feet from the nearest anode.

b. After weld is made, test integrity of connection by tapping side of weld material with hammer. If weld fails, make another weld at least 3 inches from previous attempt.

c. Document pipe test conductor exothermic welds recording identification of test station, pipe identification, and performance of an acceptable visual examination and integrity test.

~~d. At pipe connection, apply clear RTV silicone sealant on exposed copper wire, weld material and bared pipe. Overlap sealant on copper wire insulation, on any pipe coating or on bared pipe a minimum of 1 inch. Smooth sealant by hand.~~

ECN-159

ECN-159

d. At pipe connection, apply liquid epoxy coating on exposed copper wire, weld material and bared pipe. Overlap coating on any pipe coating or on bared pipe a minimum of 1 inch. Wrap exposed copper conductors with electrical splice insulating tape and plastic insulating tape.

ECN-159

ECN-159

e. Conductor size specified on the Drawings.

f. Repair damaged pipe test conductor insulation with 2 half-lapped layers of electrical splice insulating tape and 2 half-lapped layers of plastic insulating tape.

g. Make repairs of foam insulation on pipe with sprayed polyurethane as follows.

1) Install in accordance with manufacturer's recommended procedure.

2) Side-wall retainer may be used to assure uniform width and height of sprayed insulation. Obtain approval of retainer wall installation and materials from the Construction Engineer.

3) Repair opening in flexible duct liner with plastic sheet material similar to existing.

h. Identify the end of each conductor using specified wiremarker with typewritten or imprinted pipe number to which conductor is connected. Label pipe test conductors connected to unidentifiable pipes with pipe size followed by words "U. G. LINE."

i. Use terminal lugs for conductor terminations in test station.

j. Backfill in accordance with Section 02225.

3.2.5.2 New pipes

a. Wire brush each pipe conductor standoff bracket and file to bright metal surface, free of oil and dirt. Make exothermic weld of conductors

to standoff bracket in accordance with approved manufacturer's instructions.

b. After weld is made, test integrity of connection by tapping side of weld material with hammer. If weld fails, make another weld.

c. Document exothermic welds as follows:

1) Pipe test conductors: Identification of test station, pipe identification, and performance of an acceptable visual examination and integrity test.

2) Bonding jumpers and negative return cable: Pipe identification and performance of an acceptable visual examination and integrity test.

~~d. Apply clear RTV silicone sealant on exposed copper wire, weld material and bared conductor standoff bracket. Overlap sealant on copper wire insulation, on any pipe coating or on bared surface a minimum of 1 inch. Smooth sealant by hand.~~

ECN-159

ECN-159

d. Apply liquid epoxy coating on exposed copper wire, weld material and bared conductor standoff bracket. Overlap coating on any pipe coating or on bared surface a minimum of 1 inch. Wrap exposed copper conductor with electrical splice insulating tape and plastic insulating tape.

ECN-159

ECN-159

e. Conductor size specified on the Drawings.

f. Repair damaged pipe test conductor insulation with 2 half-lapped layers of electrical splice insulating tape and 2 half-lapped layers of plastic insulating tape.

g. Identify the end of each conductor using specified wiremarker with typewritten or imprinted pipe number to which conductor is connected.

h. Use terminal lugs for conductor terminations in test station.

i. Backfill in accordance with Section 02225.

3.2.6 Conductors: Install anode header, anode loop, and negative return cables as follows:

3.2.6.1 Place in trenches prepared in accordance with the Drawings.

3.2.6.2 Identify cables, using specified wiremarkers, at terminations except at inaccessible underground locations. Nomenclature shall be as shown on Drawings.

3.2.6.3 Terminate anode header and anode loop cables at anode junction boxes. Use terminal lugs for conductor terminations. Coil negative return cable and anode header, and loop cables at the future rectifier location.

3.2.6.4 Repair damaged cable insulation by using conductor splice kit.

3.2.6.5 Cover cable ends with plastic electrical tape until ready for termination.

3.2.6.6 Cable marker: Install as noted on Drawings.

3.2.7 Conduit: Install underground power conduits where shown on the Drawings. Cut conduit square, ream and deburr. Repair damaged PVC coating on conduits with touch-up compound. Seal conduits that enter control panels or boxes with duct sealing compound.

3.3 FIELD QUALITY CONTROL

3.3.1 Testing, General

3.3.1.1 Furnish instruments and equipment required to conduct testing.

3.3.1.2 Use test instruments which bear valid calibration stamps showing date of calibration and expiration dates of stamps. Calibration and accuracy of test instruments shall be certified by an independent testing laboratory having standards traceable to the National Institute of Standards and Technology.

3.3.2 Wiring Systems

3.3.2.1 Test wiring operating less than 150 V to ground for continuity and unintentional grounds.

3.3.2.2 See Appendix A for Functional Test of Reference Electrodes.

Specification Section
16640

[illegible]

Project No. W-320-C1

Project Title Tank 241-C-106 Sluicing

Specification Section 16640

VENDOR INFORMATION LIST

("X" Indicates Required Data)

[illegible]

KEH 1985.00 (03/89) KEFO

Page 24 of 24

APPENDIX A

FUNCTIONAL TEST OF REFERENCE ELECTRODES

Test each new permanent underground reference electrode just prior to installation in earth as follows:

1. Place the permanent reference electrode to be tested in a plastic bucket filled with tap water and soak for at least 3 hours.
2. Use an M.C. Miller, Model RE-5 portable reference electrode that has been tested for accuracy (see method below). Place end in the water in the plastic bucket or touch end of portable reference electrode to outside bag of permanent reference electrode.
3. Using a digital voltmeter, measure the voltage between the two reference electrodes and verify that the value is less than 50 mV.
4. If difference is equal to or greater than 50 mV, discard and replace tested permanent reference electrode with another and repeat steps 1 through 5. Record the results on the data sheet.
5. Report deficiencies to the Construction Engineer.

Accuracy Test: Place end of two M.C. Miller, Model RE-5 portable reference electrodes in a plastic bucket filled with tap water. Using a digital voltmeter, measure the voltage between the two reference electrodes and verify the value is less than 2 mV. Drive a 3 foot section of No. 4 or 6 steel reinforcing rod vertically into the earth leaving approximately 3 inches above grade. Using a digital voltmeter, measure the voltage between the rod and one of the portable reference electrodes placed on the ground approximately 3 feet from the rod. Record voltage: _____. Repeat same test using second portable reference electrode. Record voltage _____. Verify difference is less than 50 mV. Utilize either one of these reference electrodes as the portable reference electrode in the test above.

***DATA SHEET**

LOCATION: _____

[illegible]

WORK PERFORMED BY: _____

NOTES: *Obtain additional sheets from the Quality Control Inspector.
 **Between Portable Reference and Permanent Reference Electrodes

END OF APPENDIX

DISTRIBUTION SHEET

To	From	Page 1 of 1			
Distribution	JW Bailey	Date 17 July 1998			
Project Title/Work Order		EDT No. 622266			
Project W-320, 241-C-106 Sluicing, Construction Specification, W-320-C1		ECN No. n/a			
Name	MSIN	Text With All Attach.	Text Only	Attach./Appendix Only	EDT/ECN Only
JW Bailey	S2-48				
W-320 Project Files	R1-29				