

FB Line Basis for Interim Operation

by

B. Shedrow

Westinghouse Savannah River Company

Savannah River Site

Aiken, South Carolina 29808

RECEIVED
NOV 05 1998
OSTI

DOE Contract No. DE-AC09-96SR18500

This paper was prepared in connection with work done under the above contract number with the U. S. Department of Energy. By acceptance of this paper, the publisher and/or recipient acknowledges the U. S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper, along with the right to reproduce and to authorize others to reproduce all or part of the copyrighted paper.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P. O. Box 62, Oak Ridge, TN 37831; prices available from (423) 576-8401.

Available to the public from the National Technical Information Service, U. S. Department of Commerce, 5285 Port Royal Road, Springfield, VA 22161.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

DELETED
VERSION

Engineering and Projects Division
Safety Services Section

INFORMATION ONLY

ENGINEERING DOC. CONTROL - SRS
00243200
57743200

FB LINE Basis for Interim Operation (U)

UNCLASSIFIED
DOES NOT CONTAIN
UNCLASSIFIED CONTROLLED
NUCLEAR INFORMATION
T. R. DUGHEAOUR
CLASSIFICATION ANALYST

~~UNCLASSIFIED CONTROLLED NUCLEAR INFORMATION
NOT FOR PUBLIC DISSEMINATION
Unauthorized dissemination subject to civil and
criminal sanctions under section 148 of the
Atomic Energy Act of 1954, as amended (42
U.S.C. 2169).~~

H. S. Smiley

~~Reviewing
Official: H. S. Smiley Sr. Sep Safety Dir.
(Name and Title)
Date: 9/23/94~~

September 1994

~~ADC &
Reviewing
Official: J. Williams SR ENGR
(Name and Title)
Date: 9/29/94~~

~~ADC &
Reviewing
Official: J. Parker SR ENGR
(Name and Title)
Date: 9/29/94~~

Table of Contents

EXECUTIVE SUMMARY..... 4

1.0 INTRODUCTION 5

2.0 FACILITY DESCRIPTION..... 6

 2.1 Cation Exchange..... 6

 2.2 Precipitation and Filtration..... 6

 2.3 Mechanical Line..... 6

 2.4 Recovery..... 6

 2.5 Special Recovery..... 7

3.0 RELEVANT OPERATIONAL HISTORY..... 7

 3.1 Significant Events..... 7

 3.2 Significant Equipment/Operations Changes/Upgrades..... 8

4.0 SAFETY DOCUMENTATION..... 9

 4.1 Authorization Basis Documents..... 10

 4.2 Other Documents..... 14

5.0 COMPLIANCE STATUS..... 14

6.0 SAFETY MANAGEMENT..... 15

 6.1 Management Policies..... 16

 6.2 Management Responsibilities..... 16

 6.3 System of Control Documents..... 18

 6.4 Events, Conditions, and Concern Investigations, and Occurrence Reporting..... 25

 6.5 Review and Audit..... 25

 6.6 Training..... 25

 6.7 Facility Operating Records..... 26

 6.8 Radiation Protection Program..... 27

 6.9 Facility Radioactive and Hazardous Materials Shipping and Receiving Program..... 27

Table of Contents (continued)

6.10	Quality Assurance.....	28
6.11	Waste Management.....	28
6.12	Equipment Maintenance.....	28
6.13	Work Control.....	29
6.14	Conduct of Operations.....	29
6.15	Performance Indicators.....	30
7.0	OPERATING ENVELOPE.....	30
8.0	SAFETY EVALUATION.....	30
8.1	Facility Categorization and Hazard Identification.....	30
8.2	Hazard Analysis and Accident Categorization.....	33
8.3	Accident Analysis.....	38
8.4	Farmer Plots.....	58
8.5	Safety-Related Description Approach.....	61
9.0	CONCLUSION.....	65
10.0	REFERENCES.....	65

List of Tables

4.A	Applicable Authorization Basis Documents
4.B	List of Non-Applicable Sections from the FB-Line SAR, DPSTSA-200-10 SUPP-9
6.A	FB-Line Minimum Shift Crew Composition
6.B	Procedural Activities
8.A	FB-Line Isotopics, from SAR
8.B	FB-Line Process Area NCSS Maximum Permissible Inventories
8.C	FB-Line Cold Feed Tank Capacities
8.D	Chemicals Used in FB-Line Processing
8.E	Summary Table of Results of Risk Matrix Binning for FB-Line Operations
8.F	Summary Table of OSR/TS/SRS Documentation for FB-Line SAR and PHA Accidents
8.G	Summary Table of Risk for FB-Line Bounding Accidents
8.H	Safety-Related Systems and Components for FB-Line
8.I	Safety-Related Systems Required for FB-Line Operations

List of Figures

Figure 1	Risk of FB-Line - Bounding Accidents Off-Site
Figure 2	Risk of FB-Line - Bounding Accidents Co-located

EXECUTIVE SUMMARY

The safety analysis of the FB-Line Facility indicates that the operation of FB-Line to support the current mission does not present undue risk to the facility and co-located workers, general public, or the environment. This is based on the results of the hazard and accident analysis; the verification of the adequacy of the safety envelope by identification of controls, procedures and/or preventive and mitigative features against release of hazardous materials; and the implementation of aggressive safety management programs that ensure facility safety by adhering to principles of sound safety engineering and management practices.

The facility boundary is defined along with a description of hazardous materials and processes conducted within this boundary. A description of significant Safety-Related systems and design or procedural upgrades is provided. Safety and authorization basis documents are identified.

The operations of FB-Line have been examined to ensure the completeness and adequacy of the operating envelope. A Preliminary Hazards Analysis (PHA) was performed as a complement to other existing safety basis documentation to identify significant radiological and chemical hazards associated with FB-Line, dominant accident scenarios, release pathways, and their causes and consequences. The Safety Evaluation Section of this Basis for Interim Operation (BIO), Section 8.0, contains summary information about the accidents and risks associated with operation of FB-Line, as defined in the PHA and in the FB-Line Safety Analysis Report (SAR). Section 8.0 discusses a review of DOE-STD-1027-92 (Reference 1) which indicated that FB-Line is classified as Hazard Category 2 as a result of the plutonium (Pu) inventory. This section presents the impact of normal operations and postulated accident scenarios upon facility workers, co-located workers, and the public. The PHA identifies and examines existing safeguards for adequacy and recommends additional safeguards and/or analysis, if appropriate.

The frequencies and consequences associated with the accident scenarios which affect the operation of FB-Line were placed in "risk bins" which help illustrate the relative risk of the various scenarios. The results of this process were the identification of the following dominant accident scenarios, where dominant accidents are defined as Scenario Class I and II accidents (per the methodology documented in the PHA and in Section 8.2.2):

Class I Accidents:

Inadvertent Criticality
Ion Exchange Column Explosion

Class II Accident:

Single Level Propagated Fire

These accidents are discussed in detail in Section 8.0 and the safeguards that prevent/mitigate exposure of the public, co-located workers, or facility workers are identified. To reduce the risk associated with the Class I event, Ion Exchange Column Explosion, administrative controls are employed, including Authorization Basis level requirements for radiation exposure limits on the resin, time limits for leaving a column in a loaded state, maximum nitric acid concentration allowed in contact with the resin, and resin temperature. Additionally, a more thorough analysis will be performed on the explosion and its effect on existing confinement. Westinghouse Savannah River Company (WSRC)

commits to provide other measures as necessary to prevent a fatality from occurring and reduce this event to Scenario Class II or lower.

The other Class I event, Inadvertent Criticality, is classified as a Class I event for the facility worker based on its frequency as stated in the SAR and modified in this BIO. WSRC does not feel that any additional measures and/or limits are practical, nor necessary that reduce criticality frequency or consequence to Scenario Class II or lower.

FB-Line's programmatic approach to safety for facility workers, co-located workers, and the public is described (see Section 6.0) for the following areas: safety management goals and policies, emergency planning, fire protection, criticality safety, configuration control, installed process instrumentation, environmental compliance, industrial hygiene, occurrence reporting, review and audit, training, records retention, radiation protection, radioactive and hazardous materials control, quality assurance, waste management, maintenance, conduct of operations, and performance indicators.

Sections 7.0 and 8.0 of this BIO present the principal aspects of the operating envelope for the accident scenarios identified in the SAR and the PHA. The material presented provides both the preventive and mitigative features that are credited by WSRC for the various dominant accident scenarios. In defining the operating envelope of the facility, administrative controls (AC), commitments to complete an action, and certain design features (DF) not already defined as such in the authorization basis documents [e.g., SAR/Operational Safety Requirements (OSR)/Technical Standards (TS)], have been explicitly identified. The applicable ACs and DFs are included in Table 8.F, along with additional SAR/OSR/TS requirements. The use of bold face type indicates commitments contained in the text.

1.0 INTRODUCTION

FB-Line is located in the 200-F Separations Area and is used to convert Pu nitrate, recovered from irradiated natural and depleted uranium in the 221-F Canyon, to Pu metal. The portion of Building 221-F which houses FB-Line was built either as part of the original construction (Levels 3 and 4) during 1951-53 or as part of the F-Area upgrade construction (Levels 5 and 6) during 1957-58. The facility has operated safely, with no major incidents over the lifetime of the facility (since 1954). Process operations were discontinued in January 1990 for routine maintenance and project upgrades. The work was completed in April 1990, as scheduled. During the shutdown, a program was undertaken to inspect exhaust ducts and clean them of any accumulation of Pu. Process operations remain discontinued pending Department of Energy (DOE) approval for restart. Note that anion process equipment is currently operated as required. With recent changes in the world power structure, the United States no longer requires a significant nuclear stockpile. The result for FB-Line is an eventual phase out of its operation over the next few years. When restarted, the mission of the facility will be to process existing inventories of Pu and Pu-bearing materials to achieve a suitable form for long term storage. Materials to be processed in FB-Line could include Pu solutions originating from F-Canyon inventories, aluminum-clad targets and fuels requiring stabilization, various at-risk solid inventories such as Pu-bearing process residues, oxides and/or metal compounds, or other materials identified by DOE.

The present analysis integrates the existing safety basis documentation, including a recently completed PHA, to demonstrate an adequate level of safety assurance associated with the planned operation of this facility during the interim until the commencement of decontamination and decommissioning. This is done by a discussion of the safety management program, an integrated safety evaluation, and presentation of the safety

envelope. In addition, corrective or compensatory measures are discussed for identified vulnerabilities.

2.0 FACILITY DESCRIPTION

FB-Line is located in Canyon Building 221-F, specifically in Sections 1 through 5, on the third through sixth levels, plus the south loading dock on level 2, Section 1. The portion of the building that houses the process equipment is Class I - Blast Resistant Construction. The processing equipment is enclosed in process enclosures (either cabinets or gloveboxes) to prevent contaminating operating areas. The processing equipment is confined to the fifth and sixth levels with the exception of the receiving tank for 221-F Canyon Pu product on the 3 1/2 level. In addition to the processes described below, waste handling operations take place throughout the facility, and miscellaneous Pu vault storage operations take place in two vaults located in FB-Line on the third and fourth levels. The following subsections describe the functions of the process systems. Schematics are presented in the PHA.

2.1 Cation Exchange

The Pu in the 221-F Canyon Pu product solution is concentrated and decontaminated in one of four cation exchange columns of two segments each. The cation resin selectively sorbs the Pu from a relatively dilute solution. The cation resin eluant removes the Pu from the resin as a relatively concentrated solution of Pu required by the subsequent processing operations that convert the Pu to the metal. Cation exchange couples the F-Canyon process to the FB-Line metal conversion process. The main system components, in addition to the cation exchange columns, are two feed receipt tanks, four feed filters, two column head tanks, four product run tanks, and two product hold tanks.

2.2 Precipitation and Filtration

Precipitation produces Pu trifluoride cake from the Pu solution that was eluted from the cation exchange columns. The Pu concentrate from cation exchange and hydrofluoric acid are fed to the first stage precipitator to form large trifluoride crystals. The slurry overflows to the second stage precipitator and is vacuum filtered to form a cake. The main system components are two concentrate feed tanks, two first stage precipitators, two second stage precipitators, two filter stations, two filtrate catch tanks, two filtrate neutralization tanks, a boat flush station, and a boat flush run tank.

2.3 Mechanical Line

The filter boat containing Pu trifluoride is removed from the filtration station, monitored with a neutron probe for Pu content, and transferred to the Mechanical Line air drying station where dry, warm air is drawn through the cake to remove residual moisture. After air drying, the contents of the filter boats are dumped into roasting pans, which are then hydraulically raised into a roasting furnace. In the furnace, the material is converted to Pu tetrafluoride and Pu dioxide mixture. The tetrafluoride/oxide mixture is mixed with metallic calcium in a reduction vessel and heated in an induction furnace to produce the metal. The main system components are four air drying stations, two conversion furnaces, two reduction furnaces, a pickling station, and a sampling station.

2.4 Recovery

Pu in solid scrap from onsite and offsite and miscellaneous solutions from FB-Line is recovered and transferred to 221-F Canyon for recycle through solvent extraction. Solids are dissolved in a slab tank, and the dissolver solution is filtered to remove refractory

solids. Both dissolved Pu scrap and miscellaneous Pu-bearing solutions are prepared for sorption of Pu on anion exchange resin. The purified Pu solution eluted from the anion exchange resin is diluted and then transferred to F-Canyon. The main system components are two filtrate hold tanks, a recycle feed tank, a slag and crucible dissolver, a filtrate run tank, two anion exchange columns, a waste tank, and a product run tank.

2.5 Special Recovery

Special processes were previously used to dissolve Pu oxides for blending with canyon processes. This operation has been shut down and left in a safe posture. Safe posture is defined as follows: Upon last operation of the dissolvers, a clean-out run was performed to reduce the Pu heel in the vessels. The process control computer has been de-energized. The cabinet floor was swept to remove any spilled Pu. The ventilation and fire systems are being maintained in the area, as well as the roving fire watch. Routine inspections include surveillance for nuclear safety concerns, liquid in the sump, and contamination leaks.

3.0 RELEVANT OPERATIONAL HISTORY

3.1 Significant Events

Ten events have occurred since approval of the SAR in 1988 which had the potential for facility health or safety consequences. Two involved exceeding a Nuclear Criticality Safety Supplement (NCSS) limit, five involved violation of posted Nuclear Safety Limits, and three involved deficiencies with Safety-Related ventilation interlocks. None had a serious impact on facility safety. None of these events were of an unanalyzed type or consequence. The occurrences are summarized in the subsections below.

In addition, some analytical deficiencies in the accident analyses from the current SAR resulted in underestimation of the accident consequences. These are 1) possible failure of the exhaust stack liner at seismic intensities below the design basis earthquake (DBE), 2) use of nominal inventories for process steps in accident analyses, rather than NCSS maximums, and 3) use of now outdated dose conversion values in accident analyses. The deficiencies are summarized in Section 8.0.

Another change to the accident analysis in the SAR is related to an expanded analysis of an existing event, criticality. A hydrogen deflagration event was analyzed as another possible initiator of an accidental criticality. This additional analysis is described in Section 8.0.

3.1.1 Mechanical Line

Separations Occurrence Report 90-09-31 describes an incident involving accumulation of condensate in the Mechanical Line glovebox exhaust header. Inspection of the east-west header of the Mechanical Line glovebox exhaust system identified the presence of less than 6 liters of liquid and solids bearing approximately a kilogram of Pu. Although more material was found than anticipated, no potential for criticality existed, as documented in the occurrence report. Procedural and equipment modifications have been made to minimize future accumulation. These modifications include initiation of a program to inspect and monitor the Mechanical Line exhaust header system to prevent excessive accumulation of Pu, as detailed in Reference 2, and installation of covers for pickling pans to reduce the amount of vapor which enters the exhaust duct.

3.1.2 Transuranic (TRU) Waste

Occurrence Report SR--WSRC-FBLINE-1992-0047 describes an incident in which an error in Waste Tracking System software resulted in an NCSS limit violation. Calculation errors, attributed to inadequate procedures and computer software, resulted in NCSS limits being exceeded for 23 TRU waste drums sent to the Solid Waste Disposal Facility. Implementation of formal Technical Reviews including the Unreviewed Safety Question (USQ) process for all modifications, and establishment of a Configuration Control Board, will ensure that future procedural, hardware, and software changes are thoroughly reviewed for their impact on facility safety.

3.1.3 Vault

Five incidents (described in Separations Incidents SI-89-04-27 and SI-89-09-56, Separations Occurrence Report 90-12-55, and Occurrence Reports SR--WSRC-FBLINE-1992-0024 and SR--WSRC-FBLINE-1994-0029) have occurred in which Vault storage limits were exceeded, one of which involved violation of an NCSS limit. In the first occurrence (SI-89-04-27), material stored in two bin spaces of the vault exceeded the NCSS limits. Deficiencies were noted in the labeling and surveillance of vault inventory. Corrective actions to label the materials in the bins and floor spaces of the vault as well as a periodic surveillance of these materials in the vault were implemented. The three subsequent occurrences (SI-89-09-56, 90-12-55, and SR--WSRC-FBLINE-1992-0024) were discovered while implementing the corrective actions from occurrence SI-89-04-27. In these occurrences, material stored in the vaults violated the nuclear safety posted (procedural) limits. The occurrences were discovered as a result of vault inventory surveillances and operator calculations based on the labeling of the material. The fifth occurrence (SR--WSRC-FBLINE-1994-0029) was discovered during a periodic surveillance of the vault inventory. Material was found in a storage container that exceeded the nuclear safety posted limit. This was an oversight that should have been noticed during prior surveillances. The periodic surveillance did ultimately discover the discrepancy and enhancement of the vault inventory surveillance is being implemented. No potential for criticality existed as a result of any of the incidents, as documented in the respective reports. Improved administrative controls and surveillances have been implemented to minimize the potential for recurrence of these type incidents.

3.1.4 Ventilation Interlocks

Three incidents (described in Occurrence Reports SR--WSRC-FBLINE-1991-1034, SR--WSRC-FBLINE-1991-1035, and SR--WSRC-FBLINE-1992-0013) have occurred that involved deficiencies with ventilation system interlocks. In two of the incidents, initial wiring of the interlock was not per design. In the other, a temporary jumper was found to have been inadvertently left installed. Although none of the incidents resulted in any impact on facility safety, they collectively highlighted the need for improved Configuration Control and Work Control, which have since been implemented.

3.2 Significant Equipment/Operations Changes/Upgrades

Proposed changes to facility equipment for the time period between SAR issuance and implementation of the USQ process in November 1991 were reviewed and documented through several programs, including the Safety Evaluation checklists, Test Authorization (TA) Program, and Work Order Program. Transition to a DOE defined Configuration Management Program for all of Savannah River Site (SRS) is underway. The USQ process was performed retroactively on all significant upgrades implemented from January 1990 until November 1991. No facility changes, including those implemented since

November 1991 (including modifications described in Section 3.1.1 above), have been found to have any impact on the facility safety basis.

Facility upgrades for FB-Line were initiated in 1980 under Reference 3. The objectives of the restoration program were to:

1. Improve contamination control and reduce assimilation risk,
2. Meet applicable guidelines, regulations, and standards,
3. Improve accountability of special nuclear materials,
4. Restore FB-Line to a condition suitable for use at projected production rates.

As a result of this program, seven projects have been completed, including construction of New Special Recovery (NSR) and the Plutonium Storage Facility (PSF), at a cost of \$138 million, and five projects are in various stages of installation at an estimated cost of \$98.1 million. Of the 112 items identified in Reference 3, 79% have been acted upon. The aforementioned completed projects account for 40 items, while projects in progress account for another ten. Non-project work is in progress on seven items, and work has been discontinued on five. Twenty-seven items have been completed without formal projects. The 23 remaining items will be analyzed for their impact and priority based on cost and benefit. None of the 112 items are Safety-Related, nor are they required for restart.

Seven replacement cabinets have been installed in this program, four of which have been placed in operation. The four operational cabinets have reduced the radiation exposure of facility personnel due to remote process control computer operation and specially designed shielding and confinement. The remaining cabinets will not be placed in operation, since their primary purpose was to increase production capability and reduce radiation exposure by automating processes. Radiation exposure and production goals can be met with existing cabinets.

Facility upgrade plans are constantly being reviewed and changed based on DOE needs, the current mission, and the availability of funds. Projects under consideration for implementation will improve facility safety, but are not required to keep the facility within the safety envelope defined by the SAR, OSR or TS. However, they will be evaluated under the USQ process.

4.0 SAFETY DOCUMENTATION

All authorization basis documents addressed in this section are listed in Table 4.A for easy reference only. The applicable authorization basis documents are subject to change, and for the most up-to-date listing, reference should be made to controlled document WSRC-IM-93-61, "NMPD Authorization Basis Lists (U)", which contains all the authorization basis documents for the Nuclear Materials Processing Division (NMPD), and is updated as required.

**Table 4.A
Applicable Authorization Basis Documents**

Document Number	Title	Approval Date	Approval Authority
DPSTSA-200-10 SUPP-9	Safety Analysis - 200 Area Savannah River Plant FB-Line Operations	4/88	DOE-SR & E. I. DuPont
DPW-85-101, Revision 2	Operational Safety Requirements for 200-F and 200-H Areas (Excluding Tritium and Waste Management)	8/94	DOE-SR & WSRC
WSRC-TN-45, Rev. 0	221-F Building Technical Standards (U)	Multiple	DOE-SR & WSRC/ E. I. DuPont
DPSTS-NIM-85	Nuclear Incident Monitors Technical Standard	2/85	DOE-SR & E. I. DuPont
DPSTS-221-0.09 Sup.	Nuclear Criticality Safety Supplements Building 221-F, JB-Line	Multiple	DOE-SR & WSRC/ E. I. DuPont
WSRC-TA-91-00002-12-Extension (Rev. 2)	Storage of Mk 42 Scrap	1/94	DOE-SR & WSRC

4.1 Authorization Basis Documents

4.1.1 Safety Analysis Report

The FB-Line SAR was written in the mid-1980's according to DOE Order 5481.1B, and analyzed the major hazards and dominant credible accident scenarios for normal processing operations. Consequence and frequency for these scenarios as they relate to the public are contained in the SAR; however, the consequences were based on nominal source terms and International Commission on Radiation Protection, Publication 2 (ICRP 2) dose factors.

The following table (Table 4.B) lists those sections of the existing FB-Line SAR that have been superseded by either new safety analyses or because the process is no longer used. The SAR sections that are indicated as being not applicable shall not be used in determining the approved safety envelope and Authorization Basis limits for operation of FB-Line.

Table 4.B
List of Non-Applicable Sections from the FB-Line SAR,
DPSTSA-200-10 SUPP-9

Non-Applicable or Canceled Sections	Comments
Chapter 1	
Section 1.2.2	The risk summary in Section 1.2.2 has been superseded by the FB-Line BIO.
Chapter 2	
Sections 2.1.1; 2.1.2; 2.1.3; 2.1.4; 2.1.4.1; 2.1.4.2; and 2.1.5	These subsections are not applicable for the five bounding accidents analyzed in the BIO. These subsections are still applicable for all other accident scenarios, for which new analyses were not performed.
Chapter 3	
All Sections and subsections of Chapter 3	The information (including Tables and Figures) in Chapter 3 shall be retained for historical purposes only and shall not be used as part of the facility safety envelope.
Chapter 4	
Section 4.1	Refer to WSRC-1-02 for the WSRC organizational structure.
Sections 4.2; 4.3; 4.3.1; 4.3.1.1; 4.3.1.2; 4.3.1.3; 4.3.2; 4.3.2.1; 4.3.2.2; and 4.3.3	These sections have been superseded by Section 4.0 and Section 6.0 of the BIO.
Sections 4.4 and 4.5	The information in these sections has been superseded by Sections 6.5 and 6.6 of the BIO.
Sections 4.6 and 4.7	The test and inspections are covered by the Safety-Related systems procedure and the OSR and TS test and inspection requirements. Any unique hazards associated with facility operation have been identified in the PHA or the BIO.
Sections 4.8; 4.8.1; 4.8.2; 4.8.3; 4.8.4; 4.9; 4.9.1; 4.9.2; 4.9.3; 4.9.4; 4.9.5; and 4.9.6	These sections have been superseded by Section 6.0 of the BIO.
Chapter 5	
Sections 5.1.3; 5.3.3; 5.4.3; and 5.6.3	These sections have been superseded by the description and analysis of ion exchange column explosions in the PHA and this BIO. Ion Exchange Column explosion was previously considered a medium energetic event.
Section 5.1.4.2	Descriptions of fire mitigating features are superseded by the Fire Hazards Analysis (FHA).
Section 5.4.1.2	This section has been superseded by the earthquake consequence analysis in the BIO.
Section 5.5 to include all subsections.	The radiological risks for FB-Line in this section have been superseded by the risks given in the BIO.
Chapter 6	
Section 6.1	This section has been replaced by the Safety-Related Systems List (Table 8.H.)
Section 6.2.3	This section is superseded by Manual WSRC-IM-93-13.
Sections 6.3 and 6.4	These sections are retained for historical purposes only.
Chapter 7	
Sections 7.1 and 7.2	The entire chapter 7 has been replaced by the WSRC Quality Assurance (QA) Program.
Appendices	
Appendix A	See source terms in this BIO for bounding accident scenarios.
Appendix B	The BIO uses the frequencies in these tables only. The rest of the tables in Appendix B are superseded by the BIO, however, the frequencies shall continue to be used.
Appendix C	This appendix documents previous DOE comments and their resolution.
Appendix D	This appendix is superseded by the FHA, except that frequencies and frequency calculations are retained.

Table 4.B (Continued)
List of Tables in the FB-Line SAR Which are No Longer Applicable

The following tables in the FB-Line SAR have been superseded or are no longer applicable and shall not be used in determining the FB-Line safety envelope.

Note: The frequency for criticality given in tables 5-23 through 5-26 shall be not be used. Also, the nominal release terms for third level, given in tables 5-29, 5-30, and 5-31, shall not be used.

Table Number	Page
Table 1-1	1-5
Table 1-2	1-7
Table 1-3	1-8
Table 2-2	2-6
Table 2-3	2-7
Table 4-1	4-19
Table 4-2	4-24
Table 4-3	4-26
Table 4-4	4-28
Table 4-5	4-29
Table 4-6	4-32
Table 4-7	4-34
Table 5-2	5-13
Table 5-7	5-31
Table 5-34	5-79
Table 5-35	5-80
Table 5-36	5-82
Table 5-37	5-86
Table 5-38	5-88
Table 5-39	5-89
Table 5-40	5-90
Table 6-1	6-2
Table 6-2	6-3

The following figures in the FB-Line SAR have been superseded and shall not be used in determining the FB-Line safety envelope.

Figure Number	Page
Figure 4-1	4-2
Figure 4-2	4-3
Figure 4-3	4-8
Figure 4-4	4-22
Figure 4-5	4-25
Figure 4-6	4-31

The information in the table was developed by reviewing the SAR to determine those sections that reflected current and planned facility operations. Any section which contained incorrect information was reviewed to determine if any information in the section was still applicable to the facility safety envelope. If the section which contained incorrect information did not directly impact the facility safety envelope or had been superseded by

other documents, the section was indicated as being non-applicable for use in determining the safety envelope. In some cases the deleted section contained specific requirements that could affect the facility safety envelope. If a specific requirement that affected the facility safety envelope was identified in a section that was deleted, the requirement was retained and is included in the appropriate section of Table 8.F. In some cases a section may contain incorrect material but still contain a significant amount of correct material. In this case, it was determined to retain the material for historical reference only. The comment section in Table 4.B indicates those sections of the SAR that have been deleted because they were superseded by other documents or because the equipment or process is no longer used, and those SAR sections that should be retained for historical purposes.

4.1.2 Operational Safety Requirements and Technical Standards

The purpose of an OSR document is to define the envelope of authorized operations of nonreactor nuclear facilities at SRS, and formally document the requirements for operation in the following categories: Safety Limits and Limiting Control Settings, Limiting Conditions for Operations, Surveillance Requirements, Design Features, and Administrative Controls. The current approved OSR was written in 1985 to DOE Order 5481.1B, and was last revised in August, 1994.

TS are a collection of contractor and DOE approved documents which define the actual process limits within which the facilities are operated. They specify the requirements and bases for basic variables within which the process must be operated for reasons of safety, quality, and/or limitations of known technology. These requirements are within the boundaries of safe conditions reported in the OSR. Revision to the current approved TS for FB-Line is an ongoing process. TS pertaining to FB-Line were most recently revised in December 1980.

TS originated at the SRS in the early 1960's, as a requirement of the Atomic Energy Division (AED) of E. I. DuPont de Nemours & Company, the original contractor at the Site. TS were the primary control point in the AED procedural system for process safety and efficiency. They were based on Technical Manuals that included experimental results and detailed descriptions of processes. Operating manuals and procedures were written to ensure TS limits were maintained with a significant margin of safety.

4.1.3 Nuclear Criticality Safety Supplements

NCSS are a collection of contractor and DOE approved documents which specify conditions and limits within which operations must be conducted for reasons of nuclear criticality safety. The most recent revision to an FB-Line NCSS was in March 1992.

4.1.4 Test Authorizations

A TA is a contractor and DOE approved document which authorizes temporary deviations from TS. The purpose of a TA is to conduct process study trials with plant equipment or to authorize non-standard operations. Limits defined by the TA are within the boundaries of safe operations specified in the OSR and SAR and therefore are always within the facility Authorization Basis. Like the TS, TAs originated at the SRS in the early 1960's to provide for operational flexibility within safe limits. There is currently only one applicable TA for FB-Line operations.

4.2 Other Documents

4.2.1 Fire Hazards Analysis

The purpose of the FHA (Reference 4) is to evaluate the fire protection and life safety features of FB-Line, and to determine whether or not the objectives of DOE Order 5480.7A have been satisfied. **WSRC commits to have a WSRC-approved FHA prior to declaration of readiness for restart (C).**

4.2.2 Linking Database

The Linking Database provides a road map of the relationships between authorization basis document requirements and field implementation of those requirements. The database itemizes the surveillance requirements and limits included in the authorization basis documents (i.e. SAR, OSR, and TS). Duplicate requirements from these authorization basis documents are combined into a single entry with reference to all applicable source documents. The database links the requirements and limits from these documents to various program and procedure references which are used for tracking or implementation of the requirement. The Linking Database program and procedure references identify implementation methods such as the Surveillance Test Program, the Installed Process Instrumentation (IPI) Program, the Preventive Maintenance Program and the facility's operating, maintenance, test, and Safety-Related systems procedures. **Prior to declaration of readiness for restart, the Linking Database will contain information that captures any existing or new implementable safety requirements from the BIO (C).**

As indicated in the executive summary, new requirements contained throughout this BIO have been explicitly identified. Commitments are noted in **bold** and identified by a **C** in parentheses. Bold type is used to allow easy identification of commitments. This convention is not used in Table 8.F since these requirements are easily identified. **Prior to declaration of readiness for restart, commitments identified in the BIO will be incorporated into an appropriate issues/commitment tracking system (C).**

5.0 COMPLIANCE STATUS

Temporary Exemption Requests to exempt FB-Line from compliance with DOE Orders 5480.22 and 5480.23 have been approved. These Exemption Requests are documented in WSRC-RP-93-668-005 as SRS-DOE-5480.22-EX-93-009 and in WSRC-RP-93-668-007 as SRS-DOE-5480.23-EX-93-004. A temporary versus permanent exemption was granted due to the uncertainty of the future mission of FB-Line, dependent on the outcome of the Environmental Impact Statement (EIS) for Interim Management of Nuclear Materials at the SRS. A final decision for Permanent Exemption Requests will be made within 60 days of the EIS Record of Decision by DOE. This BIO will be in effect for the operational life of the FB-Line facility and reviewed and updated annually, unless the Permanent Exemption Requests cannot be supported. In this latter case, subsequent safety documentation upgrades per DOE Orders 5480.22 and/or 5480.23 would supersede the BIO when approved.

Documentation of the assessment of compliance with all other Level 1 DOE Orders (51 orders important to worker safety and protection of the public and the environment) will be completed prior to startup. Identified non-compliances with requirements will have an improvement plan in place and/or generate a Compliance Schedule Approval (CSA)/Exemption Request with identified compensatory measures. Over ninety DOE

Order Compliance Packages have been issued in final form and are contained in WSRC-RP-90-12, "DOE Directives Assessment and Compliance Plan".

Following the compliance verification step, a field validation of selected DOE Orders will be completed. Prior to completion of the WSRC Operational Readiness Review (ORR) for this restart, all documented and active compensatory plans, CSAs, and Exemption Requests, established by the DOE Order Compliance Program, will be revalidated.

6.0 SAFETY MANAGEMENT

The principal safety concerns for FB-Line are:

- a. Ionizing radiation from fixed radiation sources and from radioactive contamination
- b. Loss of process fluids and aerosols from vessels or systems, so that hazardous materials can be released to the facility atmosphere and environment
- c. A criticality event
- d. Normal industrial hazards
- e. Chemical hazards.

The following goals and requirements exist to address the principal safety concerns. The remaining paragraphs of Section 6.0 describe the management programs which exist to ensure these goals/requirements are met. It should be noted that all program descriptions herein assume compliance with "A" findings from the WSRC ORR prior to startup, as required by Procedure Manual 12Q, "Operational Readiness Review Manual".

- a. Maintain individual occupational radiation exposure as low as reasonably achievable (ALARA),
- a. Maintain non-radiological atmospheric and liquid releases within regulatory limits,
- c. Maintain offsite radiological dose (to the public) ALARA by limiting radioactive releases to the lowest possible level. Maintain offsite doses within regulatory limits,
- d. Maintain operations activities within the facility Authorization Basis,
- e. Operate in accordance with applicable industrial safety requirements.

It is the stated policy that the safety and protection of employees and the public is the first priority of WSRC and that work will stop immediately rather than conduct a job in an unsafe manner. Further, the safety philosophy is that all injuries can be prevented and that any hazards which may result in injuries must be safeguarded. To accomplish these ends, a comprehensive safety program protecting facility workers from industrial and process hazards has been implemented through Procedure Manual 8Q, "Westinghouse Savannah River Company Employee Safety Manual (U)", and Manual WSRC-IM-90-135, "Savannah River Site Process Safety Management Manual (U)". These programs, in concert with the SAR analyses, PHA, criticality studies, procedure development process,

training, etc. all serve to ensure that the hazards to facility workers are understood and controlled.

In particular, the SRS Process Safety Management (PSM) Program concerns itself with protecting facility workers from process-based hazards. The principal objective of the PSM Program is to provide a periodic, systematic review of each SRS process having the potential to result in a catastrophic accident in order to minimize injuries and property damage resulting from process-related hazards. The program is constructed around the Process Hazards Review (PHR) which is an organized effort to identify and evaluate the hazards associated with various SRS processes and to identify potential improvements in process safety.

The remainder of this section specifies the administrative framework for safe facility operation. It also provides an overview of the administrative control documents used to maintain safe operations and achieve the goals stated above. The administrative control documents for the facility are prescribed to ensure that basic and important decisions are made only after appropriate review and that decisions that could significantly affect safety receive independent review.

6.1 Management Policies

General management policies and guidance are contained in WSRC-1-01, "Westinghouse Savannah River Company Policy Manual", and include the following specific policies:

- a. Administrative and procedural controls delineate clear lines of responsibility and methods for safe operation under normal and emergency conditions,
- b. All changes to components, equipment, procedures, and systems required for facility safety require independent review,
- c. Decisions that have significant safety implications receive independent review before final approval by management,
- d. Safe boundaries for operation are carefully defined and approved by management, and communicated to affected parties.

Management policies are implemented through procedures approved by WSRC management.

6.2 Organizational Structure and Management Responsibilities

The major functions of the SRS are assigned to divisions, each under the direction of a Vice President (VP). The VPs report directly to the WSRC President. The NMPD VP is responsible for operations of nonreactor facilities within NMPD, including FB-Line. The Separations F-Area Manager reports to the VP and is responsible for the activities conducted in F-Area. Each facility in F-Area is managed by a Facility Manager. NMPD Engineering provides support to F-Area facilities through Separations Engineering, Regulatory Programs, and Engineering Programs and Assessments. This organizational arrangement is presented in WSRC-1-02, "Westinghouse Savannah River Company Organization Charts".

The FB-Line Facility Manager reports to the Separations F-Area Manager and is responsible for managing all aspects of FB-Line facility operations including Radiological Control, Industrial Safety, QA, personnel staffing, training, procurement, and facility

maintenance. The FB-Line Facility Manager carries out these responsibilities by direction of, and delegation to, the various managers and support personnel reporting to him/her. Specifically, the Facility Manager is responsible for the following, as specified in Procedure Manual S1-1-1 "FB-Line Administrative Procedures and Policy Manual (U)", Item 5.01, "FBL Shift Operating Crew Staffing Requirements (U)":

- a. Overall facility operation (He or she delegates in writing the succession to this responsibility during absence.)
- b. Operation of the facility in accordance with approved OSR and TS
- c. Facilitation and control of procedure changes and physical modifications in plant configuration and coordination of the activities of all work groups within the facility
- d. Ensuring that each on-duty shift is composed of at least the minimum shift crew composition shown in Table 6.A (Any temporary deviation from these requirements must be justified by facility-specific analysis.)
- e. Ensuring that on-call support personnel are assigned and that technical support personnel are available to provide technical assistance to the production staff
- f. Ensuring that all facility operations are performed under the direct supervision of a trained First Line Supervisor (FLS)
- g. Ensuring that facility control is carried out by qualified operators according to written procedures
- h. Ensuring that FB-Line FLS and Control Room Operators are subject to limitations when being assigned work outside of their regular schedules (These limitations are included in Procedure Manual 5B, "WSRC Human Resources Policies, Practices, and Procedures (U)", Practice 2.23, "Exempt Employee Overtime Administration (U)", and Procedure Manual 2S, "Conduct of Operations (U)", Procedure 5.1, "Facility Operation Organization and Administration (U)".)
- i. Ensuring that qualified operators are in the Coupling Operating Room and the Central Control Room at all times
- j. Ensuring the Shift Operations Manager or FLS mans the Operations Command Center at all times.

The FB-Line organization interfaces with various other WSRC organizations in accomplishing the FB-Line mission. Some of these organizations include: the Radiological Control Operations Section which provides oversight of the Radiation Protection Program to assure that the radiation exposure of the facility personnel is maintained ALARA; the Facility Safety Evaluation Section which conducts independent review of safety documentation and evaluates compliance to selective DOE orders; the Site Safety Review Committee which meets periodically to assess the adequacy of environment, safety, health, safeguards, security, and QA; and the Facility Operations Safety Committee, which meets periodically to review occurrences and to ensure significant issues are adequately evaluated.

The Shift Operations Manager (SOM) is responsible for the local command function of the facility. During any absence of the SOM from the facility, a designated, qualified individual assumes the command function.

Table 6.A - FB-Line Minimum Shift Crew Composition

<u>FACILITY MODE</u> *	<u>SOM</u>	<u>FLS</u>	<u>OP</u>	<u>NSS</u>	<u>RCO</u>	<u>Maint</u>	<u>STE</u>
Operation	1	2	9	1	3	2	1
Standby	1	1	7	1	2	2	0

- SOM - Shift Operations Manager
- FLS - First Line Supervisor
- OP - Operator
- NSS - Nuclear Safety Specialist
- RCO - Radiological Control Operations
- Maint - Maintenance Personnel
- STE - Shift Technical Engineer

* The facility is considered to be in Operation mode when one or more process areas are processing Pu material. When no process areas are processing Pu material, the facility is considered to be in Standby mode. Process areas are: Cation Exchange, Mechanical Line, Recovery, and Precipitation/Filtration.

6.3 System Of Control Documents

A formalized system of procedures is employed, as described in Procedure Manual 11Q, "WSRC Administrative and Procedural Controls System for SRS Reactor and Non-reactor Nuclear Facilities (U)", to ensure that the facility is operated and maintained as prescribed by the OSR and TS. The SAR, OSR and TS provide the requirements and bases for safe facility operation. These documents, in turn, are implemented by lower tier procedures and documents. The lower tier procedures and documents contain limits on variables and system operation that are at least as restrictive as those in the OSR and TS.

The SAR, OSR and TS are the primary safety control documents. Additional documents and controls are described below. A Safety Documentation Database, also referred to as a "Linking Database" (see Section 4.2.2), has been created to assist in locating and relating safety documentation for FB-Line. This database itemizes surveillance requirements and limits contained in the SAR, OSR, TS, NCSS, and TA. The database shows the relationship between the requirements and limits from these documents and shows how they apply to different process areas and systems. The database also identifies the FB-Line procedures which implement the requirements contained in the higher tier documents such as OSR and TS. Access to this database will be controlled by a procedure which is currently being developed by the FB-Line Procedures Group.

6.3.1 Contractual Agreement - The contract describes the relationship between the contractor (WSRC) and the contracting officer (DOE).

6.3.2 Unreviewed Safety Question Process—The WSRC USQ process is required by DOE Order 5480.21 and is implemented by Procedure Manual 11Q, Procedure 3.10, "Nonreactor Nuclear Facility Unreviewed Safety Questions" (latest revision), and lower tier NMPD or Separations procedures. All proposed activities such as facility modifications, equipment modifications, operating procedure revisions which change the operational steps or intent of the procedure, other activities that could affect safe operation of the facility, and potential inadequacies (analytical errors or omissions) in the facility

safety analysis are evaluated by the USQ process. The USQ process evaluation determines if the proposed activity or potential inadequacy is within the current DOE approved facility safety envelope and the risk (frequency or consequences) associated with the proposed activity are within the DOE accepted facility risk. The proposed activity must be approved by DOE if the USQ evaluation indicates that a USQ is involved with the activity. If no USQ is involved, WSRC implements the activity without DOE approval. Guidelines for determining if a USQ exists, based on changes in frequency and consequence of accidents, are contained in Procedure Manual 11Q, Procedure 3.10 (latest controlled and issued revision).

6.3.3 Authorization of Startup by DOE - DOE approval is required prior to facility startup if the facility operation/process will be restarted after:

- a. An OSR violation from exceeding a Safety Limit
- b. A DOE-mandated shutdown
- c. Discovery of a condition that results in a USQ
- d. Being non-operational for more than 12 months
- e. Substantial facility modifications.

6.3.4 Procedures - Procedures are established, implemented, and maintained to address the activities specified in Table 6.B. They are reviewed to ensure conformance with the following:

- a. Procedures are approved by appropriate management levels in accordance with approved procedures, which have been authorized by the Facility Manager or designee.
- b. New procedures and procedure changes that may have a potential impact on facility configuration, operation, nuclear safety, industrial safety, or environmental and health regulation compliance, are reviewed by Engineering against applicable requirements. Other disciplines may be required to review and approve a procedure based on the subject matter.

All procedures have a USQ screening/evaluation performed and do not authorize operation outside the Authorization Basis. Special Procedures provide instructions and limits for non-routine operations and are good for one use only.

Table 6.B - Procedural Activities

- A. Administrative Procedures to govern:
 - 1. Authority and responsibility for facility safe operation and shutdown
 - 2. Equipment control (e.g., locking and tagging)
 - 3. Procedure adherence
 - 4. Procedure review and approval
 - 5. Conduct of operations
 - 6. Control of maintenance work
 - 7. Control of modifications

- B. Operating Procedures to govern:
 - 1. Startup, operation, and shutdown of facility systems and equipment
 - 2. Surveillance Requirements

- C. Maintenance Procedures to govern:
 - 1. Control of routine maintenance, inspection, calibration, and test activities
 - 2. Preventive and Corrective Maintenance Program(s)

- D. Alarm Response Procedures to govern initial validation and corrective actions in response to control room alarms for safety systems

- E. Procedures to define the methods for correcting abnormal facility conditions

- F. Implementation of IPI Program

- G. Implementation of the facility Fire Protection Program

- H. Implementation of the facility Emergency Response Program, Emergency Preparedness Administrative Procedures (EPAPs), and Emergency Plan Implementing Procedures (EPIPs)

- I. Implementation of the Radiation Protection Program to limit materials released to the environment and to limit personnel exposure

- J. Implementation of the facility QA Program

- K. Implementation of the facility Nuclear Criticality Safety Program

- L. Implementation of the facility Industrial Hygiene (IH) Program

6.3.5 Emergency Plan - The Site Emergency Plan, Procedure Manual 6Q, "Westinghouse Savannah River Company Savannah River Site Emergency Plan", defines appropriate response measures for the management of emergencies involving the SRS. The plan forms the policy basis for the conduct of operations related to emergency planning, response, and consequence mitigation. Line organizations are responsible for:

- a. Implementing facility emergency preparedness programs consistent with Procedure Manual 6Q
- b. Maintaining area/facility emergency plan annexes and associated implementing procedures and updating on an annual or as needed basis
- c. Ensuring an adequate facility Emergency Response Organization (ERO) is established and maintained
- d. Providing technical support for drill/exercise scenario development
- e. Implementing facility ERO training drills
- f. Determining corrective actions; coordinating and tracking resolution of open area/facility emergency preparedness items
- g. Implementing facility protective action drill program.

6.3.6 Facility Fire Protection Program - The facility Fire Protection Program is described in Procedure Manual S1-1-1, Item 3.02, "FB-Line Facilities Fire Protection Program Plan (U)". This plan gives an overview of the responsibilities of personnel involved with fire protection and references facility procedures to minimize the following:

- a. Threats to the public or worker health or welfare resulting from a fire
- b. Hazards to site personnel from a fire
- c. Delays to important DOE programs as a result of a fire
- d. Safety and control system or property damage related to a fire.

The Fire Protection Program gives an overview of the responsibilities of personnel involved with fire protection and references facility procedures that accomplish the following objectives:

- a. Fire Prevention
 - i. Maintaining the fire-resistant construction of the structure in a manner that does not decrease the fire resistance of the structure
 - ii. Control of combustibles
 - iii. Control of ignition sources
 - iv. Facility inspections
 - v. Handling of combustible/flammable liquids and gases

- b. **Fire Control**
 - i. Automatic detection/suppression and alarm systems
 - ii. Fire Watch (If a fire detector or alarm is found inoperable, a Fire Patrol inspects the affected fire detection zone within four hours of discovery, maintains this watch on a four hour shift until the system is returned to operability, and provides backup suppression as necessary.)
 - iii. Adequate fire barriers (e.g., walls, doors, dampers)
 - iv. Proper availability and maintenance of facility fire fighting equipment
 - v. Identification of facility fire fighting personnel, responsibilities, and training
 - vi. 24-hour fire fighting coverage
 - vii. Proper Fire Control Pre-Plans that adequately cover manual fire fighting methods and possible emergency conditions during fire fighting and that identify special hazards within the facility.

FB-Line is not currently in full compliance with all DOE Order 5480.7A fire protection requirements. The FHA, M-FHA-F-00022, Rev. 4, lists all known FB-Line deficiencies with respect to fire protection. One significant issue was identified in the FHA and that is the possibility of a fire on the third or fourth level of FB-Line causing an unfiltered release of radioactivity to the environment. This issue has been addressed and is discussed in Section 8.3.2.3 of this BIO.

6.3.7 Nuclear Criticality Safety Program - The Nuclear Criticality Safety Program, as defined in Manual WSRC-IM-93-13, "Nuclear Criticality Safety Manual", is implemented by Procedure Manual 1E7, "NMPD Engineering Procedures Manual (U)", Procedure T-410, "NMPD Nuclear Criticality Safety (U)", and Procedure Manual S1-1, "Separations Program Administrative Manual", Procedure OP4.14-02, "200-Area Criticality Audit Committee Charter (U)". This program is a formal, documented system for the control of nuclear safety parameters and their bases, identification, and verification, which provides a tracking system for the status of audit findings. The Facility Manager ensures:

- a. Nuclear Criticality Safety Evaluations (NCSEs) are performed when required
- b. Facility personnel receive nuclear criticality safety training
- c. Operations are controlled to comply with established subcritical margins
- d. Nuclear Incident Monitors (NIMs) are installed and maintained as required for criticality detection
- e. Compliance with DOE Orders and American Nuclear Society (ANS) Standards.

This program has been successful in maintaining nuclear criticality safety in FB-Line. There have been no criticalities.

The current approved SAR for FB-Line does not explicitly address or document requirement statement 7.c.(8) from DOE Order 5480.24. The information in the following paragraph is included in this BIO to satisfy the requirement that the SAR include a description of the technical practices and measurement control program used in determining the quantities of fissionable material present in any location and the uncertainties of the measured values.

In response to the requirements of statement 5480.24 7.c.(8): The current approved FB-Line SAR has a section on process and facility description (Section 3.2) and engineered safety features (Section 3.3), but all the information indicated by this requirement is not present in the SAR. The information does exist in FB-Line documents relating to material control and accountability plans. These documents include (1) NMP-SBT-91-225, "FB-Line Measurement and Control Program Plan", Rev. 0, June 1992, (2) SSE-MCP-920036, "Static LEID", June 1992 (this document is classified), and (3) NMP-SBQ-930004, "FB-Line Material Control and Accountability Implementation Plan", July 1993.

In addition, a Double Contingency Analysis (EPD-NCE-94-0144) for FB-Line process operations will be completed and issued before declaration of readiness for restart (C).

6.3.8 Nuclear Criticality Safety Evaluations - NCSEs are the base document for nuclear criticality safety control. Processes must be shown to be subcritical under all normal and credible abnormal operating conditions. NCSEs are used to evaluate new processes or process changes before any fissile material is processed, stored, or shipped and document the calculations and judgments used in determining that nuclear criticality safety is ensured.

6.3.9 Configuration Control - A graded Configuration Control Program as described in Procedure Manual 7E, "Configuration Management Manual (U)", is implemented according to Reference 5 that:

- a. Identifies, documents, and functionally tests the Safety-Related systems
- b. Ensures that changes are properly developed, assessed, approved, issued, and implemented through the use of the following:
 - i. Change Control Review Boards
 - ii. Setpoint control
 - iii. Design control
 - iv. Software control
 - v. Technical review and approval process, including performance of a USQ screening/evaluation and review of environmental documentation
 - vi. Document control

- vii. Verification and acceptance process
- viii. Compliance auditing
- c. Maintains a system for recording, safeguarding, and indicating the status of technical baseline documentation.

6.3.10 Installed Process Instrumentation - IPI is identified and programmatically controlled, according to Procedure Manual 1Q, "Westinghouse Savannah River Company Quality Assurance Manual (U)", Procedure QAP 12-2, "Control of Installed Process Instrumentation (U)", when utilized to monitor process variables (such as level or temperature) used to comply with the requirements of the OSR and TS. Controls include the following:

- a. Traceability of OSR/TS-related IPI items
- b. Calibration frequencies for OSR/TS-related IPI items
- c. Evaluation of OSR/TS-related IPI items found outside of calibration tolerances.

6.3.11 Environmental Compliance Program - Facility and co-located workers and the public are provided protection from normal operational releases and exposures as well as postulated accidental releases of hazardous materials through facility compliance with its Environmental Compliance Program, as described in Procedure Manual 3Q, "Environmental Compliance Manual (U)". This manual is designed to comply with applicable federal and state environmental regulations, and consists of:

- a. Administrative procedures
- b. Training
- c. Physical controls.

FB-Line is operated in compliance with the applicable state and federal permits and regulations. Liquid waste is directed to the Effluent Treatment Facility (ETF) or the F-Area Tank Farm by way of F-Canyon. Both ETF and the Tank Farm are permitted by the state as waste water treatment facilities. Solid waste is characterized when generated and disposed of in the proper permitted Waste Management facilities. Radioactive releases are monitored in compliance with requirements of the National Emission Standard for Hazardous Air Pollutants (NESHAP). All radioactive releases are significantly less than the DOE and Environmental Protection Administration (EPA) standard for dose to the public at the site boundary.

6.3.12 Industrial Hygiene Program - An IH Program, as described in Procedure Manual 4Q, "Industrial Hygiene Manual (U)", is implemented to achieve compliance with DOE orders and DOE-prescribed IH standards for controlling occupational exposures to specific chemical, physical and biological hazards. The IH program establishes essential elements to address identification, evaluation, and control of these hazards within the workplace.

6.4 Events, Conditions, and Concern Investigations, and Occurrence Reporting

Events, conditions, and concerns that may involve safety, health, safeguards & security, or environmental implications are controlled by WSRC policy, as described in Procedure Manuals 9B, "Site Item Reportability and Issue Management (SIRIM) (U)", 9B3, "NMPD - Separations Requirements for SIRIM (U)" and 2S. It is the policy of WSRC to encourage a positive attitude toward reporting occurrences and that occurrences be consistently reported to ensure that both DOE and WSRC line management, including the Office of the Secretary, are kept fully and currently informed of all events that could: (1) affect the health and safety of the public; (2) impact the operation of DOE facilities; (3) degrade the environment; or (4) endanger the health and safety of workers. It is also the policy of WSRC that there be a system for determining appropriate corrective actions and for ensuring that such action is effectively taken. Specifically, it is WSRC policy to ensure the following:

- a. Timely identification, categorization, notification, and reporting to DOE and contractor management of all reportable occurrences at DOE-owned or -operated facilities
- b. Timely evaluation and implementation of appropriate corrective actions
- c. Submission of all required reports to the Occurrence Reporting and Processing System (ORPS) database to provide lessons learned to other DOE operations and facilities to prevent similar occurrences
- d. Review of reportable occurrences to assess significance, root causes, generic implications, the need for corrective actions, and lessons learned.

6.5 Review And Audit

Comprehensive safety reviews and audits are performed to assure compliance with applicable safety codes, standards, and good safety practices. The reviews and audits fall into one of the following categories:

- a. Independent audits, reviews, and safety appraisals
- b. Criticality audits
- c. ORRs.

The internal review system is evaluated, on the average, every 42 months, per Procedure Manual 1B, "Westinghouse Savannah River Company Management Requirements and Procedures (U)", Procedure MRP 5.09, "Triennial Reviews of Independent Review and Appraisal Systems (U)".

6.6 Training

Personnel receive initial training in the safety aspects of jobs with periodic retraining in certain areas (e.g., chemical hazards and self-monitoring of radiation exposure). Personnel also receive training in emergency actions as described in area and site emergency plans and procedures. Personnel involved in operations affecting nuclear safety are trained in their tasks prior to assuming the responsibilities of the position. Training requirements are detailed in accordance with administrative procedures.

Initial training, continuing training, and retraining of qualified supervisors and qualified operators are carried out by formal classroom instruction and on-the-job experience. Initial operator qualification is based on a demonstrated acceptable level of competence and performance. Initial operator qualification depends on satisfactory completion of comprehensive examinations and operating evaluations; satisfactory physical condition; general health; and higher supervision's judgment of general qualifications.

The training program (Procedure Manual S1, "NMPD and WMER Organization and Administration Manual (U)", Procedure OP5.10, "Personnel Selection, Training, Qualification/Certification Program (U)") addresses the positions identified for accreditation. Performance-based training is used for designing and implementing all training. Continuing training and reexamination on emergency response procedures are conducted annually, and biennially for other procedures important to safe operation. Requalification is conducted biennially. The bases for both initial qualification and requalification are documented. Documentation includes a copy of the most recent test results and grades.

DOE has approved an exemption from DOE Order 5480.18A for the FB-Line facility. The facility does not intend to have its training program accredited.

6.7 Facility Operating Records

Records retention practices are in accordance with the SRS QA Plan and Records Management directive(s). Specifically, the following documents are retained as records for the period specified by the FB-Line Records Retention Schedule and Procedure Manual S1-1-1, Item 2.17, "FB-Line Document Control and Records Management (U)":

- a. Records and logs of facility operation
- b. Records and logs of principal maintenance activities, inspections, repairs, and replacements of principal equipment items related to nuclear safety
- c. All reportable events/occurrences
- d. Records of surveillance activities, inspections, and calibrations required by OSR and TS
- e. Records of changes made to procedures
- f. Records and drawing changes reflecting facility design modifications made to systems and equipment described in the SAR
- g. Records of radiation exposure for all individuals entering radiologically controlled areas
- h. Records of gaseous and liquid radioactive material released to the environment
- i. Records of facility tests and experiments
- j. Records of training and qualification for current members of the facility Operations staff

- k. Records of USQ screenings/evaluations performed for changes made to procedures or equipment, or USQ screenings/evaluations for tests and experiments.

6.8 Radiation Protection Program

The facility Radiation Protection Program is conducted in compliance with Procedure Manual 5Q, "Radiological Controls Manual (U)", so that exposure of WSRC employees, subcontractors, visitors, and the general public to radiological hazards is well below DOE limits and are ALARA. The facility Radiation Protection Program ensures that individual and collective radiological exposures are maintained ALARA by:

- a. Integrating the support functions of Radiological Control and Health Physics (RC&HP) into daily operations and long term planning
- b. Participating in required site radiological training
- c. Creating barriers for and posting controlled areas
- d. Utilizing Radiological Work Permits
- e. Monitoring and controlling accumulated doses to workers
- f. Controlling the generation and spread of radiological contamination
- g. Managing radioactive material, and
- h. Monitoring and controlling radioactive effluent streams.

6.9 Facility Radioactive and Hazardous Materials Shipping and Receiving Program

The facility Radioactive and Hazardous Materials Shipping and Receiving Program, as specified in Procedure Manual 19Q, "Transportation Safety Manual (U)", and Procedure Manual 5Q:

- a. Is documented
- b. Implements the requirements of federal and state agencies
- c. Complies with applicable federal and state requirements by pre-shipment verification
- d. Ensures that designated cognizant personnel are trained in radioactive and hazardous material shipping and receiving (This training is documented in accordance with Section 6.6.)
- e. Retains programmatic and shipment records in accordance with the SRS QA Plan and Records Management directive(s).

6.10 Quality Assurance

The facility QA Program, through the site QA Program (Procedure Manual 1Q), :

- a. Is implemented through written procedures and instructions
- b. Applies to construction, operation, maintenance, research, development, and design
- c. Requires that sufficient records be maintained to preserve the technical baseline documentation
- d. Supports independent audit/verification requirements to determine compliance with the site QA Program
- e. Provides for a graded approach to the application of QA requirements.

6.11 Waste Management

The DOE policy as outlined in DOE Order 5820.2A "Radioactive Waste Management", is that any radioactive, hazardous or mixed waste, shall be managed in a manner that assures protection of the health and safety of the public, DOE and contractor employees, and the environment. The generation, treatment, storage, transportation, and/or disposal of radioactive, hazardous, or mixed waste shall be accomplished in such a manner that minimizes the generation of such wastes and complies with all applicable Federal, State, and local environmental, safety, and health laws and regulations and DOE requirements.

The FB-Line Waste Management Program, as described in Procedure Manual S1-1-1, Item 7.01, "FB-Line Program Waste Minimization Plan (U)", is based on Procedure Manual 1S, "Waste Acceptance Criteria Manual (U)", and Procedure Manual 3Q. Procedure Manual 1S covers solid waste generated by the facility. Procedure Manual 3Q covers air and water emissions and hazardous waste management.

6.12 Equipment Maintenance

The FB-Line Equipment Maintenance Program, as described in Procedure Manuals SS22.1, "Separations Maintenance Administrative Procedures Manual (U)" and 1Q10-3, "Separations Engineering Quality Support Procedures Manual (U)", requires planned and systematic actions to preserve and promptly restore the operability, reliability, and availability of, or to prevent failure of, facility structures, systems and components. The program is based on a graded approach to maintenance and includes the following categories of maintenance activities:

- a. Corrective Maintenance
- b. Modifications
- c. Additions
- d. Administrative orders
- e. Technical specification surveillances
- f. Periodic maintenance

- g. Planned maintenance
- h. Predictive maintenance
- i. Operating services
- j. Temporary modifications.

6.13 Work Control

The FB-Line Work Control program, as defined in Procedure Manual SS22.2, "Separations Maintenance Work Control Procedures Manual (U)", provides a methodology for safely and efficiently identifying, managing, tracking, and documenting maintenance activities using an administrative control system that details the work process, from task identification through the documentation of a completed maintenance activity. This administrative control system uses a graded approach (based upon functional classification) to maintenance activities, and includes:

- a. Work identification
- b. Work item validation
- c. Work package preparation
- d. Pre-work review and approval
- e. Staging
- f. Scheduling
- g. Coordination and release
- h. Work order performance
- i. Work completion and retest
- j. Post-work review and documentation.

6.14 Conduct of Operations

The FB-Line Conduct of Operations program implements DOE Order 5480.19 through Procedure Manual 2S. This manual is the single site document which lists the Conduct of Operations requirements for each division and facility. Facility operations and support personnel are responsible for knowing and adhering to the requirements contained in this manual including any facility-specific use of a graded approach and approved deviations.

6.15 Performance Indicators

The following are some of the performance indicators used to ensure compliance with applicable safety goals and requirements:

- a. The Savannah River Site Environmental Report
- b. The Savannah River Site Radiological Performance Report
- c. The Savannah River Site Annual Safety Appraisal Reports.

7.0 OPERATING ENVELOPE

The safety envelope for FB-Line is defined by the WSRC hazard and accident analyses and is maintained through the safety management programs and the BIO requirements. Operation within this envelope is analyzed and demonstrated in the authorization basis documents. These documents are described in Section 4.0 of this BIO, and currently address processing for Pu solution from F-Canyon, process residues, and offsite scrap. These documents also address storage of Mk 42 Scrap.

The OSR and TS, along with the additional controls identified in this BIO, provide limits and controls that ensure operation within the operating envelope. Table 8.F documents the SAR requirements, OSR limits, TS limits, Safety-Related systems, Administrative Controls and Design Features credited for each dominant accident identified in the PHA and the FB-Line SAR.

For proposed activities that arise after issuance of this BIO, the USQ process will provide the mechanism for demonstrating that new initiatives remain within the operating envelope.

8.0 SAFETY EVALUATION

8.1 Facility Categorization and Hazard Identification

The hazard category of a facility is used in determining the level of analysis and documentation required to define the Authorization Basis for operating the facility. The method to determine a facility hazard category is given in DOE Standard DOE-STD-1027-92 (Reference 1). In order to apply this method, the type and quantity of hazardous material expected to be present within the facility must be established.

For FB-Line, the significant hazards to workers and the public are the result of radioactive material and chemicals. Tables 8.A and 8.B provide information regarding the amount of radioactive material that could be present in FB-Line at any time. The maximum amount is $6.2E+06$ Curies at the isotopic distribution of Table 8.A. This value is calculated by using the maximum process inventories based on NCSS limits as summarized in Reference 6 and the specific activity from the SAR. Actual operating limits are generally well below these values, and extensive management and programmatic safety involvement would be required to approach these values for some unforeseen reason. The ^{239}Pu content fraction of this total alone establishes FB-Line as a Category 2 facility in that it exceeds the threshold of 900 gm ^{239}Pu as stated in Reference 1.

**DELETED
VERSION**

**Table 8.A
FB-Line Isotopics, from SAR**

Nuclide	Isotopic Curie Fraction
Pu-238	1.38E-03
Pu-239	6.65E-02
Pu-240	1.49E-02
Pu-241	9.17E-01
Pu-242	1.15E-06
Total	1.00E+00

**Table 8.B
FB-Line Process Area NCSS Maximum Permissible Inventories**


Process Area/Cabinet/ System	Maximum Inventory (kg of Pu)
Cation Exchange	110.8
Concentrate Feed and Flush Adjustment	10.8
Precipitation and Filtration	92.5
Mechanical Line	125.3
Recovery	49.4
Solution Transfer Vacuum System	12.14
	
Waste Handling	114.47
NDA Room	72
Miscellaneous	1273

Table 8.C provides capacities of tanks used to make up and store liquid chemicals used in FB-Line. The tanks listed transfer liquids to smaller head tanks which are used to feed process vessels. Information on the type of chemicals used in FB-Line and their physical forms is presented in Table 8.D.

**Table 8.C
FB-Line Cold Feed Tank Capacities**

Make-up Tank	Approximate Capacity, liters	Make-up Tank	Approximate Capacity, liters
P-1A, B	550	P-12	61
P-3	1211	P-13	42
P-4A, B	318	P-15	42
P-5A, B	160	P-16A, B	42
P-6A, B	250	P-17	575
P-7	250	P-18	120
P-8	255	P-19A, B	113
P-8A	770	P-20	27
P-9	200	P-21A, B	64
P-10	1014	P-22	660
P-11	61		

**Table 8.D
Chemicals Used in FB-Line Processing**

Chemical ^a	Form As Received on Site
Activated Alumina	Pellets
Aluminum Nitrate Nonahydrate	Liquid
Argon	Compressed gas
Ascorbic Acid	Solid crystals
Boric Acid	Crystalline powder
Calcium	Granulated metal
Calcium Fluoride	Solid crystals
Ferrous Sulfamate	Liquid
Hydroxylamine Nitrate	Liquid
Hydrofluoric Acid	Liquid
Ion Exchange Resin	Resin
Nitric Acid	Liquid
Magnesium Oxide	Sand and crucibles
Nitrogen	Compressed gas
Nitrogen	Cryogenic liquid
Oxygen	Compressed gas
Soda Ash	Powder
Sodium Hydroxide	Liquid
Sodium Nitrite	Solid crystals
Sodium Sulfate	Crystalline powder
Sulfamic Acid	Solid crystals
Sulfuric Acid	Liquid

a. All chemicals free of radioactivity.

The potential effect of FB-Line radiological and chemical hazards on workers and the public can be divided into two categories - effects from normal operations and the postulated effect of potential accidents.

The impact of normal operations of FB-Line to the environment and the public is negligible. The SRS Environmental Report for 1989, WSRC-IM-90-60, Volume 1, summarizes the impact of 1989 SRS normal operations on the offsite environment and to the public. The 1989 report is referenced to reflect a recent time period during which FB-Line was operating. The report concludes that the annual maximum dose from all SRS releases (not just FB-Line) for all exposure pathways was 0.61 mrem, as compared to the limit of 100 mrem (as specified in DOE Order 5400.5). Nonradiological atmospheric emissions were within applicable standards during 1989.

The impact of potential accidents is discussed in detail in Section 8.3. The accident evaluation in this BIO is based on the SAR for FB-Line, and a PHA. The dominant accidents for the facility, their relative frequency and consequence, and their degree of risk (i.e., Scenario Class) are given in Table 8.E.

8.2 Hazard Analysis and Accident Categorization

8.2.1 Hazards Analysis

8.2.1.1 PHA Method

A PHA was completed in May, 1994, for FB-Line, under the direction of DOE Headquarters (DOE-HQ). A team of WSRC personnel from FB-Line and DOE-HQ personnel was assembled to perform the PHA and document the results. The PHA represents a team exercise to identify significant radiological and chemical hazards associated with FB-Line. Frequencies and consequences were estimated in a semi-quantitative manner for the accidents identified affecting the public or co-located worker. Accidents identified affecting the facility worker were treated qualitatively. For both cases, existing safety documentation and information were used to the extent possible.

After identification, the accident scenarios were binned into one of three frequency categories and one of three consequence categories, for a final risk class (called Scenario Classes) ranging from I to IV, with I being those with the highest risk and IV being those with the lowest risk. In addition to categorizing the accidents, the team identified engineered systems, structures, components, controls, or procedures that are in place to prevent or mitigate the accidents. Table 8.F summarizes the significant results of the PHA including the prevention and mitigation characteristics for the process accidents identified in the PHA/SAR. The principal recommendations in Section 4.0 of the PHA are addressed in Table 8.F and Section 8.3.2. The recommended enhancement in Section 4.4 of the PHA (compliance with FHA recommendations) will be addressed by facility management and documented in approved CSAs prior to declaration of readiness for restart (C).

The purpose of the PHA was to identify dominant accident scenarios and the safeguards in place to protect against them. The process by which scenarios were identified as dominant was largely qualitative, based on a review of the deviations by the PHA Team to determine a set of scenarios spanning a spectrum of accident types (fires, spills, explosions, etc.) having the potential to present significant radiological or non-radiological consequences to personnel inside the facility, onsite, and offsite. To characterize the potential for consequences in a manner appropriate to the level of effort required for a BIO document, the identification generally focused on the event presenting the largest consequences to the

affected receptors. This does not necessarily mean that the accident scenarios are valid for situations involving other process equipment and smaller source terms.

The technique used in the PHA accident analysis was an adaptation of the Hazard and Operability Review (HazOp) technique that was first developed for use in the chemical process industries. The facility in question is split into nodes, which usually are lengths of pipework between major items of equipment or major vessels. Then the causes and consequences of deviations from normal operation, such as high flow/temperature/pressure, low flow/temperature/pressure, no flow, reverse flow, high or low level, etc. are investigated. If a cause is identified that leads to significant consequences, existing safeguards are discussed. If these safeguards are not adequate, design or procedural changes or additional analysis may be recommended. Details on the hazard analysis process for FB-Line may be found in the PHA.

Estimates of frequencies and consequences for the dominant accidents identified in the process described above were refined, where necessary, through further research and consideration of additional information such as airborne release fractions, respirable fractions, initiating events, preventive and mitigative features, and dispersion mechanisms. Additional supporting information for the PHA analyses was developed using a range of qualitative and semi-quantitative techniques, ranging from engineering judgment to event tree development.

The accident scenarios thought to bound the risk at FB-Line are summarized in the PHA. These scenarios are as follows:

1. Inadvertent Criticality
2. Ion Exchange Column Explosion
3. Propagated Fire
4. Worker Exposure Due to Air Reversal

Section 8.2.2, Accident Categorization, describes the "binning" of these scenarios into classes which indicate the relative risk associated with these scenarios. Only the accident scenarios binned as Scenario Class I and II are considered dominant accidents and given detailed discussion in this BIO.

8.2.1.2 SAR Method

The purpose of the SAR is to describe the facility and equipment operation and document the principal analyses made to determine that the facility can be operated without undue risk to the public. It identifies potential hazards and parameters affecting facility safety and determines with reasonable assurance that the facility has the capacity for preventing accidents or mitigating their effects sufficiently to preclude undue risks to the health and safety of the public and co-located workers. It also provides technical information needed to define the boundary between acceptable and unacceptable conditions.

8.2.1.2.1 Conversion Factors

ICRP 2 Dose Conversion Factors were used in SAR consequence analyses, as opposed to the most current ICRP 30 Dose Conversion Factors. An increase of risk caused by ICRP 30 dose conversion factors will occur, but sample calculations show that the resulting increased risk is still within the guidelines that have been documented by DOE, NRC, and

WSRC. Section 8.3 of this BIO gives descriptions of accidents analyzed in the SAR, and the estimated effect of ICRP 30 conversion factors, as well as ICRP 30 consequences for bounding accidents (see section 8.2.1.2.2). The ICRP 2 models for lung, bone and other organs were defined in 1959. The ICRP 30 (1979) models account for dose to organs (target) from beta- or gamma-emitting nuclides deposited in neighboring (source) organs. This added complexity accounts for no change in dose if the nuclide is an alpha emitter, but may be quite large for some organs if the nuclide is a gamma emitter. Dose calculations for mixed fission products generally yield higher results with the ICRP 30 models than with the earlier models. For this document, the dose due to weapons grade Pu (isotopes 238, 239, 240, 241, and 242) in both the ICRP 2 and ICRP 30 models were compared, and the weighted effect (by isotopic fraction) was an increase by a factor of nearly seven for all accidents except criticality. Criticality doses are dominated by the volatile fission products, which when compared in the same manner, increase by a factor of less than three. These factors can be conservatively applied to any accident analyzed in the SAR. For the bounding accidents, doses were calculated using AXAIR89Q, which includes upgrades to meteorology and population databases, and therefore do not reflect the simplified factors of seven and three.

8.2.1.2.2 Source Terms

Existing risks in the SAR reflect nominal batch sizes and are based on typical Pu isotopic composition for the material that was being processed in the facility at the time the SAR was written. Specific activities used in dose consequence calculations were based on half-lives for the various Pu isotopes published in Reference 7. Source terms for accident consequence analysis were based on the energetics of the accident. Release fractions are based on the material being in the form of liquids and finely divided solids, which is conservative, given that in many cases, some, if not all of the material is metal. For simplicity, accidents were grouped into three potential categories: high energetic, medium energetic, and low energetic. A high energetic event is defined in the SAR as one which will destroy both the first and second confinement barriers (e. g., vessel and glovebox), allowing radioactivity to reach the process room directly. Given that no high energetic accidents were identified for the FB-Line operation, a single batch of material was a logical source term for all risk analyses.

Current USQ requirements show the need for a bounding consequence analysis in each of 3 frequency categories. Therefore, for this document, the source term for five bounding accidents is conservatively based on maximum allowable inventories, as defined in the NCSS. Five accidents, rather than three, are analyzed in this manner so that a comparison can be made among accidents of different types within the same frequency category. The maximum inventories, allowed by NCSS under special conditions, are significantly above the normal operating limits. This method for determining the source term is applied to the processing inventory in the analyses discussed in this report and the FB-Line Vault inventory, as well, for the earthquake analysis. Although the vaults contain a variety of different materials with different isotopic compositions, this assumed weapons grade isotopic composition was compared to the material contained in the vaults and to material postulated to be in the vaults in the near future and found to be conservative (Reference 8). The build-up of ²⁴¹Am was considered in this comparison. In addition, these bounding consequence analyses were analyzed using the updated AXAIR89Q dose code, rather than simply multiplied by a factor to account for differences in ICRP 2 and ICRP 30. Table 8.B shows the maximum inventories by Process Area/Cabinet/System.

Existing material has been analyzed according to operating procedures and found to be within the scope of the Authorization Basis, and any material to be stored or processed in

the facility in the future that is not within prescribed composition limits will be analyzed under the USQ process and the new configuration control system to evaluate the risk.

8.2.1.2.3 Population Data Base

A population database for 1980 was used in the SAR as opposed to the more current 1989 database, which reflects an increase in both onsite and offsite populations. This difference does not affect the maximum individual risk, but depending on which sector is "worst" for a particular accident scenario, the onsite population risk could increase by a factor of approximately two.

The maximum onsite population dose due to a single accident, as documented in the SAR, was 2.78 person-rem, for criticality, with a frequency of once per 7400 years. Accounting for the conversion to ICRP 30, this would increase by a factor of 3 to 8.34 person-rem. With the new population database, the risk could approximately double to 16.7 person-rem.

8.2.1.2.4 Dose Recipients

The existing SAR evaluates 3 dose recipients. These recipients include the onsite population, offsite population, and the maximum exposed individual offsite. SARs prepared to SROM 5480.5-1 (Reference 9) evaluate 7 dose recipients. The 4 additional groups are:

- Facility operator at the site of the accident
- Personnel within adjacent areas within the facility
- Maximally exposed individuals within the area (excluding the initiating facility)
- Area population (excluding the initiating facility).

The maximum individual offsite is the only recipient for which DOE has criteria on which to judge the acceptability of accidental radiation dose. An estimate of the dose for the co-located worker 640 meters from the stack was made for the bounding accidents. Using 50% meteorology, this co-located worker could expect a dose (ICRP 30) of about 5.21 rem due to a propagated fire with maximum inventory, 260 mrem due to a criticality with $1E+19$ fissions, and 343 mrem due to a 0.2g earthquake with maximum inventory. Given the low frequency for such events WSRC considers this to be an acceptable risk.

8.2.2 Accident Categorization

The accident scenarios from both the SAR and the PHA have been evaluated in terms of a "Risk Matrix" to place the consequences and frequencies of accidents into broad bins to aid

in comparing the relative risks of the accidents. This matrix appears below:

High Consequence	II	I	I
Medium Consequence	III	II	I
Low Consequence	IV	III	III

Frequency: Low Medium High
 (10⁻⁶ to 10⁻⁴/yr) (10⁻⁴ to 10⁻²/yr) (above 10⁻²/yr)

The Roman numerals in the table represent Scenario Classes, which are defined as follows:

- Scenario Class IV - Negligible
- Scenario Class III - Marginal
- Scenario Class II - Serious
- Scenario Class I - Major

The consequence levels corresponding to the high, medium and low consequence bins are shown in the matrices below, the first for radiological consequences and the second for chemical accident consequence levels :

	Public	Workers
High Consequence	> 5 rem at site boundary	> 25 rem at 600 m or prompt death in facility
Medium Consequence	> 0.1 rem at site boundary	> 0.5 rem at 600 m or serious injury in facility
Low Consequence	< Medium	< Medium

	Public	Workers
High Consequence	> ERPG-2* at site boundary	> ERPG-3* at 600 m or prompt death in facility
Medium Consequence	not applicable	serious injury in facility
Low Consequence	< High	< Medium

* ERPG-2 and-3 are Emergency Response Planning Guidelines as stated in DOE Standard DOE-STD-3011-94.

It is noted that the co-located receptor location is 600 m in the DOE guidance (Reference 10), whereas the co-located receptor location that was used in this analysis is 640 m. This is due to the existing standard at SRS of using the dose at 640 m for evaluation purposes.

Table 8.E contains a summary of the results of the binning process. Consequences in this table are identified in terms of the impact to facility workers, co-located workers, and the public, as applicable. The Scenario Class I and II accident scenarios are described in Section 8.3.2.

Table 8.E
Summary Table of Results of Risk Matrix Binning for FB-Line Operations

SCENARIO	CONSEQUENCE	FREQUENCY	SCENARIO CLASS	RECEPTOR (Note 1)	SOURCE DOCUMENT
Inadvertent Criticality	High	Medium	I	Facility Worker	SAR
Inadvertent Criticality	Low	Medium	III	Co-Located Worker, Public	BIO
Ion Exchange Column Explosion	High	Medium	I	Facility Worker	PHA
Ion Exchange Column Explosion	Low	Medium	III	Co-Located Worker, Public	PHA
Single Level Propagated Fire	Medium	Medium	II	Co-Located Worker, Public	PHA
Propagated Fire	Medium	Low	III	Co-Located Worker, Public	BIO
Air Reversal	Low	High	III	Facility Worker	PHA/SAR
Earthquake	Low	Medium	III	Co-Located Worker, Public	BIO
Medium Energetic Event	Low	Medium	III	Public	SAR
Low Energetic Event	Low	High	III	Public	SAR/BIO

Note 1 - The co-located worker is 640m away from the release point.

8.3 Accident Analysis

8.3.1 Dominant Accidents

A summary of the operating risks for FB-Line, documented in the PHA, the SAR, and this BIO, is included in Table 8.E. The "bins" selected for the accidents listed in the table are based on the maximum consequence value calculated and the corresponding frequency.

8.3.2 Dominant Accident Scenario Descriptions

This section presents descriptions of the dominant accident scenarios (i.e., Scenario Class I and II) reported in Table 8.E. A comprehensive presentation of specific safeguards for these accidents and detail on how these safeguards are preserved can be found in Table 8.F. These safeguards include items such as applicable SAR requirements, OSR, TS, identification of Safety-Related equipment, ACs, and DFs. Table 8.F also classifies the safeguards for these accidents as either preventors or mitigators. Each accident scenario discussion provided below describes the sequence of failures that must occur to cause a release, the assumptions incorporated in characterization of the release; the consequence, frequency and accident scenario classification; and provides a description of the preventive

and mitigative features (safeguards) relied upon to protect against the accident. Safeguards added or recognized as a result of a scenario evaluation are specifically identified as ACs or DFs. For Scenario Class I accidents, an explanation of frequency and/or consequence reduction is provided from the original PHA/SAR scenario.

The Scenario Class III accidents listed in Table 8.E are not explicitly described in this section because they are not considered to be dominant accident scenarios. For more information on these accident scenarios, see the PHA, the SAR, or Section 8.3.3 and 8.3.4 of this BIO. Where BIO is listed as the source document, the new analyses upon which classification is based are those analyses described herein as having been performed using the new updated AXAIR89Q source code.

8.3.2.1 Inadvertent Criticality

The potential for inadvertent criticality was examined extensively in the PHA and has been a key safety concern FB-Line operators have managed for decades. The controls and safeguards against inadvertent criticality generally consist of geometrical configurations that limit the potential for criticality in vessels, and/or limits on the concentrations of fissile materials in solutions, and/or limits on the total amount of fissile materials in any one vessel, and/or limits on the quantity of solid fissile material in any one area.

These general safeguards are implemented throughout FB-Line by specific equipment such as favorable geometry process vessels; precipitator neutron monitors to prevent excessive Pu accumulation; and sample and waste assay equipment.

Inadvertent criticality was analyzed as a credible and bounding accident in the SAR. Estimated number of fissions produced as a result of a Pu solution criticality (the most likely criticality scenario) was determined by a statistical analysis of historical criticality accidents. The mean number of fissions was determined to be $2E+18$, and this was the value used in developing the source term for a criticality accident in FB-Line. The release percentage for a medium energetic event, 0.02%, (Reference 11) is applied to the typical batch size of one vessel, and this amount of Pu and nonvolatile fission products was assumed released to the sand filter (99.51% efficient). In addition, 100% of the volatile fission products are assumed to be released, with no filtration provided by the sand filter. The result was a release to the environment of $4.8E+4$ curies of volatile fission products and 0.047 curies of nonvolatile fission products plus Pu. The resulting dose to the maximally exposed offsite individual was 1.6 mrem (ICRP 2 values). The same accident, factored up to account for ICRP 30 dose values, would be 3 times greater in consequence, or 4.8 mrem. The reason for the factor of three, versus the factor of seven used in all other consequence analyses, is due to the dominating effect of the volatile fission products on the final weighted average dose. Volatile fission products did not change as significantly as Pu in the ICRP upgrade from version 2 to version 30.

For the new bounding criticality accident, the source term was based on a maximum number of fissions, as recommended in NUREG Guide 3.34 ($1E+19$). The typical batch size for one vessel was used for calculation of the Pu release, as was done in the SAR. Use of the maximum permissible inventory per NCSS limits would not have affected the consequence analysis, since volatile fission products (which are not filtered out and are determined by number of fissions rather than batch size) dominate the release, which is analyzed using the updated AXAIR89Q dose code. This maximum number of fissions is considered to be bounding for both solution and metal criticalities. The result was a dose to the maximally exposed offsite individual of 7 mrem (ICRP 30). Co-located workers, located 640 meters from the stack, using 50% meteorology, could expect a dose of about 260 mrem (ICRP 30) from this criticality accident scenario.

For the FB-Line SAR, the sequence of events that can lead to an accidental criticality was modeled in a fault tree. It is believed that this fault tree accurately bounds the full spectrum of possible accidents, including both solution and metal criticalities. Input for the basic events in the fault tree was extracted from the 200 Area Fault Tree Data Bank, which contains over 250,000 entries, and spans over 20 years of operation at SRS. The use of this facility specific data allows for inclusion of many types of failures, including those due to aging, and also allows for trend analyses, as documented in Reference 12. It may not, however, consider all common mode failures. Use of the 200 Area Data Bank, in conjunction with estimates on human reliability, results in an estimated frequency of a criticality accident of $1.4E-04$ per year or once every 7400 years, as documented in Reference 13. As with most fault tree estimates, there is uncertainty in the estimated values.

During a Readiness Self Assessment for restart of FB-Line, it was recognized that a need existed to re-examine controls for hydrogen dilution in FB-Line process vessels. Subsequent investigation revealed that enough hydrogen could be generated and could accumulate with time in the vapor space of FB-Line process vessels to potentially exceed the lower flammability limit (LFL). Structural analyses and nuclear criticality safety studies have concluded that geometrically favorable vessels can be sufficiently deformed during a hydrogen deflagration to cause a nuclear criticality based on existing mass limits. A fault tree analysis was performed (Reference 14) that showed the additional frequency of criticality due to hydrogen deflagration in FB-Line is $4.47E-04$ per year for a new overall frequency of $5.9E-04$ per year or once every 1700 years. As a result of this analysis, the facility has identified the hydrogen dilution purge systems as Safety-Related equipment for inclusion into Procedure Manual S1-1-1, Item 2.01 (See Section 8.5 for a description of this procedure).

An additional criticality concern for FB-Line is the sprinkler systems to be installed in the facility. The possibility that the sprinkler water may increase the likelihood of an inadvertent criticality and/or violate existing assumptions regarding the criticality safety of the facility has been noted. In light of this concern, the facility will perform a study to determine the impact of the sprinklers prior to their installation (C).

NIMs are required where needed in accordance with DOE Order 5480.24 requirements. The monitors have historically been considered as very important to safety, and under recent guidelines are being defined as a Safety-Related system, with rigorous surveillance requirements, as defined in the OSR and NIM TS. Personnel are periodically trained in the proper response to a NIM alarm, and are assumed to evacuate immediately when an alarm is activated.

The SAR assumed that in the event of a nuclear criticality accident, the NIMs would allow facility personnel to evacuate before the second burst. However, if multiple bursts were considered, only the impact on in-facility personnel would increase (consequence due to released fission products already assumes a total number of curies over an 8 hour period). In the SAR, an estimate was made for the number of in-facility worker fatalities that would occur as a result of a criticality in FB-Line. In Reference 13, estimates of typical facility occupancy were transposed to facility floor plans, and then, circles with radii of 23 feet (unshielded distance from an isotropically emitting radiation source of $2E+17$ fissions [first burst] that would produce an instantaneous dose of about 500 rad) were drawn from analyzed sectors in the fault tree where a criticality could occur. The number of workers within the circles were counted as assumed fatalities, and divided by the number of sectors for an average consequence of 4 fatalities per criticality. As part of the startup requirements, evacuation of facility personnel was verified to take less than 103 seconds

(Reference 15). It is possible that multiple bursts could occur before complete evacuation of the facility can take place. However, as stated in Reference 16, the time between bursts coupled with typical evacuation speed should be ample to assure that no worker is exposed to appreciably more than one burst. Given the low probability of occurrence of a second burst, and the fact that no credit is taken for self absorption or shielding, the estimate of 4 fatalities per criticality is considered to be quite conservative.

It is WSRC's position that the SAR estimate of worker fatalities due to a criticality, which uses a mean number of fissions from the first burst for historical solution criticalities, is conservatively realistic, given that of the 8 process accidents and 5 critical experiment accidents recorded in DOE/NCT-04 (A Review of Criticality Accidents, March 1989), none had a spike yield over $6E+17$, only one even had a total yield over $3E+18$, and only two of the accidents resulted in fatalities (single each). The largest accident, with a total yield of $4E+19$ and a spike of $1E+17$, occurred in a 5000 gallon tank with 35 kg of uranium, which is much larger than any FB-Line scenario. Bare and reflected metal systems had even lower yields. In addition, for most criticality accident scenarios in FB-Line, a second burst is unlikely to occur. This is due to the fact that the fault tree analysis concludes that the accidents most likely to occur either involve solid fissile material (which will disassemble and have only a single burst) or involve a solution that has been mistakenly collected in a temporary, nonfavorable geometry container such as a bucket, plastic bag, etc. In the solution scenario, either the container would not survive the criticality event, or the solution would quickly become subcritical due to rapid boil off of moderator.

At the request of the Office of Nuclear Safety, a nuclear criticality expert at Los Alamos National Laboratory provided an independent review of the criticality assumptions and analyses pertaining to WSRC's FB-Line Operations. The scope of his review (Reference 16) included site specific safety documentation, site visits, and published documents on criticality accidents, and supports WSRC's position that existing analyses are conservative.

Although criticality is classified as a Class I event for the facility worker based on its frequency as stated in the SAR and modified in this BIO, WSRC does not feel that any additional measures and/or limits are practical, nor necessary that reduce criticality frequency or consequence to Scenario Class II or lower. This position is supported by the above described review, as well as the conclusion of the PHA team that criticality is a low frequency event, resulting in its classification as a Class II scenario, and takes into consideration the Nuclear Criticality Safety Program described in Section 6.3.7.

8.3.2.2 Ion Exchange Column Explosion

FB-Line contains 2 anion exchange columns and 4 cation exchange columns. Many process specific engineering and administrative controls are in place to assure the resin is kept in a safe configuration.

Ion exchange resin, specifically nitrated anion exchange resin, has been known to breakdown with the evolution of combustible gases and pressures rupturing equipment causing significant equipment damage. Several incidents of anion exchange column ruptures have occurred across the DOE Complex and world wide with similar causal factors. The causal factors involved with the anion exchange incidents all have root causes which are the same. These root causes have been verified through extensive laboratory testing performed over the past 30 years to be the chief contributors to ion exchange column accidents and therefore are the most pertinent operational parameters to control.

The chief parameters responsible for maintaining safe ion exchange resin operation are nitric acid concentration of solutions in contact with the resin, heat load on the resin,

maintaining liquid surrounding the resin, pressure build-up negation, and resin radiation dose limitation. Controlling these parameters has been proven to assure safe ion exchange column operation. Contrarily, the absence of control on individual parameters does not guarantee the occurrence of an adverse event. These events initiate only from a combination of out of control parameters, not from a single out of control parameter.

FB-Line employs engineering controls in the resin process to assure these chief parameters are maintained. Both anion and cation resin processes employ a "loop-seal" design in the process piping which ensures the resin is covered with liquid at all times. Having a liquid blanket around the resin is important as it provides a very effective heat sink for removing the decay heat generated from the absorbed Pu and not allowing the resin temperature to increase. Another significant engineering control on the resin processes is the ever open vent. This ever open vent system provides a pressure sink to absorb gases which may be generated during a resin incident thus preventing pressure induced temperature increases and vessel pressurization. Typically, these Engineering controls are sufficient to guarantee a safe condition of the resin. However, to further ensure the safe condition of the resin, additional administrative controls are implemented.

The administrative controls employed by FB-Line include items which support the Engineering controls and additional Authorization Basis level requirements for radiation exposure limits on the resin, time limits for leaving a column in a loaded state, maximum nitric acid concentration allowed in contact with the resin, and resin temperature. By controlling these additional parameters administratively, in association with the Engineering controls, safe operation of the ion exchange processes can be assured.

In response to Recommendation 4.0 in the PHA, the safety envelope for this scenario is presented in Table 8.F. The PHA classified this event as a Class I scenario on the basis of a fault tree performed in 1987, which calculated a frequency of $1.7E-4$ /yr for anion and $4.1E-11$ /yr for cation, and a "high spot" estimate of consequences, which took no credit for the cabinet's ability to contain the explosion. The letter that presented the estimate of consequences suggests that the estimate could be improved by considering the effectiveness of the cabinet in containing an explosion.

A more thorough analysis will be performed within 12 months after startup on the explosion and its effect on existing confinement. WSRC commits to provide other measures as necessary to prevent a fatality from occurring and reduce this event to Scenario Class II or lower (C). In performing the analysis of the ion exchange column explosion, mitigative structural features of the cabinets will be reviewed and included. It is suspected that specific structural features of the ion exchange equipment will significantly reduce the frequency of worker fatality.

Dose consequences to facility workers are mitigated by the cabinets and cabinet and room exhaust ventilation systems which would continue to operate following an explosion, thereby reducing the concentration of radionuclides in the operating room air. The room exhaust ventilation system would also serve to prevent workers in other parts of the facility from being exposed.

8.3.2.3 Propagated Fire

The existing SAR analyzed a process fire scenario that was assumed to propagate through the building level with the highest typical Pu inventory present. This scenario is considered highly unlikely due to the administrative controls on transient combustibles and the presence of few initiators. The resulting release was 0.16 curies, with a dose to the maximally exposed offsite individual of 2.43 mrem (ICRP 2 values). Again, the same

accident, factored up to account for ICRP 30 dose values, would be 7 times greater in consequence, or 17.0 mrem. It should be noted that over 99% of the curies released in the propagated fire scenario were the result of burning ion exchange resin. A release fraction of 2.5% was applied to the Pu contained on the burning resin, unlike the process fire scenario which uses a release fraction of 0.02%.

The PHA also examined a fire that propagates through a single level, but assumed maximum NCSS inventories. The worst case fire considered by the PHA was a propagated fire on fifth level, which was assumed to occur at a frequency of $1.7E-4$ /yr. However, analyses available at the time of the PHA did not reflect the fact that the third and fourth level exhaust is not tied to the sand filter. A more recent analysis, which correctly reflects third and fourth level filtration and assumes no vault involvement, has shown that the worst case is in fact a fire which propagates throughout the fourth level. The source term for a propagated fire on fourth level would be a 35.9 curie release. Analysis, using the updated AXAIR89Q dose code, resulted in a dose to the maximally exposed offsite individual of 2.23 rem (ICRP 30). A co-located worker, located 640 meters from the stack, using 50% meteorology, could expect a dose of about 2.95 rem (ICRP 30). The SAR envisioned no plausible scenario for a propagated fire on fourth level; however, for the purposes of this BIO, the fifth level frequency is conservatively assumed. Thus, a single level propagated fire becomes the bounding accident for the middle frequency category.

The consequence analysis in the existing SAR for a propagated fire assumed typical processing, which would be a single batch of material in each unit operation. Additionally, the SAR assumed that a fire would not propagate from one level to the next. However, a bounding analysis would analyze the conservative scenario of maximum allowable inventory within a unit operation, which is allowed under current NCSS, and assume the fire could propagate from level to level. A study has been conducted (Reference 17) that concluded a propagated fire would not engulf the vaults or cause the nuclear material there to be dispersed. Assuming maximum NCSS inventories, with all parts of the facility involved with the exception of the vaults, with no credit taken for high efficiency particulate air (HEPA) filters (i.e., no filtration for 3rd and 4th levels and only sand filter filtration for 5th and 6th levels), the source term for a propagated fire would be a 53.6 curie release. Analysis, using the updated AXAIR89Q dose code, resulted in a dose to the maximally exposed offsite individual of 3.95 rem (ICRP 30). A co-located worker, located 640 meters from the stack, using 50% meteorology, could expect a dose of about 5.21 rem (ICRP 30). The occurrence of fire that consumes the entire facility is conservatively assumed to be a factor of 10 less frequent than one which propagates throughout the fifth level as analyzed in the SAR, given the fact that no fires have propagated beyond their room of origin. Although the current release values result in an acceptable risk versus DOE guidelines, the facility commits to complete the tie-in of third and fourth level exhausts to the sand filter by December 1995, in order to further reduce this risk (C). To further ensure that the vaults will not be breached during a fire, the facility commits before declaration of readiness for restart to complete computer modeling to predict temperatures during a worst case fire. Any upgrades deemed necessary to prevent fire propagation into the vaults will be provided on a schedule to be determined (C). Piping penetrations will be sealed by October 30, 1994, regardless of the results of the computer modeling (C). Other penetrations will be evaluated after computer modeling is complete. Until modeling and upgrades are complete, transient combustibles will be restricted in rooms adjacent to the vaults.

A fire which propagates into a vault through an open door would result in a higher consequence than the bounding fire described above. In order to understand the dominant

sequences that could lead to such an event, a fault tree was constructed and analyzed. Scenarios included in the tree were : 1) A fire starts near a NIM and grows to cause a false NIM alarm before propagating to the vault, 2) a "hot short" in a NIM unit that causes both a false alarm and leads to a propagated fire, and 3) a fire starts outside the vault and propagates into the vault through a door left open due to violation of the exiting procedure. The result of the fault tree analysis was a frequency of $6.8E-7$ /yr, with the "hot short" scenario being dominant. The following are examples of some of the conservatism incorporated in the analysis: 1) All NIM "hot shorts" are assumed to result in false NIM alarms, 2) all NIM shorts are assumed to result in a fire large enough to propagate, 3) propagation potential for all NIMs was estimated based on the "worst case" NIM configuration, and 4) Data from burning televisions and business machines with plastic and wood frames were used to estimate the heat output for a burning NIM, which has a metal base. Given the low frequency and the conservatism in the estimate, further consequence analysis is not required. As a result of the fault tree analysis, an additional AC has been added to Table 8.F to restrict combustibles from the vicinity of NIM units. The addition of an automatic door closing mechanism, as committed to in CSA SRS-DOE-5480.7-CSA-225, will further reduce the frequency of a fire propagating to the vault through an open door.

A seismically induced propagated fire is not considered credible (Reference 19).

The consequence of a fire which propagates from F-Canyon into FB-Line is bounded by the multi-level propagated fire described above. Since the frequency of such a fire is expected to be less than the frequency of a propagated fire which originates in FB-Line, the risk is also bounded.

The safety envelope for the propagated fire scenario is presented in Table 8.F.

8.3.2.4 Earthquake

The process building and sand filter system were built to Class I construction (Reference 20) standards, and are expected to withstand a DBE (References 21,22,23,24). The SAR assumes they will remain intact, with localized damage, and provide confinement after a DBE. A DBE is defined as one with a ground acceleration of 0.2g, which corresponds approximately to a Modified Mercalli Scale VII earthquake.

In 1989, the U.S. Army Corps of Engineers re-evaluated the results from an earthquake study performed for the 221-H Building by Engineering Decision Analysis Company (EDAC) and essentially agreed with the results, but had some recommendations. The recommendations included a further evaluation to be completed on the facility to investigate the DBE seismic effects on non-structural items, including mechanical and electrical equipment and their systems. Based on these recommendations WSRC has developed a schedule for the re-evaluation of the 221-H Building to withstand a 0.2g earthquake. This schedule includes the development of a static and dynamic model and includes a structural and geotechnical analysis of the H-Canyon and surrounding facilities along with an analysis of the effect of localized structural failures. Since 221-F Building, including FB-Line is structurally similar to the 221-H Canyon Building, the analysis and results obtained for 221-H will be applied to the 221-F Building with appropriate justifications, as necessary (C).

An additional, limited scope structural analysis was performed to assess the F-Canyon's structural performance during and after earthquake events. (reference WSRC-TR-94-0248) The primary goal of this analysis was to assess if the structures met code allowables when

subjected to a ground acceleration of 0.2g (DBE). If code allowables were not met, a "no collapse" evaluation would have to be performed with the input being the Blume spectrum scaled to a level of 0.3g.

Section 6 of the F-Canyon, including the FB-Line penthouse was selected for the analysis. This section was chosen because the structural details of the main structure and the penthouse are typical to a number of other sections and would be generally representative of the F-Canyon structure. This typical section is also critical under seismic load conditions due to its lack of shear walls and thus has a limited ability to withstand seismic forces. As indicated in the analysis, several locations within the building did not meet ACI 349 code allowables for the 0.2g Blume input; therefore, non-linear analyses were performed. The two non-linear hysteresis models (elasto-plastic and Takeda) were used with the single-degree-of-freedom (SDOF) system representing the global behavior of the building to compute the dynamic response of the building to the 0.2g and 0.3g Blume input.

For the 0.2g input, the results of the dynamic analyses indicate that both non-linear hysteresis models produce a maximum relative displacement of the SDOF system of about 2.3 inches, as compared to 2.0 inches predicted in the elastic SASSI (a System for the Analysis of Soil-Structure Interaction) analysis. Both non-linear analyses indicate limited global non-linear behavior and the permanent displacements predicted are insignificant. For the 0.3g input, the non-linear hysteresis models predict a maximum relative displacement of less than 4 inches. The elasto-plastic hysteresis model results in a permanent displacement of the SDOF system of about 2 inches, which is less than 0.25% of the story height. The Takeda hysteresis model results in a permanent displacement of less than 1 inch.

The analysis concluded Section 6 of the F-Canyon does not meet ACI 349 code allowables for the DBE input. However, the localized non-linearities realized during the DBE event have limited global consequences. For the 0.3g earthquake, more extensive non-linear behavior is predicted, but given the areas that were critically examined in the analysis, the structure remains stable (i.e., it does not collapse) and shows joint rotation less than those specified in ACI 349.

Consequence analysis is based on 5E-6% (Reference 11) of the total facility inventory becoming airborne, either through the ventilation system (if running) or through building cracks that may result from the DBE. The composite release fraction of 5E-08 is consistent with more recent information on airborne release fractions from DOE-HDBK-3010-94 (1E-04 for free-falling liquids and powders) and leakpath factors from Reference 27 (5E-03 for a 0.3g earthquake), given that less than 10% of the maximum permissible facility inventory based on NCSS limits is in-process, non-metal material. The result from the SAR (mean inventory) was an airborne release of 5E-3 curies, with a dose to the maximally exposed offsite individual of 7.6E-2 mrem, based on ICRP 2 values. The same accident, factored up to account for ICRP 30 dose values, would be 7 times greater in consequence, or 5.3E-1 mrem. Converting from a stack release, as analyzed in the SAR, to the more conservative ground release, the consequence would be 2.1 times greater, or 1.1 mrem. USQ screening/evaluation USQD-FBL-93-0458 documents this latter inadequacy in the SAR.

To model the bounding consequence of a DBE, the conservative assumption of the maximum allowable facility inventory based on the NCSS was used, and the release was analyzed using the updated AXAIR89Q dose code. The result was an unfiltered ground level airborne release of 0.310 curies, with a dose to the maximally exposed offsite individual of 42 mrem (ICRP 30). Co-located workers 640 meters from the stack, using

50% meteorology, could expect a dose of about 343 mrem (ICRP 30). This is conservative not only in the inventory assumptions, but also in the assumed release time of two hours.

Earthquakes of less intensity than 0.2 g could cause the ventilation stack liner to fail and possibly block the ventilation exhaust path. In the event of stack liner collapse, ventilation system interlocks (backed up by manual intervention) will stop the supply fans and prevent pressurization of the facility. Therefore, the result of an earthquake of intensity less than the DBE will be ventilation failure with possible facility air reversals. The impact of air reversals has already been examined in the SAR, where they are considered very low energy events whose consequences are contained within the facilities. These consequences could include building contamination, worker contamination, and worker assimilation. As a part of a USQ screening/evaluation for stack liner failure, the risk of other accidents during an earthquake of less intensity than the DBE was examined for the F and H Canyon buildings. Based on the analysis shown in Reference 25, the additional risk of an accident capable of pressurizing FB-Line (a medium energetic event) occurring simultaneously with a stack liner failure is $1.3E-4$ mrem/yr to the maximally exposed offsite individual or an increase of about 5.2% in the risk due to medium energetic events. Since the SAR shows the risk due to medium energetic events to be 44.7% of the total facility risk, this represents an increase in total facility risk of about 2.3%.

8.3.2.4.1 Earthquake Induced Nuclear Criticality

A seismically induced criticality is not directly analyzed in the SAR. The most likely location for such an event to occur is in the vaults. The frequency of an earthquake induced criticality is estimated to be $2.0E-04$ per year, which is less than the process induced criticality frequency of $5.9E-04$ per year. This is based on the frequency of an earthquake of 0.1g intensity for the SRS area of $2.0E-03$ per year (once every 500 years) and an estimated conditional probability of 0.1 (Reference 12) that the material in the racks will form a critical mass. WSRC commits to complete detailed analyses of the vault storage racks and provide a schedule for completion of any corrective actions necessary to meet these assumptions prior to declaration of readiness for restart. (C)

8.3.2.5 Low Energetic Events

Although not a dominant accident scenario, low energetic events are discussed here because the bounding accident for the high frequency category is a low energetic event. A low energetic event is defined in the SAR as one which may cause penetration of the primary containment barrier, and occur at a frequency of several times per year. The low energetic events analyzed in the SAR are:

Transfer Error -	intentional movement of material to an unintended location, premature movement, or excessive movement where potential for chemical reaction is unlikely
Overflow -	exceeding the capacity of a vessel
Chemical Addition Error -	transfer of incorrect or unknown material or quantity into a known vessel, or addition of an undesired quantity of material

Spill -	overturning or dropping of a vessel or container, liquid loss due to loose connections, liquid draining from a fitting that has been deliberately disconnected, or material seeping beneath a cabinet panel
Leaks -	loss of material from primary containment
Sparge Failure -	failure to mix or purge a vessel
Siphoning -	transfer of material to an unintended location due to difference in elevation
Coil or Tube Failure -	loss of integrity of primary containment through the heating or cooling system
Pluggage -	foreign solid material deposits that restrict or halt fluid flow
Corrosion -	loss of or decrease in integrity of primary containment
Over pressure -	unplanned addition of energy to a system beyond normal

The consequence analysis in the SAR conservatively took no credit for operator response, redundant process controls, or the HEPA filtration within the facility, with the total release fraction released directly to the sand filter.

The release percentage for a low energetic event, 0.001%, (Reference 11) was applied to the typical batch size for one vessel. Using a sand filter efficiency of 99.51%, the result was a release of 8.3E-5 curies, with a dose to the maximally exposed offsite individual of 1.3E-3 mrem (ICRP 2 values). The same accident, factored up to account for ICRP 30 dose values, would be 7 times greater in consequence, or 9.1E-3 mrem.

In order to provide a bounding case for an accident with high frequency, the same release percentage was applied to the maximum batch size permissible by NCSS in each process area, assuming typical weapons grade isotopics. The releases were analyzed using the updated AXAIR89Q dose code. The resulting worst case was a release from the vaults due to a single can overpressure. A subsequent analysis was then performed (Reference 26) using maximum batch size and the worst case isotopic fraction for material stored in the vaults. The result was a release of 4.04E-02 curies, with a dose to the maximally exposed offsite individual of 5.93 mrem (ICRP 30). Co-located workers 640 meters from the stack, using 50% meteorology, could expect a dose of about 7.84 mrem (ICRP 30).

Table 8.F
 Summary Table of OSR/TS/SRS Documentation for FB-Line SAR and PHA Accidents

Scenario	Preventors	Mitigators
Ion Exchange Column Explosion (Scenario Class I with respect to Facility Worker only)	<p><i>#1</i></p> <p>SAR Requirements <u>DE/STSA-200-10, Supp 9, 4/88 Section 3.2.2.1</u> 1) The design of the cation exchange columns piping keeps the resin in these columns covered with solution at all times, 2) The column is equipped with a vent line without valves or restrictions.</p> <p><i>#2</i></p> <p><u>Section 3.2.2.7</u> 1) The design of the anion exchange column piping keeps the resin in these columns covered with solution at all times, 2) The column is also equipped with a vent line without valves or restrictions, 3) To preclude the resin from reaching a temperature that would initiate a resin explosion the column is maintained at a temperature less than 60 degrees C, 4) Resin degradation as a result of radiation is limited by keeping the resin exposure level to less than 1E+8 R, 5) Used resin, when it is to be discarded, is treated in such a manner that the nitrate form is converted to the sulfate form.</p> <p><i>#3</i></p> <p><i>#6</i></p> <p><i>#7</i></p>	<p>SAR Requirements None</p> <p>OSR None</p> <p>TS None</p> <p>Safety Related Systems</p> <p><u>Procedure Manual S1-1-1, Item 2.0.1: FB-Line Configuration Control and Safety-Related Systems</u></p> <ul style="list-style-type: none"> • Room Exhaust Subsystem <i>#8</i> • Cabinet Exhaust Subsystem <i>#9</i> <p>Design Features <i>10</i></p> <p>Process Enclosures</p>

INFORMATION ONLY

Table 8.F (continued)
 Summary Table of OSR/TS/SRS Documentation for FB-Line SAR and PHA Accidents

Scenario	Preventors	Mitigators
<u>Ion Exchange Column Explosion</u> (Continued)	Section 6.3.1 1) Use only the hydrogen form of strong acid cation exchange resins that have been qualified by laboratory tests of thermal stability and process compatibility, 2) Limit the maximum allowable column operating temperature to 60 degrees C, 3) Specify service limits on radiation and/or chemical degradation times to permit removal of resins from service before they become hazardous under the allowed processing conditions, 4) Establish time limits on flow interruption when using strong nitric acid in contact with resin to prevent resin from becoming hazardous, 5) Limit the maximum allowable concentration of nitric acid to 9 molar, 6) No chemicals that produce explosive gas mixtures or compounds are combined.	2 3 4 5
	OSR <u>DPW-85-101, Rev. 2, (3/94)</u>	
	7 <u>1.2.2.C Limiting Control Settings for Ion Exchange Operations</u>	
	8 <u>2.2.C LCO requiring Ion Exchange Column Temperature Instruments</u>	
	9 <u>3.1.C.1 Surveillance Requirement for Ion Exchange Column Instruments</u>	

Table 8.F (continued)
 Summary Table of OSR/TS/SRS Documentation for FB-Line SAR and PHA Accidents

Scenario	Preventors	Mitigators
Ion Exchange Column Explosion (Continued)	<p>TS</p> <p><u>DPSTS-221-21.03: "Cation Exchange Coupling"</u></p> <ol style="list-style-type: none"> 1 • C.1.c Resin operating temperature 2 • C.6.a Pu elutriant HNO₃ concentration limits <p><u>DPSTS-221-42.06: "Recovery Anion Exchange"</u></p> <ol style="list-style-type: none"> 3 • C.1.b Resin operating temperature 4 • C.1.c Resin columns must be operated in a flooded condition 5 • C.1.d Concentration of nitric acid in contact with resin <p>Safety Related Systems</p> <p><u>Procedure Manual S1-1-1, Item 2.0.1: FB-Line Configuration Control and Safety-Related Systems</u></p> <ol style="list-style-type: none"> 6 • Anion and Cation Temperature Instruments <p>7 Administrative Controls Periodically flow liquid through columns while facility is in standby to ensure resin remains wetted. This is required only if resin is loaded in column.</p> <p>8 Visual sump inspections to detect potential leaks.</p> <p>9 Change out the resin after a cumulative exposure of 1E+8 rad (anion), and 1E+9 rad (cation).</p> <p>10 Columns are not left in a loaded state for an extended period.</p>	

Table 8.F (continued)
 Summary Table of OSR/TS/SRS Documentation for FB-Line SAR and PHA Accidents

Scenario	Preventors	Mitigators
Single Level Propagated Fire (Scenario Class II with respect to Co-Located Worker and Public)	SAR Requirements DPSTSA-200-10, Supp 9, 4/88 Appendix D, Sections 3.4 and 4.3 Fire detection is the first step in the fire protection and is accomplished by fire watch surveillance and normal operations staff present.	SAR Requirements DPSTSA-200-10, Supp 9, 4/88 Section 5.3.9.2 The principal barrier to radioactivity release to the environment via the process enclosure ventilation system and the room ventilation system is the sand filter servicing 5th and 6th level exhausts.
	OSR None	OSR DPW-85-101, Rev. 2, (8/94) 3.1.C.1 Surveillance Requirements for Sand Filter and HEPA Filters
	TS None	TS None
	Safety Related Systems None	Safety Related Systems Procedure Manual S1-1-1, Item 2.0.1: FB-Line Configuration Control and Safety-Related Systems <ul style="list-style-type: none"> 5 • Building Walls 6 • Duct to Sand Filter 7 • Sand Filters 8 • Cabinet Exhaust 9 • Room Exhaust
	Administrative Controls Until computer modeling of fire effects on vault contents and any resultant upgrades are complete, transient combustibles will be restricted in rooms adjacent to the vaults.	Administrative Controls Restrict combustibles from the vicinity of NIM units.
	Design Features Process Enclosures	

Table 8.F (continued)
 Summary Table of OSR/TS/SRS Documentation for FB-Line SAR and PHA Accidents

Scenario	Preventors	Mitigators
Inadvertent Criticality (Scenario Class I with respect to Facility Worker only)	<p>SAR Requirements DPSTSA-200-10, Supp 9, 4/88 Section 3.2.2.1 The four cation exchange columns of eight cylindrical segments, the Product Run Tanks, the Product Hold Tanks, and Sump Receipt Tank, are constructed to be geometrically favorable vessels for the concentrations handled.</p> <p>Section 3.2.2.2 The accumulation of Pu precipitates on the walls of the precipitator could conceivably result in a Pu accumulation in excess of the 8 kg Pu batch limit. A monitor alerts operators to the extent of the buildup, then flushes are performed to remove it.</p> <p>Section 3.2.2.6 The racks are constructed to physically space only one can per rack position, in a configuration that meets criticality control requirements.</p> <p>Section 3.2.2.7 1) Solution overflowing from a tank or leaking from a process line collects in geometrically favorable sumps provided beneath each tank, 2) The solution in A-6 must be less than 17 g/l Pu prior to transfer to canyon tanks. This is because the solution is transferred using a 3:1 eductor. 3) The transfer line contains a siphon break which is necessary to prevent concentrate from A-6 siphoning to the canyon tank if the eductor motive solution (dilute nitric acid) should stop after the transfer is started.</p> <p>Section 3.2.3.1 The cation exchange column and the Pu processing equipment downstream of the cation exchange are limited to geometrically favorable configuration for criticality safety.</p>	<p>SAR Requirements DPSTSA-200-10, Supp 9, 4/88 Section 4.9.6 NIMs are provided at strategic locations throughout 200-Area facilities. These monitors are provided wherever fissionable materials are stored, or processed in sufficient quantity for a potential critical configuration. The monitors alarm to warn personnel to move to certain locations, along with previously established well marked routes.</p> <p>OSR DPW-85-101, Rev. 2, (8/94)</p> <p>2.1.C LCOs requiring NIM system and that it be operational during fissile material handling</p> <p>3.1.C.1 Surveillance Requirement for NIMs</p> <p>TS DPSTS-NIM-85 All limits</p> <p>Safety Related Systems Procedure Manual S1-1-1, Item 2.0.1; FB-Line Configuration Control and Safety-Related Systems 12 • NIMs</p> <p>Administrative Controls Annual NIM Response Training NIMs monitoring a potential incident location are bypassed to perform authorized work per approved work package or workbook. Prior to bypassing of NIMs, operations in that location are brought to a safe configuration per facility procedures.</p> <p>Design Features Process Enclosures</p>

Table 8.F (continued)
 Summary Table of OSR/TS/SRS Documentation for FB-Line SAR and PHA Accidents

Scenario	Preventors	Mitigators
<u>Inadvertent Criticality</u> (Continued)	<p>Section 3.2.3.2 The hardwired neutron monitors will result in termination of the Pu feed to the first and second stage precipitators upon a high neutron count.</p> <p>Section 3.3.5.1 Process vessels for Pu solution of concentrations greater than 6.75 g/l are geometrically favorable by design for nuclear criticality control. Typically, these vessels have a maximum width of 4.0 in. For metal vessels, this width is maintained by properly spaced stay bolts. Plastic vessels are housed in a metal frame to prevent the vessel from bulging. Collection sumps are built into the bottom (or lower level) of all process enclosures. All process vessel are suspended above these collection sumps. The dimensions of each sump for highly concentrated solutions are, in effect, greater than the maximum volume of the vessel(s) served by that sump. Therefore, should a process vessel lose its integrity, the solution dimensions would be maintained geometrically favorable for nuclear safety. (See Design Features for exceptions.)</p>	

Table 8.F (continued)
 Summary Table of OSR/TS/SRS Documentation for FB-Line SAR and PHA Accidents

Scenario	Preventors	Mitigators
inadvertent Criticality (Continued)	<ol style="list-style-type: none"> 1) Section 5.6.4.2 1) In situations where concentrated Pu solutions are transferred to vessels where the concentration limit for vessels with unrestricted geometry applies, written procedures act to ensure that adequate controls are in place to ensure safety. 2) Storage of Pu in the vaults and movement of Pu within FB-Line are by approved operating procedure to avoid accumulation of Pu in excess of safe mass limits and violation of critically safe geometry. 3) Section 6.2.1 Before geometrically favorable vessels are placed in service, vessels must be measured and the dimensions independently verified using approved nuclear safety measurement procedures and measuring instruments calibrated to NBS standards. 4) Section 6.3.1 1) The limits for Pu²³⁹ concentration in an ungeometrically favorable vessel is 6.75 g/l. 2) Collection of fissile process solution leaks in containers is prohibited (deviations require use of geometrically favorable containers per special procedure approved by the Nuclear Safety Group). 3) Prior to removing cabinet panels for work inside the cabinet, confirm and verify (dual and independent) that all nuclear safety control limits are met and proper panel (dual and independent) is being removed. 4) Routinely survey (flush, monitor or visually inspect) sumps, seal pots, and other designated process locations for accumulation of potential Pu-bearing solids. 	

2

Table 8.F (continued)
 Summary Table of OSR/TS/SRS Documentation for FB-Line SAR and PHA Accidents

Scenario	Preventors	Mitigators
<u>Inadvertent Criticality</u> (Continued)	<ol style="list-style-type: none"> 1 <u>Section 6.3.2 1) Monitor and verify Pu inventory in precipitators prior to starting each precipitation, 2) Routinely check and calibrate safety-related neutron monitors with a neutron source and verify neutron monitors (M-2, M-3) will alarm if specified set points are exceeded, 3) Verify and document that the dimensions and tolerances for new tanks and equipment to be installed are in specifications, 4) Prior to removing cabinet panels for work inside the cabinet, confirm and verify (dual, independent) that all nuclear safety control limits are met and proper panel (dual, independent) is being removed.</u> 5 <u>Section 6.3.4 1) Before replacing resin in the anion resin columns, A-4 A/B, elute the columns as directed in approved procedures to remove residual Pu. Verify and confirm actions taken,</u> 6 <u>2) Prior to removing cabinet panels for work inside the cabinet, confirm and verify (dual and independent) that all nuclear safety control limits are met and proper panel (dual and independent) is being removed. 3) Transfer eluting solution from A-6 to canyon tanks 10.2 and 10.3 in the hot canyon as specified in approved operating procedures to keep Pu concentration and acid concentration within specified Nuclear Criticality Safety limits, 4) Operate A-6 tank as specified in approved operating procedures to prevent accidental transfer of A-6 tank contents to canyon tanks. Siphon break line should be open (not blanked) to prevent siphoning of A-6 contents to canyon tanks.</u> 	

Table 8.F (continued)
 Summary Table of OSR/TS/SRS Documentation for FB-Line SAR and PHA Accidents

Scenario	Preventors	Mitigators
<u>Inadvertent Criticality</u> (Continued)	<p>1 6.3.6 Control neutron shielding, filter tube spacing, and Pu mass limits for the solution transfer filters, air drying filter and vessel vent filter as specified in the approved Nuclear Safety Control operating procedures.</p> <p>2 <u>OSR DPW-85-101, Rev. 2. (8/94)</u></p> <p>2 1.1.C.1.6 Safety Limits</p> <p>3 1.2.1.C Limiting Control Settings which limit composition and configuration of fissile components to prevent formation of a critical array.</p> <p>4 1.2.6.C.4 Limiting Control Setting for concentration of hydrogen.</p> <p>5 2.2.C LCO requiring Gamma Pulse Height Analyzer Instrument (Sample PHA, Segmented Gamma Scanner, and Portable Waste PHA) and Hydrogen Dilution Controls</p> <p>6 3.1.C.1 Surveillance Requirement for Precipitator Neutron Monitors, Sample PHA, Segmented Gamma Scanner, and Portable Waste PHA</p> <p>7 TS DPSTS-221-0.09 and DPSTS-221-0.09 Sup. All NCSS except NCSS 10, 11, 20, and 24</p> <p>8 TA <u>WSRC-TA-91-00002-12-Extension (Rev. 2)</u></p>	

Table 8.F (continued)
 Summary Table of OSR/TS/SRS Documentation for FB-Line SAR and PHA Accidents

Scenario	Preventors	Mitigators
<u>Inadvertent Criticality</u> (Continued)	<p>Safety Related Systems Procedure Manual S1-1-1, Item 2.0.1; FB-Line Configuration Control and Safety-Related Systems</p> <ul style="list-style-type: none"> 1 • Sample Assay Equipment 2 • Waste Assay Equipment 3 • Precipitator Neutron Monitors 4 • Process Vessel and Sump Geometry 5 • Vault Storage Location Geometry 6 • Nuclear Safety Blanks 7 • Recovery Product Tank (A6) Eductor 8 • Finishing Balance 9 • Dissolver Hydrogen Dilution Control Rotameters 10 • Hydrogen Dilution Vessel Vent Purge System 11 • Hydrogen Dilution Vessel Pneumatic Purge System 	
	<ul style="list-style-type: none"> 12 Design Features The sumps for the <u>New ST Vacuum System Cabinet</u> and the <u>C & D Precipitator Cabinets</u> have overflows. 	
	<p>Administrative Controls</p>	
	<ul style="list-style-type: none"> 14 <u>Annual Nuclear Criticality Safety Training</u> 15 <u>Nuclear criticality safety samples are analyzed within the FB-Line facility or by the analytical laboratory.</u> 	
	<ul style="list-style-type: none"> 16 <u>Dual signatures are required for vault procedure steps that verify safe Pu mass limits or critically safe geometry configuration when storing and handling Pu material.</u> 	
	<ul style="list-style-type: none"> 17 <u>Monitoring to prevent excessive accumulation of Pu in ventilation ducts.</u> Procedures are in place to maintain hydrogen concentration less than 25% of the LFL. 	

8.3.3.4 Non-radiological Evaluation

A review was also made of the facility's chemical hazards. The SAR, Section 5.4.7, addresses chemical hazards in FB-Line, with the conclusion that the associated risk is acceptable. Based upon operating experience which includes greater than 30 years without a significant chemical release, continued operation is judged to be acceptable. In addition, Emergency Action Levels have been established according to Procedure Manual 6Q and documented in EPIP EPIP-6Q-FBL-PSF-001. This BIO will be revised within 6 months of approval, to provide a complete analysis of the environmental effect of hazards and an evaluation of chemical hazards (C). Chemicals used as liquids in the FB-Line processes have been reviewed to determine if any are present in sufficient quantity to be of a regulatory concern. There are no chemicals in FB-Line in excess of the Threshold Quantities (TQ) per OSHA PSM Rule 29CFR1910.119.

8.4 Farmer Plots

The public and co-located risk of the bounding (maximum source term) accidents in FB-Line are shown in Table 8G and the Farmer Plots in Figures 1 and 2. These values are included only to allow comparison of the bounding accident risks with WSRC Risk Acceptance Guidelines. Defense-in-depth for FB-Line is documented in this BIO using Table 8.F, Summary Table of OSR/TS/SRS Documentation for FB-Line SAR and PHA Accidents.

**Table 8.G
Summary Table of Risk for FB-Line Bounding Accidents**

ACCIDENT	FREQUENCY, per year	CO-LOCATED MAXIMUM INDIVIDUAL DOSE, rem	CO-LOCATED MAXIMUM INDIVIDUAL RISK, rem/yr	OFFSITE MAXIMUM INDIVIDUAL DOSE, rem	OFFSITE MAXIMUM INDIVIDUAL RISK, rem/yr
Earthquake	2.0×10^{-4}	3.43×10^{-1}	6.9×10^{-5}	4.2×10^{-2}	8.4×10^{-6}
Criticality	5.9×10^{-4}	2.6×10^{-1}	$\leq 1.5 \times 10^{-4}$	7.0×10^{-3}	$\leq 4.1 \times 10^{-6}$
Propagated Fire	1.7×10^{-5}	5.21×10^0	8.9×10^{-5}	3.95×10^0	6.7×10^{-5}
Fourth Level Fire	1.7×10^{-4}	2.95×10^0	5.0×10^{-4}	2.23×10^0	3.8×10^{-4}
Low Energetic Event in Vault	9.0×10^{-2}	7.84×10^{-3}	7.1×10^{-4}	5.93×10^{-3}	5.3×10^{-4}

Figure 1
**RISK OF FB-LINE - BOUNDING ACCIDENTS
OFF-SITE**





Figure 2
**RISK OF FB-LINE - BOUNDING ACCIDENTS
CO-LOCATED**



8.5 Safety-Related Description Approach

The accidents analyzed in the SAR were examined and the major features to detect, prevent, or mitigate the accidents were identified as Safety-Related systems. Safety-Related systems for FB-Line are addressed in Procedure Manual S1-1-1, Item 2.01, "FB-Line Configuration Control and Safety-Related Systems (U)", Rev. 1 (Draft). **This procedure will be approved and issued before declaration of readiness for restart (C).** It defines specific FB-Line systems and components as well as F-Area systems that can impact FB-Line operations. It describes the actions to be taken upon failure or unavailability of a Safety-Related system or component and the bases for the actions. It also describes the testing/surveillance requirements for FB-Line specific systems. Testing/surveillance requirements for F-Area systems related to FB-Line are documented in Standard Operating Procedure (SOP) 221-F/OF-F-51230, "F-Canyon/OF-F/FA-Line Safety Related Systems". Both procedures include the criteria for selection of the Safety-Related systems and components. FB-Line systems are summarized in Table 8.H below.

Some systems are required for all operations within FB-Line, while others are required only for operation of specific processes. The Safety-Related systems for FB-Line are identified by unit operation in Table 8.I.

The schematics for selected Safety-Related systems and other support systems are presented in the PHA.

**Table 8.H
Safety-Related Systems and Components for FB-Line**

Category	System	FB-Line Operator Intervention Required?	FB-Line Surveillance Type	Minimum Surveillance Frequency
Ventilation & Confinement	-Room Exhaust	No	Interlock Tests	12 Months
	-Cabinet Exhaust	No	Interlock Tests	12 Months
	-Building Walls	No	None	None
	-HEPA Filters	No	DOP Test	9 Months
Room Air Monitoring	-High Volume Air Monitors (HVAMs)	No	Functional Test Calibration Trouble Alarm Test	Monthly 12 Months 12 Months
	-Portable Constant Air Monitors (CAMs)	No	Functional Test Calibration	Daily 12 Months
Nuclear Criticality Control	-Sample Assay Equipment	Yes	Calibration Performance Check	6 Months Prior to Use for Nuclear Safety
	-Waste Assay Equipment Segmented Gamma Scanner Neutron Coincidence Counter Portable Pulse Height Analyzer	Yes	Performance Check Performance Check Calibration Performance Check	Prior to Use Prior to Use 6 Months Before /After Use
	-NIMs	No	Audibility Test Calibration Source Check	12 Months 12 Months 3 Months
	-Precipitator Neutron Monitors	No	Calibration Interlock Tests Plating Flush	6 Months* 6 Months* When Required*
	-Process Vessel/Sump Geometry	No	Ultrasonic Test Sump Inspection	5 Years * 12 Months
	-Vault Storage Location Geometry	No	None	None
	-Transfer Eductor Eductor System	No	Ratio Calculated Ratio Trended Siphon Break Test	After Use* 3 Months* 12 Months*
	-Finishing Balance	Yes	Calibration Performance Check	12 Months Before/After Use
	-Nuclear Safety Blanks	No	Visual Inspection	12 Months
	-Dissolver Hydrogen Dilution Control Rotameters	Yes	Rotameter replacement	6 Months*
	-Hydrogen Dilution Vessel Vent Purge System	Yes	Funnel Path Flow Test Vent Header Gages Replaced	6 Months 12 Months
	-Hydrogen Dilution Vessel Pneumatic Purge System	No	Verification Reference Rotameter Replacement	6 Months

* During process operation

**Table 8.H (continued)
Safety-Related Systems and Components for FB-Line**

Category	System	FB-Line Operator Intervention Required?	FB-Line Surveillance Type	Minimum Surveillance Frequency
Standby Electrical Power	-FB-Line Diesel Generators	No	Load Test	12 Months
			No-Load Test	4 Months
			Battery Specific Gravity Check	3 Months
			Fuel Water Analysis	Monthly
			Fuel Particulate	3 Months
			Fuel Microorganism Analysis	12 Months
Process Hazards	-Ion Exchange Column Temperature Instrumentation	No	Calibration	12 Months*
			Interlock Tests	18 Months*
F-Area Common Systems	-221-F Canyon Exhaust Tunnel, 291-F Stack, & Stack Liner	No	F-Canyon Controlled Systems. Surveillances performed according to WSRC-RP-93-1215.	
		No	F-Canyon Controlled Systems. Surveillances performed according to WSRC-RP-93-1215.	
	-Sand Filters	No	F-Canyon Controlled Systems. Surveillances performed according to WSRC-RP-93-1215.	
		No	F-Canyon Controlled Systems. Surveillances performed according to WSRC-RP-93-1215.	
	-281-6F Segregated Water Monitors	No	F-Canyon Controlled Systems. Surveillances performed according to WSRC-RP-93-1215.	
	-281-4F Circulated Water Monitors	No	F-Canyon Controlled Systems. Surveillances performed according to WSRC-RP-93-1215.	
	-Segregated Cooling Water Diversion Valves	No	F-Canyon Controlled Systems. Surveillances performed according to WSRC-RP-93-1215.	
-Circulated Cooling Water Diversion Valves	No	F-Canyon Controlled Systems. Surveillances performed according to WSRC-RP-93-1215.		
	-291-F Stack Monitors	No	F-Canyon Controlled Systems. Surveillances performed according to WSRC-RP-93-1215.	

* During process operation

**Table 8.I
Safety-Related Systems Required for FB-Line Operations**

Unit Operation	Required Safety-Related Components	*When Required:
Facility	Room Exhaust Cabinet Exhaust Building Walls HEPA Filters HVAMs Portable CAMs NIMs Nuclear Safety Blanks FB-Line Diesel Generators 221-F Canyon Exhaust Tunnel, 291-F Stack, & Stack Liner 221-F Canyon Exhaust System Sand Filters 281-6F Segregated Water Monitors 281-4F Circulated Water Monitors Segregated Cooling Water Diversion Valves Circulated Cooling Water Diversion Valves 291-F Stack Monitors	All times
	Vessel/Sump Geometry Hydrogen Dilution Vessel Vent Purge System Hydrogen Dilution Vessel Pneumatic Purge System	When associated vessels contain fissile material
Cation Exchange	Ion Exchange Column Temperature Instrumentation	When fissile material is being fed to the cation exchange columns
Precipitation and Filtration	Precipitator Neutron Monitor	During precipitator operation
Mechanical Line	Finishing Balance	Prior to moving fissile material out of the finishing cabinet
Recovery	Sample Assay Equipment	Prior to transferring product to F-Canyon
	Transfer Eductor System	When transferring from tank A-6 to F-Canyon
	Dissolver Hydrogen Dilution Control Rotameters	During dissolution of material that generates hydrogen
	Ion Exchange Column Temperature Instrumentation	When anion exchange columns contain resin
Waste Handling Operations	Waste Assay Equipment	Prior to removing TRU waste from the facility
Vaults	Vault Storage Location Geometry	When the vaults contain fissile material

* Compensatory measures per S1-1-1, Item 2.01, shall be in place when component is not operable when required.

9.0 CONCLUSION

The safety analysis of the FB-Line Facility indicates that the operation of FB-Line to support the current mission does not present undue risk to the facility and co-located workers, general public, or the environment. This is based on the results of the hazard and accident analysis; the verification of the adequacy of the safety envelope by identification of controls, procedures and/or preventive and mitigative features against release of hazardous materials; and the implementation of aggressive safety management programs that ensure facility safety by adhering to principles of sound safety engineering and management practices. This conclusion is further supported by the existence of corrective and compensatory measures to reduce the frequencies and/or consequences of Class I accident scenarios.

10.0 REFERENCES

1. DOE Standard, Hazard Categorization and Accident Analysis Techniques for Compliance with DOE Order 5480.23, Nuclear Safety Analysis Reports, DOE-STD-1027-92, U. S. Department of Energy, Washington, D. C., December 1992.
2. J. W. McClard to R. L. McQuinn, FB-Line Exhaust Duct System Monitoring Program (U), NMP-SBT-0102, May 20, 1992.
3. Memorandum from E. N. Moore to A. S. Messick, "Upgrade Review FB-Line Facility," 1980.
4. Fire Hazards Analysis for Building 221-FB-Line (U), M-FHA-F-00022, Rev. 4, February 14, 1994.
5. Configuration Management Program Plan for FB-Line Facility, WSRC-RP-94-568, June 28, 1994.
6. M. L. Kellogg to P. L. Fisk, FB-Line Maximum Inventory (U), NMP-SDG-93043, Rev. 1, June 21, 1993.
7. Handbook of Chemistry and Physics, 47th Edition, The Chemical Rubber Co., 1966.
8. M. E. DelGenio to J. M. Low, FB-Line Vault Inventory (U), SRT-DCA-94-0014, January 21, 1994.
9. Nonreactor Nuclear Facilities Safety Analysis Report Format and Content Guide, SROM 5480.5-1, U. S. Department of Energy, Savannah River Operations, Aiken, SC, February 1989.
10. DOE-STD-3011-94, Guidance for Preparation of DOE 5480.22 (TSR) and DOE-5480.23 (SAR) Implementation Plans, August 1994.
11. Stoddard, D. H., Guides for Estimating Consequences in 200 Area Systems and Safety Analyses, DPST-82-789, August 1982.
12. Systems Analysis - 200 Area Savannah River Plant, FB-Line Operations, Internal Report DPSTSY-200-10, Rev. 1, October 1985.

13. W. S. Durant and D. H. Stoddard to E. W. Holtzscheiter, Revised Fault Tree and Consequence Analysis of FB-Line Based on 1986 Administrative Control and Equipment Upgrades, DPST-86-558, July 18, 1986.
14. H. S. Smiley, Frequency Analysis for Criticality due to Hydrogen Deflagration in FB-Line Vessels (U), WSRC-TR-94-0192 (Draft), June 1994.
15. S. F. Walters to C. L. Martin, FBL NIM Evacuation Plan to Validate SAR Assumptions Results (U), NMP-SBO-91-0724, December 12, 1991.
16. T. P. McLaughlin, LANL, Review of Savannah River Site (SRS) FB-Line Safety Analysis Report (SAR) for Criticality Accident Analyses, Assumptions, and Consequences, HS-6-92-214, October 30, 1992.
17. R. C. Grim, Parsons Main, to D. E. Berning, FB-Line Fire Spread Evaluation for Vaults 309 and 410A (U), EPD-CTM-94-569, June 23, 1994.
18. D. S. Cramer and C. L. Sossman, Impact of Hot Electrical Shorts in F-Canyon Equipment (U), WSRC-RP-94-637 (Draft), August 1994.
19. P. L. Fisk to T. G. Campbell, Review of the Frequency of a Postulated Earthquake Induced Major Fire in F-Canyon, FB-Line (U), EPD-RAG-940010, June 28, 1994.
20. Specification No. 7096, Structural Specification for Building Code Requirements for Savannah River Site, Aiken, South Carolina, Engineering Department, E. I. DuPont De Nemours & Co. Inc.
21. Seismic Evaluation of Building 221-F Section 2 and JB-Line Penthouse Addition at the Savannah River Plant, Aiken, S.C., EDAC-253-070.03, September 1981.
22. Phase I - Feasibility Study of Building 221-F Section 6 with JB-Line Penthouse Addition Using Blume Seismic Criteria at the Savannah River Plant, Aiken, S. C., EDAC-253-110.02, April 1983.
23. Phase III Seismic Analysis of Building 221-F Sections 5 Through 8 with JB-Line Penthouse Addition Using Blume Seismic Criteria at the Savannah River Plant, Aiken, S. C., EDAC-253-112.02, July 1983.
24. Baldwin, G. R., Evaluation of the F-Area Separation Building Ventilation System Structures, Internal Report EPD-SE-91-0235:63, October 23, 1991.
25. P. L. Fisk to Distribution, Evaluation of the Risks Regarding Exhaust Stack Liner Collapse After 0.04 g Earthquake (U), Internal Report SRL-0AG-92-0041, Revision 3, April 30, 1992.
26. DelGenio, M. E. to H. S. Smiley, Worst Case Consequence for FB-Line Low Energetic Event (U), EPD-CAT-94-0038, August 16, 1994.
27. A. Kolaczowski, et. al., DP Safety Survey, HB-Line and FB-Line, Savannah River Site, Draft, November 27, 1991.

Savannah River Site Safety Analysis Report Approval Sheet

<input checked="" type="checkbox"/> New	<input type="checkbox"/> Revision	Classification U	Date September 23, 1994	
Change Request Number				
Title FB-LINE BASIS FOR INTERIM OPERATION (U), WSRC-RP-93-1102 Page Change, pgs. 43,44,48,56,57				
E&PD Responsible Engineer H. S. Smiley		Organization * SSS		Phone Number 644-5447
Signature <i>H. S. Smiley</i>		Date 9/23/94		
WSRC Approval				
Organization	Title	Name	Signature	Date
E&PD	Manager, SC&SS	F. F. Cadek	<i>F. F. Cadek</i>	9/23/94
E&PD	Manager, STD	F. Beranek	<i>F. Beranek</i>	9/25/94
SRTC	Manager, CPT	C. R. Wolfe	<i>C. R. Wolfe</i>	9/23/94
NMPD	Chief Engineer	P. W. Dickson	<i>P. W. Dickson</i>	9/23/94
ESH & QA	Manager, O&ED	R. J. Skwarek	<i>R. Skwarek</i>	9/23/94
Comments <hr/> <hr/> <hr/> <hr/> <hr/> <hr/> <hr/> <hr/>				
New SARs and TSRs are prepared by SRTC. Revisions to these documents are submitted via a SAR Change Request to SRTC. The Responsible Engineer maintains information regarding the Originator of the change.				
note Engineering and Projects Division (E&PD) review and concurrence is required only when E&PD is involved from a new project or major facility modification standpoint. The approving SRTC Manager shall indicate where no E&PD involvement is applicable by inserting "NA" in place of the E&PD approval signature and dating and initialing this entry.				
DOE Approval: Approval of the Manager, DOE-SR is required for all changes to the TSRs and changes to the SARs when a Positive Unreviewed Safety Question is involved.				
Manager, DOE-SR (printed name/signature) M. P. Fiori			Date	
Desired Effective Date	Restricted Data Stamp if Applicable		Classification	