DOE-HTGR-87-015
Revision 1

HTGR

CORE FLUCTUATIONS TEST

MASTER

AUTHORS/CONTRACTORS

GA TECHNOLOGIES INC.

ISSUED BY GA TECHNOLOGIES INC.
FOR THE DEPARTMENT OF ENERGY
CONTRACT DE-AC03-84SF11962

MASTER

JUNE 1987

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

DISCLAIMER

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Department of Energy, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, mark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

CORE FLUCTUATIONS TEST

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

44
DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

Issued By:
GA Technologies Inc.
P.O. Box 85608
San Diego, California 92138-5608

MASTER

DOE Contract No. DE-AC03-84SF11962

GA Project 6300

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

JUNE 1987

ISSUE SUMMARY

TITLE Core Fluctuations Test	☐ R & D ☒ DV & S ☐ DESIGN	APPROVAL LEVEL <u>2</u>
---------------------------------	---	-------------------------

DISCIPLINE M	SYSTEM 1018	DOC. TYPE SPE	PROJECT 6300	DOCUMENT NO. 909370	ISSUE NO./LTR. 1
-----------------	----------------	------------------	-----------------	------------------------	---------------------

QUALITY ASSURANCE LEVEL I	SAFETY CLASSIFICATION 1	SEISMIC CATEGORY CAT-I	ELECTRICAL CLASSIFICATION N/A
------------------------------	----------------------------	---------------------------	----------------------------------

ISSUE	DATE	PREPARED BY	APPROVAL				ISSUE DESCRIPTION/ CWBS NO.
			ENGINEERING	QA	FUNDING PROJECT	APPLICABLE PROJECT	
0	MAY 29 1987	WSB W. S. Betts	R.E. Vollman R. E. Vollman		J-D. Wistrom		Initial Issue 6217001001 DOE-HTGR-87-015, Rev. 0
1	JUN 26 1987	WSB W.S. Betts	R.E. Vollman R.E. Vollman		J-D Wistrom		

CONTINUE ON GA FORM 1485-1

NEXT INDENTURED DOCUMENTS

909243

* See List of Effective Pages for page count.

LIST OF EFFECTIVE PAGES

<u>Page Numbers</u>	<u>Page Count</u>	<u>Rev</u>
i to iii	= 3	1
iii to vii	= 4	0
1-1	= 1	0
2-1 to 2-25	= 25	0
3-1	= 1	0
4-1 to 4-2	= 2	0
5-1	= 1	1
A-1 to A-14	= 14	0
B-1 to B-18	= 18	0
B-19	= 1	1
Total	70	

CONTENTS

INTRODUCTION	vi
1. TEST REQUIREMENTS	1-1
2. TEST DESCRIPTION	2-1
2.1. Test Article Description	2-2
2.1.1. Single Column 3-D Model	2-2
2.1.2. The Seven Column 3-D Model	2-3
2.1.3. The 66 Column 3-D Model	2-3
2.2. Test Setup Description - Single Column Model	2-4
2.3. Equipment Requirements	2-7
2.4. Instrumentation Requirements	2-7
2.5. Calibration Requirements	2-7
2.6. Data Requirements	2-7
2.7. Acceptance Criteria	2-8
2.7.1. Model Inspection	2-8
2.7.2. Testing	2-9
3. QUALITY ASSURANCE	3-1
4. PROCEDURE	4-1
4.6.1. Testing of the Unrestrained Column	4-1
4.6.2. Testing of the Restrained Column	4-2
5. REFERENCES	5-1
APPENDIX A: MHTGR CORE DESIGN	A-1
APPENDIX B: THERMAL/HYDRAULIC CHARACTERISTICS NEEDED IN MODEL . . .	B-1

FIGURES

2-1.	Schematic of single column model	2-10
2-2.	Block sketch	2-11
2-3.	Side wall sketch	2-12
2-4.	Apparatus photograph	2-13
2-5.	Photographs of plenum chamber	2-14
2-6.	Photographs of support spider	2-15
2-7.	Proximity probe of static tap locations	2-16
2-8.	Schematic of single column model with instrumentation locations	2-17
2-9.	Schematic of cross section of test rig showing instrumentation locations	2-18
2-10.	The elevation location of instrumentation on column and channel	2-19
2-11.	Plots of key measured parameter versus time	2-20
2-12.	Plots of key measured parameters as a function of height along column at selected times	2-21

TABLES

2-1.	Equipment requirements	2-22
2-2.	Instrumentation requirements	2-23
2-3.	Data recorded for 1/4 scale column test	2-25

INTRODUCTION

Fluctuations were first encountered in the Fort St. Vrain reactor early in cycle 1 operation, during the initial rise from 40% to 70% power. Subsequent in-core tests and operation throughout cycles 1 and 2 demonstrated that fluctuations were repeatable, occurring at core pressure drops of between 2.5 psi and 4.0 psi, and that in each instance their characteristics were very similar.

During a fluctuation at the Fort St. Vrain reactor the total core power and flow remained relatively constant but there were changes in measured region outlet temperature and slower but occasionally much larger temperature changes in steam generator modules. There were also changes in neutron flux in the core. The single explanation for the observed fluctuations in temperature and neutron flux is core motion.

Subsequently, tests and analysis were done to understand the core fluctuation phenomenon. These efforts demonstrated that the following scenario resulted in the core fluctuation.

A column leans in one direction which causes a reduction of cooling gas flow on the side it is leaning towards. That side of the column becomes hotter than the other side, and expands, and the column bows. The bowing of the column causes a redistribution of cooling gas flow and the gas pressures on the vertical surfaces of the column, and the column moves to a new stable position, leaning in another direction. The uneven cooling, thermal distortion, redistribution of flow and gas pressure is then repeated, and after some time another movement takes place.

These efforts also lead to a design fix which stopped these fluctuations in the FSV reactor core. This fix required that keys be used to restrict the motion of the top plenum elements. These keys were in addition to the keys in the core support floor which already existed.

This report outlines a test plan to validate that core fluctuations will not occur in the MHTGR core.

1. TEST REQUIREMENTS

The purpose of this test is to validate that the ten-block high active core design and associated reflectors of the MHTGR (as described in Appendix A) are stable to mechanical/thermal movements which could cause fluctuations in the outlet coolant temperature. This will be achieved by:

1. Conducting fluctuation test on scale models of one or more core columns of fuel and reflector elements, with and without modifications to inhibit fluctuations.
2. Analytically extrapolating these results to MHTGR core design and operating conditions. The techniques for extrapolating these data as discussed in Appendix B.

The simplest and most effective method of preventing core fluctutaions will be selected for the MHTGR core design.

2. TEST DESCRIPTION

Three models are envisioned. They will all be 3-D models, and will represent a single column of fuel and reflector blocks, seven columns (i.e., a typical 30° segment of the active core*), and 66 columns (i.e., the number of columns in the annular active core).

A model of a single column of core fuel and reflector blocks will be tested first to support the conceptual design of the MHTGR core**. During the first phase of testing, the effect of the following parameters on the potential for core fluctuations will be evaluated:

1. Gap size and distribution.
2. Block and column shape.
3. Flow rate and pressure drop.
4. Restricted motion and the top reflector element.

Subsequent models have multiple columns and therefore are expected to more closely represent fluctuation motion in the reactor core. They will be used to study interaction between columns and prove the effectiveness of the MHTGR core design to suppress core fluctuations. It is conceivable that the antifucluation design will be assured without making and testing the 66-columns model.

As in previous tests (described in Ref. 1) the flow and thermal conditions in the reactor core will be simulated in the models using air at room temperature and pressure at the inlet and electrically heated fuel elements.

*As shown in Fig. A-2, a typical 30° sector really consist of four full columns and three half columns. The other half of the three half columns are in adjacent 30° sectors. However, it is not recommended that a column be divided in half for testing fluctuations.

**The design of the MHTGR core is described in Appendix A.

All the models proposed will dimensionally represent the reactor fuel column at 1/4 scale. This scale is small enough to permit easy and economical fabrication, assembly, and handling of the models, yet it is large enough so that gap dimensions and block distortions are not being controlled by manufacturing tolerances. The 1/4 scale is the same as was used in the previous 3-D single column fluctuation model (described in Refs. 1 and 2).

The models will be made of materials having properties which can simulate the thermal distortion of the columns with small temperature variations.

2.1. TEST ARTICLE DESCRIPTION

2.1.1. Single Column 3-D Model

The simulated fuel and reflector elements of this model shall be hexagonal in section and 1/4 scale. The core fuel elements will be represented by ten heated elements. The reflector elements above and below the active core as well as two core support elements shall all be simulated as unheated elements and arranged as in the MHTGR core. Dowel pins shall restrain the relative rotation and lateral movement between all elements of the columns.

The assembled column shall be housed in a flow channel. The walls shall have heaters on their external surface at the elevations of the active core.

The top of the flow channel shall be constructed to permit the gap between the top 1/2-height reflector block and the flow channel to be less than or equal to the gap between the rest of the column and the channel walls. This same option shall be available over the bottom 1/2-height core support block.

The walls of the flow channel are required to be stiff and dimensionally stable throughout the operating temperature range of the model. Figure 2-1 is a sketch of the column mounted on its support plate and installed in the flow channel. Air is drawn into the top of the model and flows down the gaps between the column and the channel walls and into the plenum chamber below the column. A fan draws the air from the plenum through flow screens to ensure a uniform sink pressure at the gap exit.

2.1.2. The Seven Column 3-D Model

The seven simulated core columns of this model will be identical to that used in the single column 3-D model. They will be arranged in a typical star cluster. As shown in Fig. A-2 of Appendix A, this star cluster represents a typical 30° sector of the active core. Air will be drawn down through the gaps between columns in a manner similar to the single column model (see Fig. 2-1). This model will be tested over a range of conditions which include simulated reactor core operating conditions (as summarized in Table A-4).

This model will be used to evaluate core design changes incorporated to prevent fluctuation motions of columns. It will further our understanding of techniques to prevent fluctuations in a reactor core.

The model will also serve to refine techniques of model design, manufacture, and test before the final 66 column proof test model (described below) is made.

2.1.3. The 66 Column 3-D Model

This will be the last of the series of models intended to increase the understanding of core fluctuations and for testing ways to prevent them. Like the prior models of this series it will be 1/4 scale.

If tests on the previous models demonstrate with confidence that the fluctuation phenomenon is understood sufficiently to ensure that the design changes adopted are effective, this model will not be made.

The model will simulate all 66 columns in the active annular core, each identical to the column used in the single-column tests. This model will be used to evaluate antifiuctuations design features in an extensive array of core columns.

The model in its final form (with the recommended design changes incorporated) will be used for the proof test. The proof test will ensure that the design adopted will not fluctuate under any reactor operating condition.

2.2. TEST SETUP DESCRIPTION - SINGLE COLUMN MODEL

The model shall be comprised of simulated core fuel column at 1/4 scale standing in a flow channel. Air shall be drawn down the gap between the column and the flow channel walls into an exit plenum and then exhausted to atmosphere. The arrangement is shown diagrammatically in Fig. 2-1.

Small gaps (typically 0.068 in.) shall be maintained between the simulated fuel column and the flow channel walls over the 111.22 in. height of the column. This will require special care in the design, manufacture, and assembly of the model.

The flow channel shall be designed to be capable of reducing this gap over the top 3.9 in. and bottom 3.9 in. to 0.005 in. while maintaining the gaps over the rest of the height at their nominal value of 0.068 in..

The simulated fuel column shall be hexagonal in section and comprises ten heated and seven unheated elements. The heated elements

represent core fuel elements and the unheated elements represent core reflector blocks and the core support blocks. These blocks shall be arranged as shown in Fig. 2-1.

The elements representing the core fuel elements shall be heated by flexible silicon heaters capable of up to 1.6 W/in.^2 installed over the outer surface of each block. The other elements shall not have heaters.

All elements shall be fabricated very accurately from sheets of 1/2-in. thick polycarbonate resin (like Lexan which is made by GE)* which have been machined to suit. Figure 2-2 is the fabrication sketch for the standard height block. The half-height block is the same only shorter.

Dowel pins shall be used to restrain the relative rotational and lateral movements between all elements of the column and between the column and its support spider.

The simulated core column shall stand in a steel-walled flow channel. The flow channel shall be hexagonal in section and made from six bevelled plates. The fabrication sketch for the plates is shown in Fig. 2-3. The six plates shall be dowelled and keyed together and shall be held in position by the tube and bulkhead support structure similar to the one shown in Fig. 2-4. The bulkheads shall be provided with means for adjustment to hold the wall plates in position. With all the flow channel walls in the fully "in" position the gap between the column and flow channel shall be 0.068 in.

*As an alternative, the blocks can be made out of 0.2 in. thick aluminum as discussed in Appendix B. For the aluminum blocks the heaters could be placed on the inner surface of each block.

The plenum chamber and column support spider shall be as illustrated in Figs. 2-5, 2-6 and 2-7.

The floor and walls of the plenum chamber shall be made from 1/2-in. thick steel plate, and the top shall be made from ground 3/4-in. thick steel plate. Two transverse screens shall separate the inlet flow coming from the column gap from the four exit pipes to the fans. The screens ensure that the sink pressure at exit from the column gap is uniform. The plenum box stands on four level adjustment feet.

The simulated fuel column shall stand on steel plate which shall be welded to a six-legged spider. The spider shall be a very stiff structure and shall be suspended from the plenum top plate by six bolts which permit adjustments to make vertical the column while a test is in progress. These features are illustrated in Figs. 2-6 and 2-7.

The flow channel walls shall stand on the ground upper surface of the top plate of the plenum and shall be held in position by the support structure. The lowest bulkhead of the support structure shall be bolted to the top plate on the plenum as shown in Fig. 2-5.

Flexible silicon heaters capable of 5 W/in.^2 shall be installed in six independently controllable sections. Specifically, these heaters are located at elevations adjacent to the ten active core elements shown in Fig. 2-1.

The heaters shall be sufficient to heat the wall temperatures to a uniform temperature around the channel. Also, the heaters shall be capable of heating sides A, B, and C of the channel (see Fig. 2-9) to a different temperature than sides D, E, and F.

2.3. EQUIPMENT REQUIREMENTS

A detailed list of the required equipment, equipment function, and quantity is given in Tabel 2-1.

2.4. INSTRUMENTATION REQUIREMENTS

The instrumentation shall be sufficient for detecting the motion and location of the column; the nominal axial pressure profile; overall apparatus flow rate, pressure drop, and heat rate. Specifically this shall include the instrumentation summarized in Table 2-2.

The weight of the blocks shall be measured prior to testing and again after all testing is complete.

All the remaining measurements are to be recorded with time and stored so that plots of the data can be generated. Plots similar to those shown in Fig. 2-11 are to be generated for each test. After a review of these plots, additional plots may be generated similar to those shown in Fig. 2-12.

2.5. CALIBRATION REQUIREMENTS

All test instruments shall be in current calibration. Where applicable, instrument systems shall be calibrated end-to-end prior to testing and upon completion of testing.

2.6. DATA REQUIREMENTS

The testing to be performed is investigative in nature. The principal objective of determining a fluctuation threshold requires that some reasonable parameters be used to determine and display the results. In fact, these parameters may not be known prior to the investigation itself. Such is the case here. If the mechanism of fluctuation is the

thermal expansion, pressure mechanism as it is currently understood, then the two likely candidates for describing the threshold would be:

- (a) something proportional to the forces developed by the flow, and
- (b) something proportional to the thermal bowing restoring movement.

The initial choices of parameters are as follows: For the force developed by the flow, the overall apparatus pressure drop (ΔP_G) is used. For the parameter proportional to thermal movement, the maximum available temperature change of the column is used; i.e., the difference between the hottest wall temperature and the coldest wall temperature (ΔT). This would be the maximum value of ΔT_{iAD} , ΔT_{iBE} , and ΔT_{iCF} for a given block elevation i .

For each test the data shall be summarized as indicated in Table 2-3. If the column does not fluctuate then the measured values are not expected to change significantly with time. If columns do fluctuate, then the values will change with time as shown in the plots in Figs. 2-11 and 2-12. In this case the data in Table 2-3 should correspond to one or more selected time points. Plots similar to those shown in Figs. 2-11 and 2-12 shall be generated for any test condition which experience fluctuations.

2.7. ACCEPTANCE CRITERIA

2.7.1. Model Inspection

The model column and channel shall be inspected by Quality Assurance to record the block dimensions, angles, and cross flats dimensions. The model is acceptable if its dimensions are as specified in Figs. 2-2 and 2-3 (drawings to be released for fabrication and inspection).

Based on the dimensions in Fig. 2-3, the cross flat dimensions (L_x) on the inside of the pressure boundary forming the outer boundary of the flow channel is:

$$\begin{aligned} L_x &= 2 L_z \cos 30^\circ , \\ L_z &= 2.096 \pm 0.005 \text{ in.} , \\ L_x &= 3.63 \pm 0.009 \text{ in.} , \end{aligned}$$

since for the column $L_x = 3.494$ in. (per Fig. 2-2). This implies an average gap between column and channel of:

$$\delta = (3.63 - 3.494)/2 = 0.068 \text{ in.}$$

2.7.2. Testing

A given test condition can be acceptable if it reaches a steady state condition for at least 30 minutes.

If the column does not fluctuate, then acceptable steady state conditions are reached when ΔP_g , $\Delta T_a (= T_{aout} - T_{ain})$, $\dot{m}_a$, and HE6 do not vary by more than $\pm 10\%$ from their nominal value.

If the column does fluctuate, then in addition to the above it is necessary to check that the key parameters shown in Fig. 2-11 are repeatable between cycles within $\pm 20\%$.

Fig. 2-1. Schematic of single column model

Fig. 2-2. Block sketch

SECT. AA (THROUGH KEYWAY)

SCALE ~ F.S

SECT. BB (THROUGH DOWEL)

SURFACE $\neq$ GROUND FLAT TO
 ± 0.004 " TRANSVERSELY
 ± 0.004 " PER 6" LENGTH

Fig. 2-3. Side wall sketch

Fig. 2-4. Apparatus photograph

Fig. 2-5. Photographs of plenum chamber

Fig. 2-6. Photographs of support spider

Channel
elevation (j)
Number

Fig. 2-7. Proximity probe of static tap locations

Fig. 2-8. Schematic of single column model with instrumentation locations

Fig. 2-9. Schematic of cross section of test rig showing instrumentation locations

Fig. 2-10. The elevation location of instrumentation on column and channel

Fig. 2-11. Plots of key measured parameter versus time

Plots of Key measured parameters as a function of elevation height along column at selected times

Fig 2-12

TABLE 2-1
EQUIPMENT REQUIREMENTS

Equipment/Number	Function
1. Blower	Force up to 0.04 lb/s of air through model with pressure drop of up to 2 psi
2. Flexible silicon heaters capable of 5 W/in. ²	Heat channel wall up to 200°F above ambient
3. Electricity	Sufficient to run fan and electric heater plus all instrumentation

TABLE 2-2
INSTRUMENTATION REQUIREMENTS

Measurement	Location	Range/Desired Accuracy
1. Static pressure drop (ΔP) relative to ambient pressure (P_{∞}) psig		
1.1. Along flow channel (ΔP_{ij}) ^(a)	10 elevation, 3 sides (Figs. 7 and 9)	0 to 2/ ± 0.01
1.2. Lower plenum: $\Delta P_G = P_{\infty} - P_0$	Upstream of screens	0 to 2.0/ ± 0.01
2. Static pressure drop ΔP relative to pressure on opposite face of block, ΔP_{iAD} , ΔP_{iBE} , ΔP_{iCE}	10 elevation x 3 sides (Figs. 7 and 8)	0 to 0.5/ ± 0.01
3. Temperature (T), °F		
3.1. Air (T_{ain})	Inlet	60 to 100/ ± 1
3.2. Fuel element/reflect element block (T_{iA} , T_{iB} , T_{iC} , T_{iD} , T_{iE} , T_{iF})	17 elevation x middle of face (Fig. 9)	60 to 200/ ± 1
3.3. Air (T_{aout})	Outlet	60 to 200/ ± 1
3.4. Channel wall (T_{cij})	10 elevation x 3 sides (Figs. 7 and 9)	60 to 200/ ± 1

TABLE 2-2 (Continued)
INSTRUMENTATION REQUIREMENTS

Measurement	Location	Range/Desired Accuracy
4. Air flow rate ($\dot{m}$), lb/s	Total flow	0 to 0.04/ ± 0.001
5. Electric power to heaters	Voltmeter, ammeter	
6. Gap width between column and channel (δ_{ij})	3 sides, 5 elevations (Figs. 7, 9, and 10)	0.000 to 0.200/ ± 0.001 in.
7. Weight (W)		
7.1. Blocks (each separately) (W_i)	With and without instrumentation	0.5 to 5 lb/ ± 0.01 lb
8. Time (τ) (b)	At least every 60 s except for 6 key measurements which shall be recorded every 10 s	0 to 2 h/ ± 2 s

(a) Subscript: i = elevations, 1 through 10 (Fig. 7) on channel walls,
 i = elevations, 1 through 17 (Fig. 8) on column blocks, and
 j = side A through D (Fig. 9) of hexagonal.

(b) This indicates the time between the measurements indicated above. The one exception is the electric power to heaters which is only required to be measured three times (start, middle, and end) during the test.

TABLE 2-3
DATA RECORDED FOR 1/4 SCALE COLUMN TEST

No. (a)	Measurement
8	Date , Time
1.2.	ΔP_G , psi
2.	ΔP_{6AD} , psi ΔP_{6BE} ΔP_{6CF}
3.1.	T_{ain} , °F
3.2.	T_{6A} , °F T_{6B} T_{6C} T_{6D} T_{6E} T_{6F}
3.3.	T_{aout} , °F
3.4.	T_{C6B} , °F
4.	$\dot{m}$, lb/s
5.	HE6 , volts
6.	δ_{6A} , inch δ_{6B} δ_{6C}
	Fluctuations observed , yes or no

(a) No. refers to the measurement number given in Table 2-2.

3. QUALITY ASSURANCE

These tests are classified as QAL-I and shall be carried out in accordance with QAPD-6465.

4. PROCEDURE

4.6.1. Testing of the Unrestrained Column

The testing procedure that shall nominally be used for these test is as follows:

- a. The balance and general location of the column shall be checked before the flow or heat is applied to the apparatus. If necessary, the spider shall be adjusted to bring the column center at the uppermost level nominally to the centermost position.
- b. The blowers shall be turned on and the flow rate shall be increased to a value below what is believed to be the fluctuation threshold. (This point is not always known but, generally speaking, can be determined by watching the displacement of the columns. The column moves with increasing pressure and should not be displaced beyond a freestanding position; i.e., no pressure forces are supported by the walls.
- c. The heaters shall be turned on to heat the walls of the apparatus to the desired temperature level. (This could be any number of heaters.)
- d. The heater power shall be adjusted periodically to maintain some desired wall temperatures.
- e. The air flow rate shall be increased to some test level to try to induce fluctuation. (The time required to determine this point is several minutes. However, after fluctuations start, it is evident that there are some transient heating effects to the column that take longer to stabilize; i.e., 10 to 15 minutes.)

- f. Air flow rate and/or heating rate shall be changed to cover the fluctuation map desired.

4.6.2. Testing of the Restrained Column

The fluctuation testing to determine the effectiveness of restraining the top of the column preceded as follows first with no restraint:

- a. The central position of the column shall be checked as before.
- b. The flow shall be increased to a nonfluctuation level.
- c. The heaters shall be turned on and the wall temperature brought to a fluctuating level.
- d. The flow shall be increased well into the fluctuation zone.
- e. Fluctuation shall be allowed to stabilize.
- f. Restraint devices shall be installed to demonstrate the cessation of fluctuations.
- g. Pressure drop and temperature shall then be varied greatly to look for a new fluctuation threshold.

The restraint devices that shall be used in this test are thin wires located at the top of the column in the middle of faces A, C, and E; such that there is approximately 0.008 in. of free movement in any one direction. This simulates in principal the restraint divide idea whereby the gap widths are stabilized even though there is the possibility of some movement.

5. REFERENCES

1. Betts, W. S., "Review of Core Fluctuations," Doc. 909274/1, GA proprietary report, January 29, 1987.
2. Saeger, J., "Test Report of 1/4 Scale Fluctuations," Doc. 907459/1, GA proprietary report, April 27, 1984.

APPENDIX A MHTGR CORE DESIGN

Tables A-1 through A-4 and Figs. A-1 through A-9 summarize the characteristics of the core in the MHTGR reactor. A column in the active core consists of ten fuel elements with one full-height and two half-height reflectors above the active core and four blocks below the active core. As shown in Fig. A-2, the active core consists of 54 standard fuel elements and 12 RSC fuel elements. A schematic of these fuel elements is shown in Figs. A-3 and A-4.

The reflector elements above the active core are basically the same as the fuel elements except that there are no fuel holes. The configuration of the four blocks below the active core is shown in Fig. A-5.

The hexagonal central reflectors and outer reflectors are made of H451 graphite and have no coolant holes. Figure A-9 is a schematic of one of the 30 reflectors with control rod channels.

REFERENCES

1. Yu, H., "TWOD Thermal-Irradiation and Seismic Stresses in the MHTGR Fuel Element Column 25," Document 909016/0, September 25, 1986.
2. Henderson, M., "Core Thermal/Hydraulics Performance and Hot Streaks," Document 909051/0, September 26, 1986.

TABLE A-1
SUMMARY OF CORE DESIGN CONFIGURATION - MHTGR

- Annular (see Fig. A-2) - 163 hexagonal columns each 17 blocks high (452.7 in.).
 - 66 columns with 10F + 7R.
 - 97 columns with 17R.
- Material for fuel and reflectors - H451 graphite.
 - Density (ρ) = 116 ± 2 lb/ft³.
 - Coefficient of thermal expansion $\alpha_y = 2.6 \times 10^{-6}$ °F⁻¹.
 - Elastic modulus (E) = 1.2×10^6 psi for unirradiated graphite.
- Block characteristics (Figs. A-3, A-4, and A-5).
 - Cross flats width = 14.172 ± 0.010 in.².
 - Height = 31.22 in.
 - Hexagonal with surface area = 173 in.².
 - Weight fuel block, $Wt_F = 287$ lb.
 - Weight reflector block, $Wt_R = 363$ lb (with no holes).
- Gap conditions.
 - Normal operation (Table A-2)
- Block distortions (δ_B) vary with layer location (i) in core and time (t). See Fig. A-7.
 - BOL (beginning of life) $\delta_B \leq$ less than shown in Table A-3.
 - EOL (end of life) δ_B is given in Table A-3.

TABLE A-2
NORMAL OPERATION (HOT) CORE GAPS (UNIFORM CASE) (a)

Layer	Central Reflector	Interface CR/Core	Core	Interface Core/Hexagon Reflector	Hexagon Reflector	Interface Hexagon Reflector	Permenant Reflector	PR/Core Barrel
Plenum(b)	0.040	0.040	0.040	0.040	0.040	0.040	0.030	0.125
Top Reflector	0.076	0.076	0.076	0.076	0.076	0.076	0.053	0.163
F1	0.090	0.099	0.107	0.096	0.085	0.072	0.046	0.159
F2	0.091	0.097	0.102	0.093	0.083	0.069	0.043	0.157
F3	0.089	0.088	0.087	0.082	0.076	0.063	0.041	0.155
F4	0.083	0.079	0.075	0.072	0.069	0.069	0.040	0.154
F5	0.075	0.070	0.064	0.063	0.061	0.055	0.038	0.153
F6	0.067	0.060	0.052	0.055	0.058	0.052	0.040	0.154
F7	0.063	0.054	0.045	0.050	0.055	0.051	0.040	0.154
F8	0.059	0.050	0.041	0.047	0.053	0.052	0.040	0.154
F9	0.056	0.047	0.037	0.045	0.052	0.051	0.041	0.155
F10	0.054	0.045	0.035	0.043	0.051	0.051	0.041	0.155
Bottom reflector	0.052	0.052	0.052	0.056	0.060	0.058	0.044	0.158
Core support	0.022	0.022	0.022	0.026	0.029	0.044	0.047	0.159

(a) These gaps were used in Ref. 2 to make core flow distribution estimates. All gaps dimensions are in inches.

(b) Metallic plenum elements.

TABLE A-3
BLOCK DISTORTIONS - MHTGR CORE

Elevation Location	δ_B , in. (a)
Layer 1	0.041
Layer 5	0.033
Layer 10	0.004

(a) Values given are for column 25 (as shown in Fig. A-2) at EOL per Ref. 1. These values represent maximum distortions and reflect the effects of unsymmetric temperature and fluence distribution.

The portion of this distortion due to unsymmetric temperature distribution is :

$$\delta B_{th} = H^2 / (8r) \quad ,$$

$$\text{where } r = L_x / (\Delta T \alpha) \quad ,$$

where as shown in Fig. A-3

$$H = 31.22 \text{ in.} \quad ,$$

$$L_x = 14.173 \text{ in.} \quad ,$$

$$\text{and } \alpha = 2.6 \times 10^{-6} \text{ } ^\circ\text{F}^{-1} \text{ (per Table A-1)} \quad .$$

It follows that for a block $\delta B_{th} = 2.3 \times 10^{-5} \Delta T$, inch. Based on a linear temperature gradient of approximately 200°F through thickness of block $\delta B_{th} = 0.0045$ in.

TABLE A-4
SUMMARY OF CONDITION OF PRIMARY COOLANT IN MHTGR CORE

- Pressure:
 - Inlet pressure, $P_{Gi} = 925$ psia
 - Pressure drop from inlet to exit, $\Delta P_G = 4$ to 5 psi
- Temperature of gas in gaps (see Fig. A-8):
 - Inlet temperature, $T_{Gi} = 497^\circ\text{F} = 957^\circ\text{R}$
 - Outlet temperature, $T_{Go} = 1122^\circ\text{F} = 1582^\circ\text{R}$
 - Average temperature, $T_G = (T_{Gi} + T_{Go})/2 = 810^\circ\text{F} = 1270^\circ\text{R}$
- Properties of helium:
 - $R_G = 386$ ft-lb_f/lb_m °R
 - Density, $\rho_G = P/RT$: $\bar{\rho}_G = 0.27$ lb/ft³, based on $T = T_G$
 - Viscosity, $\mu_G = 1.86 \times 10^{-7} T^{0.68}$ lb/ft-s (with T in °R):
 $\bar{\mu}_G = 2.4 \times 10^{-5}$ lb/ft-s, based on $T = T_G$
- Flow conditions (per Ref. 2):
 - Based on gap dimensions shown in Table A-2
 - Flow distribution per Fig. A-8 includes following gas velocities

V_G gaps:

$$V_G = \dot{m}_G / \rho_G A_G$$

$$A_G = 150 \times 8.18 \times \delta_G \text{ in.}^2$$

δ_G is gap width, in. (these are given in Table A-2)

For Level 5:

$$\delta_G = 0.064 \text{ in.} \quad A_G = 78.5 \text{ in.}^2 = 0.545 \text{ ft}^2$$

$$\dot{m}_G = \frac{1.19}{100} \times 1.248 \times 10^6 = 1.485 \times 10^4 \frac{\text{lb}}{\text{h}} = 4.13 \frac{\text{lb}}{\text{s}}$$

$$V_G = \frac{4.13}{0.27 \times 0.545} = 28 \text{ ft/s}$$

$$Re_d = \frac{\rho_G V_G \times 2\delta}{\mu_G} = \frac{0.27 \times 28 \times 2 \times 0.064/12}{2.4 \times 10^{-5}} \approx 3400$$

FIG. A-1.

Fig. A-1. Reactor core subsystem - elevation view

Fig. A-2. Reactor core layout

Fig. A-3. Standard fuel element

Fig. A-4. RSC fuel element

Fig. A-5. Bottom reflector and graphite core support

Fig. A-6. Plenum elements - plan view

Fig. A-7. Block distortions - MHTGR

Fig. A-8. Core flow distribution - uniform gap case

Fig. A-9. Reflector block

APPENDIX B THERMAL/HYDRAULIC CHARACTERISTIC NEEDED IN MODEL

Summary

This appendix calculates the thermal/hydraulic characteristics of the model needed to simulate fluctuation potential in the prototype MHTGR core. These calculations show that to properly simulate the ratio of the disturbing moment (M_D) to the restoring moment (M_R) based on full power conditions (i.e., $\Delta P_G = 5$ psi in MHTGR):

$$\left(\frac{\Delta P_G}{\rho H + \Delta P_G} \right) = 0.17 \quad , \quad (16)$$

where ρ = density of model blocks,

H = height of entire column of block in model, $H = 111.22$ (per Fig. 2-1)

ΔP_G = pressure difference of gas between top and bottom of column.

Solving equation 16 for the 1/4 scale model with a $\rho = 0.022$ lb/in.³* shows that a $\Delta P_G = 0.5$ psi in the model yields the same ratio of the M_D/M_R as in the MHTGR core at full power. If ΔP_G increases above 0.5 psi then the relative magnitude of the disturbing moments to the restoring moments increases above what would be expected in the MHTGR core.

Implicit in the above conclusion is the assumption that the pressure distribution around the column in the model is the same as the

*A $\rho = 0.022$ lb/in.³ is achieved with a model made of a polycarbonate like Lexan with the dimensions shown in Fig. 2-2 or a model made of aluminum with dimensions same as Fig. 2-2 except with wall thickness decreased from 0.5 in. to 0.2 in.

prototype. This leads to the additional requirement that the block distortion are scaled properly. To insure this requires that:

$$\left(\frac{\delta_B}{H}\right)_M = \left(\frac{\delta_B}{H}\right)_P, \quad (23)$$

$$\left(\frac{\delta_B}{\delta}\right)_M = \left(\frac{\delta_B}{\delta}\right)_P, \quad (37)$$

where δ_B = thermal induced distortion as shown in Fig. A-7 of Appendix A,

H = height of column,

δ = gap between the column and the channel.

For equation 23 to be valid

$$(\alpha\Delta T)_M = (\alpha\Delta T)_P,$$

where α = coefficient of thermal expansion,

ΔT = temperature drop across width of block.

Based on the maximum expected ΔT of a fuel block at 100% power (i.e., $\Delta T_P = 200^\circ\text{F}$), equation 24 reduces to

$$(\alpha\Delta T)_M \approx 5.2 \times 10^{-4}. \quad (25)$$

Based on α of a polycarbonate ($\alpha = 3.75 \times 10^{-5} \text{ }^\circ\text{F}^{-1}$) it follows that $\Delta T_M = 14^\circ\text{F}$.

Based on α of aluminum ($\alpha = 13 \times 10^{-6} \text{ }^\circ\text{F}^{-1}$), it follows that $\Delta T_M = 40^\circ\text{F}$.

For both equations 23 and 37 to be valid requires that $\delta_M = 1/4 \delta_P$ (since $H_M = 1/4 H_P$). While this is an ideal objective in theory, it is

hard to achieve in practice due to tolerances on δ_M . It is more realistic to set $\delta_M \approx \delta_p$. This then requires that for ΔT_M be increased by a factor of 4 in order to insure that equation 37 is satisfied. Based on the above it is suggested that tests be run with ΔT_M ranging from what is needed to satisfy equation 23 (i.e., 14°F for polycarbonate) to what is needed to satisfy equation 37 (i.e., 56°F based on $\delta_M = \delta_p$ for polycarbonate).

Discussion

As described in Ref. 1 fluctuations are the result of changes in the relative magnitude of the disturbing forces (F_D) and restoring forces (F_R) on a block or column. These forces are shown in Fig. B-1.

The disturbing forces (F_D) are produced by the differences in the static pressure (P_S) profile on the faces of the fuel column.

$$F_D = \Delta P_S A \quad , \quad (1)$$

Based on nomenclature shown in Fig. B-2, the difference in static pressure force in the x direction is:

$$\Delta P_S A = \left[\left(P_{SB} + \frac{P_{SCX}}{2} + \frac{P_{SAX}}{2} \right) - \left(P_{SE} + \frac{P_{SDX}}{2} + \frac{P_{SFX}}{2} \right) \right] L_z H \quad , \quad (2)$$

where P_{SB} = static pressure on face B,

$P_{SCX} = P_{SC} \times \cos 60^\circ = P_{SC}/2$,

$P_{SAX} = P_{SA} \times \cos 60^\circ = P_{SA}/2$,

P_{SE} = static pressure on face E,

$P_{SDX} = P_{SD}/2$,

$P_{SFX} = P_{SF}/2$,

H = height over which static pressure applies,

$$L_z = L_x / (2 \cos 30^\circ) \quad (3)$$

$F = \text{Force}$
 $v = \text{velocity of gas}$

Fig. B-1. Schematic of column with associated disturbing forces and restoring forces

$$L_z = \frac{L_x}{2 \cos 30^\circ}$$

$$A_H = \frac{3 L_x^2}{4 \cos 30^\circ}$$

Fig. B-2. Schematic showing pressure forces on vertical faces of hexagonal block

Based on model with $L_x = 3.475$ in. (per Fig. 2-2 of text)
 $L_z = 2.006$ in. While for the prototype MHTGR with $L_x = 14.172$ (per
 Fig. A-4 of Appendix A), $L_z = 8.18$ in.

The relative magnitude of ΔP_S (per Ref. 1) is:

$$\Delta P_S \propto \frac{fH}{2\delta} \frac{\rho_G V_G^2}{2g_c} , \quad (4)$$

where δ = gap width,

ρ_G = density of gas,

V_G = velocity of gas,

f = hydraulic friction coefficient (see Fig. B-3).

The restoring forces (F_R) result from the weight of the blocks or column (F_{RW}) and the net pressure loading on the ends of the blocks or columns (F_{RP}).

$$F_{RW} = \rho V , \quad (5)$$

where ρ = density

V = volume

while (per Ref. 1)

$$F_{RP} = \Delta P_G A_H , \quad (6a)$$

$$\Delta P_G = \frac{fH}{2\delta} \frac{\rho_G V_G^2}{2g_c} . \quad (6b)$$

To properly simulate core fluctuation the ratio of the disturbing moment (M_D) to the restoring moment (M_R) in the model should be the same as in the prototype (MHTGR).

Fig. B-3. Friction coefficient as a function of Reynolds number for round pipes of various roughness ratio ϵ_s/d

$$\frac{M_D}{M_R} = \frac{H \times F_D}{W \times (F_{RW} + F_{RP})} \quad (7)$$

Substituting equations 3, 4, 5, and 6 yield

$$\frac{M_D}{M_R} \propto \frac{\frac{fH}{2\delta} \frac{\rho_G V_G^2}{2g_c} L_x H}{\rho V + \Delta P_{GAH}} \frac{H}{L_x} \quad (8)$$

For hexagonal shaped blocks

$$A_H = \frac{3L_x^2}{4 \cos 30^\circ} \quad (10)$$

$$\frac{M_D}{M_R} \propto \frac{\frac{fH}{2\delta} \frac{\rho_G V_G^2}{2g_c} L_x H}{\rho H + \Delta P_{GA}} \left(\frac{H}{L_x^3} \right) \quad (11)$$

Substituting equation 6b into 11 yields

$$\frac{M_D}{M_R} \propto \frac{\Delta P_G}{\rho H + \Delta P_G} \left(\frac{H}{L_x} \right)^2 \quad (12)$$

For typical MHTGR conditions (per Ref. 1)

$$\begin{aligned} \rho &= 0.053 \text{ lb/in.}^3 \\ H &= 453 \text{ in.} \quad \rho H = 24 \text{ psi} \\ \Delta P_G &= 5.0 \text{ psi} \end{aligned}$$

Substitution into equation 12 yield

$$\left(\frac{M_D}{M_R} \right)_P \propto 0.17 \left(\frac{H}{L_x} \right)^2 \quad (13a)$$

If $\Delta P_G = 10 \text{ psi}$, then

$$\left(\frac{M_D}{M_R} \right)_P \propto 0.30 \left(\frac{H}{L_x} \right)^2 \quad (13b)$$

Based on using Lexan (polycarbonate) blocks with dimensions as shown in Fig. 2-2 of main text, the weight (F_{RW}) a single full-size block

$$(F_{RW})_1 = \rho_M V_M ,$$

$$\rho_M = \text{density of block material} = 75 \text{ lb/ft}^3 ,$$

$$V_M = \text{volume of Lexan in block} ,$$

$$V_M = \frac{3}{\cos 30^\circ} \times (1.7375^2 - 1.2375^2) \times 7.8 \\ + 3 \times \frac{1.2375^2}{\cos 30^\circ} \times \frac{2}{8} \text{ in.}^3 ,$$

$$V_M = 40.2 + 1.3 = 41.5 \text{ in.}^3 ,$$

$$(F_{RW})_1 = 1.8 \text{ lb} .$$

For 1/2 height blocks (see Fig. 1)

$$V_{1/2} = 40.2 \times 1/2 + 1.3 = 21.4 ,$$

$$(F_{RW})_{1/2} = 0.93 \text{ lb} .$$

For other height blocks

$$(F_{RW})_{3/4} = 1.37 \text{ lb} ,$$

$$(F_{RW})_{0.6} = 1.10 \text{ lb} ,$$

$$(F_{RW})_{0.4} = 0.75 \text{ lb} ,$$

$$F_{RW} = 11 \times (F_{RW})_1 + 3 \times (F_{RW})_{1/2} + (F_{RW})_{3/4} \\ + (F_{RW})_{0.6} + (F_{RW})_{0.4} ,$$

$$F_{RW} = 25.8 \text{ lb} .$$

Cross section area of block

$$A = 3 \times \frac{1.7375^2}{\cos 30^\circ} = 10.46 \text{ in.}^2 ,$$

therefore, the weight of the blocks is equal to a pressure load of

$$\frac{F_{RW}}{A} = 2.47 \text{ psi} .$$

The effective density of full size block is:

$$\rho = F_{RW}/V ,$$

$$V = \frac{3L_x^2}{4 \cos 30^\circ} H ,$$

$$L_x = 3.475 \text{ in. and } H = 7.8 \text{ in.} \Rightarrow V = 81.5 \text{ in.}^3 ,$$

$$\rho = 1.8/81.5 = 0.022 \text{ lb/in.}^3 .$$

Based on $H_M = 111.22 \text{ in.}$ (per Fig. 2-1 of main text) equation 12 yields

$$\left(\frac{M_D}{M_R} \right)_M \propto \frac{\Delta P_G}{2.47 + \Delta P_G} \left(\frac{H}{L_x} \right)_M^2 , \quad (14)$$

to insure

$$\left(\frac{M_D}{M_R} \right)_M = \left(\frac{M_D}{M_R} \right)_P , \quad (15)$$

based on equation 13a [i.e., $(\Delta P_G)_P = 5 \text{ psi}$]

$$\frac{\Delta P_G}{2.47 + \Delta P_G} \left(\frac{H}{L_x} \right)_M^2 = 0.17 \left(\frac{H}{L_x} \right)_P^2 . \quad (16)$$

Based on

$$\left(\frac{H}{L_x} \right)_M = \left(\frac{H}{L_x} \right)_P ,$$

it follows that

$$(\Delta P_G)_M = 0.50 \text{ psi} ,$$

as ΔP_G in the model increase above 0.5 psi, it is more likely to fluctuate than in the prototype (actual MHTGR core). Based on equation 13b (i.e., assuming $(\Delta P_G)_P$ increases to 10 psi) then $(\Delta P_G)_M = 1.06 \text{ psi}$.

The above does not include the weight of any instrumentation in the density of the model. Once this weight is known it should be included. This additional weight will have the effect of increasing the required $(\Delta P_G)_M$. However, implicit in the conclusion is the additional assumption that the pressure distribution around the column in the model is the same as the prototype. This leads to the additional requirement that the block distortions are scaled properly.

If fluctuations are to occur, it will be due to changes in the magnitude of the disturbing moment (M_D). This can occur due to changes in the pressure profile around the hexagonal block as indicated by equation 2. The mechanism for these changes is a change in the shape of the blocks in the column due to thermal gradients in the block. Figure A-7 of Appendix A shows a typical block distorted by δB . This block is assumed to curve in the arc of a circle of radius (r). Assuming a linear temperature gradient through the thickness (L_x) of the block.

$$r = \frac{L_x}{\Delta T \alpha} \quad (17)$$

Therefore, for the distorted shape of the model to match that of the prototype

$$\left(\frac{L_x}{\Delta T \alpha} \right)_M = \left(\frac{L_x}{\Delta T \alpha} \right)_P \quad (18)$$

Since

$$\frac{L_{xM}}{L_{xP}} = \frac{1}{4} ,$$

it follows

$$(\alpha \Delta T)_M = 1/4 (\alpha \Delta T)_P . \quad (19)$$

For MHTGR core

$$\alpha_P \approx 2.6 \times 10^{-6} \text{ } ^\circ\text{F}^{-1} ,$$

$$\Delta T_P \leq 200^\circ\text{F} ,$$

it follows that

$$\Delta T_M \approx 3.5^\circ\text{F} .$$

The deflection associated with the above distortion is:

$$\delta B = r(1 - \cos \theta) , \quad (20)$$

$$\theta = \frac{H}{2r} \text{ rad} , \quad (21)$$

$$\delta B = \frac{H}{8r} . \quad (22)$$

For prototype: $L_x = 14.17$ in. (per Appendix A). Based on $H = 31.22$ in. (block height): $(\delta B)_P = 0.005$ in. Based on $H=453$ in. (column height): $(\delta B)_P = 0.94$ in. Based on equation 22 if $r_M = r_P$ and $H_M = 1/4 H_P$, then $\delta B_M = 1/16 \delta B_P$.

It would be conservative (maximize potential to induce fluctuation) to design the test model so that

$$\left(\frac{\delta B}{H}\right)_M = \left(\frac{\delta B}{H}\right)_P, \quad (23)$$

or

$$(\alpha \Delta T)_M = (\alpha \Delta T)_P. \quad (24)$$

Based on equation 24 and the values for α_p , ΔT_p , and α_M , it follows $\Delta T_M \leq 14^\circ\text{F}$.

Per equation 6a

$$\Delta P_G = \frac{fH}{2\delta} \frac{\rho_G V_G^2}{2g_c} \quad (6a)$$

Since

$$\dot{m} = \rho_G V_G A_G, \quad (25)$$

$$A = 6L_z \delta, \quad (26)$$

$$\Delta P_G = \frac{fH}{2\delta^3} \frac{\dot{m}^2}{2g_c \rho_G} (6L_z)^2, \quad (27)$$

assuming laminar flow ($Re_d \leq 2000$):

$$f = 94/Re_d, \quad (28)$$

$$Re_d = \frac{\rho_G V_G 2\delta}{\mu_G} = \frac{\dot{m}}{3L_z \mu_G} \quad (29)$$

Substitution of 29 and 28 into 27 yields

$$\Delta P_G = 0.0608 \frac{\mu_G}{\rho_G} \frac{H}{\delta^3 L_z} \dot{m} \quad , \quad (30)$$

with ΔP_G in psf, δ in ft, $\dot{m}$ in lb/s.

For air at 100°F

$$\begin{aligned} \rho_G &= 0.071 \text{ lb/ft}^3 \quad , \\ \mu_G &= 1.285 \times 10^{-5} \text{ lb/ft-s} \quad , \end{aligned}$$

substitution of these properties into equation 30 yields

$$\Delta P_G = 1.1 \times 10^{-5} \frac{H}{\delta^3 L_z} \dot{m} \quad . \quad (31)$$

For the model

$$\begin{aligned} H &= 111.22 \text{ in.} \quad , \\ L_z &= 2.017 \text{ in.} \quad , \\ \Delta P_G &= 7.3 \times 10^{-3} \frac{\dot{m}}{\delta^3} \quad , \end{aligned} \quad (33)$$

with ΔP_G in psi, δ in inch and $\dot{m}$ in lb/s. Note equation 33 is valid of $Re_d < 2000$ which per equation 29 implies $\dot{m} < 8.6 \times 10^{-3}$ lb/s. If $\Delta P_G = 0.5$ psi, this means $\delta < 0.05$ in. The associated velocity $V_G = 29$ ft/s (this corresponds closely to the V_G in MHTGR shown in Table A-5 of Appendix A). If $\delta = 0.064/4 = 0.016$ in. (i.e., 1/4 gap of core given in Table A-5 of Appendix A), then $\Delta P_G = 1780$ $\dot{m}$. Therefore, to get $\Delta P_G = 0.5$ psi, $\dot{m} = 2.8 \times 10^{-4}$ lb/s which yields a velocity $V_G = 2.9$ ft/s. If $\delta = 0.064$ in. (as is the case in the MHTGR at level 5 per Table A-5 of Appendix A), then equation 33 would only be valid if $\Delta P_G \leq 0.24$ psi.

In the turbulent flow regime ($Re > 3000$) the friction factor is a function of the relative surface roughness (ϵ_s/d) as well as the Reynolds number as shown in Fig. B-3. As a first guess, however, assume the ϵ_s/d is sufficiently small such that can assume smooth pipes where

$$f = 0.3164 Re_d^{-1/4} \quad (34)$$

Substitution of 34 and 29 into 27 yields

$$\Delta P_G = \frac{2.9 \times 10^{-3}}{\epsilon_c} \frac{\mu_G^{1/4}}{\rho_G} \frac{H}{\delta^3 L_z^{1.75}} \dot{m}^{1.75}, \quad (35)$$

based on values of ρ_G , μ_G , H , and L_z of model given above equation 35 becomes

$$\Delta P_G = \frac{0.19}{\delta^3} \dot{m}^{1.75}, \quad (36)$$

with ΔP_G in psi, δ in inch, and $\dot{m} = \text{lb/s}$. If $\Delta P = 0.5$ psi and $\delta = 0.064$ in., $\dot{m} = 0.016$ lb/s which yields $V_G = 42$ ft/s and $Re_d = 2410$. This shows that for these conditions the flow is really in the transitional flow regime.

Based on $\delta = 0.068$ in. (which is the gap used in the 1/4 scale model test of Ref. B-1) and $\Delta P = 0.5$ psi $\dot{m} = 0.017$ lb/s which yields $Re_d = 2610$ and a velocity of $V_G = 40$ ft/s. These values of Re_d and V_G are close to the values of 3300 and 28 ft/s, respectively, estimated in Table A-5 of Appendix A for the MHTGR core.

The above shows that the Reynolds number of the model will be closer to that prototype if the gap in the model is not scaled as are the other block dimensions. However, it is not expected to be that important to match Reynolds number of the model to that of the prototype.

It is probably more important that the gap width to be scaled such that

$$\left(\frac{\delta_B}{\delta}\right)_M = \left(\frac{\delta_B}{\delta}\right)_P , \quad (37)$$

This combined with equation 23 yields

$$\left(\frac{\delta}{H}\right)_M = \left(\frac{\delta}{H}\right)_P , \quad (38)$$

or

$$\delta_M = 1/4 \delta_P . \quad (39)$$

While this is a good objective in theory, it is hard to achieve in practice due to tolerance on δ_M . It should be conservative to set $\delta_M \approx \delta_P$ and then increase δ_B over a range to cover both equations 23 and 37. This would imply that the ΔT_M be varied from 14°F required from equation 24 to approximately 56°F (i.e., 4 x 14°F).

Now to size of heater to raise the temperature of gas 100°F as it flows through model:

$$Q = \dot{m} C_p \Delta T , \quad (40)$$

$$\dot{m} = 0.04 \text{ lb/s (per Table 2-1)} ,$$

$$C_p = 0.24 \frac{\text{Btu}}{\text{lbm}^\circ\text{F}} \text{ (for air)} ,$$

$$\Delta T = 100^\circ\text{F} ,$$

$$Q = 3500 \text{ Btu/h} = 1000 \text{ W} .$$

Note to match expected $\dot{m} = 0.16 \text{ lb/s}$ (per page B-15)

$$Q = 1400 \text{ Btu/h} = 400 \text{ W} .$$

Based on 1000 W for 10 elements $\Rightarrow 100 \text{ W/element}$. The internal surface area of model blocks is A_S . Per Fig. 2-2, $A_S = 6 \times L_Z \times H$.

$$\left. \begin{aligned} L_X &= 3.5 - 0.5 \times 2 = 2.5 \text{ in.} \\ L_Z &= L_X/2 \cos 30^\circ = 1.44 \\ H &= 7.8 - 2 \times 3/16 = 7.4 \end{aligned} \right\} A_S = 64 \text{ in.}^2 ,$$

$$q = \text{Heat Flux} = \frac{100}{64} = 1.6 \frac{\text{W}}{\text{in.}^2} = 5.5 \frac{\text{Btu}}{\text{h in.}^2} .$$

If heater is on inside of test block, then there will be a temperature drop (ΔT) across the wall thickness (ΔX)

$$\text{since } q = k \frac{\Delta T}{\Delta X} \quad (41)$$

$$\Delta T = q \frac{\Delta X}{k} \quad (41a)$$

for polycarbonate

$$k = 1.4 \frac{\text{Btu in.}}{\text{h ft}^2 \text{ } ^\circ\text{F}}$$

based on $\Delta X = 0.5 \text{ in.}$ (per Fig. 2-2):

$$\frac{k}{\Delta X} = 2.8 \frac{\text{Btu}}{\text{h ft}^2 \text{ } ^\circ\text{F}} = 0.019 \frac{\text{Btu}}{\text{h in.}^2 \text{ } ^\circ\text{F}}$$

this implies

$$\Delta T = \frac{q}{k/\Delta X} = \frac{5.5}{0.019} = 280^\circ\text{F}$$

since this ΔT is larger than ΔT_M discussed above, it is too large. Therefore, recommend placing heaters on outside of test block. These heaters should be flexible so as not to restruct the thermal distortion of the block.

As an altenrative, the blocks could be made from aluminum. The density of aluminum $\rho_M = 169 \text{ lb/ft}^3$ compared to 75 lb/ft^3 for polycarbonate. Therefore, it would be necessary to reduce wall thickness of the block to maintain the same block weight (see page B-8 through B-9). If wall thickness of an aluminum block is 0.2 in. (instead of 0.5 in. for polycarbonate as shown in Fig. 2-2) then weight (and density) of the aluminum blocks as approximately equal to that of the polycarbonate blocks.

To keep $(\alpha\Delta T)_M$ equal to that proposed for polycarbonate block would require increasing ΔT_M in aluminum blocks. This is because α_M for aluminum is $13 \times 10^{-6} \text{ }^\circ\text{F}^{-1}$ which is only 0.35 as large as it is for polycarbonate. Based on maximum $\Delta T_M = 56^\circ\text{F}$ for the polycarbonate block, $\Delta T_M = 160^\circ\text{F}$ in the aluminum block.

If aluminum was selected the heaters could be placed on the inner wall of the block. This is because for aluminum $k = 100 \text{ Btu/h ft}^\circ\text{F}$. Therefore, $k/\Delta X = 42 \text{ Btu/h in. }^\circ\text{F}$. This implied (based on equation 41a) that $\Delta T \leq 0.2^\circ\text{F}$ which is very small compared to ΔT_M .

A trade-off study is needed to determine which maternal alternative is preferred.

REFERENCES

1. Saeger, J., "Test Report of 1/4 Scale Fluctuations,"
Document