FEB 24 1997

ENGINEERING DATA TRANSMITTAL

Page 1 of 1
1. EDT 620778

2. To: (Receiving Organization) Distribution	3. From: (Originating Organization) Spent Nuclear Fuel Evaluations	4. Related EDT No.:
5. Proj./Prog./Dept./Div.: Spent Nuclear Fuel Project	6. Design Authority/ Design Agent/Cog. Engr.: A. L. Pitner	7. Purchase Order No.:
8. Originator Remarks: Release for Inclusion in SNF Data Book.		9. Equip./Component No.:
		10. System/Bldg./Facility:
11. Receiver Remarks: 11A. Design Baseline Document? ☐ Yes ☒ No		12. Major Assm. Dwg. No.:
		13. Permit/Permit Application No.:
		14. Required Response Date:

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Design- ator	Reason for Trans- mittal	Orig- inator Dispo- sition	Receiv- er Dispo- sition
1	HNF-SD-SNF-CN-015		0	INITIAL ASSESSMENT OF K WEST FUEL CONDITION BASED ON K EAST CLEANLINESS EVALUATION CATEGORIES	N/A	2	1	

16. KEY			
Approval Designator (F)	Reason for Transmittal (G)	Disposition (H) & (I)	
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)	1. Approval 2. Release 3. Information	4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)	1. Approved 2. Approved w/comment 3. Disapproved w/comment 4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN
		Design Authority				2		D. R. Duncan			R3-86
		Design Agent				3		B. J. Makenas	<i>B. J. Makenas</i>	2/13/97	H0-40
1	1	Cog.Eng. A. L. Pitner	<i>A. L. Pitner</i>	2/13/97	H0-40	3		J. R. Frederickson			R3-86
1	1	Cog. Mgr. R. P. Omberg	<i>R. P. Omberg</i>	2/13/97	H0-40	3		A. J. Pajunen			R3-86
		QA				3		T.L. Welsh			T4-40
		Safety				3		Central Files			A3-88
		Env.									

18. <i>A. L. Pitner</i> 2/13/97 A. L. Pitner Signature of EDT Originator	19. _____ Authorized Representative for Receiving Organization	20. <i>R. P. Omberg</i> for 2/13/97 R. P. Omberg Design Authority/ Cognizant Manager	21. DOE APPROVAL (if required) Ctrl. No. ☐ Approved ☐ Approved w/comments ☐ Disapproved w/comments
---	--	---	---

INITIAL ASSESSMENT OF K WEST FUEL CONDITION BASED ON K EAST CLEANLINESS EVALUATION CATEGORIES

A. L. Pitner

Duke Engineering and Services Hanford, Inc., Richland, WA 99352
U.S. Department of Energy Contract DE-AC06-96RL13200

EDT/ECN: 620778

UC: 2070

Org Code: 2T650

Charge Code: LB024

B&R Code: EW7070000

Total Pages: 4

Key Words: K Basin, Fuel Condition, Fuel Damage

Abstract: Recent in-basin examinations of K West fuel were conducted and the defect frequencies were assessed in terms of "minor" and "major" damage. To be consistent with previous damage assessments of K East fuel, the defect categorizations were converted to similar classifications. For the outer elements examined in the K West campaign, 50% are Intact, 26% are Breached, 0% are Defected, and 24% are in the Bad category.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

Release Approval

Date

Approved for Public Release

**INITIAL ASSESSMENT OF K WEST FUEL CONDITION
BASED ON K EAST CLEANLINESS EVALUATION CATEGORIES**

February 1997

A handwritten signature in black ink, appearing to read 'A. L. Pitner', is positioned above the printed name.

A. L. Pitner

Purpose

Recent in-basin full length visual examinations were conducted on selected fuel elements from the K East and K West Basins. Defect occurrences in these examinations were reported in terms of "minor" and "major" damage levels. Interest has been expressed in presenting the defect frequencies for the K West fuel in the same terms as reported in an earlier assessment of K East fuel condition based on the potential need for cleaning; i.e., categories of Intact, Breached, Ruptured, and Bad. This document provides that assessment based on initial observations from the approximately 250 assemblies examined in-basin. Extrapolation to basin-wide distributions awaits statistical evaluation.

Summary of Results and Conclusions

For the outer elements that were visually examined, 50% are Intact, 26% are Breached, and 24% are in the Bad category.

Assumptions

The four fuel condition categories described in the K East Cleanliness report (Reference 1) are as follows:

- Intact - No evidence of cladding breach or deposited sludge.
- Breached - Minor cladding rupture with no reacted fuel or deposited sludge visibly present.
- Defected - Definite evidence of cladding breach with reacted fuel egressing from the element, but there is no gross cladding splitting, element dilation, or fuel voiding.
- Bad - Gross failure is evident with substantial element dilation, cladding splitting, fuel "mushrooming," or fuel voiding.

Recent in-basin examinations were conducted in K East Basin (Reference 2) and K West Basin (Reference 3) where selected fuel elements were extracted from their storage canisters and examined full length. Summary tabulations from these examinations were made for the relative frequencies of minor and major damage. Minor damage consisted of local rupture of the element, usually at the end cap-to-cladding interface, or minor cracking along the side of the element. Major damage included occasions of split or peeled cladding, broken elements, or open cracks along the side of the element. The reported frequencies of minor and major damage for the K West fuel were as follows:

	<u>Inners</u>	<u>Outers</u>
Minor Damage	8%	21%
Major Damage	3%	24%

In comparing this damage breakdown with the K East Cleanliness categories, minor damage would correspond to the "Breached" category. There were no observations of "Defected" elements in K West; i.e., failed elements with

reacted fuel egressing from the failure point. This may be due to the corrosion inhibitor injected into each of the sealed K West canisters. Major damage would correspond to the "Bad" category.

One additional adjustment must be made in converting to the "Breach" category. In the cleanliness evaluation (Reference 1), this category included hard incipient breaches. These are situations where there is some damage to the cladding (usually a ding in the area of the end cap-to-cladding braze), but no sure indication of rupture. From a potential fuel cleaning need, it was considered possible that these areas may eventually open up and result in reacted fuel being exposed. Thus they were included in the "Breached" category. For the K West damage assessment, these incipient breaches were not included as minor damage since they had no immediate impact on canister sludge generation, a primary concern for the K West examinations. The frequency of these incipient breach numbered about 5% for both the inner and outer elements in the K West fuel inspections. To make the categories consistent, then, 5% should be added to the "Minor Damage" values when converting to the "Breached" category.

Sources

- References: (1) A. L. Pitner, *K East Fuel Cleanliness Evaluation*, WHC-SD-SNF-TI-018, Rev. 0, dated January 1996.
- (2) A. L. Pitner, *Visual Examinations of K East Fuel Elements*, HNF-SD-SNF-TI-045, Rev 0, dated February 1997.
- (3) A. L. Pitner, *Visual Examinations of K West Fuel Elements*, HNF-SD-SNF-TI-046, Rev 0, dated February 1997.

Calculation

Based on the above conversion bases, the equivalent K West fuel conditions are as follows:

	<u>Inners</u>	<u>Outers</u>
Intact	84%	50%
Breached	13%	26%
Defected	0%	0%
Bad	3%	24%

These values are based on the direct examination of about 250 selected fuel elements in K West Basin. Extrapolation to basin-wide conditions is currently being statistically evaluated.