APT Blanket System Model Based on Initial Conceptual Design - Integrated 1D TRAC System Model

by

L. L. Hamm

Westinghouse Savannah River Company
Savannah River Site
Aiken, South Carolina 29808

S. Y. Lee

M. A. Shadday

F. G. Smith, III

DOE Contract No. **DE-AC09-96SR18500**

This paper was prepared in connection with work done under the above contract number with the U. S. Department of Energy. By acceptance of this paper, the publisher and/or recipient acknowledges the U. S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper, along with the right to reproduce and to authorize others to reproduce all or part of the copyrighted paper.

APT BLANKET SYSTEM MODEL BASED ON INITIAL CONCEPTUAL DESIGN -

Integrated 1D TRAC System Model

L. Larry Hamm
Si Young Lee
M. Andy Shadday
Frank G. Smith, III

UNCLASSIFIED

DOES NOT CONTAIN
UNCLASSIFIED CONTROLLED
NUCLEAR INFORMATION

ADC &
Reviewing
Official: *Frank G. Smith*
(Name and Title) Mgr.
Date: 7/30/98

Westinghouse Savannah River Company
Savannah River Site
Aiken, SC 29808

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from the Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831; prices available from (615) 576-8401.

Available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, VA 22161.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

WSRC-TR-98-0053

KEYWORDS:

*Accelerator Production of Tritium
Blanket System
Conceptual Design
TRAC Code
System Model
Safety Analysis*

RETENTION - Permanent

APT BLANKET SYSTEM MODEL BASED ON INITIAL CONCEPTUAL DESIGN -

Integrated 1D TRAC System Model

SAVANNAH RIVER TECHNOLOGY CENTER

L. Larry Hamm
Si Young Lee
M. Andy Shadday
Frank G. Smith, III

Publication Date: July 1998

Westinghouse Savannah River Company
Savannah River Site
Aiken, SC 29808

SAVANNAH RIVER SITE

Prepared for the U.S. Department of Energy under Contract No. DE-AC09-96SR18500

DOCUMENT: WSRC-TR-98-0053
TITLE: APT BLANKET SYSTEM MODEL BASED ON INITIAL
CONCEPTUAL DESIGN - Integrated 1D TRAC System
Model

APPROVALS

L. L. Hamm Date: 7-16-98
L. Larry Hamm, Task Leader (EM&S Group/SRTC)

Si Young Lee Date: 7-20-98
Si Young Lee, Co-author (EM&S Group/SRTC)

M. Andy Shadday Date: 7/20/98
M. Andy Shadday, Co-author (EM&S Group/SRTC)

Frank G. Smith, III Date: 7/20/98
Frank G. Smith, III, Co-author (PC&C Group/SRTC)

Cynthia P. Holding-Smith Date: 7/16/98
Cynthia P. Holding-Smith, Manager (EM&S Group/SRTC)

M. A. Ebra Date: 28 Jul 98
Martha A. Ebra, Manager (EDS/SRTC)

M. R. Buckner Date: 7/21/98
Mel R. Buckner, Technical & Regulatory Lead (APT OPO)

The internal technical review function is being performed at the APT project level and is coordinated through LANL.

Table of Contents

1 Introduction	1-1
1.1 Overview of Blanket System	1-1
1.2 Modeling Strategy.....	1-2
1.3 Analysis Requirements of Integrated System Model.....	1-3
1.3.1 System Model Requirements	1-3
1.3.2 System Code Selection	1-4
1.4 System Design Versus Model.....	1-5
1.5 Special Purpose Standalone Models	1-6
1.4 References	1-6
 2 Module Descriptions	 2-1
2.1 Introduction.....	2-1
2.2 Module Layout	2-1
2.3 Lumping Strategy	2-2
2.4 1-D Lumped TRAC Model.....	2-2
2.5 References	2-3
 3 HR and Component Descriptions	 3-1
3.1 Introduction.....	3-1
3.2 Pipe Network Layout.....	3-1
3.3 Heat Exchanger Design.....	3-2
3.4 Pump Head Curve	3-2
3.5 Steady-State Hydraulic Model.....	3-3
3.6 Pipe Size Design Study	3-4
3.7 TRAC Modeling of Tee's.....	3-4
3.8 TRAC Model Steady-State Benchmarking	3-6
3.9 TRAC Model Component Layout	3-6
3.10 References	3-6
 4 Pressurizer Description	 4-1
4.1 Introduction.....	4-1
4.2 Pressurizer Design	4-1
4.3 Pressurizer Drain Down Design Study	4-1
4.4 TRAC Model	4-2
 5 RHR and Component Descriptions	 5-1
5.1 Introduction.....	5-1
5.2 Pipe Network Layout.....	5-1
5.3 Heat Exchanger Design.....	5-2
5.4 Pump Head Curve	5-2
5.5 Steady-State Hydraulic Model.....	5-2
5.6 Pipe size Design Study	5-3
5.7 TRAC Model steady-State Benchmarking	5-4
5.8 TRAC Model Component Layout	5-4
5.9 References	5-4

6 Cavity Vessel/Flood System Descriptions	6-1
6.1 Background.....	6-1
6.2 Cavity Vessel	6-2
6.2.1 Thermal Coupling of Heat Structures.....	6-2
6.2.2 Cavity Vessel Vent Valve	6-2
6.2.3 Potential Break Locations within Cavity Vessel.....	6-2
6.2 Cavity Flood Pool	6-3
6.3 Cavity Flood Valve and Fill Line	6-3
6.4 Simple Vapor-Liquid Equilibrium (VLE) Model.....	6-3
6.5 References.....	6-4
 7 Secondary HR and RHR Component Descriptions	 7-1
7.1 Introduction	7-1
7.2 1-D TRAC Model for HR and RHR Secondary Sides	7-1
7.3 References.....	7-2
 8 Control Procedure Using Trip Signals, Signal Variables, and Control Valves	 8-1
8.1 References.....	8-1
 Appendix A: TRAC Standard Input File for Normal Operation Case	
 Appendix B: TRAC Graphics Input File for Normal Operation Case	
 Appendix C: QKTRAC - A Simple Hydraulic Code for HR Assessment	
 Appendix D: RHRTRC - A Simple Hydraulic Code for RHR Assessment	

List of Figures

1 Introduction

Figure 1-1	Schematic of blanket primary, secondary, and tertiary heat removal systems.	1-7
Figure 1-2	Areal view of Target/Blanket building highlighting blanket system layout.....	1-8
Figure 1-3	Vertical view of Target/Blanket building highlighting blanket system layout.	1-9
Figure 1-4	Essential differences between cruciform- and plate-type blanket module components.	1-10
Figure 1-5	Strategy to establish blanket safety envelope for PSAR purposes.	1-11
Figure 1-6	Solution approach using 1-D TRAC model.	1-12

2 Module Descriptions

Figure 2.2-1	Top cross-sectional facemap of 16 blanket system modules.....	2-14
Figure 2.2-2	Front cross sectional view of the blanket system modules.	2-15
Figure 2.2-3	Decoupler and Row 1 cruciform bin geometries.	2-16
Figure 2.2-4	Row 2 and Row 3 cruciform bin geometries.	2-17
Figure 2.3-1	Lumping strategy for 1-D TRAC blanket system model.	2-18
Figure 2.4-1	1-D TRAC model for Lateral Decoupler / Row 1 Module.....	2-19
Figure 2.4-2	Top cross-sectional facemap of 6 lumped blanket system modules.....	2-20
Figure 2.4-3	6 blanket module layout for safety analysis.	2-21
Figure 2.4-4	Typical axial power distribution for Row 1 module.	2-22
Figure 2.4-5	Typical axial power distribution for Row 2 module.	2-22

3 HR and Component Descriptions

Figure 3.2-1	Schematic of the external portion of the blanket primary heat removal system.	3-8
Figure 3.2-2	Areal view of the of the external portion of the blanket primary heat removal system. Lengths of straight pipe are in parentheses.	3-9
Figure 3.2-3	Side view of the external portion of the blanket primary heat removal system. Lengths of straight pipe are in brackets.	3-10
Figure 3.3-1	Schematic of a blanket primary heat removal system heat exchanger.	3-10
Figure 3.4-1	Pump normalized homologous head curves.	3-11
Figure 3.5-1	Schematic of the fixed header/pipe connection, showing how the header flow areas are treated to calculate an abrupt contraction form loss coefficient.....	3-11
Figure 3.7-1	Schematic of dividing Tee pipe components.....	3-12
Figure 3.7-2	Pressure drop comparison across a symmetric dividing Tee, between a TRAC Tee component and literature loss coefficients.....	3-13
Figure 3.7-3	Pressure drop comparison across a symmetric dividing Tee, between a TRAC plenum component and literature loss coefficients.	3-13
Figure 3.7-4	Pressure drop comparison across a symmetric combining Tee, between a TRAC plenum component and literature loss coefficients.	3-14

Figure 3.7-5	Pressure drop comparison across an asymmetric dividing Tee, between a TRAC plenum component and literature loss coefficients.....	3-14
Figure 3.7-6	Pressure drop comparison across an asymmetric combining Tee, between a TRAC plenum component and literature loss coefficients.....	3-15
Figure 3.9-1	TRAC model component layout of the external portion of the primary HR system.	3-16

4 Pressurizer Description

Figure 4.2-1	Schematic of the pressurization vessel and the surge line.....	4-3
Figure 4.3-1	TRAC component layout of a stand-alone drain down model of the pressurizer and surge line.....	4-4
Figure 4.3-2	Pressurizer fluid pressures for a simulated internal large-break LOCA located just above the top shield.	4-5
Figure 4.3-3	Pressurizer fluid temperatures for a simulated internal large-break LOCA located just above the top shield.	4-5
Figure 4.3-4	Pressurizer liquid mass flowrates for a simulated internal large-break LOCA located just above the top shield.	4-6
Figure 4.3-5	Pressurizer void fractions for a simulated internal large-break LOCA located just above the top shield.	4-6
Figure 4.3-6	Pressurizer surge line fluid pressures for a simulated internal large-break LOCA located just above the top shield.	4-7
Figure 4.3-7	Pressurizer surge line liquid mass flowrates for a simulated internal large-break LOCA located just above the top shield.....	4-7
Figure 4.3-8	Pressurizer surge line void fractions for a simulated internal large-break LOCA located just above the top shield.	4-8

5 RHR and Component Descriptions

Figure 5.2-1	Schematic of the blanket residual heat removal system.....	5-5
Figure 5.2-2	Areal and side views of the residual heat removal system.	5-6
Figure 5.3-1	Schematic of the blanket residual heat removal system heat exchanger system.....	5-7
Figure 5.5-1	Schematic of the break location in the primary heat removal system that was used to determine the fixed inlet header pressure boundary condition for the residual heat removal system simple hydraulic model, (RHRTTC).....	5-7
Figure 5.8-1	TRAC model component layout of the blanket residual heat removal system.....	5-8

6 Cavity Vessel/Flood System Descriptions

Figure 6.2-1	TRAC component layout for the cavity vessel and blanket module heat structures.	6-5
Figure 6.2-2	TRAC component layout for the cavity vessel and cavity flood system.	6-6

7 Secondary HR and RHR Component Descriptions

Figure 7.2-1	Typical coolant temperature profiles for primary and secondary heat exchanger sides.....	7-3
Figure 7.2-2	1-D TRAC model for the secondary side of primary HR heat exchanger.	7-4

Figure 7.2-3	Heat exchanger fluid and heat structure nodalization for 1-D TRAC model under counter-current flow pass.....	7-5
--------------	--	-----

8 Control Procedure Using Trip Signals, Signal Variables, and Control Valves

Figure 8-1	Control procedure for blanket system component hardware actions.....	8-4
Figure 8-2	S-shape forcing function curve used in the present analysis.	8-5

List of Tables

1 Introduction

2 Module Descriptions

Table 2.2-1	Module types and geometric dimensions for 16 blanket modules.	2-4
Table 2.2-2	Typical area fractions for various types of blanket module bins.	2-5
Table 2.2-3	Deposited powers, liquid flowrates and module coolant pipe sizes for 16 blanket modules.....	2-5
Table 2.2-4	Decay power fractions of full power for lead cruciforms of various locations.....	2-6
Table 2.4-1	6 lumped blanket module system model used for the present PSAR analysis	2-7
Table 2.4-2	Blanket System Component Descriptions in TRAC Model.	2-8
Table 2.4-2	Blanket System Component Descriptions in TRAC Model (continued).....	2-9
Table 2.4-2	Blanket System Component Descriptions in TRAC Model (continued).....	2-10
Table 2.4-2	Blanket System Component Descriptions in TRAC Model (continued).....	2-11
Table 2.4-2	Blanket System Component Descriptions in TRAC Model (continued).....	2-12
Table 2.4-3	Steady State Conditions.....	2-12
Table 2.4-4	6 Lumped Blanket Modules from 16 Full Blanket Module System.....	2-13

3 HR and Component Descriptions

Table 3.6-1	Estimated required and available NPSH for HR piping.....	3-7
Table 3.8-1	Comparison between TRAC and simple hydraulic model pressure profile for HR piping loop.....	3-7

4 Pressurizer Description

5 RHR and Component Descriptions

Table 5.6-1	Estimated required and available NPSH for RHR piping.	4-4
Table 5.7-1	Comparison between TRAC and simple hydraulic model pressure profile for RHR piping loop.	4-4

6 Cavity Vessel/Flood System Descriptions

7 Secondary HR and RHR Component Descriptions

8 Control Procedure Using Trip Signals, Signal Variables, and Control Valves

Table 8-1	Control signal variables used in the APT blanket system model.	8-2
Table 8-2	Trip signal variables used in the APT blanket system model.....	8-2
Table 8-3	Design basis accident scenarios for the APT blanket system safety analysis.	8-3

1 Introduction

This report documents the approaches taken in establishing a 1-dimensional integrated blanket system model using the TRAC code, developed by Los Alamos National Laboratory. Descriptions of all major components are provided in this report. Where appropriate, discussions include the processes used and justifications made in making key design decisions. In certain circumstances supporting analyses were performed to support or verify the modeling approach employed. Due to the lack of key design information on many of the blanket system components within the Conceptual Design Report [1], many of the components presented and modeled within this report represent the author's best judgment. However, when design specifications were made available (either within the CDR [1] or through correspondence with LANL personnel), they were incorporated into the system model. Reference [8] discusses the blanket system safety analysis methodology pertaining to the efforts documented within this report.

1.1 Overview of Blanket System

Figure 1.1-1 provides a schematic highlighting the various cooling systems associated with the overall blanket system. The blanket system consists of one 100% capacity primary heat removal (HR) coolant loop with light water as the working fluid. Two 100% primary residual heat removal (RHR) coolant loops are also available (upon actuation) with light water as their working fluid as well.

The HR and RHR coolant loops are connected to common fixed inlet/outlet headers that reside within a cavity vessel. System pressure is controlled using a large pressurizer vessel that is directly connected to the inlet fixed header through a 10 inch schedule 40 surge line. Multiple (16) heat generating lead/aluminum module units are also connected to these fixed headers and reside within the cavity vessel proper. The cavity vessel represents one level of confinement, while a second level of confinement is established within the Target/Blanket facility using a ventilation system exhausting through HEPA filters and the stacks.

As an ultimate heat sink for certain classes of accidents, a cavity flood system has been provided. A cavity flood pool (upon actuation) dumps by gravity sufficient light water into the cavity vessel space to cover the blanket components and fixed headers. Secondary and tertiary cooling systems exist for the HR, RHR, and cavity vessel as shown in Fig. 1.1-1.

Based on available design guidance and Target/Blanket building geometric constraints, blanket component and piping layouts for the HR, RHR, and pressurizer primary coolant systems were established. Figures 1.1-2 and 1.1-3 provide areal and vertical views of the blanket systems, respectively. In Fig. 1.1-2 note that only the lower two HR primary coolant pumps are in the system model (the upper third pump is in a standby mode and is valved out-of-service during normal operation (NO) and under accident conditions). Figures 1.1-2 and 1.1-3 are approximately to scale with respect to component sizes and locations.

At the bin level within a given blanket module, the original design was of a cruciform-type concept as shown in the upper portion of Fig. 1.1-4. This design consisted of discrete heat structures made of aluminum clad lead cruciforms placed within a rectangular aluminum structure defined as a local bin. Several bins ganged together

constitute an individual blanket module. Within each bin, neighboring cruciform components were spaced apart using discontinuous longitudinal ribs. Within these bins was a continuous coolant channel with many sub-channels of varying widths due to fabrication tolerances. This cruciform-type design was based on preliminary NO design calculations only. Later a preliminary safety assessment for the cruciform design was performed [2,3]. The NO calculations in Ref. [2] confirmed the earlier design analyses; however, design concerns emerged for various accident scenarios considered [3]. Reference [3] prompted a need for a new design improvement study. Recognizing (1) that beam shutdown occurs very rapidly, (2) that a significant reduction in decay power occurs, and (3) these lead components are massive and contain large thermal inertia, the possibility existed to redesign the blanket modules at the bin level. The design improvement study centered around:

- taking advantage of the low decay heat conditions (i.e., use heat conduction as a major means for heat removal from the bins);
- eliminating the difficult analysis requirements associated with complex sub-channeling due to varying rib geometries.

The expectations for the outcome of this design improvement were more robust blanket modules with much simpler safety analysis requirements, both experimentally and numerically. These expectations were met based on a plate-type design as shown in the lower portion of Fig. 1.1-4. The main features of the plate-type design is to have a continuous heat structure at the bin level with discrete one-dimensional flow channels dispersed throughout the heat structure. Safety analyses (both NO and various bounding accident scenarios) were performed to better quantify the thermal/hydraulic benefits over the earlier cruciform design [4].

1.2 Modeling Strategy

The thermal/hydraulic modeling aspects for the Target/Blanket Systems have been broken into several basic modeling components. Due to the natural separation (i.e., separated flow loops) that occurs between the Target System, the Blanket System, and the Cavity System, these systems are in most cases modeled separately. However, under certain accident conditions (e.g., flooded cavity conditions) these systems can interact materially and thermally. In these situations these system models may have one or two way communication between each other through appropriate boundary conditions. Such de-coupling of interacting systems necessitates the need for a limited amount of iterations to be performed or some set of bounding boundary conditions be applied.

The detailed modeling of every module and its individual sub-components within the blanket system is unnecessary and perhaps not currently achievable. Due to the complexity of flow paths and geometric shapes of heat structures, the Blanket Primary Coolant System (BPCS) has been subdivided into two basic analysis models:

- First, an integrated 1-D system model was chosen that contains all major components, systems, and heat structures deemed necessary, and making use of varying and appropriate degrees of lumping wherever possible. The integrated system model is based on the TRAC code [5]. The TRAC code was modified to incorporate graphics output file generation [7].

TRAC BLANKET SYSTEM MODEL

- Second, the integrated 1-D system model will provide local boundary conditions to a more detailed multi-dimensional bin model at the component level within a given "hot" module. The detailed bin model is based on a modified version of the FLOWTRAN-TF code [6].

As indicated in Fig. 1.2-1, the overall safety strategy taken relies on a separated approach (i.e., a system model supplying boundary conditions to a more detailed bin model). The two major advantages of this type of approach are: (1) the ability to investigate certain aspects of the facility in much greater detail and (2) the ability to perform a significantly larger number of sensitivity analyses on individual components. The disadvantages are: (1) the strategy used and adequacy of such lumping techniques must be formulated and demonstrated and (2) a limited number of iterative analyses between model components must be performed. With regard to the TRAC system model, Fig. 1.2-2 outlines the solution strategy approach taken.

1.3 Analysis Requirements of Integrated System Model

1.3.1 System Model Requirements

With the integrated blanket system model, overall system behavior for a variety of different thermal/hydraulic (T/H) states can be considered. Briefly these states include: (1) a flow regime comprised of single phase subcooled flowing liquid, (2) a slightly-to-highly subcooled nucleate boiling regime, (3) a dominantly bulk boiling regime, and (4) a post-CHF transition boiling regime. A broad range of accident scenarios can be addressed with the system model. The following is a partial list of key accident scenarios associated with the blanket system that may need to be considered for analysis in establishing an overall safety envelope:

- Internal and external to the cavity vessel large break (LB) loss-of-coolant accidents (LOCA's) within a primary HR loop, RHR loop, or pressurizer surge line. A single guillotine double-ended pipe break (DEGB) at varying locations may be considered.
- Internal and external to the cavity vessel small break (SB) LOCA's within the primary loops. A single break with varying size and location may be considered.
- Loss-of-flow accident (LOFA) for the primary coolant flow. The loss of a single and both primary pumps may be considered.
- Loss of secondary side heat sink accident (LOHS). The loss of secondary coolant flow of a single and both second sides may be considered.
- Loss of Off-Site power and Station Blackout initiating events may be considered.
- Local flow blockages within the primary coolant loops or blanket modules. Varying degrees of blockage and location may be considered (at the module inlet level and among the discrete flow channels within module bin).
- A local power density insertion accident resulting from beam expander magnet failure (a beam focusing accident).

In order to accommodate the various key features of the above potential list of accident scenarios, the blanket system model must include both branches of the HR coolant loops associated with its two online pumps, as well as one of the 100% capacity residual heat removal (RHR) systems. To maintain reasonable computing run times and overall memory requirements, individual discrete flow channels within a module bin, as well as

individual bins that make up a complete module unit, it may be necessary not to modeled them separately. Instead, the blanket system model may required a limited number of lumped modules that also contain a limited number of composite (and lumped) heat structures. The level of adequacy in the lumped modules and composite heat structures employed in a blanket system model can be assessed by: (1) comparison to separate analytical models, (2) comparison to the more detailed bin model, or (3) comparison to standalone sub-models of the system. The blanket system model provides the key boundary conditions necessary for performing the more detailed thermal analyses at the bin level.

1.3.2 System Code Selection

Selection of a system code capable of accommodating the various stated requirements/objectives above was necessary. At the outset it was recognized that to be able to handle the potentially diverse thermal/hydraulic (T/H) conditions that may be present during a given accident sequence, a flexible two-fluid T/H based algorithm is necessary. Some of the more basic features and options needed are:

- A two-fluid formulation whose constitutive packages can reasonably handle the needs of a APT blanket modules and their expected T/H conditions.
- Capable of performing transient single & two-phase flow within 1-D system components and piping branches (i.e., models the axial motion of liquid and vapor phases).
- A lumping strategy to reduce discrete flow channels and heat structures down to a single effective one dimensional rod and channel.
- Lumping together of multiple flowpaths within modules and potentially among modules.
- For natural circulation conditions secondary light water cooling systems coupled to their primary sides through heat exchangers. Ability to reduce secondary side modeling down by handling them as BCs within a heat exchanger component.
- A pressurizer explicitly connected to the system model.
- Handle inlet and outlet headers are modeled as common manifolds.
- Tee components to model pipe branching.
- Centrifugal pump models for the HR and RHR loops based on appropriate pump head curves for single and two-phase flow conditions. Pump coastdown characteristics are included to handle flywheel inertia.
- For internal cavity break locations a special cavity model coupled to the HR and RHR systems.

The currently available series of TRAC codes at LANL meet most of the requirements/objectives stated above. During model development some level of development/upgrade to the TRAC code may be required with regard to its constitutive packages. Various other available candidates (e.g. RELAP5, RETRAN, etc.) are capable of handling the transient, multi-phase flow, and conjugate heat transfer behavior expected; however, the TRAC code was selected for the system model for consistency since target and cavity flood systems are already TRAC based models.

1.4 System Design Versus Model

Due to the initial lack of firm designs and continued design iterations on many of the major blanket components, several of the components described in this report do not correspond to the information provided in the Conceptual Design Report [1]. As such, it is anticipated that many of the systems and components described in the following sections will be significantly altered when the next set of blanket safety analyses are performed. The following two major design modifications will most likely be incorporated in future safety analyses:

- Lumped cruciform-type module components are being used in the current system model. Based on an earlier assessment analysis [2,3] and then a follow up design improvement study [4], plate-type module components were chosen in early June, 1997. A complete set of plate-type component designs originally due in August, 1997, are still unavailable as of this writing.
- Piping layout of the HR and RHR primary loops are to be modified to better handle large break LOCA's internal to the cavity. The current layout contains inverted P-traps (see Fig. 1.1-3) that result in flashing and collection of steam in their high points.

The current methodology consists of two (varying in complexity) system models that provide local boundary conditions to a more detailed bin model at the component level within a given "hot" module. The methodology for the overall system model(s) is to separate accident analyses into two separate categories:

- Design basis accident scenarios (e.g., normal operation, anticipated operational occurrences, loss-of-flow accidents, and internal/external large break loss-of-coolant accidents).
- Accident scenarios of a bounding nature (e.g., the internally dry module with a flooded cavity space, beyond design basis accidents, residual risk events).

Each category places different computational demands on the analysis tools and available computer resources. For category 1 the plan is to use the lumped six module TRAC system model where justification for the additional module lumping is provided using our most detailed 16 module model under similar steady-state conditions. For category 2 we will most likely have to abandon TRAC at some point in the scenario and make bounding assumptions or separate evaluation modeling calculations.

The current one-dimensional blanket system models (both 16 and 6 module cases) have been developed using version 5.4.28a of the TRAC-P code [5]. The 1-D detailed blanket system model consists of 16 unique blanket modules based on the existing cruciform-type design components (the necessary design specifications required to develop a plate-type set of modules is currently not available but should be forthcoming in late February). During the assessment period for the detailed blanket system model, it was recognized that lumping of various similar modules could be performed without adversely affecting the results from transient accident analyses. It was also recognized that: (1) the helium components could be deleted; and (2) a reduction in heat exchanger nodalization was acceptable. A lumping strategy was developed based on module similarity, deposited power levels, and locations that resulted in a total of six separate lumped modules and reduced computational effort requirements. The six lumped modules are, respectively: the first-row lateral modules; the second-row lateral modules; the decoupler/row 1 downstream module; the row 1/row 2 downstream module; the row

2/row 2 downstream module; and the remaining low-power modules (that consists of the upstream module, the four bottom modules, and the two top modules). For providing blanket system safety analysis in support of the initial PSAR, this report will focus primarily on the six module model. Only limited assessments are provided comparing the detailed 16 module model to the lumped six module model.

1.5 Special Purpose Standalone Models

Special purpose thermal/hydraulic models have also been developed to assist in verification of various components of the integrated system model. For example, separate steady-state hydraulic models of the primary heat removal and residual heat removal systems were developed (i.e., the piping and components from the fixed inlet header to the fixed outlet header). These models were used to assess the single phase steady-state hydraulic behavior of the appropriate sections of the TRAC system model when compared to standard textbook hydraulic models. Also, a standalone model of the cavity flood systems based on a simple thermodynamic vapor-liquid-equilibrium (VLE) model was created. This VLE model provides insights into the timing of key events during the flooding phase.

1.4 References

1. "APT Conceptual Design Report," Los Alamos National Laboratory report, LA-UR-97-1329 (April 1997).
2. L. L. Hamm and M. A. Shadday, "APT Blanket Safety Analysis: Preliminary Hot Subchannel Model Results," Westinghouse Savannah River Company, Section memorandum number SRT-EMS-97-0024, April 9, 1997.
3. L. L. Hamm and M. A. Shadday, "APT Blanket Safety Analysis: Preliminary Internally Dry Flooded Cavity Results," Westinghouse Savannah River Company, Section memorandum number SRT-EMS-97-0030, May 2, 1997.
4. L. L. Hamm and M. A. Shadday, "APT Blanket Safety Analysis: Preliminary Thermal Conduction Analysis of the B&W Plate-Type Blanket Assembly (U)," Westinghouse Savannah River Company, Section memorandum SRT-EMS-97-0039, June 2, 1997.
5. Safety Code Development Group, "TRAC-PF1/MOD2: An Advanced Best Estimate Computer Program for Pressurized Water Reactor Thermal-Hydraulic Analysis," Los Alamos National Laboratory report LA-12031-M, Vol. 1 (NUREG/CR-5673), (July 21, 1993).
6. L. L. Hamm, S. Y. Lee, M. A. Shadday, and F. G. Smith, "FLOWTRAN-TF Code Modifications made for APT Blanket Safety Analyses," Westinghouse Savannah River Company, WSRC-TR-98-0056 (July 1998).
7. L. L. Hamm, S. Y. Lee, M. A. Shadday, and F. G. Smith, III, "TRAC Code Modifications made for APT Blanket Safety Analysis," Westinghouse Savannah River Company, WSRC-TR-0054 (July 1998).
8. L. L. Hamm, S. Y. Lee, M. A. Shadday, and F. G. Smith, III, "APT Blanket Safety Analysis Methodology," Westinghouse Savannah River Company, WSRC-TR-0052 (May 1998).

Figure 1.1-1 Schematic of blanket primary, secondary, and tertiary heat removal systems.

Figure 1.1-2 Areal view of Target/Blanket building highlighting blanket system layout.

Figure 1.1-3 Vertical view of Target/Blanket building highlighting blanket system layout.

Figure 1.1-4 Essential differences between cruciform- and plate-type blanket module components.

Figure 1.2-1 Strategy to establish blanket safety envelope for PSAR purposes.

TRAC BLANKET SYSTEM MODEL

Figure 1.2-2 Solution approach using 1-D TRAC model.

2 Module Descriptions

2.1 Introduction

The blanket system is designed as a modular-type assembly to allow for replacement and maintenance of short-lived components. Tritium will be produced with the source neutrons generated as a result of spallation from primary high energy protons striking tungsten targets. The main function of the blanket system is to enhance neutron production and to catch high energy particles scattered out of the tungsten neutron source. From the release of neutrons and the interaction of the high energy particles within the blanket materials, approximately 57 MW of thermal energy is deposited within the blanket region under normal operating conditions. This corresponds to about 48% of the total thermal energy deposited in the APT target/blanket system [1], and is an important input parameter used in the thermal-hydraulic design and safety analysis.

2.2 Module Layout

The blanket system consists of 18 different blanket modules, surrounding the central target system. For each of the front and back lateral modules located next to the target region, two lateral modules are merged into a single pipe through a T-junction and connected to fixed headers, so 16 separate thermal-hydraulic loops are connected to two fixed headers for all the 18 separate blanket modules [2]. Figure 2.2-1 shows the entire blanket face map with 16 individual modules consisting of: six lateral modules, three downstream modules, one upstream module, two top modules and four bottom modules. Each blanket module is subdivided into two different regions, either a decoupler and lead cruciform row or two different cruciform rows, depending on the type of blanket module. One region is for downflow, and the other is for upflow. There is no flow communication between regions within a blanket module. Each of the two regions contains a number of rectangular bins, and each bin has a number of aluminum tubes and blanket rows. Figure 2.2-2 shows that each blanket module has two flow zones and that the decoupler is located adjacent to the target region, oriented vertically. The lateral decoupler and row 1 blanket are 2.8 m high and extend to just below the bottom of the tungsten target ladder. The other vertical blanket modules are all 3.5 m high. Table 2.2-1 lists blanket types, geometric dimensions, and number of bins for each module. Figure 2.2-3 shows bin cruciform geometries for the decoupler / Row 1 module. The decoupler surrounds the target ladder region and consists of three or four layers of tightly packed aluminum tubes containing helium. Light water coolant flows downward outside the tubes under moderate pressure. The helium in this region mainly absorbs low energy neutrons that scatter from the lead cruciform rows toward the target region, thus maximizing neutron utilization and minimizing neutron absorption in the target tungsten. Four or five layers of closely-packed lead cruciforms surround the decoupler region. The present blanket system has five different cruciform designs in Row 1 through Row 5, from the central target region to the blanket system boundary. Moving outward radially from the target ladder, the lead power density drops rapidly. To accommodate this variation, the amount of lead, He, aluminum, and coolant water is tailored to the deposited power density to optimize the tritium production and thermal-hydraulic safety. Table 2.2-2 shows typical material compositions for the three blanket rows considered in this analysis. The power densities for each blanket module require minimum liquid flow rates for each module, to satisfy the thermal-hydraulic design criteria. Table 2.2-3 shows deposited powers, liquid flowrates, and connection pipe sizes for all of the 16 blanket modules. Figure 2.2-4 shows geometric dimensions for Row 2 and Row 3 bins.

TRAC BLANKET SYSTEM MODEL

There are two separate light water heat removal systems to remove the deposited heat from the blanket modules. One is for high and medium power blanket modules (Row 1, Row 2, and Row 3), and the other is for low power blanket modules (Row 4 and Row 5, The reflector, and shielding regions). The Row 4 and Row 5 modules are not included in the present blanket safety analysis since they have a separate coolant system and they are very low power modules. Figure 2.2-2 shows the vertical layout of the blanket modules. Table 2.2-4 presents transient decay power fractions of full power for the various types of lead cruciforms used in the modular blanket system.

2.3 Lumping Strategy

Within a module blanket bin, there are coolant passages between the lead cruciforms and bin boundaries, between neighboring cruciforms, and between the cruciforms and He tubes. These flow passages provide adequate cooling for the blanket module while minimizing the pressure drop through the blanket assembly. A single flow channel around a lead cruciform is formed by four neighboring aluminum tubes, as shown in Fig. 2.2-3 and Fig. 2.2-4. There is interaction between the adjacent flow channels due to cross-flow and turbulent flow mixing within a module bin. Before a local hot channel in a module can be analyzed, the average flow conditions of the module assembly must be known, to provide local boundary conditions for a detailed hot subchannel model. The module subchannels are lumped into a single annular flow channel that is part of a comprehensive heat removal system model. This flow channel is hydraulically similar to a single closed subchannel, since there is a repetitive subchannel pattern within a bin. The thermal and hydraulic lumped approach evaluates the enthalpy rise in the flow channel by using the subchannel analysis. The annular channel area is determined by preserving area fractions for each material of the equivalent subchannel, as provided in Table 2.2-3. Figure 2.3-1 shows a one-dimensional thermal-hydraulic conjugate model for blanket module 1, used with version 5.4.28a of the TRAC-PF1/MOD2 code.

2.4 1-D Lumped TRAC Model

The one-dimensional detailed blanket system model consists of 16 unique blanket modules based on the existing cruciform-type design (the necessary design specifications required to develop a plate-type set of modules are currently not available, but should be forthcoming in late February). Each module is separately connected to the two fixed coolant headers, as shown in Fig. 2.4-1. Based on the present CDR information, there are 16 pipe connections between the plenum of each module and the coolant fixed headers. The model contains about 400 system components, including the primary coolant loop and the residual heat removal (RHR) systems, along with component control signals for transient loss-of-coolant accident (LOCA) simulations. The detailed geometric dimensions and deposited power densities for each blanket module are based on existing design information. Table 2.2-2 shows deposited thermal power, coolant flowrate, and connection pipe size for each of the 16 modules.

During the assessment period of the detailed blanket system model, it was recognized that lumping of similar modules could be performed without adversely affecting the results of transient accident analyses. It was also recognized that the helium components could be deleted and a reduction in the heat exchanger nodalization is acceptable. A lumping strategy was developed based on module similarity and deposited power levels that resulted in a total of six separate lumped modules and reduced computational effort requirements. The six lumped modules are, respectively: the first-row lateral modules; the second-row lateral modules; the decoupler / Row 1 downstream module; the Row 1 / Row 2 downstream module; the Row 2 / Row 2 downstream module; and the remaining low-power modules, which consist of the

TRAC BLANKET SYSTEM MODEL

upstream module, the four bottom modules, and the two top modules. Figure 2.4-2 shows the cross-sectional face map for the 6 module blanket system. Table 2.4-1 summarizes the lumped module description, thermal deposited power, and connection pipe sizes of each of the 6 blanket modules, as modeled in the present one-dimensional lumped approach. Different numbers of mesh cells are used for the 1st lateral and 2nd lateral modules since they have different modular heights, as shown in Table 2.2-1. For example, 5 fluid cells were used for the 1st lateral module, and 7 fluid cells were used for 2nd lateral module. 6 radial cells and 5 or 7 axial node cells in the heater structure region of each subchannel were used to compute metal temperatures. Table 2.4-2 lists the component ID number, number of cells, and a brief model description for each of the blanket system components, including the external primary coolant loop system and the residual heat removal system, which were included in the one-dimensional 6 module system model. Figure 2.4-3 shows all the module components and connection pipes within the cavity vessel, as modeled in the present 6 blanket module model. Circles in Fig. 2.4-2 represent PLENUM components, and rectangles stand for PIPE or HEAT STRUCTURE components. PLENUM components 80, 81, 83, 85, 87, and 89 are potential pipe break points for internal LOCA simulations. Figure 2.4-4 and Fig. 2.4-5 show typical power profiles, in the flow direction, for Row 1 and Row 2.

Table 2.4-2 summarizes the model results of key thermal-hydraulic parameters under normal operation conditions. Benchmarking was performed at steady-state nominal conditions to verify the results of the lumped six module model with the earlier results obtained from the 16 module model. Table 2.4-3 shows the benchmarking results.

2.5 References

1. "APT Conceptual Design Report," Los Alamos National Laboratory report, LA-UR-97-1329 (April 1997).
2. R. Kapernick, "Thermal-Hydraulic Design of APT Blanket", Presented at Thermal-Hydraulic Group Meeting, Los Alamos National Laboratory, May 14, 1997.

TRAC BLANKET SYSTEM MODEL

Table 2.2-1 Module types and geometric dimensions for 16 blanket modules.

16 Module Number (Location)	Module Types: downflow / upflow	Hydraulic Diameter* downflow / upflow	No. of Bins downflow / upflow	Module Length (m)
Module 1 (Front 1 st Lateral)	Decoupler / Row 1	8.6117e-03 / 5.0627e-03	8 / 8	2.758
Module 2 (Front 2 nd Lateral)	Row 3 / Row 2	3.1084e-03 / 3.1838e-03	11 / 11	3.500
Module 3 (Front 2 nd Lateral)	Row 3 / Row 2	3.1084e-03 / 3.1838e-03	11 / 11	3.500
Module 4 (Back 1 st Lateral)	Decoupler / Row 1	8.6117e-03 / 5.0627e-03	9 / 9	2.758
Module 5 (Back 2 nd Lateral)	Row 3 / Row 2	3.1084e-03 / 3.1838e-03	11 / 11	3.500
Module 6 (Back 2 nd Lateral)	Row 3 / Row 2	3.1084e-03 / 3.1838e-03	11 / 11	3.500
Module 7 (1 st Downstream)	Decoupler / Row 1	9.9388e-03 / 5.7015e-03	4 / 4	2.758
Module 8 (2 nd Downstream)	Row 2 / Row 1	3.1198e-03 / 5.1537e-03	8 / 8	3.500
Module 9 (3 rd Downstream)	Row 2 / Row 2	3.1519e-03 / 3.1519e-03	12 / 12	3.500
Module 10 (Blanket Upstream)	Decoupler / Row 2	1.0594e-02 / 2.8707e-03	horizontal flow 22 / 50	1.020 / 1.077
Module 11 (Lower Front Upper)	Decoupler / Row 2	9.5264e-03 / 3.6243e-03	horizontal flow 5 / 5	2.114
Module 12 (Lower Front Lower)	Row 2 / Row 2	3.6243e-03 / 3.6243e-03	horizontal flow 5 / 5	2.114
Module 13 (Lower Back Upper)	Decoupler / Row 2	9.5264e-03 / 3.6243e-03	horizontal flow 5 / 5	0.248
Module 14 (Lower Back Lower)	Row 2 / Row 2	3.6243e-03 / 3.6243e-03	horizontal flow 5 / 5	0.248
Module 15 (Upper Front)	Row 2 / Row 2	3.1132e-03 / 3.1132e-03	7 / 7	0.521
Module 16 (Upper Lower)	Row 2 / Row 2	3.1132e-03 / 3.1132e-03	7 / 7	0.521
Total (bins)	—	—	141 / 169	

*unit - [m]

Table 2.2-2 Typical area fractions for various types of blanket module bins.

Row	Helium	Lead	Aluminum	H2O
Row 1	10.7 %	42.7 %	22.4 %	24.2 %
Row 2	10.0 %	59.7 %	18.0 %	12.3 %
Row 3	9.5 %	65.0 %	18.0 %	7.5 %

Table 2.2-3 Deposited powers, liquid flowrates and module coolant pipe sizes for 16 blanket modules.

16 Full Blanket Modules (Location)	Power downflow / upflow	Liquid Flowrate (kg / sec)	Module Connection Pipe Size (inch)
Module 1 (Front 1 st Lateral)	3.869 MW / 7.420 MW	256	7.500
Module 2 (Front 2 nd Lateral)	0.765 MW / 1.915 MW	88	4.750
Module 3 (Front 2 nd Lateral)	0.765 MW / 1.915 MW	88	4.750
Module 4 (Back 1 st Lateral)	4.353 MW / 8.348 MW	288	8.000
Module 5 (Back 2 nd Lateral)	0.765 MW / 1.915 MW	88	4.750
Module 6 (Back 2 nd Lateral)	0.765 MW / 1.915 MW	88	4.750
Module 7 (1 st Downstream)	0.744 MW / 2.812 MW	56	3.750
Module 8 (2 nd Downstream)	3.924 MW / 5.412 MW	95	5.375
Module 9 (3 rd Downstream)	1.355 MW / 1.811 MW	112	6.000
Module 10 (Blanket Upstream)	0.580 MW / 1.240 MW	154	6.000
Module 11 (Lower Front Upper)	0.225 MW / 0.667 MW	50	3.750
Module 12 (Lower Front Lower)	0.185 MW / 0.050 MW	40	3.500
Module 13 (Lower Back Upper)	0.268 MW / 0.803 MW	50	3.875
Module 14 (Lower Back Lower)	0.222 MW / 0.060 MW	40	3.625
Module 15 (Upper Front)	0.0 MW / 0.706 MW	38	2.750
Module 16 (Upper Back)	0.0 MW / 0.706 MW	38	2.750
Total Flowrate	18.785 MW / 37.695 MW	1569	

TRAC BLANKET SYSTEM MODEL

Table 2.2-4 Decay power fractions of full power for lead cruciforms of various locations.

Time	Lateral Row 1	Lateral Row 2	Lateral Row 3	Downstream Row 1
0 sec	1.385e-02	2.079e-02	2.801e-02	9.736e-03
1 sec	1.209e-02	1.747e-02	2.370e-02	8.718e-03
2sec	1.142e-02	1.614e-02	2.197e-02	8.335e-03
5 sec	1.086e-02	1.511e-02	2.061e-02	8.000e-03
10 sec	1.059e-02	1.477e-02	2.014e-02	7.836e-03
20 sec	1.024e-02	1.432e-02	1.947e-02	7.620e-03
1 min.	9.237e-03	1.293e-02	1.730e-02	7.035e-03
2 min.	8.125e-03	1.135e-02	1.482e-02	6.399e-03
5 min.	6.215e-03	8.651e-03	1.059e-02	5.280e-03
10 min.	5.058e-03	7.042e-03	8.183e-03	4.520e-03
20 min.	4.454e-03	6.255e-03	7.174e-03	3.998e-03
1 hr.	3.849e-03	5.490e-03	6.370e-03	3.346e-03
2 hr.	3.457e-03	4.950e-03	5.783e-03	2.938e-03
5 hr.	2.831e-03	4.062e-03	4.784e-03	2.363e-03
10 hr.	2.267e-03	3.271e-03	3.872e-03	1.898e-03
1 day	1.472e-03	2.169e-03	2.573e-03	1.284e-03
2 days	9.137e-04	1.377e-03	1.618e-03	8.591e-04
5 days	4.449e-04	6.317e-04	6.990e-04	4.776e-04
10 days	2.677e-04	3.457e-04	3.595e-04	3.075e-04
20 days	1.664e-04	2.046e-04	2.088e-04	1.963e-04
30 days	1.239e-04	1.488e-04	1.516e-04	1.475e-04
60 days	7.690e-05	8.841e-05	9.016e-05	9.167e-05

TRAC BLANKET SYSTEM MODEL

Table 2.4-1 6 lumped blanket module system model used for the present PSAR analysis

6 Lumped Modules	Prototypic 16 Full Blanket Modules	Thermal Deposited Power Downflow / Upflow / Total Power	Pipe Size (inch)
Module 1	Front 1 st Lateral Dec. / Row 1 Module Back 1 st Lateral Dec. / Row 1 Module	8.222 MW / 15.768 MW / 23.990 MW	7.500
Module 2	Front 2 nd Lateral Row 2 / Row 3 Modules Back 2 nd Lateral Row 2 / Row 3 Modules	3.060 MW / 7.660 MW / 10.720 MW	4.750
Module 3	1 st Downstream Dec. / Row 1 Module	0.744 MW / 2.812 MW / 3.556 MW	3.750
Module 4	2 nd Downstream Row 1 / Row 2 Module	3.924 MW / 5.412 MW / 9.336 MW	5.375
Module 5	3 rd Downstream Row 2 / Row 2 Module	1.355 MW / 1.811 MW / 3.167 MW	6.000
Module 6	Low Power Modules Blanket Upstream Dec. / Row 2 Module Lower Front Dec. / Row 2 Module Lower Front Row 2 / Row 2 Module Lower Back Dec. / Row 2 Module Lower Back Row 2 / Row 2 Module Upper Front Row 2 / Row 2 Module Upper Back Row 2 / Row 2 Module	(Horizontal Flow) 0 MW / 5.712 MW / 5.712 MW	3.875
Total Deposited Power		17.305 MW / 39.175 MW / 56.480 MW	

TRAC BLANKET SYSTEM MODEL

Table 2.4-2 Blanket System Component Descriptions in TRAC Model.

System	Component Type	Comp #	No of Cells	Descriptions
HR	Fixed Header (FH)	380	1	coolant Supply FH
		340	1	coolant Return FH
	Pressurizer (Pzr)	760	1	Pzr surge line 1 connected to Supply FH 380
		761	2	Pzr surge line 2
		762	1	Pzr surge line 3
		763	1	Pzr surge line 4
		764	1	Pzr surge line 5
		765	13	Pzr surge line 6
		766	9	primary Pzr
	Hot Leg Loop	20	1	pipe connected to Return FH340
		21	1	plenum for potential break loc.
		22	7	pipe connection to external loop
		23	1	pipe connect. for potential break
		24	13	connection pipe
		25	1	connection pipe
		26	2	pipe connected to two pumps
		27	1	plenum for two pump connection
		28	2	pump#1 suction pipe
		29	7	pump#2 suction pipe
		30	2	pump located at cell face 2
		31	2	pump located at cell face 2
		32	3	check valve located at pump#1 discharge
		33	3	check valve located at pump#2 discharge
		34	1	pump outlet plenum
		36	1	connect. pipe between pump and pipe
		37	1	HX connect. pipe for potential break
		38	1	pipe connect. to two HX's inlet plenum
	HX	40	1	plenum
		48	3	HX #1 inlet pipe
		50	4	HX #1 1 st pass
		52	3	HX #1 middle header
		54	4	HX #1 2 nd pass
		49	3	HX #2 inlet pipe
		51	4	HX #2 1 st pass
		53	3	HX #2 middle header
		55	4	HX #2 2 nd pass
		710	1	HX #1 secondary side fill
		711	4	HX #1 2 nd pass secondary side
		712	3	HX #1 middle header secondary side
		713	4	HX #1 1 st pass secondary side
		714	1	HX #1 secondary side break BC
		730	1	HX #2 secondary side fill BC
		731	4	HX #2 2 nd pass secondary side
		732	3	HX #2 middle header secondary side
		733	4	HX #2 1 st pass secondary side
		734	1	HX #2 secondary side break BC

TRAC BLANKET SYSTEM MODEL

Table 2.4-2 Blanket System Component Descriptions in TRAC Model (continued).

System	Component Type	Comp #	No of Cells	Descriptions
HR	Cold Leg Loop	56	3	HX #1 outlet pipe
		57	6	HX #2 outlet pipe
		60	3	HX outlet plenum merged after two HX's
		62	1	cold leg pipe
		63	1	cold leg pipe
		64	13	cold leg pipe located outside cavity wall
		65	1	pipe for cold leg pipe break
		66	1	horizontal cold leg pipe penetration
		67	1	plenum for internal break on HR loop
		854	2	HR isolation valve for internal break
		69	1	plenum for internal LOCA simulation
		68	5	pipe connect. to FH 340 inside cavity
				valve located bet. cavity vessel and HR
Cavity Vessel	Cold Leg Loop	850	2	valve located bet. cavity vessel and HR
		852	2	valve located bet. cavity vessel and HR
			1	plenum for cavity vessel connection
		828	3	cavity vent valve
		802	1	break component for cavity vent pressure BC
		823	11	pipe for cavity lower section simulation
		824	1	plenum for cavity connection
		840	2	valve to connect cavity line to Module 1
Cavity Pool	Cavity Flood Line	825	4	pipe for cavity middle section simulation
		820	13	pipe for cavity pool connection to cavity vessel
		821	2	cavity flood line valve
		822	1	flood line pipe inside cavity vessel
	Cavity Flood Pool	801	1	break component for cavity pool BC
		810	10	pipe for top cavity pool section
		811	1	plenum for middle cavity pool section
		812	7	pipe for lower cavity pool section
RHR	RHR Loop	813	1	plenum for cavity pool bottom
		621	1	pipe located to return FH
		623	10	pipe located inside the cavity vessel
		624	1	pipe located outside the cavity vessel
		625	18	pipe bet. RHR pump and pipe comp. #624
		630	2	RHR pump located at face 2
		640	3	check valve located at pump discharge
		652	4	HX tubes
		660	16	pipe at the cold leg side
		661	1	pipe located before cavity vessel
		662	8	cold leg pipe inside cavity vessel
		663	1	cold leg pipe connected to supply FH
		672	1	fill for HX secondary side BC
		671	4	HX secondary shell side
		673	1	break comp. for HX secondary side BC

TRAC BLANKET SYSTEM MODEL

Table 2.4-2 Blanket System Component Descriptions in TRAC Model (continued).

System	Component Type	Comp #	No of Cells	Descriptions
Module	Module 1 Flow	454	7	pipe connected to supply FH
		80	1	plenum for potential internal break simulation at Module 1
		375	5	pipe connection bet. Supply FH and Module 1 upper plenum
		370	1	upper plenum for Module 1 downcomer
		360	5	Module 1 downflow region
		350	1	middle plenum bet. Module 1 downflow and upflow regions
		300	5	Module 1 upflow region
		330	1	upper plenum for module 1 upflow region
		335	5	connection pipe after Module 1 upper plenum
		429	4	pipe connected to return FH
	Module 2 Flow	173	7	pipe connected to supply FH
		81	1	plenum for potential internal break simulation at Module 2
		82	3	pipe connection
		172	1	upper plenum for Module 2 downcomer
		158	6	Module 2 downflow region
		147	1	middle plenum bet. Module 2 downflow and upflow regions
		102	6	Module 2 upflow region
		133	1	upper plenum for module 2 upflow region
		136	7	pipe connected to return FH
		415	7	pipe connected to supply FH
	Module 3 Flow	85	1	plenum for potential internal break simulation at Module 3
		86	3	pipe connection
		479	1	upper plenum for Module 3 downcomer
		478	5	Module 3 downflow region
		418	1	middle plenum bet. Module 3 downflow and upflow regions
		409	5	Module 3 upflow region
		423	1	upper plenum for module 3 upflow region
		417	7	pipe connected to return FH
	Module 4 Flow	485	7	pipe connected to supply FH
		87	1	plenum for potential internal break simulation at Module 4
		88	3	pipe connection
		489	1	upper plenum for Module 4 downcomer
		480	6	Module 4 downflow region
		419	1	middle plenum bet. Module 4 downflow and upflow regions
		412	6	Module 4 upflow region
		483	1	upper plenum for module 4 upflow region

TRAC BLANKET SYSTEM MODEL

Table 2.4-2 Blanket System Component Descriptions in TRAC Model (continued).

System	Component Type	Comp #	No of Cells	Descriptions
		484	7	pipe connected to return FH
Module	Module 5 Flow	513	7	pipe connected to supply FH
		89	1	plenum for potential internal break simulation at Module 5
		90	3	pipe connection
		510	1	upper plenum for Module 5 downcomer
		507	6	Module 5 downflow region
		503	1	middle plenum bet. Module 4 downflow and upflow regions
		500	6	Module 5 upflow region
		508	1	upper plenum for Module 5 upflow region
		511	7	pipe connected to return FH
	Module 6 Flow	541	7	pipe connected to supply FH
		83	1	plenum for potential internal break simulation at Module 6
		84	1	pipe connection
		538	1	upper plenum for Module 6 decoupler
		535	5	Module 6 downcomer region
		531	1	middle plenum bet. Module 6 decoupler and main heated regions
		528	5	Module 6 main heated region
		536	1	upper plenum for module 6 main heated region
		539	12	pipe connected to return FH
	Module 1 Heater Structure	901	5	Al tube structure in Row 1
		951	5	Lead zone with Al cladding in Row 1
		984	5	Al tube structure in decoupler
	Module 2 Heater Structure	905	6	Al tube structure in Row 2
		955	6	Lead zone with Al cladding in Row 2
		916	6	Al tube structure in Row 3
		966	6	Lead zone with Al cladding in Row 3
	Module 3 Heater Structure	911	5	Al tube structure in Row 1
		961	5	Lead zone with Al cladding in Row 1
		988	5	Al tube structure in decoupler
	Module 4 Heater Structure	912	6	Al tube structure in Row 1
		962	6	Lead zone with Al cladding in Row 1
		931	6	Al tube structure in Row 2
		978	6	Lead zone with Al cladding in Row 2
	Module 5 Heater Structure	913	6	Al tube structure in Row 2
		963	6	Lead zone with Al cladding in Row 2

TRAC BLANKET SYSTEM MODEL

Table 2.4-2 Blanket System Component Descriptions in TRAC Model (continued).

System	Component Type	Comp #	No of Cells	Descriptions
		932	6	Al tube structure in Row 2
		979	6	Lead zone with Al cladding in Row 2
	Module 6 Heater Structure	915	5	Al tube structure in Row 2
		965	5	Lead zone with Al cladding in Row 2

Table 2.4-3 Steady State Conditions.

Parameter	Units	Calculated Values
Total power deposited in blanket modules	MW	56.5
Total flow rate	kg/sec gpm	1569 25252
Pressure in cold-leg fixed header	Mpa psia	0.7325 106.24
Pressure in hot-leg fixed header	Mpa psia	0.4563 66.180
Pressurizer (cell #1) pressure	Mpa psia	0.7311 106.03
Pump #1 suction pressure	Mpa psia	0.2751 39.90
Pump #1 discharge pressure	Mpa psia	1.0356 150.20
Pump #2 suction pressure	Mpa psia	0.2958 42.91
Pump #2 discharge pressure	Mpa psia	1.0409 150.97
Temperature in cold-leg fixed header	C F	49.43 121.0
Temperature in hot-leg fixed header	C F	58.03 136.5
Max. fluid temperature of the hottest module	C F	71.95 161.5

Table 2.4-4 6 Lumped Blanket Modules from 16 Full Blanket Module System.

6 Modules	16 Full Blanket Modules	Mass Flow Rate		$(\Delta T)_{MOD}$	
		CDR (kg/sec)	Model (kg/sec)	CDR (C)	Model (C)
Module 1	2 First-Row Lateral Modules	544	544	10.5	10.4
Module 2	4 Second-Row Lateral Modules	352	344	7.27	7.48
Module 3	First Downstream Module (Dec. / Row 1)	56	55	15.2	15.7
Module 4	Second Downstream Module (Row 1 / Row 2)	95	99	23.4	22.6
Module 5	Third Downstream Module (Row 2 / Row 2)	112	117	6.75	6.51
Module 6	Upstream Module 4 Bottom Modules 2 Top Modules	410	410	3.32	3.34
Overall System		1569	1569	8.60	8.59

$(\Delta P)_{Fixed\ Header} = 40.15$ psid for 6 blanket module system model

Figure 2.2-1 Top cross-sectional facemap of 16 blanket system modules.

Figure 2.2-2 Front cross sectional view of the blanket system modules.

Figure 2.2-3 Decoupler and Row 1 cruciform bin geometries.

TRAC BLANKET SYSTEM MODEL

Figure 2.2-4 Row 2 and Row 3 cruciform bin geometries.

Figure 2.3-1 Lumping strategy for 1-D TRAC blanket system model.

TRAC BLANKET SYSTEM MODEL

Lateral Dec. / Row 1 Module

1-D TRAC Lumped Model for Lateral Dec. / Row 1 Module

Figure 2.4-1 1-D TRAC model for Lateral Decoupler / Row 1 Module.

Figure 2.4-2 Top cross-sectional facemap of 6 lumped blanket system modules.

Figure 2.4-4 Typical axial power distribution for Row 1 module.

Figure 2.4-5 Typical axial power distribution for Row 2 module.

3 HR and Component Descriptions

3.1 Introduction

The purpose of the primary heat removal system is to dissipate energy that is generated within the lead blanket during normal operation. The external part of the system is the piping and components of the system, between the fixed headers, that are external to the target/blanket cavity vessel. This section of the system includes the pumps and heat exchangers. This section of the document describes the layout, which was used to develop the TRAC system model, of the external part of the primary heat removal system and supporting analyses that were instrumental in the development of the TRAC model.

3.2 Pipe Network Layout

Figure 3.2-1 is a schematic of the external portion of the primary heat removal system. It shows the elbows and valves in the pipe network, the pumps and heat exchangers, and the locations where the pipe diameter is reduced or enlarged. The flow proceeds from the fixed outlet header in the cavity vessel, through the pumps and heat exchangers, and back to the fixed inlet header. There are cutout valves on the suction and discharge sides of each pump and on the discharge side of each heat exchanger. There are also check valves on the discharge sides of each pump. The pipe system consists of 20 inch schedule 40 pipe for sections of the system through which the full flow travels, and 16 inch schedule 40 pipe for sections where the flow is split between the two pumps and heat exchangers. The primary heat removal system is designed to have three parallel pumps, two of which will be operating at any point in time. The non-operating pump is not included in the TRAC model, and is therefore not shown in this layout.

Figure 3.2-2 is an areal view of the primary heat removal system. This drawing is to scale, and it shows the walls that form the room in which the pumps and heat exchangers will be placed. The lengths of straight pipe are shown in brackets.

Figure 3.2-3 is a side view of the external portion of the blanket primary heat removal system. It shows the elevations of the horizontal sections of pipe. The datum for the elevations is the top of the shield in the target/blanket cavity. This is the reference elevation for the TRAC model. The four fixed headers are respectively from the lowest; the blanket outlet header, the blanket inlet header, the tungsten target outlet header, and the target inlet header. The blanket primary heat removal piping, from both the inlet and outlet headers, runs radially inward from fixed headers, goes vertically upward to the elevation 2 m. above the centerline of the top fixed header, and then radially and horizontally out through the wall of the target/blanket cavity vessel. The elevation at which the pipes exit the cavity vessel is necessary for the pipes to clear components internal to the vessel. Once outside the cavity vessel, the pipes drop to the elevation 0.75 m. above the floor on which the pumps and heat exchangers are supported. Lengths of straight pipe are also shown in brackets in this figure.

3.3 Heat Exchanger Design

Figure 3.3-1 is a schematic of a heat exchanger. It is a shell-and-tube heat exchanger, two shell and two tube passes. The blanket heat removal flow is on the tube side. The heat exchanger parameters are based on the parameters in the APT Conceptual Design Report (CDR)[1], appropriately scaled for a flowrate of 784.5 kg/s instead of the CDR value of 477 kg/s for each heat exchanger. The dimensions and the thermal performance of a single tube are assumed to

TRAC BLANKET SYSTEM MODEL

remain unchanged. Therefore the number of tubes in the updated design is proportional to the ratio of new to old mass flowrates. The total number of tubes is increased from 8,400 to 13,816, 6,908 in each pass. The ratio of the total tube flow area to the tube sheet area is assumed to also remain constant, therefore the shell diameter increases from 2.24 m. in the CDR design to 2.87 m. in the updated design. This preserves the heat transfer area to surrounding volume ratio on the secondary side, and justifies the assumption that the tube thermal performance remains invariant. The headers at either end of the heat exchanger are hemispherical. There is a horizontal baffle that separates the inlet and outlet headers. The assumed elevation drop, in the lumped TRAC model, between an average first pass tube and an average second pass tube is half of the shell diameter.

3.4 Pump Head Curve

The pumps head curve is based on the Loss of Flow Test Facility (LOFT) homologous head curve, normalized with scaled values of the pump speed, flowrate, and total dynamic head of a SRS production reactor Bingham pump [2]. The head curve is normalized with Bingham pump characteristics because reliable required net positive suction head (NPSH) data exists for these pumps, and the normalized homologous LOFT and Bingham head curves are similar. The normalized homologous head curve has the form of equation (3.4-1). The total dynamic head (H), the pump flowrate (Q), and the pump speed (O) are normalized with the Bingham pump characteristics at half capacity and at the best efficiency point (BEP). The reference state is:

pump speed	500 rpm
volumetric flowrate	12.5 kgpm (0.788635 m ³ /s)
total dynamic head	131.2 ft (40.0 m)

These are the starred symbols in equation (3.4.1).

$$\frac{H/H^*}{(\Omega/\Omega^*)^2} = f\left(\frac{Q/Q^*}{\Omega/\Omega^*}\right) \quad (3.4.1)$$

Figure 3.4-1 is the first quadrant of the LOFT pump head curve, along with the Bingham pump head curve. The head curves are in homologous form, and they are normalized with the reference state parameters. The LOFT head curve is defined by three points, and TRAC uses linear interpolation between them.

3.5 Steady-State Hydraulic Model

A simple steady-state hydraulic model of the external portion of the blanket primary heat removal system was developed to determine the necessary pipe sizes, and to compare TRAC model results with a model that includes single-phase literature based form losses. The model QKTRAC applies the mechanical energy equation to five sections of the network sequentially: from downstream of the heat exchanger discharge combining Tee to the fixed inlet header, across the parallel heat exchangers, the single pipe between the pumps and heat exchangers, across the parallel pumps, and from the fixed outlet header to upstream of the pump suction dividing Tee. The independent variables in this model are: the total volumetric flowrate, the pump speeds, and the inlet header pressure, and the model calculates pressures at the outlet header and desired intermediate locations. Since the portion of the loop between the fixed headers and inside of the cavity that contains the modules is not modeled, the system demand curve is indeterminate. At a system flowrate of 1569 kg/s, the pressure drop between the inlet and outlet headers is assumed to be approximately 40 psid. The model input pump speed is

TRAC BLANKET SYSTEM MODEL

varied until the header-to-header pressure drop is calculated to be this value. The model QKTRAC is a fortran code that is run on a SGI work station. The code is very fast, so the user can update the pump speeds in a iterative manner between runs until the header pressure drop converges to the desired value. A code listing and also input and output files, are included in Appendix C.

The entrance form loss for the flow from the fixed outlet header to the 20 in. pipe is treated as an abrupt contraction. Figure 3.5-1 is a schematic of the header/pipe connection, showing the flow areas, and it also shows that the contraction upstream flow area is assumed to be twice the header flow area. Equation 3.5.1 is the expression for the form loss coefficient for an abrupt contraction [3]. The pressure drop is based on the higher velocity. The exit form loss for the flow from the pipe into the fixed inlet header is treated as an abrupt expansion, and the equivalent header flow area is treated in the same manner as for the inlet header. Equation 3.5.2 is the expression for the form loss coefficient, and it is again based on the higher velocity.

$$K = 0.42 \left[1 - \left(\frac{D_2}{D_1} \right)^2 \right] \quad (3.5.1)$$

$$K = \left(1 - \frac{A_1}{A_2} \right)^2 \quad (3.5.2)$$

These expressions are used to calculate the expansion and contraction form loss coefficients for the pipe diameter transitions and the flows into and out of the heat exchanger headers. The loss coefficients are:

- Contraction from fixed outlet header into 20" pipe K = 0.243
- Expansion from 20" pipe to fixed inlet header K = 0.335
- Contraction from 20" to 16" pipe K = 0.153
- Expansion from 16" to 20" pipe K = 0.133
- Expansion from 16" pipe into heat exchanger inlet header K = 0.931
- Contraction from header into heat exchanger tubes K = 0.347
- Expansion heat exchanger tubes into header K = 0.681
- Contraction from heat exchanger header into 16" pipe K = 0.405

The 90 degree elbow form loss coefficients are calculated from the fully-developed turbulent frictional pressure drop in an equivalent length of straight pipe [4]. The elbow form loss coefficients are:

$$K_{20"} = 0.156$$

$$K_{16"} = 0.159$$

The form loss coefficients for fully open gate valves are 0.047 and 0.5 for fully open check valves [5].

These form loss coefficients are used in QKTRAC and, where appropriate, in the primary heat removal system TRAC model.

3.6 Pipe Size Design Study

QKTRAC was used to size the pipes in the flow network, with the criteria that the pumps not cavitate under normal operating conditions. Equation 3.6.1 is the expression for the required

TRAC BLANKET SYSTEM MODEL

NPSH [6] in meters. This expression has been scaled to the half speed reference state listed in sub-section 3.4.

$$NPSH_R = 2.256 \left(\frac{\Omega}{\Omega^*} \right)^2 + 5.334 \left(\frac{Q}{Q^*} \right)^2 \quad (3.6.1)$$

Four different combinations of main pipe diameters and smaller diameters of the secondary pipes associated with the individual pumps and heat exchangers were considered, and the results of the model are presented Table 3.6-1. All diameters are in inches and are nominal values for schedule 40 steel pipes. Shown are the available and required NPSH values for pumps one and two respectively. Cavitation is predicted if the available NPSH is less than the required. Main pipes with diameters less than eighteen inches are unsuitable. Eighteen inch main and fourteen inch secondary pipes meet the criteria. The design authority at Los Alamos National Laboratory suggested twenty inch main and sixteen inch secondary piping, to ensure plenty of margin. Pipe is relatively inexpensive, and a larger pipe diameter could lower pump operating costs.

3.7 TRAC Modeling of Tee's

As part of the verification process of the TRAC model of the external portion of the primary heat removal system, results of a stand-alone TRAC model were compared with the results of the simple hydraulic model. In the course of this study, it was ascertained that the TRAC TEE component significantly over-predicted the irreversible pressure drop across the legs of the Tee. Figure 3.7-1 shows schematics of symmetric and asymmetric Tee's for both dividing and combining flows, along with branch nomenclature for the form loss coefficient correlations. These are the four types of Tee's that occur in the network. Equation 3.7.1 is the correlation for the form loss in a dividing symmetric Tee [5]. The pressure drop is based on the incoming velocity.

$$K_{12} = 0.59 + \left[1.18 - 1.84 \left(\frac{r}{D} \right)^{1/2} + 1.16 \left(\frac{r}{D} \right) \left(\frac{U_2}{U_1} \right) \right] - \left[0.68 - 1.04 \left(\frac{r}{D} \right)^{1/2} + 1.16 \left(\frac{r}{D} \right) \left(\frac{U_2}{U_1} \right) \right]^2 \quad (3.7.1)$$

Figure 3.7-2 shows the pressure drops across a symmetric dividing Tee, as functions of the inlet mass flowrate, predicted by TRAC and from literature loss coefficients, equation 3.7.1. A horizontal Tee with 16 inch schedule 40 pipe and an equal flow split between the two discharge legs is assumed. The Tee junction is assumed to not be rounded, $r/D=0$. TRAC predicts pressure drops that are approximately four times those from literature correlations. To correct this discrepancy, Tee's in the TRAC model were replaced by PLENUM components, and literature based form loss coefficients are used. Equation 3.7.2 is the correlation for the form loss in a combining symmetric Tee [5]. The pressure drops are based on the outgoing velocity.

$$K_{13} = 1.19 - 1.16 \left(\frac{r}{D} \right)^{1/2} + 0.46 \left(\frac{r}{D} \right) - 1.73 \left(1 - \frac{r}{D} \right) \frac{U_2}{U_3} + \left(1.34 - 1.69 \frac{r}{D} \right) \left(\frac{U_2}{U_3} \right)^2 \quad (3.7.2)$$

Equations 3.7.3 and 3.7.4 are correlations for form loss coefficients for an asymmetric combining Tee [5]. The pressure drops are again based on the outgoing velocity.

$$K_{13} = 0.045 + \left[1.38 - 1.94 \left(\frac{r}{D} \right)^{1/2} + 1.34 \frac{r}{D} \right] \frac{U_2}{U_3} - \left[0.90 - 0.95 \left(\frac{r}{D} \right)^{1/2} + 1.23 \frac{r}{D} \right] \left(\frac{U_2}{U_3} \right)^2 \quad (3.7.3)$$

TRAC BLANKET SYSTEM MODEL

$$K_{23} = 1.09 - 0.80\left(\frac{r}{D}\right)^{1/2} - \left[0.53 + 1.27\left(\frac{r}{D}\right)^{1/2} - 1.86\frac{r}{D}\right]\frac{U_1}{U_3} - \left[1.48 - 2.28\left(\frac{r}{D}\right)^{1/2} + 1.80\frac{r}{D}\right]\left(\frac{U_1}{U_3}\right)^2 \quad (3.7.4)$$

Equations 3.7.5 and 3.7.6 are correlations for form loss coefficients for an asymmetric dividing Tee [5]. The pressure drops are based on the incoming velocity.

$$K_{12} = 0.65\left(\frac{U_3}{U_1} - 0.22\right)^2 - 0.03 \quad (3.7.5)$$

$$K_{13} = 0.99 - 0.23\left(\frac{r}{D}\right)^{1/2} - \left[0.82 + 0.29\left(\frac{r}{D}\right)^{1/2} + 0.30\frac{r}{D}\right]\frac{U_3}{U_1} + \left[1.02 - 0.64\left(\frac{r}{D}\right)^{1/2} + 0.76\frac{r}{D}\right]\left(\frac{U_3}{U_1}\right)^2 \quad (3.7.6)$$

Figs. 3.7-3 through 3.7-6 show comparisons between TRAC with PLENUM components in place of TEE components and literature based pressure drops for the four Tee configurations. The kinetic energy terms are included in the literature based pressure drops, and these account for the large differences in pressure drops between combining and dividing Tee's. There is actually a pressure recovery in the straight pipe section of an asymmetric dividing Tee. The irreversible pressure drops though are always positive. In all cases, the pressure drops calculated with the literature correlations are less than the TRAC results because friction is neglected in the literature based results. The agreement is otherwise excellent. In all cases, equal branch flowrates were assumed, and the pipe junctions are assumed to be square, $r/D=0$. TRAC requires that the loss coefficients be constants, whereas the correlations are functions of the flow splits. Ideally the flows through the parallel pumps and heat exchangers should be equal, and would be if the branch piping layouts were symmetric. They are not, but the branch flowrates are close to equal, and it is a reasonable assumption in calculating the Tee loss coefficients to assume that they are, because Tee pressure drops are small in comparison with the overall pressure drops across the pump and heat exchanger branches.

3.8 TRAC Model Steady-State Benchmarking

Once the TEE components were replaced in the TRAC model, the agreement between the TRAC model and the simple hydraulic model was excellent, Table 3.8-1. The pressures are high because the TRAC model was run at a high system pressure, during the development process, to ensure that flashing did not occur. This comparison was made with a TRAC model of an earlier primary heat removal system pipe layout. The requirement that the pipes exit the cavity vessel two meters above the highest fixed header had not been promulgated when this comparison was made. Minor changes in pipe lengths and elevations should not change the close agreement between TRAC and the hydraulic model QKTRAC. This comparison will be repeated for future pipe network design layouts, as time permits.

3.9 TRAC Model Component Layout

Figure 3.9-1 shows the TRAC component layout and junction numbers for the external portion of the blanket primary heat removal system. Also shown is the component layout of the blanket primary pressurizer. A brief description of and the number of cells in each component of the entire TRAC model is listed in Table 2.4-2. Further details such as cell lengths, flow areas, hydraulic diameters, and form loss coefficients can be found in the TRAC model input deck (see Appendix A).

TRAC BLANKET SYSTEM MODEL

The components modeling the lumped first and second pass heat exchanger tubes are PIPE components 50 and 54 respectively for heat exchanger number one and 51 and 55 for heat exchanger number two. HEAT STRUCTURES and secondary side flow components for the heat exchangers are also shown in Fig. 3.9-1, the 700 series components. Components 30 and 31 are the two PUMP components, and VALVE components 32 and 33 model the check valves on the discharge side of each pump. PLENUM components 380 and 340 are respectively the fixed inlet and outlet headers. PIPE component 37 is the location for pump discharge large break LOCA's, and component 65 is the location for a large break LOCA external to the cavity vessel and close to the inlet header. The internal to the cavity large break LOCA is modeled by the group of components that includes CONTROL VALVE components 850, 852, and 854. Component 826 is a PIPE component in the cavity vessel. To simulate a break, VALVE 854 is shut, and VALVES 850 and 852 open in concert.

3.10 References

1. "APT Conceptual Design Report," Los Alamos National Laboratory report, LA-UR-97-1329 (April 1997).
2. L. L. Hamm and D. A. Crowley, "1985 L-Reactor Test Results Used to Determine Pressure-Flow Relationships," E. I. Du Pont de Nemours & Co., DPST-88-814, December 1988.
3. P. M. Gerhart and R. J. Gross, Fundamentals of Fluid Mechanics, Addison Wesley Publishing Company, 1985.
4. R. W. Fox and A. T. McDonald, Introduction to Fluid Mechanics, John Wiley & Sons, Inc., 1973.
5. R. D. Blevins, Applied Fluid Dynamics Handbook, Van Nostrand Reinhold Company, 1984.
6. L. L. Hamm, "Reanalysis of Bingham Pump Cavitation Characteristics for PLK Reactors," E. I. Du Pont de Nemours & Co., DPST-84-624, August 1984.

Table 3.6-1 Estimated required and available NPSH for HR piping.

Pipe Diameters (main-secondary)	NPSH Available (m) (pumps ½)	NPSH Required (m) (pumps ½)
14 - 10 in.	-16.4/-10.8	7.7/8.4
16 - 12	-1.5/2.9	7.3/7.9
18 - 14	14.0/16.9	7.0/7.4
20 - 16	23.9/26.0	6.8/7.1

Table 3.8-1 Comparison between TRAC and simple hydraulic model pressure profile for HR piping loop.

Location	RHRTRC pressure (psia)	TRAC pressure (psia)
Fixed Outlet Header	163.15	165.3
Pump Suction	144.93	145.4
Pump Discharge	226.19	225.6
Heat Exchanger Inlet	224.50	224.6
Heat Exchanger Outlet	209.86	209.5
Fixed Inlet Header	203.20	203.20

Figure 3.2-1 Schematic of the external portion of the blanket primary heat removal system.

Figure 3.2-2 Areal view of the of the external portion of the blanket primary heat removal system. Lengths of straight pipe are in parentheses.

Figure 3.2-3 Side view of the external portion of the blanket primary heat removal system. Lengths of straight pipe are in brackets.

Figure 3.3-1 Schematic of a blanket primary heat removal system heat exchanger.

Figure 3.4-1 Pump normalized homologous head curves.

Figure 3.5-1 Schematic of the fixed header/pipe connection, showing how the header flow areas are treated to calculate an abrupt contraction form loss coefficient.

Figure 3.7-1 Schematic of dividing Tee pipe components.

Figure 3.7-2 Pressure drop comparison across a symmetric dividing Tee, between a TRAC Tee component and literature loss coefficients.

Figure 3.7-3 Pressure drop comparison across a symmetric dividing Tee, between a TRAC plenum component and literature loss coefficients.

TRAC BLANKET SYSTEM MODEL

Figure 3.7-4 Pressure drop comparison across a symmetric combining Tee, between a TRAC plenum component and literature loss coefficients.

Figure 3.7-5 Pressure drop comparison across an asymmetric dividing Tee, between a TRAC plenum component and literature loss coefficients.

Figure 3.7-6 Pressure drop comparison across an asymmetric combining Tee, between a TRAC plenum component and literature loss coefficients.

TRAC BLANKET SYSTEM MODEL

Figure 3.9-1 TRAC model component layout of the external portion of the primary HR system.

(This Page Intentionally Left Blank)

4 Pressurizer Description

4.1 Introduction

The blanket heat removal system is pressurized to approximately 100 psia to prevent cavitation from occurring anywhere in the system during normal operation. The pressurizer also serves as a reservoir for replacing lost coolant inventory in the event of an accident. The pressurizer is a large vessel, partially filled with water, that is connected by pipe to the fixed inlet header. There is a helium filled gas space above the water, and the gas space pressure determines the inlet header pressure. During normal operation, the gas space pressure is 97.6 psia. The pressurizer will prevent a rapid system depressurization during a LOCA.

4.2 Pressurizer Design

Figure 4.2-1 is a schematic of the pressurizer vessel and the surge line that connects it to the fixed inlet header. The vessel is 8.54 m. high, and it has a diameter of 3.658 m. Water fills the vessel to a height of 6.723 m. The pressurizer is connected to the inlet header by a 10" schedule 40 steel pipe, with a length of 31.698 m. Figure 4.2-1 is to scale vertically, but not horizontally.

The pressurizer was designed to not completely drain during a LOCA, thereby not entraining gas in the heat removal system flow. Two additional design constraints are that the water in the vessel not flash, and cavitation not occur in the surge line during the drain down transient.

4.3 Pressurizer Drain Down Design Study

A stand-alone TRAC model of the pressurizer and surge line was developed and exercised parametrically, to determine the initial level of water in the vessel, the surge line diameter, and the elevation of the vessel. Figure 4.3-1 is a TRAC component layout of this model. The accident scenario chosen for this design study was a large-break LOCA, internal to the cavity, just above the top shield. The break location is assumed to be 1.532 m. below the header. The cavity vessel has a vacuum breaker that will be actuated in the event of an internal break, consequently the cavity will be at atmospheric pressure several minutes after the occurrence of an internal LOCA, and the inlet header pressure will be 12.53 psia, based on the hydrostatic difference. This is the break component pressure boundary condition for the stand-alone TRAC model.

A final liquid depth of 0.625 m. was chosen as the target for this design study. This results in a void fraction of 0.5 in the vessel component cell adjacent to the bottom cell. Since TRAC cannot handle multiple non-condensable constituents, the gas space was assumed to be filled with air. The initial liquid temperature was assumed to be 40 C.

Figures 4.3-2 through 4.3-8 show results of the stand-alone TRAC model. Figure 4.3-2 shows the fluid pressures in the pressurizer vessel component cells. The final pressure in the gas space, after completion of the expansion, is 12.39 psia. Figure 4.3-3 shows the fluid temperatures in the pressurizer. The liquid remains at the initial temperature of 40 C. As the cells sequentially empty, the cell gas temperatures drops to zero, due to the expansion. TRAC will not allow the gas temperature to drop below zero C. Figure

TRAC BLANKET SYSTEM MODEL

4.3-4 shows the pressurizer liquid mass flowrates. Down flow in the pressurizer is negative. As the cells sequentially empty, the mass flowrates jump to zero. Fig. 4.3-5 shows the pressurizer void fractions. The bottom cell remains at zero, and the adjacent cell finishes the transient with a void fraction of 0.5. The rest of the cells finish at one. Figure 4.3-6 shows surge line pressures. The differences in final pressures are due to elevation differences in the line. Figure 4.3-7 shows the surge line mass flowrates. It takes approximately 1000 seconds or 17 minutes for the pressurizer to drain down. Fig. 4.3-8 shows voids in the surge line. There is a slight amount of voiding early on in the transient. The pipe size was increased from 6 to 10 inches to reduce this voiding. The pressurizer vessel was lowered approximately 4 m. to prevent flashing in the vessel during the expansion process.

4.4 TRAC Model

The TRAC model shown in Fig. 4.3-1 is the same as the pressurizer model in the large TRAC system model, with the exceptions that components 201 and 220 are removed and PIPE component 760 is connected to the fixed inlet header, component 380. A brief description of the number of cells in each component for the entire TRAC model is listed in Table 2.4-2. Further details such as; cell lengths, flow areas, hydraulic diameters, and form loss coefficients can be found in the TRAC model input deck, Appendix A. PIPE components 760 and 762, in Fig. 4.3-1, are potential locations for internal to the cavity breaks, and PIPE component 764 is the potential location for an external break.

Figure 4.2-1 Schematic of the pressurization vessel and the surge line.

TRAC BLANKET SYSTEM MODEL

Figure 4.3-1 TRAC component layout of a stand-alone drain down model of the pressurizer and surge line.

Figure 4.3-2 Pressurizer fluid pressures for a simulated internal large-break LOCA located just above the top shield.

Figure 4.3-3 Pressurizer fluid temperatures for a simulated internal large-break LOCA located just above the top shield.

Figure 4.3-4 Pressurizer liquid mass flowrates for a simulated internal large-break LOCA located just above the top shield.

Figure 4.3-5 Pressurizer void fractions for a simulated internal large-break LOCA located just above the top shield.

Figure 4.3-6 Pressurizer surge line fluid pressures for a simulated internal large-break LOCA located just above the top shield.

Figure 4.3-7 Pressurizer surge line liquid mass flowrates for a simulated internal large-break LOCA located just above the top shield.

Figure 4.3-8 Pressurizer surge line void fractions for a simulated internal large-break LOCA located just above the top shield.

(This Page Intentionally Left Blank)

5 RHR and Component Descriptions

5.1 Introduction

The purpose of the blanket residual heat removal system is to dissipate energy that is generated within lead blanket components, following an accident that interrupts the primary heat removal system flow. It is designed to remove decay heat. Most of the system piping is external to the cavity vessel, but it connects to the two fixed blanket headers that are inside the vessel. The residual heat removal system piping is parallel to the primary heat removal system, and the design flowrate is between one to four percent of the primary heat removal system flowrate. A check valve ensures that back flow will not occur through the residual heat removal system while the primary system is in operation.

5.2 Pipe Network Layout

Figure 5.2-1 is a schematic of the residual heat removal system. It shows the elbows and valves in the pipe network, and also the pump and heat exchanger. The system piping is 6 inch schedule 40 steel pipe. The flow proceeds from the fixed outlet header in the cavity vessel, through the pump and heat exchanger, and back to the fixed inlet header. There are cutout valves on both the suction and discharge sides of the pump and on the discharge side of the heat exchanger. There is also a check valve on the discharge side of the pump.

Figure 1.1-2 is an areal view of the primary and residual heat removal systems, showing the relative placements of the pumps and heat exchangers of the two systems. Also shown are the positions of the cavity vessel and the pressurizer. Figure 5.2-2 shows both areal and side scale views of the residual heat removal system. Lengths of straight pipe are shown in this figure. The residual heat removal system pipes pass through the cavity vessel wall 2 meters above the top fixed header, in the same manner as the primary system pipes.

5.3. Heat Exchanger Design

The residual heat removal system has a single pass shell-and-tube heat exchanger. It was designed based on a flowrate of one percent of the primary system flowrate. The blanket decay power drops to less than one percent of full power in the first second following beam trip. The mass flowrate per tube and the axial temperature gradient in a tube are assumed to be the same for both the primary and residual system heat exchangers. The tube diameters and lengths are the same in both systems. There are two passes in the primary system heat exchangers, consequently the effective tube length is twice that of the residual heat removal system heat exchanger. A single pass of both primary heat removal system heat exchangers has 13,816 tubes. Equation 5.3.1 equates the power removed by the residual system heat exchanger to one percent of the power removed by the two primary system heat exchangers. This equation was used to calculate the number of tubes in the residual heat removal system heat exchanger (277 tubes).

$$N_{t_{RHR}} \left(\frac{\dot{m}}{\text{tube}} \right) C_p \frac{dT}{dz} L_{RHR} = 0.01 (N_{t_{PHR}}) \left(\frac{\dot{m}}{\text{tube}} \right) C_p \frac{dT}{dz} L_{PHR} \quad (5.3.1)$$

TRAC BLANKET SYSTEM MODEL

where:

$$L_{PHR} = 2(L_{RHR})$$

$$Nt_{PHR} = 13816$$

The ratio of the total tube cross-sectional area to the tube sheet area is assumed to be the same as in the primary system heat exchangers. The shell diameter is consequently 0.406 m. Figure 5.3-1 is a schematic of the heat exchanger.

5.4 Pump Head Curve

The pump head curve is based on the LOFT homologous head curve. The reference state parameters with which the head curve is normalized are:

pump speed	1000 rpm
volumetric flowrate	0.079838 m ³ /s
total dynamic head	14.8392 m

These values were chosen such that, at a residual system flowrate of 5% of the primary system full flowrate, the pump speed is 1000 rpm. The first quadrant of the LOFT normalized homologous head curve is shown in Fig. 3.4-1. This is the normalized homologous head curve for the primary system pumps. While the primary and residual heat removal systems use the same normalized head curves, the reference states are significantly different for the two pump types.

5.5 Steady-State Hydraulic Model

A simple steady-state hydraulic model, similar to that developed for the primary heat removal system, was developed for the residual heat removal system. This model was developed to determine the necessary pipe size, and to compare with TRAC model results. The model RHRTRC applies the mechanical energy equation to five sections of the system sequentially: from the heat exchanger discharge to the fixed inlet header, across the heat exchanger, between the pump and heat exchanger, across the pump, and from the fixed outlet header to the pump. The independent variables in this model are: the volumetric flowrate, the pump speed, and the inlet header pressure. The model calculates at the outlet header and desired intermediate points in the system.

Since the portion of the heat removal system inside of the cavity vessel that contains the blanket modules is not modeled, the system demand curve is indeterminate. The dynamic pressure drop between the fixed headers is assumed to be proportional to the square of the flowrate, equation 5.5.1, and at full primary heat removal system flow of 1569 kg/s, the pressure drop from the inlet to outlet header is approximately 41 psid. This operating point was used to calculate the proportionality constant. The pressure drop between the headers, as a function of mass flowrate, is evaluated with equation 5.5.2.

$$\Delta P_{dyn.} = K(\dot{m})^2 \quad (5.5.1)$$

$$P_{IH} - P_{OH} = K(\dot{m})^2 - \rho g \Delta z \quad (5.5.2)$$

At two percent flow, the inlet minus outlet header pressure drop is -1.052 psid, and at four percent flow the pressure drop is -1.002 psid.

The fixed inlet header pressure, that would occur in the event of a large break LOCA, is a function of time and the break location. The transient is due in part to the pressurizer

TRAC BLANKET SYSTEM MODEL

flow. For breaks external to the cavity vessel, the minimum pressure will occur after the pressurizer flow ceases, and there is no longer flow out of the inlet header through the primary system pipe. Figure 5.5-1 is a schematic of a break in the primary system piping at the point where the heat exchanger discharge piping passes through the cavity vessel wall. The pressure at the break location is atmospheric, and there is a stagnant column of water in the vertical primary system pipe that connects to the inlet header. The hydrostatic head establishes the inlet header pressure at 19.3 psia. This is the inlet header pressure boundary condition in the steady-state model. A break internal to the cavity would eventually be submerged by the cavity flood system, and water would flow into the heat removal system through the break, a different situation altogether.

A code listing of RHRTRC and also input and output files are included in Appendix D. A script that is used to run RHRTRC on a SGI work station is also included.

5.6 Pipe size Design Study

RHRTRC was used to size the pipe in the residual heat removal system, with the criteria that the pump not cavitate at flowrates below 4% of the primary system flowrate. Equation 5.6.1 is the relation for the required NPSH [1]. This relation is based on data from over 600 small centrifugal pumps from different manufacturers. The Bingham pump NPSH relation was not used because of scaling problems due to the great difference in capacities.

$$NPSH_R = NPSH_{ref} \left(\frac{\Omega}{\Omega_{ref}} \right) \left(\frac{Q}{Q_{ref}} \right)^{.424} \quad (5.6.1)$$

The reference parameters are:

NPSH	2.35 m
pump speed	1760 rpm
flowrate	0.02778 m ³ /s

Schedule 40 steel pipes with diameters from 3 to 6 inches were considered. Table 5.6-1 shows the available and required values of NPSH as functions of the the pipe diameter and the percent full flow. The 6 inch pipe is the only one to satisfy the criterion that cavitation not occur at 4% of full flow. The threshold for cavitation in 6 inch pipe occurs at 5.4% of full flow.

5.7 TRAC Model steady-State Benchmarking

Table 5.7-1 shows a comparison between pressures in the residual heat removal system predicted by the steady-state model RHRTRC and a stand-alone TRAC model of the system. The flowrate is 62.912 kg/s (4% of full flow) and the pump speed is 897 rpm. The agreement between the two code results is excellent. This stand-alone TRAC model was incorporated into the blanket heat removal system model.

5.8 TRAC Model Component Layout

Figure 5.8-1 shows the TRAC component layout and junction numbers for the blanket residual heat removal system. A brief description of and the number of cells in each component of the entire TRAC model is listed in Table 2.4-2. Further details such as

TRAC BLANKET SYSTEM MODEL

cell lengths, flow areas, hydraulic diameters, and form loss coefficients are found in the TRAC model input deck (see Appendix A).

Figure 5.8-1 does not show the heat exchanger secondary flow and heat structure components. Component 630 is the pump, component 640 contains the check valve, that opens to enable the residual heat removal system, and component 652 models the heat exchanger tubes. PIPE components 624 and 661 are potential break locations that are external to the cavity vessel. PLENUM components 380 and 340 are respectively the inlet and outlet fixed headers.

5.9 References

1. S. Yedidiah, Centrifugal Pump Problems, Causes and Cures, Petroleum Publishing Co., 1980.

Table 5.6-1 Estimated required and available NPSH for RHR piping.

Pipe Diameter	% Full Flow	NPSH Available (m)	NPSH Required (m)
3 inch	2	-20.71	1.46
4 inch	4	-22.04	2.50
5 inch	4	-0.067	1.95
6 inch	5	3.87	2.09

Table 5.7-1 Comparison between TRAC and simple hydraulic model pressure profile for RHR piping loop.

Location	RHRTRC pressure (psia)	TRAC pressure (psia)
Outlet Header	20.299	20.335
Pump Suction	11.843	11.775
Pump Discharge	28.799	28.705
Heat Exchanger Inlet	28.038	27.990
Heat Exchanger Discharge	21.880	22.060
Inlet Header	19.295	19.295

TRAC BLANKET SYSTEM MODEL

Figure 5.2-1 Schematic of the blanket residual heat removal system.

Figure 5.2-2 Areal and side views of the residual heat removal system.

Figure 5.3-1 Schematic of the blanket residual heat removal system heat exchanger system.

Figure 5.5-1 Schematic of the break location in the primary heat removal system that was used to determine the fixed inlet header pressure boundary condition for the residual heat removal system simple hydraulic model, (RHRTRC).

Figure 5:8-1 TRAC model component layout of the blanket residual heat removal system.

6 Cavity Vessel/Flood System Descriptions

Since a variety of design improvements for the primary coolant systems are currently being considered by General Atomics (GA), LANL, and SRTC personnel, internal break loss-of-coolant accidents will be re-addressed at a later date when proposed design modifications can be tested with the integrated system model. The following discussions apply to the current cavity vessel and cavity flood models incorporated into the system TRAC model.

6.1 Background

A TRAC cavity flood system model consisting of the cavity vessel, VALVE components to simulate internal breaks, and a cavity flood pool was developed. The target system's original cavity flood system model was not directly applicable to the blanket system. Potential break locations differ between the target and blanket systems. Also, thermal connections of the blanket heat structures require a different spatial nodalization of the cavity vessel. To accommodate various potential break locations, VALVE components were employed to connect the primary heat removal and individual blanket module coolant lines to the cavity vessel.

The current cavity flood system model for blanket system safety analyses does not explicitly account for potential heat sources or sinks with regard to the neighboring target ladders that are also housed within this cavity vessel. Under those accident scenarios where the cavity vessel is not flooded, thermal radiation and gas-phase natural convection are the predominate means for energy exchange. In most cases these modes for energy transfer will be negligible. Under flooded cavity scenarios it is assumed that the net energy generated in and removed from the target ladders is reasonably balanced and imposes no net impact on the cavity flood water.

During the initial phase of development of the primary HR piping models, it was determined that TRAC's TEE component results in a significant over-prediction of hydraulic losses. Knowing this, all TEE components existing in the original target cavity system model were replaced using an appropriate combination of PLENUM and PIPE components.

6.2 Cavity Vessel

The overall geometric features, such as flow areas and volumes of the cavity vessel, are essentially identical with the values used in the target cavity pool model.

6.2.1 Thermal Coupling of Heat Structures

As mentioned above, modifications to the target cavity vessel model were required to accommodate the axial locations of the 6 lumped blanket modules. The TRAC-PF1/MOD2 code version 5.4.28a [1] was used to model the blanket system. This specific version of TRAC has a limitation on how multiple heat structures can be connected to a common fluid component (i.e., in this case pipe components). This limitation applies to PIPE components that are vertically oriented. As shown in Fig. 6.2-1 the lower portion of the cavity vessel is modeled with a vertically oriented PIPE component labeled 823. Blanket modules 1 through 5 were divided into axial cells

TRAC BLANKET SYSTEM MODEL

consistent with the axial cells chosen for component 823. Due to the low power and flow demands of module 6 (note that module 6 is a composite of various spatially complex modules), module 6 remains thermally isolated from the cavity vessel gas space.

The darker shaded HEAT STRUCTURES shown in Fig. 6.2-1 represent the lead components clad with aluminum (i.e., components 951, 966, 955, 961, 978, 962, 979, 963). The lighter shaded HEAT STRUCTURES represent the aluminum structures located between the various coolant flow channels and the cavity vessel gas space (i.e., components 984, 901, 916, 905, 988, 911, 931, 912, 932, and 913). Solid lines have been drawn between these aluminum structures and the lower cavity gas space to indicate the thermal connections made in the cavity vessel model. Depending upon the aluminum structure considered, 5 to 6 axial connection per heat structure exists.

6.2.2 Cavity Vessel Vent Valve

In the upper region of the cavity vessel dome a control valve (i.e., component 828) exists. A control valve was placed here to allow pressurization of the cavity vessel gas space once a LOCA has been determined. Above the control (vent) valve a vent line saturated with air exists that emanates from a common vent line system ultimately connected to the building HEPA filter systems. The control valve and vent line were assumed to have the size of a 12 inch schedule 40 pipe. The control valve is actuated regardless of the location of the LOCA line break (i.e., internal or external). The current trip signal logic is based on a 5% reduction in system pressure in the pressurizer surge line next to the fixed inlet header. A one second valve opening time is assumed.

6.2.3 Potential Break Locations within Cavity Vessel

In Fig. 6.2-2 a more detailed view of the cavity vessel model can be seen. Three basic vertical sections exist within this vessel model (i.e., a lower, middle, and upper section). As discussed above, the lower section contains the thermal connections made between the cavity vessel gas space and the various blanket modules (1 through 5). Numerous narrow passageways (i.e., approximately one inch gaps) exist within this section of the cavity vessel. The fill line is connected to the bottom of this lower section as illustrated in Fig. 6.2-2.

The middle section represents the area just above the top shields where a significant increase in cross-sectional flow area occurs. In this section potential break locations have been placed to accommodate large break LOCA's associated with individual modules. Due to the confined geometric arrangements below the top of the shields line, breaks situated in the lower section would result in much smaller flowrates and shorter times to cover. Potential break locations have been placed in each of the 6 modules just above the top of the shields. As shown in Fig. 6.2-2, VALVE components 840 and 842 connect to each side of a module break and also then connect to the cavity space in PLENUM component 824 (note that the 201 through 204 BREAK components shown are used only when isolated test runs of the cavity flood system are being performed).

In the upper section of the cavity vessel similar CONTROL VALVE components are used to simulate a potential break in the primary HR, RHR, or pressurizer lines entering into the fixed inlet header (see components 850 and 852 in Fig. 6.2-2). As shown in Fig. 6.2-2, VALVE components 850 and 852 connect to each side of a primary loop pipe

TRAC BLANKET SYSTEM MODEL

break and also then connect to the cavity space in PLENUM component 826. The very top of the upper section within the cavity dome connects to the controlled vent valve (component 828).

6.2 Cavity Flood Pool

The geometric features of the cavity pool are essentially identical to the values used in the target cavity pool model. The TEE component was replaced with a PLENUM component as stated above. The cavity flood pool is presented in Fig. 6.2-2. The upper portion of the cavity flood pool is filled with saturated air emanating from a common vent line ultimately connected to the building HEPA filter systems.

6.3 Cavity Flood Valve and Fill Line

Modifications were made to the flood fill line by moving the flood control valve down to the lower portion of the fill line. Line lengths and fluid volumes were preserved. By lowering this flood valve, pool water reaches the cavity vessel in a shorter time and also eliminates the difficult task of flooding the vertical section of a fill line initially filled with a gas. The cavity flood valve and fill line are also presented in Fig. 6.2-2.

Upon receiving a signal to open the control valve, the valve fully opens within a 1 second time period. The actuation signal chosen is based on a 1.5 meter high liquid inventory at the base of the cavity vessel gas space. This particular signal was chosen to ensure that no inadvertent flood valve openings would occur. Once actuated, the flood valve fully opens and remains open throughout the remainder of the transient. For the massive blanket modules housed within the cavity vessel, thermal inertia is sufficiently large such that rapid flooding of the cavity space is unnecessary.

6.4 Simple Vapor-Liquid Equilibrium (VLE) Model

A simple standalone model based on the control volume approach was also developed to provide supporting analyses and insight into the cavity flooding process. The TRAC code has demonstrated trouble modeling pipe break flows into cavities when the cavity pressure is below and the nominal APT cavity pressure is on the order of 0.1 psia. The control volume model (based on thermodynamic vapor-liquid equilibrium) was used to help understand the implications of assuming an initial cavity pressure of 5 psia, currently used in the TRAC system model.

Under normal operating conditions the cavity vessel will be operating between 50 to 60 C, while the cavity flood pool will be seating at or below the maximum expected building temperature of approximately 40 C. The saturation temperature of water at a vapor pressure of 5 psia is approximately 32.7 C.

The simple VLE model predicts cavity vessel saturation to occur very rapidly following an internal break (i.e., on the order of 0.2 seconds). Initially, the cavity vessel contains a low pressure unsaturated gas mixture. The rapid evaporation process results in an early on cavity vessel gas temperature drop to approximately 27 C with a corresponding saturated gas pressure of 3.4 psia. Without opening the vent valve at the cavity dome, the cavity gas pressure would only slowly rise as the gas space within the cavity vessel is compressed during the fill process. However, opening of the vent valve results in a fairly rapid process of pressurizing (i.e., on the order of minutes). The impact of the initially slightly higher cavity pressure in the TRAC model (5 versus 3.4 psia) is minimal

TRAC BLANKET SYSTEM MODEL

since near choke flow conditions exist at the break location and the initial driving force for cavity flood is significantly larger.

6.5 References

1. Safety Code Development Group, "TRAC-PF1/MOD2: An Advanced Best Estimate Computer Program for Pressurized Water Reactor Thermal-Hydraulic Analysis," Los Alamos National Laboratory report LA-12031-M, Vol. 1 (NUREG/CR-5673), (July 21, 1993).

Figure 6.2-1 TRAC component layout for the cavity vessel and blanket module heat structures.

TRAC BLANKET SYSTEM MODEL

Figure 6.2-2 TRAC component layout for the cavity vessel and cavity flood system.

7 Secondary HR and RHR Component Descriptions

7.1 Introduction

Major components of a typical blanket heat removal system include heat exchangers, piping, and pumps. The blanket heat removal system is comprised of the primary heat removal (HR) system, the secondary heat removal system, the primary residual heat removal (RHR) system, and the secondary RHR system. These systems provide the heat removal function for all the thermal energy deposited within the blanket modules. The blanket coolant system has one primary HR, one secondary HR, two 100% primary RHR, and two secondary RHR systems. The blanket module system is connected to a single main primary loop, with three 50% of total capacity pumps in parallel. Two pumps are normally operating and the remaining pump is available for immediate startup in the event of failure of a running pump. The cooling loop has two 50% capacity heat exchangers in parallel. The primary and secondary working fluids of the blanket coolant system are light water. The pumps are a canned-motor type.

The two RHR loops are both sized such that each can accommodate 100% of the decay heat removal requirements. Currently, the RHR components are sized for approximately 4% of the full power flow, 1569 kg/sec. Each of the RHR loops has one heat exchanger and one pump. The RHR loops may be isolated from the blanket primary loop with valves. The current baseline design has the RHR systems shutdown in standby mode during normal operation to enhance the system's response to some abnormal accident scenarios. This approach is compatible with the natural circulation capability of the RHR loops. The two RHR secondary side loops are also sized for each to accommodate 100% of the decay heat removal requirements. The RHR primary side and secondary side pumps are supplied with on-site backup diesel power as well as a dc backup power supply. Both the primary HR and the RHR loops are connected to the large fixed headers (20.5 inch diameter) that are internal to the target/blanket cavity vessel. The blanket heat energy is transported by the primary HR or RHR coolant water to the heat exchangers, and is transferred to the secondary side of the heat exchanger through the multiple tube shells. Schematic diagrams of the primary HR and RHR systems are shown in Sections 3 and 5. Detailed TRAC modeling descriptions for the primary HR and RHR systems are provided in the previous sections. This section describes the TRAC modeling of the secondary sides of HR and RHR heat exchangers.

7.2 1-D TRAC Model for HR and RHR Secondary Sides

The blanket heat removal system heat exchangers are conventional shell and tube type, horizontal heat exchangers, with single-pass or two-pass configurations. The HR cooling system has two-pass horizontal heat exchangers, and a single-pass horizontal heat exchanger is used in the RHR system. The current TRAC model does not include the entire secondary loops of the HR and RHR systems. Operating conditions of the secondary systems are simulated by using fill and break boundary conditions at the inlets and outlets of the secondary sides of heat exchanger components. A simple energy balance approach was taken to determine flow inputs for the secondary side of the heat exchanger in the one-dimensional TRAC system model. The basic approach to determine the secondary flow conditions is shown in Fig. 7.2-1. According to the

TRAC BLANKET SYSTEM MODEL

current CDR, heat exchanger exit temperatures for the primary coolant are about 50 C under normal operation conditions.

From a steady-state thermal energy balance,

$$Q \approx M_{sf} C_p (T_{sfo} - T_{sfi}) \approx M_{pf} C_p (T_{pfi} - T_{pfo}) \quad (7.2.1)$$

where

M_{pf}	= primary side liquid flowrate
C_p	= coolant specific heat
T_{pfo}	= primary coolant outlet temperature
T_{pfi}	= primary coolant inlet temperature
M_{sf}	= secondary side liquid flowrate
T_{sfo}	= secondary coolant outlet temperature
T_{sfi}	= secondary coolant inlet temperature

From eq. 7.2.1, secondary coolant flow of a HR heat exchanger is about 1570 kg/sec. In a similar fashion, the flowrate, to provide the fill boundary condition for the secondary side inlet of the RHR heat exchanger, was calculated. Geometric dimensions and one-dimensional lumped TRAC model components for the counter-current flow heat exchanger are shown in Fig. 7.2-2. Figure 7.2-3 shows heat exchanger fluid and solid heat structure nodalizations to model the secondary side of the heat exchanger.

7.3 References

1. Safety Code Development Group, "TRAC-PF1/MOD2: An Advanced Best Estimate Computer Program for Pressurized Water Reactor Thermal-Hydraulic Analysis," Los Alamos National Laboratory report LA-12031-M, Vol. 1 (NUREG/CR-5673), (July 21, 1993).

Figure 7.2-1 Typical coolant temperature profiles for primary and secondary heat exchanger sides

Figure 7.2-2 1-D TRAC model for the secondary side of primary HR heat exchanger.

Secondary Side Noding Noding Under HX Flow Condition

Figure 7.2-3 Heat exchanger fluid and heat structure nodalization for 1-D TRAC model under counter-current flow pass.

(This Page Intentionally Left Blank)

8 Control Procedure Using Trip Signals, Signal Variables, and Control Valves

Signal input parameters and procedures are used to control the blanket system operation in the simulation of LOCA transients. For the APT blanket system simulation control signal variables, control blocks, trips, and component action tables are defined (along with a multi-pass procedure) at the start of each code simulation. Values of the control signal variables are checked each time step. Component action tables list a component response as a function of elapsed time after actuation. Signal variables are independent variable values that are defined by action tables. The component action tables are parts of the component input. Figure 8-1 shows the control signal procedure to simulate a response to accident conditions and system component actions such as check valve control, heat structure power shutdown, and pump trips.

Normal operation conditions were simulated by using constrained steady-state (CSS) controllers or running the code in the transient mode. Pre-incident steady-state normal operation (NO) conditions of the APT blanket system were attained by specifying the desired total liquid flowrate of the two primary heat removal (HR) pumps with the CSS controller. In the TRAC model, 12 signal variables and 10 trip signals are used to control the APT blanket HR and RHR systems operation. Table 8-1 lists all of the signal variables used in the APT blanket system model. For the loss-of-flow accident (LOFA) and LOCA simulations, the transient values of: elapsed time, pressurizer pressure, open areas of check valves, and residual heat removal (RHR) pump speed are provided as transient boundary conditions. The heat structure power trip is controlled by using the pressure signal of the pressurizer surge line and a specified time delay. To avoid flow reversals, the opening and closing of check valves, at the discharge sides of HR and RHR pumps, was controlled by using component action data tables with S-shaped forcing functions. Figure 8-2 shows a S-shape forcing function curve. Table 8-2 shows all the trip signals used in the present blanket system model. The accident analysis methodology calls for several design basis accident scenarios, including, LOFA and internal/external large break LOCA's, and NO to be simulated with the TRAC system model to provide local boundary conditions for the detailed FLOWTRAN-TF bin model. The accident scenarios were simulated by using control signal variables. The initial conditions and values of the signal variables are listed in Table 8-3.

8.1 References

1. Safety Code Development Group, "TRAC-PF1/MOD2: An Advanced Best Estimate Computer Program for Pressurized Water Reactor Thermal-Hydraulic Analysis," Los Alamos National Laboratory report LA-12031-M, Vol. 1 (NUREG/CR-5673), (July 21, 1993).

Table 8-1 Control signal variables used in the APT blanket system model.

Signal Variable ID No.	Control Parameter	System Component	Descriptions
1	time	---	delay time
2	pressure difference	RHR check valve	no flow reversal
3	pump speed and time	RHR pump and cavity vessel vent valve	S-shaped forcing function using action table
4	--	HR pump	not used
5	pressure difference	HR check valve for pump#1	S-shaped forcing function using action table
6	pressure difference	HR check valve for pump#2	S-shaped forcing function using action table
7	pressure	pressurizer	pressurizer pressure
8	time	module valve for internal LOCA simulation	S-shaped forcing function using action table
9	time	HR valve for internal LOCA simulation	elapsed time
10	pressure	cavity flooding system	pressure
11	--	cavity flood system	not used
12	time	cavity flood line valve	S-shaped forcing function using action table

Table 8-2 Trip signal variables used in the APT blanket system model.

Trip Signal ID Number	Control Component	Signal Variables ID Number (Control Variable)	Signal Value under NO
101	Fill boundary for secondary heat exchanger side	1 (time)	1.0e-06 sec
102	Cavity flood system valve	10 (cavity vessel pressure)	valve closed
103	RHR check valve	1 (time)	1.0e-06 sec
104	Heat structure	7 (pressurizer pressure) and time delay	no trips
105	RHR pump	7 (pressurizer pressure) and RHR ΔP	off
106	Primary HR pump	7 (pressurizer pressure) and time delay	on
107	Primary HR check valve	1 (time) and action table (S-shaped forcing function)	1.0e-08 sec
108	Cavity vessel check valve	1 (time)	valve closed
109	Cavity vessel check valve on the HR side	1 (time)	valve closed
110	Cavity vessel vent valve	7 (pressurizer pressure)	valve closed

TRAC BLANKET SYSTEM MODEL

Table 8-3 Design basis accident scenarios for the APT blanket system safety analysis.

Accident Scenarios		Initial and System Control Signal Conditions
Pre-Accident Normal Operation		Steady state normal operation conditions Total liquid flowrate: 1569 kg/sec Total power: 56.5MW
Pump Coastdown		Beam trip: 1.0 sec delay after 5% reduction of Pzr surge line pressure RHR pump trip: signal activated after 5 % reduction of pump ΔP
External LOCA	Case 1: HR Cold Leg Break (Break Location: Comp. 65)	Pump trip: 0.2 sec delay after 5% reduction of Pzr surge line pressure Beam trip: 0.2 sec delay after 5% reduction of Pzr surge line pressure RHR pump: signal activated after 5% reduction of Pzr surge line pressure
	Case 2: Pump Discharge Side Break with Pump Trip (Break Location: Comp. 37)	Pump trip: 0.2 sec delay after 5% reduction of Pzr surge line pressure Beam trip: 0.2 sec delay after 5% reduction of Pzr surge line pressure RHR pump: signal activated after 5% reduction of Pzr surge line pressure
	Case 3: Pump Discharge Side Break without Pump Trip (Break Location: Comp. 37)	Pump trip: no pump trip 0.2 sec delay after 5% reduction of Pzr surge line pressure RHR pump: signal activated after 5% reduction of Pzr surge line pressure
	Case 4: Pzr Surge Line Break (Break Location: Comp. 764)	Pump trip: 0.2 sec delay after 5% reduction of Pzr surge line pressure Beam trip: 0.2 sec delay after 5% reduction of Pzr surge line pressure RHR pump: signal activated after 5% reduction of Pzr surge line pressure
	Case 5: RHR Cold Leg Break (Break Location: Comp. 661)	Pump trip: 0.2 sec delay after 5% reduction of Pzr surge line pressure Beam trip: 0.2 sec delay after 5% reduction of Pzr surge line pressure RHR pump: signal activated after 5% reduction of Pzr surge line pressure
Internal LOCA	Case 1: HR Cold Leg Break (Break Location: Comp. 67-69)	Pump trip: 0.2 sec delay after 5% reduction of Pzr surge line pressure Beam trip: 0.2 sec delay after 5% reduction of Pzr surge line pressure RHR pump: signal activated after 5% reduction of Pzr surge line pressure
	Case 2: Module 1 Inlet Break (Break Location: Comp. 80)	Cavity valve actuated when liquid level (on cavity vessel floor) = 1.5 m (Comp. 823) Cavity vessel vent valve actuated similar to heat structures similar to heat structure without delay

TRAC BLANKET SYSTEM MODEL

Figure 8-1 Control procedure for blanket system component hardware actions.

TRAC BLANKET SYSTEM MODEL

Figure 8-2 S-shape forcing function curve used in the present analysis.

(This Page Intentionally Left Blank)

Appendix A: TRAC Standard Input File for Normal Operation Case

The file listed below represents the entire TRAC code "tracin" file that corresponds to the normal operation case for the blanket system, all of its primary heat removal (HR) and residual heat removal (RHR) piping components, its six lumped modules, the cavity vessel, and the cavity flood system. This input deck provides the nominal design basis case for normal operation (NO) and the TRAC restart file ("trcrst") for all design basis accidents (DBAs) considered.

Input file tracin:

```

free format
*
*****
* main data *
*****
*
*          numtcr          ieos          inopt          nmat          id2o
*              4              0              1              2              0
*
* APT Lumped (six modules + cavity vessel) Blanket Model (1/29/98)
*      (Normal Operation Case)
*
*
*
*****
* namelist data *
*****
*
&inopts nrslv=1, nhtstr=25, iconht=0, iadded=10, ielv=1, ipowr=-1,
      tpowr=10, igas=1, noair=0, nlt=13, ikfac=1, ithd=1, nsend=999999 &
*
*          dstep          timet
*              0          0.0000e-04
*
*          stdyst          transi          ncomp          njun          ipak
*              0              1          170          152          1
*
*          epso          epss
*      1.0000e-03      1.0000e-04
*
*          oitmax          sitmax          isolut          ncontr          nccfl
*              50              50              0              2              0
*
*          ntsv          ntcb          ntcf          ntrp          ntcp
*              12              0              0          10              1
*
*
*****
* component-number data *
*****
*
* iorder*
*
* Pressurizer and surge line
*
760 s * pipe          pressurizer surge line1
761 s * pipe          pressurizer surge line2
762 s * pipe          pressurizer surge line3
763 s * pipe          pressurizer surge line4
764 s * pipe          pressurizer surge line5
765 s * pipe          pressurizer surge line6

```

TRAC BLANKET SYSTEM MODEL

766	s	* pipe	primary pressurizer
767	s	* break	pressurizer boundary
*			
* HR hot leg			
20	s	* pipe	HR pump suction pipe
21	s	* plenum	HR pump suction pipe (bk)
22	s	* pipe	HR pump suction pipe
23	s	* pipe	HR pump suction pipe (bk)
24	s	* pipe	HR pump suction pipe
25	s	* pipe	HR pump suction pipe (bk)
26	s	* pipe	HR pump suction pipe
* HR pumps			
27	s	* plenum	HR pump suction plenum
28	s	* pipe	HR pump #1 inlet pipe
30	s	* pump	HR pump #1
32	s	* valve	HR pump #1 outlet pipe
29	s	* pipe	HR pump #2 inlet pipe
31	s	* pump	HR pump #2
33	s	* valve	HR pump #2 outlet pipe
34	s	* plenum	HR pump discharge plenum
* HR pump-to-hx piping			
36	s	* pipe	HR pump discharge pipe
37	s	* pipe	HR pump discharge pipe (bk)
38	s	* pipe	HR pump discharge pipe
* HR hx's			
40	s	* plenum	HR hx inlet plenum
48	s	* pipe	HR hx 1 inlet pipe
50	s	* pipe	HR hx 1 tubes 1st pass
52	s	* pipe	HR hx 1 mid-header
54	s	* pipe	HR hx 1 tubes 2nd pass
56	s	* pipe	HR hx 1 outlet pipe
49	s	* pipe	HR hx 2 inlet pipe
51	s	* pipe	HR hx 2 tubes 1st pass
53	s	* pipe	HR hx 2 mid-header
55	s	* pipe	HR hx 2 tubes 2nd pass
57	s	* pipe	HR hx 2 outlet pipe
60	s	* plenum	HR hx outlet plenum
* HR cold leg			
62	s	* pipe	HR hx discharge pipe
63	s	* pipe	HR hx discharge pipe (bk)
64	s	* pipe	HR hx discharge pipe
65	s	* pipe	HR hx discharge pipe (bk)
66	s	* pipe	HR hx discharge pipe
67	s	* plenum	HR hx discharge pipe (bk)
854	s	* valve	HR hx discharge pipe (bk)
69	s	* plenum	HR hx discharge pipe (bk)
68	s	* pipe	HR hx discharge pipe
* HR hx Secondary Side			
710	s	* fill	HR hx Secondary Side-1
711	s	* pipe	HR hx Secondary Side-1
712	s	* pipe	HR hx Secondary Side-1
713	s	* pipe	HR hx Secondary Side-1
714	s	* break	HR hx Secondary Side-1
730	s	* fill	HR hx Secondary Side-2
731	s	* pipe	HR hx Secondary Side-2
732	s	* pipe	HR hx Secondary Side-2
733	s	* pipe	HR hx Secondary Side-2
734	s	* break	HR hx Secondary Side-2
*			
* RHR primary loop			
*			
621	s	* pipe	RHR hot leg sect 1 (bk)

TRAC BLANKET SYSTEM MODEL

623	s	*	pipe	RHR hot leg sect 2
624	s	*	pipe	RHR hot leg sect 3 (bk)
625	s	*	pipe	RHR hot leg sect 4
630	s	*	pump	RHR primary pump
640	s	*	valve	RHR pump discharge valve
652	s	*	pipe	RHR primary heat exchanger tubes
660	s	*	pipe	RHR cold leg sect 1
661	s	*	pipe	RHR cold leg sect 2 (bk)
662	s	*	pipe	RHR cold leg sect 3
663	s	*	pipe	RHR cold leg sect 4 (bk)
* RHR hx Secondary Side				
672	s	*	fill	RHR hx Secondary Side
671	s	*	pipe	RHR hx Secondary Side
673	s	*	break	RHR hx Secondary Side
*				
80	s	*	plenum	L1 Blanket Row1 Plenum
82	s	*	pipe	L2 Blanket Row1
81	s	*	plenum	L2 Blanket Row1 Plenum
86	s	*	pipe	L3 Blanket Row1
85	s	*	plenum	L3 Blanket Row1 Plenum
88	s	*	pipe	L4 Blanket Row1
87	s	*	plenum	L4 Blanket Row1 Plenum
90	s	*	pipe	L5 Blanket Row1
89	s	*	plenum	L5 Blanket Row1 Plenum
84	s	*	pipe	L6 Blanket Row1
83	s	*	plenum	L6 Blanket Row1 Plenum
*				
300	s	*	pipe	L1 Blanket Row1
330	s	*	plenum	L1 Blanket Row1 Plenum
335	s	*	pipe	L1 pipe conn. 330 - 340
340	s	*	plenum	L1 outlet header
350	s	*	plenum	L1 lower plenum
360	s	*	pipe	L1 decoupler
370	s	*	plenum	L1 decoupler upper plenum
375	s	*	pipe	L1 pipe conn. 370 - 380
380	s	*	plenum	L1 inlet header
429	s	*	pipe	L1 connect hot header-tee
454	s	*	pipe	L1 connect cold header-tee
*				
173	s	*	pipe	L1 Blanket Row1
172	s	*	plenum	L1 Blanket Row1 Plenum
158	s	*	pipe	L1 pipe conn. 330 - 340
147	s	*	plenum	L1 outlet header
102	s	*	pipe	L1 lower plenum
133	s	*	plenum	L1 decoupler
136	s	*	pipe	L1 decoupler upper plenum
*				
541	s	*	pipe	L1 Blanket Row1
538	s	*	plenum	L1 Blanket Row1 Plenum
535	s	*	pipe	L1 pipe conn. 330 - 340
531	s	*	plenum	L1 outlet header
528	s	*	pipe	L1 lower plenum
536	s	*	plenum	L1 decoupler
539	s	*	pipe	L1 decoupler upper plenum
*				
415	s	*	pipe	L1 Blanket Row1
479	s	*	plenum	L1 Blanket Row1 Plenum
478	s	*	pipe	L1 pipe conn. 330 - 340
418	s	*	plenum	L1 outlet header
409	s	*	pipe	L1 lower plenum
423	s	*	plenum	L1 decoupler
417	s	*	pipe	L1 decoupler upper plenum

TRAC BLANKET SYSTEM MODEL

```

*
485 s * pipe      2nd DNS Blanket Row1
489 s * plenum    2nd DNS Blanket Row1 Plenum
480 s * pipe      2nd DNS pipe conn. 330 - 340
419 s * plenum    2nd DNS outlet header
412 s * pipe      2nd DNS lower plenum
483 s * plenum    2nd DNS decoupler
484 s * pipe      2nd DNS dec upper plenum
*
513 s * pipe      Third DNS Blanket Row1
510 s * plenum    Third DNS Row1 Plenum
507 s * pipe      Third DNS pipe conn. 330-340
503 s * plenum    Third DNS outlet header
500 s * pipe      Third DNS lower plenum
508 s * plenum    Third DNS decoupler
511 s * pipe      Third DNS dec upper plenum
*
* Cavity Pool
*
801 s * break     Cavity pool bk BC
810 s * pipe      Cavity pool upper section
811 s * plenum    Cavity pool middle section
812 s * pipe      Cavity pool lower section
813 s * plenum    Cavity pool bottom (no fill)
*
* Cavity Flood Line
*
820 s * valve     Cavity flood line valve
821 s * pipe      Cavity flood line external to vessel
822 s * pipe      Cavity flood line internal to vessel
*
* Cavity Vessel
*
823 s * pipe      Cavity vessel lower section
824 s * plenum    Cavity vessel lower break location
825 s * pipe      Cavity vessel middle section
826 s * plenum    Cavity vessel upper break location
*
* Cavity Vessel -to- Primary Loops (HR & Module lines)
*
840 s * valve     Cavity vessel to "Hot" Module inlet line
850 s * valve     Cavity vessel to HR inlet (HR side)
852 s * valve     Cavity vessel to HR inlet (Header side)
*
* Cavity Vent Line
*
828 s * valve     Cavity vessel vent line valve
802 s * break     Cavity vent line bk BC
*
* Heat Structures
*
901 s * rod       annular aluminum rod
951 s * rod       cylindrical lead rod
984 s * rod       cylindrical lead rod
*
905 s * rod       annular aluminum rod
955 s * rod       cylindrical lead rod
916 s * rod       cylindrical lead rod
966 s * rod       cylindrical lead rod
*
915 s * rod       annular aluminum rod
965 s * rod       cylindrical lead rod

```


TRAC BLANKET SYSTEM MODEL

```

*
    911  s  * rod      annular aluminum rod
    961  s  * rod      cylindrical lead rod
    988  s  * rod      cylindrical lead rod
*
    912  s  * rod      annular aluminum rod
    962  s  * rod      cylindrical lead rod
    931  s  * rod      cylindrical lead rod
    978  s  * rod      cylindrical lead rod
*
    913  s  * rod      annular aluminum rod
    963  s  * rod      cylindrical lead rod
    932  s  * rod      cylindrical lead rod
    979  s  * rod      cylindrical lead rod
*
    919  s  * rod      annular ss rod
    920  s  * rod      annular ss rod
    921  s  * rod      annular ss rod
    922  s  * rod      annular ss rod
    971  e  * rod      annular ss rod
*
*****
* material-properties data *
*****
*
*
* matb *           51           52e
* ptbln *          2           6e
*
* lead material
*
*   prptb(1,i)  prptb(2,i)  prptb(3,i)  prptb(4,i)  prptb(5,i)
*   2.7300e+02  1.1374e+04  1.2970e+02  3.4592e+01  2.8000e-01
*   1.0000e+10  1.1374e+04  8.9538e+02  3.3382e+01  2.8000e-01
e
*
* aluminum material
*
*   prptb(1,i)  prptb(2,i)  prptb(3,i)  prptb(4,i)  prptb(5,i)
*   2.7300e+02  2.6990e+03  8.6985e+02  2.1046e+02  5.0000e-02
*   3.0000e+02  2.6990e+03  8.9000e+02  2.1046e+02  5.0000e-02
*   3.7300e+02  2.6990e+03  9.4140e+02  2.1046e+02  5.0000e-02
*   4.7300e+02  2.6990e+03  9.9538e+02  2.2175e+02  5.0000e-02
*   6.7300e+02  2.6990e+03  1.0900e+03  2.2845e+02  5.0000e-02
*   1.0000e+10  2.6990e+03  1.2000e+03  2.3000e+02  5.0000e-02
e
*
*
*****
*
* CSS data
*
*****
*   numcss      amncss      amxcss      nmpcss      napcss
*
*****
* control-parameter data *
*****
*
*****
* signal variables
*****

```

TRAC BLANKET SYSTEM MODEL

```

*
* time
*      idsv      isvn      ilcn      icn1      icn2
*      1          0          0          0          0
*
* pressure difference across RHR check valve
*      idsv      isvn      ilcn      icn1      icn2
*      2          -21      640          1          2
*
* Elapse time since RHR pump activated
*      idsv      isvn      ilcn      icn1      icn2
*      3          0          0          0          0
*
* Elapse time since HR pumps and cavity vessel vent valve activated
*      idsv      isvn      ilcn      icn1      icn2
*      4          0          0          0          0
*
* pressure difference across HR check valve
*      idsv      isvn      ilcn      icn1      icn2
*      5          -21      32          1          2
*
* pressure difference across HR check valve
*      idsv      isvn      ilcn      icn1      icn2
*      6          -21      33          1          2
*
* pressure, cold leg at plenum, component 761
*      idsv      isvn      ilcn      icn1      icn2
*      7          21      761          1          1
*
* Elapse time since controlled valves activated (Module valve)
*      idsv      isvn      ilcn      icn1      icn2
*      8          0          0          0          0
*
* Elapse time since controlled valves activated (HR valves)
*      idsv      isvn      ilcn      icn1      icn2
*      9          0          0          0          0
*
* Pressure of component 823 liquid level, (CFS and cav ves vent valves)
*      idsv      isvn      ilcn      icn1      icn2
*      10         21      823          1          1
*
* Free slot
*      idsv      isvn      ilcn      icn1      icn2
*      11         0          0          0          0
*
* Elapse time since controlled valves activated (CFS valve)
*      idsv      isvn      ilcn      icn1      icn2
*      12         0          0          0          0
*
* *****
* control-block data *
* *****
*
* *****
* trips
* *****
*
* trips from off to on at time given by setp(2), secondary HX's
*      ntse      ntct      ntsf      ntdp      ntsd
*      1          0          0          0          0
*
*      idtp      isrt      iset      itst      idsg
*      101        2          0          1          1

```

TRAC BLANKET SYSTEM MODEL

```

*      setp(1)      setp(2)
0.0000e+00      1.0000e-06
*      dtsp(1)      dtsp(2)
0.0000e+00      0.0000e+00
*      ifsp(1)      ifsp(2)
0              0
*
* trips from off to on at time given by setp(2), CFS valve
*      idtp      isrt      iset      itst      idsg
102              2              0              1      10
*      setp(1)      setp(2)
0.0000e+00      4.0727e+14
*      dtsp(1)      dtsp(2)
0.0000e+00      0.0000e+00
*      ifsp(1)      ifsp(2)
0              0
*
* trips from off to on at time given by setp(2), trips RHR check valve
*      idtp      isrt      iset      itst      idsg
103              2              0              1      1
*      setp(1)      setp(2)
0.0000e+00      1.0000e-06
*      dtsp(1)      dtsp(2)
0.0000e+00      0.0000e+00
*      ifsp(1)      ifsp(2)
0              0
*
* trips from off to on when the cold leg 1 press. drops below setp(1)
*      trips power in bundles, heat structures
*      idtp      isrt      iset      itst      idsg
104              1              0              1      7
104              2              0              1      1
*      setp(1)      setp(2)
6.8745e+05      6.8745e+15
0.0000e+05      1.0000e+06
*      dtsp(1)      dtsp(2)
2.0000e-01      2.0000e-01
0.0000e+00      0.0000e+00
*      ifsp(1)      ifsp(2)
0              0
*
* trips from off to on at setp(2), starts RHR pump
*      idtp      isrt      iset      itst      idsg
105              1              0              1      7
105              2              0              1      1
*      setp(1)      setp(2)
6.8745e+05      6.8745e+15
0.0000e+05      1.0000e+06
*      dtsp(1)      dtsp(2)
0.0000e+00      0.0000e+00
*      ifsp(1)      ifsp(2)
0              0
*
* trips from off to on at time given by setp(2), trips Primary HR pumps
*      idtp      isrt      iset      itst      idsg
106              1              0              1      7
106              2              0              1      1
*      setp(1)      setp(2)
6.8745e+05      6.8745e+15
0.0000e+05      1.0000e+06
*      dtsp(1)      dtsp(2)
2.0000e-01      2.0000e-01
0.0000e+00      0.0000e+00

```

TRAC BLANKET SYSTEM MODEL

```

*      ifsp(1)      ifsp(2)
*              0              0
*
* trips from off to on at time given by setp(2), trips HR check valves
*      idtp      isrt      iset      itst      idsg
*          107          2          0          1          1
*
*      setp(1)      setp(2)
*      0.0000e+00      1.0000e-08
*
*      dtsp(1)      dtsp(2)
*      0.0000e+00      0.0000e+00
*
*      ifsp(1)      ifsp(2)
*              0              0
*
* trips from off to on at setp(2), for Hot Mod-to-cavity vessel check valve
*      idtp      isrt      iset      itst      idsg
*          108          2          0          1          1
*
*      setp(1)      setp(2)
*      0.0000e+00      1.0000e+06
*
*      dtsp(1)      dtsp(2)
*      0.0000e+00      0.0000e+00
*
*      ifsp(1)      ifsp(2)
*              0              0
*
* trips from off to on at setp(2), for HR-to-cavity vessel control valves
*      one for HR side and one for Header side
*      idtp      isrt      iset      itst      idsg
*          109          2          0          1          1
*
*      setp(1)      setp(2)
*      0.0000e+00      1.0000e+06
*
*      dtsp(1)      dtsp(2)
*      0.0000e+00      0.0000e+00
*
*      ifsp(1)      ifsp(2)
*              0              0
*
* trips from off to on at setp(2), opens cavity vessel vent valve
*      idtp      isrt      iset      itst      idsg
*          110          1          0          1          7
*          110          2          0          1          1
*
*      setp(1)      setp(2)
*      6.8745e+05      6.8745e+15
*
*      0.0000e+00      1.0000e+06
*
*      dtsp(1)      dtsp(2)
*      2.0000e-01      2.0000e-01
*
*      0.0000e+00      0.0000e+00
*
*      ifsp(1)      ifsp(2)
*              0              0
*
*
* *****
* component data *
* *****
* *****
* Single Loop for Lumped Blanket System *
* *****
* *****
* Inlet Water Header
* *****
*
*      type      num      id      ctitle
plenum          380      380      $380$Inlet Header
*
*      npljn      iconc      juns1      juns2
*          9          0          0          0
*
*

```

TRAC BLANKET SYSTEM MODEL

```

* juncs *      69s      *Connected to Primary Coolant Loop
* juncs *      454s     *Connected to 1st Lateral Decoup Upper Pl
* juncs *      173s     *Connected to 2nd Lateral Decoup Upper Pl
* juncs *      541s     *Connected to 3rd LoPwr Mod Decoup Upper Pl
* juncs *      415s     *Connected to 1st DNS Mod Decoup Upper Pl
* juncs *      485s     *Connected to 2nd DNS Mod Decoup Upper Pl
* juncs *      513s     *Connected To 3rd DNS Mod Decoup Upper Pl
* juncs *      760s     *Connected To Pressurizer
* juncs *      664e     *Connected to RHR Loop

```

```

* dx * f 5.2070e-01e
* vol * 3.1727e-01e
* elev * 2.0375e+00e
* alp * 0.0000e+00e
* tl * 3.2315e+02e
* tv * 3.2315e+02e
* p * 7.32556e+05e
* pa * 0.0000e+00e

```

* Outlet Header

```
*****
```

```

***** type          num          id          ctitle
plenum          340          340      $340$Outlet Head
*      npljn          iconc          juns1          juns2
*              8              0              0              0

```

```

* juncs *      20s      *Connected to Primary Coolant Loop
* juncs *      429s     *1st Lateral R1 Pl to Outlet Header
* juncs *      127s     *2nd Lateral R1 Pl to Outlet Header
* juncs *      539s     *Low Pwr R1 Pl to Outlet Header
* juncs *      417s     *1st DNS R1 Pl to Outlet Header
* juncs *      484s     *2nd DNS R1 Pl to Outlet Header
* juncs *      511s     *3rd DNS R1 Pl to Outlet Header
* juncs *      621e     *Connected to RHR Loop

```

```

* dx * f 5.2070e-01e
* vol * 3.1727e-01e
* elev * 1.2755e+00e
* alp * 0.0000e+00e
* tl * 3.3315e+02e
* tv * 3.3315e+02e
* p * 4.53187e+05e
* pa * 0.0000e+00e

```

```

=====
* ===== PRESSURIZER =====
* =====

```

```

***** type          num          id          ctitle
pipe          760          760 $760$ pressurizer surge line1
*      ncell          nodes          jun1          jun2          epsw
*              1              0              760              761          5.0000e-05
*      ichf          iconc          iacc          ipow
*              1              0              0              0
*      radin          th          hout1          houtv          tout1
*      0.0000e+00      7.1100e-03      0.0000e+00      0.0000e+00      3.2315e+02
*      toutv          powin          powof          rpowmx          powsc1
*      3.2315e+02          0.0              0.0              0.0              0.0

```

```

* dx * 1.0e

```

TRAC BLANKET SYSTEM MODEL

```

* vol * 5.0874e-02e
* fa * r2 5.0874e-02e
* fric * 1.0000e-08 0.175e
* elev * 2.032e
* hd * r2 2.5451e-01e
* nff * f 1e
* alp * f 0.0000e+00e
* vl * f 0.0000e+00e
* vv * f 0.0000e+00e
* tl * f 3.2315e+02e
* tv * f 3.2315e+02e
* p * f 7.32543e+05e
* pa * f 0.0000e+00e
*
***** type num id ctitle
pipe 761 761 $761$ pressurizer surge line2
* ncell nodes jun1 jun2 epsw
2 0 761 762 5.0000e-05
* ichf iconc iacc ipow
1 0 0 0
* radin th hout1 houtv tout1
0.0000e+00 7.1100e-03 0.0000e+00 0.0000e+00 3.2315e+02
* toutv powin powof rpowmx powscl
3.2315e+02 0.0 0.0 0.0 0.0
*
* dx * r2 1.762e
* vol * r2 8.9639e-02e
* fa * r3 5.0874e-02e
* fric * 0.175 1.0000e-08 0.175e
* elev * 2.913 4.675e
* hd * r3 2.5451e-01e
* nff * r3 1e
* alp * f 0.0000e+00e
* vl * f 0.0000e+00e
* vv * f 0.0000e+00e
* tl * f 3.2315e+02e
* tv * f 3.2315e+02e
* p * 7.23999e+05 7.06911e+05e
* pa * f 0.0000e+00e
*
***** type num id ctitle
pipe 762 762 $762$ pressurizer surge line3
* ncell nodes jun1 jun2 epsw
1 0 762 763 5.0000e-05
* ichf iconc iacc ipow
1 0 0 0
* radin th hout1 houtv tout1
0.0000e+00 7.1100e-03 0.0000e+00 0.0000e+00 3.2315e+02
* toutv powin powof rpowmx powscl
3.2315e+02 0.0 0.0 0.0 0.0
*
* dx * 1.0e
* vol * 5.0874e-02e
* fa * r2 5.0874e-02e
* fric * 0.175 1.0000e-08e
* elev * 5.556e
* hd * r2 2.5451e-01e
* nff * r2 1e
* alp * f 0.0000e+00e
* vl * f 0.0000e+00e
* vv * f 0.0000e+00e
* tl * f 3.2315e+02e

```

TRAC BLANKET SYSTEM MODEL

```

* tv      * f      3.2315e+02e
* p       * f      6.98367e+05e
* pa      * f      0.0000e+00e
*
*****  type          num          id          ctitle
pipe          763          763 $763$ pressurizer surge line4
*          ncell      nodes      jun1      jun2      epsw
          1          0          763          764      5.0000e-05
*          ichf      iconc      iacc      ipow
          1          0          0          0
*          radin      th          hout1      houtv      tout1
          0.0000e+00      7.1100e-03      0.0000e+00      0.0000e+00      3.2315e+02
*          toutv      powin      powof      rpowmx      powscl
          3.2315e+02      0.0          0.0          0.0          0.0
*
* dx      *          2.3981e
* vol     *          1.2200e-01e
* fa      * r2      5.0874e-02e
* fric    * r2      1.0000e-08e
* elev    *          5.556e
* hd      * r2      2.5451e-01e
* nff     * r2      1e
* alp     * f      0.0000e+00e
* vl      * f      0.0000e+00e
* vv      * f      0.0000e+00e
* tl      * f      3.2315e+02e
* tv      * f      3.2315e+02e
* p       * f      6.98367e+05e
* pa      * f      0.0000e+00e
*

```

```

*****  type          num          id          ctitle
pipe          764          764 $764$ pressurizer surge line5
*          ncell      nodes      jun1      jun2      epsw
          1          0          764          765      5.0000e-05
*          ichf      iconc      iacc      ipow
          1          0          0          0
*          radin      th          hout1      houtv      tout1
          0.0000e+00      7.1100e-03      0.0000e+00      0.0000e+00      3.1315e+02
*          toutv      powin      powof      rpowmx      powscl
          3.1315e+02      0.0          0.0          0.0          0.0
*
* dx      *          1.0e
* vol     *          5.0874e-02e
* fa      * r2      5.0874e-02e
* fric    *          1.0000e-08      0.0875e
* elev    *          5.556e
* hd      * r2      2.5451e-01e
* nff     * r2      1e
* alp     * f      0.0000e+00e
* vl      * f      0.0000e+00e
* vv      * f      0.0000e+00e
* tl      * f      3.1315e+02e
* tv      * f      3.1315e+02e
* p       * f      6.98367e+05e
* pa      * f      0.0000e+00e
*

```

```

*****  type          num          id          ctitle
pipe          765          765 $765$ pressurizer surge line6
*          ncell      nodes      jun1      jun2      epsw
          13         0          765          766      5.0000e-05
*          ichf      iconc      iacc      ipow
          1          0          0          0

```

TRAC BLANKET SYSTEM MODEL

```

*      radin      th      houtl      houtv      toutl
*      0.0000e+00  7.1100e-03  0.0000e+00  0.0000e+00  3.1315e+02
*      toutv      powin      powof      rpowmx      powsc1
*      3.1315e+02      0.0      0.0      0.0      0.0
*
* dx * r3 2.18 r5 1.8312 r2 1.873s
* dx * r2 1.417 0.5e
* vol * r3 1.1090e-01 r5 9.3160e-02 r2 9.5286e-02s
* vol * r2 7.2088e-02 2.5437e-02e
* fa * r14 5.0874e-02e
* fric * 0.0875 r2 1.0000e-08 0.175 r4 1.0000e-08s
* fric * 0.175 1.0000e-08 0.175 1.0000e-08s
* fric * 0.175 1.0000e-08e
* elev * r8 5.556 4.6195 2.7465 r2 1.81s
* elev * 2.06e
* hd * r14 2.5451e-01e
* nff * r13 1 -1e
* alp * f 0.0000e+00e
* vl * f 0.0000e+00e
* vv * f 0.0000e+00e
* tl * f 3.1315e+02e
* tv * f 3.1315e+02e
* p * 6.98367e+05 6.98367e+05 6.98367e+05 6.98367e+05s
* p * 6.98367e+05 6.98367e+05 6.98367e+05 6.98367e+05s
* p * 7.07488e+05 7.25728e+05 7.34849e+05 7.34849e+05s
* p * 7.32414e+05e
* pa * f 0.0000e+00e
*
*
***** type num id ctitle
pipe 766 766 $766$ primary pressurizer
* ncells nodes jun1 jun2 epsw
* 9 0 766 767 5.0e-05
* ichf iconc iacc ipow
* 1 0 1 0
* radin th houtl houtv toutl
* 0.0000e+00 1.2700e-02 0.0000e+00 0.0000e+00 3.1315e+02
* toutv powin powof rpowmx powsc1
* 3.1315e+02 0.0 0.0 0.0 0.0
*
* dx * 0.25 0.75 r6 1.09 1.0e
* vol * 2.6268e+01 7.8803e+01 r6 1.1453e+01 1.0507e+01e
* fa * 5.0874e-02 r8 1.0507e+01 1.8639e-02e
* fric * r10 1.0000e-08e
* elev * 2.185 2.685 3.605 4.695 5.785s
* elev * 6.875 7.965 9.055 10.100e
* hd * 2.5451e-01 r8 3.6576e+00 1.5405e-01e
* nff * -1 r8 1 -1e
* alp * r7 0.0 0.75 1.0e
* vl * f 0.0000e+00e
* vv * f 0.0000e+00e
* tl * f 3.1315e+02e
* tv * f 3.1315e+02e
* p * 7.31197e+05s
* p * 7.26327e+05 7.17368e+05 7.06752e+05 6.96137e+05s
* p * 6.85522e+05 6.74907e+05 6.68243e+05 6.66862e+05e
* pa * r7 0.00000e+00 6.60722e+05 6.57605e+05e
*
*
***** type num id ctitle
break 767 767 $767$ pressurizer boundary
* jun1 ibty isat ioff

```


TRAC BLANKET SYSTEM MODEL

```

      767      0      0      0
*      dxin      volin      alpin      tin      pin
1.0000e+00  1.8639e-02  1.0000e+00  3.1315e+02  6.6679e+05
*      pain      concin      rbmx      poff      belv
6.6679e+05  0.0000e+00  1.0000e+04  6.6679e+05  1.1100e+01

```

```

***** type      num      id      ctitle
*fill      767      767 $767$ pressurizer boundary
*      jun1      ifty      ioff
*      767      2      0
*      twtold      rfmix      concin      felv
*      0.0000e+00  1.0000e+20  0.0000e+00  1.1100e+01
*      dxin      volin      alpin      vlin      tlin
*      1.0000e+00  1.8639e-02  1.0000e+00  0.0000e+00  3.1315e+02
*      pin      pain      flowin      vvin      tvin
*      6.6679e+05  6.6679e+05  0.0000e+00  0.0000e+00  3.1315e+02

```

```

=====
* ===== HR PRIMARY LOOP =====
* =====

```

```

***** type      num      id      ctitle
pipe      20      20 $20$ Loop 1 PRI - hot leg, pt 1
*      ncells      nodes      jun1      jun2      epsw
*      1      0      20      21      5.0000e-05
*      ichf      iconc      iacc      ipow
*      0      0      0      0
*      radin1      th1      houtl1      houtv1      toutl1
*      0.0000e+00  7.1120e-03  0.0000e+00  0.0000e+00  3.0000e+02
*      toutv1
3.0000e+02

```

```

* dx * 1.0000e+00e
* vol * 1.7936e-01e
* fa * f 1.7936e-01e
* fric * 1.0000e-08 0.156e
* elev * 1.27e+00e
* hd * f 4.7788e-01e
* nff * -1 1e
* alp * f 0.0000e+00e
* vl * f 8.881e+00e
* vv * f 8.890e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * f 4.01540e+05e
* pa * f 0.0000e+00e

```

```

***** type      num      id      ctitle
plenum      21      21 $21$ Loop 1 PRI - hot leg, brk loc
*      npljn      iconc      juns1      juns2
*      2      0      1      1

```

```

* juncs * 21s * Pipe connected to outlet header
* juncs * 22e * Pump suction piping

```

```

* dx * f 1.0000e+00e

```

TRAC BLANKET SYSTEM MODEL

```
* vol * 1.7936e-01e
* elev * 1.7700e+00e
* alp * 0.0000e+00e
* tl * 3.3215e+02e
* tv * 3.3215e+02e
* p * 3.89646e+05e
* pa * 0.0000e+00e
*
*
```

```
***** type num id ctitle
pipe 22 22 $22$ Loop 1 PRI - hot leg, pt 2
* ncells nodes jun1 jun2 epsw
7 0 22 23 5.0000e-05
* ichf iconc iacc ipow
0 0 0 0
* radin th houtl houtv toutl
0.0000e+00 7.1120e-03 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
3.0000e+02
*
```

```
* dx * r2 1.6430e+00 r5 1.0700e+00e
* vol * r2 2.9469e-01 r5 1.9192e-01e
* fa * f 1.7936e-01e
* fric * r2 1.0000e-08 0.156 r5 1.0000e-08e
* elev * 3.0915e+00 4.7345e+00 r5 5.5560e+00e
* hd * f 4.7788e-01e
* nff * f 1e
* alp * f 0.0000e+00e
* vl * f 8.882e+00e
* vv * f 8.882e+00e
* tl * r7 3.3215e+02e
* tv * r7 3.3215e+02e
* p * 3.75557e+05 3.58040e+05 3.42686e+05 3.41613e+05s
* p * 3.40540e+05 3.39467e+05 3.38394e+05e
* pa * f 0.0000e+00e
*
*
```

```
***** type num id ctitle
pipe 23 23 $23$ Loop 1 PRI - hot leg, bk loc
* ncells nodes jun1 jun2 epsw
1 0 23 24 5.0000e-05
* ichf iconc iacc ipow
0 0 0 0
* radin1 th1 houtl1 houtv1 toutl1
0.0000e+00 7.1120e-03 0.0000e+00 0.0000e+00 3.0000e+02
* toutv1
3.0000e+02
*
```

```
* dx * 1.0000e+00e
* vol * 1.7936e-01e
* fa * f 1.7936e-01e
* fric * 1.0000e-08 0.156e
* elev * 5.5560e+00e
* hd * f 4.7788e-01e
* nff * f 1e
* alp * f 0.0000e+00e
* vl * f 8.882e+00e
* vv * f 8.882e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * f 3.37354e+05e
```

TRAC BLANKET SYSTEM MODEL

```

* pa      * f      0.0000e+00e
*
*
*****      type          num          id          ctitle
pipe                24                24 $24$ Loop 1 PRI - hot leg, pt 3
*      ncells          nodes          jun1          jun2          epsw
*      13              0              24            25            5.0000e-05
*      ichf            iconc          iacc          ipow
*      0              0              0            0
*      radin          th              hout1          houtv          tout1
*      0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02
*
* dx      * r3      1.0667e+00      r4 1.1500e+00      r6 2.3750e+00e
* vol      * r3      1.9132e-01      r4 2.0626e-01      r6 4.2598e-01e
* fa      * f      1.7936e-01e
* fric      *      0.156          r2 1.0000e-08      0.156          r3 1.0000e-08s
* fric      *      0.156          r6 1.0000e-08e
* elev      *      5.0227e+00      3.9560e+00      2.8893e+00      r10 2.3559e+00e
* hd      * f      4.7788e-01e
* nff      * f          1e
* alp      * f      0.0000e+00e
* vl      * f      8.882e+00e
* vv      * f      8.882e+00e
* tl      * f      3.3215e+02e
* tv      * f      3.3215e+02e
* p      *      3.35408e+05      3.44641e+05      3.53875e+05      3.51855e+05s
* p      *      3.50702e+05      3.49549e+05      3.48396e+05      3.40570e+05s
* p      *      3.38189e+05      3.35808e+05      3.33426e+05      3.31045e+05s
* p      *      3.28664e+05e
* pa      * f      0.0000e+00e
*
*
*****      type          num          id          ctitle
pipe                25                25 $25$ Loop 1 PRI - hot leg bk loc
*      ncells          nodes          jun1          jun2          epsw
*      1              0              25            26            5.0000e-05
*      ichf            iconc          iacc          ipow
*      0              0              0            0
*      radin          th              hout1          houtv          tout1
*      0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02
*
* dx      * f      1.0000e+00e
* vol      * f      1.7936e-01e
* fa      * f      1.7936e-01e
* fric      *      1.0000e-08      0.156e
* elev      *      2.3559e+00e
* hd      * f      4.7788e-01e
* nff      * f          1e
* alp      * f      0.0000e+00e
* vl      * f      8.882e+00e
* vv      * f      8.882e+00e
* tl      * f      3.3215e+02e
* tv      * f      3.3215e+02e
* p      * f      3.26972e+05e
* pa      * f      0.0000e+00e
*
*
*****      type          num          id          ctitle

```

TRAC BLANKET SYSTEM MODEL

```

pipe                26                26 $26$ Loop 1 PRI - hot leg
*      ncells      nodes      jun1      jun2      epsw
          2          0          26          27      5.0000e-05
*      ichf      iconc      iacc      ipow
          0          0          0          0
*      radin      th      hout1      houtv      tout1
          0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
          3.0000e+02
*

```

```

* dx      * r2      1.2250e+00e
* vol      * r2      2.1972e-01e
* fa      * r3      1.7936e-01e
* fric      *      0.156      r2 1.0000e-08e
* elev      * f      2.3559e+00e
* hd      * f      4.7788e-01e
* nff      * f      1e
* alp      * f      0.0000e+00e
* vl      * f      8.882e+00e
* vv      * f      8.882e+00e
* tl      * f      3.3215e+02e
* tv      * f      3.3215e+02e
* p      *      3.19797e+05      3.18569e+05e
* pa      * f      0.0000e+00e
*

```

```

*****      type      num      id      ctitle
plenum      27      27 $27$ HR pump inlet plenum
*      npljn      iconc      juns1      juns2
          3          0          0          0
*

```

```

* juncs *      27s      * Hot leg piping
* juncs *      28s      * Pipe connected to pump #1
* juncs *      29e      * Pipe connected to pump #2
*

```

```

* dx      * f      0.5000e+00e
* vol      *      8.9680e-02e
* elev      *      2.3559e+00e
* alp      *      0.0000e+00e
* tl      *      3.3215e+02e
* tv      *      3.3215e+02e
* p      *      3.56552e+05e
* pa      *      0.0000e+00e
*

```

```

*****      type      num      id      ctitle
pipe      28      28 $28$ HR pump #1 suction pipe
*      ncells      nodes      jun1      jun2      epsw
          2          0          28          30      5.0000e-05
*      ichf      iconc      iacc      ipow
          0          0          0          0
*      radin      th      hout1      houtv      tout1
          0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
          3.0000e+02
*

```

```

* dx      *      0.75      1.2e
* vol      *      1.3452e-01      1.7602e-01e
* fa      * r2      1.7936e-01      1.1401e-01e
* fric      *      3.5786      1.0000e-08      0.047e
* elev      *      2.9809      3.9559e
* hd      * r2      4.7788e-01      0.381e

```

TRAC BLANKET SYSTEM MODEL

```

* nff * 1 -1 -1e
* alp * f 0.0000e+00e
* vl * r2 4.318e+00 6.793e+00e
* vv * r2 4.318e+00 6.793e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * 3.08331e+05 2.93292e+05e
* pa * f 0.0000e+00e
*
*
***** type num id ctitle
pipe 29 29 $29$ HR pump #2 suction pipe
* ncells nodes jun1 jun2 epsw
* 7 0 29 31 5.0000e-05
* ichf iconc iacc ipow
* 0 0 0 0
* radin th houtl houtv toutl
* 0.0000e+00 7.1120e-03 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
* 3.0000e+02
*
* dx * 0.5 r4 1.0 r2 1.1e
* vol * 8.968e-02 1.4669e-01 r3 1.1401e-01 r2 1.2541e-01e
* fa * r2 1.7936e-01 r6 1.1401e-01e
* fric * 0.0546 r4 1.0000e-08 0.159 1.0000e-08 0.047e
* elev * r5 2.3559 2.9059 4.0059e
* hd * r2 4.7788e-01 r6 0.381e
* nff * 1 r2 -1 r5 1e
* alp * f 0.0000e+00e
* vl * r2 4.564e+00 r6 7.180e+00e
* vv * r2 4.564e+00 r6 7.180e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * 3.45599e+05 3.39379e+05 3.26515e+05 3.25653e+05s
* p * 3.24790e+05 3.14536e+05 3.02963e+05e
* pa * f 0.0000e+00e
*
*
***** type num id ctitle
pump 30 30 $30$ primary Loop #1 pump
* ncells nodes jun1 jun2 epsw
* 2 5 30 32 5.0000e-05
* ichf iconc ipmpty irp ipm
* 0 0 2 0 1
* ipmptr ipmpsv npmptb npmpsv npmprf
* 106 0 0 0 0
* iqp3tr iqp3sv nqp3tb nqp3sv nqp3rf
* 0 0 0 0 0
* radin th houtl houtv toutl
* 0.0000e-00 1.2700e-02 0.0000e+00 0.0000e+00 3.3215e+02
* toutv effmi
* 3.3215e+02 175.00
* tfr0 tfr1 tfr2 tfr3 tfrb
* 40.000e+00 0.0000e+00 0.0000e+00 0.0000e+00 1.2600e+00
* tfr10 tfr11 tfr12 tfr13
* 946.20e+00 0.0000e+00 0.0000e+00 0.0000e+00
* rhead rtork rflow rrho romea
* 3.9228e+02 8.8578e+02 7.8863e-01 9.8465e+02 5.2360e+01
* omegan omgoff romgm omgscl npmpsd
* 6.9639e+01 6.9639e+01 1.0000e+20 1.0000e+00 0
* qp3in qp3off rqp3mx qp3scl
* 0.0000e+00 0.0000e+00 0.0000e+00 0.0000e+00

```

TRAC BLANKET SYSTEM MODEL

```

*      option
*      2
*
* dx      *      0.5      1.1e
* vol     *      5.7005e-02  1.2541e-01e
* fa      * f      1.1401e-01e
* fric    *      0.047  1.0000e-08  0.206e
* elev    *      4.8059e+00  5.0559e+00e
* hd      * f      3.8100e-01e
* nff     *      -1  r2  1e
* alp     * f      0.0000e+00e
* vl      * f      6.793e+00e
* vv      * f      6.793e+00e
* tl      * f      3.3215e+02e
* tv      * f      3.3215e+02e
* p       *      2.72618e+05  1.03566e+06e
* pa      * f      0.0000e+00e
* qppp    * f      0.0000e+00e
* matid   * f      7e
* tw      * f      3.7800e+02e
*
*
*****  type          num          id          ctitle
pump                31            31 $31$ primary Loop #2 pump
*      ncells        nodes        jun1        jun2        epsw
*      2              5            31          33        5.0000e-05
*      ichf          iconc        ipmpty        irp          ipm
*      0              0            2            0            1
*      ipmptr        ipmpsv        npmpbtb        npmpsv        npmprf
*      106            0            0            0            0
*      iqp3tr        iqp3sv        nqp3tb        nqp3sv        nqp3rf
*      0              0            0            0            0
*      radin         th           houtl        houtv        toutl
*      0.0000e-00    1.2700e-02    0.0000e+00    0.0000e+00    3.3215e+02
*      toutv         effmi
*      3.3215e+02    175.00
*      tfr0          tfr1          tfr2          tfr3          tfrb
*      40.000e+00    0.0000e+00    0.0000e+00    0.0000e+00    1.2600e+00
*      tfrl0         tfrl1         tfrl2         tfrl3
*      946.20e+00    0.0000e+00    0.0000e+00    0.0000e+00
*      rhead         rtork         rflow        rrho          romege
*      3.9228e+02    8.8578e+02    7.8863e-01    9.8465e+02    5.2360e+01
*      omegan        omgoff        romgmxx       omgscl        npmpsd
*      6.9639e+01    6.9639e+01    1.0000e+20    1.0000e+00    0
*      qp3in         qp3off        rqp3mx        qp3scl
*      0.0000e+00    0.0000e+00    0.0000e+00    0.0000e+00
*      option
*      2
*
* dx      *      0.5      1.1e
* vol     *      5.7005e-02  1.2541e-01e
* fa      * f      1.1401e-01e
* fric    *      0.047  1.0000e-08  0.206e
* elev    *      4.8059e+00  5.0559e+00e
* hd      * f      3.8100e-01e
* nff     * r3  1e
* alp     * f      0.0000e+00e
* vl      * f      7.180e+00e
* vv      * f      7.180e+00e
* tl      * f      3.3215e+02e
* tv      * f      3.3215e+02e
* p       *      2.93353e+05  1.04102e+06e

```

TRAC BLANKET SYSTEM MODEL

```
* pa * f 0.0000e+00e
* qppp * f 0.0000e+00e
* matid * f 7e
* tw * f 3.7800e+02e
*
*
```

```
***** type num id ctitle
valve 32 32 $32$ HR pump #1 dsch vlv
* ncells nodes jun1 jun2 epsw
3 0 32 34 5.0000e-05
* ichf iconc ivty ivps nvtb2
0 0 3 2 0
* ivtr ivsv nvtb1 nvsv nvrf
107 5 5 0 0
* ivtrov ivtyov
0 0
* rvmx rvov fminov fmaxov
1.0000e+00 1.0000e+00 0.0000e+00 1.0000e+00
* radin th hout1 houtv tout1
0.0000e+00 7.1120e-03 0.0000e+00 0.0000e+00 0.0000e+00
* toutv avlve hvlve favlve xpos
0.0000e+00 1.1401e-01 3.8100e-01 1.0000e+00 0.0000e+00
*
```

```
* dx * r3 7.0830e-01e
* vol * r3 8.0753e-02e
* fa * r4 1.1401e-01e
* fric * 0.206 r2 1.0000e-08 2.8115e
* elev * f 5.0559e+00e
* hd * f 3.8100e-01e
* nff * f 1e
* alp * f 0.0000e+00e
* vl * f 6.793e+00e
* vv * f 6.793e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * 1.03029e+06 1.02907e+06 1.02852e+06e
* pa * f 0.0000e+00e
*
```

```
* vtb1 * -1.0e-09 0.0e+00 0.0 0.0s
* vtb1 * 50.0 0.36s
* vtb1 * 100.0 0.74 1.0e+09 0.74e
*
```

```
***** type num id ctitle
valve 33 33 $33$ HR pump #2 dsch vlv
* ncells nodes jun1 jun2 epsw
3 0 33 35 1.0000e-05
* ichf iconc ivty ivps nvtb2
0 0 3 2 0
* ivtr ivsv nvtb1 nvsv nvrf
107 6 5 0 0
* ivtrov ivtyov
0 0
* rvmx rvov fminov fmaxov
1.0000e+00 1.0000e+00 0.0000e+00 1.0000e+00
* radin th hout1 houtv tout1
0.0000e+00 7.1120e-03 0.0000e+00 0.0000e+00 0.0000e+00
* toutv avlve hvlve favlve xpos
0.0000e+00 1.1401e-01 3.8100e-01 1.0000e+00 0.0000e+00
*
```

```
* dx * r3 7.0830e-01e
* vol * r3 8.0753e-02e
```

TRAC BLANKET SYSTEM MODEL

```

* fa      * r4  1.1401e-01e
* fric    *      0.206      r2 1.0000e-08      2.8115e
* elev    * f    5.0559e+00e
* hd       * f    3.8100e-01e
* nff      * f    1e
* alp      * f    0.0000e+00e
* vl       * f    7.180e+00e
* vv       * f    7.180e+00e
* tl       * f    3.3215e+02e
* tv       * f    3.3215e+02e
* p        *      1.03503e+06      1.03378e+06      1.03330e+06e
* pa       * f    0.0000e+00e
*
* vtbl     *      -1.0e-09      0.0e+00      0.0      0.0s
* vtbl     *      50.0      0.36s
* vtbl     *      100.0      0.74      1.0e+09      0.74e
*
*
*****      type          num          id          ctitle
plenum      34          34 $34$ HR pump outlet plenum
*      npljn      iconc      juns1      juns2
*          3          0          0          0
*
* juncs    *      36s      * Pump discharge piping
* juncs    *      34s      * Pipe connected to pump #1
* juncs    *      35e      * Pipe connected to pump #2
*
* dx       * f    0.5000e+00e
* vol      *      5.7005e-02e
* elev     *      5.0559e+00e
* alp      *      0.0000e+00e
* tl       *      3.3215e+02e
* tv       *      3.3215e+02e
* p        *      9.86905e+05e
* pa       *      0.0000e+00e
*
*
*****      type          num          id          ctitle
pipe        36          36 $36$ HR - pmp-hx pipe
*      ncells      nodes      jun1      jun2      epsw
*          .1          0          36          37      5.0000e-05
*      ichf      iconc      iacc      ipow
*          0          0          0          0
*      radin      th      hout1      houtv      tout1
*      0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02
*
* dx       * f    1.3000e+00e
* vol      * f    1.4821e-01e
* fa       * f    1.1401e-01e
* fric     * f    1.0000e-08e
* elev     * f    5.0559e+00e
* hd       * f    3.8100e-01e
* nff      * f    1e
* alp      * f    0.0000e+00e
* vl       * f    1.397e+01e
* vv       * f    1.397e+01e
* tl       * f    3.3215e+02e
* tv       * f    3.3215e+02e
* p        * f    8.87878e+05e
* pa       * f    0.0000e+00e

```


TRAC BLANKET SYSTEM MODEL

```

*
*
*****      type          num          id          ctitle
pipe          37          37 $37$ HR - pmp-hx pipe (bk)
*      ncells          nodes          jun1          jun2          epsw
*          1              0              37              38          5.0000e-05
*      ichf          iconc          iacc          ipow
*          0              0              0              0
*      radin          th          houtl          houtv          toutl
*          0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*          3.0000e+02

```

```

* dx      * f      1.0000e+00e
* vol     * f      1.1401e-01e
* fa      * f      1.1401e-01e
* fric    * f      1.0000e-08e
* elev    * f      5.0559e+00e
* hd      * f      3.8100e-01e
* nff     * f      1e
* alp     * f      0.0000e+00e
* vl      * f      1.397e+01e
* vv      * f      1.397e+01e
* tl      * f      3.3215e+02e
* tv      * f      3.3215e+02e
* p       * f      8.84160e+05e
* pa      * f      0.0000e+00e

```

```

*
*****      type          num          id          ctitle
pipe          38          38 $38$ HR - pmp-hx pipe
*      ncells          nodes          jun1          jun2          epsw
*          1              0              38              39          5.0000e-05
*      ichf          iconc          iacc          ipow
*          0              0              0              0
*      radin          th          houtl          houtv          toutl
*          0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*          3.0000e+02

```

```

* dx      * f      1.3000e+00e
* vol     * f      1.4821e-01e
* fa      * f      1.1401e-01e
* fric    * f      1.0000e-08e
* elev    * f      5.0559e+00e
* hd      * f      3.8100e-01e
* nff     * f      1e
* alp     * f      0.0000e+00e
* vl      * f      1.397e+01e
* vv      * f      1.397e+01e
* tl      * f      3.3215e+02e
* tv      * f      3.3215e+02e
* p       * f      8.80443e+05e
* pa      * f      0.0000e+00e

```

```

*
*****      type          num          id          ctitle
plenum        40          40 $40$ HR hx inlet plenum
*      npljn          iconc          juns1          juns2
*          3              0              0              0

```

```

* juncs *      39s      * Pump discharge piping

```

TRAC BLANKET SYSTEM MODEL

```

* juncs *      48s      * Pipe connected to hx #1
* juncs *      49e      * Pipe connected to hx #2
*
* dx      * f      0.5000e+00e
* vol      *      5.7005e-02e
* elev      *      5.0559e+00e
* alp      *      0.0000e+00e
* tl      *      3.3215e+02e
* tv      *      3.3215e+02e
* p      *      9.73667e+05e
* pa      *      0.0000e+00e
*
*
*****      type          num          id          ctitle
pipe          48          48 $48$ HR hx #1 inlet pipe
*      ncells          nodes          jun1          jun2          epsw
*          3              0              48              50          5.0000e-05
*      ichf          iconc          iacc          ipow
*          0              0              0              0
*      radin          th          hout1          houtv          tout1
*      0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02
*
* dx      *      2.125          r2 0.5e
* vol      *      2.4447e-01      5.7005e-02      1.6175e
* fa      * r3      1.1401e-01      5.6558e-01e
* fric      *      3.8574      0.159      r2 1.0000e-08e
* elev      * f      5.0559e+00e
* hd      * r3      3.8100e-01      1.021e-02e
* nff      * r2      1      r2 -1e
* alp      * f      0.0000e+00e
* vl      * r3      7.237e+00      1.458e+00e
* vv      * r3      7.237e+00      1.458e+00e
* tl      * f      3.3215e+02e
* tv      * f      3.3215e+02e
* p      *      8.47673e+05      8.41956e+05      8.43273e+05e
* pa      * f      0.0000e+00e
*
*
*****      type          num          id          ctitle
pipe          50          50 $50$ hx #1 first pass
*      ncells          nodes          jun1          jun2          epsw
*          4              0              50              52          2.5000e-06
*      ichf          iconc          iacc          ipow
*          0              0              0              0
*      radin          th          hout1          houtv          tout1
*      0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02
*
* dx      * f      9.9000e-01e
* vol      * f      5.5992e-01e
* fa      * f      5.6558e-01e
* fric      * f      1.0000e-08e
* elev      * f      5.0559e+00e
* hd      * f      1.0210e-02e
* nff      *      -1      r3 1      -1e
* alp      * f      0.0000e+00e
* vl      * f      1.458e+00e
* vv      * f      1.458e+00e
* tl      * f      3.3215e+02e

```

TRAC BLANKET SYSTEM MODEL

```

* tv * f 3.3215e+02e
* p * 8.39292e+05 8.36841e+05 8.34381e+05 8.31913e+05e
* pa * f 0.0000e+00e
*
*
***** type num id ctitle
pipe 52 52 $52$ hx #1 middle header
* ncells nodes jun1 jun2 epsw
3 0 52 54 5.0000e-05
* ichf iconc iacc ipow
0 0 0 0
* radin th houtl houtv toutl
0.0000e+00 7.1120e-03 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
3.0000e+02
*
* dx * 5.0000e-01 1.5000e+00 5.0000e-01e
* vol * 1.6175e+00 4.8525e+00 1.6175e+00e
* fa * 5.6558e-01 r2 3.2350e+00 5.6558e-01e
* fric * f 1.0000e-08e
* elev * 5.0559e+00 4.3059e+00 3.5559e+00e
* hd * 1.0210e-02 r2 2.0295e+00 1.0210e-02e
* nff * -1 r2 1 -1e
* alp * f 0.0000e+00e
* vl * 1.458e+00 r2 2.544e-01 1.455e+00e
* vv * 1.458e+00 r2 2.544e-01 1.455e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * 8.30356e+05 8.37618e+05 8.44881e+05e
* pa * f 0.0000e+00e
*
*
***** type num id ctitle
pipe 54 54 $54$ hx #1 second pass
* ncells nodes jun1 jun2 epsw
4 0 54 56 2.5000e-06
* ichf iconc iacc ipow
0 0 0 0
* radin th houtl houtv toutl
0.0000e+00 7.1120e-03 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
3.0000e+02
*
* dx * f 9.9000e-01e
* vol * f 5.5992e-01e
* fa * f 5.6558e-01e
* fric * f 1.0000e-08e
* elev * f 3.5559e+00e
* hd * f 1.0210e-02e
* nff * -1 r3 1 -1e
* alp * f 0.0000e+00e
* vl * f 1.455e+00e
* vv * f 1.455e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * 8.40895e+05 8.38411e+05 8.35920e+05 8.33423e+05e
* pa * f 0.0000e+00e
*
*
***** type num id ctitle
pipe 56 56 $56$ HR hx #1 outlet pipe
* ncells nodes jun1 jun2 epsw

```

TRAC BLANKET SYSTEM MODEL

```

      3          0          56          60      5.0000e-05
*      ichf      iconc      iacc      ipow
      0          0          0          0
*      radin      th      houtl      houtv      toutl
      0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
      3.0000e+02

```

```

* dx *      0.5      0.7      0.75e
* vol *      1.6175      1.0268e-01      1.2555e-01e
* fa *      5.6558e-01      1.1401e-01      r2 1.7936-01e
* fric * r3 1.0000e-08      1.8274e
* elev *      3.5559      3.3088      2.7971e
* hd *      1.021e-02      3.8100e-01      r2 4.7788e-01e
* nff * r3 -1 1e
* alp * f 0.0000e+00e
* vl *      1.455e+00      7.207e+00      r2 4.581e+00e
* vv *      1.455e+00      7.207e+00      r2 4.581e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p *      8.31843e+05      8.10952e+05      8.19083e+05e
* pa * f 0.0000e+00e

```

```

***** type      num      id      ctitle
pipe      49      49 $49$ HR hx #2 inlet pipe
*      ncells      nodes      jun1      jun2      epsw
      3          0          49          51      5.0000e-05
*      ichf      iconc      iacc      ipow
      0          0          0          0
*      radin      th      houtl      houtv      toutl
      0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
      3.0000e+02

```

```

* dx *      2.125      r2 0.5e
* vol *      2.4447e-01      5.7005e-02      1.6175e
* fa * r3 1.1401e-01      5.6558e-01e
* fric *      4.2361      0.159      r2 1.0000e-08e
* elev * f 5.0559e+00e
* hd * r3 3.8100e-01      1.021e-02e
* nff * r2 1 r2 -1e
* alp * f 0.0000e+00e
* vl * r3 6.732e+00      1.355e+00e
* vv * r3 6.732e+00      1.355e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p *      8.56178e+05      8.51230e+05      8.52369e+05e
* pa * f 0.0000e+00e

```

```

***** type      num      id      ctitle
pipe      51      51 $51$ hx #2 first pass
*      ncells      nodes      jun1      jun2      epsw
      4          0          51          53      2.5000e-06
*      ichf      iconc      iacc      ipow
      0          0          0          0
*      radin      th      houtl      houtv      toutl
      7.7026e-02      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
      3.0000e+02

```

TRAC BLANKET SYSTEM MODEL

```

* dx * f 9.9000e-01e
* vol * f 5.5992e-01e
* fa * f 5.6558e-01e
* fric * f 1.0000e-08e
* elev * f 5.0559e+00e
* hd * f 1.0210e-02e
* nff * -1 r3 1 -1e
* alp * f 0.0000e+00e
* vl * f 1.355e+00e
* vv * f 1.355e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * 8.48910e+05 8.46754e+05 8.44590e+05 8.42419e+05e
* pa * f 0.0000e+00e

```

```

***** type num id ctitle
pipe 53 53 $$$ hx #2 middle header
* ncells nodes jun1 jun2 epsw
3 0 53 55 5.0000e-05
* ichf iconc iacc ipow
0 0 0 0
* radin th houtl houtv toutl
0.0000e+00 7.1120e-03 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
3.0000e+02

```

```

* dx * 5.0000e-01 1.5000e+00 5.0000e-01e
* vol * 1.6175e+00 4.8525e+00 1.6175e+00e
* fa * 5.6558e-01 r2 3.2350e+00 5.6558e-01e
* fric * f 1.0000e-08e
* elev * 5.0559e+00 4.3059e+00 3.5559e+00e
* hd * 1.0210e-02 r2 2.0295e+00 1.0210e-02e
* nff * -1 r2 1 -1e
* alp * f 0.0000e+00e
* vl * 1.355e+00 r2 2.367e-01 1.353e+00e
* vv * 1.355e+00 r2 2.367e-01 1.353e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * 8.41044e+05 8.48308e+05 8.55572e+05e
* pa. * f 0.0000e+00e

```

```

***** type num id ctitle
pipe 55 55 $$$ hx #2 second pass
* ncells nodes jun1 jun2 epsw
4 0 55 57 2.5000e-06
* ichf iconc iacc ipow
0 0 0 0
* radin th houtl houtv toutl
7.7026e-02 7.1120e-03 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
3.0000e+02

```

```

* dx * f 9.9000e-01e
* vol * f 5.5992e-01e
* fa * f 5.6558e-01e
* fric * f 1.0000e-08e
* elev * f 3.5559e+00e
* hd * f 1.0210e-02e
* nff * -1 r3 1 -1e
* alp * f 0.0000e+00e

```

TRAC BLANKET SYSTEM MODEL

```

* vl * f 1.353e+00e
* vv * f 1.353e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * 8.52107e+05 8.49921e+05 8.47729e+05 8.45530e+05e
* pa * f 0.0000e+00e
*
*
***** type num id ctitle
pipe 57 57 $57$ HR hx #2 outlet pipe
* ncells nodes jun1 jun2 epsw
6 0 57 61 5.0000e-05
* ichf iconc iacc ipow
0 0 0 0
* radin th hout1 houtv tout1
0.0000e+00 7.1120e-03 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
3.0000e+02
*
* dx * 0.5 1.7 r2 1.5 1.0 0.5e
* vol * 1.6175 1.9382e-01 r2 1.7102e-01 1.4669e-01s
* vol * 8.968e-02e
* fa * 5.6558e-01 r4 1.1401e-01 r2 1.7936-01e
* fric * r2 1.0000e-08 0.159 r3 1.0000e-08 2.1799e
* elev * 3.5559 2.9559 r4 2.3559e
* hd * 1.021e-02 r4 3.8100e-01 r2 4.7788e-01e
* nff * r2 -1 r2 1 r2 -1 1e
* alp * f 0.0000e+00e
* vl * 1.353e+00 r4 6.704e+00 r2 4.261e+00e
* vv * 1.353e+00 r4 6.704e+00 r2 4.261e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * 8.44134e+05 8.16347e+0 8.17420e+05 8.16283e+05s
* p * 8.23032e+05 8.26855e+05e
* pa * f 0.0000e+00e
*
*
***** type num id ctitle
plenum 60 60 $60$ HR hx outlet plenum
* npljn iconc juns1 juns2
.3 0 0 0
*
* juncs * 62s * Cold leg piping
* juncs * 60s * Pipe connected to hx #1
* juncs * 61e * Pipe connected to hx #2
*
* dx * f 0.5000e+00e
* vol * 8.9680e-02e
* elev * 2.3559e+00e
* alp * 0.0000e+00e
* tl * 3.3215e+02e
* tv * 3.3215e+02e
* p * 8.16139e+05e
* pa * 0.0000e+00e
*
*
***** type num id ctitle
pipe 62 62 $62$ HR Cold leg pipe
* ncells nodes jun1 jun2 epsw
1 0 62 63 5.0000e-05
* ichf iconc iacc ipow
0 0 0 0

```

TRAC BLANKET SYSTEM MODEL

```

*      radin1      th1      houtl1      houtv1      toutl1
*      0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv1
*      3.0000e+02

```

```

*
*
* dx      *      1.7500e+00e
* vol     *      3.1388e-01e
* fa      * f      1.7936e-01e
* fric    *      1.0000e-08      0.156e
* elev    *      2.3559e+00e
* hd      * f      4.7788e-01e
* nff     * f      1e
* alp     * f      0.0000e+00e
* vl      * f      8.843e+00e
* vv      * f      8.843e+00e
* tl      * f      3.3215e+02e
* tv      * f      3.3215e+02e
* p       * f      7.76337e+05e
* pa      * f      0.0000e+00e

```

```

*****      type      num      id      ctitle
pipe      63      63 $63$ HR Cold leg pipe (bk)
*      ncells      nodes      jun1      jun2      epsw
*      1      0      63      64      5.0000e-05
*      ichf      iconc      iacc      ipow
*      0      0      0      0
*      radin1      th1      houtl1      houtv1      toutl1
*      0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv1
*      3.0000e+02

```

```

*
*
* dx      *      1.0000e+00e
* vol     *      1.7936e-01e
* fa      * f      1.7936e-01e
* fric    *      0.156      1.0000e-08e
* elev    *      2.3559e+00e
* hd      * f      4.7788e-01e
* nff     * f      1e
* alp     * f      0.0000e+00e
* vl      * f      8.843e+00e
* vv      * f      8.843e+00e
* tl      * f      3.3215e+02e
* tv      * f      3.3215e+02e
* p       * f      7.68926e+05e
* pa      * f      0.0000e+00e

```

```

*****      type      num      id      ctitle
pipe      64      64 $64$ HR Cold leg pipe
*      ncells      nodes      jun1      jun2      epsw
*      13      0      64      65      5.0000e-05
*      ichf      iconc      iacc      ipow
*      0      0      0      0
*      radin      th      houtl      houtv      toutl
*      0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02

```

```

* dx      * r6 1.7583e+00      r4 1.0125e+00      r3 1.0667e+00e

```

TRAC BLANKET SYSTEM MODEL

```

* vol * r6 3.1537e-01 r4 1.8160e-01 r3 1.9132e-01e
* fa * f 1.7936e-01e
* fric * r6 1.0000e-08 0.156 r3 1.0000e-08s
* fric * 0.156 r2 1.0000e-08 0.156e
* elev * r10 2.3559e+00 2.8893e+00 3.9560e+00 5.0227e+00e
* hd * f 4.7788e-01e
* nff * f 1e
* alp * f 0.0000e+00e
* vl * f 8.843e+00e
* vv * f 8.843e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * 7.67546e+05 7.65787e+05 7.64027e+05 7.62267e+05s
* p * 7.60507e+05 7.58747e+05 7.51326e+05 7.50313e+05s
* p * 7.49299e+05 7.48286e+05 7.36037e+05 7.24621e+05s
* p * 7.13205e+05e
* pa * f 0.0000e+00e
*
*
***** type num id ctitle
pipe 65 65 $65$ HR Cold leg pipe (bk)
* ncells nodes jun1 jun2 epsw
1 0 65 66 5.0000e-05
* ichf iconc iacc ipow
0 0 0 0
* radin1 th1 hout11 houtv1 tout11
0.0000e+00 7.1120e-03 0.0000e+00 0.0000e+00 3.0000e+02
* toutv1
3.0000e+02
*
*
* dx * 1.0000e+00e
* vol * 1.7936e-01e
* fa * f 1.7936e-01e
* fric * 0.156 1.0000e-08e
* elev * 5.5560e+00e
* hd * f 4.7788e-01e
* nff * f 1e
* alp * f 0.0000e+00e
* vl * f 8.843e+00e
* vv * f 8.843e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * f 7.00964e+05e
* pa * f 0.0000e+00e
*
*
***** type num id ctitle
pipe 66 66 $66$ HR Cold leg pipe
* ncells nodes jun1 jun2 epsw
1 0 66 67 5.0000e-05
* ichf iconc iacc ipow
0 0 0 0
* radin th hout1 houtv tout1
0.0000e+00 7.1120e-03 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
3.0000e+02
*
* dx * f 1.3000e+00e
* vol * f 2.3317e-01e
* fa * f 1.7936e-01e
* fric * f 1.0000e-08e

```


TRAC BLANKET SYSTEM MODEL

```

* elev * f 5.5560e+00e
* hd * f 4.7788e-01e
* nff * f 1e
* alp * f 0.0000e+00e
* vl * f 8.843e+00e
* vv * f 8.843e+00e
* tl * f 3.3215e+02e
* tv * f 3.3215e+02e
* p * 6.98736e+05e
* pa * f 0.0000e+00e

```

```

***** type num id ctitle
plenum 67 67 $67$ HR break (HR side)
* npljn iconc juns1 juns2
* 3 0 1 1

```

```

* juncs * 67s * Cold leg piping
* juncs * 854s * Piping between HR Cold Leg plenums
* juncs * 851e * Valve connected to Cavity Vessel (HR side)

```

```

* dx * r2 0.5 0.25e
* vol * 8.9680e-02e
* elev * 5.5560e+00e
* alp * 0.0000e+00e
* tl * 3.2315e+02e
* tv * 3.2315e+02e
* p * 6.97585e+05e
* pa * 0.0000e+00e

```

```

***** type num id ctitle
valve 854 854 $854$ HR isolation valve internal
* ncells nodes jun1 jun2 epsw
* 2 0 854 855 5.0000e-05
* ichf iconc ivty ivps nvtb2
* 0 0 3 2 0
* ivtr ivsv nvtb1 nvsv nvrf
* 109 9 -7 0 0
* ivtrov ivtyov
* 0 0
* rvmx rvov fminov fmaxov
* 1.0000e+01 0.0000e+00 0.0000e+00 1.0000e+00
* radin th houtl houtv toutl
* 0.0000e-00 8.1800e-03 0.0000e+00 0.0000e+00 3.3300e+00
* toutv avlve hvlve favlve xpos
* 3.3300e+00 1.7936e-01 4.7788e-01 1.0000e+00 1.0000e+00

```

```

* dx * f 0.5e
* vol * f 8.9680e-02e
* fa * f 1.7936e-01e
* fric * f 1.0000e-08e
* elev * f 5.5560e
* hd * f 4.7788e-01e
* nff * f 1e
* alp * f 0.0e
* vl * f 8.843e+00e
* vv * f 8.843e+00e
* tl * f 3.2300e+02e
* tv * f 3.2300e+02e
* p * f 6.97585e+05e

```

TRAC BLANKET SYSTEM MODEL

* pa * f 0.00000e+00e

*

* vtbl * 0.000 1.000s

* vtbl * 1.000 1.000s

* vtbl * 1.200 0.896s

* vtbl * 1.400 0.648s

* vtbl * 1.600 0.352s

* vtbl * 1.800 0.104s

* vtbl * 2.000 0.000e

*

*

*****	type	num	id	ctitle
plenum		69	69 \$69\$	HR break (Header side)

*	npljn	iconc	juns1	juns2
	3	0	1	1

*

* juncs * 855s * Piping between HR COLD Leg plenums

* juncs * 68s * Pipe going on to inlet header

* juncs * 853e * Valve connected to Cavity Vessel (Header side)

*

* dx * r2 0.5 0.25e

* vol * 8.9680e-02e

* elev * 5.5560e+00e

* alp * 0.0000e+00e

* tl * 3.2315e+02e

* tv * 3.2315e+02e

* p * 6.97585e+05e

* pa * 0.0000e+00e

*

*

*****	type	num	id	ctitle
pipe		68	68 \$68\$	Loop 1 PRI - cold leg, pt 3

*	ncells	nodes	jun1	jun2	epsw
	5	0	68	69	5.0000e-05

*	ichf	iconc	iacc	ipow
	0	0	0	0

*	radin1	th1	hout11	houtv1	tout11
	0.0000e+00	7.1120e-03	0.0000e+00	0.0000e+00	3.0000e+02

*	toutv1
	3.0000e+02

*

*

* dx * 1.0 r3 1.1747 1.0e

* vol * 1.7936e-01 r3 2.1069e-01 1.7936e-01e

* fa * f 1.7936e-01e

* fric * 1.0000e-08 0.156 r2 1.0000e-08 0.156s

* fric * 1.0000e-08e

* elev * 5.5560 4.9687 3.7940 2.6193 2.0320e

* hd * f 4.7788e-01e

* nff * r5 1 -1e

* alp * f 0.0000e+00e

* vl * f 8.843e+00e

* vv * f 8.843e+00e

* tl * f 3.3215e+02e

* tv * f 3.3215e+02e

* p * 6.96434e+05 6.95315e+05 7.06294e+05 7.16135e+05s

* p * 7.13951e+05e

* pa * f 0.0000e+00e

*

*

* =====
 * ===== HR SECONDARY SIDE (1) =====

TRAC BLANKET SYSTEM MODEL

```

* =====
*
*
*****  type          num          id          ctitle
fill          710          710 $710$ secondary fill - 1
*      jun1          ifty          ioff
*      710           8           0
*      iftr          ifsv          nftb          nfsv          nfrf
*      101           1           3           0           0
*      twtold          rfm          concin          felv
*      0.0000e+00      1.0000e+20      0.0000e+00      3.5559e+00
*      dxin          volin          alpin          vlin          tlin
*      5.0000e-01      7.8882e-01      0.0000e+00      0.0000e+00      3.1625e+02
*      pin          pain          flowin          vvin          tvin
*      2.0000e+06      0.0000e+00      1.5700e+03      0.0000e+00      3.1625e+02
*
*      vmscl          vvscl
*      1.0000e+00      1.0000e+00
*
* vmtb *      0.0000e+00      1.5700e+03s
* vmtb *      6.0000e+01      1.5700e+03s
* vmtb *      1.0000e+03      1.5700e+03e
*
*****  type          num          id          ctitle
pipe          711          711 $711$ heat exch. sec. part 1 - 1
*      ncells          nodes          jun1          jun2          epsw
*      4              0              710          711          1.0000e-05
*      ichf          iconc          iacc          ipow
*      1              0              0              0
*      radin          th          houtl          houtv          toutl
*      0.0000e+00      0.0000e+00      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02
*
* dx      * r4  9.9000e-01e
* vol      * r4  2.3363e+00e
* fa      * f   2.3599e+00e
* fric     * f   0.0000e+00e
* elev     * r4  3.5559e+00e
* hd       * f   3.3582e-02e
* nff      *    -1      r3 1      -1e
* alp      * f   0.0000e+00e
* vl       * f   6.712e-01e
* vv       * f   6.712e-01e
* tl       * f   3.1800e+02e
* tv       * f   3.1800e+02e
* p        * f   1.01646e+06e
* pa       * f   0.0000e+00e
*
*****  type          num          id          ctitle
pipe          712          712 $712$ heat exch. sec. part 1 - 1
*      ncells          nodes          jun1          jun2          epsw
*      3              0              711          712          1.0000e-05
*      ichf          iconc          iacc          ipow
*      1              0              0              0
*      radin          th          houtl          houtv          toutl
*      0.0000e+00      0.0000e+00      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02
*
* dx      *      5.0000e-01      1.5000e+00      5.0000e-01e
* vol      *      1.1800e+00      3.5399e+00      1.1800e+00e

```

TRAC BLANKET SYSTEM MODEL

```

* fa * f 2.3599e+00e
* fric * f 1.0000e-08e
* elev * 3.5559e+00 4.3059e+00 5.0559e+00e
* hd * f 3.3582e-02e
* nff * -1 r2 1 -1e
* alp * f 0.0000e+00e
* vl * f 6.712e-01e
* vv * f 6.712e-01e
* tl * f 3.1800e+02e
* tv * f 3.1800e+02e
* p * 1.01589e+06 1.00845e+06 1.00100e+06e
* pa * f 0.0000e+00e
*

```

```

***** type num id ctitle
pipe 713 713 $713$ heat exch. sec. part 1 - 1
* ncells nodes jun1 jun2 epsw
4 0 712 713 1.0000e-05
* ichf iconc iacc ipow
1 0 0 0
* radin th hout1 houtv tout1
0.0000e+00 0.0000e+00 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
3.0000e+02
*

```

```

* dx * r4 9.9000e-01e
* vol * r4 2.3363e+00e
* fa * f 2.3599e+00e
* fric * f 1.0000e-08e
* elev * f 5.0559e+00e
* hd * f 3.3582e-02e
* nff * -1 r3 1 -1e
* alp * f 0.0000e+00e
* vl * f 6.712e-01e
* vv * f 6.712e-01e
* tl * f 3.1800e+02e
* tv * f 3.1800e+02e
* p * f 1.00073e+06e
* pa * f 0.0000e+00e
*

```

```

***** type num id ctitle
break 714 714 $714$ secondary break - 1
* jun1 ibty isat ioff
713 0 0
* dxin volin alpin tin pin
5.0000e-01 7.8882e-01 0.0000e+00 3.1800e+02 1.0000e+06
* pain concin rbmx poff belv
0.0000e+00 0.0000e+00 1.0000e+20 0.0000e+00 5.0559e+00
*

```

```

* =====
* ===== HR SECONDARY SIDE (2) =====
* =====

```

```

***** type num id ctitle
fill 730 730 $730$ secondary fill - 2
* jun1 ifty ioff
730 0
* iftr ifsv nftb nfsv nfrf
101 1 3 0 0
* twtold rfmxc concin felv
0.0000e+00 1.0000e+20 0.0000e+00 3.5559e+00

```

TRAC BLANKET SYSTEM MODEL

```

*      dxin      volin      alpin      vlin      tlin
5.0000e-01      7.8882e-01      0.0000e+00      0.0000e+00      3.1625e+02
*      pin      pain      flowin      vvin      tvin
2.0000e+06      0.0000e+00      1.5700e+03      0.0000e+00      3.1625e+02
*
*      vmscl      vvscl
1.0000e+00      1.0000e+00
*
* vmtb *      0.0000e+00      1.5700e+03s
* vmtb *      6.0000e+01      1.5700e+03s
* vmtb *      1.0000e+03      1.5700e+03e
*
*****      type      num      id      ctitle
pipe      731      731 $731$ heat exch. sec. part 1 - 2
*      ncells      nodes      jun1      jun2      epsw
4      0      730      731      1.0000e-05
*      ichf      iconc      iacc      ipow
1      0      0      0
*      radin      th      hout1      houtv      tout1
0.0000e+00      0.0000e+00      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
3.0000e+02
*
* dx * r4 9.9000e-01e
* vol * r4 2.3363e+00e
* fa * f 2.3599e+00e
* fric * f 0.0000e+00e
* elev * r4 3.5559e+00e
* hd * f 3.3582e-02e
* nff * -1 r3 1 -1e
* alp * f 0.0000e+00e
* vl * f 6.711e-01e
* vv * f 6.711e-01e
* tl * f 3.1800e+02e
* tv * f 3.1800e+02e
* p * f 1.01631e+06e
* pa * f 0.0000e+00e
*
*****      type      num      id      ctitle
pipe      732      732 $732$ heat exch. sec. part 1 - 2
*      ncells      nodes      jun1      jun2      epsw
3      0      731      732      1.0000e-05
*      ichf      iconc      iacc      ipow
1      0      0      0
*      radin      th      hout1      houtv      tout1
0.0000e+00      0.0000e+00      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
3.0000e+02
*
* dx * 5.0000e-01      1.5000e+00      5.0000e-01e
* vol * 1.1800e+00      3.5399e+00      1.1800e+00e
* fa * f 2.3599e+00e
* fric * f 1.0000e-08e
* elev * 3.5559e+00      4.3059e+00      5.0559e+00e
* hd * f 3.3582e-02e
* nff * -1 r2 1 -1e
* alp * f 0.0000e+00e
* vl * f 6.711e-01e
* vv * f 6.711e-01e
* tl * f 3.1800e+02e
* tv * f 3.1800e+02e
* p * 1.01589e+06      1.00845e+06      1.00100e+06e

```

TRAC BLANKET SYSTEM MODEL

* pa * f 0.0000e+00e

*

```

*****  type          num          id          ctitle
pipe          733      733 $733$ heat exch. sec. part 1 - 2
*      ncells      nodes      jun1      jun2      epsw
      4          0          732          733      1.0000e-05
*      ichf      iconc      iacc      ipow
      1          0          0          0
*      radin      th      hout1      houtv      tout1
      0.0000e+00      0.0000e+00      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
      3.0000e+02

```

```

* dx * r4 9.9000e-01e
* vol * r4 2.3363e+00e
* fa * f 2.3599e+00e
* fric * f 1.0000e-08e
* elev * f 5.0559e+00e
* hd * f 3.3582e-02e
* nff * -1 r3 1 -1e
* alp * f 0.0000e+00e
* vl * f 6.711e-01e
* vv * f 6.711e-01e
* tl * f 3.1800e+02e
* tv * f 3.1800e+02e
* p * f 1.00074e+06e
* pa * f 0.0000e+00e

```

```

*****  type          num          id          ctitle
break          734      734 $734$ secondary break - 2
*      jun1      ibty      isat      ioff
      733          0          0          0
*      dxin      volin      alpin      tin      pin
      5.0000e-01      7.8882e-01      0.0000e+00      3.1800e+02      1.0000e+06
*      pain      concin      rbmx      poff      belv
      0.0000e+00      0.0000e+00      1.0000e+20      0.0000e+00      5.0559e+00

```

```

* =====
* ===== END OF HR LOOP =====
* =====

```

```

* =====
* ===== START OF RHR LOOP =====
* =====

```

```

*****  type          num          id          ctitle
pipe          621      621 $621$ RHR - hot leg, pt 1
*      ncells      nodes      jun1      jun2      epsw
      1          0          621          623      5.0000e-05
*      ichf      iconc      iacc      ipow
      0          0          0          0
*      radin1      th1      hout11      houtv1      tout11
      7.7026e-02      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv1
      3.0000e+02

```

```

* dx * 1.0000e+00e
* vol * 1.8639e-02e
* fa * f 1.8639e-02e

```

TRAC BLANKET SYSTEM MODEL

```

* fric *      1.0000e-08      0.25e
* elev *      1.2700e+00e
* hd * f      1.5405e-01e
* nff *      -1      1e
* alp * f      0.0000e+00e
* vl * f      0.0000e+00e
* vv * f      0.0000e+00e
* tl * f      3.3215e+02e
* tv * f      3.3215e+02e
* p * f      4.53240e+05e
* pa * f      0.0000e+00e
*
***** type          num          id          ctitle
pipe          623          623 $623$ RHR - hot leg, pt 2
*      ncells          nodes          jun1          jun2          epsw
          10              0              623          624          5.0000e-05
*      ichf          iconc          iacc          ipow
          0              0              0              0
*      radin          th          hout1          houtv          tout1
          7.7026e-02      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
          3.0000e+02
*
* dx * r4      1.0715e+00r6      1.1000e+00e
* vol * r4      1.9972e-02r6      2.0503e-02e
* fa * f      1.8639e-02e
* fric *      0.25 r3 1.0e-08      0.25 r2 1.0e-08s
* fric *      0.0425 r3 1.0e-08e
* elev *      1.8058e+00      2.8773e+00      3.9488e+00      5.0203e+00r6      5.5560e+00e
* hd * f      1.5405e-01e
* nff * f      1e
* alp * f      0.0000e+00e
* vl * f      0.0000e+00e
* vv * f      0.0000e+00e
* tl * r10      3.3215e+02e
* tv * r10      3.3215e+02e
* p *      4.48068e+05      4.37724e+05      4.27380e+05      4.17036e+05s
* p * r6      4.11865e+05e
* pa * f      0.0000e+00e
*
***** type          num          id          ctitle
pipe          624          624 $624$ RHR - hot leg, pt 3
*      ncells          nodes          jun1          jun2          epsw
          1              0              624          625          5.0000e-05
*      ichf          iconc          iacc          ipow
          0              0              0              0
*      radin1          th1          hout11          houtv1          tout11
          0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv1
          3.0000e+02
*
*
* dx *      1.0000e+00e
* vol *      1.8639e-02e
* fa * f      1.8639e-02e
* fric *      1.0000e-08      0.25e
* elev *      5.5560e+00e
* hd * f      1.5405e-01e
* nff * f      1e
* alp * f      0.0000e+00e
* vl * f      0.0000e+00e
* vv * f      0.0000e+00e

```

TRAC BLANKET SYSTEM MODEL

```

* tl      * f      3.1315e+02e
* tv      * f      3.1315e+02e
* p        * f      4.11865e+05e
* pa      * f      0.0000e+00e
*
*****      type          num          id          ctitle
pipe          625          625 $625$ RHR - hot leg, pt 4
*      ncells          nodes          jun1          jun2          epsw
          18              0              625          630          5.0000e-05
*      ichf          iconc          iacc          ipow
          0              0              0              0
*      radin          th          hout1          houtv          tout1
          0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
          3.0000e+02
*
* dx      * r3      1.2000e+00r7 1.9143e+00r7 2.0286e+00 1.0000e+00e
* vol      * r3      2.2367e-02r7 3.5680e-02r7 3.7810e-02 1.8639e-02e
* fa      * f      1.8639e-02e
* fric      *      0.25      0.251      1.0e-08      0.25      r6 1.0e-08s
* fric      *      0.25      r6 1.0e-08      0.25      0.25e
* elev      *      4.9560e+00      3.7560e+00      2.5560e+00r15      1.9560e+00e
* hd      * f      1.5405e-01e
* nff      * f      1e
* alp      * f      0.0000e+00e
* vl      * f      0.0000e+00e
* vv      * f      0.0000e+00e
* tl      * f      3.1315e+02e
* tv      * f      3.1315e+02e
* p        *      4.17704e+05      4.29389e+05      4.41074e+05      r15 4.46917e+05e
* pa      * f      0.0000e+00e
*
*****      type          num          id          ctitle
pump          630          630 $630$ RHR - pump
*      ncells          nodes          jun1          jun2          epsw
          2              5              630          640          5.0000e-05
*      ichf          iconc          ipmpty          irp          ipm
          0              0              1              0              1
*      ipmptr          ipmpsv          npmptb          npmpsv          npmprf
          105              3              -6              0              0
*      iq3tr          iq3sv          nqp3tb          nqp3sv          nqp3rf
          0              0              0              0              0
*      radin          th          hout1          houtv          tout1
          0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv          effmi
          3.0000e+02      175.00
*      tfr0          tfr1          tfr2          tfr3          tfrb
          473.10e+00      0.0000e+00      0.0000e+00      0.0000e+00      1.2600e+00
*      tfrl0          tfrl1          tfrl2          tfrl3
          946.20e+00      0.0000e+00      0.0000e+00      0.0000e+00
*      rhead          rtork          rflow          rrho          romega
          1.4553e+02      6.0177e+00      7.9838e-02      0.9850e+03      1.0472e+02
*      omegan          omgoff          romgmx          omgscl          npmpsd
          0.0000e+02      0.9435e+02      1.0000e+20      1.0000e+00      0
*      qp3in          qp3off          rqp3mx          qp3scl
          0.0000e+00      0.0000e+00      0.0000e+00      0.0000e+00
*      option
          2
*
* dx      * f      1.0000e-00e
* vol      * f      1.8639e-02e
* fa      * f      1.8639e-02e

```


TRAC BLANKET SYSTEM MODEL

```

* fric *      0.25      1.0000e-08      0.251e
* elev *      2.4560e+00      2.9560e+00e
* hd * f      1.5405e-01e
* nff * f      1e
* alp * f      0.0000e+00e
* vl *      0.0000e+00      0.0000e+00      0.0000e+00e
* vv *      0.0000e+00      0.0000e+00      0.0000e+00e
* tl *      3.1315e+02      3.1315e+02e
* tv *      3.1315e+02      3.1315e+02e
* p *      4.42048e+05      4.37179e+05e
* pa * f      0.0000e+00e
* qppp * f      0.0000e+00e
* matid * f      7e
* tw * f      3.7800e+02e
*
* pmptb *      0.0      0.0      3.000      9.812s
* pmptb *      6.000      33.211      9.000      61.139s
* pmptb *      12.000      84.538      15.000      94.350e
*
*****      type      num      id      ctitle
valve      640      640 $640$ RHR pump dsch
*      ncells      nodes      jun1      jun2      epsw
      3      0      640      652      5.0000e+05
*      ichf      iconc      ivty      ivps      nvb2
      0      0      3      2      0
*      ivtr      ivsv      nvb1      nvsv      nvrf
      103      2      5      0      0
*      ivtrov      ivtyov
      0      0
*      rvmx      rvov      fminov      fmaxov
      1.0000e+00      1.0000e+00      0.0000e+00      1.0000e+00
*      radin      th      hout1      houtv      tout1
      0.0000e+00      7.1120e-03      0.0000e+00      0.0000e+00      0.0000e+00
*      toutv      avlve      hvlve      favlve      xpos
      0.0000e+00      1.8639e-02      1.5405e-01      0.0000e+00      0.0000e+00
*
* dx *      1.0000e+00      0.797      0.203e
* vol *      1.8639e-02      1.4855e-02      2.6281e-02e
* fa * r3      1.8639e-02      2.2679e-02e
* fric *      0.251      r3      1.0000e-08e
* elev * f      2.9560e+00e
* hd * r03      1.5405e-01      1.0210e-02e
* nff *      1. -1 -1 -1e
* alp * f      0.0000e+00e
* vl * f      0.0000e+00e
* vv * f      0.0000e+00e
* tl * f      3.1315e+02e
* tv * f      3.1315e+02e
* p * f      4.37179e+05      r2 7.23900e+05e
* pa * f      0.0000e+00e
*
* vtb1 *      -1.0e-09      0.0e+00      0.0      0.0s
* vtb1 *      50.0      0.36s
* vtb1 *      100.0      0.712      1.0e+09      0.712e
*
*****      type      num      id      ctitle
pipe      652      652 $652$ RHR - HX pr tubes
*      ncells      nodes      jun1      jun2      epsw
      4      0      652      660      2.5000e-06
*      ichf      iconc      iacc      ipow
      0      0      0      0
*      radin      th      hout1      houtv      tout1

```

TRAC BLANKET SYSTEM MODEL

```

0.0000e+00 0.0000e+00 0.0000e+00 0.0000e+00 3.0000e+02
*
  toutv
3.0000e+02
*
* dx * f 9.9000e-01e
* vol * f 2.2452e-02e
* fa * f 2.2679e-02e
* fric * f 1.0000e-08e
* elev * f 2.9560e+00e
* hd * f 1.0210e-02e
* nff * -1 r3 1 -1e
* alp * f 0.0000e+00e
* vl * f 0.0000e+00e
* vv * f 0.0000e+00e
* tl * f 3.1315e+02e
* tv * f 3.1315e+02e
* p * f 7.23900e+05e
* pa * f 0.0000e+00e
*
***** type num id ctitle
pipe 660 660 $660$ RHR - cold leg pt 1
* cold leg from heat exchanger exit
* ncells nodes jun1 jun2 epsw
16 0 660 661 5.0000e-05
* ichf iconc iacc ipow
0 0 0 0
* radin th houtl houtv toutl
0.0000e+00 7.1120e-03 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
3.0000e+02
*
* dx * 0.203 0.797 r6 1.0677e+00 r6 2.0667e+00 r2 1.3000e+00e
* vol * 2.6281e-02 1.4855e-02 r6 1.9900e-02 r6 3.8520e-02s
* vol * r2 2.4230e-02e
* fa * 2.2679e-02 r16 1.8639e-02e
* fric * r4 1.0000e-08 0.25 r3 1.0000e-08 0.251 r5 1.0000e-08s
* fric * 0.25 1.0000e-08 0.25e
* elev * r14 2.9560e+00 3.6060e+00 4.9060e+00e
* hd * 1.0210e-02 r16 1.5405e-01e
* nff * -1 -1 r15 1e
* alp * f 0.0000e+00e
* vl * f 0.0000e+00e
* vv * f 0.0000e+00e
* tl * f 3.1315e+02e
* tv * f 3.1315e+02e
* p * 7.23900e+05 7.23900e+05 7.23900e+05 7.23900e+05s
* p * 7.23900e+05 7.23900e+05 7.23900e+05 7.23900e+05s
* p * 7.23900e+05 7.23900e+05 7.23900e+05 7.23900e+05s
* p * 7.23900e+05 7.23900e+05 7.17570e+05 7.04910e+05e
* pa * f 0.0000e+00e
*
***** type num id ctitle
pipe 661 661 $661$ RHR - cold leg, pt 2
* ncells nodes jun1 jun2 epsw
1 0 661 662 5.0000e-05
* ichf iconc iacc ipow
0 0 0 0
* radin1 th1 hout11 houtv1 tout11
0.0000e+00 7.1120e-03 0.0000e+00 0.0000e+00 3.0000e+02
* toutv1
3.0000e+02
*

```

TRAC BLANKET SYSTEM MODEL

```

*
* dx      *      1.0000e+00e
* vol     *      1.8639e-02e
* fa      * f    1.8639e-02e
* fric    *      0.25      1.0000e-08e
* elev    *      5.5560e+00e
* hd      * f    1.5405e-01e
* nff     * f      1e
* alp     * f    0.0000e+00e
* vl      * f    0.0000e+00e
* vv      * f    0.0000e+00e
* tl      * f    3.1315e+02e
* tv      * f    3.1315e+02e
* p       * f    6.98583e+05e
* pa      * f    0.0000e+00e
*
*****      type          num          id          ctitle
pipe          662          662 $662$ RHR - cold leg pt 3
*      cold leg from heat exchanger exit
*      ncells      nodes      jun1      jun2      epsw
*          8          0          662          663      5.0000e-05
*      ichf      iconc      iacc      ipow
*          0          0          0          0
*      radin      th      houtl      houtv      toutl
*      7.7026e-02      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02
*
* dx      * r5 1.3800e+00 r3 1.7467e+00e
* vol     * r5 2.5722e-02 r3 3.2556e-02e
* fa      * f    1.8639e-02e
* fric    * r2 1.0000e-08      0.0833      r2 1.0000e-08      0.25s
* fric    * r2 1.0000e-08      0.25e
* elev    * r5 5.5560e+00      4.6987e+00      3.7940e+00      2.6193e+00e
* hd      * f    1.5405e-01e
* nff     * f      1e
* alp     * f    0.0000e+00e
* vl      * f    0.0000e+00e
* vv      * f    0.0000e+00e
* tl      * f    3.3215e+02e
* tv      * f    3.3215e+02e
* p       *      6.98583e+05      6.98583e+05      6.98583e+05      6.98583e+05s
* p       *      6.98583e+05      7.06860e+05      7.15595e+05      7.26937e+05e
* pa      * f    0.0000e+00e
*
*****      type          num          id          ctitle
pipe          663          663 $663$ RHR - cold leg, pt 4
*      ncells      nodes      jun1      jun2      epsw
*          1          0          663          664      5.0000e-05
*      ichf      iconc      iacc      ipow
*          0          0          0          0
*      radinl      thl      houtl1      houtv1      toutl1
*      7.7026e-02      7.1120e-03      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv1
*      3.0000e+02
*
*
* dx      *      1.0000e+00e
* vol     *      1.8639e-02e
* fa      * f    1.8639e-02e
* fric    *      0.25      1.0000e-08e
* elev    * f    2.0320e+00e

```

TRAC BLANKET SYSTEM MODEL

```

* hd      * f      1.5405e-01e
* nff     *      1      -1e
* alp     * f      0.0000e+00e
* vl      * f      0.0000e+00e
* vv      * f      0.0000e+00e
* tl      * f      3.307e+02e
* tv      * f      3.307e+02e
* p       * f      7.32609e+05e
* pa      * f      0.0000e+00e

```

```

* =====
* ===== RHR SECONDARY SIDE =====
* =====

```

```

*****  type          num          id          ctitle
fill          672      672 $672$ Loop 1 RHR - HX sec fill
*          jun1      ifty          ioff
*          672      8          2
*          iftr      ifsv          nftb          nfsv          nfrf
*          101      1          3          0          0
*          twtold      rfmX          concin          felv
*          0.0000e+00  1.0000e+20  0.0000e+00  2.9560e+00
*          dxin      volin          alpin          vlin          tlin
*          5.0000e-01  4.7055e-02  0.0000e+00  0.0000e+00  3.1100e+02
*          pin      pain          flowin          vvin          tvin
*          2.0000e+06  0.0000e+00  2.5220e+01  0.0000e+00  3.1100e+02
*          flowoff      vloff          vvoff          alpoff
*          4.1682e+06  0.0000e+00  0.0000e+00  0.0000e+00
*          vmscl      vvscl
*          1.0000e+00  1.0000e+00
*
* vmtb *      0.0000e+00  2.5220e+01s
* vmtb *      6.0000e+01  2.5220e+01s
* vmtb *      1.0000e+04  2.5220e+01e

```

```

*****  type          num          id          ctitle
pipe          671      671 $671$ Loop 1 RHR - HX sec part 2
*          ncells      nodes          jun1          jun2          epsw
*          4          0          672          673          1.0000e-05
*          ichf      iconc          iacc          ipow
*          1          0          0          0
*          radin      th          houtl          houtv          toutl
*          0.0000e+00  0.0000e+00  0.0000e+00  0.0000e+00  3.0000e+02
*          toutv
*          3.0000e+02

```

```

* dx      * f      9.9000e-01e
* vol     * f      9.3466e-02e
* fa      * f      9.4411e-02e
* fric    * f      1.0000e-08e
* elev    * f      2.9560e+00e
* hd      * f      3.5419e-02e
* nff     *      -1      r3      1      -1e
* alp     * f      0.0000e+00e
* vl      * f      2.686e-01e
* vv      * f      2.686e-01e
* tl      * f      3.1100e+02e
* tv      * f      3.1100e+02e

```

TRAC BLANKET SYSTEM MODEL

```
* p      *      2.00011e+06  2.00008e+06  2.00005e+06  2.00002e+06e
* pa     * f      0.0000e+00e
```

```
*****  type          num          id          ctitle
break          673          673 $673$ Loop 1 RHR - HX  sec break
*            jun1          ibty          isat          ioff
*            673           0           0           0
*            dxin          volin          alpin          tin          pin
*            5.0000e-01  4.7055e-02  0.0000e+00  3.1800e+02  2.0000e+06
*            pain          concin          rbmx          poff          belv
*            0.0000e+00  0.0000e+00  1.0000e+20  0.0000e+00  2.9560e+00
```

```
* =====
* =====  END OF RHR LOOP  =====
* =====
```

```
* =====  MODULE FLOW CHANNELS  =====
* =====
```

```
* =====  MODULE 1 (DOWNFLOW - PLENUM - UPFLOW) =====
*
```

```
* Pipe connection from Cold Leg Fixed Header
```

```
*****  type          num          id          ctitle
pipe          454          454 $454$ Pipe conn. header
*            ncells          nodes          jun1          jun2          epsw
*            7              0              454          380          1.0000e-05
*            ichf          iconc          iacc          ipow
*            1              0              0              0
*            radin          th          hout1          houtv          tout1
*            9.5250e-02  1.1130e-02  0.0000e+00  0.0000e+00  3.0000e+02
*            toutv
*            3.0000e+02
```

```
* dx      * r2  6.2500e-01  7.6200e-01 r3 1.2500e+00  4.5000e-01e
* vol     * r2  3.8082e-02  4.6429e-02 r3 7.6164e-02  2.7419e-02e
* fa.     * f   6.0931e-02e
* fric    *    0.2500e+00  0.0100e+00  0.1700e+00  0.1700e+00s
* fric    *    0.0100e+00  0.0100e+00  1.0000e-02  1.0000e-08e
* elev    *    1.7772e+00  1.7772e+00  1.3962e+00s
* elev    * r3  1.0152e+00  7.9020e-01e
* hd      * f   1.9050e-01e
* nff     *    1      r5 1  1      1e
* alp     * f   0.0000e+00e
* vl      * f   9.046e+00e
* vv      * f   9.046e+00e
* tl      * f   3.2315e+02e
* tv      * f   3.2315e+02e
* p       *    6.83083e+05  6.81142e+05  6.76253e+05  6.70598e+05s
* p       *    6.67122e+05  6.63647e+05  6.63337e+05e
* pa      * f   0.0000e+00e
```

```
* Decoupler Upper Plenum
```

```
*****  type          num          id          ctitle
plenum          80          80          $80$ Dec UpperPl
*            npljn          iconc          juns1          juns2
*            3              0              0              0
```

TRAC BLANKET SYSTEM MODEL

```

*
* juncs * 380s *Inlet Hd to UP1
* juncs * 80s *UP1 to Decoupler
* juncs * 841e *Valve connected to Cavity Vessel
*
* dx * r2 1.1520e-01 5.7600e-02e
* vol * 7.0193e-03e
* elev * 5.0760e-01e
* alp * 0.0000e+00e
* tl * 3.2315e+02e
* tv * 3.2315e+02e
* p * 7.05858e+05e
* pa * 0.0000e+00e
*
*
***** type num id ctitle
pipe 375 375 $375$ Pipe conn. tee-plenum 370
* ncells nodes jun1 jun2 epsw
* 5 0 80 307 1.0000e-05
* ichf iconc iacc ipow
* 1 0 0 0
* radin th hout1 houtv tout1
7.6200e-02 1.1130e-02 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
3.0000e+02
*
* dx * 4.5000e-01 r2 1.0000e+00 r2 1.0000e+00e
* vol * 2.7419e-02 r2 6.0931e-02 r2 6.0931e-02e
* fa * f 6.0931e-02e
* fric * 1.0000e-08 0.0100e+00 0.0100e+00 0.0100e+00s
* fric * 0.0100e+00 0.1000e+00e
* elev * 2.2500e-01 -5.0000e-01 -1.5000e+00 -2.5000e+00s
* elev * -3.5000e+00e
* hd * f 1.9050e-01e
* nff * 1 r4 1 -1e
* alp * f 0.0000e+00e
* vl * f 9.046e+00e
* vv * f 9.046e+00e
* tl * f 3.2315e+02e
* tv * f 3.2315e+02e
* p * 6.67432e+05 6.72278e+05 6.79118e+05 6.85958e+05s
* p * 6.92798e+05e
* pa * f 0.0000e+00e
*
*
* Decoupler Upper Plenum
***** type num id ctitle
plenum 370 370 $370$ Dec UpperPl
* npljn iconc juns1 juns2
* 2 0 0 0
*
* juncs * 307s *Inlet Hd to UP1
* juncs * 308e *UP1 to Decoupler
*
* dx * f 2.0320e-01e
* vol * 5.0000e-01e
* elev * -4.0170e+00e
* alp * 0.0000e+00e
* tl * 3.2315e+02e
* tv * 3.2315e+02e
* p * 6.94268e+05e
* pa * 0.0000e+00e

```

TRAC BLANKET SYSTEM MODEL

```

*
*
* Module 1 Downflow
*****  type          num          id          ctitle
pipe          360          360 $360$ Decoupler water
*
*      ncells      nodes      jun1      jun2      epsw
*          5          0          308          309      1.0000e-05
*      ichf      iconc      iacc      ipow
*          1          0          0          0
*      radin1      th1      hout11      houtv1      tout11
*      0.0000e+00      1.1130e-02      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv1
*      3.0000e+02
*
*
*
* dx      *      3.1980e-01      r4 6.0960e-01e
* vol      *      6.3714e-02      r4 1.2145e-01e
* fa      * f      1.9923e-01e
* fric      *      1.3229e+00      r4 1.0000e-02      3.6840e-01e
* elev      *      -4.2785e+00      -4.7432e+00      -5.3528e+00s
* elev      *      -5.9624e+00      -6.5720e+00e
* hd      * f      8.6117e-03e
* nff      * f          1e
* alp      * f      0.0000e+00e
* vl      * f      2.769e+00e
* vv      * f      2.769e+00e
* tl      * f      3.2315e+02e
* tv      * f      3.2315e+02e
* p      *      6.85124e+05      6.84474e+05      6.83638e+05      6.82808e+05s
* p      *      6.81981e+05e
* pa      * f      0.0000e+00e
*
*
* Module 1 Mid-plenum
*****  type          num          id          ctitle
plenum          350          350 $350$ Down Pl in Water
*      npljn      iconc      juns1      juns2
*          2          0          0          0
*
* juncs *      309s      *Dec to Down Pl
* juncs *      310e      *Down Pl to Row1
*
* dx      * f      7.6200e-02e
* vol      *      5.0000e-01e
* elev      *      -6.9149e+00e
* alp      *      0.0000e+00e
* tl      *      3.2615e+02e
* tv      *      3.2615e+02e
* p      *      6.83934e+05e
* pa      *      0.0000e+00e
*
*
* Module 1 Upflow
*****  type          num          id          ctitle
pipe          300          300 $300$ Row1 water
*
*      ncells      nodes      jun1      jun2      epsw
*          5          0          310          320      1.0000e-05
*      ichf      iconc      iacc      ipow
*          1          0          0          0
*      radin      th      hout1      houtv      tout1

```

TRAC BLANKET SYSTEM MODEL

```

0.0000e+00  1.1130e-02  0.0000e+00  0.0000e+00  3.0000e+02
*
  toutv
3.0000e+02
*
* dx      * r4  6.0960e-01  3.1980e-01e
* vol     * r4  1.2106e-01  6.3509e-02e
* fa      * f   1.9859e-01e
* fric    *     1.9902e+00  r4 9.0220e-02  7.5935e-01e
* elev    *     -6.5720e+00  -5.9624e+00  -5.3528e+00s
* elev    *     -4.7432e+00  -4.2785e+00e
* hd      * f   5.0627e-03e
* nff     *     1  r4          1          1e
* alp     * f   0.0000e+00e
* vl      * f   2.787e+00e
* vv      * f   2.787e+00e
* tl      * f   3.3315e+02e
* tv      * f   3.3315e+02e
* p       *     6.61800e+05  6.42441e+05  6.23122e+05  6.03821e+05s
* p       *     5.89030e+05e
* pa      * f   0.0000e+00e
*
*
* Upper Row1 Plenum
*****
*****      type          num          id          ctitle
plenum      330          330          $330$ Upper R1
*      npljn          iconc          juns1          juns2
*          2          0          0          0
*
* juncs *      320s      *R1 to Upper PL
* juncs *      370e      *Upper PL to Outlet Header
*
* dx      * f   2.0320e-01e
* vol     *     5.0000e-01e
* elev    *     -4.0170e+00e
* alp     *     0.0000e+00e
* tl      *     3.3315e+02e
* tv      *     3.3315e+02e
* p       *     5.81824e+05e
* pa      *     0.0000e+00e
*
*
*****      type          num          id          ctitle
pipe        335          335 $335$ Pipe conn. tee-plenum 330
*      ncells          nodes          jun1          jun2          epsw
*          5          0          370          335          1.0000e-05
*      ichf          iconc          iacc          ipow
*          1          0          0          0
*      radin          th          hout1          houtv          tout1
*      7.6200e-02  1.1130e-02  0.0000e+00  0.0000e+00  3.0000e+02
*      toutv
3.0000e+02
*
* dx      * r2  1.0000e+00  r2 1.0000e+00  1.0152e+00e
* vol     * r2  6.0931e-02  r2 6.0931e-02  6.1857e-02e
* fa      * f   6.0931e-02e
* fric    *     0.1000e+00  0.0000e+00  0.0000e+00  0.0000e+00s
* fric    *     0.0000e+00  1.7000e-01e
* elev    *     -3.5000e+00  -2.5000e+00  -1.5000e+00s
* elev    *     -5.0000e-01  5.0760e-01e
* hd      * f   1.9050e-01e
* nff     *     -1  r4 1  1e

```


TRAC BLANKET SYSTEM MODEL

```

* alp * f 0.0000e+00e
* vl * f 9.094e+00e
* vv * f 9.094e+00e
* tl * f 3.3315e+02e
* tv * f 3.3315e+02e
* p * 5.10970e+05 4.98873e+05 4.86777e+05 4.74682e+05s
* p * 4.62494e+05e
* pa * f 0.0000e+00e
*
*
* Pipe connection from Hot Leg Fixed Header to tee 428 component
***** type num id ctitle
pipe 429 429 $429$ Pipe conn. 428 - 340
* ncells nodes jun1 jun2 epsw
* 4 0 335 429 1.0000e-05
* ichf iconc iacc ipow
* 1 0 0 0
* radin th hout1 houtv tout1
* 9.5250e-02 1.1130e-02 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
* 3.0000e+02
*
* dx * r4 1.2500e+00e
* vol * r4 7.6164e-02e
* fa * f 6.0931e-02e
* fric * 1.7000e-01 r3 1.0000e-02 0.5000e+00e
* elev * 1.0152e+00 r2 1.0152e+00 1.0152e+00e
* hd * f 1.9050e-01e
* nff * 1 r3 1 1e
* alp * f 0.0000e+00e
* vl * f 9.094e+00e
* vv * f 9.094e+00e
* tl * f 3.3315e+02e
* tv * f 3.3315e+02e
* p * 4.47909e+05 4.44446e+05 4.40982e+05 4.37518e+05e
* pa * f 0.0000e+00e
*
*
* ===== MODULE 2 (DOWNFLOW - PLENUM - UPFLOW) =====
*
* Module 2 Downflow
* 2nd Lateral Module
*
* Water Pipe Connection After Water Supply Manifold in Loop5
***** type num id ctitle
pipe 173 173 $173$ Pipe conn.
* ncells nodes jun1 jun2 epsw
* 7 0 173 81 1.0000e-05
* ichf iconc iacc ipow
* 1 0 0 0
* radin th hout1 houtv tout1
* 6.0325e-02 1.1130e-02 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
* 3.0000e+02
*
* dx * r2 6.2500e-01 7.6200e-01 r3 1.2500e+00s
* dx * 4.5000e-01e
* vol * r2 2.8583e-02 3.4848e-02 r3 5.7165e-02s
* vol * 2.0579e-02e
* fa * f 4.5732e-02e
* fric * 2.5000e-01 5.1803e-02 0.1700e+00 0.1700e+00s
* fric * 1.0361e-01 1.0361e-01 0.1700e+00 1.0000e-08e

```

TRAC BLANKET SYSTEM MODEL

```

* elev * r2 1.7772e+00 1.3962e+00 r3 1.0152e+00 7.9020e-01e
* hd * f 1.2065e-01e
* nff * 1 r6 1 -1e
* alp * f 0.0000e+00e
* vl * f 7.771e+00e
* vv * f 7.771e+00e
* tl * f 3.2315e+02e
* tv * f 3.2315e+02e
* p * 6.95947e+05 6.92434e+05 6.88871e+05 6.84326e+05s
* p * 6.77301e+05 6.70276e+05 6.64707e+05e
* pa * f 0.0000e+00e

```

* Decoupler Upper Plenum

```

***** type num id ctitle
plenum 81 81 $81$ Dec UpperPl
* npljn iconc juns1 juns2
2 0 0 0

```

```

* juncs * 81s *Inlet Hd to UP1
* juncs * 82e *UP1 to Decoupler

```

```

* dx * f 1.1520e-01e
* vol * 5.2683e-03e
* elev * 5.0760e-01e
* alp * 0.0000e+00e
* tl * 3.2315e+02e
* tv * 3.2315e+02e
* p * 6.96430e+05e
* pa * 0.0000e+00e

```

* Water Pipe Connection After Water Supply Manifold in Loop5

```

***** type num id ctitle
pipe 82 82 $82$ Pipe conn.
* ncells nodes jun1 jun2 epsw
3 0 82 172 1.0000e-05
* ichf iconc iacc ipow
1 0 0 0
* radin th hout1 houtv tout1
6.0325e-02 1.1130e-02 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
3.0000e+02

```

```

* dx * 4.5000e-01 r2 2.0000e+00e
* vol * 2.0579e-02 r2 9.1464e-02e
* fa * f 4.5732e-02e
* fric * 1.0000e-08 1.0000e-02 1.0000e-02 1.0000e-08e
* elev * 2.2500e-01 -1.0000e+00 -3.0000e+00e
* hd * f 1.2065e-01e
* nff * -1 r2 1 -1e
* alp * f 0.0000e+00e
* vl * f 7.771e+00e
* vv * f 7.771e+00e
* tl * f 3.2315e+02e
* tv * f 3.2315e+02e
* p * 6.68414e+05 6.76147e+05 6.88962e+05e
* pa * f 0.0000e+00e

```

* Water Decoupler Upper Plenum in Loop5

* Decoupler Upper Plenum

```

***** type num id ctitle

```

TRAC BLANKET SYSTEM MODEL

```

plenum          172          172          $172$ Dec UpperPl
*      npljn      iconc      juns1      juns2
*          2          0          0          0
*
* juncs *      172s      *Inlet Hd to UP1
* juncs *      158e      *UP1 to Decoupler
*
* dx      * f      2.0320e-01e
* vol      *      5.0000e-01e
* elev      *      -4.0170e+00e
* alp      *      0.0000e+00e
* tl      *      3.2315e+02e
* tv      *      3.2315e+02e
* p      *      6.96464e+05e
* pa      *      0.0000e+00e
*
*
* Module 2 Downflow
***** type          num          id          ctitle
pipe          158          158 $158$ Row3 water
*
*      ncells      nodes      jun1          jun2          epsw
*          6          0          158          117      1.0000e-05
*      ichf      iconc      iacc      ipow
*          1          0          0          0
*      radinl      thl      houtl1      houtv1      toutl1
*      0.0000e-00      1.1130e-02      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv1
*      3.0000e+02
*
*
* dx      *      0.3198 r4      0.6096      0.7418e
* vol      *      7.3014e-02 r4      1.3918e-01      1.6936e-01e
* fa      * f      2.2831e-01e
* fric      *      1.3229e+00      r5      1.0000e-02      3.6840e-01e
* elev      *      -4.2785e+00      -4.7432e+00      -5.3528e+00s
* elev      *      -5.9624e+00      -6.5720e+00      -7.2477e+00e
* hd      * f      3.1084e-03e
* nff      * f          1e
* alp      * f      0.0000e+00e
* vl      * f      1.557e+00e
* vv      * f      1.557e+00e
* tl      * f      3.2315e+02e
* tv      * f      3.2315e+02e
* p      *      6.92497e+05      6.90384e+05      6.87626e+05      6.84884e+05s
* p      *      6.82152e+05      6.79130e+05e
* pa      * f      0.0000e+00e
*
*
* Module 2 Mid-plenum
***** type          num          id          ctitle
plenum          147          147 $147$ Down Pl in Water
*      npljn      iconc      juns1      juns2
*          2          0          0          0
*
* juncs *      117s      *Dec to Down Pl
* juncs *      116e      *Down Pl to Row1
*
* dx      * f      7.6200e-02e
* vol      *      5.0000e-01e
* elev      *      -7.6567e+00e
* alp      *      0.0000e+00e

```

TRAC BLANKET SYSTEM MODEL

```
* tl      *      3.2615e+02e
* tv      *      3.2615e+02e
* p       *      6.78066e+05e
* pa      *      0.0000e+00e
*
*
* Module 2 Upflow
*****      type          num          id          ctitle
pipe         102          102 $102$ Row2 water
*
*      ncells          nodes          jun1          jun2          epsw
*      6              0              116          102          1.0000e-05
*      ichf          iconc          iacc          ipow
*      1              0              0              0
*      radin          th          hout1          houtv          tout1
*      0.0000e-00      1.1130e-02      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02
*
* dx      *      0.7418      r4 0.6096          0.3198e
* vol      *      1.5081e-01r4 1.2393e-01      6.5015e-02e
* fa      * f      2.0330e-01e
* fric      *      1.9902e+00      r5 9.0220e-02      7.5935e-01e
* elev      *      -7.2477e+00      -6.5720e+00      -5.9624e+00s
* elev      *      -5.3528e+00      -4.7432e+00      -4.2785e+00e
* hd      * f      3.1838e-03e
* nff      * f      1e
* alp      * f      0.0000e+00e
* vl      * f      1.750e+00e
* vv      * f      1.750e+00e
* tl      * f      3.3015e+02e
* tv      * f      3.3015e+02e
* p       *      6.62665e+05      6.44586e+05      6.28313e+05      6.12078e+05s
* p       *      5.95861e+05      5.83469e+05e
* pa      * f      0.0000e+00e
*
*
* Water Upper Plenum in Loop5
* Upper Row1 Plenum
*****
*****      type          num          id          ctitle
plenum         133          133          $133$ Upper R1
*      npljn          iconc          juns1          juns2
*      2              0              0              0
*
* juncs *      102s      *R1 to Upper PL
* juncs *      133e      *Upper Pl to Outlet Header
*
* dx      * f      2.0320e-01e
* vol      *      5.0000e-01e
* elev      *      -4.0170e+00e
* alp      *      0.0000e+00e
* tl      *      3.3015e+02e
* tv      *      3.3015e+02e
* p       *      5.76938e+05e
* pa      *      0.0000e+00e
*
*
* Water Pipe Before Water Return Manifold in Loop5
*****      type          num          id          ctitle
pipe         136          136 $136$ Pipe conn.
*      ncells          nodes          jun1          jun2          epsw
```

TRAC BLANKET SYSTEM MODEL

```

      7          0          133          127      1.0000e-05
*      ichf      iconc      iacc      ipow
      1          0          0          0
*      radin      th      houtl      houtv      toutl
      6.0325e-02      1.1130e-02      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
      3.0000e+02
*

```

```

* dx      * r2      2.0000e+00      1.0152e+00      r4      1.2500e+00e
* vol      * r2      9.1464e-02      4.6427e-02      r4      5.7165e-02e
* fa      * f      4.5732e-02e
* fric      *      1.6577e-01      1.6577e-01      2.5685e-02      0.1700e+00s
* fric      *      1.0361e-01      1.0361e-01      1.0361e-01      0.5000e+00e
* elev      *      -3.0000e+00      -1.0000e+00      5.0760e-01      r4      1.0152e+00e
* hd      * f      1.2065e-01e
* nff      *      1      r6      1      1e
* alp      * f      0.0000e+00e
* vl      * f      7.799e+00e
* vv      * f      7.799e+00e
* tl      * f      3.3015e+02e
* tv      * f      3.3015e+02e
* p      *      5.28717e+05      4.98154e+05      4.78091e+05      4.64543e+05s
* p      *      4.57524e+05      4.50505e+05      4.43485e+05e
* pa      * f      0.0000e+00e
*

```

```

* ===== MODULE 3 (DOWNFLOW - PLENUM - UPFLOW) =====
*

```

```

* Water Pipe Connection After Water Supply Manifold in Loop11

```

```

* Backstop 1st Decoupler/Row 1 module

```

```

*****      type      num      id      ctitle
pipe      415      415 $415$ Pipe conn.
*      ncells      nodes      jun1      jun2      epsw
      7          0          415      85      1.0000e-05
*      ichf      iconc      iacc      ipow
      1          0          0          0
*      radin      th      houtl      houtv      toutl
      4.7625e-02      1.1130e-02      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
      3.0000e+02
*

```

```

* dx      * r2      6.2500e-01      7.6200e-01      r3      1.2500e+00      4.5000e-01e
* vol      * r2      4.4535e-03      5.4297e-03      r3      8.9070e-03      3.2065e-03e
* fa      * f      7.1256e-03e
* fric      *      1.5000e-01      5.1803e-02      0.1700e+00      0.1700e+00s
* fric      *      1.0361e-01      1.0361e-01      0.1700e+00      1.0000e-08e
* elev      * r2      1.7772e+00      1.3962e+00      r3      1.0152e+00      7.9020e-01e
* hd      * f      9.5250e-02e
* nff      *      1      r6      1      -1e
* alp      * f      0.0000e+00e
* vl      * f      7.873e+00e
* vv      * f      7.873e+00e
* tl      * f      3.2315e+02e
* tv      * f      3.2315e+02e
* p      *      6.97380e+05      6.93121e+05      6.88642e+05      6.82829e+05s
* p      *      6.74312e+05      6.65796e+05      6.59135e+05e
* pa      * f      0.0000e+00e
*

```

```

* Decoupler Upper Plenum

```

```

*****      type      num      id      ctitle
plenum      85      85      $85$ Dec UpperPl

```

TRAC BLANKET SYSTEM MODEL

```

*      npljn      iconc      juns1      juns2
*          2          0          0          0
*
* juncs *      85s      *Inlet Hd to UPl
* juncs *      86e      *UPl to Decoupler
*
* dx      * f      1.1520e-01e
* vol      *      8.2087e-04e
* elev      *      5.0760e-01e
* alp      *      0.0000e+00e
* tl      *      3.2215e+02e
* tv      *      3.2215e+02e
* p      *      6.91327e+05e
* pa      *      0.0000e+00e
*
*
* Water Pipe Connection After Water Supply Manifold in Loop15
*****      type      num      id      ctitle
pipe      86      86 $86$ Pipe conn.
*      ncells      nodes      jun1      jun2      epsw
*          3          0          86          479      1.0000e-05
*      ichf      iconc      iacc      ipow
*          1          0          0          0
*      radin      th      hout1      houtv      tout1
*      4.9213e-02      1.1130e-02      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02
*
* dx      *      4.5000e-01      r2      2.0000e+00e
* vol      *      3.2065e-03      r2      1.4251e-02e
* fa      * f      7.1256e-03e
* fric      *      1.0000e-08      5.0000e-02      5.0000e-02      1.0000e-08e
* elev      *      2.2500e-01      -1.0000e+00      -3.0000e+00e
* hd      * f      9.5250e-02e
* nff      *      -1      r2 1      -1e
* alp      * f      0.0000e+00e
* vl      * f      7.873e+00e
* vv      * f      7.873e+00e
* tl      * f      3.2315e+02e
* tv      * f      3.2315e+02e
* p      *      6.62204e+05      6.67320e+05      6.76645e+05e
* pa      * f      0.0000e+00e
*
*
* Water Decoupler Upper Plenum in Loop11
* Decoupler Upper Plenum in Backstop 1st Dec-Row1 Module
*****      type      num      id      ctitle
plenum      479      479      $479$ Dec UpperPl
*      npljn      iconc      juns1      juns2
*          2          0          0          0
*
* juncs *      479s      *Inlet Hd to UPl
* juncs *      478e      *UPl to Decoupler
*
* dx      * f      2.0320e-01e
* vol      *      5.0000e-01e
* elev      *      -4.0170e+00e
* alp      *      0.0000e+00e
* tl      *      3.2315e+02e
* tv      *      3.2315e+02e
* p      *      6.81982e+05e
* pa      *      0.0000e+00e

```

TRAC BLANKET SYSTEM MODEL

```

*
*
* Module 3 Downflow
*****  type          num          id          ctitle
pipe          478          478 $478$ Decoupler water
*
*      ncells          nodes          jun1          jun2          epsw
*          5              0              478          418          1.0000e-05
*      ichf          iconc          iacc          ipow
*          1              0              0              0
*      radin1          th1          hout11          houtv1          tout11
*      0.0000e+00      1.1130e-02      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv1
*      3.0000e+02
*
*
*      dx      *      3.1980e-01      r4 6.0960e-01e
*      vol      *      8.8363e-03      r4 1.6844e-02e
*      fa      * f      2.7631e-02e
*      fric      *      5.0000e-01      r4 1.0000e-02      3.6840e-01e
*      elev      *      -4.2785e+00      -4.7432e+00      -5.3528e+00s
*      elev      *      -5.9624e+00      -6.5720e+00e
*      hd      * f      9.9388e-03e
*      nff      * f          1e
*      alp      * f      0.0000e+00e
*      vl      * f      2.032e+00e
*      vv      * f      2.032e+00e
*      tl      * f      3.2515e+02e
*      tv      * f      3.2515e+02e
*      p      *      6.80102e+05      6.82180e+05      6.84914e+05      6.87650e+05s
*      p      *      6.90387e+05e
*      pa      * f      0.0000e+00e
*
*
* Module 3 Mid-plenum
*****  type          num          id          ctitle
plenum          418          418 $418$ Down Pl in Water
*      npljn          iconc          juns1          juns2
*          2              0              0              0
*
*      juncs      *      418s      *Dec to Down Pl
*      juncs      *      426e      *Down Pl to Row1
*
*      dx      * f      7.6200e-02e
*      vol      *      5.0000e-01e
*      elev      *      -6.9149e+00e
*      alp      *      0.0000e+00e
*      tl      *      3.2615e+02e
*      tv      *      3.2615e+02e
*      p      *      6.93228e+05e
*      pa      *      0.0000e+00e
*
*
* Module 3 Upflow
*****  type          num          id          ctitle
pipe          409          409 $409$ Row1 water
*
*      ncells          nodes          jun1          jun2          epsw
*          5              0              426          409          1.0000e-05
*      ichf          iconc          iacc          ipow
*          1              0              0              0
*      radin          th          hout1          houtv          tout1

```

TRAC BLANKET SYSTEM MODEL

```

0.0000e+00  1.1130e-02  0.0000e+00  0.0000e+00  3.0000e+02
*   toutv
3.0000e+02

```

```

*
* dx   * r4  6.0960e-01  3.1980e-01e
* vol  * r4  1.1043e-02  5.7932e-03e
* fa   * f   1.8115e-02e
* fric *     7.5000e-01  r4 8.4840e-02  5.7897e-01e
* elev *     -6.5720e+00  -5.9624e+00  -5.3528e+00s
* elev *     -4.7432e+00  -4.2785e+00e
* hd   * f   5.7015e-03e
* nff  *     -1  r4      1          1e
* alp  * f   0.0000e+00e
* vl   * f   3.111e+00e
* vv   * f   3.111e+00e
* tl   * f   3.3515e+02e
* tv   * f   3.3515e+02e
* p    *     6.71423e+05  6.51297e+05  6.31231e+05  6.11214e+05s
* p    *     5.95872e+05e
* pa   * f   0.0000e+00e
*
*

```

* Water Upper Plenum in Loop11

* Upper Row1 Plenum

```

*****  type          num          id          ctitle
plenum          423          423      $423$ Upper R1
*      npljn          iconc          juns1          juns2
          2              0              0              0

```

```

* juncs *      409s      *R1 to Upper PL
* juncs *      423e      *Upper P1 to Outlet Header

```

```

* dx   * f   2.0320e-01e
* vol  *     5.0000e-01e
* elev *     -4.0170e+00e
* alp  *     0.0000e+00e
* tl   *     3.3815e+02e
* tv   *     3.3815e+02e
* p    *     5.89487e+05e
* pa   *     0.0000e+00e

```

* Water Pipe Before Water Return Manifold in Loop11

* Dec - Row 1 in Backstop 1st Module

```

*****  type          num          id          ctitle
pipe          417          417  $417$ Pipe conn.
*      ncells          nodes          jun1          jun2          epsw
          7              0              423          417          1.0000e-05
*      ichf          iconc          iacc          ipow
          1              0              0              0
*      radin          th          hout1          houtv          tout1
          4.7625e-02  1.1130e-02  0.0000e+00  0.0000e+00  3.0000e+02
*      toutv
3.0000e+02

```

```

* dx   * r2  2.0000e+00  1.0152e+00  r4 1.2500e+00e
* vol  * r2  1.4251e-02  7.2339e-03  r4 8.9070e-03e
* fa   * f   7.1256e-03e
* fric *     1.6577e-01  1.6577e-01  2.5685e-02  0.1700e+00s
* fric *     1.0361e-01  1.0361e-01  1.0361e-01  0.5000e+00e
* elev *     -3.0000e+00  -1.0000e+00  5.0760e-01  r4 1.0152e+00e

```


TRAC BLANKET SYSTEM MODEL

```

* hd * f 9.5250e-02e
* nff * 1 r6 1 1e
* alp * f 0.0000e+00e
* vl * f 7.936e+00e
* vv * f 7.936e+00e
* tl * f 3.3815e+02e
* tv * f 3.3815e+02e
* p * 5.39006e+05 5.06154e+05 4.84458e+05 4.69517e+05s
* p * 4.61013e+05 4.52510e+05 4.44007e+05e
* pa * f 0.0000e+00e
*
*
* ===== MODULE 4 (DOWNFLOW - PLENUM - UPFLOW) =====
*
* Water Pipe Connection After Water Supply Manifold in Loop12
* Water Pipe Connection in 2nd Layer Module Backstop
***** type num id ctitle
pipe 485 485 $485$ Pipe conn.
* ncells nodes jun1 jun2 epsw
7 0 485 87 1.0000e-05
* ichf iconc iacc ipow
1 0 0 0
* radin th hout1 houtv tout1
6.8265e-02 1.1130e-02 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
3.0000e+02
*
* dx * r2 6.2500e-01 7.6200e-01 r3 1.2500e+00 4.5000e-01e
* vol * r2 9.1500e-03 1.1156e-02 r3 1.8300e-02 6.5880e-03e
* fa * f 1.4640e-02e
* fric * 1.5000e-01 5.1803e-02 0.1700e+00 0.1700e+00s
* fric * 1.0361e-01 1.0361e-01 0.1700e+00 1.0000e-08e
* elev * r2 1.7772e+00 1.3962e+00 r3 1.0152e+00 7.9020e-01e
* hd * f 1.3653e-01e
* nff * 1 r6 1 -1e
* alp * f 0.0000e+00e
* vl * f 6.686e+00e
* vv * f 6.686e+00e
* tl * f 3.2315e+02e
* tv * f 3.2315e+02e
* p * 7.08492e+05 7.06076e+05 7.04606e+05 7.02499e+05s
* p * 6.97669e+05 6.92839e+05 6.89536e+05e
* pa * f 0.0000e+00e
*
*
* Decoupler Upper Plenum
***** type num id ctitle
plenum 87 87 $87$ Dec UpperPl
* npljn iconc juns1 juns2
2 0 0 0
*
* juncs * 87s *Inlet Hd to UP1
* juncs * 88e *UP1 to Decoupler
*
* dx * f 1.1520e-01e
* vol * 1.6865e-03e
* elev * 5.0760e-01e
* alp * 0.0000e+00e
* tl * 3.2215e+02e
* tv * 3.2215e+02e
* p * 7.13813e+05e
* pa * 0.0000e+00e

```

TRAC BLANKET SYSTEM MODEL

```

*
*
* Water Pipe Connection After Water Supply Manifold in Loop15
*****  type          num          id          ctitle
pipe          88      88 $88$ Pipe conn.
*          ncells      nodes      jun1      jun2      epsw
          3          0          88          489      1.0000e-05
*          ichf      iconc      iacc      ipow
          1          0          0          0
*          radin      th      hout1      houtv      tout1
          4.9213e-02      1.1130e-02      0.0000e+00      0.0000e+00      3.0000e+02
*          toutv
          3.0000e+02
*
* dx      *      4.5000e-01      r2      2.0000e+00e
* vol      *      6.5880e-03      r2      2.9280e-02e
* fa      * f      1.4640e-02e
* fric      *      1.0000e-08      5.0000e-02      5.0000e-02      1.0000e-08e
* elev      *      2.2500e-01      -1.0000e+00      -3.0000e+00e
* hd      * f      1.3653e-01e
* nff      *      -1      r2 1      -1e
* alp      * f      0.0000e+00e
* vl      * f      6.686e+00e
* vv      * f      6.686e+00e
* tl      * f      3.2315e+02e
* tv      * f      3.2315e+02e
* p      *      6.93871e+05      7.02160e+05      7.16394e+05e
* pa      * f      0.0000e+00e
*
*
* Water Decoupler Upper Plenum in Loop12
* Decoupler Upper Plenum in 2nd Layer Backstop
*****  type          num          id          ctitle
plenum          489      489      $489$ Dec UpperPl
*          npljn      iconc      juns1      juns2
          2          0          0          0
*
* juncs      *      489s      *Inlet Hd to UP1
* juncs      *      480e      *UP1 to Decoupler
*
* dx      * f      2.0320e-01e
* vol      *      5.0000e-01e
* elev      *      -4.0170e+00e
* alp      *      0.0000e+00e
* tl      *      3.2315e+02e
* tv      *      3.2315e+02e
* p      *      7.24285e+05e
* pa      *      0.0000e+00e
*
*
* Module 4 Downflow
*****  type          num          id          ctitle
pipe          480      480 $480$ Row 2 water
*
*          ncells      nodes      jun1      jun2      epsw
          6          0          480          419      1.0000e-05
*          ichf      iconc      iacc      ipow
          1          0          0          0
*          radin      th1      hout11      houtv1      tout11
          0.0000e-00      1.1130e-02      0.0000e+00      0.0000e+00      3.0000e+02
*          toutv1
          3.0000e+02

```

TRAC BLANKET SYSTEM MODEL

```

*
*
* dx      *      0.3198  r4  0.6096      0.7418e
* vol     *      1.1540e-02  r4  2.1997e-02  2.6768e-02e
* fa      * f      3.6085e-02e
* fric    *      4.4423e-01  r5  7.3700e-02  7.5000e-01e
* elev    *      -4.2785e+00  -4.7432e+00  -5.3528e+00s
* elev    *      -5.9624e+00  -6.5720e+00  -7.2477e+00e
* hd      * f      3.1198e-03e
* nff     * f      1e
* alp     * f      0.0000e+00e
* vl      * f      2.719e+00e
* vv      * f      2.719e+00e
* tl      * f      3.3015e+02e
* tv      * f      3.3015e+02e
* p       *      7.11357e+05  6.97515e+05  6.79536e+05  6.61680e+05s
* p       *      6.43890e+05  6.24228e+05e
* pa      * f      0.0000e+00e
*
*
* Module 4 Mid-plenum
***** type          num          id          ctitle
plenum          419          419 $419$ Down Pl in Water
*              npljn      iconc      juns1      juns2
*              2          0          0          0
*
* juncs *      419s  *Dec to Down Pl
* juncs *      487e  *Down Pl to Row1
*
* dx      * f      7.6200e-02e
* vol     *      5.0000e-01e
* elev    *      -7.6567e+00e
* alp     *      0.0000e+00e
* tl      *      3.3215e+02e
* tv      *      3.3215e+02e
* p       *      6.13407e+05e
* pa      *      0.0000e+00e
*
*
* Module 4 Upflow
***** type          num          id          ctitle
pipe          412          412 $412$ Row1 water
*
*          ncells      nodes      jun1      jun2      epsw
*          6          0          487      412      1.0000e-05
*          ichf      iconc      iacc      ipow
*          1          0          0          0
*          radin      th      hout1      houtv      tout1
*          0.0000e+00  1.1130e-02  0.0000e+00  0.0000e+00  3.0000e+02
*          toutv
*          3.0000e+02
*
* dx      *      0.7418  r4  0.6096      0.3198e
* vol     *      5.1601e-02  r4  4.2405e-02  2.2246e-02e
* fa      * f      6.9562e-02e
* fric    *      1.1236e+00  r5  9.0890e-02  7.2777e-01e
* elev    *      -7.2477e+00  -6.5720e+00  -5.9624e+00s
* elev    *      -5.3528e+00  -4.7432e+00  -4.2785e+00e
* hd      * f      5.1537e-03e
* nff     * f      1e
* alp     * f      0.0000e+00e
* vl      * f      1.422e+00e

```

TRAC BLANKET SYSTEM MODEL

```

* vv * f 1.422e+00e
* tl * f 3.4315e+02e
* tv * f 3.4315e+02e
* p * 6.04924e+05 5.94301e+05 5.84753e+05 5.75237e+05s
* p * 5.65735e+05 5.58474e+05e
* pa * f 0.0000e+00e
*
*
* Water Upper Plenum in Loop12
* Upper Row1 Plenum
*****
***** type num id ctitle
plenum 483 483 $483$ Upper R1
* npljn iconc juns1 juns2
* 2 0 0 0
*
* juncs * 412s *R1 to Upper PL
* juncs * 483e *Upper PL to Outlet Header
*
* dx * f 2.0320e-01e
* vol * 5.0000e-01e
* elev * -4.0170e+00e
* alp * 0.0000e+00e
* tl * 3.4615e+02e
* tv * 3.4615e+02e
* p * 5.54709e+05e
* pa * 0.0000e+00e
*
*
* Water Pipe Before Water Return Manifold in Loop12
***** type num id ctitle
pipe 484 484 $484$ Pipe conn.
* ncells nodes jun1 jun2 epsw
* 7 0 483 484 1.0000e-05
* ichf iconc iacc ipow
* 1 0 0 0
* radin th hout1 houtv tout1
* 6.8625e-02 1.1130e-02 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
* 3.0000e+02
*
* dx * r2 2.0000e+00 1.0152e+00 r4 1.2500e+00e
* vol * r2 2.9280e-02 1.4863e-02 r4 1.8300e-02e
* fa * f 1.4640e-02e
* fric * 1.6577e-01 1.6577e-01 2.5685e-02 0.1700e+00s
* fric * 1.0361e-01 1.0361e-01 1.0361e-01 0.5000e+00e
* elev * -3.0000e+00 -1.0000e+00 5.0760e-01 r4 1.0152e+00e
* hd * f 1.3653e-01e
* nff * 1 r6 1 1e
* alp * f 0.0000e+00e
* vl * f 6.771e+00e
* vv * f 6.771e+00e
* tl * f 3.4315e+02e
* tv * f 3.4315e+02e
* p * 5.16653e+05 4.89762e+05 4.71715e+05 4.60768e+05s
* p * 4.55935e+05 4.51102e+05 4.46270e+05e
* pa * f 0.0000e+00e
*
*

```

===== MODULE 5 (DOWNFLOW - PLENUM - UPFLOW) =====

* Water Pipe Connection After Water Supply Manifold in Loop13

TRAC BLANKET SYSTEM MODEL

```

***** type          num          id          ctitle
pipe          513      513 $513$ Pipe conn.
* ncells      nodes      jun1      jun2      epsw
  7            0          513        89      1.0000e-05
* ichf        iconc      iacc        ipow
  1            0          0          0
* radin       th        hout1      houtv      tout1
  7.6200e-02   1.1130e-02  0.0000e+00  0.0000e+00  3.0000e+02
* toutv
  3.0000e+02
*

```

```

* dx * r2 6.2500e-01 7.6200e-01 r3 1.2500e+00 4.5000e-01e
* vol * r2 1.1401e-02 1.3900e-02 r3 2.2803e-02 8.2089e-03e
* fa * f 1.8242e-02e
* fric * 1.5000e-01 5.1803e-02 0.1700e+00 0.1700e+00s
* fric * 1.0361e-01 1.0361e-01 0.1700e+00 1.0000e-08e
* elev * r2 1.7772e+00 1.3962e+00 r3 1.0152e+00 7.9020e-01e
* hd * f 1.5240e-01e
* nff * 1 r6 1 -1e
* alp * f 0.0000e+00e
* vl * f 6.360e+00e
* vv * f 6.360e+00e
* tl * f 3.2315e+02e
* tv * f 3.2315e+02e
* p * 7.11147e+05 7.09098e+05 7.08270e+05 7.06938e+05s
* p * 7.02841e+05 6.98744e+05 6.96149e+05e
* pa * f 0.0000e+00e
*

```

* Decoupler Upper Plenum

```

***** type          num          id          ctitle
plenum        89      89 $89$ Dec UpperPl
* npljn      iconc      juns1      juns2
  2            0          0          0
*

```

```

* juncs * 89s *Inlet Hd to UP1
* juncs * 90e *UP1 to Decoupler
*

```

```

* dx * f 1.1520e-01e
* vol * 2.1015e-03e
* elev * 5.0760e-01e
* alp * 0.0000e+00e
* tl * 3.2315e+02e
* tv * 3.2315e+02e
* p * 7.18438e+05e
* pa * 0.0000e+00e
*

```

* Water Pipe Connection After Water Supply Manifold in Loop15

```

***** type          num          id          ctitle
pipe          90      90 $90$ Pipe conn.
* ncells      nodes      jun1      jun2      epsw
  3            0          90        510      1.0000e-05
* ichf        iconc      iacc        ipow
  1            0          0          0
* radin       th        hout1      houtv      tout1
  4.9213e-02   1.1130e-02  0.0000e+00  0.0000e+00  3.0000e+02
* toutv
  3.0000e+02
*

```

```

* dx * 4.5000e-01 r2 2.0000e+00e
* vol * 8.2089e-03 r2 3.6484e-02e

```

TRAC BLANKET SYSTEM MODEL

```

* fa * f 1.8242e-02e
* fric * 1.0000e-08 5.0000e-02 5.0000e-02 1.0000e-08e
* elev * 2.2500e-01 -1.0000e+00 -3.0000e+00e
* hd * f 1.5240e-01e
* nff * -1 r2 1 -1e
* alp * f 0.0000e+00e
* vl * f 6.360e+00e
* vv * f 6.360e+00e
* tl * f 3.2315e+02e
* tv * f 3.2315e+02e
* p * 7.00717e+05 7.09616e+05 7.24779e+05e
* pa * f 0.0000e+00e

```

* Water Decoupler Upper Plenum in Loop13

* Decoupler Upper Plenum

```

***** type num id ctitle
plenum 510 510 $510$ Dec UpperPl
* npljn iconc juns1 juns2
2 0 0 0

```

```

* juncs * 510s *Inlet Hd to UPl
* juncs * 507e *UPl to Decoupler

```

```

* dx * f 2.0320e-01e
* vol * 5.0000e-01e
* elev * -4.0170e+00e
* alp * 0.0000e+00e
* tl * 3.2315e+02e
* tv * 3.2315e+02e
* p * 7.33156e+05e
* pa * 0.0000e+00e

```

* Module 5 Downflow

```

***** type num id ctitle
pipe 507 507 $507$ Decoupler water
* ncells nodes jun1 jun2 epsw
6 0 507 503 1.0000e-05
* ichf iconc iacc ipow
1 0 0 0
* radin1 th1 hout11 houtv1 tout11
0.0000e+00 1.1130e-02 0.0000e+00 0.0000e+00 3.0000e+02
* toutv1
3.0000e+02

```

```

* dx * 0.3198 r4 0.6096 0.7418e
* vol * 1.7412e-02 r4 3.3190e-02 4.0388e-02e
* fa * f 5.4446e-02e
* fric * 7.2950e-02 r5 7.3700e-02 7.5000e-01e
* elev * -4.2785e+00 -4.7432e+00 -5.3528e+00s
* elev * -5.9624e+00 -6.5720e+00 -7.2477e+00e
* hd * f 3.1519e-03e
* nff * f 1e
* alp * f 0.0000e+00e
* vl * f 2.131e+00e
* vv * f 2.131e+00e
* tl * f 3.2315e+02e
* tv * f 3.2315e+02e
* p * 7.26820e+05 7.19688e+05 7.10405e+05 7.01151e+05s

```

TRAC BLANKET SYSTEM MODEL

```

* p      *      6.91915e+05  6.81704e+05e
* pa     * f      0.0000e+00e
*
*
* Module 5 Mid-plenum
*****      type              num          id          ctitle
plenum              503              503 $503$ Down Pl in Water
*      npljn          iconc          juns1          juns2
*              2              0              0              0
*
* juncs *      503s      *Dec to Down Pl
* juncs *      504e      *Down Pl to Row1
*
* dx      * f      7.6200e-02e
* vol     *      5.0000e-01e
* elev    *      -7.6567e+00e
* alp     *      0.0000e+00e
* tl      *      3.2515e+02e
* tv      *      3.2515e+02e
* p       *      6.76187e+05e
* pa      *      0.0000e+00e
*
*
* Module 5 Upflow
*****      type              num          id          ctitle
pipe              500              500 $500$ Row1 water
*
*      ncells          nodes          jun1          jun2          epsw
*              6              0              504          500          1.0000e-05
*      ichf          iconc          iacc          ipow
*              1              0              0              0
*      radin          th          hout1          houtv          tout1
*      0.0000e+00      1.1130e-02      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02
*
* dx      *      0.7418      r4      0.6096      0.3198e
* vol     *      4.0388e-02r4      3.3190e-02      1.7412e-02e
* fa      * f      5.4446e-02e
* fric    *      7.5000e-01      r5 7.3700e-02      7.2950e-01e
* elev    *      -7.2477e+00      -6.5720e+00      -5.9624e+00s
* elev    *      -5.3528e+00      -4.7432e+00      -4.2785e+00e
* hd      * f      3.1519e-03e
* nff     * f      1e
* alp     * f      0.0000e+00e
* vl      * f      2.137e+00e
* vv      * f      2.137e+00e
* tl      * f      3.2815e+02e
* tv      * f      3.2815e+02e
* p       *      6.58253e+05      6.34994e+05      6.14038e+05      5.93114e+05s
* p       *      5.72203e+05      5.56226e+05e
* pa      * f      0.0000e+00e
*
*
* Water Upper Plenum in Loop13
* Upper Row1 Plenum
*****
*****      type              num          id          ctitle
plenum              508              508      $508$ Upper R1
*      npljn          iconc          juns1          juns2
*              2              0              0              0
*

```

TRAC BLANKET SYSTEM MODEL

* juncs * 500s *R1 to Upper PL
 * juncs * 508e *Upper Pl to Outlet Header
 *

* dx * f 2.0320e-01e
 * vol * 5.0000e-01e
 * elev * -4.0170e+00e
 * alp * 0.0000e+00e
 * tl * 3.3015e+02e
 * tv * 3.3015e+02e
 * p * 5.47939e+05e
 * pa * 0.0000e+00e
 *

* Water Pipe Before Water Return Manifold in Loop13

*****	type	num	id	ctitle	
pipe		511	511	\$511\$ Pipe conn.	
*	ncells	nodes	jun1	jun2	epsw
	7	0	508	511	1.0000e-05
*	ichf	iconc	iacc	ipow	
	1	0	0	0	
*	radin	th	hout1	houtv	tout1
	7.6200e-02	1.1130e-02	0.0000e+00	0.0000e+00	3.0000e+02
*	toutv				
	3.0000e+02				

* dx * r2 2.0000e+00 1.0152e+00 r4 1.2500e+00e
 * vol * r2 3.6484e-02 1.8519e-02 r4 2.2803e-02e
 * fa * f 1.8242e-02e
 * fric * 1.6577e-01 1.6577e-01 2.5685e-02 0.1700e+00s
 * fric * 1.0361e-01 1.0361e-01 1.0361e-01 0.5000e+00e
 * elev * -3.0000e+00 -1.0000e+00 5.0760e-01 r4 1.0152e+00e
 * hd * f 1.5240e-01e
 * nff * 1 r6 1 1e
 * alp * f 0.0000e+00e
 * vl * f 6.381e+00e
 * vv * f 6.381e+00e
 * tl * f 3.3015e+02e
 * tv * f 3.3015e+02e
 * p * 5.12934e+05 4.87045e+05 4.69522e+05 4.59378e+05s
 * p * 4.55284e+05 4.51189e+05 4.47095e+05e
 * pa * f 0.0000e+00e
 *

* ===== MODULE 6 (DOWNFLOW - PLENUM - UPFLOW) =====

* Water Pipe Connection After Water Supply Manifold in Loop15

*****	type	num	id	ctitle	
pipe		541	541	\$541\$ Pipe conn.	
*	ncells	nodes	jun1	jun2	epsw
	7	0	541	83	1.0000e-05
*	ichf	iconc	iacc	ipow	
	1	0	0	0	
*	radin	th	hout1	houtv	tout1
	4.9213e-02	1.1130e-02	0.0000e+00	0.0000e+00	3.0000e+02
*	toutv				
	3.0000e+02				

* dx * r2 6.2500e-01 7.6200e-01 r3 1.2500e+00 4.5000e-01e
 * vol * r2 3.8973e-02 4.7515e-02 r3 7.7945e-02 2.8060e-02e
 * fa * f 6.2356e-02e
 * fric * 1.5000e-01 5.0000e-02 0.1700e+00 0.1700e+00s
 * fric * 5.0000e-02 5.0000e-02 0.1700e+00 1.0000e-08e

TRAC BLANKET SYSTEM MODEL

```

* elev *      1.7772e+00      1.7772e+00      1.3962e+00      1.0152e+00s
* elev *      1.0152e+00      1.0152e+00      7.9020e-01e
* hd * f      9.8425e-02e
* nff *      1      r6 1      -1e
* alp * f      0.0000e+00e
* vl * f      6.569e+00e
* vv * f      6.569e+00e
* tl * f      3.2315e+02e
* tv * f      3.2315e+02e
* p *      7.08881e+05      7.06003e+05      7.04061e+05      7.01215e+05s
* p *      6.96526e+05      6.91838e+05      6.87929e+05e
* pa * f      0.0000e+00e

```

* Decoupler Upper Plenum

```

***** type          num          id          ctitle
plenum          83          83          $83$ Dec UpperPl
*      npljn          iconc          juns1          juns2
*      2              0              0              0

```

```

* juncs *      83s      *Inlet Hd to UPl
* juncs *      84e      *UPl to Decoupler

```

```

* dx * f      1.1520e-01e
* vol *      7.1834e-03e
* elev *      5.0760e-01e
* alp *      0.0000e+00e
* tl *      3.2315e+02e
* tv *      3.2315e+02e
* p *      7.11192e+05e
* pa *      0.0000e+00e

```

* Water Pipe Connection After Water Supply Manifold in Loop15

```

***** type          num          id          ctitle
pipe          84          84 $84$ Pipe conn.
*      ncells          nodes          jun1          jun2          epsw
*      8              0              84          538          1.0000e-05
*      ichf          iconc          iacc          ipow
*      1              0              0              0
*      radin          th          hout1          houtv          tout1
*      4.9213e-02      1.1130e-02      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02

```

```

* dx *      4.5000e-01      r7      9.9330e-01e
* vol *      2.8060e-02      r7      6.1938e-02e
* fa * f      6.2356e-02e
* fric *      1.0000e-08      5.0000e-02      5.0000e-02      5.0000e-02s
* fric *      5.0000e-02      5.0000e-02      5.0000e-02      5.0000e-02s
* fric *      1.0000e-08e
* elev *      2.2500e-01      -4.9665e-01      -1.4899e+00      -2.4832e+00s
* elev *      -3.4765e+00      -4.4698e+00      -5.4631e+00      -6.4564e+00e
* hd * f      9.8425e-02e
* nff *      -1      r7 1      -1e
* alp * f      0.0000e+00e
* vl * f      6.569e+00e
* vv * f      6.569e+00e
* tl * f      3.2315e+02e
* tv * f      3.2315e+02e
* p *      6.91775e+05      6.95618e+05      7.01308e+05      7.06999e+05s
* p *      7.12690e+05      7.12690e+05      7.24073e+05      7.29764e+05e

```

TRAC BLANKET SYSTEM MODEL

* pa * f 0.0000e+00e

*

*

* Water Decoupler Upper Plenum in Loop15

* Decoupler Upper Plenum

*****	type	num	id	ctitle
plenum		538	538	\$538\$ Dec UpperPl
*	npljn	iconc	juns1	juns2
	2	0	0	0

*

* juncs * 538s *Inlet Hd to UP1
 * juncs * 535e *UP1 to Decoupler

*

* dx * f 8.5060e-02e
 * vol * 5.0000e-01e
 * elev * -6.9956e+00e
 * alp * 0.0000e+00e
 * tl * 3.2315e+02e
 * tv * 3.2315e+02e
 * p * 7.33883e+05e
 * pa * 0.0000e+00e

*

*

* Decoupler Water in Loop15

* Water in Decoupler

*****	type	num	id	ctitle
pipe		535	535	\$535\$ Decoupler water
*	ncells	nodes	jun1	jun2
	5	0	535	531
				1.0000e-05
*	ichf	iconc	iacc	ipow
	1	0	0	0
*	radin1	th1	hout11	houtv1
	4.7632e-03	1.1130e-02	0.0000e+00	0.0000e+00
				3.0000e+02
*	toutv1			
	3.0000e+02			

*

*

* dx * 4.9580e-01 r4 4.9580e-01e
 * vol * 7.9412e-02 r4 7.9412e-02e
 * fa * f 1.6017e-01e
 * fric * 7.8128e-01 r4 3.6096e-01 4.9804e-01e
 * elev * -7.0381e+00 -7.0381e+00 -7.0381e+00s
 * elev * -7.0381e+00 -7.0381e+00e
 * hd * f 9.5264e-03e
 * nff * 1 r4 -1 1e
 * alp * f 0.0000e+00e
 * vl * f 2.557e+00e
 * vv * f 2.557e+00e
 * tl * f 3.2315e+02e
 * tv * f 3.2315e+02e
 * p * 7.26093e+05 7.20760e+05 7.15426e+05 7.10093e+05s
 * p * 7.04759e+05e
 * pa * f 0.0000e+00e

*

*

* Lower Water Plenum in Loop15

* Plenum for Lumped Single Loop Blanket System

*****	type	num	id	ctitle
-------	------	-----	----	--------

TRAC BLANKET SYSTEM MODEL

```

plenum          531          531      $531$ Down Pl in Water
*      npljn      iconc      juns1      juns2
*          2          0          0          0
*
* juncs * 531s *Dec to Down Pl
* juncs * 532e *Down Pl to Row1
*
* dx * f 2.7216e-01e
* vol * 5.0000e-01e
* elev * -7.0381e+00e
* alp * 0.0000e+00e
* tl * 3.2315e+02e
* tv * 3.2315e+02e
* p * 7.03157e+05e
* pa * 0.0000e+00e
*
*
* Row1 Water in Loop 15 (Lower Back Module)
* Row1
***** type          num          id          ctitle
pipe          528          528 $528$ Row1 water
*
*      ncells      nodes      jun1          jun2          epsw
*          5          0          532          528          1.0000e-05
*      ichf      iconc      iacc      ipow
*          1          0          0          0
*      radin      th      hout1      houtv      tout1
*      7.8378e-02      1.1130e-02      0.0000e+00      0.0000e+00      3.0000e+02
*      toutv
*      3.0000e+02
*
* dx * r4 4.9580e-01      4.9580e-01e
* vol * r4 7.4360e-02      7.4360e-02e
* fa * f 1.4998e-01e
* fric * 7.1423e-01      r4 7.4290e-02      7.5000e-01e
* elev * -7.1317e+00      -7.1317e+00      -7.1317e+00s
* elev * -7.1317e+00      -7.1317e+00e
* hd * f 3.6243e-03e
* nff * 1 r4          1          1e
* alp * f 0.0000e+00e
* vl * f 2.733e+00e
* vv * f 2.733e+00e
* tl * f 3.2415e+02e
* tv * f 3.2415e+02e
* p * 6.85250e+05      6.68875e+05      6.52523e+05      6.36191e+05s
* p * 6.19881e+05e
* pa * f 0.0000e+00e
*
*
* Water Upper Plenum in Loop15
* Upper Row1 Plenum
*****
***** type          num          id          ctitle
plenum          536          536      $536$ Upper R1
*      npljn      iconc      juns1      juns2
*          2          0          0          0
*
* juncs * 528s *R1 to Upper PL
* juncs * 536e *Upper Pl to Outlet Header
*
* dx * f 1.8710e-01e
* vol * 5.0000e-01e

```

TRAC BLANKET SYSTEM MODEL

```

* elev * -7.1317e+00e
* alp * 0.0000e+00e
* tl * 3.2615e+02e
* tv * 3.2615e+02e
* p * 6.09765e+05e
* pa * 0.0000e+00e
*
*
* Water Pipe Before Water Return Manifold in Loop15
***** type num id ctitle
pipe 539 539 $539$ Pipe conn.
* ncells nodes jun1 jun2 epsw
12 0 536 539 1.0000e-05
* ichf iconc iacc ipow
1 0 0 0
* radin th houtl houtv toutl
4.9213e-02 1.1130e-02 0.0000e+00 0.0000e+00 3.0000e+02
* toutv
3.0000e+02
*
* dx * r7 1.0055e+00 1.0152e+00 r4 1.2500e+00e
* vol * r7 6.2699e-02 6.3304e-02 r4 7.7945e-02e
* fa * f 6.2356e-02e
* fric * 5.0000e-02 5.0000e-02 5.0000e-02 5.0000e-02s
* fric * 5.0000e-02 5.0000e-02 5.0000e-02 5.0000e-02s
* fric * 0.1700e+00 5.0000e-02 5.0000e-02 5.0000e-02s
* fric * 0.5000e+00e
* elev * -6.5354e+00 -5.5300e+00 -4.5245e+00 -3.5191e+00s
* elev * -2.5136e+00 -1.5082e+00 -5.0273e-01 5.0760e-01s
* elev * r4 1.0152e+00e
* hd * f 9.8425e-02e
* nff * -1 r11 1 1e
* alp * f 0.0000e+00e
* vl * f 6.580e+00e
* vv * f 6.580e+00e
* tl * f 3.2615e+02e
* tv * f 3.2615e+02e
* p * 5.69483e+05 5.55771e+05 5.42059e+05 5.28347e+05s
* p * 5.14634e+05 5.00923e+05 4.87211e+05 4.73438e+05s
* p * 4.61615e+05 4.56933e+05 4.52252e+05 4.47571e+05e
* pa * f. 0.0000e+00e
*
*
* =====
* ===== CAVITY BREAK CONNECTIONS =====
* =====
*
***** type num id ctitle
valve 840 840 $840$ Cavity line to Hot Module
* ncells nodes jun1 jun2 epsw
2 0 841 840 5.0000e-05
* ichf iconc ivty ivps nvth2
0 0 3 2 0
* ivtr ivsv nvth1 nvsv nvrf
108 8 -6 0 0
* ivtrov ivtyov
0 0
* rvmx rvov fminov fmaxov
1.0000e+01 0.0000e+00 0.0000e+00 1.0000e+00
* radin th houtl houtv toutl
0.0000e-00 8.1800e-03 0.0000e+00 0.0000e+00 3.3300e+00

```

TRAC BLANKET SYSTEM MODEL

```

*      toutv      avlve      hvlve      favlve      xpos
*      3.3300e+00  2.9280e-02  1.9308e-01  0.0000e+00  0.0000e+00
*
*
* dx      * f      0.5e
* vol     * f      6.0931e-02e
* fa      * f      0.121862e
* fric    * f      1.0000e-08e
* elev    * f      0.5076e
* hd      * f      3.9390e-01e
* nff     *      -1  1  -1e
* alp     *      0.0  1.0e
* vl      * f      0.0000e+00e
* vv      * f      0.0000e+00e
* tl      * f      3.3300e+02e
* tv      * f      3.3300e+02e
* p       *      7.05858e+05  3.41852e+04e
* pa      *      0.00000e+00  2.82855e+04e
*
* vtbl    *      0.000      0.000s
* vtbl    *      0.200      0.104s
* vtbl    *      0.400      0.352s
* vtbl    *      0.600      0.648s
* vtbl    *      0.800      0.896s
* vtbl    *      1.000      1.000e
*
*
*****  type      num      id      ctitle
valve      850      850 $850$ Cav Ves-to-HR (HR side)
*      ncells      nodes      jun1      jun2      epsw
*      2      0      851      850      5.0000e-05
*      ichf      iconc      ivty      ivps      nvtb2
*      0      0      3      2      0
*      ivtr      ivsv      nvtbl      nvsv      nvrf
*      109      9      -6      0      0
*      ivtrov      ivtyov
*      0      0
*      rvmx      rvov      fminov      fmaxov
*      1.0000e+01  0.0000e+00  0.0000e+00  1.0000e+00
*      radin      th      houtl      houtv      toutl
*      0.0000e-00  8.1800e-03  0.0000e+00  0.0000e+00  3.3300e+00
*      toutv      avlve      hvlve      favlve      xpos
*      3.3300e+00  3.5872e-01  6.7582e-01  0.0000e+00  0.0000e+00
*
*
* dx      * f      0.5e
* vol     *      3.3125e-01  7.0880e-01e
* fa      *      3.5872e-01  9.6629e-01  1.8689e+00e
* fric    * f      1.0000e-08e
* elev    * f      5.5560e
* hd      *      6.7582e-01  1.1092e+00  1.5426e+00e
* nff     *      -1  -1  -1e
* alp     *      0.0  1.0e
* vl      * f      0.0000e+00e
* vv      * f      0.0000e+00e
* tl      * f      3.3300e+02e
* tv      * f      3.3300e+02e
* p       *      7.16135e+05  3.41785e+04e
* pa      *      0.00000e+00  2.82800e+04e
*
* vtbl    *      0.000      0.000s
* vtbl    *      0.200      0.104s

```

TRAC BLANKET SYSTEM MODEL

```

* vtbl *      0.400      0.352s
* vtbl *      0.600      0.648s
* vtbl *      0.800      0.896s
* vtbl *      1.000      1.000e
*
*
*****  type          num          id          ctitle
valve          852          852 $852$ Cav Ves-to-HR (Header side)
*      ncells          nodes          jun1          jun2          epsw
*          2              0              853          852          5.0000e-05
*      ichf          iconc          ivty          ivps          nvth2
*          0              0              3              2              0
*      ivtr          ivsv          nvth1          nvsv          nvrf
*          109            9              -6              0              0
*      ivtrov          ivtyov
*          0              0
*      rvmx          rvov          fminov          fmaxov
*      1.0000e+01      0.0000e+00      0.0000e+00      1.0000e+00
*      radin          th          hout1          houtv          tout1
*      0.0000e-00      8.1800e-03      0.0000e+00      0.0000e+00      3.3300e+00
*      toutv          avlve          hvlve          favlve          xpos
*      3.3300e+00      3.5872e-01      6.7582e-01      0.0000e+00      0.0000e+00
*
*
* dx      * f      0.5e
* vol      *      3.3125e-01      7.0880e-01e
* fa      *      3.5872e-01      9.6629e-01      1.8689e+00e
* fric      * f      1.0000e-08e
* elev      * f      5.5560e
* hd      *      6.7582e-01      1.1092e+00      1.5426e+00e
* nff      *      -1      -1      -1e
* alp      *      0.0      1.0e
* vl      * f      0.0000e+00e
* vv      * f      0.0000e+00e
* tl      * f      3.3300e+02e
* tv      * f      3.3300e+02e
* p      *      7.16135e+05      3.41785e+04e
* pa      *      0.00000e+00      2.82800e+04e
*
* vtbl *      0.000      0.000s
* vtbl *      0.200      0.104s
* vtbl *      0.400      0.352s
* vtbl *      0.600      0.648s
* vtbl *      0.800      0.896s
* vtbl *      1.000      1.000e
*
*

```

```

* =====
* ===== CAVITY FLOOD POOL =====
* =====
*

```

```

*****  type          num          id          ctitle
break          801          801 $801$ bk BC on cavity pool
*      jun1          ibty          isat          ioff
*          810              0              0              0
*      dxin          volin          alpin          tin          pin
*      1.0000e+00      1.3936e+02      1.0000e+00      3.1315e+02      1.0133e+05
*      pain          concin          rbmx          poff          belv
*      9.3946e+04      0.0000e+00      1.0000e+02      0.0000e+00      8.0736e+00
*
*

```

TRAC BLANKET SYSTEM MODEL

```

*****  type          num          id          ctitle
pipe          810          810 $810$ pool top section
*          ncells      nodes      jun1      jun2      epsw
          10          0          810          811      5.0000e-05
*          ichf      iconc      iacc      ipow
          1          0          0          0
*          radin      th      hout1      houtv      tout1
          0.0000e+01      2.5400e-02      0.0000e+00      0.0000e+00      3.1315e+02
*          toutv      powin      powoff      rpowmx      powscl
          3.1315e+02

```

```

*
*
* dx * f 1.0000e+00e
* vol * f 1.3936e+02e
* fa * f 1.3936e+02e
* fric * f 1.0000e-08e
* elev * 7.0736 6.0736 5.0736 4.0736 3.0736s
* elev * 2.0736 1.0736 0.0736 -0.9264 -1.9264e
* hd * f 1.3320e+01e
* nff * 1 r10 1e
* alp * 0.5243 r9 0.0000e+00e
* vl * 2.728e+00 r10 0.0000e+00e
* vv * 0.0000e+00 -3.387e-01 r9 0.0000e+00e
* tl * f 3.1315e+02e
* tv * f 3.1315e+02e
* p * 1.03466e+05 1.10644e+05 1.20380e+05 1.30116e+05s
* p * 1.39852e+05 1.49589e+05 1.59325e+05 1.69062e+05s
* p * 1.78798e+05 1.88535e+05e
* pa * 9.60571e+04 r9 0.0000e+00e

```

```

*****  type          num          id          ctitle
plenum          811          811 $811$ Pool middle section
*          npljn      iconc      juns1      juns2
          3          0          0          0

```

```

* juncs * 811s * Pool upper section connection
* juncs * 812s * Pool lower section connection
* juncs * 820e * Cavity flood valve connection

```

```

* dx. * 1.0 1.0 10.55e
* vol * 1.3936e+02e
* elev * -2.9264e+00e
* alp * 0.0000e+00e
* tl * 3.1315e+02e
* tv * 3.1315e+02e
* p * f 1.98271e+05e
* pa * f 0.0000e+00e

```

```

*****  type          num          id          ctitle
pipe          812          812 $812$ pool lower section
*          ncells      nodes      jun1      jun2      epsw
          7          0          812          813      5.0000e-05
*          ichf      iconc      iacc      ipow
          1          0          0          0
*          radin      th      hout1      houtv      tout1
          0.0000e+01      2.5400e-02      0.0000e+00      0.0000e+00      3.1315e+02
*          toutv      powin      powoff      rpowmx      powscl
          3.1315e+02

```

```

* dx * f 1.5286e-00e

```

TRAC BLANKET SYSTEM MODEL

```

* vol * f 2.1303e+02e
* fa * f 1.3936e+02e
* fric * f 0.0000e+00e
* elev * -4.1907 -5.7193 -7.2479 -8.7765s
* elev * -10.3051 -11.8337 -13.3623e
* hd * f 1.3320e+01e
* nff * f 1e
* alp * f 0.0000e+00e
* vl * f 0.0000e+00e
* vv * f 0.0000e+00e
* tl * f 3.1315e+02e
* tv * f 3.1315e+02e
* p * 2.10581e+05 2.25465e+05 2.40348e+05 2.55232e+05s
* p * 2.70116e+05 2.84999e+05 2.99883e+05e
* pa * f 0.0000e+00e

```

```

***** type num id ctitle
plenum 813 813 $813$ pool bottom
* npljn iconc juns1 juns2
1 0 0 0

```

```

* juncs * 813e *connected to pool 4

```

```

* dx * 1.5311e-01e
* vol * 2.1338e+01e
* elev * -1.4203e+01e
* alp * 0.0000e+00e
* tl * 3.1315e+02e
* tv * 3.1315e+02e
* p * 3.08069e+05e
* pa * 0.0000e+00e

```

```

=====
===== CAVITY FLOOD LINE =====
=====

```

```

***** type num id ctitle
pipe 820 820 $820$ Flood line external
* ncells nodes jun1 jun2 epsw
13 0 820 821 5.0000e-05
* ichf iconc iacc ipow
1 0 0 0
* radin th houtl houtv toutl
0.0000e-01 1.0000e-02 0.0000e+00 0.0000e+00 3.1315e+02
* toutv powin powoff rpownx powsc1
3.1315e+02

```

```

* dx * r2 1.25 r6 1.0 r3 1.8334 r2 1.053e
* vol * r2 9.0134e-02 r6 7.2107e-02 r3 1.322e-01s
* vol * r2 7.5929e-02e
* fa * f 7.2107e-02e
* fric * r8 1.0000e-08 0.172 r2 1.0000e-08s
* fric * 0.172 r2 1.0000e-08e
* elev * r2 -2.9264 -3.0387 -3.2632 -3.4877 -3.7122s
* elev * -3.9367 -4.1612 -5.1902 -7.0236 -8.8570s
* elev * r2 -9.7737e
* hd * f 3.0300e-01e
* nff * -1 r13 1e

```


TRAC BLANKET SYSTEM MODEL

```

* alp * f 0.0000e+00e
* vl * f 0.0000e+00e
* vv * f 0.0000e+00e
* tl * f 3.1315e+02e
* tv * f 3.1315e+02e
* pn * 1.98262e+05 1.98262e+05 1.99345e+05 2.01511e+05s
* pn * 2.03678e+05 2.05844e+05 2.08010e+05 2.10176e+05s
* pn * 2.20104e+05 2.37793e+05 2.55482e+05 2.64327e+05s
* pn * 2.64327e+05e
* pan * f 0.00000e+04e
*
*
***** type num id ctitle
valve 821 821 $821$ Cavity flood line valve
* ncells nodes jun1 jun2 epsw
2 0 821 822 5.0000e-05
* ichf iconc ivty ivps nvtb2
0 0 3 2 0
* ivtr ivsv nvtb1 nvsv nvrf
102 12 -6 0 0
* ivtrov ivtyov
0 0
* rvmx rvov fminov fmaxov
1.0000e+01 0.0000e+00 0.0000e+00 1.0000e+00
* radin th hout1 houtv tout1
0.0000e-00 1.0000e-02 0.0000e+00 0.0000e+00 3.1315e+02
* toutv avlve hvlve favlve xpos
3.1315e+02 7.2107e-02 3.0300e-01 0.0000e+00 0.0000e+00
*
*
* dx * 1.5 1.0e
* vol * 1.0816e-01 7.2107e-02e
* fa * f 7.2107e-02e
* fric * 1.0000e-08 0.088 0.172e
* elev * f -9.7737e+00e
* hd * f 3.0300e-01e
* nff * f 1e
* alp * 0.0000e+00 1.0000e+00e
* vl * f 0.0000e+00e
* vv * f 0.0000e+00e
* tl * 3.1315e+02 3.3300e+02e
* tv * 3.1315e+02 3.3300e+02e
* p * 2.64327e+05 3.42228e+04e
* pa * 0.0000e+00 2.83164e+04e
*
* vtbl * 0.0 0.000s
* vtbl * 0.2 0.104s
* vtbl * 0.4 0.352s
* vtbl * 0.6 0.648s
* vtbl * 0.8 0.896s
* vtbl * 1.0 1.000e
*
***** type num id ctitle
pipe 822 822 $822$ Flood line internal
* ncells nodes jun1 jun2 epsw
1 0 822 823 5.0000e-05
* ichf iconc iacc ipow
1 0 0 0
* radin th hout1 houtv tout1
0.0000e-01 1.0000e-02 0.0000e+00 0.0000e+00 3.3300e+02
* toutv powin powoff rpowmx powsc1

```

TRAC BLANKET SYSTEM MODEL

```

3.3300e+02
*
* dx      * f    0.5e
* vol     * f    3.6053e-02e
* fa      * f    7.2107e-02e
* fric    *      0.172   1.0000e-08e
* elev    *      -9.5237e
* hd      * f    3.0300e-01e
* nff     *      1      -1e
* alp     * f    1.0000e+00e
* vl      * f    0.0000e+00e
* vv      * f    0.0000e+00e
* tl      * f    3.3300e+02e
* tv      * f    3.3300e+02e
* pn      *      3.42220e+04e
* pan     *      2.83159e+04e
*
*
* =====
* ===== CAVITY VESSEL =====
* =====
*
*
*****      type          num          id          ctitle
pipe          823          823 $823$ Cavity lower section
*      ncells          nodes          jun1          jun2          epsw
*          11              0              823          824          5.0000e-05
*      ichf          iconc          iacc          ipow
*          1              0              1              0
*      radin          th          hout1          houtv          tout1
*      0.0000e-01      1.0000e-02      0.0000e+00      0.0000e+00      3.3300e+02
*      toutv          powin          powoff          rpowmx          powscl
*      3.3300e+02
*
* dx      *      1.6551   0.7418   r4 0.6096   0.3198   r4 1.0297e
* vol     *      9.2358   4.1394   r4 3.4017   1.7845   r4 5.7457e
* fa      *      7.2107e-02   r11 5.5802e
* fric    * f    1.0000e-08e
* elev    *      -8.4462   -7.2477   -6.572   -5.9624   -5.3528s
* elev    *      -4.7432   -4.2785   -3.6038   -2.5741   -1.5445s
* elev    *      -0.51483e
* hd      *      0.303   r11 2.6655e
* nff     *      -1   r10 1   -1e
* alp     * f    1.0000e+00e
* vl      * f    0.0000e+00e
* vv      * f    0.0000e+00e
* tl      * f    3.3300e+02e
* tv      * f    3.3300e+02e
* p       *      3.42146e+04   3.42107e+04   3.42084e+04   3.42064e+04s
* p       *      3.42044e+04   3.42024e+04   3.42009e+04   3.41987e+04s
* p       *      3.41953e+04   3.41919e+04   3.41885e+04e
* pa      *      2.83093e+04   2.83029e+04   2.83015e+04   2.83009e+04s
* pa      *      2.83001e+04   2.82984e+04   2.82965e+04   2.82963e+04s
* pa      *      2.82933e+04   2.82905e+04   2.82877e+04e
*
*
*****      type          num          id          ctitle
plenum          824          824 $824$ Cavity Module bk loc.
*      npljn          iconc          juns1          juns2
*          3              0              0              0
*
* juncs *      824s      * Cavity lower section connection

```

TRAC BLANKET SYSTEM MODEL

```

* juncs *      825s      * Cavity middle section connection
* juncs *      840e      * Cavity line connection to Hot Module
*
* dx      * r2  1.0152    9.0964e
* vol     *      1.0696e+02e
* elev    *      0.5076e
* alp     *      1.0000e+00e
* tl      *      3.3300e+02e
* tv      *      3.3300e+02e
* p       * f   3.41852e+04e
* pa      * f   2.82855e+04e
*
*
*****      type          num          id          ctitle
pipe         825          825 $825$ Cavity middle section
*      ncells          nodes          jun1          jun2          epsw
          4              0              825          826          5.0000e-05
*      ichf            iconc          iacc          ipow
          1              0              1              0
*      radin            th          houtl          houtv          toutl
          0.0000e-01      1.0000e-02      0.0000e+00      0.0000e+00      3.3300e+02
*      toutv            powin          powoff          rpowmx          powscl
          3.3300e+02
*
* dx      *      1.0168    r3 1.0267e
* vol     *      1.0713e+02    r3 1.08168e+02e
* fa      * f   1.0536e+02e
* fric    * f   1.0000e-08e
* elev    *      1.5236    2.5454    3.5721    4.5988e
* hd      * f   11.582e
* nff     * f   1e
* alp     * f   1.0000e+00e
* vl      * f   0.0000e+00e
* vv      * f   0.0000e+00e
* tl      * f   3.3300e+02e
* tv      * f   3.3300e+02e
* p       * f   3.41818e+04e
* pa      * f   2.82822e+04e
*
*
*****      type          num          id          ctitle
plenum       826          826 $826$ Cavity HR bk loc.
*      npljn            iconc          juns1          juns2
          4              0              0              0
*
* juncs *      826s      * Cavity middle section connection
* juncs *      828s      * Cavity vent valve connection
* juncs *      850s      * Cavity line connection to HR line (HR side)
* juncs *      852e      * Cavity line connection to HR line (Header side)
*
* dx      * r2  0.888    r2 9.0964e
* vol     *      9.35552e+01e
* elev    *      5.556e
* alp     *      1.0000e+00e
* tl      *      3.3300e+02e
* tv      *      3.3300e+02e
* p       * f   3.41785e+04e
* pa      * f   2.82800e+04e
*
*
*****      type          num          id          ctitle
valve       828          828 $828$ cavity vent valve

```

TRAC BLANKET SYSTEM MODEL

```

*      ncells      nodes      jun1      jun2      epsw
*      3           0          828      829      5.0000e-05
*      ichf        iconc      ivty      ivps      nvtyb2
*      0           0          3         3         0
*      ivtr        ivsv      nvtyb1     nvsv      nvrf
*      110         3         -6         0         0
*      ivtrov      ivtyov
*      0           0
*      rvmx        rvov      fminov      fmaxov
*      1.0000e+01  0.0000e+00  0.0000e+00  1.0000e+00
*      radin       th        hout1     houtv      tout1
*      0.0000e-00  8.1800e-03  0.0000e+00  0.0000e+00  3.3300e+00
*      toutv       avlve     hvlve     favlve     xpos
*      3.3300e+00  3.2429e-02  2.0320e-01  0.0000e+00  0.0000e+00

```

```

*
* dx      *      1.0156e+00  r2 1.0000e+00e
* vol     *      1.0701e+02  r2 7.2107e-02e
* fa      *      1.0536e+02  r3 7.2107e-02e
* fric    * f      1.0000e-08e
* elev    *      6.5078   7.5156   8.5156e
* hd      *      1.1582e+01  r3 3.0300e-01e
* nff     * r2     -1      r2 1e
* alp     * f      1.0000e+00e
* vl      * f      0.0000e+00e
* vv      * f      0.0000e+00e
* tl      * f      3.3300e+02e
* tv      * f      3.3300e+02e
* p       *      3.4165e+04   3.41622e+04   1.01340e+05e
* pa      *      2.82690e+04   2.82662e+04   9.76470e+04e
*
* vtbl1   *      0.0   0.000s
* vtbl1   *      0.2   0.104s
* vtbl1   *      0.4   0.352s
* vtbl1   *      0.6   0.648s
* vtbl1   *      0.8   0.896s
* vtbl1   *      1.0   1.000e

```

```

***** type      num      id      ctitle
break      .      802      802 $802$ Cavity vent press. BC
*      jun1      ibty      isat      ioff
*      829       0         0         0
*      dxin      volin      alpin      tin      pin
*      1.0000e+00  7.2107e-02  1.0000e+00  3.3300e+02  1.0133e+05
*      pain      concin     rbmx      poff      belv
*      9.3946e+04  0.0000e+00  1.0000e+02  0.0000e+00  9.5156e+00

```

```

* =====
* ===== HEAT STRUCTURES =====
* =====

```

```

* ===== MODULE 1 (UPFLOW) =====

```

```

* Upflow (Heated Al structure connected to Water & Cavity)
***** type      num      id      ctitle
rod      .      901      901 $901$He to Aluminum and then water
*      ncrx      ncrz      ittc
*      1         5         0
*      nopowr     nrldr     modez     liqlev     iaxcnd

```

TRAC BLANKET SYSTEM MODEL

	0	2	1	0	1
* idbci		idbco	hdri	hdro	
	2	2	9.8768e-03	1.2115e-02	
* nrods		nodes	irftr	nzmax	
	1	3	0	23	
* dtxht(1)		dtxht(2)	dznht	hgapo	shelv
	1.0000e+03	1.0000e+03	1.0000e+02	1.0000e+03	0.0000e+00
* irpwtv		ndgx	ndhx	nrtv	nhist
	7	0	0	10	0
* irpwtr		irpwsv	nrpwtb	nrpwsv	nrpwrf
	104	1	20	0	0
* izpwtr		izpwsv	nzpwtb	nzpwsv	nzpwrf
	0	1	1	0	0
* nmwrx		nfcil	nfcil		
	0	0	0		
* nzpwz		nzpwi	nfbpwt		
	16	-1	0		
* react		tneut	rpwoff	rrpwmv	rpwscl
	0.0000e+00	0.0000e+00	0.0000e+00	1.0000e+12	1.3341e+06
* rpowri		zpwin	zpwoff	rzpwmv	
	1.3341e+06	0.0000e+00	0.0000e+00	1.0000e+20	
* extsou		pldr	pdrat	fucrac	
	0.0000e+00	0.0000e+00	1.1000e+00	1.0000e+00	
* nhcomi*	r6	300	300e		
* nhceli*	-1	1 2 3 4s			
	5	5e			
* nhcomo*	r6	823	823e		
* nhcelo*	-3	3 4 5 6s			
	7	7e			
* dz	* r4	6.0960e-01	3.1980e-01e		
* elev	*	-6.5720e+00	-5.9624e+00	-5.3528e+00	-4.7432e+00s
* elev	*	-4.2785e+00e			
* idrod	*	1e			
* idrodo*	*	1e			
* rdx	*	2.1600e+02e			
* radrd	*	1.2303e-02	1.2513e-02	1.2723e-02e	
* matrd	* f	52e			
* nfax	* f	1e			
* rftn	* f	3.7300e+02e			
* rdpwr	* f	1.0000e+00e			
* cpowr	*	1.0000e+00e			
* zpwzt	*	0.0000e+00	1.8397e-01	3.6767e-01	5.5164e-01s
* zpwzt	*	7.3561e-01	9.1931e-01	1.1033e+00	1.2873e+00s
* zpwzt	*	1.4709e+00	1.6459e+00	1.8389e+00	2.0226e+00s
* zpwzt	*	2.2066e+00	2.3905e+00	2.5742e+00	2.7582e+00e
* zpwtb	*	3.0220e-01	7.9130e-01	1.4832e+00	1.7457e+00s
* zpwtb	*	1.8234e+00	1.8304e+00	1.7919e+00	1.7208e+00s
* zpwtb	*	1.6161e+00	1.1067e+00	4.2970e-01	2.0630e-01s
* zpwtb	*	1.2790e-01	7.9700e-02	4.5800e-02	3.0600e-02s
* zpwtb	*	0.0000e+00e			
* rpwtb	*	0.000e+00	1.385e-02s		
		1.000e+00	1.209e-02s		
		2.000e+00	1.142e-02s		
		5.000e+00	1.086e-02s		
		1.000e+01	1.059e-02s		
		2.000e+01	1.024e-02s		
		6.000e+01	9.237e-03s		
		1.200e+02	8.125e-03s		
		3.000e+02	6.215e-03s		
		6.000e+02	5.058e-03s		
		1.200e+03	4.454e-03s		
		3.600e+03	3.849e-03s		

TRAC BLANKET SYSTEM MODEL

```

7.200e+03      3.457e-03s
3.600e+04      2.267e-03s
8.640e+04      1.472e-03s
1.728e+05      9.137e-04s
4.320e+05      4.449e-04s
8.640e+05      2.677e-04s
1.728e+06      1.664e-04s
2.592e+06      1.239e-04e
* fpuo2 *      0.0000e+00e
* ftd *        1.0000e+00e
* gmix *       1.0000e+00r06 0.0000e+00e
* gmles *      1.0000e+00e
* pgapt *      1.0000e+00e
* plvol *      1.0000e+00e
* pslen *      1.0000e+00e
* clen *       1.0000e+00e
* burn * f     1.0000e+00e
*
*
* Upflow (Heated Pb/Al structure connected to Water only)
***** type          num          id          ctitle
rod          951          951 $951$ Blanket row1 htr
* ncrx          ncrz          ittc
1            5            0
* nopowr          nrldr          modez          liqlev          iaxcnd
0            1            1            0            1
* idbci          idbco          hdri          hdro
0            2            0.0000e+00      2.1164e-02
* nrods          nodes          irftr          nzmax
1            6            0            26
* dtxht(1)      dtxht(2)      dznht          hgapo          shelv
1.0000e+03    1.0000e+03    1.0000e+02    1.0000e+03    0.0000e+00
* irpwt          ndgx          ndhx          nrts          nhist
7            0            0            10          0
* irpwtr          irpws          nrpwtb          nrpws          nrpwr
104          1            20          0            0
* izpwtr          izpws          nzpwtb          nzpws          nzpwr
0            1            1            0            0
* nmwrx          nfci          nfcil
0            0            0
* nzpwz          nzpwi          nfbpwt
16           -1          0
* react          tneut          rpwoff          rrpwm          rpwscl
0.0000e+00    0.0000e+00    0.0000e+00    1.0000e+12    1.4157e+07
* rpowr          zpwin          zpwoff          rzpwm
1.4157e+07    0.0000e+00    0.0000e+00    1.0000e+20
* extsou          pldr          pdrat          fucrac
0.0000e+00    0.0000e+00    1.1000e+00    1.0000e+00
* nhcomo*       r6 300      300e
* nhcelo*       -1 1 2 3 4s
5 5e
* dz * r4      6.0960e-01    3.1980e-01e
* elev *       -6.5720e+00    -5.9624e+00    -5.3528e+00s
* elev *       -4.7432e+00    -4.2785e+00e
* idrod * f     1e
* rdx * f       2.8534e+02e
* radrd *       0.0000e+00    3.1822e-03    6.3643e-03    9.5465e-03s
* radrd *       1.0064e-02    1.0582e-02e
* matrdr * r3   51 r2 52e
* nfax * f      1e
* rftn * f      3.7300e+02e
* rdpwr * f     1.0000e+00e

```

TRAC BLANKET SYSTEM MODEL

```

* cpowr *      1.0000e+00e
* zpwzt *      0.0000e+00      1.8397e-01      3.6767e-01      5.5164e-01s
* zpwzt *      7.3561e-01      9.1931e-01      1.1033e+00      1.2873e+00s
* zpwzt *      1.4709e+00      1.6459e+00      1.8389e+00      2.0226e+00s
* zpwzt *      2.2066e+00      2.3905e+00      2.5742e+00      2.7582e+00e
* zpwtb *      3.0220e-01      7.9130e-01      1.4832e+00      1.7457e+00s
* zpwtb *      1.8234e+00      1.8304e+00      1.7919e+00      1.7208e+00s
* zpwtb *      1.6161e+00      1.1067e+00      4.2970e-01      2.0630e-01s
* zpwtb *      1.2790e-01      7.9700e-02      4.5800e-02      3.0600e-02s
* zpwtb *      0.0000e+00e
* rpwtb *      0.000e+00      1.385e-02s
                1.000e+00      1.209e-02s
                2.000e+00      1.142e-02s
                5.000e+00      1.086e-02s
                1.000e+01      1.059e-02s
                2.000e+01      1.024e-02s
                6.000e+01      9.237e-03s
                1.200e+02      8.125e-03s
                3.000e+02      6.215e-03s
                6.000e+02      5.058e-03s
                1.200e+03      4.454e-03s
                3.600e+03      3.849e-03s
                7.200e+03      3.457e-03s
                3.600e+04      2.267e-03s
                8.640e+04      1.472e-03s
                1.728e+05      9.137e-04s
                4.320e+05      4.449e-04s
                8.640e+05      2.677e-04s
                1.728e+06      1.664e-04s
                2.592e+06      1.239e-04e
* fpuc2 *      0.0000e+00e
* ftd *        1.0000e+00e
* gmix *        1.0000e+00r06 0.0000e+00e
* gmles *       1.0000e+00e
* pgapt *       1.0000e+00e
* plvol *       1.0000e+00e
* pslen *       1.0000e+00e
* clenn *       1.0000e+00e
* burn * f      1.0000e+00e

```

* ===== MODULE 1 (DOWNFLOW) ===== *

* Downflow (Heated Al structure connected to Water & Cavity)

```

***** type      num      id      ctitle
rod          984          984 $984$ He to Aluminum and then water
*      ncrx      ncrz      ittc
      1          5          0
*      nopowr      nridr      modez      liqlev      iaxcnd
      0          2          1          0          1
*      idbci      idbco      hdri      hdro
      2          2      9.8768e-03      1.2115e-02
*      nrods      nodes      irftr      nzmax
      1          3          0          23
*      dtxht(1)      dtxht(2)      dznht      hgapo      shelv
      1.0000e+03      1.0000e+03      1.0000e+02      1.0000e+03      0.0000e+00
*      irpwty      ndgx      ndhx      nrts      nhist
      7          0          0          10          0
*      irpwtr      irpwsv      nrpwtb      nrpwsv      nrpwrf
      104          1          20          0          0
*      izpwtr      izpwsv      nzpwtb      nzpwsv      nzpwrf
      0          1          1          0          0

```

TRAC BLANKET SYSTEM MODEL

```

*      nmwrx      nfci      nfci1
      0            0            0
*      nzpwz      nzpwi      nfbpwt
      16          -1            0
*      react      tneut      rpwoff      rrpwmx      rpwscl
      0.0000e+00    0.0000e+00    0.0000e+00    1.0000e+12    8.2220e+06
*      rpowri      zpwini      zpwoff      rzpwmx
      8.2220e+06    0.0000e+00    0.0000e+00    1.0000e+20
*      extsou      pldr      pdrat      fucrac
      0.0000e+00    0.0000e+00    1.1000e+00    1.0000e+00
* nhcomi*      r6 360      360e
* nhceli*      -1 1 2 3 4s
      5 5e
* nhcomo*      r6 823      823e
* nhcelo*      -7 7 6 5 4s
      3 3e
* dz *      3.1980e-01 r4 6.0960e-01e
* elev *      -4.2785e+00    -4.7432e+00    -5.3528e+00s
* elev *      -5.9624e+00    -6.5720e+00e
* idrod *      1e
* idrodo*      1e
* rdx *      6.1183e+02e
* radrd *      4.9384e-03    5.4980e-03    6.0576e-03e
* matrd * f      52e
* nfax * f      1e
* rftn * f      3.7300e+02e
* rdpwr * f      1.0000e+00e
* cpowr *      1.0000e+00e
* zpwzt *      0.0000e+00    1.8397e-01    3.6767e-01    5.5164e-01s
* zpwzt *      7.3561e-01    9.1931e-01    1.1033e+00    1.2873e+00s
* zpwzt *      1.4709e+00    1.6459e+00    1.8389e+00    2.0226e+00s
* zpwzt *      2.2066e+00    2.3905e+00    2.5742e+00    2.7582e+00e
* zpwtb *      3.0220e-01    7.9130e-01    1.4832e+00    1.7457e+00s
* zpwtb *      1.8234e+00    1.8304e+00    1.7919e+00    1.7208e+00s
* zpwtb *      1.6161e+00    1.1067e+00    4.2970e-01    2.0630e-01s
* zpwtb *      1.2790e-01    7.9700e-02    4.5800e-02    3.0600e-02s
* zpwtb *      0.0000e+00e
* rpwtb *      0.000e+00    1.385e-02s
      1.000e+00    1.209e-02s
      2.000e+00    1.142e-02s
      5.000e+00    1.086e-02s
      1.000e+01    1.059e-02s
      2.000e+01    1.024e-02s
      6.000e+01    9.237e-03s
      1.200e+02    8.125e-03s
      3.000e+02    6.215e-03s
      6.000e+02    5.058e-03s
      1.200e+03    4.454e-03s
      3.600e+03    3.849e-03s
      7.200e+03    3.457e-03s
      3.600e+04    2.267e-03s
      8.640e+04    1.472e-03s
      1.728e+05    9.137e-04s
      4.320e+05    4.449e-04s
      8.640e+05    2.677e-04s
      1.728e+06    1.664e-04s
      2.592e+06    1.239e-04e
* fpuo2 *      0.0000e+00e
* ftd *      1.0000e+00e
* gmix *      1.0000e+00r06 0.0000e+00e
* gmles *      1.0000e+00e
* pgapt *      1.0000e+00e

```


TRAC BLANKET SYSTEM MODEL

```

* plvol *      1.0000e+00e
* pslen *      1.0000e+00e
* clen *       1.0000e+00e
* burn * f     1.0000e+00e
*
*
* ===== MODULE 2 (UPFLOW) =====
*
* Upflow (Unheated Al structure connected to Water & Cavity)
***** type          num          id          ctitle
rod          905          905 $905$ Water to Al then Cavity
*           ncrx          ncrz          ittc
*           1            6            0
*           nopowr        nrldr          modez          liqlev          iaxcnd
*           1            2            1            0            1
*           idbci          idbco          hdri          hdro
*           2            2          1.0210e-02          5.3477e-02
*           nrods          nodes          irftr          nzmax
*           1            3            0            23
*           dtxht(1)      dtxht(2)      dznht          hgapo          shelv
*           1.0000e+03    1.0000e+03    1.0000e+02    1.0000e+03    0.0000e+00
* nhcomi*      r7 102      102 e
* nhceli*      -1 1 2 3 4 s
* nhceli*      5 6 6e
* nhcomo*      r7 823      823 e
* nhcelo*      -2 2 3 4s
* nhcelo*      5 6 7 7e
* dz *         0.7418 r4 0.6096          0.3198e
* elev *       -7.2477e+00 -6.5720e+00 -5.9624e+00s
* elev *       -5.3528e+00 -4.7432e+00 -4.2785e+00e
* idrod *          1e
* idrodo*        1e
* rdx *          3.5325e+02e
* radrd *        1.6882e-02 1.7076e-02 1.7269e-02e
* matrd * f          52e
* nfax * f          1e
* rftn * f          3.7300e+02e
*
*
* Upflow (Heated Pb/Al structure connected to Water only)
***** type          num          id          ctitle
rod          955          955 $955$ Pb/Al to Water
*           ncrx          ncrz          ittc
*           1            6            0
*           nopowr        nrldr          modez          liqlev          iaxcnd
*           0            1            1            0            1
*           idbci          idbco          hdri          hdro
*           0            2          0.0000e+00          2.1164e-02
*           nrods          nodes          irftr          nzmax
*           1            6            0            26
*           dtxht(1)      dtxht(2)      dznht          hgapo          shelv
*           1.0000e+03    1.0000e+03    1.0000e+02    1.0000e+03    0.0000e+00
*           irpwtv          ndgx          ndhx          nrts          nhist
*           7            0            0            10            0
*           irpwtr          irpwsv          nrpwtb          nrpwsv          nrpwrf
*           104           1            20            0            0
*           izpwtr          izpwsv          nzpwtb          nzpwsv          nzpwrf
*           0            1            1            0            0
*           nmwrx          nfci          nfcil
*           0            0            0
*           nzpwz          nzpwi          nfbpwt
*           16           -1            0

```

TRAC BLANKET SYSTEM MODEL

```

*      react      tneut      rpwoff      rrpwmx      rpwscl
0.0000e+00  0.0000e+00  0.0000e+00  1.0000e+12  7.6600e+06
*      rpowri      zpwini      zpwoff      rzpwmx
7.6600e+06  0.0000e+00  0.0000e+00  1.0000e+20
*      extsou      pldr      pdrat      fucrac
0.0000e+00  0.0000e+00  1.1000e+00  1.0000e+00
* nhcomo*      r7 102      102e
* nhcelo*      -1 1 2 3s
* nhcelo*      4 5 6 6e
* dz *      0.7418      r4      0.6096      0.3198e
* elev *      -7.2477e+00  -6.5720e+00  -5.9624e+00s
* elev *      -5.3528e+00  -4.7432e+00  -4.2785e+00e
* idrod * f      1e
* rdx * f      3.5325e+02e
* radrd *      0.0000e+00  5.0017e-03  1.0003e-02  1.5005e-02s
* radrd *      1.5497e-02  1.5989e-02e
* matrd * r3 51      r2 52e
* nfax * f      1e
* rftn * f      3.7300e+02e
* rdpwr * f      1.0000e+00e
* cpowr *      1.0000e+00e
* zpwzt *      0.0000e+00  2.3345e-01  4.6655e-01  7.0000e-01s
* zpwzt *      9.3345e-01  1.1666e+00  1.4000e+00  1.6335e+00s
* zpwzt *      1.8666e+00  2.1000e+00  2.3335e+00  2.5666e+00s
* zpwzt *      2.8000e+00  3.0334e+00  3.2666e+00  3.5000e+00e
* zpwtb *      0.0000e+00  1.1700e-02  3.4800e-02  1.6680e-01s
* zpwtb *      4.7850e-01  1.5993e+00  2.2734e+00  2.4080e+00s
* zpwtb *      2.3795e+00  2.2644e+00  2.0159e+00  8.2910e-01s
* zpwtb *      2.7530e-01  1.4430e-01  7.2700e-02  4.0200e-02s
* zpwtb *      0.0000e+00e
* rpwtb *      0.000e+00      2.079e-02s
1.000e+00      1.747e-02s
2.000e+00      1.614e-02s
5.000e+00      1.511e-02s
1.000e+01      1.477e-02s
2.000e+01      1.432e-02s
6.000e+01      1.293e-02s
1.200e+02      1.135e-02s
3.000e+02      8.651e-03s
6.000e+02      7.042e-03s
1.200e+03      6.255e-03s
3.600e+03      5.490e-03s
7.200e+03      4.950e-03s
3.600e+04      3.271e-03s
8.640e+04      2.169e-03s
1.728e+05      1.377e-03s
4.320e+05      6.317e-04s
8.640e+05      3.457e-04s
1.728e+06      2.046e-04s
2.592e+06      1.488e-04e
* fpuo2 *      0.0000e+00e
* ftd *      1.0000e+00e
* gmix *      1.0000e+00r06 0.0000e+00e
* gmles *      1.0000e+00e
* pgapt *      1.0000e+00e
* plvol *      1.0000e+00e
* pslen *      1.0000e+00e
* clen *      1.0000e+00e
* burn * f      1.0000e+00e
*
*
* ===== MODULE 2 (DOWNFLOW) =====

```

TRAC BLANKET SYSTEM MODEL

```

*
* Downflow (Unheated Al structure connected to Water & Cavity)
***** type          num          id          ctitle
rod          916          916 $916$Water to Al then Cavity
*          ncrx          ncrz          ittc
*          1          6          0
*          nopowr          nridr          modez          liqlev          iaxcnd
*          1          2          1          0          1
*          idbci          idbco          hdri          hdro
*          2          2          1.0210e-02          5.3477e-02
*          nrods          nodes          irftr          nzmax
*          1          3          0          23
*          dtxht(1)          dtxht(2)          dznht          hgapo          shelv
*          1.0000e+03          1.0000e+03          1.0000e+02          1.0000e+03          0.0000e+00
* nhcomi*          r7 158          158 e
* nhceli*          -1 1 2 3 4 s
* nhceli*          5 6 6e
* nhcomo*          r7 823          823 e
* nhcelo*          -7 7 6 5 4 s
* nhcelo*          3 2 2e
* dz *          0.3198 r4 0.6096          0.7418e
* elev *          -4.2785e+00          -4.7432e+00          -5.3528e+00s
* elev *          -5.9624e+00          -6.5720e+00          -7.2477e+00e
* idrod *          1e
* idrodo*          1e
* rdx *          1.8472e+02e
* radrd *          2.6740e-02          2.6928e-02          2.7115e-02e
* matrdr * f          52e
* nfax * f          1e
* rftn * f          3.7300e+02e
*
*
* Downflow (Heated Pb/Al structure connected to Water only)
***** type          num          id          ctitle
rod          966          966 $966$ Pb/Al to Water
*          ncrx          ncrz          ittc
*          1          6          0
*          nopowr          nridr          modez          liqlev          iaxcnd
*          0          1          1          0          1
*          idbci          idbco          hdri          hdro
*          0          2          0.0000e+00          2.1164e-02
*          nrods          nodes          irftr          nzmax
*          1          6          0          26
*          dtxht(1)          dtxht(2)          dznht          hgapo          shelv
*          1.0000e+03          1.0000e+03          1.0000e+02          1.0000e+03          0.0000e+00
*          irpwty          ndgx          ndhx          nrts          nhist
*          7          0          0          10          0
*          irpwtr          irpwsv          nrpwtb          nrpwsv          nrpwrf
*          104          1          20          0          0
*          izpwtr          izpwsv          nzpwtb          nzpwsv          nzpwrf
*          0          1          1          0          0
*          nmwrx          nfcil          nfcil
*          0          0          0
*          nzpwz          nzpwi          nfbpwt
*          16          -1          0
*          react          tneut          rpwoff          rrpwmx          rpwscl
*          0.0000e+00          0.0000e+00          0.0000e+00          1.0000e+12          3.0600e+06
*          rpowri          zpwini          zpwini          rrpwmx
*          3.0600e+06          0.0000e+00          0.0000e+00          1.0000e+20
*          extsou          pldr          pdrat          fucrac
*          0.0000e+00          0.0000e+00          1.1000e+00          1.0000e+00
* nhcomo*          r7 158          158e

```

TRAC BLANKET SYSTEM MODEL

```

* nhcelo*   -1  1  2  3  4s
              5  6 6e
* dz      *   0.3198  r4  0.6096   0.7418e
* elev    *   -4.2785e+00 -4.7432e+00 -5.3528e+00s
* elev    *   -5.9624e+00 -6.5720e+00 -7.2477e+00e
* idrod    * f               1e
* rdx      * f   1.8472e+02e
* radrd    *   0.0000e+00   8.0407e-03   1.6081e-02   2.4122e-02s
* radrd    *   2.5033e-02   2.5943e-02e
* matrdr   * r3  51   r2 52e
* nfax     * f               1e
* rftn     * f   3.7300e+02e
* rdpwr    * f   1.0000e+00e
* cpowr    *   1.0000e+00e
* zpwzt    *   0.0000e+00   2.3345e-01   4.6655e-01   7.0000e-01s
* zpwzt    *   9.3345e-01   1.1666e+00   1.4000e+00   1.6335e+00s
* zpwzt    *   1.8666e+00   2.1000e+00   2.3335e+00   2.5666e+00s
* zpwzt    *   2.8000e+00   3.0334e+00   3.2666e+00   3.5000e+00e
* zpwtb    *   0.0000e+00   1.1700e-02   3.4800e-02   1.6680e-01s
* zpwtb    *   4.7850e-01   1.5993e+00   2.2734e+00   2.4080e+00s
* zpwtb    *   2.3795e+00   2.2644e+00   2.0159e+00   8.2910e-01s
* zpwtb    *   2.7530e-01   1.4430e-01   7.2700e-02   4.0200e-02s
* zpwtb    *   0.0000e+00e
* rpwtb    *   0.000e+00   2.801e-02s
              1.000e+00   2.370e-02s
              2.000e+00   2.197e-02s
              5.000e+00   2.061e-02s
              1.000e+01   2.014e-02s
              2.000e+01   1.947e-02s
              6.000e+01   1.730e-02s
              1.200e+02   1.482e-02s
              3.000e+02   1.059e-02s
              6.000e+02   8.183e-03s
              1.200e+03   7.174e-03s
              3.600e+03   6.370e-03s
              7.200e+03   5.783e-03s
              3.600e+04   3.872e-03s
              8.640e+04   2.573e-03s
              1.728e+05   1.618e-03s
              4.320e+05   6.990e-04s
              8.640e+05   3.595e-04s
              1.728e+06   2.088e-04s
              2.592e+06   1.516e-04e
* fpuo2    *   0.0000e+00e
* ftd      *   1.0000e+00e
* gmix     *   1.0000e+00r06 0.0000e+00e
* gmles    *   1.0000e+00e
* pgapt    *   1.0000e+00e
* plvol    *   1.0000e+00e
* pslen    *   1.0000e+00e
* clenn    *   1.0000e+00e
* burn     * f   1.0000e+00e
*
*
* ===== MODULE 3 (UPFLOW) =====
*
* Upflow (Unheated Al structure connected to Water & Cavity)
*****      type          num          id          ctitle
rod          911
*      ncrx          ncrz          ittc
              1          5          0
*      nopowr        nrldr        modez        liqlev        iaxcnd

```

TRAC BLANKET SYSTEM MODEL

```

      1          2          1          0          1
*      idbci      idbco      hdri      hdro
      2          2      1.0210e-02      5.3477e-02
*      nrods      nodes      irftr      nzmax
      1          3          0          23
*      dtxht(1)    dtxht(2)    dznht      hgapo      shelv
      1.0000e+03    1.0000e+03    1.0000e+02    1.0000e+03    0.0000e+00
*      nhcomi*    r6 409      409e
*      nhceli*    -1 1 2 3 4s
*      nhceli*    5 5e
*      nhcomo*    r6 823      823e
*      nhcelo*    -3 3 4 5 6s
*      nhcelo*    7 7e
*      dz * r4 6.0960e-01    3.1980e-01e
*      elev *    -6.5720e+00    -5.9624e+00    -5.3528e+00s
*      elev *    -4.7432e+00    -4.2785e+00e
*      idrod *    1e
*      idrodo*    1e
*      rdx *    1.1794e+02e
*      radrd *    1.2303e-02    1.2513e-02    1.2723e-02e
*      matr * f    52e
*      nfax * f    1e
*      rftn * f    3.7300e+02e
*
*
* Upflow (Heated Pb/Al structure connected to Water only)
***** type num id ctitle
rod 961 961 $961$ Blanket row1 hTr
*      ncrx      ncrz      ittc
      1          5          0
*      nopowr      nridr      modez      liqlev      iaxcnd
      0          1          1          0          1
*      idbci      idbco      hdri      hdro
      0          2      0.0000e+00    2.1164e-02
*      nrods      nodes      irftr      nzmax
      1          6          0          26
*      dtxht(1)    dtxht(2)    dznht      hgapo      shelv
      1.0000e+03    1.0000e+03    1.0000e+02    1.0000e+03    0.0000e+00
*      irpwt y      ndgx      ndhx      nrts      nhist
      7          0          0          10          0
*      irpwtr      irpwsv      nrpwtb      nrpwsv      nrpwrf
      104          1          20          0          0
*      izpwtr      izpwsv      nzpwtb      nzpwsv      nzpwrf
      0          1          1          0          0
*      nmwrx      nfcil      nfcil
      0          0          0
*      nzpwz      nzpwi      nfbpwt
      6          -1          0
*      react      tneut      rpwoff      rrpwm x      rpwscl
      0.0000e+00    0.0000e+00    0.0000e+00    1.0000e+12    2.8120e+06
*      rpowri      zpwin      zpwoff      rrpwm x
      2.8120e+06    0.0000e+00    0.0000e+00    1.0000e+20
*      extsou      pldr      pdrat      fucrac
      0.0000e+00    0.0000e+00    1.1000e+00    1.0000e+00
*      nhcomo*    r6 409      409e
*      nhcelo*    -1 1 2 3 4s
      5 5e
*      dz * r4 6.0960e-01    3.1980e-01e
*      elev *    -6.5720e+00    -5.9624e+00    -5.3528e+00s
*      elev *    -4.7432e+00    -4.2785e+00e
*      idrod * f    1e
*      rdx * f    1.1794e+02e

```

TRAC BLANKET SYSTEM MODEL

```

* radrd *      0.0000e+00      3.1822e-03      6.3643e-03      9.5465e-03s
* radrd *      1.0064e-02      1.0582e-02e
* matrd * r3   51      r2 52e
* nfax * f      1e
* rftn * f      3.7300e+02e
* rdpwr * f      1.0000e+00e
* cpowr *      1.0000e+00e
* zpwzt *      0.0000e+00      6.0960e-01      1.2192e+00      1.8288e+00s
* zpwzt *      2.4384e+00      2.7582e+00e
* zpwtb *      0.0000e+00 r5 1.0000e+00 0.0000e+00e
* rpwtb *      0.000e+00      9.736e-03s
      1.000e+00      8.718e-03s
      2.000e+00      8.335e-03s
      5.000e+00      8.000e-03s
      1.000e+01      7.836e-03s
      2.000e+01      7.620e-03s
      6.000e+01      7.035e-03s
      1.200e+02      6.399e-03s
      3.000e+02      5.280e-03s
      6.000e+02      4.520e-03s
      1.200e+03      3.998e-03s
      3.600e+03      3.346e-03s
      7.200e+03      2.938e-03s
      3.600e+04      1.898e-03s
      8.640e+04      1.284e-03s
      1.728e+05      8.591e-04s
      4.320e+05      4.776e-04s
      8.640e+05      3.075e-04s
      1.728e+06      1.963e-04s
      2.592e+06      1.475e-04e
* fpuo2 *      0.0000e+00e
* ftd *      1.0000e+00e
* gmix *      1.0000e+00r06 0.0000e+00e
* gmles *      1.0000e+00e
* pgapt *      1.0000e+00e
* plvol *      1.0000e+00e
* pslen *      1.0000e+00e
* clen *      1.0000e+00e
* burn * f      1.0000e+00e
*
*

```

* ===== MODULE 3 (DOWNFLOW) ===== *

* Downflow (Heated Al structure connected to Water & Cavity)

```

***** type      num      id      ctitle
rod      988      988 $988$He to Aluminum and then water
*      ncrx      ncrz      ittc
      1      5      0
*      nopowr      nrldr      modez      liqlev      iaxcnd
      0      2      1      0      1
*      idbci      idbco      hdri      hdro
      2      2      9.8768e-03      1.2115e-02
*      nrods      nodes      irftr      nzmax
      1      3      0      23
*      dtxht(1)      dtxht(2)      dznht      hgapo      shelv
      1.0000e+03      1.0000e+03      1.0000e+02      1.0000e+03      0.0000e+00
*      irpwty      ndgx      ndhx      nrts      nhist
      7      0      0      10      0
*      irpwtr      irpwsv      nrpwtb      nrpwsv      nrpwrfr
      104      1      20      0      0
*      izpwtr      izpwsv      nzpwtb      nzpwsv      nzpwrfr
      0      1      1      0      0

```

TRAC BLANKET SYSTEM MODEL

```

*      nmwrx      nfcil      nfcil
*      0          0          0
*      nzpwz      nzpwi      nfbpwt
*      16          -1          0
*      react      tneut      rpwoff      rrpwmx      rpwscl
*      0.0000e+00  0.0000e+00  0.0000e+00  1.0000e+12  7.4400e+05
*      rpowri      zpwini      zpwoff      rrpwmx
*      7.4400e+05  0.0000e+00  0.0000e+00  1.0000e+20
*      extsou      pldr      pdrat      fucrac
*      0.0000e+00  0.0000e+00  1.1000e+00  1.0000e+00
* nhcomi*      r6 478      478e
* nhceli*      -1 1 2 3 4s
*              5 5e
* nhcomo*      r6 823      823e
* nhcelo*      -7 7 6 5 4 s
*              3 3e
* dz *      3.1980e-01 r4 6.0960e-01e
* elev *      -4.2785e+00 -4.7432e+00 -5.3528e+00s
* elev *      -5.9624e+00 -6.5720e+00e
* idrod *      1e
* idrodo*      1e
* rdx *      6.1183e+02e
* radrd *      4.9384e-03 5.4980e-03 6.0576e-03e
* matrd * f      52e
* nfax * f      1e
* rftn * f      3.7300e+02e
* rdpwr * f      1.0000e+00e
* cpowr *      1.0000e+00e
* zpwzt *      0.0000e+00 1.8397e-01 3.6767e-01 5.5164e-01s
* zpwzt *      7.3561e-01 9.1931e-01 1.1033e+00 1.2873e+00s
* zpwzt *      1.4709e+00 1.6459e+00 1.8389e+00 2.0226e+00s
* zpwzt *      2.2066e+00 2.3905e+00 2.5742e+00 2.7582e+00e
* zpwtb *      3.0220e-01 7.9130e-01 1.4832e+00 1.7457e+00s
* zpwtb *      1.8234e+00 1.8304e+00 1.7919e+00 1.7208e+00s
* zpwtb *      1.6161e+00 1.1067e+00 4.2970e-01 2.0630e-01s
* zpwtb *      1.2790e-01 7.9700e-02 4.5800e-02 3.0600e-02s
* zpwtb *      0.0000e+00e
* rpwtb *      0.000e+00 9.736e-03s
*              1.000e+00 8.718e-03s
*              2.000e+00 8.335e-03s
*              5.000e+00 8.000e-03s
*              1.000e+01 7.836e-03s
*              2.000e+01 7.620e-03s
*              6.000e+01 7.035e-03s
*              1.200e+02 6.399e-03s
*              3.000e+02 5.280e-03s
*              6.000e+02 4.520e-03s
*              1.200e+03 3.998e-03s
*              3.600e+03 3.346e-03s
*              7.200e+03 2.938e-03s
*              3.600e+04 1.898e-03s
*              8.640e+04 1.284e-03s
*              1.728e+05 8.591e-04s
*              4.320e+05 4.776e-04s
*              8.640e+05 3.075e-04s
*              1.728e+06 1.963e-04s
*              2.592e+06 1.475e-04e
* fpuo2 *      0.0000e+00e
* ftd *      1.0000e+00e
* gmix *      1.0000e+00r06 0.0000e+00e
* gmles *      1.0000e+00e
* pgapt *      1.0000e+00e

```

TRAC BLANKET SYSTEM MODEL

```

* plvol *      1.0000e+00e
* pslen *      1.0000e+00e
* clen *       1.0000e+00e
* burn * f     1.0000e+00e
*
*
* ===== MODULE 4 (UPFLOW) =====
*
* Upflow (Unheated Al structure connected to Water & Cavity)
***** type          num          id          ctitle
rod          912          912 $912$He to Aluminum and then water
*          ncrx          ncrz          ittc
*          1            6            0
*          nopowr        nridr          modez          liqlev          iaxcnd
*          1            2            1            0            1
*          idbci          idbco          hdri          hdro
*          2            2          1.0210e-02          5.3477e-02
*          nrods          nodes          irftr          nzmax
*          1            3            0            23
*          dtxht(1)      dtxht(2)      dznht          hgapo          shelv
*          1.0000e+03    1.0000e+03    1.0000e+02    1.0000e+03    0.0000e+00
* nhcomi*      r7 412      412 e
* nhceli*      -1 1 2 3 4 s
* nhceli*      5 6 6e
* nhcomo*      r7 823      823 e
* nhcelo*      -2 2 3 4s
* nhcelo*      5 6 7 7e
* dz *         0.7418 r4 0.6096      0.3198e
* elev *       -7.2477e+00 -6.5720e+00 -5.9624e+00s
* elev *       -5.3528e+00 -4.7432e+00 -4.2785e+00e
* idrod *          1e
* idrodo*        1e
* rdx *          4.4326e+02e
* radrd *        1.2303e-02 1.2513e-02 1.2723e-02e
* matr * f         52e
* nfax * f         1e
* rftn * f        3.7300e+02e
*
*
* Upflow (Heated Pb/Al structure connected to Water only)
***** type          num          id          ctitle
rod          962          962 $962$ Blanket row1 htr
*          ncrx          ncrz          ittc
*          1            6            0
*          nopowr        nridr          modez          liqlev          iaxcnd
*          0            1            1            0            1
*          idbci          idbco          hdri          hdro
*          0            2          0.0000e+00          2.1164e-02
*          nrods          nodes          irftr          nzmax
*          1            6            0            26
*          dtxht(1)      dtxht(2)      dznht          hgapo          shelv
*          1.0000e+03    1.0000e+03    1.0000e+02    1.0000e+03    0.0000e+00
*          irpwt          ndgx          ndhx          nrtts          nhist
*          7            0            0            10            0
*          irpwtr          irpwsv          nrpwtb          nrpwsv          nrpwrf
*          104           1            20            0            0
*          izpwtr          izpwsv          nzpwtb          nzpwsv          nzpwrf
*          0            1            1            0            0
*          nmwrx          nfci          nfcil
*          0            0            0
*          nzpwz          nzpwi          nfbpwt
*          16           -1            0

```


TRAC BLANKET SYSTEM MODEL

```

*      react      tneut      rpwoff      rrpwmx      rpwscl
    0.0000e+00    0.0000e+00    0.0000e+00    1.0000e+12    5.4120e+06
*      rpowri      zpin      zpwoff      rzpwmx
    5.4120e+06    0.0000e+00    0.0000e+00    1.0000e+20
*      extsou      pldr      pdrat      fucrac
    0.0000e+00    0.0000e+00    1.1000e+00    1.0000e+00
* nhcomo*      r7 412      412e
* nhcelo*      -1 1 2 3 4s
* nhcelo*      5 6 6e
* dz *      0.7418      r4      0.6096      0.3198e
* elev *      -7.2477e+00    -6.5720e+00    -5.9624e+00s
* elev *      -5.3528e+00    -4.7432e+00    -4.2785e+00e
* idrod * f      1e
* rdx * f      4.4326e+02e
* radrd *      0.0000e+00      3.1822e-03      6.3643e-03      9.5465e-03s
* radrd *      1.0064e-02      1.0582e-02e
* matrd * r3 51      r2 52e
* nfax * f      1e
* rftn * f      3.7300e+02e
* rdpwr * f      1.0000e+00e
* cpowr *      1.0000e+00e
* zpwzt *      0.0000e+00      2.3345e-01      4.6655e-01      7.0000e-01s
* zpwzt *      9.3345e-01      1.1666e+00      1.4000e+00      1.6335e+00s
* zpwzt *      1.8666e+00      2.1000e+00      2.3335e+00      2.5666e+00s
* zpwzt *      2.8000e+00      3.0334e+00      3.2666e+00      3.5000e+00e
* zpwtb *      0.0000e+00      1.1700e-02      3.4800e-02      1.6680e-01s
* zpwtb *      4.7850e-01      1.5993e+00      2.2734e+00      2.4080e+00s
* zpwtb *      2.3795e+00      2.2644e+00      2.0159e+00      8.2910e-01s
* zpwtb *      2.7530e-01      1.4430e-01      7.2700e-02      4.0200e-02s
* zpwtb *      0.0000e+00e
* rpwtb *      0.000e+00      1.104e-02s
      1.000e+00      9.894e-03s
      2.000e+00      9.463e-03s
      5.000e+00      9.085e-03s
      1.000e+01      8.890e-03s
      2.000e+01      8.628e-03s
      6.000e+01      7.890e-03s
      1.200e+02      7.077e-03s
      3.000e+02      5.662e-03s
      6.000e+02      4.746e-03s
      1.200e+03      4.179e-03s
      3.600e+03      3.519e-03s
      7.200e+03      3.103e-03s
      3.600e+04      2.008e-03s
      8.640e+04      1.348e-03s
      1.728e+05      8.917e-04s
      4.320e+05      4.856e-04s
      8.640e+05      3.098e-04s
      1.728e+06      1.972e-04s
      2.592e+06      1.479e-04e
* fpuo2 *      0.0000e+00e
* ftd *      1.0000e+00e
* gmix *      1.0000e+00r06 0.0000e+00e
* gmles *      1.0000e+00e
* pgapt *      1.0000e+00e
* plvol *      1.0000e+00e
* pslen *      1.0000e+00e
* clenr *      1.0000e+00e
* burn * f      1.0000e+00e

```

* ===== MODULE 4 (DOWNFLOW) =====

TRAC BLANKET SYSTEM MODEL

*

* Downflow (Unheated Al structure connected to Water & Cavity)

```

*****  type          num          id          ctitle
rod      931          931 $931$He to Aluminum and then water
*        ncrx          ncrz          ittc
          1            6            0
*        nopowr        nridr        modez        liqlev        iaxcnd
          1            2            1            0            1
*        idbci          idbco          hdri          hdro
          2            2      1.0210e-02      5.3477e-02
*        nrods          nodes          irftr          nzmax
          1            3            0            23
*        dtxht(1)      dtxht(2)      dznht          hgapo          shelv
          1.0000e+03      1.0000e+03      1.0000e+02      1.0000e+03      0.0000e+00
* nhcomi*      r7 480      480 e
* nhceli*      -1 1 2 3 4 s
* nhceli*      5 6 6e
* nhcomo*      r7 823      823 e
* nhcelo*      -7 7 6 5 4 s
* nhcelo*      3 2 2e
* dz *        0.3198 r4 0.6096 0.7418e
* elev *      -4.2785e+00 -4.7432e+00 -5.3528e+00s
* elev *      -5.9624e+00 -6.5720e+00 -7.2477e+00e
* idrod *          1e
* idrodo*          1e
* rdx *        2.8076e+02e
* radrd *      1.6882e-02 1.7076e-02 1.7269e-02e
* matrdr * f          52e
* nfax * f          1e
* rftn * f      3.7300e+02e

```

*

* Downflow (Heated Pb/Al structure connected to Water only)

```

*****  type          num          id          ctitle
rod      978          978 $978$ Blanket row2 htr
*        ncrx          ncrz          ittc
          1            6            0
*        nopowr        nridr        modez        liqlev        iaxcnd
          0            1            1            0            1
*        idbci          idbco          hdri          hdro
          0            2      0.0000e+00      2.1164e-02
*        nrods          nodes          irftr          nzmax
          1            6            0            26
*        dtxht(1)      dtxht(2)      dznht          hgapo          shelv
          1.0000e+03      1.0000e+03      1.0000e+02      1.0000e+03      0.0000e+00
*        irpwtly        ndgx          ndhx          nrtts          nhist
          7            0            0            10            0
*        irpwtr        irpwsv        nrpwtb        nrpwsv        nrpwrf
          104          1            20            0            0
*        izpwtr        izpwsv        nzpwtb        nzpwsv        nzpwrf
          0            1            1            0            0
*        nmwrx          nfcil          nfbpwt
          0            0            0
*        nzpwz          nzpwi          nfbpwt
          16          -1            0
*        react          tneut          rpwoff          rrpwmx          rpwscl
          0.0000e+00      0.0000e+00      0.0000e+00      1.0000e+12      3.9240e+06
*        rpowri          zpwin          zpwoff          rrpwmx
          3.9240e+06      0.0000e+00      0.0000e+00      1.0000e+20
*        extsou          pldr          pdrat          fucrac
          0.0000e+00      0.0000e+00      1.1000e+00      1.0000e+00
* nhcomo*      r7 480      480e

```

TRAC BLANKET SYSTEM MODEL

```

* nhcelo* -1 1 2 3 4s
* nhcelo* 5 6 6e
* dz * 0.3198 r4 0.6096 0.7418e
* elev * -4.2785e+00 -4.7432e+00 -5.3528e+00s
* elev * -5.9624e+00 -6.5720e+00 -7.2477e+00e
* idrod * f 1e
* rdx * f 2.8076e+02e
* radrd * 0.0000e+00 5.0017e-03 1.0003e-02 1.5005e-02s
* radrd * 1.5497e-02 1.5989e-02e
* matrd * r3 51 r2 52e
* nfax * f 1e
* rftn * f 3.7300e+02e
* rdpwr * f 1.0000e+00e
* cpowr * 1.0000e+00e
* zpwzt * 0.0000e+00 2.3345e-01 4.6655e-01 7.0000e-01s
* zpwzt * 9.3345e-01 1.1666e+00 1.4000e+00 1.6335e+00s
* zpwzt * 1.8666e+00 2.1000e+00 2.3335e+00 2.5666e+00s
* zpwzt * 2.8000e+00 3.0334e+00 3.2666e+00 3.5000e+00e
* zpwtb * 0.0000e+00 1.1700e-02 3.4800e-02 1.6680e-01s
* zpwtb * 4.7850e-01 1.5993e+00 2.2734e+00 2.4080e+00s
* zpwtb * 2.3795e+00 2.2644e+00 2.0159e+00 8.2910e-01s
* zpwtb * 2.7530e-01 1.4430e-01 7.2700e-02 4.0200e-02s
* zpwtb * 0.0000e+00e
* rpwtb * 0.000e+00 1.402e-02s
          1.000e+00 1.220e-02s
          2.000e+00 1.146e-02s
          5.000e+00 1.089e-02s
          1.000e+01 1.068e-02s
          2.000e+01 1.041e-02s
          6.000e+01 9.584e-03s
          1.200e+02 8.659e-03s
          3.000e+02 7.036e-03s
          6.000e+02 5.983e-03s
          1.200e+03 5.332e-03s
          3.600e+03 4.543e-03s
          7.200e+03 4.012e-03s
          3.600e+04 2.586e-03s
          8.640e+04 1.747e-03s
          1.728e+05 1.168e-03s
          4.320e+05 6.158e-04s
          8.640e+05 3.734e-04s
          1.728e+06 2.259e-04s
          2.592e+06 1.625e-04e
* fpuo2 * 0.0000e+00e
* ftd * 1.0000e+00e
* gmix * 1.0000e+00r06 0.0000e+00e
* gmles * 1.0000e+00e
* pgapt * 1.0000e+00e
* plvol * 1.0000e+00e
* pslen * 1.0000e+00e
* clenr * 1.0000e+00e
* burn * f 1.0000e+00e
*
*
* ===== MODULE 5 (UPFLOW) =====
*
* Upflow (Unheated Al structure connected to Water & Cavity)
***** type num id ctitle
rod 913 913 $913$ He to Aluminum and then water
* ncrx ncrz ittc
  1 6 0
* nopowr nridr modez liqlev iaxcnd

```

TRAC BLANKET SYSTEM MODEL

```

      1      2      1      0      1
*      idbci      idbco      hdri      hdro
      2      2      1.0210e-02      5.3477e-02
*      nrods      nodes      irftr      nzmax
      1      3      0      23
*      dtxht(1)      dtxht(2)      dznht      hgapo      shelv
      1.0000e+03      1.0000e+03      1.0000e+02      1.0000e+03      0.0000e+00
* nhcomi*      r7 500      500 e
* nhceli*      -1 1 2 3 4 s
* nhceli*      5 6 6e
* nhcomo*      r7 823      823 e
* nhcelo*      -2 2 3 4s
* nhcelo*      5 6 7 7e
* dz *      0.7418 r4 0.6096      0.3198e
* elev *      -7.2477e+00 -6.5720e+00 -5.9624e+00s
* elev *      -5.3528e+00 -4.7432e+00 -4.2785e+00e
* idrod *      1e
* idrodo*      1e
* rdx *      3.9373e+02e
* radrd *      1.6882e-02 1.7076e-02 1.7269e-02e
* matrd * f      52e
* nfax * f      1e
* rftn * f      3.7300e+02e
*
*
* Upflow (Heated Pb/Al structure connected to Water only)
***** type      num      id      ctitle
rod      963      963 $963$ Blanket row1 htr
*      ncrx      ncrz      ittc
      1      6      0
*      nopowr      nrldr      modez      liqlev      iaxcnd
      0      1      1      0      1
*      idbci      idbco      hdri      hdro
      0      2      0.0000e+00      2.1164e-02
*      nrods      nodes      irftr      nzmax
      1      6      0      26
*      dtxht(1)      dtxht(2)      dznht      hgapo      shelv
      1.0000e+03      1.0000e+03      1.0000e+02      1.0000e+03      0.0000e+00
*      irpwty      ndgx      ndhx      nrts      nhist
      7      0      0      10      0
*      irpwtr      irpwsv      nrpwtb      nrpwsv      nrpwrf
      104      1      20      0      0
*      izpwtr      izpwsv      nzpwtb      nzpwsv      nzpwrf
      0      1      1      0      0
*      nmwrx      nfcil      nfcil
      0      0      0
*      nzpwz      nzpwi      nfbpwt
      16      -1      0
*      react      tneut      rpwoff      rrpwmx      rpwscl
      0.0000e+00      0.0000e+00      0.0000e+00      1.0000e+12      1.8110e+06
*      rpowri      zpwin      zpwoff      rrpwmx
      1.8110e+06      0.0000e+00      0.0000e+00      1.0000e+20
*      extsou      pldr      pdrat      fucrac
      0.0000e+00      0.0000e+00      1.1000e+00      1.0000e+00
* nhcomo*      r7 500      500e
* nhcelo*      -1 1 2 3 4s
* nhcelo*      5 6 6e
* dz *      0.7418 r4 0.6096      0.3198e
* elev *      -7.2477e+00 -6.5720e+00 -5.9624e+00s
* elev *      -5.3528e+00 -4.7432e+00 -4.2785e+00e
* idrod * f      1e
* rdx * f      3.9373e+02e

```

TRAC BLANKET SYSTEM MODEL

```

* radrd *      0.0000e+00      5.0017e-03      1.0003e-02      1.5005e-02s
* radrd *      1.5497e-02      1.5989e-02e
* matrd * r3  51      r2 52e
* nfax * f      1e
* rftn * f      3.7300e+02e
* rdpr * f      1.0000e+00e
* cpwr *      1.0000e+00e
* zpwzt *      0.0000e+00      2.3345e-01      4.6655e-01      7.0000e-01s
* zpwzt *      9.3345e-01      1.1666e+00      1.4000e+00      1.6335e+00s
* zpwzt *      1.8666e+00      2.1000e+00      2.3335e+00      2.5666e+00s
* zpwzt *      2.8000e+00      3.0334e+00      3.2666e+00      3.5000e+00e
* zpwtb *      0.0000e+00      1.1700e-02      3.4800e-02      1.6680e-01s
* zpwtb *      4.7850e-01      1.5993e+00      2.2734e+00      2.4080e+00s
* zpwtb *      2.3795e+00      2.2644e+00      2.0159e+00      8.2910e-01s
* zpwtb *      2.7530e-01      1.4430e-01      7.2700e-02      4.0200e-02s
* zpwtb *      0.0000e+00e
* rpwtb *      0.000e+00      1.402e-02s
*          1.000e+00      1.220e-02s
*          2.000e+00      1.146e-02s
*          5.000e+00      1.089e-02s
*          1.000e+01      1.068e-02s
*          2.000e+01      1.041e-02s
*          6.000e+01      9.584e-03s
*          1.200e+02      8.659e-03s
*          3.000e+02      7.036e-03s
*          6.000e+02      5.983e-03s
*          1.200e+03      5.332e-03s
*          3.600e+03      4.543e-03s
*          7.200e+03      4.012e-03s
*          3.600e+04      2.586e-03s
*          8.640e+04      1.747e-03s
*          1.728e+05      1.168e-03s
*          4.320e+05      6.158e-04s
*          8.640e+05      3.734e-04s
*          1.728e+06      2.259e-04s
*          2.592e+06      1.625e-04e
* fpuo2 *      0.0000e+00e
* ftd *      1.0000e+00e
* gmix *      1.0000e+00r06 0.0000e+00e
* gmles *      1.0000e+00e
* pgapt *      1.0000e+00e
* plvol *      1.0000e+00e
* pslen *      1.0000e+00e
* clen *      1.0000e+00e
* burn * f      1.0000e+00e
*
*
* ===== MODULE 5 (DOWNFLOW) =====
*
* Downflow (Unheated Al structure connected to Water & Cavity)
***** type num id ctitle
rod 932 932 $932$He to Aluminum and then water
* ncrx ncrz ittc
* 1 6 0
* nopowr nrldr modez liqlev iaxcnd
* 1 2 1 0 1
* idbci idbco hdri hdro
* 2 2 1.0210e-02 5.3477e-02
* nrods nodes irftr nzmax
* 1 3 0 23
* dtxht(1) dtxht(2) dznht hgapo shelv
1.0000e+03 1.0000e+03 1.0000e+02 1.0000e+03 0.0000e+00

```

TRAC BLANKET SYSTEM MODEL

```

* nhcomi*      r7 507      507 e
* nhceli*      -1 1 2 3 4 s
* nhceli*      5 6 6e
* nhcomo*      r7 823      823 e
* nhcelo*      -7 7 6 5 4 s
* nhcelo*      3 2 2e
* dz *         0.3198 r4 0.6096 0.7418e
* elev *       -4.2785e+00 -4.7432e+00 -5.3528e+00s
* elev *       -5.9624e+00 -6.5720e+00 -7.2477e+00e
* idrod *      1e
* idrodo*      1e
* rdx *        3.9373e+02e
* radrd *      1.6882e-02 1.7076e-02 1.7269e-02e
* matrdr * f    52e
* nfax * f      1e
* rftn * f     3.7300e+02e
*
*
* Downflow (Heated Pb/Al structure connected to Water only)
***** type          num          id          ctitle
rod          979          979 $979$ Blanket row2 htr
*           ncrx          ncrz          ittc
*           1            6            0
*           nopowr        nrldr          modez          liqlev          iaxcnd
*           0            1            1            0            1
*           idbci         idbco          hdri          hdro
*           0            2            0.0000e+00 2.1164e-02
*           nrods         nodes          irftr          nzmax
*           1            6            0            26
*           dtxht(1)      dtxht(2)      dznht          hgapo          shelv
*           1.0000e+03 1.0000e+03 1.0000e+02 1.0000e+03 0.0000e+00
*           irpwty        ndgx          ndhx          nrts          nhist
*           7            0            0            10          0
*           irpwtr        irpwsv        nrpwtb        nrpwsv        nrpwrfr
*           104          1            20          0            0
*           izpwtr        izpwsv        nzpwtb        nzpwsv        nzpwrfr
*           0            1            1            0            0
*           nmwrx         nfci          nfcil
*           0            0            0
*           nzpwz         nzpwi          nfbpwt
*           16          -1            0
*           react         tneut          rpwoff          rrpwmx          rpwscl
*           0.0000e+00 0.0000e+00 0.0000e+00 1.0000e+12 1.3550e+06
*           rpowri        zpwin          zpwoff          rrpwmx
*           1.3550e+06 0.0000e+00 0.0000e+00 1.0000e+20
*           extsou        pldr          pdrat          fucrac
*           0.0000e+00 0.0000e+00 1.1000e+00 1.0000e+00
* nhcomo*      r7 507      507e
* nhcelo*      -1 1 2 3 4s
* nhcelo*      5 6 6e
* dz *         0.3198 r4 0.6096 0.7418e
* elev *       -4.2785e+00 -4.7432e+00 -5.3528e+00s
* elev *       -5.9624e+00 -6.5720e+00 -7.2477e+00e
* idrod * f      1e
* rdx * f      3.9373e+02e
* radrd *      0.0000e+00 5.0017e-03 1.0003e-02 1.5005e-02s
* radrd *      1.5497e-02 1.5989e-02e
* matrdr * r3 51 r2 52e
* nfax * f      1e
* rftn * f     3.7300e+02e
* rdpwr * f     1.0000e+00e
* cpowr *      1.0000e+00e

```

TRAC BLANKET SYSTEM MODEL

```

* zpwzt * 0.0000e+00 2.3345e-01 4.6655e-01 7.0000e-01s
* zpwzt * 9.3345e-01 1.1666e+00 1.4000e+00 1.6335e+00s
* zpwzt * 1.8666e+00 2.1000e+00 2.3335e+00 2.5666e+00s
* zpwzt * 2.8000e+00 3.0334e+00 3.2666e+00 3.5000e+00e
* zpwtb * 0.0000e+00 1.1700e-02 3.4800e-02 1.6680e-01s
* zpwtb * 4.7850e-01 1.5993e+00 2.2734e+00 2.4080e+00s
* zpwtb * 2.3795e+00 2.2644e+00 2.0159e+00 8.2910e-01s
* zpwtb * 2.7530e-01 1.4430e-01 7.2700e-02 4.0200e-02s
* zpwtb * 0.0000e+00e
* rpwtb * 0.000e+00 1.402e-02s

```

```

1.000e+00 1.220e-02s
2.000e+00 1.146e-02s
5.000e+00 1.089e-02s
1.000e+01 1.068e-02s
2.000e+01 1.041e-02s
6.000e+01 9.584e-03s
1.200e+02 8.659e-03s
3.000e+02 7.036e-03s
6.000e+02 5.983e-03s
1.200e+03 5.332e-03s
3.600e+03 4.543e-03s
7.200e+03 4.012e-03s
3.600e+04 2.586e-03s
8.640e+04 1.747e-03s
1.728e+05 1.168e-03s
4.320e+05 6.158e-04s
8.640e+05 3.734e-04s
1.728e+06 2.259e-04s
2.592e+06 1.625e-04e

```

```

* fpuo2 * 0.0000e+00e
* ftd * 1.0000e+00e
* gmix * 1.0000e+00r06 0.0000e+00e
* gmles * 1.0000e+00e
* pgapt * 1.0000e+00e
* plvol * 1.0000e+00e
* pslen * 1.0000e+00e
* clen * 1.0000e+00e
* burn * f 1.0000e+00e

```

```

* ===== MODULE 6 (HORIZONTAL OUTFLOW) =====

```

```

* Horizontal outflow (Unheated Al structure not connected to Water & Cavity)

```

```

* Loop15

```

```

* He + Al + Water in Lower Back Module Row2

```

```

***** type num id ctitle
rod 915 915 $915$He to Aluminum and then water
* ncrx ncrz ittc
1 5 0
* nopowr nridr modez liqlev iaxcnd
1 2 1 0 1
* idbci idbco hdri hdro
2 0 1.0210e-02 5.3477e-02
* nrods nodes irftr nzmax
1 3 0 23
* dtxht(1) dtxht(2) dznht hgapo shelv
1.0000e+03 1.0000e+03 1.0000e+02 1.0000e+03 0.0000e+00
* nhcomi* r6 528 528 e
* nhceli* -1 1 2 3 4 s
5 5e
* dz * r4 4.9580e-01 4.9580e-01e

```

TRAC BLANKET SYSTEM MODEL

```

* elev *      -7.1317e+00  -7.1317e+00  -7.1317e+00s
* elev *      -7.1317e+00  -7.1317e+00e
* idrod *      1e
* idrodo *     1e
* rdx *      1.3224e+02e
* radrd *     1.6882e-02   1.7076e-02   1.7269e-02e
* matr * f      52e
* nfax * f      1e
* rftn * f     3.7300e+02e

```

```

* Horizontal outflow (Heated Pb/Al structure connected to Water only)

```

```

* Loop15

```

```

* Lower Blanket Back Module Row2 Region

```

```

***** type          num          id          ctitle
rod          965          965 $965$ Blanket Row2 htr
*          ncrx          ncrz          ittc
*          1            5            0
*          nopowr        nrldr          modez          liqlev          iaxcnd
*          0            1            1            0            1
*          idbci          idbco          hdri          hdro
*          0            2            0.0000e+00      2.1164e-02
*          nrods          nodes          irftr          nzmax
*          1            6            0            26
*          dtxht(1)      dtxht(2)      dznht          hgapo          shelv
*          1.0000e+03    1.0000e+03    1.0000e+02      1.0000e+03    0.0000e+00
*          irpwtly        ndgx          ndhx          nrts          nhist
*          7            0            0            10          0
*          irpwtr        irpwsv        nrpwtb        nrpwsv        nrpwrf
*          104           1            20           0            0
*          izpwtr        izpwsv        nzpwtb        nzpwsv        nzpwrf
*          0            1            1            0            0
*          nmwrx          nfcil          nfcil
*          0            0            0
*          nzpwz          nzpwi          nfbpwt
*          6            -1           0
*          react          tneut          rpwoff          rrpwmx          rpwscl
*          0.0000e+00    0.0000e+00    0.0000e+00    1.0000e+12    5.7120e+06
*          rpowri          zpin          zpowff          rrpwmx
*          5.7120e+06    0.0000e+00    0.0000e+00    1.0000e+20
*          extsou          pldr          pdrat          fucrac
*          0.0000e+00    0.0000e+00    1.1000e+00    1.0000e+00
* nhcomo*      r6 528      528e
* nhcelo*      -1 1 2 3 4s
*          5 5e
* dz * r4 4.9580e-01  4.9580e-01e
* elev *      -7.1317e+00  -7.1317e+00  -7.1317e+00s
* elev *      -7.1317e+00  -7.1317e+00e
* idrod * f      1e
* rdx * f      1.3224e+02e
* radrd *      0.0000e+00   5.0017e-03   1.0003e-02   1.5005e-02s
* radrd *      1.5497e-02   1.5989e-02e
* matr * r3 51 r2 52e
* nfax * f      1e
* rftn * f     3.7300e+02e
* rdpwr * f     1.0000e+00e
* cpowr *      1.0000e+00e
* zpwzt *      0.0000e+00   4.9580e-01   9.9160e-01   1.4874e+00s
* zpwzt *      1.9832e+00   2.4790e+00e
* zpwtb *      0.0000e+00 r5 1.0000e+00 0.0000e+00e

```


TRAC BLANKET SYSTEM MODEL

```

* rpwtb *      0.000e+00      1.411e-02s
                1.000e+00      1.143e-02s
                2.000e+00      1.036e-02s
                5.000e+00      9.552e-03s
                1.000e+01      9.335e-03s
                2.000e+01      9.092e-03s
                6.000e+01      8.413e-03s
                1.200e+02      7.661e-03s
                3.000e+02      6.338e-03s
                6.000e+02      5.472e-03s
                1.200e+03      4.932e-03s
                3.600e+03      4.287e-03s
                7.200e+03      3.841e-03s
                3.600e+04      2.516e-03s
                8.640e+04      1.667e-03s
                1.728e+05      1.063e-03s
                4.320e+05      5.131e-04s
                8.640e+05      2.946e-04s
                1.728e+06      1.748e-04s
                2.592e+06      1.257e-04e

* fpuo2 *      0.0000e+00e
* ftd *        1.0000e+00e
* gmix *      1.0000e+00r06 0.0000e+00e
* gmles *      1.0000e+00e
* pgapt *      1.0000e+00e
* plvol *      1.0000e+00e
* pslen *      1.0000e+00e
* clienn *     1.0000e+00e
* burn * f     1.0000e+00e
*
*
* ===== MODULE 6 (HORIZONTAL INFLOW) =====
*
* (These structures not modeled at this time.)
*
* ===== HR SECONDARY SIDE =====
*
* HR Heat exchanger number 1b
*
*****      type          num          id          ctitle
rod          919          919 $919$ primary to secondary h.e.
*           ncrx          ncrz          ittc
*           1             4             0
*           nopowr        nrldr          modez          liqlev          iaxcnd
*           1             2             1             0             1
*           idbci          idbco          hdri           hdro
*           2             2             1.0210e-02      5.3477e-02
*           nrods          nodes          irftr          nzmax
*           1             6             0             23
*           dtxht(1)       dtxht(2)       dznht          hgapo          shelv
*           1.0000e+03      1.0000e+03      1.0000e+02      1.0000e+03      0.0000e+00
* nhcomi*      r5  54      54 e
* nhceli*      -1  1  2  3  4 s
*              4e
* nhcomo*      f  711 e
* nhcelo*      -4  4  3 s
*              2  1 -1 e
* dz * r3 9.9000e-01  9.9000e-01e
* grav * f  3.5559e+00e
* idrod *      1e
* idrodo*      1e

```

TRAC BLANKET SYSTEM MODEL

```

* rdx * 6.9080e+03e
* radrd * 5.1050e-03 5.3540e-03 5.6030e-03 5.8520e-03s
* radrd * 6.1010e-03 6.3500e-03e
* matr * f 7e
* nfax * f 1e
* rftn * f 3.780e+02e
*
*
* HR Heat exchanger number 1a
*
***** type num id ctitle
rod 920 920 $920$ primary to secondary h.e.
* ncrx ncrz ittc
1 4 0
* nopowr nridr modez liqlev iaxcnd
1 2 1 0 1
* idbci idbco hdri hdro
2 2 1.0210e-02 5.3477e-02
* nrods nodes irftr nzmax
1 6 0 23
* dtxht(1) dtxht(2) dznht hgapo shelv
1.0000e+03 1.0000e+03 1.0000e+02 1.0000e+03 0.0000e+00
* nhcomi* r5 50 50 e
* nhceli* -1 1 2 3 4 s
4e
* nhcomo* f 713 e
* nhcelo* -4 4 3 s
2 1 -1 e
* dz * r3 9.9000e-01 9.9000e-01e
* grav * f 5.0559e+00e
* idrod * 1e
* idrodo* 1e
* rdx * 6.9080e+03e
* radrd * 5.1050e-03 5.3540e-03 5.6030e-03 5.8520e-03s
* radrd * 6.1010e-03 6.3500e-03e
* matr * f 7e
* nfax * f 1e
* rftn * f 3.780e+02e
*
*
* HR Heat exchanger number 2b
*
***** type num id ctitle
rod 921 921 $921$ primary to secondary h.e.
* ncrx ncrz ittc
1 4 0
* nopowr nridr modez liqlev iaxcnd
1 2 1 0 1
* idbci idbco hdri hdro
2 2 1.0210e-02 5.3477e-02
* nrods nodes irftr nzmax
1 6 0 23
* dtxht(1) dtxht(2) dznht hgapo shelv
1.0000e+03 1.0000e+03 1.0000e+02 1.0000e+03 0.0000e+00
* nhcomi* r5 55 55 e
* nhceli* -1 1 2 3 4 s
4e
* nhcomo* f 731 e
* nhcelo* -4 4 3 s
2 1 -1 e
* dz * r3 9.9000e-01 9.9000e-01e
* grav * f 3.5559e+00e

```

TRAC BLANKET SYSTEM MODEL

```

* idrod *          1e
* idrodo*          1e
* rdx *           6.9080e+03e
* radrd *          5.1050e-03  5.3540e-03  5.6030e-03  5.8520e-03s
* radrd *          6.1010e-03  6.3500e-03e
* matrd * f        7e
* nfax * f         1e
* rftn * f        3.780e+02e
*
*
* HR Heat exchanger number 2a
*
***** type          num          id          ctitle
rod          922      922 $922$ primary to secondary h.e.
*           ncrx      ncrz      ittc
*           1         4         0
*           nopowr     nrldr      modez      liqlev      iaxcnd
*           1         2         1         0         1
*           idbci      idbco      hdri      hdro
*           2         2         1.0210e-02  5.3477e-02
*           nrods      nodes      irftr      nzmax
*           1         6         0         23
*           dtxht(1)    dtxht(2)    dznht      hgapo      shelv
*           1.0000e+03  1.0000e+03  1.0000e+02  1.0000e+03  0.0000e+00
* nhcomi*      r5 51      51 e
* nhceli*      -1 1 2 3 4 s
*              4e
* nhcomo*      f 733 e
* nhcelo*      -4 4 3 s
*              2 1 -1 e
* dz * r3 9.9000e-01  9.9000e-01e
* grav * f 5.0559e+00e
* idrod *          1e
* idrodo*          1e
* rdx *           6.9080e+03e
* radrd *          5.1050e-03  5.3540e-03  5.6030e-03  5.8520e-03s
* radrd *          6.1010e-03  6.3500e-03e
* matrd * f        7e
* nfax * f         1e
* rftn * f        3.780e+02e
*
*

```

```

* ===== RHR SECONDARY SIDE =====
*

```

```

* RHR Heat exchanger
*

```

```

***** type          num          id          ctitle
rod          971      971 $971$ rhr to secondary h.e.
*           ncrx      ncrz      ittc
*           1         4         0
*           nopowr     nrldr      modez      liqlev      iaxcnd
*           1         2         1         0         1
*           idbci      idbco      hdri      hdro
*           2         2         1.0210e-02  5.3477e-02
*           nrods      nodes      irftr      nzmax
*           1         6         0         23
*           dtxht(1)    dtxht(2)    dznht      hgapo      shelv
*           1.0000e+03  1.0000e+03  1.0000e+02  1.0000e+03  0.0000e+00
* nhcomi*      r5 652     652 e
* nhceli*      -1 1 2 3 4 s
*              4e
* nhcomo*      f 671 e

```

TRAC BLANKET SYSTEM MODEL

```
* nhcelo*      -4  4  3 s
                2  1 -1 e
* dz      * r3 9.9000e-01  9.9000e-01e
* grav * f  2.9560e+00e
* idrod *                1e
* idrodo*                1e
* rdx      *      2.7700e+02e
* radrd *      5.1050e-03  5.3540e-03  5.6030e-03  5.8520e-03s
* radrd *      6.1010e-03  6.3500e-03e
* matrd * f                7e
* nfax * f                1e
* rftn * f      3.780e+02e
*
end
*
*****
* time-step data *
*****
*
*      dtmin      dtmax      tend      rtwfp
* 1.0000e-04  1.0000e-00  4.0000e+02  1.0000e+01
*      edint      gfint      dmpint      sedint
* 1.0000e+01  5.0000e+00  1.0000e+06  1.0000e+06
*
*      endflag
* -1.0000e+00
```

Appendix B: TRAC Graphics Input File for Normal Operation Case

The file listed below represents the entire TRAC code "graphin" file that contains the various graphics points selected for output to the "tecsum.grf" file. Modifications were made to the TRAC code standard output routines in order to generate an ASCII output file called "tecsum.grf". This output file contains results at each requested graphic point (i.e., TRAC component and specified cell number) written out at a specified time frequency.

In a post-processing mode, the graphic ASCII output file is split into individual ASCII files for each graphic point using a special purpose fortran program named "TSPLIT". The output from TSPLIT was formatted to be TecPlot™ ready. TecPlot™ is a widely used commercial scientific and engineering data visualization software package for creating multi-dimensional graphics interactively. For additional details regarding the post-processing procedure see Ref. [7].

Input file graphin:

```

/ npoints /
  182
/ component      cell      ictype      id_leg/
  340             1         1           1      Fixed outlet header
  380             1         1           1      Fixed inlet header

  454             2         0           1      Module 1 pipe before break
  173             2         0           1      Module 2 pipe before break
  415             2         0           1      Module 3 pipe before break
  485             2         0           1      Module 4 pipe before break
  513             2         0           1      Module 5 pipe before break
  541             2         0           1      Module 6 pipe before break

  375             1         0           1      Module 1 pipe after break
   82             1         0           1      Module 2 pipe after break
   86             1         0           1      Module 3 pipe after break
   88             1         0           1      Module 4 pipe after break
   90             1         0           1      Module 5 pipe after break
   84             1         0           1      Module 6 pipe after break

  300             1         0           1      Module 1 Row1
  102             1         0           1      Module 2 Row2
  409             1         0           1      Module 3 Row1
  412             1         0           1      Module 4 Row1
  500             1         0           1      Module 5 Row2
  528             1         0           1      Module 6 Low Power

  300             3         0           1      Module 1 Row1
  102             3         0           1      Module 2 Row2
  409             3         0           1      Module 3 Row1
  412             3         0           1      Module 4 Row1
  500             3         0           1      Module 5 Row2
  528             3         0           1      Module 6 Low Power

  300             5         0           1      Module 1 Row1
  102             6         0           1      Module 2 Row2
  409             5         0           1      Module 3 Row1
  412             6         0           1      Module 4 Row1
  500             6         0           1      Module 5 Row2

```

TRAC BLANKET SYSTEM MODEL

528	5	0	1	Module 6 Low Power
370	1	1	1	Module 1 Inlet Plenum
350	1	1	1	Module 1 Middle Plenum
330	1	1	1	Module 1 Outlet Plenum
172	1	1	1	Module 2 Inlet Plenum
147	1	1	1	Module 2 middle Plenum
133	1	1	1	Module 2 Outlet Plenum
479	1	1	1	Module 3 Inlet Plenum
418	1	1	1	Module 3 Middle Plenum
423	1	1	1	Module 3 Outlet Plenum
489	1	1	1	Module 4 Inlet Plenum
419	1	1	1	Module 4 Middle Plenum
483	1	1	1	Module 4 Outlet Plenum
510	1	1	1	Module 5 Inlet Plenum
503	1	1	1	Module 5 Middle Plenum
508	1	1	1	Module 5 Outlet Plenum
538	1	1	1	Module 6 Inlet Plenum
531	1	1	1	Module 6 Middle Plenum
536	1	1	1	Module 6 Outlet Plenum
26	1	0	1	Hot leg pump suction line
22	7	0	1	Hot leg pump suction line near break
20	1	0	1	Hot leg pump suction line near break
30	1	0	1	PCL Pump 1 Suction
30	2	0	1	PCL Pump 1 Discharge
31	1	0	1	PCL Pump 2 Suction
31	2	0	1	PCL Pump 2 Discharge
32	2	0	1	PCL Pump 1 check valve
33	2	0	1	PCL Pump 2 check valve
37	1	0	1	PCL Pump to HX
48	3	0	1	PCL Hx 1 inlet
52	2	0	1	PCL Hx 1 middle
56	1	0	1	PCL Hx 1 outlet
49	2	0	1	PCL Hx 2 inlet
53	2	0	1	PCL Hx 2 middle
57	3	0	1	PCL Hx 2 outlet
713	4	0	1	PCL Hx 1 secondary side outlet
710	1	0	1	PCL Hx 1 secondary side inlet fill
733	4	0	1	PCL Hx 2 secondary side outlet
730	1	0	1	PCL Hx 2 secondary side inlet fill
62	1	0	1	Cold leg Hx discharge line
66	1	0	1	Cold leg Hx discharge line near break
67	1	1	1	Cold leg Hx discharge line near break
854	1	0	1	Cold leg Hx discharge line near break
854	2	0	1	Cold leg Hx discharge line near break
68	2	0	1	Cold leg Hx discharge line near break
630	1	0	1	RHR Pump Suction
630	2	0	1	RHR Pump Discharge
640	3	0	1	RHR Hx inlet
660	1	0	1	RHR Hx outlet
671	4	0	1	RHR Hx secondary side outlet
672	1	0	1	RHR Hx secondary side inlet fill
761	1	0	1	Pzr Pressure Signal

TRAC BLANKET SYSTEM MODEL

766	1	0	1	Pzr Bottom Pressure
951	1	3	1	Hot Module (1) upflow inside
951	3	3	1	Hot Module (1) upflow inside
951	5	3	1	Hot Module (1) upflow inside
951	1	3	2	Hot Module (1) upflow outside
951	3	3	2	Hot Module (1) upflow outside
951	5	3	2	Hot Module (1) upflow outside
955	1	3	1	Hot Module (2) upflow inside
955	3	3	1	Hot Module (2) upflow inside
955	6	3	1	Hot Module (2) upflow inside
955	1	3	2	Hot Module (2) upflow outside
955	3	3	2	Hot Module (2) upflow outside
955	6	3	2	Hot Module (2) upflow outside
961	1	3	1	Hot Module (3) upflow inside
961	3	3	1	Hot Module (3) upflow inside
961	5	3	1	Hot Module (3) upflow outside
961	1	3	2	Hot Module (3) upflow outside
961	3	3	2	Hot Module (3) upflow outside
961	5	3	2	Hot Module (3) upflow outside
962	1	3	1	Hot Module (4) upflow inside
962	3	3	1	Hot Module (4) upflow inside
962	6	3	1	Hot Module (4) upflow inside
962	1	3	2	Hot Module (4) upflow outside
962	3	3	2	Hot Module (4) upflow outside
962	6	3	2	Hot Module (4) upflow outside
963	1	3	1	Hot Module (5) upflow inside
963	3	3	1	Hot Module (5) upflow inside
963	6	3	1	Hot Module (5) upflow inside
963	1	3	2	Hot Module (5) upflow outside
963	3	3	2	Hot Module (5) upflow outside
963	6	3	2	Hot Module (5) upflow outside
965	1	3	1	Hot Module (6) upflow inside
965	3	3	1	Hot Module (6) upflow inside
965	5	3	1	Hot Module (6) upflow inside
965	1	3	2	Hot Module (6) upflow outside
965	3	3	2	Hot Module (6) upflow outside
965	5	3	2	Hot Module (6) upflow outside
820	1	0	1	Flood valve pool side
820	2	0	1	Flood valve vessel side
821	1	0	1	Flood horizontal line
821	3	0	1	Flood horizontal line
821	6	0	1	Flood horizontal line
822	1	0	1	Flood vertical line
822	3	0	1	Flood vertical line
822	6	0	1	Flood vertical line
823	1	0	1	Cavity vessel lower 1
823	2	0	1	Cavity vessel lower 2
823	3	0	1	Cavity vessel lower 3
823	4	0	1	Cavity vessel lower 4
823	6	0	1	Cavity vessel lower 6
823	8	0	1	Cavity vessel lower 8
823	10	0	1	Cavity vessel lower 10
823	11	0	1	Cavity vessel lower 11
840	1	0	1	Cavity line to Hot module loc. 1
840	2	0	1	Cavity line to Hot module loc. 2
824	1	1	1	Cavity vessel Hot module loc.
825	1	0	1	Cavity vessel middle 1

TRAC BLANKET SYSTEM MODEL

825	4	0	1	Cavity vessel middle 1
826	1	1	1	Cavity vessel HR line loc.
850	1	0	1	Cavity line to HR line (HR side)
850	2	0	1	Cavity line to HR line (HR side)
852	1	0	1	Cavity line to HR line (Header side)
852	2	0	1	Cavity line to HR line (Header side)
828	3	0	1	Vent Line break side
811	1	1	1	Cavity Pool flood line plenum
810	1	0	1	Cavity pool upper 1
810	4	0	1	Cavity pool upper 4
810	7	0	1	Cavity pool upper 7
810	10	0	1	Cavity pool upper 10
984	1	3	2	Module 1 downflow A1 1
984	3	3	2	Module 1 downflow A1 3
984	5	3	2	Module 1 downflow A1 5
901	1	3	2	Module 1 upflow A1 1
901	3	3	2	Module 1 upflow A1 3
901	5	3	2	Module 1 upflow A1 5
916	1	3	2	Module 2 downflow A1 1
916	3	3	2	Module 2 downflow A1 3
916	6	3	2	Module 2 downflow A1 6
905	1	3	2	Module 2 upflow A1 1
905	3	3	2	Module 2 upflow A1 3
905	6	3	2	Module 2 upflow A1 6
988	1	3	2	Module 3 downflow A1 1
988	3	3	2	Module 3 downflow A1 3
988	5	3	2	Module 3 downflow A1 5
911	1	3	2	Module 3 upflow A1 1
911	3	3	2	Module 3 upflow A1 3
911	5	3	2	Module 3 upflow A1 5
931	1	3	2	Module 4 downflow A1 1
931	3	3	2	Module 4 downflow A1 3
931	6	3	2	Module 4 downflow A1 6
912	1	3	2	Module 4 upflow A1 1
912	3	3	2	Module 4 upflow A1 3
912	6	3	2	Module 4 upflow A1 6
932	1	3	2	Module 5 downflow A1 1
932	3	3	2	Module 5 downflow A1 3
932	6	3	2	Module 5 downflow A1 6
913	1	3	2	Module 5 upflow A1 1
913	3	3	2	Module 5 upflow A1 3
913	6	3	2	Module 5 upflow A1 6

INPUT NOTES:

npoints - number of locations (points) within TRAC model graphics requested
 component - component id number containing specified graph point
 cell - cell number within component where graphics requested
 (number second leg of tee sequentially from end cell number on first leg)
 ictype - type of component:
 (0 for fill, pipe, pressurizer, pump, turb, value)
 (1 for plenum)
 (2 for tee)
 id_leg - which leg of component cell is located in:
 (1 always for fill, pipe, pressurizer, pump, plenum, turb, value)
 (1 or 2 for tee's)

OUTPUT NOTES:

TRAC BLANKET SYSTEM MODEL

tsec	- Time into simulation (sec)
Psia	- Cell center pressure (psia)
Qf	- Liquid volumetric flowrate at cell face (gpm)
tl	- Liquid phase temperature (C)
tsub	- Liquid subcooling (C)
tsat	- Liquid saturation temperature (C)
rol	- Liquid phase density (kg/m ³)
vl	- Liquid phasic velocity at cell face (m/s)
Pa	- Cell center pressure (Pa)
qf	- Liquid volumetric flowrate at cell face (m ³ /s)
void	- Gas void fraction (-)
Qg	- Gas volumetric flowrate at cell face (gpm)
qg	- Gas volumetric flowrate at cell face (m ³ /s)
tv	- Gas phase temperature (C)
rov	- Gas phase density (kg/m ³)
vv	- Gas phasic velocity at cell face (m/s)
pair	- Partial pressure of non-condensable in gas phase (psia)

(This Page Intentionally Left Blank)

Appendix C: QKTRAC - A Simple Hydraulic Code for HR Assessment

This appendix contains the source listing for the code named QKTRAC and all of its associated subroutines. QKTRAC was written specifically for assessing the steady-state isothermal hydraulic behavior of the HR coolant loop. Sample input and output files are provided.

Program qtrac.f:

```

program qktrac
c
c *****
c *
c * This program calculates the pressure profile in the outer
c * flow loop of the APT target/blanket cooling system. The
c * mass flowrate and the pressure at the inlet header are
c * specified, and the following pressures are calculated
c * sequentially: pressurizer, heat exchanger outlet, heat
c * exchanger inlet, pump outlet, pump inlet, and the outlet
c * header. The heat exchanger and pump inlet and outlet
c * pressures are respectively upstream and downstream of the
c * "T"'s in the pipe network.
c *
c *****
c
c subroutines:
c
c   frict.f      heatx.f      module.f      npsha.f
c   npshr.f      pipdlp.f     pmphc.f       propw.f
c   psat.f       pump.f
c
c   implicit real (a-h,o-z), integer (i-n)
c   real kebow_i, kebow_h, kebow_o, kvalv_i, kvalv_h, kvalv_o
c   real kform_i, kform_h, kform_o, kent , kext
c   character*80 line1, title
c
c   parameter (mxmod=20, one=1.0)
c
c   dimension flowm(mxmod)
c   dimension pres_a(mxmod), pres_b(mxmod)
c   dimension kent(mxmod), kext(mxmod)
c   dimension kform_i(mxmod), kform_h(mxmod), kform_o(mxmod)
c   dimension kvalv_i(mxmod), kvalv_h(mxmod), kvalv_o(mxmod)
c   dimension kebow_i(mxmod), kebow_h(mxmod), kebow_o(mxmod)
c   dimension nebow_i(mxmod), nebow_h(mxmod), nebow_o(mxmod)
c   dimension dleg_i(mxmod), dleg_h(mxmod), dleg_o(mxmod)
c   dimension zl_i(mxmod), zl_h(mxmod), zl_o(mxmod)
c   dimension elv_a(mxmod), elv_b(mxmod)
c
c === SET PARAMETERS AND OPEN INPUT/OUTPUT FILES =====
c
c   iin1 = 5
c   iout1 = 6
c   iout2 = 7
c   iout3 = 8
c   iout4 = 10
c   pconv = 14.696/101325.0
c   mxhydra = 200

```

TRAC BLANKET SYSTEM MODEL

```

      hconvg = 1.0e-2
      weight = 0.5
c
      open (unit=iin1 ,file='input.dat' ,status='old')
      open (unit=iout1,file='results.out',status='unknown')
      open (unit=iout2,file='input.in' ,status='unknown')
      open (unit=iout3,file='heatX.out' ,status='unknown')
      open (unit=iout4,file='pumps.out' ,status='unknown')
c
c === READ IN INPUT PARAMETERS =====
c
c *** section #1 (pressurizer to inlet header) ***
c
c      zlg1 - length
c      diam1 - diameter
c      rough - pipe roughness
c      delz1 - delta "z"
c      dhdrin - inlet header diameter
c      fment1 - entrance loss coef.
c      fmext1 - exit loss coef.
c      fmeb1 - elbow loss coef.
c      elbn1 - number of elbows
c      isolve - flag option for solving supply & demand curves
c              (0 no, 1 yes)
c      flow - mass flowrate
c      phdin - inlet header pressure
c
      read (iin1,900) title
      do i=1,20
         read (iin1,900) line1
      enddo
      write (iout1,910) title
      title = title
      line1 = line1
c
      write (iout2,2010)
      read (iin1 ,900) line1
      write (iout2,900) line1
      read (iin1 ,*) zlg1,diam1,rough,delz1,dhdrin
      write (iout2,*) zlg1,diam1,rough,delz1,dhdrin
      read (iin1 ,900) line1
      write (iout2,900) line1
      read (iin1 ,*) fment1,fmext1,fmeb1,elbn1
      write (iout2,*) fment1,fmext1,fmeb1,elbn1
      read (iin1 ,900) line1
      write (iout2,900) line1
      read (iin1 ,*) isolve,flow,phdin
      write (iout2,*) isolve,flow,phdin
      write (iout2,2011)
c
c *** section #2 (heat exchanger outlet to pressurizer) ***
c
c      zlg2 - length
c      diam2 - diameter
c      delz2 - delta "z"
c      fment2 - entrance loss coef.
c      fmext2 - exit loss coef.
c      fmeb2 - elbow loss coef.
c      elbn2 - number of elbows
c
      do i=1,10
         read (iin1,900) line1

```

TRAC BLANKET SYSTEM MODEL

```

      enddo
c
      write (iout2,2020)
      read (iin1 ,900) line1
      write (iout2,900) line1
      read (iin1 ,*)   zlg2,diam2,delz2
      write (iout2,*)   zlg2,diam2,delz2
      read (iin1 ,900) line1
      write (iout2,900) line1
      read (iin1 ,*)   fment2,fmext2,fmeb2,elbn2
      write (iout2,*)   fment2,fmext2,fmeb2,elbn2
      write (iout2,2021)
c
c *** section #3 (heat exchanger inlet to outlet) ***
c
c      zlhxi1 - inlet side length leg 1
c      zlhxi2 - inlet side length leg 2
c      zlhxo1 - outlet side length leg 1
c      zlhxo2 - outlet side length leg 2
c      zltub  - tube length
c      delzhx - change in elevation (out - in)
c      dhxleg - diameter of leg pipes
c      diatb  - tube diameter
c      rght   - tube roughness
c      tuben  - number of tubes in a heat exchanger
c      fmhxti1 - inlet "T" loss leg 1
c      fmhxtol - outlet "T" loss leg 1
c      fmhxti2 - inlet "T" loss leg 2
c      fmhxtol - outlet "T" loss leg 2
c      fmhdi   - inlet header loss
c      fmhdo   - outlet header loss
c      fmtbi   - inlet tube loss
c      fmtbo   - outlet tube loss
c      fmeb3   - elbow loss
c      elbn3_1 - number of elbows on leg 1
c      elbn3_2 - number of elbows on leg 2
c      vlv1hx  - valve loss in leg #1
c      vlv2hx  - valve loss in leg #2
c      tmphxi  - heat exchanger inlet side temperature
c      tmphxo  - heat exchanger outlet side temperature
c
      do i=1,30
        read (iin1,900) line1
      enddo
c
      write (iout2,2030)
      read (iin1 ,900) line1
      write (iout2,900) line1
      read (iin1 ,*)   zlhxi1,zlhxi2,zlhxo1,zlhxo2,zltub,delzhx
      write (iout2,*)   zlhxi1,zlhxi2,zlhxo1,zlhxo2,zltub,delzhx
      read (iin1 ,900) line1
      write (iout2,900) line1
      read (iin1 ,*)   dhxleg,diatb,rght,tuben
      write (iout2,*)   dhxleg,diatb,rght,tuben
      read (iin1 ,900) line1
      write (iout2,900) line1
      read (iin1 ,*)   fmhxti1,fmhxtol,fmhxti2,fmhxtol,fmhdi
      write (iout2,*)   fmhxti1,fmhxtol,fmhxti2,fmhxtol,fmhdi
      read (iin1 ,900) line1
      write (iout2,900) line1
      read (iin1 ,*)   fmhdo,fmtbi,fmtbo,fmeb3
      write (iout2,*)   fmhdo,fmtbi,fmtbo,fmeb3

```

TRAC BLANKET SYSTEM MODEL

```

      read (iin1,900) line1
      write (iout2,900) line1
      read (iin1,*)  elbup1,elbup2,elbdn1,elbdn2,vlv1hx,vlv2hx
      write (iout2,*)  elbup1,elbup2,elbdn1,elbdn2,vlv1hx,vlv2hx
      read (iin1,900) line1
      write (iout2,900) line1
      read (iin1,*)  tmphxi,tmphxo
      write (iout2,*)  tmphxi,tmphxo
      write (iout2,2031)

c
c *** section #4 (pump outlet to heat exchanger inlet) ***
c
c      zlg4      - length
c      diam4     - diameter
c      delz4     - delta "z"
c      fment4    - entrance loss coef.
c      fmext4    - exit loss coef.
c      fmeb4     - elbow loss coef.
c      elbn4     - number of elbows
c
      do i=1,10
         read (iin1,900) line1
      enddo
c
      write (iout2,2040)
      read (iin1,900) line1
      write (iout2,900) line1
      read (iin1,*)  zlg4,diam4,delz4
      write (iout2,*)  zlg4,diam4,delz4
      read (iin1,900) line1
      write (iout2,900) line1
      read (iin1,*)  fment4,fmext4,fmeb4,elbn4
      write (iout2,*)  fment4,fmext4,fmeb4,elbn4
      write (iout2,2041)

c
c *** section #5 (pump inlet to outlet) ***
c
c      zlpil     - inlet side length for leg 1
c      zlpol     - outlet side length for leg 1
c      zlpil2    - inlet side length for leg 2
c      zlpol2    - outlet side length for leg 2
c      dlegpi    - diameter of inlet leg pipes
c      dlegpo    - diameter of outlet leg pipes
c      fmpti1    - inlet "T" loss
c      fmptol    - outlet "T" loss
c      fmpti2    - inlet "T" loss
c      fmptol2   - outlet "T" loss
c      fmeb5i1   inlet elbow loss coefficient for leg 1
c      fmeb5o1   outlet elbow loss coefficient for leg 1
c      fmeb5i2   inlet elbow loss coefficient for leg 2
c      fmeb5o2   outlet elbow loss coefficient for leg 2
c      vlvilp    - valve loss in suction leg #1
c      vlvi2p    - valve loss in suction leg #2
c      vlvolp    - valve loss in discharge leg #1
c      vlvo2p    - valve loss in discharge leg #2
c      omega1    - pump #1 speed (rpm)
c      omega2    - pump #2 speed (rpm)
c      elvi      - inlet elevation
c      elvo      - outlet elevation
c      elvps     pump suction elevation
c
      do i=1,26

```

TRAC BLANKET SYSTEM MODEL

```

      read (iin1,900) line1
    enddo
c
    write (iout2,2050)
    read (iin1,900) line1
    write (iout2,900) line1
    read (iin1,*)   zlp11,zlp1,zlp2,zlp2,dlegpi,dlegpo
    write (iout2,*) zlp11,zlp1,zlp2,zlp2,dlegpi,dlegpo
    read (iin1,900) line1
    write (iout2,900) line1
    read (iin1,*)   fmpti1,fmptol,fmpti2,fmpto2
    write (iout2,*) fmpti1,fmptol,fmpti2,fmpto2
    read (iin1,900) line1
    write (iout2,900) line1
    read (iin1,*)   fmeb5i1,fmeb5o1,fmeb5i2,fmeb5o2
    write (iout2,*) fmeb5i1,fmeb5o1,fmeb5i2,fmeb5o2
    read (iin1,900) line1
    write (iout2,900) line1
    read (iin1,*)   vlvi1p,vlvi2p,vlvo1p,vlvo2p,omega1,omega2
    write (iout2,*) vlvi1p,vlvi2p,vlvo1p,vlvo2p,omega1,omega2
    read (iin1,900) line1
    write (iout2,900) line1
    read (iin1,*)   elvi,elvo,elvps
    write (iout2,*) elvi,elvo,elvps
    write (iout2,2051)
c
c *** section #6 (outlet header to pump inlet) ***
c
c   zlg6   - length
c   diam6  - diameter
c   delz6  - delta "z"
c   dhdrot - outlet header diameter
c   fment6 - entrance loss coef.
c   fmext6 - exit loss coef.
c   fmeb6  - elbow loss coef.
c   elbn6  - number of elbows
c
    do i=1,11
      read (iin1,900) line1
    enddo
c
    write (iout2,2060)
    read (iin1,900) line1
    write (iout2,900) line1
    read (iin1,*)   zlg6,diam6,delz6,dhdrot
    write (iout2,*) zlg6,diam6,delz6,dhdrot
    read (iin1,900) line1
    write (iout2,900) line1
    read (iin1,*)   fment6,fmext6,fmeb6,elbn6
    write (iout2,*) fment6,fmext6,fmeb6,elbn6
    write (iout2,2061)
c
c *** Modules: (inlet header to outlet header for each module)
c
c COMMON PARAMETERS: (* implies that previous information)
c
c   nmods - number of modules connectec to fixed headers
c   pres_ih - * presure of inlet fixed header (Pa)
c   pres_oh - * presure of outlet fixed header (Pa)
c   temp_ih - * fluid temperature in inlet header (C)
c   temp_oh - * fluid temperature in outlet header (C)
c   elv_ih  - * elevation of fixed inlet header, (m)

```

TRAC BLANKET SYSTEM MODEL

```

c      elv_oh - * elevation of fixed outlet header, (m)
c
c  FOR EACH MODULE:
c
c      kent    - Entrance loss coefficient at inlet header (unitless)
c      kext    - Exit loss coefficient at outlet header (unitless)
c      kform_i - inlet segment form losses (unitless)
c      kform_h - outlet segment form losses (unitless)
c      kform_o - heated segment form losses (unitless)
c      kvalv_i - valve loss coefficient for inlet segment (unitless)
c      kvalv_h - valve loss coefficient for inlet segment (unitless)
c      kvalv_o - valve loss coefficient for inlet segment (unitless)
c      kebow_i - elbow form loss inlet leg (less than 180 degrees)
c      kebow_h - elbow form loss heated leg (less than 180 degrees)
c      kebow_o - elbow form loss outlet leg (less than 180 degrees)
c      nebow_i - number of elbows in inlet leg (unitless)
c      nebow_h - number of elbows in heated leg (unitless)
c      nebow_o - number of elbows in outlet leg (unitless)
c      dleg_i  - pipe diameter on inlet leg (m)
c      dleg_h  - pipe diameter on heated leg (m)
c      dleg_o  - pipe diameter in outlet leg (m)
c      elv_a   - elevation of entrance to heated segment (m)
c      elv_b   - elevation of exit to heated segment (m)
c      zl_i    - Length of piping in inlet segment (m)
c      zl_m    - Length of piping in heated segment (m)
c      zl_o    - Length of piping in outlet segment (m)
c      rough   - * pipe roughness (m)
c
c      do i=1,26
c          read (iin1,900) line1
c      enddo
c
c      read (iin1,900) line1
c      read (iin1,*) nmods
c      write (iout2,2069) nmods
c
c      do imod=1,nmods
c          write (iout2,2070) imod
c
c          read (iin1,900) line1
c          read (iin1,900) line1
c          write (iout2,900) line1
c          read (iin1,*) kent(imod), kext(imod)
c          write (iout2,*) kent(imod), kext(imod)
c          read (iin1,900) line1
c          write (iout2,900) line1
c          read (iin1,*) kform_i(imod), kform_h(imod), kform_o(imod)
c          write (iout2,*) kform_i(imod), kform_h(imod), kform_o(imod)
c          read (iin1,900) line1
c          write (iout2,900) line1
c          read (iin1,*) kvalv_i(imod), kvalv_h(imod), kvalv_o(imod)
c          write (iout2,*) kvalv_i(imod), kvalv_h(imod), kvalv_o(imod)
c          read (iin1,900) line1
c          write (iout2,900) line1
c          read (iin1,*) kebow_i(imod), kebow_h(imod), kebow_o(imod)
c          write (iout2,*) kebow_i(imod), kebow_h(imod), kebow_o(imod)
c          read (iin1,900) line1
c          write (iout2,900) line1
c          read (iin1,*) nebow_i(imod), nebow_h(imod), nebow_o(imod)
c          write (iout2,*) nebow_i(imod), nebow_h(imod), nebow_o(imod)
c          read (iin1,900) line1
c          write (iout2,900) line1

```


TRAC BLANKET SYSTEM MODEL

```

      read (iin1,*)      dleg_i(imod), dleg_h(imod), dleg_o(imod)
      write (iout2,*)    dleg_i(imod), dleg_h(imod), dleg_o(imod)
      read (iin1,900) line1
      write (iout2,900) line1
      read (iin1,*)      elv_a(imod),  elv_b(imod)
      write (iout2,*)    elv_a(imod),  elv_b(imod)
      read (iin1,900) line1
      write (iout2,900) line1
      read (iin1,*)      zl_i(imod),    zl_h(imod),    zl_o(imod)
      write (iout2,*)    zl_i(imod),    zl_h(imod),    zl_o(imod)
c
      write (iout2,2071) imod
    enddo
c
c === PERFORM HYDRAULIC CALCULATIONS =====
c
c Iterate between supply and demand curves to determine operating
c hydraulic operating point if isolve>0. If isolve=0, then only
c make a single pass through calculational step.
c
      do ihydra=1,mxhydra
cc      flow = 1000.0 + 3.0*float(ihydra-1)
c
c calculate the pressure drop in section #1
c
      call pipdip (flow,diam1,diam1,dhdrin,zlg1,delz1,rough,
      &            fmeb1,elbn1,fment1,fmext1,tmphxo,delp)
      ppres = phdin + delp
c
c calculate the pressure drop in section #2
c
      call pipdip (flow,diam2,diam2,diam2,zlg2,delz2,rough,
      &            fmeb2,elbn2,fment2,fmext2,tmphxo,delp)
      phxout = ppres + delp
c
c calculate the pressure drop across the heat exchangers
c
      call heatx (flow,dhxleg,diam1,zlhx11,zlhx12,zlhx01,zlhx02,
      &            zltub,delzhx,fmhxt11,fmhxt01,fmhxt12,fmhxt02,
      &            fmhdi,fmhdo,vlv1hx,vlv2hx,fmtbi,fmtbo,
      &            tuben,diatb,elbup1,elbup2,elbdn1,elbdn2,
      &            fmeb3,rough,rght,tmphxi,tmphxo,delp)
      phxin = phxout + delp
c
c calculate the pressure drop in section #4
c
      call pipdip (flow,diam4,diam4,diam4,zlg4,delz4,rough,
      &            fmeb4,elbn4,fment4,fmext4,tmphxi,delp)
      ppmpout = phxin + delp
cc      write(iout1,('ppmpout,phxin,phxout,ppres,phdin =',5f12.1))
cc      &            ppmpout,phxin,phxout,ppres,phdin
c
c calculate the pressure drop across the pumps (outlet - inlet)
c
      call pump (flow,dlegpi,dlegpo,diam6,diam4,zlpi1,zlpo1,
      &            zlpi2,zlpo2,elvi,
      &            elvo,elvps,fmpti1,fmpt01,fmpti2,fmpt02,
      &            vlvi1p,vlvi2p,vlvo1p,vlvo2p,
      &            fmeb5i1,fmeb5o1,fmeb5i2,fmeb5o2,rough,
      &            tmphxi,omega1,omega2,ppmpout,delp,
      &            ps1,ps2,iout1)
      ppmpin = ppmpout + delp

```

TRAC BLANKET SYSTEM MODEL

```

c
c calculate the pressure drop in section #6
c
      call pipdip (flow,diam6,dhdrot,diam6,zlg6,delz6,rough,
&                fmeb6,elbn6,fment6,fmext6,tmphxi,delp)
      phdout = ppmpin + delp
c
c Compute mass flowrates through each module connected to the common
c inlet & outlet headers.
c
      temp_i = tmphxo
      temp_o = tmphxi
      pres_ih = phdin
      pres_oh = phdout
      elv_ih = 2.0375
      elv_oh = 1.2755
c
      if (isolve.gt.0) then
        call module (nmods,pres_ih,pres_oh,temp_i,temp_o,
&                  kform_i,kform_h,kform_o,kvalv_i,
&                  kvalv_h,kvalv_o,kebow_i,kebow_h,kebow_o,
&                  nebow_i,nebow_h,nebow_o,kent,kext,
&                  dleg_i,dleg_h,dleg_o,elv_ih,elv_oh,
&                  elv_a,elv_b,zl_i,zl_h,zl_o,
&                  rough,flowm,pres_a,pres_b,ftot,iout1)
      endif
c
c Check for hydraulic supply & demand curve convergence.
c
      dflow = flow - ftot
      write(25,('ihydra,delp,flow,ftot =',i5,5x,3f10.3))
&      ihydra,(phdin-phdout)*pconv,flow,ftot
      write(26,('ihydra,flow,delps =',i5,2x,8f8.2))
&      ihydra,flow,(phdout-ppmpin)*pconv,
&      (ppmpin-ppmpout)*pconv,(ppmpout-phxin)*pconv,
&      (phxin-phxout)*pconv,(phxout-ppres)*pconv,
&      (ppres-phdin)*pconv,(phdin-phdout)*pconv
      if (abs(dflow).lt.hconvg .or. isolve.eq.0) then
        goto 10
      else
        flow = weight*flow + (one-weight)*ftot
      endif
    enddo
c
c Solution failed to converge within specified number of iterations,
c notify then terminate execution.
c
      write (iout1,800) mxhydra,flow,ftot,dflow
      stop
c
c Solution converged or no iteration requested, write out final
c solution.
c
10  continue
c
c === WRITE PRESSURE PROFILE TO FILE =====
c
      write (iout1,950) ihydra,flow,ftot
      write (iout1,1001) phdout*pconv
      write (iout1,1002) ppmpin*pconv
      write (iout1,1008) ps1*pconv
      write (iout1,1009) ps2*pconv

```

TRAC BLANKET SYSTEM MODEL

```

      write (iout1,1003) pmpout*pconv
      write (iout1,1004) phxin*pconv
      write (iout1,1005) phxout*pconv
      write (iout1,1006) ppres*pconv
      write (iout1,1007) phdin*pconv
      write (iout1,1018)
      totpd = (phdin - phdout)*pconv
      write (iout1,1019)totpd
c
c ===  FORMAT STATEMENTS  =====
c
800  format(//,'***** failed to converge *****',//,
      &      ' ihydra,flow,ftot,dflow      = ',i5,3f10.3)
900  format (a80)
910  format (//,a80,/)
950  format (' #hydro iterations=',i3,'  supply flow=',f7.1,
      &      '  demand flow=',f7.1,/)
c
1001 format (1x,'Outlet header pressure  =',g16.8,' psia ')
1002 format (1x,'pump inlet pressure      =',g16.8,' psia ')
1008 format (1x,'pump #1 suction pressure =',g16.8,' psia ')
1009 format (1x,'pump #2 suction pressure =',g16.8,' psia ')
1003 format (1x,'pump outlet pressure     =',g16.8,' psia ')
1004 format (1x,'HX inlet pressure        =',g16.8,' psia ')
1005 format (1x,'HX outlet pressure       =',g16.8,' psia ')
1006 format (1x,'Pressurizer pressure     =',g16.8,' psia ')
1007 format (1x,'Inlet Header pressure    =',g16.8,' psia ')
1018 format (' ')
1019 format (1x,'Header to Header pres drop =',g14.7,' psid')
c
2010 format (//,'***** PRESSURIZER -TO- INLET HEADER *****')
2011 format ( '***** PRESSURIZER -TO- INLET HEADER *****',/)
2020 format (//,'*** HEAT EXCHANGER OUTLET -TO- PRESSURIZER ***')
2021 format ( '*** HEAT EXCHANGER OUTLET -TO- PRESSURIZER ***',/)
2030 format (//,'***** HEAT EXCHANGER INLET -TO- OUTLET *****')
2031 format ( '***** HEAT EXCHANGER INLET -TO- OUTLET *****',/)
2040 format (//,'**** PUMP OUTLET -TO- HEAT EXCHANGER INLET ****')
2041 format ( '**** PUMP OUTLET -TO- HEAT EXCHANGER INLET ****',/)
2050 format (//,'***** PUMP INLET -TO- OUTLET *****')
2051 format ( '***** PUMP INLET -TO- OUTLET *****',/)
2060 format (//,'***** OUTLET HEADER -TO- PUMP INLET *****')
2061 format ( '***** OUTLET HEADER -TO- PUMP INLET *****',/)
2069 format (//,
      &      '*****',/,
      &      ' ',i2,' MODULES CONNECTED TO INLET/OUTLET HEADER ',/,
      &      '*****',/)
2070 format (//,
      &      '***** MODULE ',i2,': INLET -TO- OUTLET HEADER *****')
2071 format (
      &      '***** MODULE ',i2,': INLET -TO- OUTLET HEADER *****',/)
c
      stop
      end

```

Subroutine frict:

```

      subroutine frict(re,ed,zf)
c
c *****
c This subroutine calculates the Moody friction factor for a
c tube. Inputs are the Reynolds #, and the relative roughness.
c The Darcy friction factor is returned.

```

TRAC BLANKET SYSTEM MODEL

```

c *****
c
      if (re .gt. 50.0) go to 10
      re=50.0
10   if (re .le. 2300.0) then
      zf=64.0/re
      else if (re .ge. 4000.0) then
      zf=1.0/((1.14-2.0*log10(ed+21.25/(re**.9)))**2)
      else
      zf=.23158-2.0549e-4*re+6.6351e-8*(re**2)-6.7336e-12*(re**3)
      end if
      return
      end

```

Subroutine heatx:

```

      subroutine heatx(flow,dleg,dmpip,zli1,zli2,zlo1,zlo2,
&                    zltub,delz,fmlti1,fmlto1,fmlti2,fmlto2,
&                    fmhi,fmho,zkvlv1,zkvlv2,fmti,fmto,
&                    tuben,diat,elbup1,elbup2,elbdn1,elbdn2,
&                    fmeb90,rough,rght,tin,tout,delp)
c *****
c This subroutine calculates the pressure drop across the
c two parallel heat exchangers. The flow split, which is a
c function of the valve closures, is also calculated.
c *****
c
c INPUT:
c   flow      mass flowrate
c   dleg      pipe diameter in the two legs
c   dmpip     diameter of main pipe
c   zli1      length of pipe upstream of hx 1
c   zli2      length of pipe upstream of hx 2
c   zlo1      length of pipe downstream of hx 1
c   zlo2      length of pipe downstream of hx 2
c   zltub     tube length
c   delz      elevation change (outlet-inlet)
c   fmlti1    entrance "T" form loss for leg 1
c   fmlto1    exit "T" form loss leg 1
c   fmlti2    entrance "T" form loss leg 2
c   fmlto2    exit "T" form loss leg 2
c   fmhi      heat exchanger entrance form loss
c   fmho      heat exchanger exit form loss
c   zkvlv1    valve loss coefficient for leg #1
c   zkvlv2    valve loss coefficient for leg #2
c   fmti      hx tube entrance form loss
c   fmto      hx tube exit form loss
c   tuben     number of tubes in hx
c   diat      tube diameter
c   elbup1    number of elbows on leg 1 upstream of HX
c   elbup2    number of elbows on leg 2 upstream of HX
c   elbdn1    number of elbows on leg 1 down stream of HX
c   elbdn2    number of elbows on leg 2 down stream of HX
c   fmeb90    elbow form loss (90 degrees)
c   rough     pipe roughness
c   rght      tube roughness
c   tin       inlet temperature
c   tout      outlet temperature
c   iout2     output file number
c
      implicit real (a-h,o-z), integer (i-n)

```

TRAC BLANKET SYSTEM MODEL

```

c      parameter (zero=0.0, half=0.5, two=2.0)
c
c      iout3=8
c      pi = 3.14159
c      g = 9.807
c
c      Calculate entrance, exit, and mean fluid properties
c
c      call propw(tin,den,vis)
c      deni=den
c      visi=vis
c      call propw(tout,den,vis)
c      deno=den
c      viso=vis
c      tbar= half*(tin+tout)
c      call propw(tbar,den,vis)
c      denb=den
c      visb=vis
c
c      calculate expansion form loss coefficient for 16" to 20" pipe:
c
c      fmexp=((1.0-((dleg/dmpip)**2))**2)
c      write (iout3,701)fmexp
c      write (iout3,901)
701  format (1x,'K expansion = ',g16.8)
c
c      Start the iterative loop for flow1
c
c      write (iout3,799)
c      write (iout3,901)
799  format ('          fmlti1          fmlti2          fmlto1          fmlto2')
c      flow1= half*flow
c      itnum=0
10   itnum=itnum+1
c      flow2=flow-flow1
c
c      Calculate the friction factors
c
c      re=(4.0*flow1)/(pi*visi*dleg)
c      relrgh=rough/dleg
c      call frict(re,relrgh,f)
c      fi1=f
c      re=(4.0*flow1)/(pi*viso*dleg)
c      relrgh=rough/dleg
c      call frict(re,relrgh,f)
c      fo1=f
c      re=(4.0*flow1)/(tuben*pi*visb*diat)
c      relrgh=rgh/diat
c      call frict(re,relrgh,f)
c      ft1=f
c      flow2=flow-flow1
c      re=(4.0*flow2)/(pi*visi*dleg)
c      relrgh=rough/dleg
c      call frict(re,relrgh,f)
c      fi2=f
c      re=(4.0*flow2)/(pi*viso*dleg)
c      relrgh=rough/dleg
c      call frict(re,relrgh,f)
c      fo2=f
c      re=(4.0*flow2)/(tuben*pi*visb*diat)
c      relrgh=rgh/diat

```

TRAC BLANKET SYSTEM MODEL

```

      call frict(re,relrgh,f)
      ft2=f
c
c Calculate the "T" form losses in terms of the leg velocities
c and as functions of the flow splits:
c
      fmlti1=0.59*((flow/flow1)**2)+1.18*(flow/flow1)-0.68
c
      fmlti2=0.59*((flow/flow2)**2)+1.18*(flow/flow2)-0.68
c
      fmlto1=1.09*((flow/flow1)**2)-
&      0.53*((flow2*flow)/(flow1**2))-
&      1.48*((flow2/flow1)**2)
c
      fmlto2=0.045*((flow/flow2)**2)+
&      1.38*((flow1*flow)/(flow2**2))-
&      0.9*((flow1/flow2)**2)
c
      write (iout3,800)fmlti1,fmlti2,fmlto1,fmlto2
800 format (1x,4g16.8)
c
c Leg 1
c
      upstrm=(fmlti1 + fmhi+elbup1*fmeb90+(fi1*zli1)/dleg)/
&      (deni*dleg*dleg*dleg*dleg)
      dnstrm=(fmho+elbdn1*fmeb90+zkv1v1+fmexp+(fo1*zlo1)/dleg)/
&      (deno*dleg*dleg*dleg*dleg)+
&      (fmlto1/(deno*dmpip*dmpip*dmpip*dmpip))
      tublos=(two*(fmi+fmo) + (ft1*zltub)/diat)/
&      (denb*tuben*tuben*diat*diat*diat*diat)
      c1=upstrm+dnstrm+tublos
c
c Leg 2
c
      upstrm=(fmlti2 + fmhi+elbup2*fmeb90+(fi2*zli2)/dleg)/
&      (deni*dleg*dleg*dleg*dleg)
      dnstrm=(fmho+elbdn2*fmeb90+zkv1v2+fmexp+(fo2*zlo2)/dleg)/
&      (deno*dleg*dleg*dleg*dleg)+
&      (fmlto2/(deno*dmpip*dmpip*dmpip*dmpip))
      tublos=(two*(fmi+fmo) + (ft2*zltub)/diat)/
&      (denb*tuben*tuben*diat*diat*diat*diat)
      c2=upstrm+dnstrm+tublos
c
      dc = c1 - c2
      if (dc.eq.zero) then
        flowln = half*flow
      else
        flowln = flow*((sqrt(c1*c2)-c2)/dc)
      end if
      itnum=itnum+1
      if (itnum.gt. 25)go to 20
      error=(abs(flowln-flow1))/flowln
      if (error.gt. .001)then
        flow1 = flow1 + half*(flowln - flow1)
        goto 10
      endif
c
c End of the iterative loop, calculate the pressure drop
c
20 flow1=flowln
delp=((8.0*flow1*flow1)/(pi*pi))*c1+denb*g*delz+
&      ((8.0*flow*flow)/(pi*pi))*

```

TRAC BLANKET SYSTEM MODEL

```

      &      ((1.0/(deno*(dmpip**4)))-(1.0/(deni*(dleg**4))))
      write(27,('itnum,flow1,delp,c1,c2 = ',i3,4f10.3'))
      &      itnum,flow1,delp,c1,c2
c
c  calculate and write out the heat exchanger pressure drops:
c
      flow2 = flow - flow1
      conv = 1.451e-04
      write (iout3,900)
      write (iout3,901)
      write (iout3,1000)flow1
      write (iout3,1001)flow2
      write (iout3,901)
      write (iout3,902)
      write (iout3,901)
c
c  pressure drop from upstream of inlet "T" to upstream of
c  the heat exchanger header:
c
      vsqt = (8.0*flow*flow)/(deni*pi*pi*(dleg**4))
      vsqtl = (8.0*flow1*flow1)/(deni*pi*pi*(dleg**4))
      vsqt2 = (8.0*flow2*flow2)/(deni*pi*pi*(dleg**4))
      dp1=(vsqtl*(1.0+fmlti1+elbup1*fmeb90+
      &      (fi1*zli1)/dleg)-vsqt)*conv
      dp2=(vsqt2*(1.0+fmlti2+elbup2*fmeb90+
      &      (fi2*zli2)/dleg)-vsqt)*conv
      dp1sum=dp1
      dp2sum=dp2
      write (iout3,1002)dp1
      write (iout3,1003)dp2
      write (iout3,901)
c
c  pressure drop from upstream of the inlet header to the
c  tube entrance:
c
      write (iout3,901)
      write (iout3,903)
      write (iout3,901)
      vsqttl = (8.0*flow1*flow1)/(denb*pi*pi*tuben*tuben*(diat**4))
      vsqtt2 = (8.0*flow2*flow2)/(denb*pi*pi*tuben*tuben*(diat**4))
      dp1=(vsqttl*(fmhi-1)+vsqttl*(fmti+1.0))*conv
      dp2=(vsqt2*(fmhi-1)+vsqtt2*(fmti+1.0))*conv
      dp1sum=dp1sum+dp1
      dp2sum=dp2sum+dp2
      write (iout3,1002)dp1
      write (iout3,1003)dp2
      write (iout3,901)
c
c  pressure drop in first pass tubes:
c
      write (iout3,901)
      write (iout3,904)
      write (iout3,901)
      dp1=(vsqttl*((ft1*zltub*0.5)/diat))*conv
      dp2=(vsqtt2*((ft2*zltub*0.5)/diat))*conv
      dp1sum=dp1sum+dp1
      dp2sum=dp2sum+dp2
      write (iout3,1002)dp1
      write (iout3,1003)dp2
      write (iout3,901)
c
c  pressure drop across the middle header:

```

TRAC BLANKET SYSTEM MODEL

```

c
  write (iout3,901)
  write (iout3,905)
  write (iout3,901)
  deltaz=1.5
  dp1=(vsqtt1*(fmti+fmto)-denb*g*deltaz)*conv
  dp2=(vsqtt2*(fmti+fmto)-denb*g*deltaz)*conv
  dp1sum=dp1sum+dp1
  dp2sum=dp2sum+dp2
  write (iout3,1002)dp1
  write (iout3,1003)dp2
  write (iout3,901)

c
c  pressure drop in second pass tubes:
c
  write (iout3,901)
  write (iout3,906)
  write (iout3,901)
  dp1=(vsqtt1*((ft1*zltub*0.5)/diat))*conv
  dp2=(vsqtt2*((ft2*zltub*0.5)/diat))*conv
  dp1sum=dp1sum+dp1
  dp2sum=dp2sum+dp2
  write (iout3,1002)dp1
  write (iout3,1003)dp2
  write (iout3,901)

c
c  pressure drop from tube exit to down stream of the exit header:
c
  write (iout3,901)
  write (iout3,907)
  write (iout3,901)
  vsqt1 = (8.0*flow1*flow1)/(deno*pi*pi*(dleg**4))
  vsqt2 = (8.0*flow2*flow2)/(deno*pi*pi*(dleg**4))
  dp1=(vsqt1*(fmho+1)+vsqtt1*(fmto-1.0))*conv
  dp2=(vsqt2*(fmho+1)+vsqtt2*(fmto-1.0))*conv
  dp1sum=dp1sum+dp1
  dp2sum=dp2sum+dp2
  write (iout3,1002)dp1
  write (iout3,1003)dp2
  write (iout3,901)

c
c  pressure drop from down stream of outlet header to
c  down stream of the "T":
c
  write (iout3,901)
  write (iout3,908)
  write (iout3,901)
  vsqt = (8.0*flow*flow)/(deno*pi*pi*(dmpip**4))
  vsqt1b = (8.0*flow1*flow1)/(deno*pi*pi*(dmpip**4))
  vsqt2b = (8.0*flow2*flow2)/(deno*pi*pi*(dmpip**4))
  deltaz=1.2
  dp1 = (vsqt1*(zkvlv1+elbdn1*fmeb90-1.0+fmexp+
&      fo1*zlo1)/dleg)+
&      vsqt+vsqt1b*fmlto1-deno*g*deltaz)*conv
  dp2 = (vsqt2*(zkvlv2+elbdn2*fmeb90-1.0+fmexp+
&      fo2*zlo2)/dleg)+
&      vsqt+vsqt2b*fmlto2-deno*g*deltaz)*conv
  dp1sum=dp1sum+dp1
  dp2sum=dp2sum+dp2
  write (iout3,1002)dp1
  write (iout3,1003)dp2
  write (iout3,901)

```


TRAC BLANKET SYSTEM MODEL

```

      write (iout3,1004)dp1sum
      write (iout3,1005)dp2sum
      write (iout3,901)
      dprtn = delp*conv
      write (iout3,1006)dprtn
c
900  format ('***** HX RESULTS *****')
901  format (' ')
902  format ('*** PRESS DRP UPSTM "T" - UPSTM INLT HDR ***')
903  format ('*** PRESS DRP UPSTM INLT HDR - TUBE ENT ***')
904  format ('*** PRESS DRP in FIRST PASS TUBES ***')
905  format ('*** PRESS DRP ACROSS THE MIDDLE HEADER ***')
906  format ('*** PRESS DRP in SECOND PASS TUBES ***')
907  format ('*** PRESS DRP TUBE EXT - DNSTRM OTLT HDR ***')
908  format ('*** PRESS DRP DNSTRM OTLT HDR - DNSTRM "T" ***')
1000 format (1x,'HX #1 mass flowrate = ',g14.8,' kg/s')
1001 format (1x,'HX #2 mass flowrate = ',g14.8,' kg/s')
1002 format (1x,'delta P (sys #1) = ',g14.7,' psid')
1003 format (1x,'delta P (sys #2) = ',g14.7,' psid')
1004 format (1x,' total Delta P #1 = ',g14.7,' psid')
1005 format (1x,' total Delta P #2 = ',g14.7,' psid')
1006 format (1x,' Delta P (returned) = ',g14.7,' psid')
c
      return
      end

```

Subroutine module:

```

      subroutine module (nmods,pres_ih,pres_oh,temp_i,temp_o,
&                      kform_i,kform_h,kform_o,kvalv_i,
&                      kvalv_h,kvalv_o,kebow_i,kebow_h,kebow_o,
&                      nebow_i,nebow_h,nebow_o,kent,kext,
&                      dleg_i,dleg_h,dleg_o,elv_ih,elv_oh,
&                      elv_a,elv_b,zl_i,zl_h,zl_o,
&                      rough,flow,pres_a,pres_b,ftot,iout1)
c
c *****
c *
c * This subroutine calculates the mass flowrates through every
c * blanket module that is connected to the inlet and outlet
c * fixed headers. The mass flow calculations are performed
c * based on inputted header pressure drop and inlet/outlet/
c * average temperatures specified within each section.
c *
c * Note: Each module contains three segments (an inlet, heated,
c *       and outlet segments whose temperature is assumed to be
c *       constant over that segment).
c *       (inlet --> _i; outlet --> _o; and heated --> _h)
c *       Entrance and exit plenums are assumed for the heated
c *       segments as well.
c *
c *****
c
      implicit real (a-h,o-z), integer (i-n)
      real kebow_i, kebow_h, kebow_o, kvalv_i, kvalv_h, kvalv_o
      real kform_i, kform_h, kform_o, kent, kext
      real ksum_i, ksum_h, ksum_o
c
      parameter (mxmod=20)
      parameter (zero=0.0, half=0.5, one=1.0, four=4.0, eight=8.0)
c
      dimension flow(mxmod)

```

TRAC BLANKET SYSTEM MODEL

```

dimension pres_a(mxmod), pres_b(mxmod)
dimension kent(mxmod), kext(mxmod)
dimension kform_i(mxmod), kform_h(mxmod), kform_o(mxmod)
dimension kvalv_i(mxmod), kvalv_h(mxmod), kvalv_o(mxmod)
dimension kebow_i(mxmod), kebow_h(mxmod), kebow_o(mxmod)
dimension nebow_i(mxmod), nebow_h(mxmod), nebow_o(mxmod)
dimension dleg_i(mxmod), dleg_h(mxmod), dleg_o(mxmod)
dimension zl_i(mxmod), zl_h(mxmod), zl_o(mxmod)
dimension elv_a(mxmod), elv_b(mxmod)

c
c INPUT:
c
c nmods - number of modules connectec to fixed headers
c pres_ih - presure of inlet fixed header (Pa)
c pres_oh - presure of outlet fixed header (Pa)
c temp_i - average fluid temperature in inlet segment (C)
c temp_h - average fluid temperature in inlet segment (C)
c temp_o - average fluid temperature in inlet segment (C)
c
c kform_i - inlet segment form losses (unitless)
c kform_h - outlet segment form losses (unitless)
c kform_o - heated segment form losses (unitless)
c kvalv_i - valve loss coefficient for inlet segment (unitless)
c kvalv_h - valve loss coefficient for inlet segment (unitless)
c kvalv_o - valve loss coefficient for inlet segment (unitless)
c kebow_i - elbow form loss inlet leg (less than 180 degrees)
c kebow_h - elbow form loss heated leg (less than 180 degrees)
c kebow_o - elbow form loss outlet leg (less than 180 degrees)
c nebow_i - number of elbows in inlet leg (unitless)
c nebow_h - number of elbows in heated leg (unitless)
c nebow_o - number of elbows in outlet leg (unitless)
c kent - Entrance loss coefficient at inlet header (unitless)
c kext - Exit loss coefficient at outlet header (unitless)
c
c dleg_i - pipe diameter on inlet leg (m)
c dleg_h - pipe diameter on heated leg (m)
c dleg_o - pipe diameter in outlet leg (m)
c elv_ih - elevation of fixed inlet header, (m)
c elv_a - elevation of entrance to heated segment (m)
c elv_b - elevation of exit to heated segment (m)
c elv_oh - elevation of fixed outlet header, (m)
c zl_i - Lenght of piping in inlet segment (m)
c zl_h - Lenght of piping in heated segment (m)
c zl_o - Lenght of piping in outlet segment (m)
c rough - pipe roughness (m)
c
c OUTPUT:
c
c flow - array of mass flowrates per module (kg/s)
c ftot - total mass flowrate from all modules (kg/s)
c pres_a - pressure at entrance of heated segment (Pa)
c pres_b - pressure at exit of heated segment (Pa)
c
p_conv = 14.696/101325.0
pi = acos(-one)
g = 9.807
fac = eight/(g*pi*pi)
conv = 1.0e-4
eps = 1.0e-3
maxit = 1000
fric = 0.015
write (iout1,130)

```

TRAC BLANKET SYSTEM MODEL

```

c
c Check for exceeding allowable number of modules.
c
  if (nmods.gt.mxmod) then
    write (iout1,'(//,
    & " ERROR: maximum number of modules allowed = ",i4)') mxmod
    stop
  endif
c
c Calculate fluid properties for each segment. Note that each model
c considered to be operating at similar temperatures as neighbors.
c
  temp_h = half*(temp_i + temp_o)
c
  call propw (temp_i,den_i,vis_i)
  call propw (temp_h,den_h,vis_h)
  call propw (temp_o,den_o,vis_o)
c
c Compute total dynamic head drop between inlet and outlet headers.
c We are assuming that inlet and outlet header velocities are
c approximately equal.
c
  dthd = (pres_ih/den_i - pres_oh/den_o)/g + (elv_ih - elv_oh)
c
c === Loop over each module and compute its flowrate =====
c
  do imod=1,nmods
c
c Sum up all form-type losses per segment.
c
    ksum_i = kform_i(imod) + kvalv_i(imod) +
    & float(nebow_i(imod))*kebow_i(imod) + kent(imod)
    ksum_h = kform_h(imod) + kvalv_h(imod) +
    & float(nebow_h(imod))*kebow_h(imod)
    ksum_o = kform_o(imod) + kvalv_o(imod) +
    & float(nebow_o(imod))*kebow_o(imod) + kext(imod)
c
c Estimate initial guess for flow split based on form losses with a
c constant friction loss term (i.e., fully turbulent assumption).
c
    rdenom_i = fac/(den_i**2*dleg_i(imod)**4)
    rdenom_h = fac/(den_h**2*dleg_h(imod)**4)
    rdenom_o = fac/(den_o**2*dleg_o(imod)**4)
    ratio_i = zl_i(imod)/dleg_i(imod)
    ratio_h = zl_h(imod)/dleg_h(imod)
    ratio_o = zl_o(imod)/dleg_o(imod)
    sum_i = rdenom_i*(ksum_i + fric*ratio_i)
    sum_h = rdenom_h*(ksum_h + fric*ratio_h)
    sum_o = rdenom_o*(ksum_o + fric*ratio_o)
    sum = sum_i + sum_h + sum_o
    flo2 = dthd/sum
c
    if (flo2.ge.zero) then
      flow(imod) = sqrt(flo2)
    else
      flow(imod) = -sqrt(-flo2)
    endif
c
c === For current module solve non-linear flow equation =====
c
    do iter=1,maxit
c

```

TRAC BLANKET SYSTEM MODEL

```

c Calculate function at current iterate & perturbation.
c
c Calculate perturbed flows
c
      flo = flow(imod)
      flop = flo*(one+eps)

c
c Update friction factors
c
c Inlet segment:
      relrgh = rough/dleg_i(imod)
      re      = (four*flo)/(pi*vis_i*dleg_i(imod))
      rep     = re*(one+eps)
      call frict (re ,relrgh,f_i)
cc      write (iout1,(' f_i = ",f8.4')) f_i
      call frict (rep,relrgh,f_ip)
c Heated segment:
      relrgh = rough/dleg_h(imod)
      re      = (four*flo)/(pi*vis_h*dleg_h(imod))
      rep     = re*(one+eps)
      call frict (re ,relrgh,f_h)
cc      write (iout1,(' f_h = ",f8.4')) f_h
      call frict (rep,relrgh,f_hp)
c Outlet segment:
      relrgh = rough/dleg_o(imod)
      re      = (four*flo)/(pi*vis_o*dleg_o(imod))
      rep     = re*(one+eps)
      call frict (re ,relrgh,f_o)
cc      write (iout1,(' f_o = ",f8.4')) f_o
      call frict (rep,relrgh,f_op)

c
c Calculate function at current iterate point
c
      sum_i = rdenom_i*(ksum_i + f_i*ratio_i)
      sum_h = rdenom_h*(ksum_h + f_h*ratio_h)
      sum_o = rdenom_o*(ksum_o + f_o*ratio_o)
      sum   = sum_i + sum_h + sum_o
      func  = flo*flo*sum - dthd

c
c Calculate function at its perturbation point
c
      sum_ip = rdenom_i*(ksum_i + f_ip*ratio_i)
      sum_hp = rdenom_h*(ksum_h + f_hp*ratio_h)
      sum_op = rdenom_o*(ksum_o + f_op*ratio_o)
      sump   = sum_ip + sum_hp + sum_op
      funcp  = flop*flop*sump - dthd

c
c === Estimate function derivative numerically & solve =====
c
c Simple forward differencing
c
      dfunc = (funcp - func)/(flop*eps)
      dflow = -func/dfunc

c
c Solve for new estimate of flows by Newton-Raphson technique.
c
cc      write (iout1,200) imod,iter,flo,dflow
      if (abs(dflow).lt.conv) goto 10
      flow(imod) = flow(imod) + dflow
enddo

c
c Solution failed to converge within specified number of iterations,

```

TRAC BLANKET SYSTEM MODEL

```

c notify then terminate execution.
c
      write (iout1,205) imod,iter,maxit,flow,dflow
      stop

c
c Solution converged, compute entrance and exit plenum pressures to
c the heated segment and then loop to next module.
c
10    continue
c
c Entrance plenum pressure:
      tvel_i      = rdenom_i*flo*flo
      delv        = elv_a(imod) - elv_ih
      delp        = g*den_i*(delv + tvel_i + sum_i*flo*flo)
      pres_a(imod) = pres_ih - delp
c Exit plenum pressure:
      tvel_h      = rdenom_h*flo*flo
      delv        = elv_b(imod) - elv_a(imod)
      delp        = g*den_h*(delv + tvel_h + sum_h*flo*flo)
      pres_b(imod) = pres_a(imod) - delp

c
      enddo

c
c Write out module results.
c
      write (iout1,300)

c
      do imod=1,nmods
        write (iout1,310) imod,flow(imod),pres_a(imod)*p_conv,
&                                pres_b(imod)*p_conv
      enddo

c
      ftot = zero
      do imod=1,nmods
        ftot = ftot + flow(imod)
      enddo
      write (iout1,320) ftot

c
      write (iout1,430)

c
c === Statement functions =====
c
130  format(/,
&    '===== START OF MODULE COMPONENT RESULTS =====',/)
200  format(' imod,iter,flow,dflow1 = ',2i5,2f10.3)
205  format(' failed to converge',/,
&    ' imod,iter,maxit,flow,dflow          = ',3i5,2f10.3)
300  format(/,
&    ' module      flow      entrance      exit  ',/,
&    '   id          plenum      plenum  ',/,
&    '      (kg/s)    (psia)    (psia)  ',/,
&    ' -----      -----      -----  ')
310  format(5x,i2,6x,f8.3,2x,f8.2,4x,f8.2)
320  format('   Total = ',f8.3)
430  format(/,
&    '===== END OF MODULE COMPONENT RESULTS =====',/)

c
      return
      end

```

Subroutine npsha:

TRAC BLANKET SYSTEM MODEL

```

      subroutine npsha (tfld,pfld,rhof,velf,a_npsh)
c
c *****
c *
c * This subroutine computes the net positive suction head
c * available at the piping location provided.
c *
c * INPUT:
c *      tfld - fluid temperature (C)
c *      pfld - fluid pressure (Pa)
c *      rhof - fluid density (kg/m^3)
c *      velf - fluid velocity (m/s)
c *
c * OUTPUT:
c *      a_npsh - net positive suction head available (m)
c *
c *****
c
      implicit real (a-h,o-z), integer (i-n)
      parameter (two=2.0)

c Gravitational constant:
c
      data grav / 9.807 /
c
c CONVERSION FACTORS EMPLOYED (SI)
c
c con_tmp - converts C to K
c
      con_tmp = 273.15
c
c === COMPUTE NPSH AVAILABLE =====
c
c CONVERT TEMPERATURE TO ABSOLUTE
c
      tk = tfld + con_tmp
c
c COMPUTE FLUID SATURATION PRESSURE FOR H2O
c
      ifluid = 1
      call psat (tk,ifluid,pvap,x dum)
c
c EVALUATE NPSH AVAILABLE FUNCTION
c
      a_npsh = (pfld - pvap)/(grav*rhof) + velf/(two*grav)
c
      return
      end

```

Subroutine npshr:

```

      subroutine npshr (omega,flow,r_npsh)
c
c *****
c *
c * This subroutine computes the net positive suction head
c * requirements for the blanket system primary coolant pumps
c * at the entrance piping location called.
c *
c * Correlation used is based on SRS Bingham pumps with a BEP at:
c *
c * Bingham BEP:      1000 rpm
c

```

TRAC BLANKET SYSTEM MODEL

```

c      *      25 kgpm (1.577267 m^3/s)      *
c      *      406 ft (123.7488 m)          *
c      *                                     *
c      * INPUT:                             *
c      *      omega - requested pump speed (rpm)      *
c      *      flow  - volumetric flowrate (m^3/s)     *
c      *                                     *
c      * OUTPUT:                               *
c      *      r_npsh - net positive suction head required (m) *
c      *                                     *
c      *****
c
c      implicit real (a-h,o-z), integer (i-n)
cc      parameter (zero=0.0, one=1.0)
c
c      Coefficients for NPSH required quadratic function:
c
c      data acoef,bcoef / 7.4, 0.028 /
c      data qbing,obing / 25.0, 1000.0 /
c
c      Requested pump's reference state values.
c
c      data romega,rflow,rhead / 500.0, 0.78863, 123.7488 /
cc      data romega,rflow,rhead / 500.0, 0.78863, 40.0 /
c
c      CONVERSION FACTORS EMPLOYED (SI TO ENGLISH)
c
c      con_flo - converts m^3/s to kgpm
c      con_len - converts ft to m
c
c      con_flo = 15.8502
c      con_len = 0.3048
c
c      === COMPUTE NPSH REQUIRED =====
c
c      CONVERT INPUT PARAMETER TO ENGLISH UNITS
c
c      qp      = flow/rflow
c      domega  = omega/romega
c
c      EVALUATE NPSH REQUIRED FUNCTION
c      (altered bingham to requested reference pump)
c
c      r_npsh = obing**2*acoef*(domega/1000.0)**2
c      &      + qbing**2*bcoef*qp*qp
c
c      CONVERT NPSH REQUIRED VALUE TO SI
c
c      r_npsh = r_npsh*con_len
c
c      return
c      end

```

Subroutine pipdlp:

```

      subroutine pipdlp(flow,diam,diamin,diamot,zlength,delz,rough,
&      fmeb90,elbn90,fment,fmext,temp,delp)
c
c      *****
c      This subroutine calculates the pressure drop in a length of pipe.
c      The units are SI.
c      *****

```

TRAC BLANKET SYSTEM MODEL

```

c
c  INPUT:
c    flow    mass flowrate
c    diam    pipe diameter
c    diamin  inlet diameter
c    diamot  outlet diameter
c    zlngth  pipe length
c    delz    change in elevation {Z(downstream) - Z(upstream)}
c    rough   pipe roughness
c    fmeb90  elbow form loss (90 degrees)
c    elbn90  number of 90 deg. elbows
c    fment   entrance form loss
c    fmext   exit form loss
c    g       acceleration of gravity
c    temp    fluid temperature
c
c    pi  = 3.14159
c    g   = 9.807
c
c  Calculate the friction factor
c
c    call propw(temp,den,vis)
c    re    = (4.0*flow)/(pi*vis*diam)
c    relrgh = rough/diam
c    call frict(re,relrgh,f)
c    elbn45=0.0
c    fmeb45=0.0
c
c  Calculate the pressure drop
c
c    coef=(8.0*flow*flow)/(den*pi*pi*diam*diam*diam*diam)
c    bern=((8.0*flow*flow)/(den*pi*pi))*
c    &    ((1.0/(diamot**4))-(1.0/(diamin**4)))
c    frmsum=elbn90*fmeb90+elbn45*fmeb45+fment+fmext
c    delp=(den*g*delz)+bern+coef*(frmsum+(f*zlngth)/diam)
c    return
c    end

```

Subroutine pmphc:

```

subroutine pmphc (omega,flow,tdh)
c
c *****
c *
c * This subroutine computes the total dynamic head given a
c * pump speed and volumetric flowrate. A Hardwired homologous
c * head curve is used that is based on the LANL LOFT curve and
c * the reference state of the BEP for the SRS Bingham Pump.
c *
c *
c * Bingham BEP:      1000 rpm
c *                   25 kgpm (1.577267 m^3/s)
c *                   406 ft (123.7488 m)
c *
c *
c * INPUT:
c *    omega - requested pump speed (rpm)
c *    flow  - volumetric flowrate (m^3/s)
c *
c * OUTPUT:
c *    tdh   - total dynamic head (m)
c *
c *****

```


TRAC BLANKET SYSTEM MODEL

```

c
      implicit real (a-h,o-z), integer (i-n)
      parameter (one=1.0, two=2.0)
c
c Bingham BEP Reference conditions (SI units):
c
      data romega,rflow,rhead / 500.0, 0.78863, 40.0 /
cc      data romega,rflow,rhead / 1000.0, 1.577267, 123.7488 /
cc      data romega,rflow,rhead / 314.16, 0.51546, 54.68951 /
c
c Quadratic polynomial fit of LANL LOFT Homologous head curve coeffs:
c
      data acoef,bcoef,ccoef / 1.4, -0.15, -0.25 /
c
c === COMPUTE TOTAL DYNAMIC HEAD =====
c
c NORMALIZE INPUT PARAMETERS
c
      d_omega = omega/romega
      d_flow  = flow/rflow
      x_homo  = d_flow/d_omega
c
c EVALUATE HOMOLOGOUS FUNCTION
c
      if (x_homo.le.one) then
c
c      either a quadratic fit or linear interpolation:
c
c      y_homo = acoef + x_homo*(bcoef + ccoef*x_homo)
c      if (x_homo.le. 0.4) then
c        y_homo = 1.3 + 0.25*(0.4 - x_homo)
c      else
c        y_homo = 1.0 + 0.5*(1.0 - x_homo)
c      endif
c      else
c        y_homo = one + (bcoef + two*ccoef)*(x_homo - one)
c      endif
c
c SCALEUP TO THD VALUE
c
      . tdh = y_homo*d_omega*d_omega*rhead
cc      tdh = 107.0
cc      tdh = 0.0
c
      return
      end

```

Subroutine propw:

```

subroutine propw(temp,den,vis)
c
c This subroutine returns properties for liquid
c water as a function of temperature, (deg. C)
c
      parameter (a1=1004.39, a2=-0.13226, a3=-3.053e-3)
      parameter (b1=1.4051e-3, b2=-2.2076e-5, b3=1.0849e-7)
c
      den=a1+a2*temp+a3*temp*temp
      vis=b1+b2*temp+b3*temp*temp
      return
      end

```

TRAC BLANKET SYSTEM MODEL

Subroutine psat:

```

      subroutine psat(t,ifld,ps,dpsdt)
c
c      *****
c      *
c      * INPUT:
c      *   t = MIXTURE GAS OR LIQUID TEMPERATURE, K
c      *   iflg = IDENTIFIER (1=1 FOR H2O, 1=2 FOR D2O)
c      *
c      * OUTPUT:
c      *   ps = SATURATION PRESSURE OF H2O OR D2O, Pa
c      *   dpsdt = DERIVATIVE OF ps W.R.T. t
c      *
c      * RANGE:
c      *   273K < t < 453K
c      *
c      *****
c
c      implicit real (a-h,o-z), integer (i-n)
c      parameter (two=2.0, three=3.0)
c      dimension c1(2), c2(2), c3(2), c4(2)
c
c      H2O PROPERTIES
c
c      data c1(1)/-38.874/, c2(1)/0.29129/,
&      c3(1)/-5.7014e-4/, c4(1)/4.0606e-7/
c
c      D2O PROPERTIES
c
c      data c1(2)/-39.686/, c2(2)/0.29393/,
&      c3(2)/-5.7036e-4/, c4(2)/4.0230e-7/
c
c      ps = exp(c1(ifld) + (c2(ifld) + (c3(ifld) + c4(ifld)*t)*t)*t)
c      dpsdt = ps*(c2(ifld) + (two*c3(ifld) + (three*c4(ifld))*t)*t)
c
c      return
c      end

```

Subroutine pump:

```

      subroutine pump(flow,dlegi,dlego,diami,diamo,zli1,zlo1,
&      zli2,zlo2,elvi,elvo,elvps,
&      kti1,kto1,kti2,kto2,
&      kvalvei1,kvalvei2,kvalveo1,kvalveo2,
&      kebowi1,kebowo1,kebowi2,kebowo2,
&      rough,temp,omega1,omega2,pdis,delp,
&      ps1,ps2,iout1)
c
c      *****
c      *
c      * This subroutine calculates the pressure drop across the
c      * two parallel pumps. The flow split, which is a
c      * function of the valve closures, is also calculated.
c      * Also calculates available and required NPSH at pump suction
c      * for each pump.
c      *
c      *****
c
c      implicit real (a-h,o-z), integer (i-n)
c      real kti1, kto1, kti2, kto2, kvalvei1, kvalvei2
c      real kti1p, ktolp, kti2p, kto2p
c      real kvalvei1, kvalvei2, kvalveo1, kvalveo2

```

TRAC BLANKET SYSTEM MODEL

```

      real kebowi1, kebowo1, kebowi2, kebowo2
      parameter (zero=0.0, half=0.5, one=1.0, four=4.0,
&              eight=8.0)
      data cf1,cf2,cf3,cf4 / .48954, -.71606, .36098, -.13510 /

c
c  INPUT:
c
c      flow      - mass flowrate (kg/s)
c      dlegi     - pipe diameter on pump inlet leg (m)
c      dlego     - pipe diameter in pump outlet leg (m)
c      diami     - pipe diameter upstream of tee (m)
c      diamo     - pipe diameter downstream of tee (m)
c      zli1      - length of pipe upstream of pump 1 (m)
c      zlo1      - length of pipe downstream of pump 1 (m)
c      zli2      - length of pipe upstream of pump 2 (m)
c      zlo2      - length of pipe downstream of pump 2 (m)
c      elvi      - elevation of upstream piping, (m)
c      elvo      - elevation of downstream piping, (m)
c      elvps     - pump suction elevation (m)
c      kti1      - entrance "T" form loss for pump 1 (unitless)
c      kto1      - exit "T" form loss for pump 1 (unitless)
c      kti2      - entrance "T" form loss for pump 2 (unitless)
c      kto2      - exit "T" form loss for pump 2 (unitless)
c      kvalvei1  - valve loss coefficient for leg #1 (unitless)
c      kvalvei2  - valve loss coefficient for leg #2 (unitless)
c      kvalveo1  - valve loss coefficient for leg #1 (unitless)
c      kvalveo2  - valve loss coefficient for leg #2 (unitless)
c      kebowi1   - elbow form loss inlet leg 1 (less than 180 degrees)
c      kebowo1   - elbow form loss outlet leg 1 (less than 180 degrees)
c      kebowi2   - elbow form loss inlet leg 2 (less than 180 degrees)
c      kebowo2   - elbow form loss outlet leg 2 (less than 180 degrees)
c      rough     - pipe roughness (m)
c      temp      - fluid temperature (C)
c      omega1    - speed pump #1 (rpm)
c      omega2    - speed pump #2 (rpm)
c      pdis      - reference pressure downstream of exit tee (Pa)
c
c  OUTPUT:
c
c      delp      - pressure drop across entire unit (Pa)
c
c      p_conv = 14.696/101325.0
c      pi      = acos(-one)
c      g       = 9.807
c      conv    = 1.0e-4
c      eps     = 1.0e-3
c      maxit   = 1000
c      dflow1  = zero
c      iout4   = 10
c      kvalve1= kvalvei1 + kvalveo1
c      kvalve2= kvalvei2 + kvalveo2
c
c  calculate contraction form loss coefficient for 20" to 16" pipe:
c
cc      fmcont=0.42*(1.0-((dlegi/diami)**2))
c
c      ar=(dlegi/diami)**2
c      fmcont=cf1+ar*(cf2+ar*(cf3+ar*cf4))
c
c      write (iout4,701)fmcont
701  format (1x,'K contraction = ',g16.8)

```

TRAC BLANKET SYSTEM MODEL

```

      write (iout4,901)
      write (iout4,799)
      write (iout4,901)
799  format ('      kti1      kti2      kto1      kto2')
      kti1p = kti1
      kti2p = kti2
      kto1p = kto1
      kto2p = kto2

c
c Calculate fluid properties and initial guess for flow split
c base on internal form loss settings.
c
      call propw (temp,den,vis)
      rdenomi = eight/(den*pi*dlegi**2)**2
      rdenomo = eight/(den*pi*dlego**2)**2
      rdenomp = eight/(den*pi*diami**2)**2
c
      if (kvalve1.lt.eps .and. kvalve2.lt.eps) then
        flow1 = half
        flow2 = half
      else
        form1 = kebowi1 + kvalve1 + kebowo1 + fmcont
        form2 = kebowi2 + kvalve2 + kebowo2 + fmcont
        flow1 = (form1/(form1 + form2))*flow
        flow2 = flow - flow1
      endif

c
c Start the iterative loop:
c
      do iter=1,maxit

c
c === Calculate function at current iterate & perturbation =====
c
c Calculate perturbed flows
c
      flow1p = flow1*(one+eps)
      flow2p = flow - flow1p

c
c calculate the "T" form loss coefficients and write results:
c ( if these expressions are commented out, constant input
c values are used )
c
c at current flow rate:
      kti1 = 0.99*((flow/flow1)**2)-0.82*(flow/flow1)+1.02
      kti2 = (0.65*((flow1/flow)-0.22)**2)-0.03*((flow/flow2)**2)
      kto1 = 1.19*((flow/flow1)**2)-
&      1.73*((flow2*flow)/(flow1**2))+
&      1.34*((flow2/flow1)**2)
      kto2 = 1.19*((flow/flow2)**2)-
&      1.73*((flow1*flow)/(flow2**2))+
&      1.34*((flow1/flow2)**2)

c
c at perturbed flow rate:
      kti1p = 0.99*((flow/flow1p)**2)-0.82*(flow/flow1p)+1.02
      kti2p = (0.65*((flow1p/flow)-0.22)**2)-0.03*((flow/flow2p)**2)
      kto1p = 1.19*((flow/flow1p)**2)-
&      1.73*((flow2p*flow)/(flow1p**2))+
&      1.34*((flow2p/flow1p)**2)
      kto2p = 1.19*((flow/flow2p)**2)-
&      1.73*((flow1p*flow)/(flow2p**2))+
&      1.34*((flow1p/flow2p)**2)

c

```

TRAC BLANKET SYSTEM MODEL

```

      write (iout4,800)kti1,kti2,kto1,kto2
800  format (1x,4g16.8)
c
c Calculate the friction factors
c
c Pump inlet legs
      relrgh = rough/dlegi
      re     = (four*flow1)/(pi*vis*dlegi)
      rep    = re*(one+eps)
      call frict(re,relrgh,fli)
      call frict(rep,relrgh,flip)
      re     = (four*flow2)/(pi*vis*dlegi)
      rep    = (four*flow2p)/(pi*vis*dlegi)
      call frict(re,relrgh,f2i)
      call frict(rep,relrgh,f2ip)
c Pump outlet legs
      relrgh = rough/dlego
      re     = (four*flow1)/(pi*vis*dlego)
      rep    = re*(one+eps)
      call frict(re,relrgh,flo)
      call frict(rep,relrgh,flop)
      re     = (four*flow2)/(pi*vis*dlego)
      rep    = (four*flow2p)/(pi*vis*dlego)
      call frict(re,relrgh,f2o)
      call frict(rep,relrgh,f2op)
c
c Calculate pump total dynamic heads
c
c Pump leg 1
      q1     = flow1/den
      qlp    = q1*(one+eps)
      call pmp hc(omega1,q1,tdh1)
      call pmp hc(omega1,qlp,tdh1p)
c Pump leg 2
      q2     = flow2/den
      q2p    = flow2p/den
      call pmp hc(omega2,q2,tdh2)
      call pmp hc(omega2,q2p,tdh2p)
c
c Calculate function at current iterate point
c
      term_1i = rdenomi*(kebowi1 + fli*(zli1/dlegi) +
& fmcont)/g + rdenomp*kti1/g
      term_2i = rdenomi*(kebowi2 + f2i*(zli2/dlegi) +
& fmcont)/g + rdenomp*kti2/g
      term_1o = rdenomo*(kto1 + kebowo1 + kvalvel
& + flo*(zlo1/dlego))/g
      term_2o = rdenomo*(kto2 + kebowo2 + kvalve2
& + f2o*(zlo2/dlego))/g
      func1   = -tdh1 + flow1**2*(term_1i + term_1o)
      func2   = -tdh2 + flow2**2*(term_2i + term_2o)
      func    = func1 - func2
c
c Calculate function at its perturbation point
c
      term_1ip = rdenomi*(kebowi1 + flip*(zli1/dlegi) +
& fmcont)/g + rdenomp*kti1p/g
      term_2ip = rdenomi*(kebowi2 + f2ip*(zli2/dlegi) +
& fmcont)/g + rdenomp*kti2p/g
      term_1op = rdenomo*(kto1p + kebowo1 + kvalvel
& + flop*(zlo1/dlego))/g
      term_2op = rdenomo*(kto2p + kebowo2 + kvalve2

```

TRAC BLANKET SYSTEM MODEL

```

      &                                     + f2op*(zlo2/dlego))/g
      func1p  =-tdh1p + flow1p**2*(term_1ip + term_1op)
      func2p  =-tdh2p + flow2p**2*(term_2ip + term_2op)
      funcp   = func1p - func2p
c
c === Estimate function derivative numerically & solve =====
c
c Simple forward differencing
c
      dfunc = (funcp - func)/(flow1*eps)
c
c Solve for new estimate of flows by Newton-Raphson technique.
c
      dflow1 = -func/dfunc
ctmp      write (iout1,200) iter,flow,flow1,flow2,dflow1
          if (abs(dflow1).lt.conv) goto 10
          flow1 = flow1 + dflow1
          flow2 = flow - flow1
          enddo
c
c Solution failed to converge within specified number of iterations.
c
      write (iout1,205) iter,flow,flow1,dflow1
      stop
c
c Write out pump component header
c
10      continue
      write (iout1,130)
c
c Solution converged, now compute overall pressure drop.
c
      rdenom1 = eight/(den*pi*diami**2)**2
      rdenom2 = eight/(den*pi*diamo**2)**2
      vel1 = rdenom1*flow*flow
      vel2 = rdenom2*flow*flow
      term1 = g*(elvo - elvi) + (vel2 - vel1)
      delp = den*(term1 + g*func1)
      pin = pdis + delp
      write (iout1,206) pin, pin*p_conv
      write (iout1,207) pdis,pdis*p_conv
      write (iout1,210) delp,delp*p_conv
c
c === Compute pump suction pressures =====
c
c 1'st pump (path A)
      veli = rdenomi*flow1*flow1
      term1 = g*(elvo - elvps) + (vel2 - veli)
      func1 =-tdh1 + flow1**2*term_1o
      ps1 = pdis + den*(term1 + g*func1)
      ps1psi= ps1*p_conv
cc      write(iout1,('pdis,den,term1,func1 = ',4f15.5'))
cc      &      pdis,den,term1,func1
c 2'nd pump (path B)
      veli = rdenomi*flow2*flow2
      term2 = g*(elvo - elvps) + (vel2 - veli)
      func2 =-tdh2 + flow2**2*term_2o
      ps2 = pdis + den*(term2 + g*func2)
      ps2psi= ps2*p_conv
c
c === Compute NPSH available/required at pump suctions =====
c

```

TRAC BLANKET SYSTEM MODEL

```

c 1'st pump (path A)
  area1 = pi*dlegi**2/four
  qi1   = flow1/den
  vi1   = qi1/area1
  call npshr (omega1,qi1,r_npsh1)
  call npsha (temp,ps1,den,vi1,a_npsh1)
c 2'nd pump (path B)
  qi2   = flow2/den
  vi2   = qi2/area1
  call npshr (omega2,qi2,r_npsh2)
  call npsha (temp,ps2,den,vi2,a_npsh2)
c
c Write out results.
c
  write (iout1,300)
  write (iout1,310) 1,flow1,ps1,ps1psi,a_npsh1,r_npsh1,vi1,tdh1
  write (iout1,310) 2,flow2,ps2,ps2psi,a_npsh2,r_npsh2,vi2,tdh2
  write (iout1,430)
c
c pressure delta "P" results for subsections of the pump module
c are calculated and written out:
c
  write (iout4,900)
  write (iout4,901)
  write (iout4,1000) flow1
  write (iout4,1001) flow2
  write (iout4,901)
c
c pressure drop from upstream of inlet "T" to pump suction:
c
  write (iout4,901)
  write (iout4,902)
  write (iout4,901)
  vsqt = (8.0*flow*flow)/(den*pi*pi*(diami**4))
  vsqt1 = (8.0*flow1*flow1)/(den*pi*pi*(dlegi**4))
  vsqt2 = (8.0*flow2*flow2)/(den*pi*pi*(dlegi**4))
  vsqt1bp = (8.0*flow1*flow1)/(den*pi*pi*(diami**4))
  vsqt2bp = (8.0*flow2*flow2)/(den*pi*pi*(diami**4))
  dp1=(vsqt1*(1.0+fmcont+kebowi1+kvalvei1+f1i*(zli1/dlegi))+
& vsqt1bp*kti1-vsqt+den*g*(elvps-elvi))* p_conv
  dp2=(vsqt2*(1.0+fmcont+kebowi2+kvalvei2+f2i*(zli2/dlegi))+
& vsqt2bp*kti2-vsqt+den*g*(elvps-elvi))* p_conv
  dp1sum=dp1
  dp2sum=dp2
  write (iout4,1002) dp1
  write (iout4,1003) dp2
  write (iout4,901)
c
c pressure drop across the pumps:
c
  write (iout4,901)
  write (iout4,903)
  write (iout4,901)
  dp1=(elvo-elvps-tdh1)*den*g* p_conv
  dp2=(elvo-elvps-tdh2)*den*g* p_conv
  dp1sum=dp1sum+dp1
  dp2sum=dp2sum+dp2
  write (iout4,1002) dp1
  write (iout4,1003) dp2
  write (iout4,901)
c
c pressure drop from pump discharge to down stream of "T":

```

```

c
  write (iout4,901)
  write (iout4,904)
  write (iout4,901)
  vsqt = (8.0*flow*flow)/(den*pi*pi*(diamo**4))
  vsqt1 = (8.0*flow1*flow1)/(den*pi*pi*(dlego**4))
  vsqt2 = (8.0*flow2*flow2)/(den*pi*pi*(dlego**4))
  dp1=(vsqt1*(kebowo1+kvalveo1+ktol+f1o*(z1o1/dlego)-1.0)+
&   vsqt)* p_conv
  dp2=(vsqt2*(kebowo2+kvalveo2+kto2+f2o*(z1o2/dlego)-1.0)+
&   vsqt)* p_conv
  dp1sum=dp1sum+dp1
  dp2sum=dp2sum+dp2
  write (iout4,1002)dp1
  write (iout4,1003)dp2
  write (iout4,901)
  write (iout4,1004)dp1sum
  write (iout4,1005)dp2sum
  write (iout4,901)
  dprtn = delp*p_conv
  write (iout4,1006)dprtn

c
c
c === Statement functions =====
c
130  format(/,
&'===== START OF PUMP COMPONENT RESULTS =====',
&'=====',/)
200  format(' iter,flow,flow1,flow2,dflow1 = ',i5,4f10.3)
205  format(' failed to converge',/,
&      ' iter,flow,flow1,dflow          = ',i5,3f10.3)
206  format('Pressure upstream of inlet tee = ',f12.1,
&      ' Pa (',f10.3,' psia)')
207  format('Pressure downstream of exit tee = ',f12.1,
&      ' Pa (',f10.3,' psia)')
210  format('Pump component pressure drop = ',f12.1,
&      ' Pa (',f10.3,' psid)')
300  format(/,
&' pump flow      suction      suction      NPSH      NPSH  ',
&' velocity      TDH',/,
&' id.           pressure      pressure      available  required ',
&'              ',/,
&'      (kg/s)      (Pa)        (psia)        (m)        (m)  ',
&'      (m/s)      (m)',/,
&' -----',
&' -----')
310  format(i3,f9.1,6f11.1)
430  format(/,
&'===== END OF PUMP COMPONENT RESULTS =====',
&'=====',/)

c
900  format ('***** PUMP RESULTS *****')
901  format (' ')
902  format ('*** PRESS DRP UPSTM "T" - PUMP SUCTION ***')
903  format ('*** PRESS DRP ACROSS PUMPS ***')
904  format ('*** PRESS DRP PUMP DSCH - DNSTRM "T" ***')
1000 format (1x,'PUMP #1 mass flowrate = ',g14.8,' kg/s')
1001 format (1x,'PUMP #2 mass flowrate = ',g14.8,' kg/s')
1002 format (1x,'delta P (sys #1) = ',g14.7,' psid')
1003 format (1x,'delta P (sys #2) = ',g14.7,' psid')
1004 format (1x,' total Delta P #1 = ',g14.7,' psid')
1005 format (1x,' total Delta P #2 = ',g14.7,' psid')

```


TRAC BLANKET SYSTEM MODEL

```

1006 format (1x, ' Delta P (returned) =', g14.7, ' psid')
c
      return
      end

```

Input File: (input.dat)

20" base piping with 16" piping within tees

QKTRAC input file:

This is the input deck for a model of the APT target/blanket outer loop from the outlet header to the inlet header. Units are SI.

section #1: (pressurizer to inlet header)

```

      zlength length of pipe (m)
      diam     pipe diameter (m)
      rough    pipe roughness (m)
      delz     elevation change (outlet - inlet)
      dhdrin   inlet header diameter
      fment    entrance form loss coefficient
      fmext    exit form loss coefficient
      fmeb     elbow loss coefficient
      elbnum   number of elbows
      isolve   flag option for solving supply & demand curves
                (0 no, 1 yes)
      flow     mass flowrate
      temp     fluid temperature
      pout     outlet pressure

```

```

      zlength  diam    rough  delz    dhdrin
      31.624   .47788  5.0e-5 -.324   0.736
      fment    fmext    fmeb    elbnum
      0.0      0.335   0.156    6.0
      isolve   flow     phdin  (design goal = 1569.0)
      0        1569.0  1.401e6

```

section #2: (heat exchanger outlet to pressurizer)

```

      zlength length of pipe
      diam     pipe diameter
      delz     elevation change (outlet - inlet)
      fment    entrance form loss coefficient
      fmext    exit form loss coefficient
      fmeb     elbow loss coefficient
      elbnum   number of elbows

```

```

      zlength  diam    delz
      0.0      .47788  0.0
      fment    fmext    fmeb    elbnum
      0.0      0.0      0.0      0.0

```

section #3: (heat exchangers)

```

      zli1     entrance side pipe length for leg 1
      zlo1     exit side pipe length for leg 1
      zli2     entrance side pipe length for leg 2
      zlo2     exit side pipe length for leg 2
      zltub    tube length
      delzhx   elevation change (out - in)
      dleg     pipe diameter
      diat     tube diameter
      rgt      tube roughness
      tuben    number of tubes
      fmhxti1  - inlet "T" loss leg 1
      fmhxtol  - outlet "T" loss leg 1

```

```

fmhxti2 - inlet "T" loss leg 2
fmhxt02 - outlet "T" loss leg 2
fmhi    inlet header entrance form loss coefficient
fmho    outlet header exit form loss coefficient
fmti    tube entrance form loss coefficient
fmt0    tube exit form loss coefficient
fmeb    elbow loss coefficient
elbup1  number of elbows on leg 1 (upstream)
elbup2  number of elbows on leg 2 (upstream)
elbdn1  number of elbows on leg 1 (down stream)
elbdn2  number of elbows on leg 2 (down stream)
vlv1    valve loss leg #1
vlv2    valve loss leg #2
tin     entrance fluid temperature
tout    exit fluid temperature

```

```

zli1    zli2    zlo1    zlo2    zltub    delzhx
2.875   2.875   1.7    6.45   7.92     -2.7
dleg     diat    rght     tuben
.3810    .01021   2.5e-6   6908.0
fmhxti1  fmhxt01  fmhxti2  fmhxt02  fmhi
4.04     1.82     4.04     2.04     0.931
fmho     fnti     fnto     fmeb
0.405    0.347    0.681    0.159
elbup1   elbup2   elbdn1   elbdn2   vlv1     vlv2
1.0      1.0      0.0      1.0      0.047    0.047
tin      tout
59.0     59.0

```

section #4: (pump outlet to heat exchanger inlet)

```

zlength length of pipe
diam     pipe diameter
delz     elevation change (outlet - inlet)
fment    entrance form loss coefficient
fmext    exit form loss coefficient
fmeb     elbow loss coefficient
elbnum   number of elbows

```

```

zlength    diam    delz
3.6         .381    0.0
fment      fmext    fmeb     elbnum
0.0         0.0     0.0      0.0

```

section #5: (pumps)

```

zli1    entrance side pipe length pump 1
zlo1    exit side pipe length pump 1
zli2    entrance side pipe length pump 2
zlo2    exit side pipe length pump 2
dlegi   entrance side diameter
dlego   exit side diameter
fmlti1  entrance "T" form loss coefficient for leg 1
fmlto1  exit "T" form loss coefficient for leg 1
fmlti2  entrance "T" form loss coefficient for leg 2
fmlto2  exit "T" form loss coefficient for leg 2
fmeb5i1 inlet elbow loss coefficient for leg 1
fmeb5o1 outlet elbow loss coefficient for leg 1
fmeb5i2 inlet elbow loss coefficient for leg 2
fmeb5o2 outlet elbow loss coefficient for leg 2
zkvlvi1 inlet leg #1 valve loss coefficient
zkvlvi2 inlet leg #2 valve loss coefficient
zkvlvo1 outlet leg #1 valve loss coefficient
zkvlvo2 outlet leg #2 valve loss coefficient

```

TRAC BLANKET SYSTEM MODEL

omega1 pump #1 angular velocity
 omega2 pump #2 angular velocity
 elvi inlet elevation
 elvo outlet elevation
 elvps pump suction elevation

zli1	zlo1	zli2	zlo2	dlegi	dlego
2.2	2.875	6.95	2.875	0.3810	0.3810
fmlti1	fmlto1	fmlti2	fmlto2		
3.34	2.64	0.084	2.64		
fmeb5i1	fmeb5o1	fmeb5i2	fmeb5o2		
0.0	0.159	0.159	0.159		
zkvlvi1	zkvlvi2	zkvlvo1	zkvlvo2	omega1	omega2
0.047	0.047	0.547	0.547	665.0	665.0
elvi	elvo	elvps			
0.0	2.7	2.2			

section #6: (outlet header to pump inlet)

zlength length of pipe
 diam pipe diameter
 delz elevation change (outlet - inlet)
 dhdrotn outlet header diameter
 fment entrance form loss coefficient
 fmext exit form loss coefficient
 fmeb elbow loss coefficient
 elbnum number of elbows

zlength	diam	delz	dhdrotn
37.386	.47788	1.089	0.736
fment	fmext	fmeb	elbnum
0.243	0.0	0.156	6.0

Modules: (inlet header to outlet header for each module)

c nmods - number of modules connectec to fixed headers
 c kent - Entrance loss coefficient at inlet header (unitless)
 c kext - Exit loss coefficient at outlet header (unitless)
 c kform_i - inlet segment form losses (unitless)
 c kform_h - outlet segment form losses (unitless)
 c kform_o - heated segment form losses (unitless)
 c kvalv_i - valve loss coefficient for inlet segment (unitless)
 c kvalv_h - valve loss coefficient for inlet segment (unitless)
 c kvalv_o - valve loss coefficient for inlet segment (unitless)
 c kebow_i - elbow form loss inlet leg (less than 180 degrees)
 c kebow_h - elbow form loss heated leg (less than 180 degrees)
 c kebow_o - elbow form loss outlet leg (less than 180 degrees)
 c nebow_i - number of elbows in inlet leg (unitless)
 c nebow_h - number of elbows in heated leg (unitless)
 c nebow_o - number of elbows in outlet leg (unitless)
 c dleg_i - pipe diameter on inlet leg (m)
 c dleg_h - pipe diameter on heated leg (m)
 c dleg_o - pipe diameter in outlet leg (m)
 c elv_a - elevation of entrance to heated segment (m)
 c elv_b - elevation of exit to heated segment (m)
 c zl_i - Length of piping in inlet segment (m)
 c zl_m - Length of piping in heated segment (m)
 c zl_o - Length of piping in outlet segment (m)

nmods

5

MODULE 1:

kent	kext
1.0	1.0

TRAC BLANKET SYSTEM MODEL

kform_i	kform_h	kform_o
0.3	0.0	0.3
kvalv_i	kvalv_h	kvalv_o
0.0	0.0	0.0
kebow_i	kebow_h	kebow_o
0.2	0.2	0.2
nebow_i	nebow_h	nebow_o
3	2	3
dleg_i	dleg_h	dleg_o
0.25	0.25	0.25
elv_a	elv_b	
0.0	0.0	
zl_i	zl_h	zl_o
4.0	6.0	4.0

MODULE 2:

kent	kext	
1.0	1.0	
kform_i	kform_h	kform_o
0.3	0.0	0.3
kvalv_i	kvalv_h	kvalv_o
0.0	0.0	0.0
kebow_i	kebow_h	kebow_o
0.2	0.2	0.2
nebow_i	nebow_h	nebow_o
3	2	3
dleg_i	dleg_h	dleg_o
0.2032	0.2032	0.2032
elv_a	elv_b	
0.0	0.0	
zl_i	zl_h	zl_o
4.0	6.0	4.0

MODULE 3:

kent	kext	
1.0	1.0	
kform_i	kform_h	kform_o
0.3	0.0	0.3
kvalv_i	kvalv_h	kvalv_o
0.0	0.0	0.0
kebow_i	kebow_h	kebow_o
0.2	0.2	0.2
nebow_i	nebow_h	nebow_o
3	2	3
dleg_i	dleg_h	dleg_o
0.18	0.18	0.18
elv_a	elv_b	
0.0	0.0	
zl_i	zl_h	zl_o
4.0	6.0	4.0

MODULE 4:

kent	kext	
1.0	1.0	
kform_i	kform_h	kform_o
0.3	0.0	0.3
kvalv_i	kvalv_h	kvalv_o
0.0	0.0	0.0
kebow_i	kebow_h	kebow_o
0.2	0.2	0.2
nebow_i	nebow_h	nebow_o
3	2	3
dleg_i	dleg_h	dleg_o
0.15	0.15	0.15
elv_a	elv_b	

TRAC BLANKET SYSTEM MODEL

```

      0.0      0.0
      zl_i      zl_h      zl_o
      4.0      6.0      4.0

MODULE 5:
      kent      kext
      1.0      1.0
      kform_i    kform_h    kform_o
      0.3      0.0      0.3
      kvalv_i    kvalv_h    kvalv_o
      0.0      0.0      0.0
      kebow_i    kebow_h    kebow_o
      0.2      0.2      0.2
      nebow_i    nebow_h    nebow_o
      3          2          3
      dleg_i    dleg_h    dleg_o
      0.13      0.13      0.13
      elv_a      elv_b
      0.0      0.0
      zl_i      zl_h      zl_o
      4.0      6.0      4.0

```

Output File: (results.out)

20" base piping with 16" piping within tees

===== START OF PUMP COMPONENT RESULTS =====

```

Pressure upstream of inlet tee = 296770.1 Pa ( 43.043 psia)
Pressure downstream of exit tee = 883519.2 Pa ( 128.144 psia)
Pump component pressure drop = -586749.1 Pa ( -85.101 psid)

```

pump id	flow (kg/s)	suction pressure (Pa)	suction pressure (psia)	NPSH available (m)	NPSH required (m)	velocity (m/s)	TDH (m)
1	771.9	247406.6	35.9	23.9	6.8	6.9	70.3
2	797.1	267776.4	38.8	26.0	7.1	7.1	68.1

===== END OF PUMP COMPONENT RESULTS =====

#hydro iterations= 1 supply flow= 1569.0 demand flow= 0.0

```

Outlet header pressure = 66.046799 psia
pump inlet pressure = 43.043007 psia
pump #1 suction pressure = 35.883411 psia
pump #2 suction pressure = 38.837814 psia
pump outlet pressure = 128.14407 psia
HX inlet pressure = 128.01917 psia
HX outlet pressure = 108.12630 psia
Pressurizer pressure = 107.10049 psia
Inlet Header pressure = 106.48997 psia

```

(This Page Intentionally Left Blank)

Appendix D: RHRTRC - A Simple Hydraulic Code for RHR Assessment

This appendix contains the source listing for the code named RHRTRC and all of its associated subroutines. RHRTRC was written specifically for assessing the steady-state isothermal hydraulic behavior of the RHR coolant loop. Sample input and output files are provided.

Program rhrtrc:

```

program rhrtrc
c
c This program calculates the pressure profile in the outer
c flow loop of the APT target/blanket RHR cooling system. The
c mass flowrate and the pressure at the inlet header are
c specified, and the following pressures are calculated
c sequentially: heat exchanger outlet, heat
c exchanger inlet, pump outlet, pump inlet, and the outlet
c header.
c
c      character*74 line1
c      character*74 title
c      iin1 = 5
c      iout1 = 6
c      pconv = 14.696/101325.0
c      g      = 9.807
c      pi     = 3.1415927
cc      open (unit=iin1,file='input.dat',status='old')
cc      open (unit=iout1,file='testcase.out',status='unknown')
c
c Read in the input:
c
c      section #1
c
c      zlg1    length
c      diam1   diameter
c      rough   pipe roughness
c      delz1   delta "z"
c      dhdrin  inlet header diameter
c      fment1  entrance loss coef.
c      fmext1  exit loss coef.
c      fmeb1   elbow loss coef.
c      elbn1   number of elbows
c      ckvlv1  check valve form loss coefficient
c      vlvcf1  valve form loss coefficient
c      flow1   mass flowrate (1% full flow)
c      pout    inlet header pressure
c      flmult  flowrate multiplier
c
c      read (iin1,900) title
c      title =title
c      do 10 i=1,20
c          read (iin1,900)line1
10  continue
c
c      write (iout1,2001)
2001 format ('***** SECTION #1 *****')
c      read (iin1,900)line1
c      write (iout1,900)line1

```

TRAC BLANKET SYSTEM MODEL

```

line1 =line1
read (iin1,*)zlg1,diam1,rough,delz1,dhdrin
write (iout1,*)zlg1,diam1,rough,delz1,dhdrin
read (iin1,900)line1
write (iout1,900)line1
read (iin1,*)fment1,fmext1,fmeb1,elbn1,ckvlv1,vlvcf1
write (iout1,*)fment1,fmext1,fmeb1,elbn1,ckvlv1,vlvcf1
read (iin1,900)line1
write (iout1,900)line1
read (iin1,*)flow1,pout,flmult
write (iout1,*)flow1,pout,flmult
c
c section #2 (heat exchanger)
c
c      zltub  tube length
c      delzhx change in elevation (out - in)
c      diatb  tube diameter
c      rght   tube roughness
c      tuben  number of tubes in a heat exchanger
c      fmhdi  inlet header loss
c      fmhdo  outlet header loss
c      fmtbi  inlet tube loss
c      fmtbo  outlet tube loss
c      tmphxi hx inlet side temp. (input not used/calculated)
c      tmphxo heat exchanger outlet side temperature
c
do 12 i=1,14
    read (iin1,900)line1
12 continue
c
write (iout1,2003)
2003 format ('***** SECTION #2 *****')
read (iin1,900)line1
write (iout1,900)line1
read (iin1,*)zltub,delzhx
write (iout1,*)zltub,delzhx
read (iin1,900)line1
write (iout1,900)line1
read (iin1,*)diatb,rght,tuben
write (iout1,*)diatb,rght,tuben
read (iin1,900)line1
write (iout1,900)line1
read (iin1,*)fmhdi,fmhdo,fmtbi,fmtbo
write (iout1,*)fmhdi,fmhdo,fmtbi,fmtbo
read (iin1,900)line1
write (iout1,900)line1
read (iin1,*)tmphxi,tmphxo
write (iout1,*)tmphxi,tmphxo
c
c section #3 (pump to heat exchanger)
c
c      zlg3   length
c      delz3  delta "z"
c      fment3 entrance loss coef.
c      fmext3 exit loss coef.
c      fmeb3  elbow loss coef.
c      elbn3  number of elbows
c      ckvlv3 check valve form loss coefficient
c      vlvcf3 valve form loss coefficient
c
do 13 i=1,11
    read (iin1,900)line1

```


TRAC BLANKET SYSTEM MODEL

```

13  continue
c
  write (iout1,2004)
2004 format ('***** SECTION #3 *****')
  read (iin1,900)line1
  write (iout1,900)line1
  read (iin1,*)zlg3,delz3
  write (iout1,*)zlg3,delz3
  read (iin1,900)line1
  write (iout1,900)line1
  read (iin1,*)fment3,fmext3,fmeb3,elbn3,ckvlv3,vlvcf3
  write (iout1,*)fment3,fmext3,fmeb3,elbn3,ckvlv3,vlvcf3
c
c  section #4 (pumps)
c
c    omega  pump  speed (rpm)
c    delzp  elevation change (discharge.- suction)
c
  do 14 i=1,5
    read (iin1,900)line1
    write (iout1,900)line1
14  continue
c
  write (iout1,2005)
2005 format ('***** SECTION #4 *****')
  read (iin1,900)line1
  write (iout1,900)line1
  read (iin1,*)omega,delzp
  write (iout1,*)omega,delzp
c
c  section #5
c
c    zlg5    length
c    delz5   delta "z"
c    dhdrot  outlet header diameter
c    fment5  entrance loss coef.
c    fmext5  exit loss coef.
c    fmeb5   elbow loss coef.
c    elbn5   number of elbows
c    ckvlv5  check valve form loss coefficient
c    vlvcf5  valve form loss coefficient
c
  do 15 i=1,12
    read (iin1,900)line1
15  continue
c
  write (iout1,2006)
2006 format ('***** SECTION #5 *****')
c
  read (iin1,900)line1
  write (iout1,900)line1
  read (iin1,*)zlg5,delz5,dhdrot
  write (iout1,*)zlg5,delz5,dhdrot
  read (iin1,900)line1
  write (iout1,900)line1
  read (iin1,*)fment5,fmext5,fmeb5,elbn5,ckvlv5,vlvcf5
  write (iout1,*)fment5,fmext5,fmeb5,elbn5,ckvlv5,vlvcf5
c
c  the input has been read in *****
c
c  evaluate the expansion and contraction form loss coefficients
c  that are associated with the pipe diameter value.

```

TRAC BLANKET SYSTEM MODEL

```

c
    dhxhdr = 0.406
    call kloss(diam1,dhdrin,dhxhdr,fpipex,fpipin,fhxin,fhxot)
    fmext1 = fpipex
    fmhdi = fhxin
    fmhdo = fhxot
    fmext5 = fpipin
    write (iout1,1010)
    write (iout1,1100)
    write (iout1,*) fmext1,fmhdi,fmhdo,fmext5
    write (iout1,1010)

c
c  evaluate the flowrate and hx inlet temperature.  At 1% full flow
c  the delta "T" across the heat exchanger is 16 deg C.
c
    flow = flmult*flow1
    deltlp = 16.0
    tmphxi = tmphxo+deltlp/flmult

c
c  *****
c
c  for benchmarking w/ TRAC a constant temperature of 59 deg C is used:
c
    tmphxi = tmphxo
c  *****
    write (iout1,1010)
    write (iout1,998) flmult
    write (iout1,999) tmphxi
    write (iout1,1010)

c
c  calculate the pressure drop in section #1
c
    call pipd1p(flow,diam1,diam1,dhdrin,zlg1,dclz1,rough,
&              fmeb1,elbn1,fment1,fmext1,
&              ckvlv1,vlvcf1,tmphxo,delp)
    phxout=pout+delp

c
c  calculate the pressure drop across the heat exchangers
c
    call heatx(flow,diam1,zltub,dclzhx,
&             fmhdi,fmhdo,fmtbi,fmtbo,
&             tuben,diatb,rgh,tmphxi,tmphxo,delp)
    phxin=phxout+delp

c
c  calculate the pressure drop in section #3
c
    call pipd1p(flow,diam1,diam1,diam1,zlg3,dclz3,rough,
&              fmeb3,elbn3,fment3,fmext3,
&              ckvlv3,vlvcf3,tmphxi,delp)
    pmpot=phxin+delp

c
c  calculate the pressure drop across the pumps (outlet - inlet)
c
    call propw(tmphxi,dn,vis)
    vflow=flow/dn
    call pmphc(omega,vflow,tdh)
    delp=dn*g*tdh
    pmpin=pmpot-delp+dn*g*dclzp

c
c  calculate the pressure drop in section #5
c
    call pipd1p(flow,diam1,dhdrot,diam1,zlg5,dclz5,rough,

```

TRAC BLANKET SYSTEM MODEL

```

&          fmeb5,elbn5,fment5,fmext5,ckv1v5,
&          vlvcf5,tmphxi,delp)
    phdout=ppmpin+delp
c
c   calculate the pressure difference between the inlet and outlet headers:
c
c          P(inlet header) - P(outlet header)
c
    deltap=pout-phdout
c
c   write out the pressures
c
    write (iout1,910) title
    write (iout1,1001) phdout*pconv
    write (iout1,1002) ppmpin*pconv
    write (iout1,1003) ppmpot*pconv
    write (iout1,1004) phxin*pconv
    write (iout1,1005) phxout*pconv
    write (iout1,1007) pout*pconv
    write (iout1,1010)
    write (iout1,1008) deltap*pconv
    write (iout1,1010)
c
c   calculate available and required values of NPSH:
c
    area = 0.25*pi*(diam1**2)
    veloc = flow/(den*area)
    call npsha(tmphxi,ppmpin,den,veloc,a_npsh)
    write (iout1,1020)a_npsh
    call npshr(omega,vflow,r_npsh)
    write (iout1,1021)r_npsh
c
1001 format (1x,'Outlet header pressure   =','g16.8',' psia ')
1002 format (1x,'pump suction pressure    =','g16.8',' psia ')
1003 format (1x,'pump discharge pressure   =','g16.8',' psia ')
1004 format (1x,'HX inlet pressure         =','g16.8',' psia ')
1005 format (1x,'HX outlet pressure        =','g16.8',' psia ')
1007 format (1x,'Inlet Header pressure     =','g16.8',' psia ')
1008 format (1x,'In - Out header pressure =','g16.8',' psid ')
1010 format (1x,'*****')
1020 format (1x,'NPSH available   =','g14.7',' m ')
1021 format (1x,'NPSH required    =','g14.7',' m ')
1100 format (1x,'fmext1, fmhdi, fmhdo, fmext5')
c
900 format (a74)
910 format (/,a74,/)
998 format (1x,'*** PERCENT full flow =','g14.7',' % ***')
999 format (1x,'*** HX inlet temp. =','g14.7',' deg C ***')
c
    stop
end

```

Subroutine frict:

```

    subroutine frict(re,ed,zf)
c
c *****
c   This subroutine calculates the Moody friction factor for a
c   tube. Inputs are the Reynolds #, and the relative roughness.
c   The Darcy friction factor is returned.
c *****
c
c

```

TRAC BLANKET SYSTEM MODEL

```

      if (re .gt. 50.0) go to 10
      re=50.0
10   if (re .le. 2300.0) then
      zf=64.0/re
      else if (re .ge. 4000.0) then
      zf=1.0/((1.14-2.0*log10(ed+21.25/(re**.9))**.2))
      else
      zf=.23158-2.0549e-4*re+6.6351e-8*(re**2)-6.7336e-12*(re**3)
      end if
      return
      end

```

Subroutine heatx:

```

subroutine heatx(flow,dleg,zltub,delz,fmhi,fmho,
&               fmth,fmto,tuben,diat,
&               rght,tin,tout,delp)
c
c *****
c This subroutine calculates the pressure drop across the
c heat exchanger.
c *****
c
c INPUT:
c   flow    mass flowrate
c   dleg    pipe diameter in the two legs
c   zltub   tube length
c   delz    elevation change (outlet-inlet)
c   fmhi    heat exchanger entrance form loss
c   fmho    heat exchanger exit form loss
c   fmth    hx tube entrance form loss
c   fmto    hx tube exit form loss
c   tuben   number of tubes in hx
c   diat    tube diameter
c   rght    tube roughness
c   tin     inlet temperature
c   tout    outlet temperature
c
c   pi = 3.14159
c   g  = 9.807
c
c Calculate entrance, exit, and mean fluid properties
c
c   call propw(tin,den,vis)
c   deni=den
c   visi=vis
c   call propw(tout,den,vis)
c   deno=den
c   viso=vis
c   tbar=0.5*(tin+tout)
c   call propw(tbar,den,vis)
c   denb=den
c   visb=vis
c
c   flowl=flow
c
c Calculate the friction factors
c
c   re=(4.0*flowl)/(tuben*pi*visb*diat)
c   relrgh=rght/diat
c   call frict(re,relrgh,f)
c   ftl=f

```

TRAC BLANKET SYSTEM MODEL

```

c
c
c
      upstrm=(fmhi)/
&      (deni*dleg*dleg*dleg*dleg)
      dnstrm=(fmho)/
&      (deno*dleg*dleg*dleg*dleg)
      tublos=(fnti+fnto+(ftl*ztub)/diat)/
&      (denb*tuben*tuben*diat*diat*diat)
      cl=upstrm+dnstrm+tublos
c
      delp=((8.0*flow1*flow1)/(pi*pi))*cl+denb*g*delz
      return
      end

```

Subroutine kloss:

```

subroutine kloss(dpipe,dhdr,dhxhdr,
&      fpipe,fpipin,fhxin,fhxot)
c
c   This subroutine evaluates the sudden expansion and
c   contraction form loss coefficients for the RHR system,
c   that are a function of the pipe diameter.
c
c   INPUTS:
c
c      dpipe  pipe diameter
c      dhdr   inlet/outlet header diameters
c      dhxhdr heat exchanger header diameters
c
c   OUTPUTS:
c
c      fpipe  K - pipe to inlet header
c      fpipin K - outlet header to pipe
c      fhxin  K - pipe to heat exchanger inlet header
c      fhxot  K - heat exchanger outlet header to pipe
c
c      data cf1,cf2,cf3,cf4 / .48954, -.71606, .36098, -.13510 /
c
c      pi = 3.14159
c
c   evaluate areas:
c
c      areap = 0.25*pi*(dpipe**2)
c      areahd = 0.25*pi*(dhdr**2)
c      areahx = 0.25*pi*(dhxhdr**2)
c
c   evaluate form loss coefficients:
c
c      fpipe = ((1.0-(areap/areahd))**2)
cc      fpipin = 0.42*(1.0-((dpipe/dhdr)**2))
c      ar = (dpipe/dhdr)**2
c      fpipin = cf1+ar*(cf2+ar*(cf3+ar*cf4))
c      fhxin = ((1.0-(areap/areahx))**2)
cc      fhxot = 0.42*(1.0-((dpipe/dhxhdr)**2))
c      ar = (dpipe/dhxhdr)**2
c      fhxot = cf1+ar*(cf2+ar*(cf3+ar*cf4))
c
c      return
c      end

```

Subroutine npsha:

TRAC BLANKET SYSTEM MODEL

```

subroutine npsha (tfld,pfld,rhof,velf,a_npsb)
c
c *****
c *
c * This subroutine computes the net positive suction head
c * available at the piping location provided.
c *
c * INPUT:
c *     tfld - fluid temperature (C)
c *     pfld - fluid pressure (Pa)
c *     rhof - fluid density (kg/m^3)
c *     velf - fluid velocity (m/s)
c *
c * OUTPUT:
c *     a_npsb - net positive suction head available (m)
c *
c *****
c
c implicit real (a-h,o-z), integer (i-n)
c parameter (two=2.0)

c Gravitational constant:
c
c     data grav / 9.807 /
c
c CONVERSION FACTORS EMPLOYED (SI)
c
c con_tmp - converts C to K
c
c     con_tmp = 273.15
c
c === COMPUTE NPSH AVAILABLE =====
c
c CONVERT TEMPERATURE TO ABSOLUTE
c
c     tk = tfld + con_tmp
c
c COMPUTE FLUID SATURATION PRESSURE FOR H2O
c
c     ifluid = 1
c     call psat (tk,ifluid,pvap,xlum)
c
c EVALUATE NPSH AVAILABLE FUNCTION
c
c     a_npsb = (pfld - pvap)/(grav*rhof) + velf/(two*grav)
c
c     return
c     end

```

Subroutine npshr:

```

subroutine npshr (omega,flow,r_npsb)
c
c *****
c *
c * This subroutine computes the net positive suction head
c * requirements for the blanket system RHR coolant pump
c * at the entrance piping location called.
c *
c * INPUT:
c *     omega - requested pump speed (rpm)
c *
c *****

```

TRAC BLANKET SYSTEM MODEL

```

c      *      flow - volumetric flowrate (m^3/s)      *
c      *
c      *  OUTPUT:
c      *      r_npsh - net positive suction head required (m)
c      *
c      *****
c
c      implicit real (a-h,o-z), integer (i-n)
c
c      data rfnpsh,rfomg,rfflw,expon / 2.35, 1760.0, 2.778e-2, .424 /
c
c      r_npsh=rfnpsh*(omega/rfomg)*((flow/rfflw)**expon)
c
c      return
c      end

```

Subroutine pipdlp:

```

subroutine pipdlp(flow,diam,diamin,diamot,zlngth,delz,rough,
&               fmeb90,elbn90,fment,fmext,ckvlv,vlv,temp,delp)
c
c      *****
c      This subroutine calculates the pressure drop in a length of pipe.
c      The units are SI.
c      *****
c
c      INPUT:
c      flow      mass flowrate
c      diam      pipe diameter
c      diamin    inlet diameter
c      diamot    outlet diameter
c      zlngth    pipe length
c      delz      change in elevation {Z(downstream) - Z(upstream)}
c      rough     pipe roughness
c      fmeb90    elbow form loss (90 degrees)
c      elbn90    number of 90 deg. elbows
c      fment     entrance form loss
c      fmext     exit form loss
c      ckvlv     check valve form loss coefficient
c      vlv       valve form loss coefficient
c      g         acceleration of gravity
c      temp      fluid temperature
c
c      pi = 3.14159
c      g  = 9.807
c
c      Calculate the friction factor
c
c      call propw(temp,den,vis)
c      re      = (4.0*flow)/(pi*vis*diam)
c      relrgh  = rough/diam
c      call frict(re,relrgh,f)
c
c      Calculate the pressure drop
c
c      coef=(8.0*flow*flow)/(den*pi*pi*diam*diam*diam*diam)
c      bern=((8.0*flow*flow)/(den*pi*pi))*
&      ((1.0/(diamot**4))-(1.0/(diamin**4)))
c      frmsum=elbn90*fmeb90+fment+fmext+ckvlv+vlv
c      delp=(den*g*delz)+bern+coef*(frmsum+(f*zlngth)/diam)
c      return
c      end

```

Subroutine pmphc:

```

subroutine pmphc (omega,flow,tdh)
c
c *****
c *
c * This subroutine computes the total dynamic head given a *
c * pump speed and volumetric flowrate. A Hardwired homologous *
c * head curve is used that is based on the LANL LOFT curve and *
c * the reference state of the BEP for the SRS Bingham Pump. *
c *
c * Bingham BEP:      1000 rpm *
c *                   25 kgpm (1.577267 m^3/s) *
c *                   406 ft (123.7488 m) *
c *
c * RHR BEP:          1000 rpm *
c *                   .079838 m^3/s *
c *                   14.8392 m *
c *
c * INPUT: *
c *      omega - requested pump speed (rpm) *
c *      flow - volumetric flowrate (m^3/s) *
c *
c * OUTPUT: *
c *      tdh - total dynamic head (m) *
c *
c *****
c
c implicit real (a-h,o-z), integer (i-n)
c parameter (one=1.0, two=2.0)
c
c Bingham BEP Reference conditions (SI units):
c
c      data romea,rflow,rhead / 1000.0, 0.079838, 14.8392 /
c
c Quadratic polynomial fit of LANL LOFT Homologous head curve coefs:
c
c      data acoef,bcoef,ccoeff / 1.4, -0.15, -0.25 /
c
c === COMPUTE TOTAL DYNAMIC HEAD =====
c
c NORMALIZE INPUT PARAMETERS
c
c      d_omega = omega/romea
c      d_flow = flow/rflow
c      x_homo = d_flow/d_omega
c
c EVALUATE HOMOLOGOUS FUNCTION
c
c      if (x_homo.le.one) then
c
c          either a quadratic fit or linear interpolation:
c
c          y_homo = acoef + x_homo*(bcoef + ccoef*x_homo)
c          if (x_homo.le. 0.4) then
c              y_homo = 1.3 + 0.25*(0.4 - x_homo)
c          else
c              y_homo = 1.0 + 0.5*(1.0 - x_homo)
c          endif
c      else
c          y_homo = one + (bcoef + two*ccoeff)*(x_homo - one)

```


TRAC BLANKET SYSTEM MODEL

```

endif
c
c SCALEUP TO THD VALUE
c
      tdh = y_homo*d_omega*d_omega*rhead
c
      return
end

```

Subroutine propw:

```

subroutine propw(temp,den,vis)
c
c This subroutine returns properties for liquid
c water as a function of temperature, (deg. C)
c
      parameter (a1=1004.39, a2=-0.13226, a3=-3.053e-3)
      parameter (b1=1.4051e-3, b2=-2.2076e-5, b3=1.0849e-7)
c
      den=a1+a2*temp+a3*temp*temp
      vis=b1+b2*temp+b3*temp*temp
      return
end

```

Subroutine psat:

```

subroutine psat(t,ifld,ps,dpsdt)
c
c *****
c *
c * INPUT:
c * t = MIXTURE GAS OR LIQUID TEMPERATURE, K
c * iflg = IDENTIFIER (1=1 FOR H2O, 1=2 FOR D2O)
c *
c * OUTPUT:
c * ps = SATURATION PRESSURE OF H2O OR D2O, Pa
c * dpsdt = DERIVATIVE OF ps W.R.T. t
c *
c * RANGE:
c * 273K < t < 453K
c *
c *****
c
c implicit real (a-h,o-z), integer (i-n)
c parameter (two=2.0, three=3.0)
c dimension c1(2), c2(2), c3(2), c4(2)
c
c H2O PROPERTIES
c
c data c1(1)/-38.874/, c2(1)/0.29129/,
& c3(1)/-5.7014e-4/, c4(1)/4.0606e-7/
c
c D2O PROPERTIES
c
c data c1(2)/-39.686/, c2(2)/0.29393/,
& c3(2)/-5.7036e-4/, c4(2)/4.0230e-7/
c
      ps = exp(c1(ifld) + (c2(ifld) + (c3(ifld) + c4(ifld)*t)*t)*t)
      dpsdt = ps*(c2(ifld) + (two*c3(ifld) + (three*c4(ifld))*t)*t)
c
      return
end

```

TRAC BLANKET SYSTEM MODEL

Input File: (pipe6in_4%.dat)

6" base piping, (4)% flow

RHRTRC input file:

This is the input deck for a model of the APT target/blanket RHR
 outer loop from the outlet header to the inlet header. Units are SI.
 section #1: (heat exchanger to inlet header)

zlength length of pipe (m)
 diam pipe diameter (m)
 rough pipe roughness (m)
 delz elevation change (outlet - inlet)
 dhdrin inlet header diameter
 fment entrance form loss coefficient
 fmext exit form loss coefficient
 fmeb elbow loss coefficient
 elbnum number of elbows
 ckvlv1 check valve form loss coefficient
 vlvcf1 valve form loss coefficient
 flow mass flowrate (1% full flow)
 pout outlet pressure
 flmult flow multiplier (% full flow)

zlength	diam	rough	delz	dhdrin	
34.924	.154051	5.0e-5	-.924	0.736	
fment	fmext	fmeb	elbnum	ckvlv1	vlvcf1
0.0	0.0	0.18	5.33	0.0	.15
flow	pout	fmult			
15.728	133033.0	4.0			

section #2: (heat exchanger)

zltub tube length
 delzhx elevation change (out - in)
 diat tube diameter
 rght tube roughness
 tuben number of tubes
 fmhi inlet header entrance form loss coefficient
 fmho outlet header exit form loss coefficient
 fmti tube entrance form loss coefficient
 fmto tube exit form loss coefficient
 tin entrance fluid temperature
 tout exit fluid temperature

zltub	delzhx		
3.96	0.0		
diat	rght	tuben	
.01021	2.5e-6	277.0	
fmhi	fmho	fmti	fmto
0.0	0.0	0.374	0.68
tin	tout		
0.0	59.0		

section #3: (pump outlet to heat exchanger inlet)

zlength length of pipe
 delz elevation change (outlet - inlet)
 fment entrance form loss coefficient
 fmext exit form loss coefficient
 fmeb elbow loss coefficient
 elbnum number of elbows
 ckvlv3 check valve form loss coefficient
 vlvcf3 valve form loss coefficient

zlength	delz
---------	------

TRAC BLANKET SYSTEM MODEL

```

2.5      0.0
fment    fmext    fmeb    elbnum    ckvlv3    vlvcf3
0.0      0.0      0.0      0.0      0.5      0.15
*****
section #4: (pump)
      omega pump angular velocity
      delz elevation change (outlet - inlet)
*****
      omega delz
      897.0 .5
*****
section #5: (outlet header to pump inlet)
      zlength length of pipe
      delz elevation change (outlet - inlet)
      dhdrotn outlet header diameter
      fment entrance form loss coefficient
      fmext exit form loss coefficient
      fmeb elbow loss coefficient
      elbnum number of elbows
      ckvlv check valve form loss coefficient
      vlvcf valve form loss coefficient
*****
      zlength delz dhdrotn
      45.586 1.186 0.718
      fment fmext fmeb elbnum ckvlv vlvcf
      0.0 0.0 0.25 7.17 0.0 .15

```

Output File: (pipe6in_4%.out)

```

***** SECTION #1 *****
      zlength diam rough delz dhdrin
      34.92400 0.1540510 4.9999999E-05 -0.9240000 0.7360000
      fment fmext fmeb elbnum ckvlv1 vlvcf1
      0.0000000E+00 0.0000000E+00 0.1800000 5.330000 0.0000000E+00
      0.1500000
      flow pout flmult
      15.72800 133033.0 4.000000
***** SECTION #2 *****
      zltub delzhx
      3.960000 0.0000000E+00
      diat rght tuben
      1.0210000E-02 2.4999999E-06 277.0000
      fmhi fmho fmto fmto
      0.0000000E+00 0.0000000E+00 0.3740000 0.6800000
      tin tout
      0.0000000E+00 59.00000
***** SECTION #3 *****
      zlength delz
      2.500000 0.0000000E+00
      fment fmext fmeb elbnum ckvlv3 vlvcf3
      0.0000000E+00 0.0000000E+00 0.0000000E+00 0.0000000E+00 0.5000000
      0.1500000
*****
section #4: (pump)
      omega pump angular velocity
      delz elevation change (outlet - inlet)
*****
***** SECTION #4 *****
      omega delz
      897.0000 0.5000000
***** SECTION #5 *****
      zlength delz dhdrotn

```

TRAC BLANKET SYSTEM MODEL

```

45.58600      1.186000      0.7180000
fment  fmext  fmeb  elbnum  chkvlv  vlvc1f
0.0000000E+00 0.0000000E+00 0.2500000      7.170000      0.0000000E+00
0.1500000

```

```

*****

```

```

fmext1, fmhdi, fmhdo, fmext5

```

```

0.9142993      0.7327845      0.3935268      0.4588509

```

```

*****

```

```

*** PERCENT full flow = 4.000000      % ***

```

```

*** HX inlet temp. = 59.00000      deg C ***

```

```

*****

```

```

6" base piping, (4)% flow

```

```

Outlet header pressure = 20.299414      psia
pump suction pressure  = 11.843257      psia
pump discharge pressure = 28.799248      psia
HX inlet pressure      = 28.038254      psia
HX outlet pressure     = 21.880371      psia
Inlet Header pressure  = 19.294872      psia

```

```

*****

```

```

In - Out header pressure = -1.0045416      psid

```

```

*****

```

```

NPSH available = 6.643565      m

```

```

NPSH required  = 1.704061      m

```

SGI Workstation to run rhtrc:

```

rhtrc < pipe6in_4%.dat > pipe6in_4%.out
asedit pipe6in_4%.out &

```