2. To: (Receiving Organization) B Plant Facility Engineering		3. From: (Originating Organization) SAR Engineering Services		4. Related EDT No.: N/A	
5. Proj./Prog./Dept./Div.: B Plant		6. Design Authority/ Design Agent/Cog. Engr.: P. E. Roege		7. Purchase Order No.: N/A	
8. Originator Remarks: Document issued for approval and release.				9. Equip./Component No.: N/A	
				10. System/Bldg./Facility: B Plant	
11. Receiver Remarks: 11A. Design Baseline Document? ☐ Yes ☒ No The attached safety assessment establishes the safety basis for the transfer of organic waste from the B Plant facility and demonstrates that no increase in risk to the DOE is created. The actual transportation of the waste is managed by others.				12. Major Assm. Dwg. No.: N/A	
				13. Permit/Permit Application No.: N/A	
				14. Required Response Date: COB 02/11/97	

DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Transmittal	Originator Disposition	Receiver Disposition
1	HNF-SD-OPS-SAD-001	--	0	Safety Assessment for Storage of Organic Liquids Adjacent to B Plant	SQ	1,2	1	1

16. KEY					
Approval Designator (F)		Reason for Transmittal (G)		Disposition (H) & (I)	
E, S, O, D or N/A (see WHC-CM-3-5, Sec. 12.7)		1. Approval	4. Review	1. Approved	4. Reviewed no/comment
		2. Release	5. Post-Review	2. Approved w/comment	5. Reviewed w/comment
		3. Information	6. Dist. (Receipt Acknow. Required)	3. Disapproved w/comment	6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN
1,2	1	Design Authority	<i>P. E. Roege</i>	2/11/97		1,2	1	E. R. HARPLA	<i>E. R. Harpla</i>	2/12/97	56-60
--	--	Design Agent	N/A			1,2	1	E. D. ROBBINS	<i>E. D. Robbins</i>	2/12/97	56-60
1,2	1	Cog. Eng.	S. E. Chalk	2/11/97	A2-25						
1,2	1	Cog. Mgr.	L. E. Johnston	2/11/97	A2-25						
1,2	1	QA	M. A. Hill	2/13/97	54-66						
1,2	1	Safety	M. K. Ullah	2/13/97	54-66						
--	--	Env.	N/A								

18. Signature of EDT Originator <i>[Signature]</i> 2/11/97		19. Authorized Representative Date for Receiving Organization <i>[Signature]</i> 2-12-97		20. Design Authority/ Cognizant Manager <i>[Signature]</i> 2/11/97		21. DOE APPROVAL (if required) Ctrl. No. ☐ Approved ☐ Approved w/comments ☐ Disapproved w/comments	

Safety Assessment for Storage of Organic Liquids Adjacent to B Plant

Fluor Daniel Northwest, Richland, WA 99352
Steve E. Chalk
U.S. Department of Energy Contract DE-AC06-96RL13200

EDT/ECN: 616283 UC: 510
Org Code: 403 Charge Code: E58316
B&R Code: EW7002010 Total Pages: 41 43 2/13/97

Key Words: USQ, Organics, Safety, Storage

Abstract: This safety assessment was written to analyze the potential hazards and accidents that could occur during the storage of organic liquid waste outside of the B Plant facility.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: WMC/BCS Document Control Services, P.O. Box 1970, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

Barbara Suckley 2/13/97
Release Approval Date

Approved for Public Release

**SAFETY ASSESSMENT FOR STORAGE OF
ORGANIC LIQUIDS ADJACENT TO B PLANT**

Prepared By:

Fluor Daniel Northwest
P.O. Box 1050
Richland, WA 99352

For:

B & W Hanford Company
P.O. Box 1200
Richland, WA 99352

February 1997

This page intentionally left blank.

CONTENTS

1.0	SCOPE	1
2.0	DESCRIPTION OF ACTION	1
3.0	IDENTIFICATION OF HAZARDS	1
4.0	HAZARDS ANALYSIS	7
4.1	BASIC APPROACH	7
4.2	LIQUID SPILL AND BURNING SCENARIO	9
4.3	HYDROGEN GENERATION WITHIN THE TANK	11
5.0	CONSEQUENCE OF ACCIDENTS	13
5.1	CONSEQUENCE ANALYSIS METHODOLOGY	13
5.2	ORGANIC SPILL AND FIRE (RADIOLOGICAL CONSEQUENCES)	15
5.3	ORGANIC SPILL AND FIRE (TOXICOLOGICAL CONSEQUENCES)	17
5.3.1	Phosphorous Pentoxide	17
5.3.2	Carbon Monoxide	19
5.4	HYDROGEN EXPLOSION IN THE TANK HEADSPACE	20
5.5	SPILL OF ORGANIC FROM EXTERNAL TANK (RADIOLOGICAL CONSEQUENCES)	21
5.6	SPILL OF ORGANIC FROM EXTERNAL TANK (TOXICOLOGICAL CONSEQUENCES)	22
6.0	CONTROLS	22
6.1	RADIOACTIVE INVENTORIES	22
6.2	TRANSFER FROM PRIMARY TO SPARE TANK	23
7.0	REFERENCES	23
APPENDIX A	MATCAD CALCULATIONS	A-1
APPENDIX B	PRELIMINARY HAZARDS ANALYSIS (PHA) PARTICIPANTS	B-1

LIST OF TABLES

1.	PHA Table for Organic Storage Tanks USQ	3
2.	PHA Checklist	7
3.	WHC Risk Acceptance Guidelines	8
4.	Maximum ⁹⁰ Sr and ¹³⁷ Cs Quantities (Ci) Prior To Placement of Tank Onto Concrete Pad (Berm Not In Place)	8
5.	Maximum ⁹⁰ Sr and ¹³⁷ Cs Quantities (Ci) Prior To Placement of Tank Onto Concrete Pad (Berm In Place)	9
6.	Hydrogen Generation Data	12
7.	Site Boundary Distances Used in Offsite Dispersion Calculations . .	14
8.	Atmospheric Dispersion Coefficients (X/Qs) Used in the Accident Analysis	15
9.	Predicted Radiological Consequences For Organic Fire	17
10.	Predicted Concentrations of Phosphorous Pentoxide in Organic Fire Plume	18
11.	Predicted Concentrations for Carbon Monoxide in Organic Fire Plume	19
12.	Predicted Radiological Consequences For H ₂ Explosion And Organic Fire	21
13.	Maximum ⁹⁰ Sr and ¹³⁷ Cs Quantities (Ci) Prior To Placement of Tank Onto Concrete Pad	23

LIST OF TERMS

ALARA	as low as reasonably achievable
ARF	airborne release fraction
ARR	airborne release rate
Bq	Becquerel
BR	breathing rate
Ci	curie
D2EHPA	Di-2-ethylhexyl phosphoric acid
DCF	dose conversion factor
DOE-RL	U.S. Department of Energy-Richland Field Office
EDE	effective dose equivalent
ERPG	emergency response planning guideline
HAZOP	Hazard and Operability
HEPA	high efficiency particulate air (filter)
ICRP	International Commission on Radiological Protection
ISB	interim safety basis
LSA	low specific activity
LLW	low level waste
MeV	million electron volt
NIOSH	National Institute for Occupational Safety and Health
NPH	normal paraffin hydrocarbon
PHA	preliminary hazards analysis
mPa	mega-pascal
MR	mass ratio
PEL-TWA	permissible exposure limit - time weighted average
psi	pounds per square inch
RCT	Radiological Control Technician
S&M	Surveillance and Maintenance
SSC	structure, system, and component
Sv	Sievert
TBP	tributyl phosphate
USQ	unreviewed safety question
WESF	Waste Encapsulation and Storage Facility
WHC	Westinghouse Hanford Company
X/Q	atmospheric dispersion factor

This page intentionally left blank.

SAFETY ASSESSMENT FOR STORAGE OF ORGANIC LIQUIDS AT B PLANT

1.0 SCOPE

The B Plant facility is currently undergoing preparations for transition to surveillance and maintenance (S&M). Organic liquid waste is to be stored outside of B Plant in a tank located on a concrete pad approximately 100 m (328 ft) NNE of the NE corner of the plant. An Unreviewed Safety Question (USQ) screening was conducted and it was determined that the liquid storage of radioactive contaminated organic liquids outside the 221-B canyon ventilation area such as the proposed activity was not covered by the existing Safety Basis of B Plant. This Safety Assessment (SA) supports the USQ Evaluation and addresses the outside storage of the organic liquid waste.

2.0 DESCRIPTION OF SYSTEM

The storage tank has a capacity of 17,500 L (4,623 gal). The concrete pad has a 0.6 m (2 ft) high berm that acts as a secondary containment feature to contain any leaks that might occur during storage. The berm area is approximately 5.1-m (16.7-ft) by 9.14-m (30.0-ft) with a total capacity of 28 m³ (2.8 x 10⁶ L). The concrete pad will have a fence surrounding it and no electrical connections are provided to the tanks except for grounding connections. There will also be a spare tank identical to the primary tank located on the concrete pad. The spare tank can be used to store the organic liquid in case of any leak or required maintenance on the primary tank. The tanks are designed with passive ventilation systems, being vented through HEPA filters to reduce any potential emissions. The passive vent system has been specifically designed to maintain hydrogen concentrations in the headspace of the tanks at approximately 2 vol%, below the lower flammable limit (LFL) of hydrogen in air, which is 4 vol%. The spare tank located on the same concrete pad will have its own secondary containment (berm). Both tanks are rated at 1.7 MPa (250 psi). Any transfer from the primary tank to the spare will use an air driven pump. The *Safety Assessment For Removal Of Organic Liquids From B Plant* (WHC 1996a) analyzed the potential spray release consequences from transfer of the organic liquid into the tank located on the flatbed. The radionuclides were analyzed at their maximum allowable concentrations to produce dose consequences of less than 50 mSv (5 rem) onsite. The washing and filtering of the organics prior to transfer will result in concentrations less than the maximum allowable. Therefore, as long as the pump pressure does not exceed 0.70 MPa (100 psi) as assumed in WHC 1996a, the consequences of a spray leak due to organic transfer to the spare tank is bounded by WHC 1996a.

3.0 IDENTIFICATION OF HAZARDS

As the first step in the development of the USQ Evaluation, a Preliminary Hazards Analysis (PHA) was performed. The PHA used a multi-discipline team of experts (see Appendix B for lists) to examine the safety implications of removal of organic material from B Plant and storage on the

new organic storage pad outside of B Plant. The experts represented B Plant operations, engineering (design and process), and safety.

The form used for the PHA is included as Table 1. The first column, labelled "Process Step" defines the process step being analyzed. The second column, labelled "Hazardous Condition" refers to a credible abnormal event combined with an intrinsic hazard (radioactivity, toxic material, etc) which may result in adverse consequences to a facility worker and/or a person at a distance from the facility. A checklist (Table 2) was used to help ensure the completeness of the list of hazardous conditions, although the team could postulate hazardous conditions not included in the checklist. The third column, "cause" lists abnormal events which the team believed may initiate the hazardous condition. The fourth column, "consequences", qualitatively describes the postulated consequences of the hazardous condition. The fifth and sixth columns list the engineered and administrative features expected to be included in the design and/or operating procedures which may prevent or mitigate the consequences of the hazardous condition. The lists of equipment and procedures in these columns can be used to demonstrate defense in depth. The lists can also be used as the basis of safety equipment lists and technical specifications. The column labelled "inventory", is a qualitative description of the hazardous material which could potentially be dispersed in the hazardous condition (e. g., organic solvent, TBP, radionuclides, etc). The consequence and frequency category columns serve to qualitatively rank the postulated accident consequences and frequencies.

The safety consequences are ranked in the following four categories:

- S0 = No safety consequences or environmental events.
- S1 = Facility worker injury or exposure to hazardous materials; reportable release of hazardous materials within or near the pad
- S2 = Hazardous material exposure to person (co-located worker) at a distance from the pad; significant hazardous material discharge beyond the pad
- S3 = Hazardous material exposure to the public; hazardous material discharge offsite

The frequencies of the consequences (hazardous condition and failure of mitigative/preventive features) are ranked in the following four categories:

- F0 = Beyond Extremely Unlikely ($f < 10^{-6}/\text{yr}$)
- F1 = Extremely Unlikely ($10^{-6}/\text{yr} < f < 10^{-4}/\text{yr}$)
- F2 = Unlikely ($10^{-4}/\text{yr} < f < 10^{-2}/\text{yr}$)
- F3 = Anticipated ($10^{-2}/\text{yr} < f$)

The "remarks" column is used to document comments or recommendations that the team felt should be communicated to the operations and design functions.

The information in the PHA table was used to select accidents for detailed analysis for this Safety Assessment, to help develop the accident scenarios, and to assist in the selection of safety-class and safety-significant structures, systems and components (SSCs).

Table 1. PHA Table for Organic Storage Tanks USQ.

Process Step	Hazardous Condition	Cause(s)	Consequence	Engineered Safety Features	Administrative Features	Inventory	Consequence Cat.	Freq. Cat.	Remarks
Storage	Leakage Of Radioactive Or Hazardous Material	Corrosion	Personnel Exposure leakage Environmental Release	Secondary Containment Code Design Of Spare Tank Secondary Containment Vessel	Surveillance Tanks	Tank Cont-	S2	F1	ASME Section VIII Vessel
Storage	Leakage Of Radioactive Or Hazardous Material	Projectile	Environmental Release leakage Personnel Exposure Code Design Of Vessel	Emergency Procedures Tank Cont-	Emergency Procedures Tank Cont-	S2	F1		
Storage	Leakage Of Radioactive Or Hazardous Material	Vehicle Impact	Environmental Release leakage Personnel Exposure Spill Pad Wall Around Tank Area Fence Around Tank Area	Standard Handling Controls Tank Cont-	Standard Handling Controls Tank Cont-	S2	F1		
Storage	Leakage Of Radioactive Or Hazardous Material	Seismic Event	Environmental Release leakage Personnel Exposure Of Vessel And Restraints	Emergency Plan Tank Cont-	Emergency Plan Tank Cont-	S2	F1		
Storage	Leakage Of Radioactive Or Hazardous Material	Plane Crash	Environmental Release leakage Personnel Exposure	Air Traffic Regulations Tank Cont-	Air Traffic Regulations Tank Cont-	S2	F0		
Storage	Leakage Of Radioactive Or Hazardous Material	Wind	Environmental Release leakage Personnel Exposure	SDC 4.1 Design Tank Cont-	SDC 4.1 Design Tank Cont-	S2	F1		
Storage	Leakage Of Radioactive Or Hazardous Material	Internal Explosion/Fire	Environmental Release leakage Personnel Exposure	Vents Set Up So That Evolved Vapors (Hydrogen Or Organic Solvent) Will Be Adequately Diluted Tank Cont-	Surveillance To Assure Vents Are Open Tank Cont-	S2	F2		
Storage	Leakage Of Radioactive Or Hazardous Material	Overheating	Environmental Release leakage Personnel Exposure	Tank Painted White Vents Set Up So That Natural Circulation Will Prevent Overheating Tank Cont-	Surveillance To Assure Vents Are Open Tank Cont-	S2	F2		

Date: 7/18/96
Participants: See List A

Table 1. PHA Table for Organic Storage Tanks USQ.

Process Step	Hazardous Condition	Cause(s)	Consequence	Engineered Safety Features	Administrative Features	Inventory	Conseq. Cat.	Freq. Cat.	Remarks
Storage	Direct Radiation Dose	Proximity To Tank	Dose To Facility Worker Exceeding Hanford Standards	Locked Fence	Posted As A High Radiation Area	N/A	S1	F2	
Storage	Ventilation System HEPA Filter Or Vent Tube Blockage	Filter Freezing	Hydrogen Buildup (Fire) Filter Failure (Airborne Release)		Downstream Air Sample	Tank Contents (Fire) Filter Inventory; Tank Atmosphere	S2	F2	
Storage	Ventilation System HEPA Filter Or Vent Tube Blockage	Animal Intrusion	Hydrogen Buildup (Fire) Filter Failure (Airborne Release)	Design Provisions		Tank Contents (Fire) Filter Inventory; Tank Atmosphere	S2	F2	
Storage	Ventilation System HEPA Filter Or Vent Tube Blockage	Snow	Hydrogen Buildup (Fire) Filter Failure (Airborne Release)			Tank Contents (Fire) Filter Inventory Tank Atmosphere	S2	F2	
Storage	Ventilation System HEPA Filter Or Vent Tube Blockage	Organic Buildup	Hydrogen Buildup (Fire) Filter Failure (Airborne Release)		Periodic Filter Replacement	Tank Contents (Fire) Filter Inventory Tank Atmosphere	S2	F1	
Storage	Ventilation System HEPA Filter Or Vent Tube Blockage	Waste Blocking Tube	Hydrogen Buildup (Fire) Filter Failure (Airborne Release)		Maintaining Adequate Freeboard	Tank Contents (Fire) Filter Inventory Tank Atmosphere	Controlled By Degree Of Cleanup	F2	
Storage	Ventilation System HEPA Filter Or Vent Tube Blockage	Tumbleweeds	Hydrogen Buildup (Fire) Filter Failure (Airborne Release)		Surveillance Of Area	Tank Contents (Fire) Filter Inventory Tank Atmosphere	S1	F2	

Date: 7/18/96
Participants: See List A

Table 1. PHA Table for Organic Storage Tanks USQ.

Process Step	Hazardous Condition	Cause(s)	Consequence	Engineered Safety Features	Administrative Features	Inventory	Conseq. Cat.	Freq. Cat.	Remarks
Storage	Ventilation System HEPA Filter Or Vent Tube Blockage	Failure To Open Vent Valve After Tank Transfer	Hydrogen Buildup (Fire) Tank Rupture		Inspection Of Tank to Ensure Valve is Open	Tank Contents (Fire) Filter Inventory Tank Atmosphere	S2	F2	
Storage	Fire	Range Fire	Airborne Radioactive Release Expansion Airborne Toxic Release	Fence And Gravel Surrounding The Tank Spill Pad	Housekeeping	Tank Contents (Fire) Filter Inventory Tank Atmosphere	S2	F2	
Storage	Fire	Vehicle Accident	Airborne Radioactive Release Expansion Airborne Toxic Release	Fence Surrounding The Tank And Spill Pad	Standard Hanford Traffic Controls	Tank Contents (Fire) Filter Inventory Tank Atmosphere	S2	F1	
Storage	Fire	Lightning	Airborne Radioactive Release Expansion Airborne Toxic Release	Grounding Of Tank	QC Inspection And Periodic Maintenance Of Grounding	Tank Contents (Fire) Filter Inventory Tank Atmosphere	S2	F1	
Storage	Fire	Welding	Airborne Radioactive Release Expansion Airborne Toxic Release		Standard Controls On Welding Activity	Tank Contents (Fire) Filter Inventory Tank Atmosphere	S2	F2	
Storage	Fire	Maintenance	Airborne Radioactive Release Airborne Toxic Release		Administrative Controls On Maintenance Activity	Tank Contents (Fire) Filter Inventory Tank Atmosphere	S2	F2	

Date: 7/18/96
Participants: See List A

Table 1. PHA Table for Organic Storage Tanks USQ.

Process Step	Hazardous Condition	Cause(s)	Consequence	Engineered Safety Features	Administrative Features	Inventory	Conseq. Cat.	Freq. Cat.	Remarks
Storage	Fire	Deflagration Of Flammable Atmosphere (M2)	Airborne Radioc- tive Release Airborne Toxic Release	Passive Ventilation System Tank Design	QC To Make Sure That Passive Ventilation System Not Blocked Procedural Requirement To Open Vent Valve	Small Amount S1 That Might Be Made Airborne	F1		
Storage	Fire	Deflagration Of Flammable Atmosphere (Organic Vapor)	Airborne Radioc- tive Release Airborne Toxic Release	Passive Ventilation System Tank Design Temperature Expected To Be Below Organic Flashpoint Temperature		Small Amount S1 Of Material That Might Be Made Airborne	F1		
Storage	Fire				Administrative Controls Including Inspection For Leaks And Housekeeping To Keep Fire Load Down	Tank Contention	F2		
Storage	Fire	Burning Of Liquid Spill Due To Tank Leak And Sealing The Waste On Fire	Airborne Radioc- tive Release Airborne Toxic Release	Tank Design	Tank Will Be Thoroughly Washed, and Decontaminated Before Use To Store Organics	Fraction Of S2	F1		
Storage	Explosion	Nitrated Organic Reaction (Tank Formerly Used To Store Nitric Acid)	Same As Fire	Same As Fire					
Storage	Explosion	Other Causes (See Fire)	Same As Fire	See Fire Scenarios					

Table 2. PHA Checklist.

External Radioactive Contamination
Internal Radiation Dose
Criticality
Loss of Shielding
Loss of Liquid Containment
Ventilation
Fire
Explosion
Maintenance Problem
Impact
Loss of Utilities
Corrosion/Erosion
Extreme Weather
Seismic Event
Toxicity
Construction Hazard

4.0 HAZARDS ANALYSIS

4.1 BASIC APPROACH

The basic approach is to focus on the accidents that potentially produce the maximum consequences. Using the graded approach, little resources are spent initially on determining the frequency of the accidents, but rather they are assumed to be credible and the consequences are determined. If the consequences, even at a probability of one are acceptable, no further analysis is provided.

A review of the PHA table revealed that the most serious credible hazards with the potentially highest consequences were: a) a fire, b) a hydrogen explosion caused by an ignition source and the hydrogen exceeding 4 vol% in the headspace, and c) a spill of the liquid organic. B Plant personnel are planning to reduce the quantities of the ^{137}Cs and ^{90}Sr in the organic liquid as much as possible prior to transferring the liquid outside of the B Plant canyon area. The goal is to reduce the values of the radionuclides such that the liquid can be declared as Low Specific Activity (LSA).

To assist in determining to what minimum level the two radionuclides (^{137}Cs and ^{90}Sr) must be reduced, the concentrations were back-calculated (see Appendix A) to determine the allowable concentrations for an unmitigated (no berm) and mitigated (with berm) burning scenarios without exceeding the WHC onsite and offsite guidelines. These guidelines, from WHC-CM-4-46 (WHC 1996b), are summarized in Table 3. The 50 mSv (5 rem) onsite criterion was chosen for the goal of the project. This approach is conservative as plume

⁹⁰ Sr (Ci)	¹³⁷ Cs (Ci)	⁹⁰ Sr (Ci)	¹³⁷ Cs (Ci)	⁹⁰ Sr (Ci)	¹³⁷ Cs (Ci)
232.53	0	232.11	2.50	231.68	5.00
232.48	0.25	232.06	2.75	231.64	5.25
232.44	0.50	232.02	3.00	231.60	5.50
232.40	0.75	231.98	3.25	231.56	5.75
232.36	1.00	231.94	3.50	231.52	6.00
232.32	1.25	231.89	3.75	231.47	6.25
232.27	1.50	231.85	4.00	231.43	6.50
232.23	1.75	231.81	4.25	231.39	6.75
232.19	2.00	231.77	4.50	231.35	7.00
232.15	2.25	231.73	4.75		

Table 4. Maximum ⁹⁰Sr and ¹³⁷Cs Quantities (Ci) Prior to Placement of Tank Onto Concrete Pad (Berm Not In Place).

Event Frequency (Yr ⁻¹)	Toxic Chemical Concentration Limit		Radiological Dose Limit in mSv (rem)	
	Onsite	Offsite	Onsite	Offsite
>10 ⁻² to <10 ⁰	ERPG-1	PEL-TWA	50 (5)	5 (0.5)
>10 ⁻⁴ to <10 ⁻²	ERPG-2	ERPG-1	250 (25)	50 (5)
>10 ⁻⁶ to <10 ⁻⁴	ERPG-3	ERPG-2	1000 (100)	250 (25)

Table 3. WHC Risk Acceptance Guidelines.

rise that occurs as a result of a burning scenario was not initially considered for the radionuclide concentrations derived in Appendix A. This SA examines the potential accident scenarios to assure they do not exceed the ⁹⁰Sr and ¹³⁷Cs concentrations allowed with no credit taken for the 0.6 m (2 ft) berm and since the calculated burn time is less than 1-hr, credit for plume meander was not taken. Table 5 shows the allowable concentrations with the berm in place, and since the calculated burn time is greater than 1-hr, credit for plume meander was taken. Credit for plume rise (without plume meander) was not initially taken in either case.

Table 5. Maximum ^{90}Sr and ^{137}Cs Quantities (Ci) Prior To Placement of Tank Onto Concrete Pad (Berm In Place).

^{90}Sr (Ci)	^{137}Cs (Ci)	^{90}Sr (Ci)	^{137}Cs (Ci)	^{90}Sr (Ci)	^{137}Cs (Ci)
707.87	0	707.45	2.50	707.03	5.00
707.83	0.25	707.40	2.75	706.98	5.25
707.78	0.50	707.36	3.00	706.94	5.50
707.74	0.75	707.32	3.25	706.90	5.75
707.70	1.00	707.28	3.50	706.86	6.00
707.66	1.25	707.24	3.75	706.81	6.25
707.61	1.50	707.19	4.00	706.77	6.50
707.57	1.75	707.15	4.25	706.73	6.75
707.53	2.00	707.11	4.50	706.69	7.00
707.49	2.25	707.07	4.75		

4.2 LIQUID SPILL AND BURNING SCENARIO

One possible scenario involves an accident in which the tank is breached and the organic liquid is spilled and an ignition source is present, causing a radioactive release from the burning organic. Two burning scenarios are possible. One in which the liquid is contained within the berm surrounding the tank, while a second is one in which the berm is breached and the resultant burn area is increased. *B Plant Interim Safety Basis Accident Analysis* (WHC 1996c) analyzed a spill and burning of the organic liquid within B Plant. The same methodology is used in this SA to calculate the burn time as well as determining the airborne release fractions (ARFs) that release radioactive material in the respirable range. The accident scenario analyzed in the B Plant ISB and adopted for this SA include the following assumptions:

- The composition of the organic material in the tank is 70% NPH, 10% TBP, and 20% D2EHPA. The specific gravity of this material is 0.82. The organic is modeled by using the properties of kerosene.
- The length of exposure for either the onsite or offsite individual to the fire is limited to 8 hours and 24 hours.
- The cesium and strontium in the burning organic are converted to particulate oxides. Cesium is semivolatile with an airborne release fraction (ARF) of 1%. According to the *Nuclear Fuel Cycle Facility Accident Analysis Handbook*, NUREG 1320, strontium is nonvolatile with an ARF of 0.77% (Ayer et al. 1988).

The surface area for a spill with the berm intact is 46.6 m² and with 15,140 L (4,000 gal) of organic liquid, the depth of the spilled organic from the tank is 0.32 m (1 ft). The fuel burn rate is equal to the mass loss rate of fuel, $\dot{M}_b$. This is calculated by the following equations (Ayer et al. 1988). The values for the heat fluxes, the heat of vaporization, and radiative heat loss in the following equation are obtained from Ayer et al. (1988).

$$\begin{aligned}
 \dot{M}_b &= \frac{(\dot{q}_e'' + \dot{q}_{fc}'' + \dot{q}_{fr}'' - \dot{q}_{rr}'') \text{ area}}{L} \\
 &= \frac{\left(0 \frac{\text{kW}}{\text{m}^2} + 11 \frac{\text{kW}}{\text{m}^2} + 14 \frac{\text{kW}}{\text{m}^2} - 8 \frac{\text{kW}}{\text{m}^2} \right) (46.6 \text{ m}^2)}{1.5 \frac{\text{kJ}}{\text{g}} \left(\frac{1\text{W-s}}{\text{J}} \right)} \\
 &= 528 \frac{\text{g}}{\text{s}}.
 \end{aligned}$$

where

$\dot{q}_e''$ = external heat flux per unit surface area, $\frac{\text{kW}}{\text{m}^2}$

$\dot{q}_{fc}''$ = flame convective heat flux, $\frac{\text{kW}}{\text{m}^2}$

$\dot{q}_{fr}''$ = flame radiative heat flux, $\frac{\text{kW}}{\text{m}^2}$

$\dot{q}_{rr}''$ = surface radiative heat loss, $\frac{\text{kW}}{\text{m}^2}$

A = burning surface of fuel, m^2

L = heat required to generate a unit mass of fuel vapors, (i.e., the latent heat of vaporization) $\frac{\text{kJ}}{\text{g}}$.

The duration of the burn, which is assumed not extinguished, is found by:

$$\text{burn time} = \frac{\text{volume} \times \text{density}}{\text{burn rate}} = \frac{15,140 \text{ L} \left(820 \frac{\text{g}}{\text{L}} \right)}{\left(528 \frac{\text{g}}{\text{sec}} \right) \left(3,600 \frac{\text{sec}}{\text{hour}} \right)} = 6.5 \text{ hour}.$$

Without the berm, the spill area is considerably larger. To estimate the spill area without a berm, the values cited in *A Simple Formula For Estimating Source Strengths From Spills of Toxic Liquids* (Clewel 1983) is used. Clewel cites the value of a spill onto concrete or non-porous surfaces as being approximately 1.2 m^2/L of spilled liquid. For spills onto gravel or other porous surfaces, a value of 0.15 m^2/L is cited. The value of 0.15 m^2/L is used, as this is more representative of the spill surface area beyond the pad area. The exact quantity of organic liquid to be stored in the external tank is not known, but could range from 9,460 L (2,500 gal) up to 15,140 L (4,000 gal).

With the conservative 15,140 L (4,000 gal) of spilled organic liquid, the spill area becomes approximately 2,270 m^2 . With a spill area of 2,270 m^2 , the depth of the organic is initially approximately 0.67 cm (1/4 in.) and the organic liquid will rapidly soak into the soil. Using the same equation above, the estimated burn time without the berm and 15,140 L (4,000 gal) of organic becomes:

With the less conservative 9,460 L (2,500 gal) of spilled organic liquid, the spill area becomes approximately 1,420 m^2 . Using the same

$$\begin{aligned}\dot{M}_b &= \frac{(\dot{q}_e'' + \dot{q}_{fc}'' + \dot{q}_{fr}'' - \dot{q}_{rr}'') \text{ area}}{L} \\ &= \frac{\left[0 \frac{\text{kW}}{\text{m}^2} + 11 \frac{\text{kW}}{\text{m}^2} + 14 \frac{\text{kW}}{\text{m}^2} - 8 \frac{\text{kW}}{\text{m}^2} \right] (2270 \text{ m}^2)}{1.5 \frac{\text{kJ}}{\text{g}} \left(\frac{1\text{W-s}}{\text{J}} \right)} \\ &= 25,700 \frac{\text{g}}{\text{s}}\end{aligned}$$

$$\text{burn time} = \frac{\text{volume} \times \text{density}}{\text{burn rate}} = \frac{15,140 \text{ L} \left(820 \frac{\text{g}}{\text{L}} \right)}{\left(25,700 \frac{\text{g}}{\text{sec}} \right) \left(3,600 \frac{\text{sec}}{\text{hour}} \right)} = .13 \text{ hr.}$$

equation above, the estimated burn time without the berm and 9,460 L (2,500 gal) of organic becomes:

$$\begin{aligned}\dot{M}_b &= \frac{(\dot{q}_e'' + \dot{q}_{fc}'' + \dot{q}_{fr}'' - \dot{q}_{rr}'') \text{ area}}{L} \\ &= \frac{\left[0 \frac{\text{kW}}{\text{m}^2} + 11 \frac{\text{kW}}{\text{m}^2} + 14 \frac{\text{kW}}{\text{m}^2} - 8 \frac{\text{kW}}{\text{m}^2} \right] (1420 \text{ m}^2)}{1.5 \frac{\text{kJ}}{\text{g}} \left(\frac{1\text{W-s}}{\text{J}} \right)} \\ &= 16,100 \frac{\text{g}}{\text{s}}\end{aligned}$$

$$\text{burn time} = \frac{\text{volume} \times \text{density}}{\text{burn rate}} = \frac{9,460 \text{ L} \left(820 \frac{\text{g}}{\text{L}} \right)}{\left(16,100 \frac{\text{g}}{\text{sec}} \right) \left(3,600 \frac{\text{sec}}{\text{hour}} \right)} = .13 \text{ hr.}$$

As can be seen, the burn times for the unmitigated spills involving either 15,140 L (4,000 gal) or 9,460 L (2,500 gal) are the same (~8 min).

4.3 HYDROGEN GENERATION WITHIN THE TANK

As the actual quantity of organic liquid finally transferred to the external tank is not exactly known, various quantities of organic liquid are assumed in order to estimate the hydrogen generation values. A minimum value of 9,460 L (2,500 gal) liquid organic is initially assumed (which allows a maximum headspace), and step-increases are then used to determine the time to generate 4 and 10 vol% of hydrogen in the headspace of the tank. No credit for the specially designed vent system is taken.

Hydrogen is generated via the radiolysis of water and hydrocarbons. Table 6 provides values for the determination of hydrogen generation rates for ^{137}Cs and ^{90}Sr .

$$H_2 \text{ Generation Rate} = (Ci)(E)[G(H_2)]/A$$

Where:

- A = Avagadro's number, molecules/mole
- Ci = Curies in the Liquid
- E = Total energy of the disintegrations, eV/s-Ci
- $G(H_2)$ = Molecules H_2 /100eV

$$\text{Generation Rate} = \text{g-moles/s}$$

Table 6. Hydrogen Generation Data.

Hydrogen Generation Data		Reference
$G(H_2)$ /Water	0.45 molecules/100 electron volt	RHO-WM-EV-9, REV 1P (RHO 1986)
$G(H_2)$ /Hydrocarbons	5 molecules/100 electron volt	RHO-WM-EV-9, REV 1P (RHO 1986)
^{137}Cs (includes daughters)	3.06 E+10 MeV/s/Ci	Chart of Nuclides (GE 1989)
^{90}Sr (includes daughters)	4.03 E+10 MeV/s/Ci	Chart of Nuclides (GE 1989)

If there is no ventilation, the steady state value is 100%. The time to reach a value or limit is:

$$t = -\frac{V}{Q} \ln \left(1 - \frac{LFL\%}{V_{ss}\%} \right)$$

Where

V = headspace volume

Q = total gas flow

$V_{ss}\%$ = steady state volume%

Since ^{90}Sr has the higher hydrogen generation rate per Ci than ^{137}Cs , it is assumed that there are 708 Ci of ^{90}Sr (note that the decay heat is used twice for conservancy). The hydrogen generation for this quantity is:

$$G_{H_2} = \frac{708 \text{ Ci} * 4.03 \times 10^{16} \text{ eV/s/Ci} * 5.45 \text{ molecules/100 eV}}{6.02 \times 10^{23} \text{ molecules/gmole}} = 2.6 \times 10^{-6} \text{ gmole/s}$$

With the assumption that the temperature is 100°F in the tank vapor space, the volume rate of production is $2.6 \times 10^{-6} \times (560/492) \times 22.4 = 6.63 \times 10^{-5}$ L/s (5.73 L/day). The tank volume is 17,500 L (4,623 gal). With 9,460 L (2,500 gal) of organic liquid in the tank, the headspace volume is 8,040 L (2,124 gal). The time to steady state for 4% hydrogen assuming no ventilation is:

$$t = -8,040 \frac{L}{5.73 L/d} * \ln \left(1 - \frac{4}{100} \right) = 57 \text{ days}$$

For 10% hydrogen

$$t = -8,040 \frac{L}{5.73 L/d} * \ln \left(1 - \frac{10}{100} \right) = 148 \text{ days}$$

For a headspace volume of 1700L (full tank), and 708 Ci ^{90}Sr in the liquid, the time to reach 4% hydrogen with no ventilation is 12 days.

The headspace (vapor) volume can also be varied and the time to reach a hydrogen concentration value are shown below assuming no ventilation and 708 Ci of ^{90}Sr .

5.0 CONSEQUENCE OF ACCIDENTS

5.1 CONSEQUENCE ANALYSIS METHODOLOGY

The consequence analysis combines the results of the source term, atmospheric dispersion, and ICRP reference man dose models to estimate consequences to onsite and offsite individuals. For onsite calculations, 100 m (328 ft) is used as the distance to the onsite receptor. For each of

sixteen directions, a 99.5% X/Q (meaning that the X/Q is exceeded only 0.5% of the time) is calculated along with a 95% site-wide X/Q (which considers all directions at the same time). The greatest of the seventeen values is selected as the onsite X/Q. The onsite X/Qs are from *B Plant Interim Safety Basis Accident Analysis* (WHC 1996c).

For offsite calculations, the Hanford Site Boundary (i.e., fence line) is used as the location of the offsite receptor. The distances from B Plant to the Hanford Site Boundary are shown in Table 7. The 95.5% X/Q values are compared for each of the sixteen directions with the greatest value selected as the offsite X/Q. The assumptions and calculations document, *Supporting Calculations and Assumptions for Use in WESF ISB* (Hey 1996) discusses a case where offsite receptor distances correspond to the near side of the Columbia River (as opposed to the current Hanford Site boundary) for that stretch of the river which passes through the Hanford Site. Potential consequences to a receptor at this nearer boundary are also considered for each of the accidents evaluated. The offsite X/Qs, that were performed for WESF located immediately west of B Plant, are valid for B Plant.

Table 7. Site Boundary Distances Used in Offsite Dispersion Calculations.

Transport Direction	Fence-line Distance (km)	Hwy-240, Mye Barricade, and Near River Bank (km)
S	19.31	8.94
SSW	16.64	8.26
SW	18.08	8.26
WSW	19.29	9.71
W	18.89	11.04
WNW	19.39	14.36
NW	19.81	11.49
NNW	19.55	11.33
N	22.78	12.99
NNE	25.45	14.01
NE	19.88	12.27
ENE	17.04	12.14
E	16.87	13.65
ESE	21.04	20.88
SE	25.17	14.19
SSE	21.08	11.71

The radiological doses are determined using the relationship:

$$\text{Dose} = C_i \times X/Q \times BR \times DCF$$

where

C_i = total curies released as respirable
 X/Q = atmospheric dispersion coefficient, sec/m^3
 BR = breathing rate, m^3/sec ($3.3 \text{ E-}04 \text{ m}^3/\text{s}$)

DCF = dose conversion factor, rem/Ci
 = 3.19 E+04 rem/Ci for ^{137}Cs
 = 2.47 E+05 rem/Ci for ^{90}Sr (includes the daughter, ^{90}Y)

The toxic concentrations are determined using the relationship:

$$\text{Conc. (mg/m}^3\text{)} = \text{release rate (mg/s)} \times X/Q \text{ (s/m}^3\text{)}$$

Table 8 shows the onsite and offsite X/Q values which are representative of the dispersion between the B Plant release point and the receptor locations under various release conditions. The particular X/Q value used in an accident analysis is determined based on the physical phenomena associated with the accident. For radiological releases (not involving a burning scenario) lasting 1-hr or longer, credit for plume meander is taken, while for releases less than 1-hr, no credit is taken. For radiological releases from a burning scenario, credit for plume rise is taken. For toxicological releases, credit for plume meander is not taken regardless of release time, but credit for plume rise is taken for burning scenarios. For spills and subsequent burning outside the berm area, two sets of X/Qs are provided. One case is if only 9,460 L (2,500 gal) is in the tank and spilled, while the other case is if 15,140 L (4,000 gal) is spilled. For burning scenarios, taking credit for plume rise, onsite receptor locations beyond 100 m (328 ft) were tested, and the 100 m (328 ft) location was determined to provide the maximum X/Q. The X/Qs taking credit for plume rise are from *Atmospheric Dispersion Parameters for B Plant Organic Liquid Storage Fire Scenarios* (Himes 1996).

Table 8. Atmospheric Dispersion Coefficients (X/Qs) Used in the Accident Analysis.

Source/Receptor Description	On-Site 100 m X/Q (s/m ³)	Fence-Line X/Q (s/m ³)	Hwy-240, Wye Barricade, and Near River Bank X/Q (s/m ³)
Ground level release, point source	3.44 E-02	1.35 E-05	1.90 E-05
Ground level release with plume meander	1.12 E-02	1.13 E-05	1.52 E-05
Burning release with berm and plume rise	5.49 E-05	1.54 E-06	1.67 E-06
Burning release with no berm and plume rise (9,460 L organic)	4.51 E-06	1.50 E-07	2.55 E-07
Burning release with no berm and plume rise (15,140 L organic)	3.03 E-06	1.50 E-07	2.55 E-07

5.2 ORGANIC SPILL AND FIRE (RADIOLOGICAL CONSEQUENCES)

Tables 4 and 5 provide the results for bounding values for ^{137}Cs and ^{90}Sr combinations, using Mathcad computer software version 5.0. From the calculations, which are based upon not exceeding 50 mSv (5 rem) EDE onsite, calculations were performed to show the concentration limits of ^{137}Cs and ^{90}Sr combinations that would not exceed a 5 rem onsite dose from a spill and

ignition of the organic liquid. The calculations of Table 4 and 5 as derived in Appendix A were used to determine the maximum ^{90}Sr and ^{137}Cs concentrations allowed without credit for plume rise for burning scenarios. However, since plume rise does occur with the burning of the organic liquid, credit may be taken. In the case of no berm in place, since the onsite X/Q is greater for 9,460 L (2,500 gal) of organic liquid than 15,140 L (4,000 gal) of total liquid (Table 8), it is assumed that 9,460 L (2,500 gal) is at risk and burns. The higher radionuclide concentrations (Table 5) are evaluated, as will be done for all radiological releases, to determine if these higher concentrations may actually be acceptable.

The onsite receptor X/Q at 100 m (328 ft), in the direction providing the highest X/Q and taking credit for plume rise with the berm in place, is $5.49 \times 10^{-5} \text{ s/m}^3$. Without the berm, the burn area is considerably larger and the onsite X/Q is $4.51 \times 10^{-6} \text{ s/m}^3$. The X/Q for the offsite receptor located at the site boundary (fence-line) with the berm in place is $1.54 \times 10^{-6} \text{ s/m}^3$, taking credit for plume rise, and $1.50 \times 10^{-7} \text{ s/m}^3$ without the berm. Table 5 provides the higher ^{90}Sr and ^{137}Cs combinations and since all combinations are equivalent from a burning scenario dose consequence, the combination of 707.87 Ci of ^{90}Sr and 3.0 Ci of ^{137}Cs is arbitrarily chosen to calculate the onsite and offsite consequences. The ARF for the ^{90}Sr is 0.0077 and that for ^{137}Cs is 0.01. Therefore, 5.45 Ci of ^{90}Sr and 0.03 Ci of ^{137}Cs are released as respirable. For the mitigated case (berm in place), the onsite and offsite doses are calculated using the relationship:

$$\text{Dose} = \text{Ci} \times \text{X/Q} \times \text{BR} \times \text{DCF}$$

$$^{137}\text{Cs onsite} = (.03 \text{ Ci})(5.49 \text{ E-}05 \text{ s/m}^3)(3.3 \text{ E-}04 \text{ m}^3/\text{s})(3.19 \text{ E+}04 \text{ rem/Ci}) = \\ 1.73 \text{ E-}04 \text{ mSv } (1.73 \text{ E-}05 \text{ rem})$$

$$^{90}\text{Sr onsite} = (5.45 \text{ Ci})(5.49 \text{ E-}05 \text{ s/m}^3)(3.3 \text{ E-}04 \text{ m}^3/\text{s})(2.47 \text{ E+}05 \text{ rem/Ci}) = \\ 2.44 \text{ E-}01 \text{ mSv } (2.44 \text{ E-}02 \text{ rem})$$

$$^{137}\text{Cs offsite} = (.03 \text{ Ci})(1.54 \text{ E-}06 \text{ s/m}^3)(3.3 \text{ E-}04 \text{ m}^3/\text{s})(3.19 \text{ E+}04 \text{ rem/Ci}) = \\ 4.86 \text{ E-}06 \text{ mSv } (4.86 \text{ E-}07 \text{ rem})$$

$$^{90}\text{Sr offsite} = (5.45 \text{ Ci})(1.54 \text{ E-}06 \text{ s/m}^3)(3.3 \text{ E-}04 \text{ m}^3/\text{s})(2.47 \text{ E+}05 \text{ rem/Ci}) = \\ 6.84 \text{ E-}03 \text{ mSv } (6.84 \text{ E-}04 \text{ rem})$$

In a similar manner, the onsite and offsite consequences are calculated for the unmitigated case (no berm) and the consequences for both cases are summarized in Table 9. As shown in the above calculations, the "mitigated" (with berm) consequences are actually higher than the "unmitigated" (no berm) consequences, which is due to the additional lofting of the plume due to a longer burn time and resultant larger heat generation rate.

Table 9. Predicted Radiological Consequences For Organic Fire.

Receptor	X/Q (sec/m ³)	EDE mSv (rem)	RAG EDE mSv (rem)
Unmitigated (No Berm)			
Onsite	4.51 E-06	2.0 E-02 (2.0 E-03)	50 (5)
Offsite	1.50 E-07	6.7 E-04 (6.7 E-05)	5 (0.5)
Mitigated (With Berm)			
Onsite	5.49 E-05	2.4 E-01 (2.4 E-02)	50 (5)
Offsite	1.54 E-06	6.8 E-03 (6.8 E-04)	5 (0.5)

RAG = risk acceptance guideline for $>10^{-2}$ to $\leq 10^0$.

By comparison, the maximum dose at the alternate site boundary described in Section 5.1, which considers Highway 240 and the near side of the river, is 1.1×10^{-3} mSv (1.1×10^{-4} rem) for the unmitigated case, and 7.4×10^{-3} mSv (7.4×10^{-4} rem) for the mitigated case.

5.3 ORGANIC SPILL AND FIRE (TOXICOLOGICAL CONSEQUENCES)

The combustion of organic liquid could produce a smoke plume that contains noxious gases and aerosols. These noxious substances could pose an inhalation hazard to personnel in the path of the plume. In addition to soot particles and gaseous products of incomplete burning of hydrocarbon fuels, the combustion of TBP would produce oxides of phosphorous. The toxicological consequences of solvent fires are evaluated on the basis of predicted concentrations of P_2O_5 , and CO.

5.3.1 Phosphorous Pentoxide

Phosphorous pentoxide is produced by the reaction of TBP and D2EHPA. The TBP and D2EHPA burn are assumed to burn in the following reactions based on incomplete combustion, which results in 15% of the carbon remaining as carbon monoxide.

Based on these equations, the P_2O_5 to TBP mass ratio is 0.27 and 0.22 for D2EHPA. For a burn rate of 528 g/sec (with the berm in place) of which 10% is TBP and 20% is D2EHPA by mass, the rate of P_2O_5 formation is 37.62 g/sec

$$\begin{aligned}
 \text{P}_2\text{O}_5 \text{ mass rate} &= 528 \frac{\text{g}}{\text{sec}} [(10\%)(0.27) + (20\%)(0.22)] \\
 &= 37.62 \frac{\text{g}}{\text{sec.}}
 \end{aligned}$$

For a burn rate of 25,700 g/sec (without the berm and 15,140 L [4,000 gal] of organic) of which 10% is TBP and 20% is D2EHPA by mass, the rate of P_2O_5 formation is 1,825 g/sec

$$\begin{aligned}
 \text{P}_2\text{O}_5 \text{ mass rate} &= 25,700 \frac{\text{g}}{\text{sec}} [(10\%)(0.27) + (20\%)(0.22)] \\
 &= 1825 \frac{\text{g}}{\text{sec.}}
 \end{aligned}$$

The mitigated (credit for berm and plume rise) onsite and offsite (site boundary) concentrations of P_2O_5 , calculated using atmospheric dispersion factors for 100 m (328 ft) and the site boundary, are listed in Table 10. The ERPG-1, ERPG-2 and ERPG-3 values are 5 mg/m³, 25 mg/m³, and 100 mg/m³. The PEL-TWA is 1 mg/m³. The unmitigated onsite concentrations, taking credit for only plume rise, is 5.5 mg/m³ and above the ERPG-1 value of 5 mg/m³. However, this peak concentration lasts for only 8 minutes, the length of the burn, and WHC-CM-4-46 allows the peak 15-min average concentration to be used. The time-weighted average over a 15-min period becomes $8/15 \times 5.5 \text{ mg/m}^3 = 2.9 \text{ mg/m}^3$. The resulting onsite and offsite concentrations are shown in Table 10 and all are within the guidelines.

Table 10. Predicted Concentrations of Phosphorous Pentoxide in Organic Fire Plume.

Receptor	X/Q (sec/m ³)	P ₂ O ₅ Plume Conc. (mg/m ³)	RAG mg/m ³
Unmitigated (No Berm)			
Onsite	3.03 E-06	2.9	5
Offsite	1.50 E-07	0.15	1
Mitigated (With Berm)			
Onsite	5.49 E-05	2.1	5
Offsite	1.54 E-06	0.06	1

RAG = risk acceptance guideline for $>10^{-2}$ to $\leq 10^0$.

By comparison, the maximum concentration at the alternate site boundary described in Section 5.1, which considers Highway 240 and the near side of the river, is 0.25 mg/m³ for the unmitigated case, and 0.06 mg/m³ for the mitigated case.

Similar calculations as above but using 9,460 L (2,500 gal) of organic liquid spilled over a 1,420 m² area results in a P_2O_5 release rate of 1,140 g/s and the resulting concentrations are slightly less than those shown in Table 10.

5.3.2 Carbon Monoxide

The mass of CO formed is estimated on the basis of an emission factor for highly inefficient combustion. For example, the highest emission factor for CO cited in *Pollution Control Technology* (Fogiel 1973) is 0.0425 kg for open burning of municipal refuse. Using the previous equations, the calculated CO to TBP mass ratio is 0.21 and 0.174 for D2EHPA. For the organic burn rate of 528 g/sec (mitigated, with berm), of which is 10% TBP and 20% D2EHPA by mass, the rate of CO formation is 29.4 g/sec.

$$\text{CO mass rate} = 528 \frac{\text{g}}{\text{sec}} [(10\%)(0.21) + (20\%)(0.174)] = 29.4 \frac{\text{g}}{\text{sec.}}$$

For the organic burn rate of 25,700 g/sec (unmitigated, with no berm), of which is 10% TBP and 20% D2EHPA by mass, the rate of CO formation is 1,434 g/sec.

$$\text{CO mass rate} = 25,700 \frac{\text{g}}{\text{sec}} [(10\%)(0.21) + (20\%)(0.174)] = 1434 \frac{\text{g}}{\text{sec.}}$$

Unmitigated (no berm) and mitigated (with berm) onsite and offsite concentrations of carbon monoxide, calculated using atmospheric dispersion factors for 100 m (328 ft) and the site boundary are listed in Table 11. The *Registry of Toxic Effects of Chemical Substances* recommends an exposure limit for carbon monoxide of 40 mg/m³ (NIOSH 1991). WHC has not established a set of EPRG limits for carbon monoxide. The recommended exposure limit is a time-weighted average for a 10-hr work day during a 40-hr work week. The unmitigated and mitigated concentrations are within the guidelines.

Table 11. Predicted Concentrations for Carbon Monoxide in Organic Fire Plume.

Receptor	X/Q (sec/m ³)	CO plume concentration (mg/m ³)	Recommend exposure limit* (mg/m ³)
Unmitigated (No Berm)			
Onsite	3.03 E-06	2.32	40
Offsite	1.50 E-07	0.12	40
Mitigated (With Berm)			
Onsite	5.49 E-05	1.62	40
Offsite	1.54 E-06	0.04	40

*NIOSH 1991.

By comparison, the maximum concentration at the alternate site boundary described in Section 5.1, which considers Highway 240 and the near side of the river, is 0.2 mg/m³ for the unmitigated case, and 0.04 mg/m³ for the mitigated case.

5.4 HYDROGEN EXPLOSION IN THE TANK HEADSPACE

A hydrogen concentration of 10 vol% is assumed at which a hydrogen deflagration occurs. To determine the heat of combustion (BTU), assuming 11,280 BTU/m³ (319.4 BTU/ft³) (Marks' Handbook) at standard temperature and pressure (STP), requires a value for the hydrogen in the headspace to be determined. With 9,460 L (2,500 gal) of liquid, the headspace volume is 17,500 L - 9,460 L = 8,040 L (4,623 gal - 2,500 gal = 2,124 gal). With 10 vol%, there are 804 L (0.804 m³) of hydrogen. 804 L (0.804 m³) of hydrogen equates to 2.3×10^6 cal for the heat of combustion for the hydrogen. To calculate the grams of TNT equivalent, the heat of combustion for TNT of 4.773 Mjoule/kg (Thompson 1987) is used. This equates to 1,140 cal/g. A value of 2.3×10^6 cal equates to 2,018 g of TNT. To determine the amount of organic liquid released as respirable, the Steindler-Seefeldt correlation (Steindler & Seefeldt 1980) is used. The Steindler-Seefeldt correlation developed a mass ratio (MR) with the MR being defined as the ratio of the mass of solid or liquid material at risk (MAR), to the mass of the TNT equivalent of the explosive. The configuration of the explosive material and the MAR examined by Steindler-Seefeldt was typically spherical or cylindrical with a height to diameter ratio of near one. The explosive was usually placed at the center with the material to be dispersed placed in the annular space surrounding. The experiments actually considered were only up to MRs of 15, although extrapolations are provided in the form of plots up to a MR of 400. From the MRs provided, the amount of material made airborne 10 micron or smaller is provided. For this scenario, it is assumed the quantity of organic liquid is the lowest anticipated, or 9,460 L (2,500 gal). At 820 g/L, the total mass of the liquid is 7.8×10^6 g. The MR in this case becomes $7.8 \times 10^6 \text{ g} \div 2,018 = 3,865$. Since the actual experimental work only went up to a MR of 15, the more conservative value of 15 is used for the MR. Based upon the Steindler-Seefeldt correlation, for a MR of 15, ~0.07 g of material/g of TNT equivalent, is released at 20 microns or less. The use of 20 microns is chosen to allow evaporation of the liquid particles down to 10 micron while enroute to the receptors. If the equivalent of 2,018 g of TNT is released from the hydrogen detonation, 141 g of organic liquid would be released that is respirable. However, Thompson (1987) states that the "TNT-equivalent" for a unconfined flammable gas-air detonation seldom exceeds 10% of theoretical and recommends 10% be used for safety assessment purposes. Therefore, 202 g of TNT is assumed as the deflagration energy. With a MR of 0.07, 14.1 g of liquid is released as respirable. Since the ⁹⁰Sr has a higher DCF than ¹³⁷Cs, the bounding case of 707.87 Ci of ⁹⁰Sr from Table 5 is assumed to be contained in the 9,460 L (7.8×10^6 g). Therefore, $14.1 \text{ g} \div 7.8 \times 10^6 \text{ g} \times 707.8 \text{ Ci} = 0.00128 \text{ Ci}$ of ⁹⁰Sr is released as respirable. The resultant ARF is 1.8×10^{-6} . This compares closely with the 1.1×10^{-6} ARF recommended from DOE-HDBK-3010-94 (Section 3.2.2.2) for blast effects for a deflagration of a flammable vapor mixture over aqueous liquids. Using the relationship of:

$$\text{Dose} = (\text{Ci}) \times (\text{X/Q}) \times (\text{BR}) \times (\text{DCF})$$

and taking no credit for plume meander as this is a "puff" release, the consequences are:

$$\begin{aligned} {}^{90}\text{Sr onsite} &= (.00128 \text{ Ci})(3.44 \text{ E-02 s/m}^3)(3.3 \text{ E-04 m}^3/\text{s})(2.47 \text{ E+05 rem/Ci}) = \\ &3.59 \text{ E-02 mSv (3.59 E-03 rem)} \end{aligned}$$

$$^{90}\text{Sr offsite} = (.00128 \text{ Ci})(1.35 \text{ E-}05 \text{ s/m}^3)(3.3 \text{ E-}04 \text{ m}^3/\text{s})(2.47 \text{ E+}05 \text{ rem/Ci}) = 1.41 \text{ E-}05 \text{ mSv } (1.41 \text{ E-}06 \text{ rem})$$

By comparison, the maximum dose at the alternate site boundary described in Section 5.1, which considers Highway 240 and the near side of the river, is 1.98×10^{-5} mSv (1.98×10^{-6} rem).

It is highly likely that if a hydrogen explosion occurred, the organic liquid not immediately released would also burn, and the combined consequences for both the mitigated case (berm remains in place) and unmitigated case (berm not in place) from Table 9 are shown in Table 12. The combined consequences considers the explosion as a ground release while the burning of the organic takes credit for plume rise.

Table 12. Predicted Radiological Consequences For H_2 Explosion And Organic Fire.

Receptor	EDE mSv (rem)	RAG EDE mSv (rem)
Unmitigated (No Berm)		
Onsite	6.0 E-02 (6.0 E-03)	50 (5)
Offsite	6.8 E-04 (6.8 E-05)	5 (0.5)
Mitigated (With Berm)		
Onsite	2.8 E-01 (2.8 E-02)	50 (5)
Offsite	6.8 E-03 (6.8 E-04)	5 (0.5)

RAG = risk acceptance guideline for $>10^{-2}$ to $\leq 10^0$.

By comparison, the maximum consequences at the alternate site boundary described in Section 5.1, which considers Highway 240 and the near side of the river, is 1.1×10^{-3} mSv (1.1×10^{-4} rem) for the unmitigated case, and 7.4×10^{-3} mSv (7.4×10^{-4} rem) for the mitigated case.

5.5 SPILL OF ORGANIC FROM EXTERNAL TANK (RADIOLOGICAL CONSEQUENCES)

This scenario examines the consequences from a spill of organic liquid from the tank and the resuspension of radionuclides in the liquid due to wind entrainment. The tank is assumed to contain its higher concentrations from Table 5. Since ^{90}Sr has the higher DCF, it is assumed that 707.87 Ci of ^{90}Sr is present. DOE-HDBK-3010 (DOE 1994) provides recommended bounding suspension rates based upon experimental test conditions for aerodynamic entrainment and resuspension. For outdoors at low wind speeds, a bounding airborne release rate (ARR) of 4.0×10^{-7} /hr is provided, while for wind speeds at 13.4 m/s (30 mph), a bounding ARR of 4.0×10^{-6} /hr is provided. Although the dispersion factors are higher for the lower wind velocities, the 4.0×10^{-6} /hr value is conservatively used. With 707.87 Ci of ^{90}Sr contained within the organic liquid, in 8-hr the release made airborne is $707.87 \text{ Ci} \times 4.0 \times 10^{-6}/\text{hr} \times 8\text{-hr} = 2.27 \times 10^{-2}$ Ci of ^{90}Sr released to the onsite receptor. For the offsite

receptor who is assumed to remain in the plume for 24-hr, the release is 6.81-02 Ci of ^{90}Sr . Since the release last longer than 1-hr, credit for plume meander may be taken and the doses are:

$$^{90}\text{Sr} \text{ onsite} = (0.0227 \text{ Ci})(1.12 \text{ E-02 s/m}^3)(3.3 \text{ E-04 m}^3/\text{s})(2.47 \text{ E+05 rem/Ci}) = 2.07 \text{ E-01 mSv (2.07 E-02 rem)}$$

$$^{90}\text{Sr} \text{ offsite} = (0.0681 \text{ Ci})(1.13 \text{ E-05 s/m}^3)(3.3 \text{ E-04 m}^3/\text{s})(2.47 \text{ E+05 rem/Ci}) = 6.27 \text{ E-04 mSv (6.27 E-05 rem)}$$

By comparison, the maximum dose at the alternate site boundary described in Section 5.1, which considers Highway 240 and the near side of the river, is 8.44×10^{-4} mSv (8.44×10^{-5} rem).

5.6 SPILL OF ORGANIC FROM EXTERNAL TANK (TOXICOLOGICAL CONSEQUENCES)

This is a similar scenario, but the toxic consequences due to the TBP is examined. The organic liquid contains approximately 10% TBP, which is considered a toxic chemical. The emergency response planning guidelines (ERPGs) for TBP are: ERPG-1 = 3 mg/m³, ERPG-2 = 15 mg/m³, and ERPG-3 = 50 mg/m³. The PEL-TWA value is 2.5 mg/m³. With an airborne release rate (ARR) of 4.0×10^{-6} hr (1.1×10^{-9} s) the equivalent of 15,140 L x 820 g/L x 1.1×10^{-9} s = 1.37×10^{-2} g/s (13.7 mg/s) of organic liquid is released. The density of TBP is 0.98 g/cm³ while the organic liquid has a density of 0.82 g/cm³. With approximately 10% by volume of the organic liquid being TBP, on a weight percentage, the TBP represents about $10\% \times .98/.82 = 12\%$ of the organic liquid. Therefore the release rate of the TBP is approximately $12\% \times 13.7$ mg/s = 1.6 mg/s. With an onsite dispersion factor of 3.44×10^{-2} s/m³ (not taking credit for plume meander for toxic releases), the onsite concentration is 0.055 mg/m³. The offsite consequences are approximately 1000 times less. Both onsite and offsite consequences are well below the risk acceptance guidelines.

6.0 CONTROLS

All accidents analyzed, even at the higher radionuclide concentrations of Table 5, result in all onsite and offsite consequences well below the risk acceptance guidelines, even at a probability of 1 for each event. Furthermore, there is no requirement for any safety-class or safety-significant structure, system, or component (SSC).

6.1 RADIOACTIVE INVENTORIES

Since no credit is taken for the administrative or engineered barriers in the above calculations, the only Control required for storage of the organic liquid is to ensure the radionuclide concentrations are below the 5 rem calculations in Appendix A and shown in Table 5 prior to placing the tank onto the concrete pad. The allowable ^{90}Sr and ^{137}Cs concentrations still provide a large margin of safety, and are reproduced as Table 13.

Table 13. Maximum ^{90}Sr and ^{137}Cs Quantities (Ci) Prior To Placement of Tank Onto Concrete Pad.

^{90}Sr (Ci)	^{137}Cs (Ci)	^{90}Sr (Ci)	^{137}Cs (Ci)	^{90}Sr (Ci)	^{137}Cs (Ci)
707.87	0	707.45	2.50	707..03	5.00
707.83	0.25	707.40	2.75	706.98	5.25
707.78	0.50	707.36	3.00	706.94	5.50
707.74	0.75	707.32	3.25	706.90	5.75
707.70	1.00	707.28	3.50	706.86	6.00
707.66	1.25	707.24	3.75	706.81	6.25
707.61	1.50	707.19	4.00	706.77	6.50
707.57	1.75	707.15	4.25	706.73	6.75
707.53	2.00	707.11	4.50	706.69	7.00
707.49	2.25	707.07	4.75		

6.2 TRANSFER FROM PRIMARY TO SPARE TANK

Transfer of the organic liquid from the primary tank to the spare tank, as well as transfer back to the primary tank, is permitted provided the pump pressure does not exceed 0.70 MPa (100 psi) and the same type of flexible hose is used as for the transfer from B Plant to the external tank located on the flat-bed truck, as analyzed in the *Safety Assessment For Removal Of Organic Liquids From B Plant* (WHC 1996a).

7.0 REFERENCES

- Clewell, 1983, *A Simple Formula For Estimating Source Strengths From Spills Of Toxic Liquids*, ESL-TR-83-03, Engineering & Services Laboratory, Air Force Engineering & Services Center, Tyndall Air Force Base, Florida.
- Crippen, M. D., 1993, *Barometric Pressure Variations*, WHC-EP-0651, Westinghouse Hanford Company, Richland, Washington.
- DOE, 1994, *Airborne Release Fractions/Rates and Respirable Fractions For Nonreactor Nuclear Facilities*, DOE-HDBK-3010-94, U.S. Department of Energy, Washington, D.C.
- EPA, 1988, *Limiting Values of Radionuclide Intake And Air Concentration and Dose Conversion Factors For Inhalation, Submersion, And Ingestion*, EPA-520/1-88-020, U.S. Environmental Protection Agency, Washington, D.C.
- Fogiel, M., Ed., 1973, *Pollution Control Technology*, Research and Education Association, New York, New York.
- GE, 1989, *Nuclides and Isotopes*, Fourteenth Edition, General Electric Company, San Jose, California.

- Himes, D. A, 1996, *Atmospheric Dispersion Parameters for B Plant Organic Liquid Storage Fire Scenarios*, Draft WHC-SD-WM-CN-064, Westinghouse Hanford Company, Richland, Washington.
- Marks' Handbook, *Standard Handbook for Mechanical Engineers*, Eighth Edition, McGraw-Hill Book Company, New York, New York.
- NIOSH, 1991, *Registry of Toxic Effects of Chemical Substances*, U.S. Department of Health and Human Services, National Institute for Occupational Safety and Health, Washington, D.C.
- RHO, 1986, *Hydrogen Control in the Handling, Shipping and Storage of Wet Radioactive Waste*, RHO-WM-EV-9 Rev. 1P, Rockwell International, Rockwell Hanford Operations, Richland, Washington.
- Steindler, M.J. and W.H. Seefeldt, 1980, *A Method for Estimating the Challenge to an Air Cleaning System*, Proceedings of the 16th DOE Air Cleaning Conference (M.W. First, Ed.), Harvard Air Cleaning Laboratory, Boston, Massachusetts.
- Thompson, 1987, *Engineering Safety Assessment*, National Nuclear Corporation Ltd., Knutsford, Cheshire, Essex, England.
- WHC, 1996a, *Safety Assessment For Removal Of Organic Liquids From B Plant*, WHC-SD-WM-CN-017, Westinghouse Hanford Company, Richland, Washington.
- WHC, 1996b, *Safety Analysis Manual*, WHC-CM-4-46, Release 18, Westinghouse Hanford Company, Richland, Washington.
- WHC, 1996c, *B Plant Interim Safety Basis Accident Analysis*, WHC-SD-WM-SARR-030, Westinghouse Hanford Company, Richland, Washington.

APPENDIX A

MATHCAD CALCULATIONS

This page intentionally left blank.

USQ Evaluation of Organic Liquid Storage Outside of B Plant Back Calculation of ^{137}Cs and ^{90}Sr Curie Concentrations to Define Safety Envelope For Fire Scenarios

Mathcad computer software version 5.0 was used to perform these calculations. Mathcad is a trademark of MathSoft, Inc. The dose conversion factors (DCFs) are from EPA (1988). The ground release dispersion factors (X/Qs) and airborne release fractions (ARFs) are from B Plant Interim Safety Basis (ISB) Accident Analysis. With a berm in place around the tank, the burn time is greater than 1-hr and credit for plume meander may be taken. Without a berm, the spill area is much greater and the burn time is less than 1-hr and in this case, credit for plume meander cannot be taken. Both cases are examined. The criterion of 5 rem EDE onsite radiological consequences to the 100 m receptor is used, which is valid even for "anticipated" events. Since ^{90}Y is in equilibrium with the ^{90}Sr , the DCF for ^{90}Sr includes that of ^{90}Y . The ARFs are taken from the B Plant ISB and for a release from a flammable liquid, are 0.01 for ^{137}Cs and 0.0077 for ^{90}Sr . The dose calculations are derived using the following equation:

$$\text{Dose} = (\text{Ci}) \times (\text{XoverQ}) \times (\text{BR}) \times (\text{DCF})$$

where: Ci = amount of curies release as respirable = Ci available x ARF
XoverQ = dispersion factor (units of s/m^3)
BR = breathing rate ($3.3\text{E-}04 \text{ m}^3/\text{s}$)
DCF = dose conversion factor
= $3.19\text{E}+04 \text{ rem/Ci}$ for ^{137}Cs or (DCF137Cs)
= $2.47\text{E}+05 \text{ rem/Ci}$ for ^{90}Sr (includes ^{90}Y) or (DCF90Sr)
ARF = airborne release fraction
= 0.01 for ^{137}Cs
= 0.0077 for ^{90}Sr

Combining the above, the onsite dose can be calculated as:

$$\text{Doseon} = (\text{Ci}137\text{Cs})(0.01)(\text{XoverQon})(\text{BR})(\text{DCFCS}) + (\text{Ci}90\text{Sr})(0.0077)(\text{XoverQon})(\text{BR})(\text{DCFSr})$$

Definition of Terms For Mathcad Use:

Doseon : 5 rem	XoverQon : $3.44 \cdot 10^{-02} \text{ s/m}^3$ (no plume meander)
BR : $3.3 \cdot 10^{-04} \text{ m}^3/\text{s}$	XoverQonpm : $1.13 \cdot 10^{-02} \text{ s/m}^3$ (with plume meander)
DCF90Sr : $2.46 \cdot 10^{05} \frac{\text{rem}}{\text{Ci}}$	DCF137Cs : $3.19 \cdot 10^{04} \frac{\text{rem}}{\text{Ci}}$

Rearranging terms and solving for CiSr90 as a function of CiCs137:

$$\text{Ci90Sr}(\text{Ci137Cs}) = \frac{\text{Doseon} \cdot .01 \cdot \text{Ci137Cs} \cdot \text{XoverQon} \cdot \text{BR} \cdot \text{DCF137Cs}}{.0077 \cdot \text{XoverQon} \cdot \text{BR} \cdot \text{DCF90Sr}}$$

Ci137Cs = 0-Ci.,.25-Ci.,.7-Ci (Defines range for ¹³⁷Cs and steps to be evaluated)

$$\text{Ci90SR}(\text{Ci137Cs}) = \frac{\text{Doseon} \cdot .01 \cdot \text{Ci137Cs} \cdot \text{XoverQon} \cdot \text{BR} \cdot \text{DCF137Cs}}{.0077 \cdot \text{XoverQon} \cdot \text{BR} \cdot \text{DCF90Sr}}$$

Ci137Cs   Ci90Sr(Ci137Cs)

0	232.53
0.25	232.48
0.5	232.44
0.75	232.4
1	232.36
1.25	232.32
1.5	232.27
1.75	232.23
2	232.19
2.25	232.15
2.5	232.11
2.75	232.06
3	232.02
3.25	231.98
3.5	231.94
3.75	231.89
4	231.85
4.25	231.81
4.5	231.77
4.75	231.73
5	231.68
5.25	231.64
5.5	231.6
5.75	231.56
6	231.52
6.25	231.47
6.5	231.43
6.75	231.39
7	231.35

Ci = 1

rem = 1

In a similar way, the calculations are performed assuming the term is in place and therefore credit for plume meander is taken.

$$Ci90Sr(Ci137Cs) : \frac{Doseon \cdot .01 \cdot Ci137Cs \cdot XoverQonpm \cdot BR \cdot DCF137Cs}{.0077 \cdot XoverQonpm \cdot BR \cdot DCF90Sr}$$

Ci137Cs = 0-Ci, .25-Ci, 7-Ci (Defines range for ¹³⁷Cs and steps to be evaluated)

$$Ci90SSr(Ci137Cs) : \frac{Doseon \cdot .01 \cdot Ci137Cs \cdot XoverQonpm \cdot BR \cdot DCF137Cs}{.0077 \cdot XoverQonpm \cdot BR \cdot DCF90Sr}$$

Ci137Cs

0
0.25
0.5
0.75
1
1.25
1.5
1.75
2
2.25
2.5
2.75
3
3.25
3.5
3.75
4
4.25
4.5
4.75
5
5.25
5.5
5.75
6
6.25
6.5
6.75
7

Ci90Sr(Ci137Cs)

707.87
707.83
707.78
707.74
707.7
707.66
707.61
707.57
707.53
707.49
707.45
707.4
707.36
707.32
707.28
707.24
707.19
707.15
707.11
707.07
707.03
706.98
706.94
706.9
706.86
706.81
706.77
706.73
706.69

This page intentionally left blank.

APPENDIX B

PRELIMINARY HAZARDS ANALYSIS (PHA) PARTICIPANTS

This page intentionally left blank.

List A. B Plant ISB PHA Participants (7/18/96)

Name	Organization
Steve Chalk	FDNW/SAR Engineering Services
Kaleem Ullah	B&W Hanford Co./B-Plant/Safety
Bruce Gilkeson	FDNW/Projects
Monica Serkowski	B&W Hanford Co./B-Plant
Scott Ellingson	FDNW/Engineering
Rex Bendixsen	FDNW/Specialty Engineering
John Joyce	LATA
Evan Hafila	B&W Hanford Co./B-Plant
Fred Heard	NHC
Kimberly Williams	DOE/TPD/B-Plant/WESF
Judith Siemer	LATA

List B. B Plant ISB PHA Participants (7/22/96)

Name	Organization
Ron Kidder	FDNW/SAR Engineering Services
Dewey Robbins	B&W Hanford Co./B Plant
Bruce Gilkeson	FDNW/Projects
Evan Hafila	B&W Hanford Co./B-Plant
Monica Serkowski	B&W/B-Plant
Kim Beecher	GSSC
Scott Ellingson	FDNW Engineering
John Joyce	LATA
Bryan Jackson	FDNW/B-Plant
Rex Bendixson	FDNW/Specialty Engineering
Kimberly Williams	DOE/TPD/B-Plant/WESF
Judith Siemer	LATA

This page intentionally left blank.

HNF-SD-OPS-SAD-001, Rev. 0
CHECKLIST FOR PEER REVIEW

Document Reviewed: C. H. Huang, " SAFETY ASSESSMENT FOR STORAGE OF ORGANIC LIQUIDS ADJACENT TO B PLANT," February 11, 1997.

Scope of Review: SECTION 4.3

Yes No NA

☐	☐	☒	*	Previous reviews complete and cover analysis, up to scope of this review, with no gaps.
☒	☐	☐		Problem completely defined.
☒	☐	☐		Accident scenarios developed in a clear and logical manner.
☒	☐	☐		Necessary assumptions explicitly stated and supported.
☐	☐	☒		Computer codes and data files documented.
☒	☐	☐		Data used in calculations explicitly stated in document.
☒	☐	☐		Data checked for consistency with original source information as applicable.
☐	☐	☒		Mathematical derivations checked including dimensional consistency of results.
☒	☐	☐		Models appropriate and used within range of validity or use outside range of established validity justified.
☒	☐	☐		Hand calculations checked for errors. Spreadsheet results should be treated exactly the same as hand calculations.
☐	☐	☒		Software input correct and consistent with document reviewed.
☐	☐	☒		Software output consistent with input and with results reported in document reviewed.
☒	☐	☐		Limits/criteria/guidelines applied to analysis results are appropriate and referenced. Limits/criteria/guidelines checked against references.
☒	☐	☐		Safety margins consistent with good engineering practices.
☒	☐	☐		Conclusions consistent with analytical results and applicable limits.
☒	☐	☐		Results and conclusions address all points required in the problem statement.
☐	☐	☒		Format consistent with appropriate NRC Regulatory Guide or other standards
☐	☐	☒	*	Review calculations, comments, and/or notes are attached.
☒	☐	☐		Document approved.

<u>C. H. Huang Chin-Hua Huang</u>	<u>2/11/97</u>
Reviewer (Printed Name and Signature)	Date

CHECKLIST FOR PEER REVIEW

Document Reviewed: WHC-OPS-SAD-001, Safety Assessment For Storage of Organic Liquids Adjacent to B Plant

Scope of Review: Pages 1 through 29

Yes No NA

- ☐ ☐ ☒ * Previous reviews complete and cover analysis, up to scope of this review, with no gaps.
- ☒ ☐ ☐ Problem completely defined.
- ☒ ☐ ☐ Accident scenarios developed in a clear and logical manner.
- ☒ ☐ ☐ Necessary assumptions explicitly stated and supported.
- ☒ ☐ ☐ Computer codes and data files documented.
- ☒ ☐ ☐ Data used in calculations explicitly stated in document.
- ☐ ☐ ☒ Data checked for consistency with original source information as applicable.
- ☒ ☐ ☐ Mathematical derivations checked including dimensional consistency of results.
- ☒ ☐ ☐ Models appropriate and used within range of validity or use outside range of established validity justified.
- ☒ ☐ ☐ Hand calculations checked for errors. Spreadsheet results should be treated exactly the same as hand calculations.
- ☐ ☐ ☒ Software input correct and consistent with document reviewed.
- ☐ ☐ ☒ Software output consistent with input and with results reported in document reviewed.
- ☒ ☐ ☐ Limits/criteria/guidelines applied to analysis results are appropriate and referenced. Limits/criteria/guidelines checked against references.
- ☒ ☐ ☐ Safety margins consistent with good engineering practices.
- ☒ ☐ ☐ Conclusions consistent with analytical results and applicable limits.
- ☒ ☐ ☐ Results and conclusions address all points required in the problem statement.
- ☒ ☐ ☐ Format consistent with appropriate NRC Regulatory Guide or other standards
- ☐ ☐ ☒ * Review calculations, comments, and/or notes are attached.

☒ ☐ ☐ ☐ Document approved.

John E. Kelly John E. Kelly
Reviewer (Printed Name and Signature)

8/21/96

Date

* Any calculations, comments, or notes generated as part of this review should be signed, dated and attached to this checklist. Such material should be labeled and recorded in such a manner as to be intelligible to a technically qualified third party.

DISTRIBUTION SHEET

To	From	Page 1 of 1
Distribution	SAR Engineering Services	Date 2/11/97
Project Title/Work Order		EDT No. 616283
Safety Assessment for Storage of Organic Liquids Adjacent to B Plant		ECN No. N/A

Name	MSIN	Text With All Attach.	Text Only	Attach./ Appendix Only	EDT/ECN Only
Central Files (original + 2 copies)	A3-88	X			
Chalk, S.E.	A2-25	X			
Docket Files (2 copies)	B1-17	X			
Dodd, E.N. Jr.	S4-66	X			
Gray, B.J.	S6-81				X
Hafila, E.R.	S6-60	X			
Hill, M.A.	S4-66	X			
Johnson, L.E.	A2-25				X
Rau, A.B.	A2-25	X			
Robbins, E.D.	S6-59				X
Roege, P.E.	S4-66	X			