~~XXXX~~ RMIS View/Print Document Cover Sheet ~~XXXX~~

This document was retrieved from the Documentation and Records Management (DRM) ISEARCH System. It is intended for Information only and may not be the most recent or updated version. Contact a Document Service Center (see Hanford Info for locations) if you need additional retrieval information.

Accession #: D195063824

Document #: SD-WM-SDD-064

Title/Desc:

SYSTEM DESIGN DESCRIPTION FOR THE SY101 VENT
HEADER FLOW ELEMENT ENCLOSURE UPGRADE

Pages: 11

NOV 27 1995 21 ENGINEERING DATA TRANSMITTAL

Page 1 of 1
1. EDT 158602

2. To: (Receiving Organization) DISTRIBUTION		3. From: (Originating Organization) CHARACTERIZATION ENGINEERING DEVELOPMENT		4. Related EDT No.: N/A	
5. Proj./Prog./Dept./Div.: 101-SY HYDROGEN MITIGATION		6. Cog. Engr.: G. F. GAUCK		7. Purchase Order No.: WBJ-VDV-428712	
8. Originator Remarks: THIS DOCUMENT IS BEING TRANSMITTED FOR APPROVAL AND RELEASE				9. Equip./Component No.: VTP-PNL-3108	
				10. System/Bldg./Facility: TANK 241-SY-101/DACS	
11. Receiver Remarks:				12. Major Assm. Dwg. No.: H-14-100405 H-14-100406 H-14-100407	
				13. Permit/Permit Application No.: N/A	
				14. Required Response Date: 10/16/1995	

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Trans- mittal	Originator Dispo- sition	Receiver Dispo- sition
1	WHC-SD-WM-SDD-064	A11	0	SYSTEM DESIGN DESCRIPTION FOR THE SY-101 VENT HEADER FLOW ELEMENT ENCLOSURE UPGRADE	S,Q	1	1	

16. KEY					
Approval Designator (F)		Reason for Transmittal (G)			Disposition (H) & (I)
E, S, Q, D or N/A (see WHC-CM-3-5, Sec. 12.7)		1. Approval 2. Release 3. Information	4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)		
					1. Approved 2. Approved w/comment 3. Disapproved w/comment
					4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)										(G)	(H)
(G)	(H)	(J) Name	(K) Signature	(L) Date	(M) MSIN	(J) Name	(K) Signature	(L) Date	(M) MSIN	Reason	Dis p.
1	1	Cog. Eng. G. J. Gauck		10-16-95	T4-07						
1	1	Cog. Mgr. S. H. Rifaey		10-16-95	T4-07						
1	1	QA T. K. Volkman		10-16-95	T4-08						
1	1	Safety L. S. Krogsrud		10-16-95	R3-08						
1	1	Operations D.P. Niebuhr		10-16-95	T4-01						
1	1	Eng. Author G. F. Vargo, Jr		10-16-95	T5-05						
1	1	Eng. Author Mgr. C. E. Hanson		10-16-95	H5-09						

18. G. F. VARGO, JR. 10/16/95 Originator		19. S. H. RIFAHEY 10/16/95 Authorized Representative for Receiving Organization		20. S. H. RIFAHEY 10/16/95 Cognizant Manager		21. DOE APPROVAL (if required) Ctrl. No. N/A ☐ Approved ☐ Approved w/comments ☐ Disapproved w/comments	
--	--	---	--	--	--	---	--

RELEASE AUTHORIZATION

Document Number: WHC-SD-WM-SDD-064, Rev. 0

Document Title: System Design Description for the SY-101 Vent Header Flow Element Enclosure

Release Date: 11/27/95

**This document was reviewed following the
procedures described in WHC-CM-3-4 and is:**

APPROVED FOR PUBLIC RELEASE

WHC Information Release Administration Specialist:

K. G. Noland

11/27/95

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

This report has been reproduced from the best available copy. Available in paper copy. Printed in the United States of America. To obtain copies of this report, contact:

Westinghouse Hanford Company - Document Control Services
P.O. Box 1970, Mailstop H6-08, Richland, WA 99352
Telephone: (509) 372-2420; Fax: (509) 376-4989

SUPPORTING DOCUMENT

1. Total Pages 7

2. Title

**SYSTEM DESIGN DESCRIPTION FOR THE SY-101 VENT
HEADER FLOW ELEMENT ENCLOSURE UPGRADE**

3. Number

WHC-SD-WM-SDD-064

4. Rev No.

0

5. Key Words

VENT HEADER, FTE, OMEGA

6. Author

Name: **G. F. Vargo, Jr.**Signature

Organization/Charge Code

W75250/N2138

7. Abstract

**THIS DOCUMENT DESCRIBES THE DESIGN OF THE HIGH AND LOW RANGE VENT HEADER FLOW
ELEMENT(S) FIELD ENCLOSURE FOR THE 241-SY-101 HIGH LEVEL NUCLEAR WASTE UNDERGROUND
STORAGE TANK.**

8.

RELEASE STAMP

WHC-SD-WH-SDD-064
Rev 0

**SYSTEM DESIGN DESCRIPTION
FOR THE
SY-101 VENT HEADER FLOW ELEMENT
ENCLOSURE UPGRADE**

**WESTINGHOUSE HANFORD COMPANY
OCTOBER 1995**

TABLE OF CONTENTS

ACRONYMS AND ABBREVIATIONS	2
1.0 DESCRIPTION	3
2.0 HARDWARE	3
3.0 OPERATION	4
4.0 CALIBRATION	4
5.0 MAINTENANCE	4
6.0 CERTIFIED VENDOR FILE	5
7.0 REFERENCES	5

ACRONYMS AND ABBREVIATIONS

FTE	Flow Transmitter Element
GFCI	Ground Fault Circuit Interrupter
NEMA	National Electrical Manufacturers Association
SDD	System Design Description
T/C	Thermocouple
Vac	Volts Alternating Current

SYSTEM DESIGN DESCRIPTION
FOR THE SY-101 VENT HEADER FLOW ELEMENT
ENCLOSURE UPGRADE

1.0 DESCRIPTION

This document describes the design of the high and low range vent header flow element(s) field enclosure for the 241-SY-101 high level nuclear waste underground storage tank. The enclosure is environmentally protected and prevents adverse weather conditions from effecting the performance of the flow elements. Previously, during wintry conditions, the elements have become inoperable due to freezing conditions.

2.0 HARDWARE

The enclosure consists of a full size NEMA 12 72" upright cabinet with a clear Lexan¹ (polycarbonate resin) cut out window on the North door, 8000 BTU air conditioner(a/c), a roof mounted rain hood, half sun shield(s) on the South and East sides, and a 800 watt internal cabinet heater. The cabinet is fully insulated, internally, with 1" Armstrong Armaflex II² insulation. An Omega³ DP25-TC Programmable Digital Thermocouple(T/C) meter reads the cabinet internal temperature and energizes an amber flashing roof mounted beacon if the cabinet temperature exceeds 90° F or drops below 50° F. The Omega digital thermocouple provides a N.O. relay contact closure(s) for this function. The a/c and heater are independently controlled by separate thermostats and have been adjusted to maintain the cabinet internal temperature approximately between 70° F and 80° F. The vent header low range flow detector VTP-FIT-3101A(FTE50001) and the high range detector VTP-FIT-3101B(FTE50002) are mounted to a shelf inside the cabinet. Additional features include a Stabiline⁴ power conditioner and two(2) GFCI 120 Vac, 15 amp service receptacles, one(1) inside the cabinet and one(1) outside the cabinet. The externally mounted receptacle is rated for outdoor use and protected by a weatherproof cover.

The cabinet is located on the Southwest side of the 241-SY-101 vent header and is permanently mounted to the existing concrete pad.

¹ Lexan is a trademark of GE Plastics.

² Armstrong Armaflex II is a trademark of Armstrong, Corp.

³ Omega is a trademark of the Omega Corp.

⁴ Stabiline is a trademark of the Stabiline Corp.

3.0 OPERATION

The cabinet is permanently connected into the SY farm electrical power and is energized, via circuit breaker, from inside the cabinet. Reference H-14-100407, "VTP-PNL-3108 INST. CABINET WIRING DIAGRAM", and H-14-100456, "VTP-PNL-3108 INST. CABINET ELEMENTARY DIAGRAM". Once the cabinet has been energized no other actions are required by the operator. The flow transducer elements, a/c, heater, and digital thermocouple will automatically energize, and begin to function, when the main breaker to the cabinet is closed.

An interior light is provided that is controlled from a switch, located just inside the cabinet interior, on the right hand side.

4.0 CALIBRATION

The following components have been initially set and should require no further adjustment during their lifetime:

1. The enclosure a/c (VTP-AC-3108) thermostat has been set and verified to energize at 80° F. The a/c deenergizes at approximately 75° F.
2. The enclosure heater (VTP-HTR-3108) thermostat has been set and verified to energize at 70° F, and deenergizes at approximately 72° F.

NOTE: The a/c and the heater are electrically interlocked to prevent energizing simultaneously.

3. The Omega DP25-TC Programmable Digital Thermocouple Meter has been programmed to alarm at 90° F, on the high end, and 50° F, on the low end, by energizing the roof mounted amber flashing beacon when these limits are exceeded. Reference the "OMEGA DP25-TC PROGRAMMABLE DIGITAL THERMOCOUPLE METER OPERATOR'S MANUAL" for programming instructions. The alarm will automatically clear when the cabinet temperature returns to it's normal operating range. When this occurs the roof mounted light will return to the off state.

5.0 MAINTENANCE

No maintenance is required on the cabinet system. However, the flow elements, installed in the cabinet, will require periodic calibration and maintenance.

6.0 CERTIFIED VENDOR FILE

The Certified Vendor Information file (CVI) is 22129, Supplemental 64, Enclosure for Supplement 4. This is the CVI file for the 241-SY-101 Veltron vent header flow transmitters.

7.0 REFERENCES

1. WHC-SD-WM-WP-304, "Work Plan For the SY-101 Vent Header Enclosure Upgrade", Westinghouse Hanford Company, June 1995.
2. WHC-SD-WM-ATP-142, "Acceptance Test Procedure for the Fabrication of the SY-101 Vent Header Flow Element Enclosure", Westinghouse Hanford Company, August 1995.
3. WHC-SD-WM-ATR-142, "Acceptance Test Report for the Fabrication of the SY-101 Vent Header Flow Element Enclosure", Westinghouse Hanford Company, August 1995.
4. H-14-100405, "VTP-PNL-3108 INST. CABINET ASSEMBLY", Westinghouse Hanford Company drawing.
5. H-14-100406, "VTP-PNL-3108 INST. ENCLOSURE ASSEMBLY", Westinghouse Hanford Company drawing.
6. H-14-100407, "VTP-PNL-3108 INST. CABINET WIRING DIAGRAM", Westinghouse Hanford Company drawing.
7. H-14-100456, VTP-PNP-3108 INST. CABINET ELEMENTARY DIAGRAM", Westinghouse Hanford Company drawing.
8. "STANDARD ENGINEERING PRACTICES", WHC-CM-6-1, Westinghouse Hanford Company.
9. "NATIONAL ELECTRICAL CODE HANDBOOK 1993", National Fire Protection Association, Batterymarch Park, Quincy, MA.

DISTRIBUTION SHEET

To DISTRIBUTION	From CHARACTERIZATION EQUIPMENT DEVELOPMENT	Page 1 of 1 Date 10/13/95
Project Title/Work Order SYSTEM DESIGN DESCRIPTION FOR THE SY-101 VENT HEADER FLOW ELEMENT ENCLOSURE UPGRADE		EDT No. 158602 ECN No.

Name	MSIN	Text With All Attach.	Text Only	Attach./ Appendix Only	EDT/ECN Only
K. F. Armatis	H5-09	X			
T. R. Benegas	H5-09	X			
W. G. Brown	T4-07	X			
J. R. Bunch	R1-51	X			
G. J. Gauck	T4-07	X			
D. C. Larsen	R1-51	X			
J. W. Lentsch	S7-12	X			
M. L. McElroy	S1-57	X			
D. P. Niebuhr	T4-01	X			
S. H. Rifaey	T4-07	X			
C. P. Shaw	H5-09	X			
G. W. Shepherd	H5-10	X			
G. F. Vargo, Jr.	H5-09	X			
Central Files	A3-88	X			
DSTI (2 copies)	A3-36	X			
Project Files	H5-09	X			