An Assessment of the Building Sector Efficiency Resource for the Town of Handlova

October 1995 RECEIVED
OCT 04 1996
OSTI

Pacific Northwest Laboratory

for
DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

MASTER

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor Battelle Memorial Institute, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof, or Battelle Memorial Institute. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

PACIFIC NORTHWEST LABORATORY
operated by
BATTELLE MEMORIAL INSTITUTE
for the
UNITED STATES DEPARTMENT OF ENERGY
under Contract DE-AC06-76RLO 1830

This document was printed on recycled paper.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

An Assessment of the Building Sector Efficiency
Resource for the Town of Handlova

October 1995

Prepared for the U.S. Department of Energy
under Contract DE-AC06-76RLO 1830

Pacific Northwest Laboratory
Washington, DC 20024

AN ASSESSMENT OF THE BUILDING SECTOR EFFICIENCY RESOURCE FOR THE TOWN OF HANDLOVA

11 FEBRUARY 1994

Prepared by:

Tecogen Division
Thermo Power Corporation

Under Contract With:

Battelle, Pacific Northwest Laboratory

Assisted by:

EGU Bratislava

TABLE OF CONTENTS

SUMMARY	vi
1. INTRODUCTION	1
1.1 SCOPE AND APPROACH	1
1.2 REPORT ORGANIZATION	2
1.3 STUDY PARTICIPANTS	2
2. ENERGY USE BASELINE AND DEMAND FORECAST	3
2.1 INTRODUCTION	3
2.2 DEFINITION OF DEMAND SIDE SECTORS	3
2.2.1 Residential Sector	3
2.2.2 Non-Residential Sector	6
2.2.3 Industrial Sector	6
2.3 DEMAND SIDE BASELINE	8
2.3.1 Energy Consumption by Sectors	12
2.3.1.1 Residential Sector Energy Consumption	12
2.3.1.2 Non-Residential Sector Energy Consumption	14
2.3.1.3 Industrial Sector Energy Consumption	14
2.4 DEMAND FORECAST	15
3. BUILDING SECTOR EFFICIENCY ASSESSMENT	16
3.1 EFFICIENCY MEASURES	16
3.1.1 Energy Efficiency Measures Considered	16
3.1.1.1 Building Envelope Measures	16
3.1.1.2 Domestic Water Heating	18
3.1.1.3 Heating System	19
3.1.1.4 Ventilation - Heat Recovery	20
3.1.2 Efficiency Measures not Considered	21
3.1.2.1 Building Envelope	21
3.1.2.2 Domestic Water Heating	22
3.1.2.3 Heating System	22
3.1.2.4 Ventilation - Heat Recovery	23
3.1.3 Summary of Efficiency Measures Considered	23

TABLE OF CONTENTS (Continued)

3.2 ANALYSIS APPROACH	23
3.2.1 Technical Analysis Method	24
3.2.1.1 Analyses of Building Envelope Measures	24
3.2.1.2 Analyses of Water Heating Measures	26
3.2.1.3 Analyses of Building Heating System	27
3.2.1.4 Analyses of Ventilation and Heat Recovery Measures	27
3.2.2 Economic Analysis	27
3.2.2.1 Analysis Metrics	27
3.3 BUILDING SECTOR EFFICIENCY ASSESSMENT RESULTS	30
3.3.1 Baseline Efficiency Assessment	31
3.3.1.1 Residential Sector Baseline Efficiency	31
3.3.1.2 Non-Residential Sector Baseline Efficiency	33
3.3.2 Sensitivity Analysis	34
3.3.2.1 Installed Cost of Equipment	34
3.3.2.2 Fuel Price	34
3.3.2.3 Actual Energy Savings Achieved	35
3.3.2.4 Summary of Sensitivity Analysis	36

LIST OF TABLES

2.1	Residential Building Stock Data (Town of Handlova)	7
2.2	Heating Plant/User Energy Consumption Metering Comparison	9
2.3	Total Primary Fuel Input for the Production of Heat Energy, 1992	9
2.4	Primary Heat Energy Utilization, 1992	10
2.5	Energy End Use by Sectors and Fuel	12
2.6	Residential Sector Space Heating Energy Consumption by Building Type and Fuel	13
2.7	Residential Sector Water Heating Energy Consumption by Building Type and Fuel	13
2.8	Non-Residential Space and Water Heating Energy Consumption by Building Type and Fuel	14
2.9	Industrial User Energy Consumption	14
3.1	Efficiency Measures Considered and Estimated Per Unit Cost and Lifetime	25
3.2	Base Economic Assumptions for Analysis of Efficiency Measures	29
3.3	Fuel Price Levels Used to Drive Analysis of Efficiency Resource and Sensitivity Analysis by Fuel Type	29
3.4	Residential Sector Cost-Effective Space and Water Heat Efficiency Resource by Building, Fuel and Equipment Type Using Base Assumptions and 1993 Fuel Prices	32
3.5	Economic Analysis Results of Residential Sector Cost-Effective Energy Efficiency Resource for 1993 Baseline	33
3.6	Estimated Non-Residential Space and Water Heat Efficiency Potential by Fuel and Heating System Type, 1993	33
3.7	Sensitivity of the Energy Saving Potential and the Cost of Delivered Heat to Fuel Prices	35
3.8	Sensitivity of the Energy Saving Potential and the Cost of Delivered Heat to Actual Energy Savings Achieved	36

LIST OF FIGURES

2.1	Apartment Buildings (1951-52), Group 1	4
2.2	Apartment Buildings (1954-57), Group 2	4
2.3	Prefab Buildings Type T06 B (1968-84), Group 3	4
2.4	Prefab Buildings (1962-65), Group 4	5
2.5	Prefab Buildings (1987-91), Group 5	5
2.6	Single and Two Family Detached Houses, Group 6 and 7	5
2.7	District Heat Energy Flow	11

ACKNOWLEDGEMENTS

Mr. Andrew Popelka, Program Manager, would like to give special recognition to the following people who greatly contributed to the efforts of this project.

Gratitude is expressed to Len Rogers, U.S. Agency for International Development (AID), Marian Krsko, AID Slovak Mission, and Elaine Guthrie, U.S. Department of Energy, for making this study possible. Special thanks to Peter Sestak at EGU Bratislava for leading the Slovak effort, and Ed Doyle at Tecogen for his technical support and oversight. Recognition to Bill Chandler, Director of PNL's Advanced International Studies Unit, and Tom Secrest, Program Manager at PNL for their guidance in this effort. Special appreciation to Kim Myles for the final preparation of this report.

SUMMARY

The Town of Handlova in the Slovak Republic is considering options for providing energy services to its citizens in order to lower their energy bills and reduce pollution created by the burning of low quality brown coal. The U.S. Agency for International Development (AID), under the Support for Eastern European Democracy (SEED) Program, agreed to fund an assessment of the space and water heat efficiency potential in the building sector in the Town of Handlova. The assessment was funded through the U.S. Department of Energy's (DOE) Office of Energy Efficiency and Renewable Energy (EE) and conducted by the Pacific Northwest Laboratories (PNL) and its subcontractors, Tecogen, a U.S. based energy research and development firm, and EGU, a Slovak Energy Research Institute.

The purpose of this assessment is to develop information on the building sector energy efficiency and improvement potential for use by the Town management to support decisions on the provision of energy services to Handlova citizens. In support of this purpose, specific objectives of this effort are:

- to characterize baseline space and water heat energy use and efficiency improvement potential that exists in the residential and non-residential building sectors in the municipality of Handlova.
- to develop capability in Slovak organizations to conduct energy assessments modeled after procedures employed in the U.S. to support energy efficiency resource acquisitions.

This effort is not intended to provide a definitive analysis to enable selection of specific technologies for application, but rather to identify the major areas of efficiency improvement potential and cost-effectiveness.

The current changes in Slovakia toward a market economy are causing prices of fuels and energy to be in a state of flux. In order to analyze the impact of fuel and energy price changes on energy saving potential, four levels of prices were established. Level 1 represents current, subsidized and controlled prices of energy; Level 2 assumes removal of state subsidies; Level 3 represents a moderate increase, the most likely scenario of price development; and, finally, Level 4 represents a substantial fuel and energy price increase.

Subject to the data limitations and assumptions made, a significant efficiency resource exists in the space and water heating end-uses in the residential and non-residential building sectors. At the fuel price level at which the energy savings potential was evaluated, this resource amounts to 42% of the total building sector space and water heat energy consumption. At the current fuel price, Level 1 and Level 2, the savings potential represents 35% and 40%, respectively, of building sector consumption.

About 89% of the efficiency resource resides in the district heating area at current fuel prices; this is slightly lower for higher fuel prices. Space and hot water heat provided by gaseous fuels is the next largest resource, ranging from 9% to 17% of the total water heating load. The on-site coal consumption accounts for less than 1% of the total efficiency resource under the lowest fuel price scenario. Under the highest price scenario, the coal based efficiency resource increases to about 7% of the total resource. The electricity based efficiency resource is the least sensitive to fuel prices and amounts to less than 0.1% of the total efficiency resource in all price scenarios.

Nearly 80% of the residential sector efficiency resource is in the high rise multi-family building types, and of this, 97% is in the district heating area for all fuel price levels. In the non-residential sector, about 65% of the efficiency potential resides in the education and health facilities under all four fuel price scenarios. The share of the efficiency potential in the education and health (hospital) building types accounted for by the district heat area is about 81%.

The levelized energy cost of the total efficiency resource is on the order of 132 Sk/GJ as compared to the Level 1 current consumption weighted average energy price of 139 Sk/GJ. At Level 3 (realistic increase), which was analyzed in this report, the levelized energy cost of 135 Sk/GJ compares to the consumption weighted prices of 232.5 Sk/GJ. Under current prices, the levelized energy cost of the efficiency resource within the district system fuel type is on the order of 135 Sk/GJ as compared to 165 Sk/GJ for district heat. Under the assumed Level 3 price scenario, district heat is projected to increase to 270 Sk/GJ as compared to a levelized energy cost for the district heat based efficiency resource of 144 Sk/GJ.

Under three future consumption variants and in the absence of actions to acquire energy efficiency, the building sector space and water heat energy consumption is projected to be stable in the first variant, increase by 5.22% in the second variant, and increase by 11.22% in the third variant by the year 2022. Dependent upon changes in fuel prices, the future building sector space and water heat energy consumption could decrease on the order of 35% to 44% if the entire resource were acquired.

With respect to the second major objective, the Slovak team led by EGU Bratislava participated in all aspects of the study with the U.S. participants serving primarily in an advisory capacity. It is felt that the assessment process was successfully transferred to the Slovak study participants, and the process and results were well received by the Town staff.

1. INTRODUCTION

The Town of Handlova in the Slovak Republic is considering options for providing energy services to its citizens. The existing Central Heating Plant is on the end of its useful life and must be replaced. The Town is evaluating alternative solutions of providing its citizens with thermal energy at lowest possible cost and at the lowest pollution by the energy sources. In the Summer of 1993, the U.S. Agency for International Development (AID) under the Support for Eastern European Democracy (SEED) Program, agreed to fund an assessment of the options for providing heating energy to the buildings sector in the Town of Handlova.

This report documents the assessment of the buildings sector efficiency resource conducted by the Pacific Northwest Laboratories (PNL) and its subcontractors, Tecogen, a U.S. based energy research and development firm, and EGU Bratislava, the Slovak Power Research Institute.

1.1 SCOPE AND APPROACH

The purpose of this assessment is to develop information on the building sector energy efficiency potential needed by the Town management to support decisions on the provision of energy services to the citizens of Handlova. In support of this purpose, specific objectives of this effort are:

- To characterize baseline space and water heat energy use and efficiency potential that exists in the residential and non-residential building sectors in the municipality of Handlova.
- To develop capability in Slovak organizations to conduct energy assessments modelled after procedures employed in the U.S. to support energy resource acquisitions.

This effort is not intended to provide a definitive analysis to enable selection of specific technologies for application.

The baseline energy use characterization segments the residential and non-residential building stock into individual building types and estimates the space and water heat energy consumption by each building type, fuel type and equipment type. The efficiency potential is then estimated for each building, fuel and equipment type based upon cost-effectiveness criteria.

A key aspect of the effort is to build the capability in Slovak organizations/individuals for conducting subsequent assessments employing integrated resource planning principles used by the U.S. utility industry. To this end, Slovak organizations and experts participated in all aspects of the study with the U.S. participants serving primarily in an advisory capacity.

1.2 REPORT ORGANIZATION

This report summarizes the detailed assessment that was written in Slovak and is organized into the following two main chapters:

- Chapter two provides the baseline and forecast of the demand for thermal energy consumed to provide space and water heat;
- Chapter three presents the efficiency resource options considered and the estimated efficiency resource;

For readers interested in converting the energy and currency units to British Thermal Units (BTUs) and dollars, one gigajoule (GJ) equals one million BTU and about 32 Slovak Koruna (SK) equals one US dollar. This report is also published in Slovak language.

1.3 STUDY PARTICIPANTS

PNL, one of DOE's five multi-program research laboratories, conducts a significant number of programs in the area of energy efficiency and integrated resource planning. PNL's Advanced International Studies Unit (AISU) conducts research on global climate change and manages cooperative programs to transfer energy-efficiency practices and technologies to other countries. PNL provided the technical and management oversight for this effort.

PNL/AISU contracted with the U.S. firm Tecogen and the EGU - Energy Research Institute in Bratislava to support the integrated assessment activities. Tecogen, a division of Thermo Power Corporation, a Thermo Electron company, specializes in the development and manufacturing of gas-fired cogeneration and cooling equipment and has significant experience in energy demand assessment and field evaluation of energy producing and consuming systems. Tecogen conducted the assessment of the demand-side resource opportunities and provided technical support for the integration of the demand and supply resources.

EGU is currently a government organization (soon to be privatized). EGU provided the Slovak lead for the demand-side and supply-side assessment activities and the interface to the Town of Handlova for project communications, and represented the study recommendations to the Town and other organizations. EGU acquired the expertise of Mr. Certik and other local experts to assist with the collection of energy consumption data and the building of stock characterization.

2. ENERGY USE BASELINE AND DEMAND FORECAST

2.1 INTRODUCTION

This chapter presents the baseline thermal energy use data and future energy demand forecast scenarios that were used to project the future demand for the town of Handlova. Section 2.2 defines the breakdown of the thermal energy consumption sectors used in the study and provides additional information on the sectors that was needed for the energy efficiency assessments. In Section 2.3, the baseline thermal energy use for the entire town is provided by fuel form, sector and major end-use categories (space heating and water heating). The population and industrial growth scenarios used to forecast future energy demand through the Year 2022 is presented in Section 2.4.

2.2 DEFINITION OF DEMAND SIDE SECTORS

For the purpose of this study, the town was divided into three energy consumption sectors: residential, non-residential and industrial. These sectors were then further subdivided and the specific parameters needed to support the energy efficiency analyses were identified. The study concentrated on the residential sector since this is the largest thermal energy consumer.

2.2.1 Residential Sector

The data on residential building stock were acquired from the databank maintained by the Building Management Company in Handlova (Bytový podnik Mesta Handlova), from the Administration Office of the Town Hall and from AGS Atelier Company which was involved in town development studies. The residential sector was then divided into the following seven representative residential building types:

- Res-1 Apartment Buildings 2 to 3 floors (1951-1952)
- Res-2 Apartment Buildings 3 to 7 Floors (1954-1957)
- Res-3 Pre-fab Buildings T 06 B (1968-1984)
- Res-4 Pre-fab Buildings (1962-1965)
- Res-5 Pre-fab Buildings P1-15-NKS (1982-1991)
- Res-6 Two family detached houses
- Res-7 Single family detached houses

For building types Res-1 through Res-5, the years in which these buildings were constructed is provided in brackets. Figures 2.1 through 2.6 show typical buildings representing each residential building type group. The total number of residential buildings and apartment units along with the total heated square meters in each building type are shown in Table 2.1.

Figure 2.1 - Apartment Buildings (1951-52), Group 1

Figure 2.2 - Apartment Buildings (1954-57), Group 2

Figure 2.3 - Prefab Buildings Type T06 B (1968-84), Group 3

Figure 2.4 - Prefab Buildings (1962-65), Group 4

Figure 2.5 - Prefab Buildings (1987-91), Group 5

Figure 2.6 - Single and Two Family Detached Houses,
Group 6 & 7

The data in Table 2.1 for apartment building types Res-1 through Res-5 were acquired from the available building layout drawings and from the billing files of the Bytovy Podnik Mesta Handlova (BPMH). The heated floor space data included only space with heating elements (radiators) installed in the room. The difference between this heated floor space and the total floor space actually heated (maintained at room temperature) was estimated based on actual layout drawings. The heated space for building types Res-6 and Res-7 was estimated based on typical single and two family house designs found in Handlova and was compared to information maintained by the Administration Office of the Town of Handlova.

The data indicate that approximately 27% of residential heated floor space is in brick-built apartment buildings from the 1950's (Res 1-2), 49% in the pre-fab multi-family housing (Res 3-5), and the remaining 24% in detached single and two family houses.

2.2.2 Non-Residential Sector

The seven building types identified in the non-residential sector are as follows:

NonRes-1	Education (primary schools, dormitory)
NonRes-2	Culture
NonRes-3	Health Facilities (including nursery schools)
NonRes-4	Sport facilities
NonRes-5	Office/Administration
NonRes-6	Services and Retail
NonRes-7	Accommodation, Hotels

Data limitations coupled with time and budget limitations did not permit a comparable characterization of the non-residential building stock. In addition to that, each of the non-residential building types alone represent a very small fraction of the total energy consumption (maximum 3.5%) and all types of buildings in this sector combined represent less than 20% of the total energy consumption.

2.2.3 Industrial Sector

The industrial sector in Handlova is represented by the following firms: Coal Mine Handlova including garages, Slovenka, Lahke Universalne Konstrukcie, AMK, Chemika, CSD station and State Agricultural Farm. The thermal energy is used only for space and water heating. Technological use of thermal energy is negligible. Except for the Coal Mine Industry, this energy demand sector is relatively small and was not characterized in detail because of the time and budget limitations of the project.

**Table 2.1 - Residential Building Stock Data
Town of Handlova**

Bldg. Group	Number of Bldgs. by Fuel				Bldgs Total	Number of Apartments by Fuel				Apart. Total	Heated Area by Fuel [m²]				Heated Area Total [m²]	Heated Area %
	Dist.	Coal	Gas	Elect.		Distr.	Coal	Gas	Elect.		Distr.	Coal	Gas	Electr.		
1	0	0	22	0	22	0	0	232	0	232	0	0	12517	0	12517	3.71
2	40	1	6	0	47	1198	12	114	0	1324	70471	632	7943	0	79046	23.46
3	29	0	0	0	29	1567	0	0	0	1567	89719	0	0	0	89719	26.62
4	10	0	0	0	10	376	0	0	0	376	20639	0	0	0	20639	6.12
5	16	0	0	0	16	868	0	0	0	868	54947	0	0	0	54947	16.31
6	0	5	128	0	133	0	10	256	0	266	0	694	18412	0	19106	5.67
7	0	256	284	20	560	0	256	284	20	560	0	24421	34069	2511	61001	18.10
TOTAL	95	262	440	20	817	4009	278	886	20	5193	235776	25747	72941	2511	336975	100

2.3 DEMAND SIDE BASELINE

This section provides information on thermal energy consumption in the Town of Handlova in 1992. Consumption is provided by major fuel form and by the defined sectors. For the purpose of this study, the energy consumption data can be deemed to be reasonably accurate. In some instances, such as coal consumption in residential homes, the estimation had to be supported by calculations. Consumption data for each fuel type were developed as follows:

Solid fuel consumption for other than Heating Plant use was estimated based on limited data on deliveries from the coal distribution company (Uholne Sklady) and from coal mine information on employee free coal deliveries. Calculations were used to support the assumptions made. The coal consumption and the coal quality data (heating value) for the Heating Plant fuel were obtained from the Heating Plant accounting files.

Natural gas consumption data were obtained from the billing records of the local gas utility (Slovensky Plynarensky Podnik Prievidza). These records are well maintained and provided good quality data.

Electrical consumption data is available from metered consumption records for individual customers. Each living unit is metered separately. This data includes several end-uses (space heating, hot water, appliances, etc.). An estimate was made of the percentage used for space heating and water heating.

District heat energy consumption was developed from data provided by the Heating Plant. Energy delivery metering is performed for billing purposes by the Heating Plant on the primary side of the Heat Exchanger Stations. Steam flow and temperature is measured, return condensate is assumed at 40 deg C and the condensate mass flow is assumed the same as steam flow. Such measurement does not provide accurate energy consumption data. A simultaneous metering of energy consumption by recently user-installed metering on residential buildings had shown up to a 18% difference between the heating plant and the end-user measurements. Losses in secondary distribution, accuracy of measurement and assumed fixed condensate temperature are to blame for the differences. A comparison of both measurements for the first three months (1/1/93 through 31/3/93) is shown in Table 2.2. This indicates that there may be some inaccuracy in the energy consumption data used. However, it is beyond the scope of this study to resolve this problem. The Heating Plant data were used in this study.

The fuel input to produce the thermal energy required by the town is summarized by the location of conversion and by the type of fuel in Table 2.3. On-site consumption refers to the conversion of fuel to heat and/or hot water within the individual living space, e.g. single family dwelling. Boiler House consumption refers to the conversion in boilers serving large single buildings or groups of buildings. District Heating consumption refers to the fuel input to the Heating Plant boilers.

Table 2.2 - Heating Plant/User Energy Consumption Metering Comparison

HX Station	Heating Plant Measurement [GJ]	Building Measurement [GJ]	Losses in Sec. Distr.		Total Space Heating [GJ]	Water Heating [GJ]	Total Building [GJ]	Difference	
			[GJ]	[%]				[GJ]	[%]
1	23826	17979	1618	9.0	19597	3681	23278	548	2.30
2	13744	10797	971	9.0	11768	1574	13342	402	2.92
3	4660	3115	214	6.9	3329	489	3818	842	18.07
4	20520	17261	1208	7.0	18469	1754	20223	297	1.45
5	45461	31462	2202	7.0	33664	6034	39698	5763	12.68
7	2810	2208	155	7.0	2363	50	2413	397	14.13
8	8732	6327	443	7.0	6770	8129	8129	603	6.91
Total	119753	6811	6811		95960	14941	110901	8852	7.39

Table 2.3 - Total Primary Fuel Input for the Production of Heat Energy, 1992

Place of Consumption	Coal [GJ]	Gas [GJ]	Electr. Energy [GJ]	Total	
				[GJ]	[%]
On-Site	29,599	67,000	2,884	99,483	3.41
Boiler Plants	11,080	4,737	0	15,817	8.94
Heating Plant	709,283	109,027	0	818,310	87.65
TOTAL	749,962	180,764	2,884	933,610	
%	80.33	19.36	.31		

This table shows that approximately 88% of the fuel input in the town is consumed by the Heating Plant and that approximately 80% of the fuel input is in the form of solid fuel - coal.

The utilization of the 933,610 GJ of primary energy contained in the fuel input is shown in Table 2.4.

Table 2.4 - Primary Heat Energy Utilization, 1992

Energy Use	Consumption [GJ/Year]	[%]	District Heat Only	
			[GJ/Year]	[%]
Space & Water Heating Residential	331,340	35.5	251,033	30.7
Non-Residential	109,605	11.8	92,054	11.3
Industrial	107,671	11.5	107,671	13.1
Direct Heat Losses Heat Plant	275,778	29.5	275,778	33.7
Primary Distr.	91,774	9.8	91,774	11.2
Other Non-DH Conversion Losses Residential	15,062	1.6	0	
Non-Residential	2,380	0.3	0	
TOTAL	933,610	100	818,310	100

It can be seen in Table 2.4 that 35.5% of the primary energy is used for space and water heating in the residential sector, 23% is used by the other sectors and 39.3% is lost in the heating plant and in the primary distribution system. Only about 2.2% of the primary energy is being lost in the non-District Heating conversion losses. Figure 2.7 illustrates the thermal energy flow in district heating system.

Figure 2.7 - District Heat Energy Flow

2.3.1 Energy Consumption By Sectors

Thermal energy consumption in Handlova is used almost exclusively in all sectors for space and water heating. Energy consumption by sectors and fuels is summarized in Table 2.5.

Table 2.5 - Energy End Use by Sectors and Fuels

FUEL	SECTORS			TOTAL	
	Residential	Non-Residential	Industrial	[GJ/Year]	[%]
LOCAL:					
Coal	29,599	0	0	29,599	5.2
Gas	66,950	50	0	67,000	11.9
Electr.	1,200	1,684	0	2,884	0.5
BOILER HOUSES:					
Coal	0	11,080	0	11,080	2.0
Gas	0	4,737	0	4,737	0.8
DISTRICT H	251,033	92,054	107,671	450,758	79.6
TOTAL	348,782	109,605	107,671	566,058	100
[%]	61.6	19.4	19.0	100	100

Nearly 62% of the net delivered energy (fuel input less losses in conversion and transit) is consumed by the residential sector. More detailed energy consumption data are presented in the following subsections. Industrial consumption represents about 19% and the non-residential sector also about 19%. District Heat is the major energy source for space and water heating, representing 79.6% of the total energy consumption.

2.3.1.1 Residential Sector Energy Consumption

Data on the residential sector space heating and water heating are presented in Table 2.6 and Table 2.7 respectively. For each of the seven identified building types, the energy use, heated area and Energy Utilization Intensity (EUI) are shown for each of the fuel types. Space heating accounts for approximately 83% of the consumed energy and water heating for 17%.

**Table 2.6 - Residential Sector Space Heating Energy Consumption
By Building Type and Fuel**

Bldg. Group	Energy Use [GJ/year]				Total	Heated Area By Fuel				Heated Area Total	Energy Use Intensity [GJ/m ²]				Energy Use Intensity
	Distr.	Coal	Gas	Electr.		Distr.	Coal	Gas	Electr.		Distr.	Coal	Gas	Electr.	
1	0	0	9065	0	9065	0	0	12517	0	12517	0.000	0.000	0.724	0.000	0.724
2	63552	397	5508	0	69457	70471	632	7943	0	79046	0.902	0.628	0.693	0.000	0.879
3	74900	0	0	0	74900	89719	0	0	0	89719	0.835	0.000	0.000	0.000	0.835
4	19106	0	0	0	19106	20639	0	0	0	20639	0.926	0.000	0.000	0.000	0.926
5	46171	0	0	0	46171	54947	0	0	0	54947	0.840	0.000	0.000	0.000	0.840
6	0	300	10931	0	11231	0	694	18412	0	19106	0.000	0.432	0.594	0.000	0.588
7	0	19335	23579	900	43814	0	24421	34069	2511	61001	0.000	0.792	0.692	0.358	0.718
TOTAL	203729	20032	49083	900	273744	235776	25747	72941	2511	336975					

**Table 2.7 - Residential Sector Water Heating Energy Consumption
By Building Type and Fuel**

Bldg. Group	Energy Use [GJ/year]				Total	Heated Area By Fuel				Heated Area Total	Energy Use Intensity [GJ/m ²]				Energy Use Intensity
	Distr.	Coal	Gas	Electr.		Distr.	Coal	Gas	Electr.		Distr.	Coal	Gas	Electr.	
1	0	0	2265	0	2265	0	0	12517	0	12517	0.000	0.000	0.181	0.000	0.181
2	6266	98	969	0	7332	70471	632	7943	0	79046	0.089	0.154	0.122	0.000	0.093
3	23505	0	0	0	23505	89719	0	0	0	89719	0.262	0.000	0.000	0.000	0.262
4	4512	0	0	0	4512	20639	0	0	0	20639	0.219	0.000	0.000	0.000	0.219
5	13020	0	0	0	13020	54947	0	0	0	54947	0.237	0.000	0.000	0.000	0.237
6	0	5	2176	0	2251	0	694	18412	0	19106	0.000	0.108	0.118	0.000	0.118
7	0	1995	2414	300	4709	0	24421	34069	2511	61001	0.000	0.082	0.071	0.119	0.077
TOTAL	47303	2168	7824	300	57595	235776	25747	72941	2511	336975					

2.3.1.2 Non-Residential Sector Energy Consumption

The energy demand by the non-residential sector is presented in Table 2.8. The District Heat is the largest source of thermal energy and represents 84% of the total energy consumption by this sector. The largest single energy demand group is Education (local schools), representing 47.1% of the sector demand.

**Table 2.8 - Non-Residential Space and Water Heating Energy Consumption
By Building Type and Fuel**

GROUP	LOCAL			BOILER HOUSE		DISTRICT HEAT	TOTAL	
	Coal	Gas	Electr.	Coal	Gas		[GY/yr]	[%]
NonRes-1 Education	0	0	1,097	5,000	0	45,565	51,662	47.1
NonRes-2 Culture	0	0	0	0	0	5,312	5,312	4.8
NonRes-3 Health	0	0	200	0	0	19,531	19,731	18.0
NonRes-4 Sport	0	0	0	6,080	0	5,850	11,930	10.9
NonRes-5 Offices	0	0	0	0	0	928	928	0.8
NonRes-6 Services	0	50	387	0	4,737	9,687	14,861	13.7
NonRes-7 Hotels	0	0	0	0	0	5,181	5,181	4.7
TOTAL	0	50	1,684	11,080	4,737	92,054	109,605	100
[%]	0	.1	1.5	10.1	4.3	84.0	100	100

2.3.1.3 Industrial Sector Energy Consumption

The industrial sector in Handlova uses exclusively District Heating System as a source of thermal energy for space and water heating. Table 2.9 below shows the industrial energy users and the amount of energy they consume.

Table 2.9 - Industrial User Energy Consumption

USER	DISTRICT HEAT	
	[GJ/Year]	[%]
Coal Mine	76,736	71.3
Chemika	5,684	5.2
Lahke Konstrukcie	19,177	17.8
Slovenka	2,114	2.0
AMK	188	0.2
CSD Station	2,079	1.9
State Farm	1,693	1.6
TOTAL	107,671	100

2.4 DEMAND FORECAST

This section develops the three variants for energy demand growth used for the study. Assuming a 25 year life for the heat supply equipment to be built by 1997, the energy demand was projected to the year 2022.

Variant 1:

This variant assumes no change in thermal energy demand in both the residential and non-residential sectors and assumes detachment of the industrial sector from the District Heating system.

Under this variant, energy demand will, for space heating and water heating in both the residential and non-residential sectors, remain on the 1992 level of 458,387 GJ/Year. The industrial sector will be served by its own sources, but the annual consumption would remain the same at 107,671 GJ/Year. This variant represents the lowest possible energy demand.

Variant 2:

This variant was based on the Urban Development Plan for the Town of Handlova performed by AGS Atelier for the Town Hall in 1993. This study predicted the town population would increase from 18,332 in 1992 to 19,500 in a year 2010. By extrapolating the growth curve at a somewhat cautious rate, the town population was predicted to be 19,750 in 2022. This is a population increase of approximately 1400 persons, or 5.22 %. Industrial activity in this variant was assumed to stay at the 1992 level with no increase in thermal energy demand.

Under these assumptions, energy demand for space heating and water heating would increase by 18,206 GJ, or 3.22% of the town energy demand in 1992. Increase in District Heating Demand is assumed 11,268 GJ, or 4.5%

Variant 3:

This variant assumed greater population growth and increased industrial activity. Population growth was assumed to be 6% greater than predicted in Variant 1, for a total increase of 11.22% or 2057 persons. Industrial thermal energy demand was assumed to grow by 20% from the 1992 level.

For this variant, energy demand for residential space heating and water heating would increase by 39,133 GJ, or 6.91%, and industrial thermal energy demand would increase by 21,534 GJ, or 3.80%. Total energy demand would increase by 60,667 GJ, or 10.71% of the total demand in 1992. The District Heating Demand would increase by 24,247 GJ (4.28%) due to population growth, and 23,287 GJ (4.11%) due to industrial growth.

3. BUILDING SECTOR EFFICIENCY ASSESSMENT

This section presents the estimated efficiency resource in the residential and non-residential buildings and the industrial sectors. Section 3.1 describes the efficiency measures considered. Section 3.2 lists efficiency measures not considered. The technical analysis approach employed to estimate the efficiency resource is described in Section 3.3 and the economic analysis approach in Section 3.4. The building and industrial sector efficiency resource is presented in Section 3.5. Section 3.6 provides a brief discussion of the sensitivity of presented results on some input parameters.

3.1 EFFICIENCY MEASURES

Fifty energy conservation opportunities (ECOs) were considered for evaluation for the residential and non-residential building stock in Handlova. Of these, 24 ECOs were determined to be applicable to more than one building group and were analyzed with respect to energy efficiency potential, cost and availability on the Slovak market. A brief description of the ECO's follows:

3.1.1 Energy Efficiency Measures Considered

The 24 efficiency measures considered are presented by category of application: building envelope; domestic water heating; heating system; and ventilation and heat recovery.

3.1.1.1 *Building Envelope Measures*

Insulate Building Exterior Side Walls. Insulation installed on the exterior walls of the building improves the R-value of the building shell, and therefore, decreases the heat loss through the walls. Depending on the method used and material thickness, the R-value of the walls may be increased by 0.8 to 1.4 m²K/W. Exterior insulation also results in increased exterior zone temperature by as much as 3 to 5°C, thus indirectly reducing overheating of the building core space when building temperatures are properly adjusted. An additional positive effect is the elimination of moisture condensation on the interior side of the walls in cold weather. Although this ECO is widely used, poor workmanship causes the results to be less than expected in many installations.

Insulate Top Floor Ceiling. The top floor ceiling in many building types is poorly insulated, which results in a substantial heat loss from the top floor and higher space heat to compensate for this often causes overheating of the building core space. Insulating the top floor ceiling from the interior side is applicable to buildings with a flat roof, where adding insulation from the exterior side would require extensive effort to keep the insulation protected from the weather. The ceiling insulation is designed not to upset the appearance of the apartment interior and increases the R-value by 2.1 to 3.0 m²K/W.

Insulate Attic. Insulating the attic is a widely used method of reducing heat loss in a building with an attic space. The insulation may be installed in many different ways, such as blown into the attic, laid on the top of the ceiling, poured in a liquid state, etc. Fiberglass blankets or boards, and styrofoam boards are most commonly used. Depending on the method used, the R-value can be increased by as much as $3.5 \text{ m}^2\text{K/W}$.

Insulate Floor Above Basement. Insulating the floor above a cold basement or crawl space improves the floor R-value as well as occupant comfort, which typically results in a lower thermostat setting. Many floor covering materials with good thermal insulation properties are available. For floors with an air cavity, blown-in cellulose-based insulation is also available.

Weatherstrip Elevator Penthouse, Stairway, Doors and Windows. Reducing infiltration by sealing cracks around doors and windows in unheated spaces, such as stairways will increase the temperature in such spaces, thus reducing the heat loss from the heated space to unconditioned space. Eight to ten floor apartment buildings, which are approximately 22 to 28 meters high, can have a substantial draft through the stairway due to the stack effect. Sealing cracks in the upper part of the stairway substantially can reduce infiltration. The temperature on cold days may be increased by as much as 4°C .

Weatherstrip Windows and Doors. Sealing cracks around windows and doors is a simple way to reduce infiltration to occupied spaces; thus reducing the energy required to heat ambient air entering the heated space. Windows, especially in older apartment buildings, which fit poorly result in significant levels of infiltration. In order to be functional, seals have to be properly installed and maintained.

Install Revolving or Double Door in Building Vestibule. Revolving or double doors reduce infiltration of ambient air into the unconditioned lobby or entrance space of the building as people enter or leave and also provide better sealing, thus increasing the unheated space temperature. Low thermal insulation of internal walls may have a significant effect on heat loss from the heated space. Revolving doors are especially good for high traffic entries, such as stores, banks, etc. Double doors are good for apartment buildings.

Install Triple Pane Windows. The fenestration area of the residential structures found in the Slovak Republic can be a significant fraction of the building envelope area. In some buildings, such as the T-06-B, the window area is 24% of the building shell surface. The U-value of the windows is 2.7 to 4.2 times greater than for walls. Subsequently, the heat loss through the windows are significant. Triple pane windows with high performance glass provide an improved R-value for the fenestration area and reduce heat loss through the glass. The U-value of a triple pane window is typically $1.6 \text{ m}^2\text{K/W}$, whereas the regularly used window has U-value of 2.6 to $2.8 \text{ W/m}^2\text{K/W}$. It is also assumed that new windows will provide a tighter fit resulting in lower infiltration.

Install Storm Windows. An additional layer of glass mounted in its own frame, either on the inside or outside of the existing window improves the total R-value of the fenestration area and reduces the infiltration. Storm windows may be installed seasonally or permanently. Compared with triple pane windows, this alternative offers smaller improvements of R-value, but at a lower installed cost.

Install Heat Reflectors Behind Each Radiator or Heater. Heat reflectors deflect the radiant portion of the heat otherwise absorbed by the wall (in most cases an exterior wall) into the heated space. The wall temperature behind the radiator is lowered and the R-value of the part of the wall covered by reflector is increased, thus reducing the heat losses. This is in many cases a "do-it-yourself" inexpensive job.

Remove Draperies from Radiator. Radiators are typically located under the windows and covered by window draperies, especially during the evening and night hours. The draperies then form an air channel which forces the heated air leaving the radiator to flow closer to the window and thus create a local environment with higher temperatures. This increases the heat loss through the window. Removing draperies does not require any investments and will be most likely done by the occupant, providing he/she is responsible for the heating bill. An educational effort is required to implement this change.

3.1.1.2 Domestic Water Heating

Install Low-Flow Shower Heads. Low-flow shower heads are available on the market and can reduce of the required water flow by 17% to 50% without sacrificing user comfort. These shower heads create the same "massaging" effect as high water flow models. Shower heads are easy to install and do not require plumbing changes.

Install Flow Restrictors in Faucets. Reduce the flow of water in bathroom and kitchen faucets for washing, shaving, dish-washing etc. Installing flow-restricting orifices is simple and inexpensive and can be done by the occupant. The water consumption for the purposes described above can be reduced by up to 50%.

Insulate Hot Water Pipes in Unconditioned Spaces. Hot water pipes are, in most cases, already insulated. However, the old insulation is typically insufficient, damaged or otherwise not functional. Additional or new insulation lowers the hot water heat loss.

Install Hot Water Flow Meters. This ECO assumes that the occupant is responsible for the hot water bill. Hot water flow meters, installed visibly at locations of hot water use, serve not only as energy allocation devices, but also makes the occupant much more aware of hot water consumption. Occupant awareness of energy use has proven to be an effective energy saver in many installations throughout Europe and the U.S. This ECO has been shown to result in a 7% energy reduction.

3.1.1.3 Heating System

It is important to note that the heating systems found in multi-family residential building structures are designed with main branches and risers serving rooms in several apartments. For example, corner bedrooms on all floors are served by one riser, while comparably located living rooms on all floors are served by another riser. Without costly plumbing changes, this design does not allow control of the heating by a single zone valve for each apartment. Heat metering is also difficult for the same reason. Multiple zone valves and multiple heat allocation devices have to be used.

Balance Heating System Using Existing Valves. A properly balanced heating system should supply the correct amount of heat to each conditioned space to keep the temperature in that space within comfortable limits. In many cases heated spaces with higher heat losses, for example corner apartments, are receiving less than the required heat due to a poorly designed heating system. In order to keep the temperature within acceptable limits, the rest of the building, especially the core portion, is greatly overheated.

Manual regulating valves are normally installed on each radiator, but if not used for a prolonged period of time, they usually leak. The occupant is not willing to take that risk and would rather open a window to lower the room temperature. In many cases, the fact that the occupant is not accountable for the heating bill exaggerates this problem.

In some buildings the system balancing can be done by using existing balancing valves installed on risers or branches of the plumbing system. It is a very effective, low cost ECO. Balancing should be done periodically.

Install Balancing Valves on Each Radiator. This improvement is applicable to the systems where balancing valves were not originally provided. Balancing valves installed on each radiator will allow more accurate distribution of the heat throughout the building. However, this measure does not provide the occupant the ability to control the room temperature.

Install Thermostatic Radiator Valves (TRVs). Installing a TRV on each radiator provides the user with the capability to control the temperature within reasonable temperature fluctuations. In order to be an effective ECO, the TRVs have to be installed together with heat allocation devices and a building GJ-meter for proper allocation of heating cost. TRVs alone do not provide an incentive for savings, and in many cases, they are left fully open all the time. Controlled room temperature (and allocating energy cost) also discourages the occupant from unnecessarily opening windows, thus significantly reducing the infiltration rate.

Install Zone Valves on Each Radiator and Install Central Thermostat with "ON Time Counter" in Each Apartment. Zone valves, installed on each radiator and controlled by a single thermostat located centrally in the apartment, provide excellent temperature control with good accuracy. Temperature in the apartment is controlled more tightly than with TRVs, and the

operation of the thermostat is more "user-friendly". A thermostat with an electronic "On-Time counter" can be used instead of cumbersome evaporative type heat allocation devices. The use of a building level GJ-meter is also assumed with this measure.

Install Zone Valves on Each Radiator and Install Central Programmable Thermostat with TOD and "ON-Time" Counter in Each Apartment. An additional feature of this ECO, as compared to the prior ECO, is the capability to program the thermostat to maintain the room temperature based on occupancy for a one or two week period. Lowering the temperature during the unoccupied period can save a significant amount of energy. The use of a building level GJ-meter is also assumed with this measure.

Install Building Energy Management System (EMS). An Energy Management System tailored for a specific building or group of buildings provides the most energy savings in this category. An apartment building consisting of 40 to 50 living units can save as much as 48% of the space heating energy when controlled by an EMS. The EMS controls the energy source to provide optimal temperature of the heating media and controls the space temperatures allowing occupants to set the temperature in each zone. The EMS also collects energy use information and, for billing purposes, is accessible by the utility through the phone line. The cost of such systems may be prohibitive at existing energy costs in Slovakia.

3.1.1.4 Ventilation and Heat Recovery

Install Heat Recovery Vent System in Basements. Typically, the basements in apartment buildings serve as storage spaces for bicycles and baby-carriages, laundry rooms, etc. The basement is vented through permanently open ventilation windows. Installation of a heat recovery unit, which provides fresh air to the storage spaces at 90% heat recovery efficiency, (providing all cracks, openings for piping, etc. and broken windows are sealed) may increase the basement temperature during cold days by as much as 3°C.

Install Waste Water Heat Recovery Heat Exchanger. Utilizing the heat from waste water for preheating the cold water entering the hot water heater results in a sizable reduction of the heater capacity required for water heating. Apartment buildings with central water sewage pipes are the ideal candidates for such an ECO, but this method is applicable to all building groups. Up to 25% of heat required for water heating can be saved.

Install Bath/Kitchen Vent Heat Recovery Heat Exchanger. Open ventilation ducts from kitchens and bathrooms in apartment buildings cause unnecessary infiltration. Installing air dampers which operated with the exhaust fans and installing heat recovery heat exchangers prevent unnecessary infiltration and provide controlled air return with up to 90% heat recovery.

3.1.2 Efficiency Measures Not Considered

A number of Energy Conservation Opportunities identified were not considered for further evaluation because: they did not offer an adequate level of efficiency improvement potential; they could only be addressed through a more focused data collection effort beyond the scope of this effort; they would address only a small part of the building stock; and/or they were applicable to the energy supply side. The ECO's applicable to residential buildings that were not considered are presented in this subsection by ECO category.

3.1.2.1 *Building Envelope*

Insulate roofs with no attic space. Installing exterior insulation on flat and tile roofs is expensive, as this essentially requires the installation of a new roof and the need to ensure the roof is waterproof. Additional data collection would also have been required to evaluate this measure.

Internal insulation of walls. This measure is expensive to implement, affects the appearance of the interior, and imposes a considerable burden on the occupant.

Insulate roof panel cavities. Adding insulation may reduce or eliminate cavity ventilation and possibly create moisture condensation inside the cavity.

Insulate exterior walls of historical buildings and single and two family homes. This was rejected as unacceptable for the historic buildings and too expensive for the other building groups.

Insulate apartment building exterior walls having windows. This was considered too expensive to do in a manner that would be acceptable from an appearance standpoint.

Insulate internal walls between heated and unheated spaces (stairways). This was not considered to provide sufficient efficiency improvement and would have required additional data collection and analysis to evaluate.

Insulate basement perimeter above the ground. This was not considered to provide sufficient efficiency improvement and would have required additional data collection and analysis to evaluate.

Repair leaking roofs which cause wet walls and insulation to become ineffective. This was not considered to be a common measure and would have required additional data collection and analysis to evaluate.

3.1.2.2 Domestic Water Heating

Replacing electric water heaters with gas or LP gas water heaters. This was not considered to be a common measure and would have required additional data collection and analysis to evaluate.

Insulate hot water pipes in conditioned space. This was not considered to be a cost effective measure and would have required additional data collection and analysis to evaluate.

Lower hot water temperatures. Domestic water temperature is maintained at 55°C and lowering the temperature may introduce a health hazard.

Use of cold water for laundry washing. Detergents effective in cold water are not yet available.

Install overhead showers to promote use of showers. Bathing in a tub is common and would require significant effort to effect a lifestyle change.

3.1.2.3 Heating System

Re-work building heating system plumbing. Re-design and re-work the building heating system to allow a single control and energy consumption measurement point for each apartment was not considered cost-effective.

Replace or improve existing gas or coal room heaters. This was not considered to be a common measure and would have required additional data collection and analysis to evaluate.

Insulate boilers and water heaters to reduce standby losses. This would have required additional data collection and analysis to evaluate.

Fuel switching. A supply related measure beyond the scope of this analysis.

Replacing circulating pumps and temperature and flow control components with high performance parts. This would have required additional data collection and analysis to evaluate.

Insulation of conduits between boiler or heat exchanger and building. This would have required additional data collection and analysis to evaluate.

Application of heat pumps for space and water heating. The Czech climate would require a ground source heat pump for efficient operation. Additional data collection and analysis would have been required to evaluate heat pump water heaters.

Application of thermal storage. Too expensive and additional data collection and analysis would have been required to evaluate.

Application of non-conventional energy sources, such as solar, geothermal, waste heat from local industry etc. This was not considered to be a common measure and would have required additional data collection and analysis to evaluate.

Improved maintenance (cleaning) of the heat sources, such as local boilers, room heaters, etc. This would have required additional data collection and analysis to evaluate.

Installation of supply water temperature reset control systems. This would have required additional data collection and analysis to evaluate.

3.1.2.4 Ventilation and Heat Recovery

Installation of indoor air quality ventilation/heat recovery units. High efficiency heat recovery ventilation units in each room or apartment would introduce fresh air into the space with approximately a 90% heat recovery rate. The cost of such units was not considered cost-effective.

Install combustion air preheating for local heaters. A supply related measure beyond the scope of this analysis.

3.1.3 Summary of Efficiency Measures Considered

Table 3.1 summarizes the 24 efficiency measures considered by cost-per-unit of application and measure lifetime.

3.2 ANALYSIS APPROACH

The 24 measures were analyzed for the seven residential building types by the four fuel and equipment types identified: on-site gas, on-site coal, district heat, and electricity. Measures were not analyzed for electric space heating as this represents only 0.5% of the total heating load. Measures were considered for application to electric water heat.

A possibility not analyzed is that base space and water heat use may increase due to increases in living standards. Should base use increase, the efficiency potential will also increase.

The weather data required for computation of building loads and energy savings were not available for Handlova, Slovakia, so weather data for Prague, Czech Republic was used for the load calculations. Saving potential results were then adjusted based on average monthly temperature ratio of both locations.

The technical analysis approach for developing the estimated per measure efficiency improvement for each measure category is described in Section 3.2.1. The economic analysis method is discussed in Section 3.2.2.

3.2.1 Technical Analysis Method

The analysis method applied to each category of efficiency measures is described in this subsection.

3.2.1.1 Analyses of Building Envelope Measures

The ASEAM3 (A Simplified Energy Analysis Method, Version 3.0) computer program for simulating heat losses in buildings based on procedures recommended by the American Society For Heating, Refrigeration and Air Conditioning Engineers (ASHRAE) Fundamentals was used for the analysis. The program provides prediction of maximum heat loads, annual energy consumption, and the effect of other factors on building heat loads (occupancy, lighting, appliances usage, insolation, etc.)

Baseline and post-measure installation heat loss was calculated for each measure. The difference between the two heat loss values is the energy savings. The development of the baseline building heating loads for each building type required making several assumptions. The most important were infiltration rates, internal temperatures in different locations, and occupancy and equipment schedules. These assumptions were based on recommended values, previous experience and information gathered by survey (number of opened windows in apartments in occupied and unoccupied periods).

Table 3.1 - Efficiency Measures Considered and Estimated Per Unit Cost and Lifetime

Number	Energy Saving Option Description	Unit	Cost [\$/Unit]	Lifetime [Years]
Building Envelope				
1	Insulate Exterior Side Walls	m ²	700-800	30
2	Insulate Top Floor Ceiling	m ²	700	30
3	Insulate Attic	m ²	385	30
4	Insulate Floor Above Basement	m ²	120	30
5	Weatherstrip Elevator Penthouse, Stairway, Doors and Windows	m	40	10
6	Weatherstrip Doors and Windows	m	40	10
7	Install Revolving or Double Door in Building Vestibule	Unit	30,000	30
8	Install Triple Pane Windows	m ²	5409	30
9	Install Storm Windows	m ²	600	30
10	Install Heat Reflectors Behind Each Radiator or Heater	m ²	148	5
11	Remove Draperies from Radiator		0	
Domestic Water Heating				
12	Install Low-Flow Water Heads	Unit	250	10
13	Install Flow Restrictors in Faucets	Unit	70	5
14	Insulate Hot Water Pipes in Unconditioned Spaces	m	158	15
15	Install Hot Water Flow Meters	Unit	900	30
Heating System				
16	Balance Heating System Using Existing Valves	Flat	400	5
17	Install Balancing Valves on Each Radiator	Unit	350	15
18	a. Install Thermostatic Radiator Valves	Unit	650	15
	b. Install Heat Allocators/Meters	Unit	100	1
	c. Install Building Level GJ Meter	Unit	10000-40000	30
19	a. Install Zone Valves on Each Radiator	Unit	330	15
	b. Install Central Thermostats with On-Time Counter in Each Flat	Unit	2300	15
	c. Install Building Level GJ Meter	Unit	24000-46000	30
20	a. Install Zone Valves on Each Radiator	Unit	330	15
	b. Install Central Programmable Thermostats with On-Time Counter in Each Flat	Unit	6120	15
	c. Install Building Level GJ Meter	Unit	24000-46000	30
21	Install Building Energy Management System (EMS)	Unit-Radiator	7000	30
Ventilation and Heat Recovery				
22	a. Install Heat Recovery Vent System in Basements	Unit	7600	10
	b. Weatherstrip Basement Windows and Doors	m	40	10
23	Install Waste Water Heat Recovery Heat Exchanger	Unit	10200-126000	15
24	a. Install Bath/Kitchen Vent Heat Recovery Heat Exchanger	Unit	9050	10
	b. Install Back-Flow Damper in Kitchen/Bath Vent Duct	Unit	350	15

In the modeling of each ECO, only the pertinent value describing the given ECO was changed in the model. Insulation of walls, ceilings and floors were modeled by lower U-values; weatherstripping windows was modelled by lowering the infiltration coefficient; installing triple pane and storm windows was accomplished by lowering the window U-value; weatherstripping stairway windows and doors, and installing entrance double doors was modelled by increasing the unheated space temperature; and installation of a heat recovery unit for the bath/kitchen was accomplished by reducing the infiltration rate.

3.2.1.2 Analyses of Water Heating Measures

Energy saving calculations for low flow shower heads and faucet flow restrictors are based on statistical information regarding the use of hot water in the Czech Republic, statistical information on hot water use by purpose (dish-washing, shower, laundry, etc.), and manufacturers performance information. The calculation of energy savings is obtainable by insulating the hot water pipes in unconditioned spaces is based on lowering heat losses by additional pipe insulation with improved R-value or replacement of existing insulation with high performance materials. Due to the limited nature of this project, exact length and sizes of pipes could not be determined, but rather were estimated for each building group based on typical plumbing designs.

3.2.1.3 Analyses of Building Heating System

All ECOs analyzed in this category provide improved energy management in the building. Installation of temperature control devices (TRV, TS, EMS) in conjunction with installation of energy cost allocation equipment provide building occupants with an incentive to reduce energy consumption. The use of a programmable thermostat also improves the use of setback during unoccupied periods. The combination of better energy management and distribution within the building and the ability of motivated occupants to lower the energy consumption results in two effects:

- room temperature is kept at the lowest acceptable level
- windows are opened only to maintain acceptable indoor air quality and not for temperature control.

The computerized calculations used for the building heating system energy saving measures were also derived from the procedures recommended by the (ASHRAE) Fundamentals. For each measure, both the baseline and post-measure installation heat loss was calculated. The difference between the two heat loss values is then the energy use reduction. For each ECO analyzed, the temperatures and infiltration rates were estimated based on the performance of the proposed equipment and expected occupant behavior. In general, more accurate equipment and more motivated occupants will produce lower temperatures and lower infiltration rates. The temperatures were not assumed to drop below accepted comfort limits (for example, 21 C in living rooms and 18 C in bedrooms).

3.2.1.4 Analyses of Ventilation and Heat Recovery Measures

The energy saving calculations developed for the heat recovery applications were again derived from procedures recommended by the ASHRAE Fundamentals. Inputs to the calculations include properties and mass flow of media from which the waste heat is recovered and manufactures performance characteristics for the heat recovery equipment.

3.2.2 Economic Analysis

This section presents the economic analysis metrics, the economic assumptions, and the approach employed to assess the economic performance of the efficiency measures.

3.2.2.1 Analysis Metrics

The ECOs described in the previous section were analyzed in a number of ways, with the intent of presenting a variety of what are called "analysis metrics" for measuring the attractiveness of an ECO as an investment. A number of economic metrics commonly used to evaluate measure effectiveness are present value, net present value, simple payback, and levelized energy cost. These methods are described in this section.

Present Value and Net Present Value. Present values account for the fact that a crown today is worth more than a crown tomorrow, for two principal reasons: general price inflation and the time value of money. In the face of general price inflation, the purchasing power of a crown declines over time, and since the true value of money lies in what it is capable of purchasing, inflation causes its value to decline. The time value of money refers to the fact that even in the absence of general price inflation, money received sooner is preferred to money received later.

It is this preference for consuming sooner rather than later that leads to the existence of positive rates of interest, even in the absence of price level inflation. Individuals and firms are willing to pay a premium to obtain goods and services sooner rather than later: the premium they are willing to pay is the "real rate of interest". The market rate of interest, or the "nominal" rate, is the real rate plus the rate of inflation (this is a slight simplification). As an example, 100 SK received two years from today is worth only 82.64 SK today, assuming a ten percent interest rate. Conversely, 82.64 SK invested today at ten percent per annum yields 100 SK two years later.

The costs and the benefits of an efficiency investment occur at different periods of time, which must be accounted for in the analysis. The metric selected for this is net present value to calculate the present value of all of the costs associated with an ECO, less the present value of all of the benefits of the ECO. The NPV is a measure of the total value of the energy efficiency investment and is used to define the cost-effectiveness of an ECO: a negative NPV means that the costs of an ECO outweigh its benefits, while a positive NPV means that the benefits are greater than the costs. The higher the NPV, the better.

Simple Payback. The most basic analysis metric used is the simple payback period, which, in its simplest form is calculated by dividing the installed cost of the ECO by the value of the annual energy savings. The simple payback period is then the number of years required for the savings resulting from an investment in energy efficiency to offset the cost of the investment: thus, the lower the payback period, the more attractive the investment.

In many analysis situations, this metric is too simplistic to be of much use. ECO's with future costs may be overvalued if these costs are not accounted for. Escalating fuel prices will undervalue the ECO. Simple payback does not enable ready comparison for measures having different useful lives. This method also does not account for the time value of money and may not be readily comparable with other investments using more sophisticated measures of value.

Levelized Energy Cost. A slightly more complex metric is the levelized energy cost (LEC), also called the cost of conserved energy, expressed in crowns per gigajoule. The LEC is the total cost of an ECO over the measure life, converted to an annual value (the installed cost is "levelized", from a lump sum into a series of equal annual payments), divided by the annual energy savings in gigajoules. The LEC is used to compare the cost of the energy resource obtained through conservation with the cost of energy from other sources, such as purchasing energy from the district heat system, or purchasing coal for use in on-site boilers. The LEC allows the calculation of a supply curve for energy efficiency. The supply curve shows the total annual energy conservation resource available at any given cost per unit of energy conserved. Using the supply curve, it is possible to determine the conservation resource available for less than or equal to the cost of competing resources, such as coal, district heat systems, or natural gas.

Economic Assumptions. Two types of economic analysis methods typically used are nominal and real. A nominal analysis is performed using current money values, reflecting the effects of inflation. The value of energy savings in 1993 is expressed in money with 1993 purchasing power, the value of energy savings in 1994 is expressed in money with 1994 purchasing power, and so on. The value of the energy savings continues to increase, because of inflation in the general level of prices. A real analysis expresses all money values in constant terms by removing the effects of inflation. In the case of this analysis, all values are expressed in 1993 currency values.

The implications of using a real analysis are the need to calculate a real discount rate, which is basically the interest rate after the effects of inflation have been removed. For the

purposes of this analysis, a simplification was used, whereby the real discount rate is calculated as the nominal interest rate minus the expected rate of inflation.

In driving the economic analysis, three sets of assumptions were employed for evaluating the cost-effectiveness of the efficiency measures by the economic metrics. These consist of base economic assumptions and three fuel price levels.

Base Assumptions. The base economic assumptions underlying the analysis are shown in Table 3.2.

Table 3.2 - Base Economic Assumptions for Analysis of Efficiency Measures

Nominal Discount Rate	17.5%
Expected Inflation	8.0%
Real Discount Rate	9.5%
Analysis Period	30 years

Alternate Fuel Prices. Energy prices are currently subject to some form of regulation and/or subsidy, both of which will be modified in the near future. In addition, district heating system will either have to be upgraded or replaced by the decentralized system. Each of these alternatives will result in different energy price. Therefore, the four fuel price levels were developed for investigation of the impact of likely changes in near term energy prices on the energy efficiency resource. This was done in conjunction with staff from the Town, Heating Plant, EGU, ZPZ and SEP. The prices are shown in Table 3.3.

Table 3.3 - Fuel Price Levels Used to Drive Analysis of Efficiency Resource and Sensitivity Analysis, by Fuel Type

FUEL TYPE	FUEL PRICE LEVEL [\$/GJ]			
	Level 1	Level 2	Level 3	Level 4
On-Site Gas	80.00	108.00	150.00	270.00
On-site Coal	55.00	80.00	100.00	150.00
Electricity	222.00	250.00	300.00	350.00
District Heat	165.00	210.00	270.000	300.00

Level 1 represents the current, still subsidized fuel prices. Level 2 corresponds to the removal of subsidies, Level 3 corresponds to a more aggressive and most likely fuel price increase, and Level 4 roughly corresponds to West European absolute and relative fuel prices. At all four levels, the price increases are assumed to happen at the time of implementing energy conservation technologies. The price of coal is assumed to increase by 2.7% annually over the general inflation rate; price of gas is assumed to increase by 2.85% over the general inflation rate to the year 2005 and 1.4% annually after that year. The price of electricity is assumed to increase by 6% over the general inflation. Level 3 prices were used for the analysis in this report.

3.3 BUILDING SECTOR EFFICIENCY ASSESSMENT RESULTS

This section provides the energy and economic assessment of the 24 building sector efficiency measures considered for the analysis. The method employed to assess the efficiency potential consisted of four steps. The first was to screen the individual measures by NPV -- measures having a positive NPV were retained for additional analysis. The second was to combine the measures to identify interactive effects in order to avoid double counting the efficiency potential and to deselect measures that reduced the NPV of selected bundles for individual building types. Third, the measure bundles and applicable individual measures were then evaluated for each residential building type to estimate residential sector efficiency potential. Fourth, the residential sector analysis results were extended to the non-residential buildings sector.

The following group of 7 measures having an interactive effect were selected for application:

1. Insulate Building Exterior Side Walls
2. Weatherstrip Elevator Penthouse, Stairway, Doors and Windows
3. Weatherstrip Windows and Doors
4. Install Revolving or Double Door in Vestibule
5. Install Storm Windows
6. Install Zone Valves on Each Radiator and Install Central Thermostats with 'On TimeCounter' in Each Apartment
7. Install Heat Recovery Vent System in Basements

Depending upon the building type, a subset of these items was selected based upon their combined performance. The following seven measures which did not exhibit interactive effects were also selected for application depending on their performance.

1. Install Heat Reflectors Behind Each Radiator or Heater
2. Remove Draperies from Radiator
3. Install Low-Flow Shower Heads
4. Install Flow Restrictors on Faucets
5. Insulate Hot Water Pipes in Unconditioned Spaces
6. Install Hot Water Flow Meters
7. Install Waste Water Heat Recovery Heat Exchanger

3.3.1 Baseline Efficiency Assessment

This section first presents the efficiency assessment using the base economic assumptions and Level 3 fuel prices for the residential and non-residential buildings sectors.

3.3.1.1 Residential Sector Baseline Efficiency

Table 3.4 provides the cost-effective space and water heat efficiency resource by residential sector building and fuel type for 1993 using the base economic assumptions and the Level 3 fuel prices.

The 147,381 GJ of cost-effective savings represents a 42% reduction in current residential sector energy consumption. This ranges from 3.33% to 43.43% of current use for building groups 1, 6 and 7, and 32.7% to 52.13% of current use for building groups 2 through 5. Residential district heating energy use can be cost-effectively reduced by about 46%, which represents over 78.8% of all of the cost-effective savings. Residential natural gas consumption can be reduced by almost 32%, accounting for almost 15% of the efficiency potential and coal consumption can be reduced by about 32%, which represents about 6% of the efficiency potential. Residential electricity use can be cost-effectively reduced by 3%, although this represents only .03% of total cost effective savings.

Table 3.5 provides the economic analysis of the residential sector efficiency resource presented in Table 3.4.

The residential sector cost-effective efficiency resource of 147,381 GJ annually, is expected to cost about 131.8 Million SK and have a net present value of 198.3 Million SK. The cost of conserved energy (the annualized cost divided by the annual energy use reduction) works out to an average of 136 SK/GJ for all fuels. While high rise apartment buildings (building types 2-5) supplied by district heat account for about 77.8% of residential sector heat and hot water energy consumption, they account for over 80% of the cost-effective efficiency resource. This 135 SK/GJ estimated cost of this resource appears to be very cost-effective when compared to the current price of 210 SK/GJ for district heat.

Table 3.4 - Residential Sector Cost-Effective Space and Water Heat Efficiency Resource by Building, Fuel and Equipment Type Using Base Assumptions and 1993 Fuel Prices

Bldg. Group	Fuel	Baseline Use (GJ)	Percent of Total Use	Cost Effective Savings Potential (GJ)	Cost Effective Savings as Percent of Use	Percent of Total Cost Effective Savings	Levelized Energy Cost (\$/GJ)
1	On-Site Gas	13330	3.82%	5789	43.43	3.93%	100.61
1	On-Site Coal	0	0.00%	0	0.00%	0.00%	
1	Electricity	0	0.00%	0	0.00%	0.00%	
1	District Heat	0	0.00%	0	0.00%	0.00%	
1	Total	13330	3.82%	5789	43.43%	3.93%	100.61
2	On-Site Gas	7260	2.19%	2553	33.51%	1.73%	81.70
2	On-Site Coal	659	0.19%	216	32.78%	0.15%	76.83
2	Electricity	0	0.00%	0	0.00%	0	
2	District Heat	69819	20.02%	24034	34.42%	16.31%	132.75
2	Total	78098	23.40%	26803	34.32%	18.19%	127.44
3	On-Site Gas	0	0.00%	0	0.00%	0.00%	
3	On-Site Coal	0	0.00%	0	0.00%	0.00%	
3	Electricity	0	0.00%	0	0.00%	0.00%	
3	District Heat	98405	28.22%	49150	49.95%	33.35%	155.97
3	Total	98405	28.22%	49150	49.95%	33.35%	155.97
4	On-Site Gas	0	0.00%	0	0.00%	0.00%	
4	On-Site Coal	0	0.00%	0	0.00%	0.00%	
4	Electricity	0	0.00%	0	0.00%	0.00%	
4	District Heat	23618	6.77%	12146	51.43%	8.24%	132.95
4	Total	23618	6.77%	12146	51.43%	8.24%	132.95
5	On-Site Gas	0	0.00%	0	0.00%	0.00%	
5	On-Site Coal	0	0.00%	0	0.00%	0.00%	
5	Electricity	0	0.00%	0	0.00%	0.00%	
5	District Heat	59191	16.97%	30857	52.13%	20.94%	140.29
5	Total	59191	16.97%	30857	52.13%	20.94%	140.29
6	On-Site Gas	15420	4.42%	3392	22.00%	2.30%	172.17
6	On-Site Coal	400	0.11%	108	27.06%	0.07%	175.30
6	Electricity	0	0.00%	0	0.00%	0.00%	
6	District Heat	0	0.00%	0	0.00%	0.00%	
6	Total	15820	4.54%	3500	22.13%	2.38%	172.27
7	On-Site Gas	30580	8.77%	9895	32.36%	6.71%	112.08
7	On-Site Coal	28440	8.16%	9198	32.34%	6.24%	74.07
7	Electricity	1200	0.34%	40	3.33%	0.03%	168.28
7	District Heat	0	0.00%	0	0.00%	0.00%	0
7	Total	60220	17.27%	19133	31.77%	12.98%	93.93
All	On-Site Gas	66950	19.20%	21630	32.31%	14.68%	114.85
All	On-Site Coal	29599	8.46%	9522	32.28%	6.46%	75.29
All	Electricity	1200	0.34%	40	3.33%	0.03%	168.28
All	District Heat	251033	71.99%	116187	46.28%	78.83%	144.60
All	Total	348682	100.00%	147381	42.27%	100.00%	135.76

Table 3.5 - Economic Analysis Results of Residential Sector Cost-Effective Energy Efficiency Resource for 1993 Baseline

Full Price Scenario	All Fuels, All Building Groups 1993	District Heating Building Groups 2 to 5 1993
Economic Assumptions	Default	Default
Annual Energy Use Reduction (GJ)	147,381	116,187
Value of Annual Savings (Million 1993 SK)	35.6	31.4
Present Value of Energy Savings (Million 1993 SK)	529.1	480.2
Total Installed Cost (Million 1993 SK)	131.8	114.2
PV of Installed Cost (Million 1993 SK)	198.3	166.5
Simple Payback Period (Years)	4	4
Net Present Value (Million 1993 SK)	330.8	313.7
Annualized Cost (Million 1993 SK/Year)	20.0	16.8
Cost of Conserved Energy (1993 SK/GJ)	135.8	144.6

3.3.1.2 Non-Residential Sector Baseline Efficiency

The non-residential, cost-effective efficiency resource was estimated by applying the percentage of cost-effective energy efficiency in residential buildings to the space and water heating energy use in the non-residential building sector. The estimated non-residential efficiency resource for 1993 using the base economic values and medium fuel prices is shown in Table 3.6.

Table 3.6 Estimated Non-Residential Space and Water Heat Efficiency Potential by Fuel and Heating System Type (GJ), 1993

Gas	On-Site Coal	On-Site Electric	BH Gas	District Heat	TOTAL
15	0	84	1061	36822	40774

Keeping in mind that this is a very rough estimate, the cost-effective efficiency potential in the non-residential amounts to 40,774 GJ annually. This represents about a 37% reduction in non-residential energy consumption and over 90% of this resource is supplied by district heat.

3.3.2 Sensitivity Analysis

The cost effectiveness of the energy savings and the total energy saving potential are a function of fuel prices, the installed cost of the energy efficiency equipment and the energy savings actually achieved. The sensitivity of levelized energy cost to those input parameters is discussed in this subsection.

3.3.2.1 *Installed Cost of Equipment*

The purchase and installation cost of the energy saving material and equipment was determined by market research in the Slovak Republic, in other European countries and in the USA. While the prices in Slovakia are expected to change in some instances, they will not change dramatically. The cost of such equipment in Slovakia is already within the price ranges found in Western countries. Cost of installation can be expected to increase with the time, due to the general growth of wages. However, this can be predicted and taken into account in the period between the study and the actual implementation of the project. Therefore, it will not be considered in the sensitivity analysis.

3.3.2.2 *Fuel Price*

The cost of fuel can affect the potential energy savings and also the cost of saved energy. A lower fuel price will cause some ECO's to become economically ineffective due to a lower value of energy savings and unchanged installation cost. Thus, ECO's with low value index will be eliminated and the cost effective saving potential will be reduced. The levelized cost of saved energy will not be affected much, since the installation cost of ECO's will also be reduced.

The sensitivity of the energy saving potential and the cost of energy saved in the residential sector were analyzed for all four levels of fuel prices presented in Table 3.3. Level 1 represents the current energy prices, Levels 2 and 3 represent an optimistic estimate of moderate fuel price increases while Level 4 represents a pessimistic scenario of fuel prices development. The selection of fuel price levels is not intended to be an accurate estimate for the price of each fuel. Instead, a wide range of fuel price development scenarios was selected to analyze the relation between the expected energy saving potential and the fuel price. The impact of fuel prices on the levelized cost of heat and on the energy saving potential in the town of Handlova is presented in Table 3.7.

Table 3.7 - Sensitivity of the Energy Saving Potential and the Cost of Delivered Heat to Fuel Prices

Fuel Price Level	1	2	3	4
<u>All Fuels</u>				
Saving Potential [GJ/Year]	125,168 35.9%	140,825 40.4%	147,381 42.2%	154,238 44.2%
Levelized Cost [SK/GJ]	132.47	133.79	135.76	140.14
<u>District Heat</u>				
Saving Potential [GJ/Year]	112,556 44.8%	112,556 44.8%	116,187 46.3%	117,416 46.8%
Levelized Cost [SK/GJ]	135.85	141.87	144.60	149.66

The data in Table 3.7 indicates that the energy saving potential for Level 1 is lower than Level 4 by approximately 8% for all fuel groups and by approximately 2% for the district heating group only. The variation of the levelized energy cost for all fuel groups is within 5% and for district heat only within 9% of the highest value. This comparison indicates that the fuel price will have only a small impact on the cost effective potential energy savings and on the cost of the energy saved.

3.3.2.3 Actual Energy Savings Achieved

The energy saving potential in the residential building stock was calculated using methods recommended by the American Society of Heating, Refrigerating and Air Conditioning Engineers (ASHRAE). However, inherent to this process is that many assumptions have to be made based on experience and results from previous studies and demonstrations. A certain level of inaccuracy has to be recognized. Another issue is that implementation of the energy saving technologies depends on the quality of workmanship, materials and equipment used, and other factors which are difficult to predict.

The reason for analyzing the sensitivity of the economically effective energy saving potential and the levelized cost of saved energy to the savings actually achieved is not to raise skepticism about the calculated results, but to make an assessment of consequences due to the above mentioned factors. Lower-than-expected energy savings will increase the levelized cost of saved energy and reduce the energy saving potential.

For the purpose of this analysis, the calculated savings for each ECO was reduced to 50% of the calculated value which means that only 50% of calculated savings would be achieved. Fuel Case 3 was selected for the calculation. The results are presented in Table 3.8.

Table 3.8 - Sensitivity of the Energy Saving Potential and the Cost of Delivered Heat to Actual Energy Savings Achieved

	Levelized Energy Cost [SK/GJ]	Cost Effective Saving Potential [GJ/Year]	Effective Saving as % of Total Use [%]
All fuels 100% saving	135.76	147,381	42.27
All fuels 50% saving	267.75	58,940	16.90
District Heat 100% saving	144.60	116,187	46.28
District Heat 50% saving	274.60	54,060	21.54

In the unlikely scenario where only 50% of expected energy savings would be actually achieved, the cost effective saving potential for all the fuel groups would be reduced to 58,940 GJ/year, or by 60%. In the district heating system, the saving potential would be lowered by approximately 53%. The levelized energy cost for all fuel groups and for the district heating system only would increase to 267.75 SK/GJ and 274.60 SK/GJ, respectively. The results of the analysis of the three supply side alternatives shows that the cost of delivered thermal energy would be in a range from 180 SK/GJ to 350 SK/GJ, depending on selected alternatives, cost of fuel and economic environment. The cost of energy saved (274.60 SK/GJ) under this scenario is only slightly higher than the cost of thermal energy delivered by the district heating system assumed for this calculation, as previously shown in Table 3.3 (270 SK/GJ).

3.3.2.4 Summary of Sensitivity Analysis

The sensitivity analysis shows that:

- the Levelized Cost (LC) of the energy saved by implementing the energy conservation measures evaluated in this study is only moderately influenced by fuel prices. The LC variation is less than 6% for the fuel cost variation of approximately 80%.
- the LC of energy saved will be well within the range of expected cost of energy delivered by the district heating system even in the unlikely case that only 50% of the calculated energy savings are achieved. This suggests that the economic risk of implementing the recommended ECO's is almost non-existing.
- the energy saving potential is only moderately influenced by the fuel prices within the assumed range. The variation of saving potential is less than 6.5% for the fuel cost variation of approximately 80%.

- the energy saving potential is substantially dependent on the actual performance of each ECO. For the analyzed case where only 50% of calculated savings were assumed, the energy saving potential (as calculated for 100% savings) was reduced by approximately 60% for all fuel groups and by 53% for the district heating system.