Task 3.8 - Pressurized Fluidized-Bed Combustion

**Topical Report
March 1995**

RECEIVED
AUG 14 1997
OSTI

Work Performed Under Contract No.: DE-FC21-93MC30097

For
U.S. Department of Energy
Office of Fossil Energy
Federal Energy Technology Center
Morgantown Site
P.O. Box 880
Morgantown, West Virginia 26507-0880

MASTER

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

By
Energy & Environmental Research Center
University of North Dakota
P. O. Box 9018
Grand Forks, North Dakota 58202-9018

Disclaimer

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

**Portions of this document may be illegible
electronic image products. Images are
produced from the best available original
document.**

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government, nor any agency thereof, nor any of their employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

ACKNOWLEDGMENT

This final topical report was prepared with the support of the U.S. Department of Energy (DOE), Morgantown Energy Technology Center, Cooperative Agreement No. DE-FC21-93MC30097. However, any opinions, findings, conclusions, or recommendations expressed herein are those of the author(s) and do not necessarily reflect the views of the DOE.

EERC DISCLAIMER

LEGAL NOTICE This research report was prepared by the Energy & Environmental Research Center (EERC), an agency of the University of North Dakota, as an account of work sponsored by Morgantown Energy Technology Center. Because of the research nature of the work performed, neither the EERC nor any of its employees makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement or recommendation by the EERC.

TABLE OF CONTENTS

LIST OF FIGURES	ii
LIST OF TABLES	iii
1.0 INTRODUCTION	1
2.0 OBJECTIVES	2
3.0 ACCOMPLISHMENTS	2
3.1 Description of Pressurized Fluidized-Bed Reactor	2
3.2 Alkali-Sampling Probe Description	4
3.3 Shakedown Testing of Bench-Scale PFBR	7
3.4 Results from Alkali Sampling	12
3.5 Results from Sulfur Sorbent Performance Tests	14
3.6 Results from Refuse-Derived Fuel and Lignite Combustion Tests	17
4.0 SUMMARY	24
5.0 REFERENCES	27

LIST OF FIGURES

1	Maximum allowable reactor working pressure over a range of temperatures	3
2	Side view of PFBR	4
3	Photograph of PFBR	5
4	Photograph of the PFBR with heaters in place	5
5	Schematic of alkali-sampling probe	6
6	Temperature distributions for dry Knife River, Knife River slurry, and Little Tonzona slurry	10
7	Flue gas emissions over time for Knife River slurry	11
8	Comparison of flue gas emissions for three tests	11
9	Sulfur capture in the PFBR as a function of operating conditions	17
10	NO _x emissions from the PFBR as a function of operating conditions	18
11	N ₂ O emissions from the PFBR as a function of operating conditions	18
12	PFBR temperature distribution with various fuels	21
13	Comparison of SO ₂ emission and sulfur retention for each fuel type	25

LIST OF TABLES

1	Moisture-Free Fuel Analyses	8
2	Summary of Process Data	9
3	Emissions Data	10
4	Proximate, Ultimate and XRF Analyses of Blacksville Bituminous, Beulah Lignite, and Plum Run Dolomite	13
5	Operating Conditions and Gas-Phase Species Composition for Alkali Gettering Tests	13
6	XRF Analysis of Filter Material Collected from Alkali-Sampling Probe During Test BLK-PR01A	14
7	Test Matrix for Sulfur Sorbent Characterization	15
8	Operating Data and Emissions from Sulfur Sorbent Characterization Tests	16
9	Moisture, Proximate, Ultimate, Sulfur Forms, Heating Value, Ash Fusion, and Ash Analyses for Fuel Samples	19
10	Average Operating Conditions from PFB Combustion Tests with Selected Fuels	20
11	Ash Material Balance Through PFBR	22
12	XRF and XRD Analyses of PFBR Lignite Fuel Ash (high-temperature ash, % of ash)	22
13	XRF and XRD Analyses of PFBR RDF Ash (high-temperature ash, % of ash)	23
14	XRF and XRD Analyses of PFBR RDF-Lignite Fuel Ash (high-temperature ash, % of ash)	23
15	Results from TCLP Tests for RCRA Metals on Selected Combustion Products Derived from All Three Slurry Fuels	26

TASK 3.8 PRESSURIZED FLUIDIZED-BED COMBUSTION

1.0 INTRODUCTION

One of the overall goals of the U.S. Department of Energy is the development of the technology necessary to provide for a secure, reliable, affordable, and environmentally sound source of energy. A secure energy source is important to ensure economic stability and growth in the next century as well as to reduce current and minimize future environmental impact associated with power generation in the United States and the world as a whole. The continued and potentially expanded use of abundant coal reserves is one key to a secure and affordable source of energy in the United States.

Throughout the world, coal will play an expanded role in the production of the affordable energy necessary to meet the demands of economic development and growth. The development of more efficient and environmentally sound technology in the United States may present export market opportunities throughout the world; specific examples include East Central Europe and the Pacific Rim. In East Central Europe, where substantial coal utilization has occurred for decades, an urgent need exists for commercial emission control technology as well as for current clean coal technology. The lack of emission control technology in East Central Europe is exacting a high price in terms of human health and long-term environmental damage. In contrast, the Pacific Rim has only recently begun to expand the use of coal to meet energy demands created by economic growth. Therefore, the need in that region is for commercial and developing technologies to allow new coal-fired plants to meet current and future energy demands in an environmentally sound manner.

For coal to play a key role in the U.S. energy mix, it will be necessary to develop and commercialize technologies capable of producing electricity at significantly higher overall system efficiencies than the 30%-35% levels currently observed in conventional coal-fired systems. Also, the production of liquid and gaseous fuels from coal will be required to effectively meet the broad spectrum of future energy needs. To achieve overall system efficiencies of 40%-60% in an environmentally acceptable manner, development and demonstration of advanced second-generation utilization and conversion technology will be paramount. Examples include 1) advanced pulverized coal-fired combustion systems; 2) high-temperature heat exchangers for indirect firing of gas turbines; 3) pressurized combustion in staged, entrained, slagging, and fluidized-bed modes; and 4) integrated gasification and direct gas-fired turbines.

A number of barrier issues exist that are not unique to individual technologies but are in some manner common to all advanced power system processes for both oxidizing and reducing environments. Examples include material issues, specifically ceramic and refractory components, and operational issues unique to high-temperature pressurized systems. The focus of the current work on pressurized fluidized-bed combustion (PFBC) is the development of sorbents for in-bed alkali control.

2.0 OBJECTIVES

The goal of the PFBC activity is to generate fundamental process information that will further the development of an economical and environmentally acceptable second-generation PFBC. The immediate objectives focus on generic issues, including the performance of sulfur sorbents, fate of alkali, and the Resource Conservation and Recovery Act (RCRA) heavy metals in PFBC. A great deal of PFBC performance relates to the chemistry of the bed and the contact between gas and solids that occurs during combustion. These factors can be studied in a suitably designed bench-scale reactor. The present studies are focusing on the emission control strategies applied in the bed, rather than in hot-gas cleaning. Emission components include alkali and heavy metals in addition to SO_2 , NO_x , N_2O , and CO .

3.0 ACCOMPLISHMENTS

3.1 Description of Pressurized Fluidized-Bed Reactor

A pressurized fluidized-bed reactor (PFBR) has been constructed at the Energy & Environmental Research Center (EERC) to simulate the bed chemistry, ash interactions, and emissions from a PFB under closely controlled conditions. This reactor is used for sorbent characterization, testing of gaseous emissions, including trace elements, and agglomeration and hot-gas cleanup testing in a cost-effective manner over a wide range of operational conditions. The 55-in.-tall reactor is constructed of 3-in. Schedule 80 pipe and is externally heated with three ceramic heaters. A hot cyclone collects the ash and bed material that is carried out of the reactor. The preheated fluidizing gas can be either air or a mixture of air and nitrogen; in addition, one additional gas such as carbon dioxide, carbon monoxide, sulfur dioxide, or a nitrogen oxide can be added to result in a fuel gas similar to that generated in a full-scale fluidized-bed combustor. Preheated gas at temperatures of up to 1400°F and pressures of up to 200 psig are supplied at the bottom of the reactor through a 1-in. Schedule 40 pipe. The fluidizing gas is supplied at sufficiently high velocities to prevent the sized bed material from dropping out during operation. Figure 1 shows the maximum allowable working pressure of the reactor at various temperatures.

The fluidizing gas enters the 3-in. Schedule 80 main section of the reactor through a conical transition. This conical section was designed without a distributor plate to allow quick removal and quenching of the bed material after completion of a test. Bed material can be sampled or collected using a lock hopper system located at the bottom of the reactor. A sight port at the top of the reactor is fitted with a color video camera for on-line observation of the bed during either high-pressure or atmospheric operation. A recorder may be added to the camera at a later date. Figure 2 is a side-view schematic of the reactor and cyclone. Figure 3 is a photograph of the actual reactor vessel, cyclone, air preheater, reactor collection pot and fuel feed hopper. Figure 4 is a photograph of the final system after the external heaters and other auxiliaries have been installed.

Temperatures in the reactor are measured with eleven Type K thermocouples. These are located at 0.25, 1.75, 3.5, 5, 7, 9, 11, 15, 23, 31, and 43.25 inches above the conical transition section. Thermocouples are also located at the gas inlet, the cyclone exit, and the pressure letdown valve inlet. A sampling port is located downstream of the pressure letdown valve.

Figure 1. Maximum allowable reactor working pressure over a range of temperatures.

The use of electric heaters provides the capability to match the fuel feed rate to the amount of bed material in the reactor. External heaters are used for heating and maintaining the reactor and hot cyclone at temperatures of up to 2000°F for atmospheric operation and up to 1700°F for operation at 150 psig. The external ceramic heaters on the gas preheater and the reactor itself are rated at 10.8 and 10.05 kW, respectively, with an upper temperature limit of 2200°F. In a full-scale system, the bed is deep relative to that in the PFBR. Therefore, to keep a similar coal feed rate-to-bed inventory between bench- and full-scale systems, the coal feed rate in the PFBR is kept low relative to that in full-scale systems, compared on a fuel feed rate per bed cross-sectional area basis. Therefore, additional heat is required to maintain the desired temperature. The high heat losses through the reactor walls inherent to small-scale systems also require either good insulation or reactor heating. This type of heating system provides very good control of the reactor temperature. At atmospheric pressure, an in-bed cooling coil can be used to remove excess heat from the high-temperature dense-bed region, allowing for higher fuel feed rates and providing a more uniform overall temperature distribution. The use of both air and nitrogen as fluidizing gas allows excess air and gas velocity to be matched to any design condition.

The bench-scale PFBR is equipped to feed either dry fuel or slurry. Slurry feed is metered with a variable-speed pump. Dry coal and sorbent are metered with separate augers that feed into a common water-cooled auger, which in turn carries the material into the reactor. A bed material hopper empties directly into the common auger without flow control. Each hopper is maintained at a pressure slightly higher than that in the combustor during operation. The hoppers can be isolated from the pressurized system so that they can be refilled during a test. At the bottom of each

Figure 2. Side view of PFBR.

hopper is a plastic sight tube; in addition, the fuel and sorbent hoppers are equipped with sensors to alert the operator when the hoppers are empty and need to be refilled. A data acquisition and control system is used to monitor and record all critical pressures, temperatures, flow rates, and emissions. These critical data include the gas-flow rates, bed static pressure and differential pressures across the bed and cyclone, and eight different internal reactor temperatures. The air and nitrogen flow rates are controlled automatically to flow rate set points. The reactor pressure is automatically controlled to a pressure set point. The three ceramic heaters on the reactor may be controlled manually to a given heater temperature, or controlled automatically to maintain a desired gas temperature in each zone. Ports for alkali-sampling probes or, alternatively, solid-sampling or gas-sampling probes are located at the top of the reactor and the top of the cyclone. An air-cooled deposition probe is located at the top of the reactor.

3.2 Alkali-Sampling Probe Description

An alkali and particulate condensation sampling train has been designed and constructed to allow monitoring of the alkali concentrations in the PFBR. The condensation sampling train was chosen over other techniques at this time because of its relatively low cost to build and operate and its relative simplicity to operate. A disadvantage is the difficulty in collecting a representative sample, especially under reducing conditions, and the delay in obtaining the analytical results. The alkali-sampling train extracts a representative sample from the cyclone outlet of the PFBR.

EERC MS09068.CDR

Figure 3. Photograph of PFBR, shown without ceramic heaters.

EERC MS09069.CDR

Figure 4. Photograph of PFBR with heaters in place.

The PFBR alkali-sampling probe consists of a 1.315-in. (0.03-m)-OD stainless steel alkali-sampling probe which has been fitted with a small ceramic filter provided by the CeraMem Corporation. The principle behind the sampling probe is to extract a gas sample through a filter that would be representative of the hot-gas filters currently being developed for advanced coal-fired power generation systems. After passing through the ceramic filter maintained at flue gas temperatures, the gases and any vapor-phase alkali species that pass through the filter are cooled and allowed to condense on a high surface area "cold finger." The gas then passes through a final filter to collect any remaining aerosol particles. The gas flows through a series of water bubblers (impingers) to trap any additional alkali vapors and finally flows through pressure and flow measurement and control devices. Figure 5 is a diagram illustrating the alkali-sampling probe and heat exchanger with the impinger train. The high surface area cold finger and the final filter are removed at the end of a test and washed with deionized water to dissolve the alkali species. The washings and the bubbler solutions are analyzed by inductively coupled argon plasma spectroscopy (ICAP) (or other solution analysis techniques) to determine the total amount of alkali collected from the total volume of gas sampled. A cooled knockout pot for collecting coal tars will be needed when sampling from gas streams under reducing conditions (not shown).

Figure 5. Schematic of alkali-sampling probe.

Each sampling test is performed for 3.5–4 hours on-line at steady-state conditions to obtain enough sample to establish representative alkali material balances. Initially, this probe is designed to remain permanently in the gas stream, but after the sampling procedure has been proven in short-term combustion tests on the bench-scale PFBR, the probe will be modified to be retractable from a pressurized combustor. This design will allow for sample collection or changing of the probe's ceramic filter while the combustor/gasifier is still in operation. Measuring the volume of rinse solution and the concentration of alkali species in the rinse solution and monitoring the total volume of gas sampled will allow vapor-phase alkali concentration to be calculated in the gas stream.

3.3 Shakedown Testing of Bench-Scale PFBR

Shakedown of the reactor, which commenced in 1993, is detailed in the topical report, "Advanced Power Systems, Topical Report Task No. 3.0," Contract No. DE-FC21-93MC30097. This year, additional shakedown followed the installation of a new backpressure control valve and the slurry feed system. The pressure tests with dry feed were conducted with Beulah lignite at a pressure of 150 psig and an average temperature of 1550°F. Start-up and shutdown procedures for pressurized operation were established.

The slurry feed system was tested with Little Tonzana (Alaska) and Beulah (North Dakota) coal–water fuel (CWF) at 150 psig and 1550°F. The slurry feed pump is capable of delivering 3–8 lb/hr fuel against a reactor pressure of 150 psig. The feed rate is determined in part by the heat input of the fuel; the feed rate must be high enough to deliver enough heat to maintain the desired reactor temperature without exceeding it. While some heat can be made up with the external ceramic heaters, the heaters alone cannot supply full reactor temperature during pressurized operation. A second constraint on the minimum slurry feed rate is that the feed rate must be high enough to keep the material flowing into the reactor: if the feed rate is too low, the slurry will dry out and plug the feed line. The temperature distribution in the reactor was found to be much more uniform with the slurry feed than with a similar fuel fed dry.

Shakedown tests with the as-received (dry) and slurried Knife River lignite were conducted. The analyses of the shakedown fuels are shown in Table 1. During the tests, the flue gas was continuously sampled for O₂, SO₂, NO_x, N₂O, HC, CO, and CO₂. No particulate sampling was performed for the test with the dry coal. The flue gas was sampled for volatile organic carbons (VOC), and EPA Method 5 was used to measure particulate in the flue gas for the slurry test. Solid samples include fly ash and bottom ash. The fluidizing gas was a mixture of air and nitrogen, preheated to about 650°F. Table 2 shows the operating data for the shakedown test with Knife River lignite, the shakedown test with Little Tonzona slurry, and the Knife River slurry test. The heat input for the Knife River slurry was about 38,000 Btu/hr, compared to 31,000 Btu/hr for the dry Knife River and 29,000 Btu/hr for the Little Tonzona slurry. All three tests were operated at similar temperature, velocity, and excess air levels. Figure 6 shows the temperature distributions for the three tests. The two slurries had very similar temperature distributions, while the dry fuel had a lower bed temperature and higher freeboard temperature.

Table 3 shows the emissions data for the three tests. It is important to remember that the emissions shown in ppm and percent will be low because of the make-up nitrogen added to the combustion air to maintain the desired velocity in the reactor. Figure 7 shows that the SO₂, NO_x,

and N₂O emissions were relatively steady for the length of the test. Figure 8 compares the emissions, in lb/MM Btu, for the three tests. The SO₂ emissions were highest for the Little Tonzona slurry, followed by the Knife River slurry. The utilization of inherent alkali for sulfur capture was about 57% for the Little Tonzona slurry, 65% for the Knife River slurry, and 78% for the dry Knife River lignite. NO_x and N₂O emissions are greatly influenced by reactor temperature; the relatively high freeboard temperature for the dry Knife River test resulted in higher NO_x and lower N₂O emissions than either slurry test. Hydrocarbon emissions were quite low for all three tests.

TABLE 1

Moisture-Free Fuel Analyses			
	Knife River Dry	Knife River Slurry	Little Tonzona Slurry
Proximate Analysis, mf, wt%			
Volatiles	47.3	42.8	49.71
Fixed Carbon	41.2	467.0	40.05
Ash	11.4	10.3	10.24
Ultimate Analysis, mf, wt%			
Hydrogen	4.4	4.6	4.39
Carbon	61.1	66.0	63.67
Nitrogen	0.9	0.9	0.75
Sulfur	1.6	1.5	1.42
Oxygen, ind.	20.5	16.7	19.53
Ash	11.4	10.3	10.24
Ash Composition, % as oxides			
Calcium, CaO	22.6	23.5	25.3
Magnesium, MgO	9.1	11.2	2.7
Sodium, Na ₂ O	3.2	0.9	0.2
Silica, SiO ₂	25.1	22.3	27.6
Aluminum, Al ₂ O ₃	9.7	10.7	20.5
Ferric, Fe ₂ O ₃	3.6	5.3	7.2
Titanium, TiO ₂	0.5	0.4	0.2
Phosphorous, P ₂ O ₅	0.4	0.4	0.5
Potassium, K ₂ O	0.3	0.3	0.2
Sulfur, SO ₃	25.4	24.9	15.5
Heating Value, Btu/lb	10,940	11,691	10,863
Solids content, %	NA ¹	55.5	53.7
Viscosity, cp	NA	500	500
Moisture content, %	31.7	NA	NA

¹ Not applicable.

TABLE 2

Summary of Process Data

Fuel	Knife River Dry	Knife River Slurry	Little Tonzona Slurry
Start Time	11:36	11:00	10:58
Stop Time	15:24	13:27	13:06
Date	06-16-94	06-30-94	06-22-94
Fuel Feed Rate, lb/hr	4.34	5.88	4.96
Fuel Feed Rate, Btu/hr	31,265	38,138	28,629
Reactor Pressure, psig	150.42	153.1	151.2
Reactor Pressure Drop, in. H ₂ O	13.87	11.4	11.5
Cyclone Pressure Drop, in. H ₂ O	14.53	4.4	10.9
Fluidizing Gas, scfm			
Air	11	11.26	10.23
Nitrogen	11.5	11.01	12.27
Total	22.5	22.27	22.5
Flue Gas			
O ₂ , %	4.8	4.5	4.8
CO ₂ , %	4.2	4.7	3.7
CO, lb/MMBtu	0.007	0.001	0.010
SO ₂ , lb/MMBtu	0.617	0.883	1.055
NO _x , lb/MMBtu	0.387	0.242	0.273
N ₂ O, lb/MMBtu	0.053	0.118	0.131
Hydrocarbons, lb/MMBtu	0.016	0.035	0.039
Excess Air, %	23.4	21.9	23.2
Sulfur Retention, %	80.0	65.0	60.0
FG SGV ¹ , ft/sec	2.95	2.94	2.91
Reactor Temperatures			
Preheater Exit	662	649	652
Plenum	927	813	943
0.25 in.	1394	1345	1396
1.75 in.	1419	1493	1459
3.5 in.	1409	1511	1461
5.0 in.	1415	1522	1474
7.0 in.	1426	1529	1476
9.0 in.	1442	1524	1472
11.0 in.	1462	NA ²	NA
15.0 in.	1522	1568	1526
23.0 in.	1728	1642	1650
31.0 in.	1733	1616	1634
43.25 in.	1672	1556	1559
Average	1523	1551	1523
Cyclone Exit	1428	1432	1392

¹ Flue gas superficial gas velocity.² Not available - slurry feed enters the reactor through this thermocouple port.

Figure 6. Temperature distributions for dry Knife River, Knife River slurry, and Little Tonzona slurry.

TABLE 3

Emissions Data			
Parameter	Knife River Dry	Knife River Slurry	Little Tonzona Slurry
O ₂ , %	4.80	4.52	4.79
Excess Air, %	23.42	21.9	23.20
CO Content, ppm	2	1	3
CO Emission, lb/MMBtu	0.007	0.001	0.010
CO ₂ Content, %	4.2	4.7	3.7
NO _x Content, ppm	73	53	44
NO _x Emission, lb/MMBtu	0.387	0.242	0.273
N ₂ O Content, ppm	10	27	22
N ₂ O Emission, lb/MMBtu	0.053	0.118	0.131
HC Content, ppm	1	1	0.3
HC Emission, lb/MMBtu	0.016	0.035	0.039
SO ₂ Content, ppm	83	139	122
SO ₂ Emission, lb/MMBtu	0.617	0.883	1.055
SO ₂ Retention, %	80.0	65.0	60.0
Alkali-to-Sulfur Ratio	1.02	0.97	1.05
Alkali Utilization	78.5	67.3	57.1
Avg. Comb. Temp., °F	1523	1551	1523

Figure 7. Flue gas emissions over time for Knife River slurry.

Figure 8. Comparison of flue gas emissions for three tests.

3.4 Results from Alkali Sampling

Several alkali sampling tests have been completed. The first test utilized a Beulah-Zap coal (North Dakota lignite), which is considered to be a high-sodium coal, while the second test utilized a low-sodium Blacksville coal (Pittsburgh No. 8 bituminous coal). Both coals were fed using the dry feeder. Table 4 shows the results of proximate, ultimate, and x-ray fluorescence (XRF) analyses of these two coals as utilized in these combustion tests, as well as a sorbent used on later testing. Table 5 shows the gas composition of six trace species from these combustion tests.

The results from these analyses are consistent with those expected for these fuels. The higher sodium levels in the lignite coal resulted in higher sodium levels in the flue gas, while the bituminous fuel had higher potassium and chlorine levels than those in the lignite fuel. The high iron concentrations are probably due to the pyritic sulfur present in both fuels.

Table 6 shows the results of XRF analyses obtained from the filter located immediately after the alkali-sampling probe. The green sludge material is primarily a hydrated iron sulfate or sulfite material. The high iron levels appear to come from the small quantity of iron present in the coal ash.

Three subsequent tests utilizing a Beulah lignite and an inert silica sand bed material were completed at essentially the same operating conditions. The first test was a repeat of the baseline lignite test and demonstrated good repeatability in the technique. Two tests utilized a kaolin clay as an alkali getter to capture vapor-phase alkali species. The kaolin was mixed with the crushed Beulah lignite, in the ratio of 1 part kaolin to 2 parts ASTM coal ash.

Kaolin is a clay composed primarily of the mineral kaolinite ($\text{Al}_2\text{Si}_2\text{O}_5[\text{OH}]_4$). It was preferred for the gettering test over other types of clays because kaolin can be found in relatively pure form, containing less alkali and alkaline-earth elements which may flux the material upon heating. Also, kaolinite has a layered structure composed of a sheet of silica tetrahedra bonded on one side to a sheet of aluminum hydroxide octahedra, so it has a higher aluminum-to-silicon ratio than most other clays. Because of its higher aluminum content and thus possible fusion with an ash deposit, the viscosity of the deposit will usually increase, thereby weakening it. Kaolin is mined in a number of places in the United States and can be supplied in rock, dried powder, or sieved dried powder forms. The kaolin used for these tests was provided as rock by J.M. Huber Corporation of Macon, Georgia.

One test utilized kaolin sized at $-1/8$ in. to $+30$ mesh, while the other utilized a particle size of -30 mesh. A 77% reduction in sodium was noted using the larger-sized kaolin and a 93% reduction using the finer-sized kaolin. Final sodium levels were 840 and 270 ppb for the $-1/8$ -in. and -30 -mesh, respectively.

The higher surface area of the smaller-sized kaolin facilitated the improved sodium gettering, but the level of 270 ppb is still above that recommended by turbine manufactures. These results do indicate, however, that significant reduction in alkali can be obtained using in-bed getters. Sulfur retention for the tests using kaolin was lower than that for the test without kaolin. Capturing the sodium with the kaolin left less of the sodium available for sulfur capture. Future work will focus

Beulah Lignite, and Plum Run Dolomite

Mine Name:	Blacksville	Beulah	Plum Run
Type:	Bituminous	Lignite	Dolomite
Proximate, mf, wt%			
Volatile Matter	37.7	45.6	NA
Fixed Carbon	49.6	37.0	NA
Ash	12.7	17.4	NA
Ultimate, mf, wt%			
Carbon	70.1	56.8	NA
Hydrogen	5.0	3.5	NA
Nitrogen	1.4	0.7	NA
Sulfur	2.8	3.1	NA
Oxygen, ind	8.0	18.5	NA
Ash	12.7	17.4	NA
Ash Composition, % as oxides			
SiO ₂	46.9	24.5	0.6
Al ₂ O ₃	21.0	11.4	0.4
Fe ₂ O ₃	23.2	19.1	1.1
TiO ₂	0.8	0.6	0.0
P ₂ O ₅	0.2	0.3	0.0
CaO	1.8	12.0	71.2
MgO	1.8	6.9	26.0
Na ₂ O	0.3	3.4	0.2
K ₂ O	1.5	0.1	0.2
SO ₃	2.6	21.7	0.2
Heating Value, Btu/lb	12,388.0	9203.0	NA

TABLE 5

Operating Conditions and Gas-Phase Species Composition for Alkali Gettering Tests

PFB Run:	BLK-PR01A	B13-0894	B14-1294	B15-1294	B16-1394
Coal Name:	Blacksville	Beulah	Beulah	Beulah	Beulah
Coal Type:	Bituminous	Lignite	Lignite	Lignite	Lignite
Sorbent Name:	Plum Run	Plum Run	None	-1/8 in.	-30 mesh
Sorbent Type:	Dolomite	Dolomite	None	Kaolin	Kaolin
Operating Conditions					
Temperature, °F	1600	1550	1514	1544	1543
Pressure, psig	125	150	150	150	150
FG SGV, ft/sec	2.8	3.0	2.8	2.9	2.9
Excess Air, %	25	25	25.1	26.2	24.9
Sulfur Retention, %	53.9	90.0	78.1	55.0	62.0
Gas Species Concentration, ppm					
Na	0.64	3.00	3.61	0.84	0.27
K	0.41	<0.19	<0.11	<0.13	<0.13
SO ₄	136	95.3	106.0	64.3	82.6
Cl	11.0	2.97	3.0	0.56	0.68
Fe	32.3	34.9	54.0	20.8	31.3

TABLE 6

XRF Analysis of Filter Material Collected from Alkali-Sampling Probe During Test BLK-PR01A

Oxide Component, wt%	Normalized XRF	Normalized, SO ₃ -free
SiO ₂	8.4	22.4
Al ₂ O ₃	0.7	1.9
Fe ₂ O ₃	25.3	67.4
TiO ₂	0.2	0.5
P ₂ O ₅	1.4	3.8
CaO	0.0	0.0
MgO	1.5	4.0
Na ₂ O	0.0	0.0
K ₂ O	0.1	0.1
SO ₃	62.4	---
Total	100.0	100.1

on establishing optimum conditions for in-bed alkali gettering and identifying getters that result in the most alkali capture for the least cost.

3.5 Results from Sulfur Sorbent Performance Tests

The first of a series of conventional sulfur sorbents has been tested in the PFBR. The performance of Plum Run dolomite as a sulfur sorbent has been characterized over a range of operating conditions. The coal and dolomite were the same as those used in the Tidd commercial PFBC and allowed for some comparison of data. The emission performance under the various operating conditions is reported in this paper. Ongoing work will characterize additional sorbents. In addition, work will focus on developing an accurate predictive technique for evaluating sorbent performance. The information and models developed will be used to suggest strategies to optimize sorbent performance. The parameters include sorbent selection, sizing, and conditions of operation. These sorbents will also be characterized in the PFBR to determine their propensity to break down in the PFBC.

Sorbent characterization test procedures include preheating the PFBR with the electric heaters, augering in inert silica sand bed material, and establishing air, nitrogen, and reactor pressure before starting the coal feed to the reactor. Initially, a steady-state condition using a Pittsburgh No. 8 bituminous coal and elemental sulfur mixture was established using a dry feed. The elemental sulfur was added to the coal to provide an artificially high SO₂ concentration in the flue gas which allowed the impact of sulfur to be studied without changing the coal. These SO₂ concentrations were approximately 1500, 3000, and 4500 ppm uncorrected for nitrogen dilution. After a baseline was established, the coal feed was changed to a Pittsburgh No. 8, elemental sulfur, and dolomite mixture. This mixture was the same as the baseline mixture except for the addition of dolomite to obtain a desired Ca:S ratio. The decrease in the observed SO₂ concentration was attributed to the sulfur capture capability of the dolomite sorbent at the given bed conditions.

The test matrix utilized for these tests is given in Table 7. The actual test conditions and results from the first series of tests utilizing the Plum Run dolomite and Pittsburgh No. 8 coal are presented in Table 8. The coal and dolomite properties are presented in Table 4. Figure 9 shows the impact of operating conditions on sulfur capture. Trends shown on the curve are an increase in sulfur retention with increasing calcium-to-sulfur ratio, decreasing pressure, and increasing SO₂ level in the flue gas. Data from the Tidd PFBC are shown on the curve for comparison purposes. The overall sulfur retention is low for the bench-scale tests, most likely because of the shallow bed, which results in a very short residence time. Future work will generate similar data for five additional sorbents, and comparisons will be made to full-scale data. The result will be a series of curves that determine the same relative differences as those obtained in the full scale. If the bench scale can reflect the differences noted at the full scale, then the PFBR can become a useful tool for evaluating sorbent performance.

The impact of operating conditions on NO_x emissions is not as well defined. Figure 10 is a graph showing NO_x emissions versus bed temperature. Generally, these results indicate decreasing NO_x with increasing SO₂ levels in the flue gas, decreasing calcium-to-sulfur ratio, increasing temperature, and increasing pressure. Of concern is the trend of decreasing NO_x with increasing temperature. Because some researchers have noted little effect of temperature on NO_x emissions over this temperature range, a significant decrease in NO_x was not expected (1). This phenomenon will be investigated more in the future.

Nitrous oxide measurements were also taken during this work. Figure 11 shows the results. In contrast to the NO_x results, the trends exhibited for the N₂O emissions were very distinct. N₂O emissions decreased sharply as temperature increased. Emissions were slightly lower at higher pressures and higher SO₂ concentrations. These levels were lower than those measured from other pilot-scale atmospheric fluid-bed combustors at the EERC (2). Future testing will establish baseline readings at atmospheric pressure with the PFBR for direct comparison.

TABLE 7

Test Matrix for Sulfur Sorbent Characterization									
Test Number	0	1	2	3	4	5	6	7	8
Temp, °F	0	-	-	-	+	-	+	+	+
Press., psig	0	+	-	+	-	-	-	+	+
SO ₂ , ppm	0	-	-	+	+	+	-	+	-
Ca:S	0	+	-	-	-	+	+	+	-

Key to Symbols			
	-	0	+
Temp, °F	1500	1600	1700
Press., psig	100	125	150
SO ₂ , ppm	1500	3000	4500
Ca:S	1.5	2.25	3.0

TABLE 8

Operating Data and Emissions from Sulfur Sorbent Characterization Tests¹

Temp., °F	Freeboard Temp., °F	Pressure, psia	Excess Air, %	Velocity, ft/sec	Added SO ₂ , ppm	Ca/S Molar Ratio	S Ret., %	NO _x , lb/MMBtu	NO _x , ppm	N ₂ O, lb/MMBtu	N ₂ O, ppm	Label for Figures
1594	1704	139	24.4	1.54	3032	2.25	47.3	0.323	203	0.004	2.6	0000
1497	1551	164	24.1	1.63	1414	3	39.9	0.574	425	0.160	124	tPsC
1504	1556	115	21.9	1.84	1329	1.5	16.9	0.476	294	0.176	114	tpsc
1486	1553	164	28.0	1.82	4716	1.5	40.8	0.368	241	0.138	95	tPSc
1650	1752	114	34.3	1.81	4073	1.5	50.1	0.254	205	0.019	16	TpSc
1468	1556	115	25.7	1.79	4862	3	73.3	0.386	333	0.155	141	tpSC
1675	1734	115	24.1	1.82	1292	3	44.3	0.322	205	0.040	26	TpsC
1606	1763	164	21.7	1.74	4946	3	66	0.162	152	0.011	10	TPSC
1657	1779	164	26.2	1.71	2367	1.5	7.3	0.226	162	NA	NA	TPsc
1536	NA ²	116	NA	NA	NA	2.88	89.4	NA	NA	NA	NA	(Tidd) tp
1537	NA	114	NA	NA	NA	3.93	94	NA	NA	NA	NA	(Tidd) tp

¹ Plum Run dolomite used in all tests. Blacksville bituminous (Pittsburgh No. 8) fired for all tests. Tidd uses Plum Run dolomite sorbent and Pittsburgh No. 8 fuel.

² Not available.

Figure 9. Sulfur capture in the PFBR as a function of operating conditions.

3.6 Results from Refuse-Derived Fuel and Lignite Combustion Tests

Slurries of carbonized refused-derived fuel (RDF) and lignite were burned in the PFBR. These tests accomplished several objectives, including demonstrating that slurries could be burned in the PFBR, characterizing performance of the fuels, and investigating the fate of RCRA heavy metals in PFBC. The properties of the fuels used for these tests are given in Table 9.

The average operating conditions obtained from the combustion tests of a Knife River lignite slurry fuel, a pure RDF slurry fuel, and a RDF-Knife River lignite slurry fuel mixed in a ratio to supply a sulfur-compliant fuel are shown in Table 10. The desired operating conditions for these tests were to be 1550°F, 150 psig, 3.0 feet/second reactor velocity, and 25% excess air, with an initial bed of silica sand. The average operating conditions obtained are shown in Table 10. The temperature distribution inside the PFBR is shown in Figure 12. The average reactor temperature increased in the reactor freeboard when the fuel was changed from the Knife River lignite to the RDF slurry fuel to the RDF-lignite fuel. While some correlation exists between the freeboard temperature and the heat rate of the lignite fuel fed to the PFBR, the correlation is not strong. Rather, these trends suggest that the greater amount of volatile matter in the RDF and the RDF-lignite mixture results in more burning in the freeboard. Thus, more of the fuel combustion occurs in the freeboard area, resulting in the higher temperatures seen in those zones. The increased energy density (i.e., reduced water content) of the RDF-lignite blend (7143 Btu/lb) versus that of the lignite alone (6466 Btu/lb) is also partly responsible for the temperature differences noted.

Figure 10. NO_x emissions from the PFBR as a function of operating conditions.

Figure 11. N₂O emissions from the PFBR as a function of operating conditions.

TABLE 9

Moisture, Proximate, Ultimate, Sulfur Forms, Heating Value,
Ash Fusion, and Ash Analyses for Fuel Samples

Analysis	RDF	Lignite	RDF-Lignite
Solids Concentration, wt%	44.4	55.2	56.4
Viscosity, cP	250	825	815
Proximate, mf ¹ wt%			
Volatile Matter	56.1	42.7	49.2
Fixed Carbon	32.8	47.0	40.9
Ash	11.1	10.3	9.9
Ultimate, mf wt%			
Carbon	68.0	66.0	67.4
Hydrogen	7.2	4.6	5.8
Nitrogen	0.5	0.9	0.8
Sulfur	0.1	1.5	1.1
Oxygen	13.1	16.7	15.0
Sulfur Forms, mf wt%			
Organic	0.11	0.96	0.48
Pyrite	0.01	0.33	0.57
Sulfatic	0.01	0.02	0.04
Heating Value, Btu/lb, mf, wt%			
Experimental	14,200	11,690	12,670
Calculated	13,420	11,350	12,370
Ash Fusion, reducing atmosphere, °C			
Initial	1366	1284	1220
Softening	> 1538	1303	1261
Hemispherical	> 1538	1309	1319
Fluid	> 1538	1316	1423
Ash Component, mf wt% (as Oxides)			
Silicon	41.8	22.3	37.7
Aluminum	36.0	10.7	24.7
Iron	2.6	5.3	5.8
Titanium	10.1	0.4	3.7
Phosphorous	1.6	0.4	0.7
Calcium	1.9	23.5	9.6
Magnesium	2.3	11.2	6.6
Sodium	0.4	0.9	0.7
Potassium	0.3	0.3	0.4
Sulfur	3.0	24.9	10.1

¹Moisture-free.

TABLE 10

Average Operating Conditions from PFB Combustion Tests with Selected Fuels

	Lignite Slurry	RDF Slurry	RDF-Lignite Blend
Reactor Pressure, psig	153.2	149.8	146.3
Slurry Feed Rate, lb/hr	5.9	7.05	6.4
As-fired Slurry HHV, ¹ Btu/lb	6466	6398	7143
As-fired Solids Loading, %	55.6	47.2	56.7
Slurry Heat Rate, Btu/hr	38,150	45,110	45,720
Reactor FGV, ² ft/s	2.94	3.11	3.09
Excess Air, %	23.3	22.2	25.9
Reactor dP, in. H ₂ O	11.4	14.0	12.9
Avg. Zone 1 Temp., °F	1509	1520	1507
Avg. Zone 2 Temp., °F	1571	1603	1621
Avg. Zone 3 Temp., °F	1586	1672	1767
Avg. Reactor Temp., °F	1551	1580	1602
Carbon Burnout, %	98.5	99.0	99.5
Avg. Gas Emissions, as-run			
O ₂ , mol%	4.5	4.4	4.9
CO ₂ , mol%	4.8	4.6	4.6
CO, ppm	0.5	3.2	3.2
HC, ³ ppm	1.2	3.2	1.6
SO ₂ , ppm	137.9	18.0	39.2
NO _x , ppm	53.0	43.1	39.5
N ₂ O, ppm	27.7	3.2	10.2
Hcl, ppm	ND ⁴	1.4	2.1
Avg. Gas Emissions, corrected to 3% O ₂ without dilution N ₂			
CO ₂ , mol%	14.0	12.4	13.1
CO, ppm	1.6	8.6	9.0
HC, ppm	3.6	8.8	4.4
SO ₂ , ppm	407	49.0	111
No _x , ppm	156	117	113
N ₂ O, ppm	81.6	8.6	28.9
Avg. Gas Emissions, lb/MMBtu			
SO ₂	0.62	0.10	0.22
NO _x	0.24	0.17	0.18
CO	0.003	0.009	0.01
Avg. Sulfur Retention	69	35	85

¹ High heating value.² Flue gas velocity.³ Hydrocarbons.⁴ Not determined.

Figure 12. PFBR temperature distribution with various fuels.

The average gaseous emissions from these tests are also shown in Table 10. These emissions are shown on an as-run basis as well as corrected for dilution N_2 and to 3% O_2 . The emissions of components considered to be potential pollutants are also shown on a lb/MMBtu basis. The nitrogen oxide emissions from the RDF-based fuels were lower than those from the lignite fuel owing to the lower fuel-bound nitrogen for the RDF fuel. These levels are below the current federal standards for NO_x .

Carbon monoxide and hydrocarbon emissions appeared to be slightly higher for the fuels that contained RDF. These emissions were low and indicated a good burnout of the fuel. The hydrocarbon emissions detected from the volatile organic compounds (VOCs) analysis were not substantially different from those detected in the blank XAD-2 resin. Some of the compounds detected were naphthalene, diethyl benzenes, 1-methyl-1-propenyl benzene and C10-C12 branched hydrocarbons. These same compounds were detected in both the field and blank samples in approximately the same concentrations. Therefore, these compounds are believed to be coming from the XAD-2 resin and are not expected to be an emission problem for these fuels.

Table 11 shows the ash material balances for the three different tests. One result shown in Table 11 is that the fly ash passing through the cyclone decreased dramatically for the combustion test using the RDF-lignite blend. This lower fly ash level could be caused by the higher freeboard temperatures and/or interactions between the coal ash and the RDF ash, which would make the fly ash leaving the reactor more cohesive. The higher temperatures could increase the cohesivity (stickiness of the ash) making it easier to collect in the cyclone. Interactions between the RDF and

lignite ash result in a larger ash particle size, as indicated by the mass median diameters of the cyclone fly ash presented in Tables 12, 13, and 14. The larger, more sticky fly ash entering the hot primary cyclone is more efficiently collected.

TABLE 11

Ash Material Balance Through PFBR						
	Lignite		RDF		RDF-Lignite	
	Mass, g	wt %	Mass, g	wt %	Mass, g	wt %
Ash Material In						
Bed Material	1097	64	1400	81	1205	80
Fuel Ash	616	36	324	19	299	20
Total Ash Material In	1713	100	1724	100	1504	100
Ash Material Out						
Spent Bed Material	861	63	1098	67	1020	66
Cyclone Ash	362	27	480	29	529	34
Fly Ash	137	10	55	3	3.2	<0.2
Total Ash Material Out	1360	100	1633	100	1552	100
Closure, %	79		95		103	

TABLE 12

XRF and XRD¹ Analyses of PFBR Lignite Fuel Ash
(high-temperature ash, % of ash)

Sample Number PFB-KR1-0694	Fuel Ash	Bed Material	Cyclone Ash	Fly Ash
Loss on Ignition	NA ¹	0	7.0	12.7
Particle Size, μm	NA	ND ²	32.2	12.8
XRF Analysis				
SiO ₂	22.3	94.7	56.6	36.9
Al ₂ O ₃	10.7	1.2	6.9	13.1
Fe ₂ O ₃	5.3	0.6	4.5	6.0
TiO ₂	0.4	0.0	0.4	0.5
P ₂ O ₅	0.4	0.1	0.3	0.2
CaO	23.5	1.7	15.4	23.6
MgO	11.2	0.6	5.3	8.3
Na ₂ O	0.9	0.1	0.6	1.1
K ₂ O	0.3	0.0	0.7	0.4
SO ₃	24.9	1.0	9.3	9.8
Total	99.9	100.0	100.0	99.9
XRD Analysis of Cyclone Ash Material				
Major Phase:	Quartz SiO ₂			
Minor Phase:	Anhydrite CaSO ₄			
	Hematite Fe ₂ O ₃			

¹ X-ray diffraction.

² Not applicable.

³ Not determined

TABLE 13

XRF and XRD Analyses of PFBR RDF Ash
(high-temperature ash, % of ash)

Sample Number PFB-RF1- 794	Fuel Ash	Bed Material	Cyclone Ash	Fly Ash
Loss on Ignition	NA ¹	0	3.75	2.50
Particle Size, μm	NA	ND ²	18.4	5.7
XRF Analysis				
SiO ₂	41.8	95.7	49.5	47.3
Al ₂ O ₃	36.0	2.5	23.6	38.5
Fe ₂ O ₃	2.6	0.2	3.5	2.0
TiO ₂	10.1	0.3	3.0	5.3
P ₂ O ₅	1.6	0.0	0.7	1.3
CaO	1.9	0.6	7.6	1.7
MgO	2.3	0.4	4.1	2.2
Na ₂ O	0.4	0.0	1.2	0.3
K ₂ O	0.3	0.0	0.7	0.4
SO ₃	3.0	0.1	6.0	0.9
Total	100.0	99.8	99.9	99.9
XRD Analysis of Cyclone Ash Material				
Major Phase: Quartz SiO ₂				
Minor Phase: Anhydrite CaSO ₄				
Hematite Fe ₂ O ₃				

¹ Not applicable.² Not determined.

TABLE 14

XRF and XRD Analyses of PFBR RDF-Lignite Fuel Ash
(high-temperature ash, % of ash)

Sample Number PFB-RFK1-0794	Fuel Ash	Bed Material	Cyclone Ash	Fly Ash
Loss on Ignition	NA ¹	0	1.95	ND
Particle Size, μm	NA	ND ²	33.5	ND
XRF Analysis				
SiO ₂	37.7	98.0	65.0	40.3
Al ₂ O ₃	24.7	1.1	15.2	26.3
Fe ₂ O ₃	5.8	0.2	3.4	3.3
TiO ₂	3.7	0.0	2.2	3.2
P ₂ O ₅	0.7	0.0	0.7	0.9
CaO	9.6	0.3	5.9	9.7
MgO	6.6	0.2	4.1	4.4
Na ₂ O	0.7	0.1	0.8	1.1
K ₂ O	0.4	0.0	0.3	0.6
SO ₃	10.1	0.1	2.4	10.1
Total	100.0	100.0	100.0	99.9
XRD Analysis of Cyclone Ash Material				
Major Phase: Quartz SiO ₂				
Minor Phase: Plagioclase (Ca,Na)(Al,Si) ₄ O ₈				

¹ Not applicable.² Not determined.

These data indicate that the SO_2 emissions decrease significantly when the RDF and RDF-lignite blend are used. This result was expected because of the low sulfur levels in the RDF. The low SO_2 numbers were also the result of the relatively high sulfur retention performance of these fuels, retaining the sulfur in the ash material. Figure 13 compares the SO_2 emissions and sulfur retention for each fuel. Tables 12, 13, and 14 show the results of XRF and XRD analyses of the fuel ash as compared to composite bed material, cyclone ash, and fly ash samples. With all three fuels, the bed material was composed mostly of the silica sand bed material, with very little calcium and sulfur being retained. The cyclone ashes from these fuels tended to contain more of the calcium, magnesium, and sulfur than did the other fractions. While the cyclone ash from the RDF combustion did not contain very much calcium and magnesium, the relatively high SO_3 concentration indicates that the available calcium and magnesium were highly sulfated. The intermediate concentration of calcium and magnesium in the RDF-lignite blend, together with the low SO_3 concentration, indicates the presence of excess calcium in the RDF-lignite blend and is consistent with the high sulfur retention seen with this fuel.

Results from toxicity characteristic leaching procedure (TCLP) tests are shown in Table 15 for both the bed material and the cyclone ash for each of the fuels tested. The TCLP is designed to determine the mobility of both organic and inorganic components of solid or liquid wastes out of the waste and into the environment. In this case, the solid residues from these combustion tests were extracted with 20 times the weight of the solid in the appropriate extraction fluid. The choice of extraction fluid depends on the alkalinity of the solid phase. Following extraction, the fluid is separated from the solid phase and analyzed by atomic absorption (AA) or inductively coupled atomic plasma (ICAP). The only Resource Conservation and Recovery Act (RCRA) metal that appears to present a possible problem for the disposal of these combustion by-products in a landfill is leachable chromium. The cyclone ash samples seem to contain significantly more chromium than the spent bed material. Approximately 43% of the chromium content in various household waste fractions (i.e., sources of RDF) can be attributed to metal alloys (1). These metal alloys could be reduced by a more discriminating resource recovery process rather than the "handpicked" RDF process from which the current fuel source was supplied.

4.0 SUMMARY

The EERC has recently commissioned a 3-in.-ID pressurized fluidized-bed reactor to be used for sorbent characterization, the evaluation of gaseous emission including testing for trace elements, and agglomeration and hot-gas cleanup testing. Initial results from the characterization of alkali gettering indicate that in-bed getters can remove a significant amount of the alkali in the bed. Using kaolin as a sorbent, sodium levels in the flue gas were reduced from 3.6 ppm to less than 0.22 ppm. Sulfur was also reduced by 60% using the kaolin sorbent. Future work will examine the impact of operating conditions and sorbent type and size on the reduction of alkali.

Other testing focused on the characterization of sulfur sorbents. The intent of the study was to develop a reliable technique to predict the performance of sorbents in the PFBC. One limestone has been characterized to date, with testing on additional sorbents planned. Preliminary results indicate that although the total sulfur capture is significantly lower than that observed in a full-scale PFBC, the emission trends tend to be similar. The true test of the small PFBR will come when additional

Figure 13. Comparison of SO₂ emission and sulfur retention for each fuel type.

sorbents are tested, the relative trends are ranked against other sorbents, and the data of the small PFBR are compared to full-scale data. Additional data is being generated and can be obtained from the authors.

The RDF and RDF-lignite fuels combusted very well in the PFBR combustion facility at the EERC, with combustion efficiencies exceeding 99.0% in all cases. Sulfur dioxide emission was significantly lower for the RDF-based fuels than the levels seen for the lignite fuel alone. The nitrogen oxide emission was lower for the RDF-based fuels than that experienced from the lignite fuel owing to the lower fuel-bound nitrogen for the RDF fuel. Sulfur dioxide and nitrogen oxide emissions were well below current federal regulations. Carbon monoxide and hydrocarbon emissions appeared to be slightly higher for the fuels containing RDF but were below 9 ppm for the worst case (RDF alone). Analysis of VOC emission does not indicate an emission problem for these fuels. Some differences were apparent in the amount of particulate matter exiting the primary cyclone between the RDF-lignite blend and both the lignite fuel and the RDF slurry alone. Chromium appears to be the only RCRA metal that might present some disposal problem; however, processing of the RDF with the wet resource recovery method should reduce the levels of chromium to below those seen in the current test fuel.

TABLE 15

Results from TCLP Tests for RCRA Metals on Selected
Combustion Products Derived from All Three Slurry Fuels

Elements, mg/L	Knife River Lignite, Bed Material	Knife River Lignite, Cyclone Ash	RDF Bed Material	RDF Cyclone Ash	RDF-Lignite Bed Material	RDF-Lignite Cyclone Ash	Maximum Concentration Limits
Ag	<0.001	<0.001	<0.001	<0.001	<0.001	<0.001	0.05
Ba	0.193	0.141	0.314	0.437	0.306	0.112	1.0
As	<0.01	0.026	<0.01	<0.01	<0.01	0.011	0.05
Cr	0.030	0.056	0.070	0.109	<0.01	0.106	0.05
Cd	<0.001	<0.001	0.0011	<0.001	<0.001	0.0028	0.01
Pb	<0.01	<0.01	0.018	<0.01	<0.01	<0.01	0.05
Hg	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	<0.0001	0.002
Se	<0.002	<0.002	<0.002	0.0028	<0.002	<0.002	0.01

5.0 REFERENCES

1. Newby, R.A.; Keairns, D.L.; Lippert, T.E.; Alvin, M.A.; Bachovchin, D.M. "PFBC at Higher Combustion Temperatures," *Modern Power Systems* **1989**, 9 (11), 41-47.
2. Collings, M.E.; Mann, M.D. "Empirical Modeling of N₂O Emissions from Circulating Fluidized-Bed Combustion," *Energy & Fuels* **1994**, 8, 1083-1094.