**National Ignition Facility
SubSystem Design Requirements
Final Optics Assembly Subsystem
SSDR 1.8.7**

C. Adams

October 30, 1996

DISCLAIMER

This document was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor the University of California nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or the University of California, and shall not be used for advertising or product endorsement purposes.

This report has been reproduced
directly from the best available copy.

Available to DOE and DOE contractors from the
Office of Scientific and Technical Information
P.O. Box 62, Oak Ridge, TN 37831
Prices available from (615) 576-8401, FTS 626-8401

Available to the public from the
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Rd.,
Springfield, VA 22161

National Ignition Facility
Subsystem Design Requirements
Final Optics Assembly Subsystem
SSDR 1.8.7

Revision B
30 October, 1996

Prepared by:

C. Adams, Final Optics Assembly Lead Engineer

Date 10/24/96

Reviewed:

V. Karpenko, Target Experimental System Engineer

Date 10/21/96

R. Sawicki, NIF Special Equipment APE

Date 10/18/96

Level 4 Configuration Control Board Approval:

S. Kumpan, NIF Project Engineer

Approval Date 10/30/96

Table of Contents

<u>Paragraph</u>	<u>Title</u>
1.0	Scope
2.0	Applicable Documents
2.1	Applicable NIF Project Documents
2.2	Applicable US Government Orders, Codes, and Standards
2.3	Applicable National Consensus Codes and Standards
2.4	Applicable LLNL Standards
3.0	Subsystem Description and Characteristics
3.1	System Definition
3.1.1	System Description
3.1.2	System Functions
3.1.3	System Diagrams
3.1.3.1	System Operating Modes
3.1.4	System Interfaces
3.1.5	Major Subsystems
3.2	Subsystem Requirements and Verification
3.2.1	Performance Characteristics
3.2.1.01	Performance Characteristics - Mounting/ Position of Optical Elements
3.2.1.02	Performance Characteristics - Alignment/ Adjustability of Optical Elements
3.2.1.03	Performance Characteristics - Structural Stability
3.2.1.04	Performance Characteristics - Thermal
3.2.1.05	Performance Characteristics - Vacuum Compatibility
3.2.1.06	Performance Characteristics - Cleanliness
3.2.1.07	Performance Characteristics - Allowable Stress
3.2.1.08	Performance Characteristics - External Loading
3.2.1.09	Performance Characteristics - Neutron Activation
3.2.1.10	Performance Characteristics - Debris Shields - Physical Protection
3.2.1.11	Performance Characteristics - Debris Shield - Contamination Barrier
3.2.1.12	Performance Characteristics - Debris Shields- Removal Rate
3.2.1.13	Performance Characteristics - Vacuum Isolation Valve - Cycle Time
3.2.2	Physical Characteristics of Subsystems
3.2.2.1	Physical Characteristics - Integrated Optic Module (IOM)
3.2.2.1.1	Physical Characteristics - Final Optic Cell (FOC)
3.2.2.1.2	Physical Characteristics - FCC Angular Adjustment System (FAAS)
3.2.2.1.3	Physical Characteristics - FFL Linear Adjustment System (FLAS)
3.2.2.1.4	Physical Characteristics - Debris Shield System (DSS)
3.2.2.1.5	Physical Characteristics - Vacuum Window System (VWS)
3.2.2.1.6	Physical Characteristics - Thermal Control System (TCS)
3.2.2.2	Physical Characteristics - Laser Diagnostics
3.2.2.3	Physical Characteristics - Optical Spacing and Sizes of Elements
3.2.2.5	Physical Characteristics - Integration of FOA
3.2.3	Reliability, Availability, Maintainability
3.2.3.1	Lifetime
3.2.3.2	Replaceability
3.2.3.2.1	Replaceability - Integrated Optic Module (IOM)
3.2.3.2.2	Replaceability - Debris Shield System (DSS)
3.2.3.2.3	Replaceability - 3w Calorimeter Detector
3.2.3.2.4	Replaceability - 3w Calorimeter Chamber (3wCC)
3.2.3.2.5	Replaceability - Vacuum Isolation Valve
3.2.3.3	Reliability

3.2.3.4	Inherent Availability
3.2.3.5	Maintainability
3.2.3.6	Recovery from Abnormal Events
3.2.4	Environmental
3.2.4.1	Environmental - Operating and Transportation
3.2.4.2	Environmental - Ambient Cleanliness
3.2.4.3	Environmental - Ambient Random Vibration
3.2.4.4	Environmental - Shot Characteristics
3.3	Design and Construction
3.3.1	Design/ Construction - Hazard Classification
3.3.1.1	Design/ Construction - Hazards Classification - Natural
3.3.2	Design/ Construction - Safety
3.3.2.1	Design/ Construction - Safety - Life
3.3.2.2	Design/ Construction - Safety - Laser
3.3.2.3	Design/ Construction - Safety - Occupational
3.3.2.4	Design/ Construction - Safety - Radiation Protection
3.4	Logistics
3.4.1	Spare Equipment
3.4.2	Maintenance Equipment
4.0	QA Provisions
4.1	Q-Level Assigned

1.0 Scope

This SSDR establishes the performance, design, development and test requirements for the Final Optic Assembly (FOA). The FOA (WBS 1.8.7) as part of the Target Experimental System (1.8) includes vacuum windows, frequency conversion crystals, focus lens, debris shields and supporting mechanical equipment.

2.0 Applicable Documents

This section lists NIF Project Documents, DOE and other government orders, codes, and standards, and national consensus standards which are applicable to the FOA Subsystem. Applicable LLNL standards are also being considered contingent upon the decision of final site selection.

2.1 Applicable NIF Project Documents

National Ignition Facility Functional Requirements and Primary Criteria, Revision 1.4, L-15983-3, February, 1996

National Ignition Facility System Design Requirements, Laser System SDR002, Revision A, NIF-LLNL-96-228, L-21707-01

National Ignition Facility System Design Requirement 003, Target Experimental System Design Requirements, Revision A, NIF-96-227, L-21706-01

"Proposed Metrication Policy for NIF," memo from R. Sawicki, NIF-LLNL-96-038, L-21248-01, 21 January, 1996

NIF Grounding Plan, NIF-LLNL-94-211, L-17346-1

NIF-LLNL-93-044/L-15958-1, National Ignition Facility Quality Assurance Program Plan, November 1993

Target Emission Group (Tobin, Marshall, et al) papers
Debris Shield Group (Marion, Campbell, et al) papers

2.2 Applicable US Government Orders, Codes, and Standards

- 420.1 - Facility Safety
- N441.1 - Protection for DOE Radiological Activities
- 5400.5 - Radiation Protection of the Public and the Environment
- 5700.6C—Quality Assurance
- 5480.9—Construction Safety and Health Program
- 5480.10—Contractor Industrial Hygiene Program
- 5480.11—Radiation Protection for Occupational Workers

2.3 Applicable National Consensus Codes and Standards

ASME Boiler and Pressure Vessel Code; Section VIII

2.4 Applicable LLNL Standards

LLNL Committee on Metrification, 10 October 1992, "LLNL Metric Transition Path"
LLNL M-012 Rev 7, Feb 1993, "Design Safety Standards -Mechanical Engineering"
LLNL M-010, March 1989, "Health and Safety Manual"
LLNL, M-010 "Hazards Control Manual"
LLNL, M-256 "Mechanical Engineering Design Practice"
LLNL "Mechanical Engineering Policy Procedures Manual"

3.0 Subsystem Description and Characteristics

3.1 System Definition

This section defines the overall Final Optic Assembly (FOA) as well as subsystems of the FOA to which this SDDR applies. It provides sufficient description of the system configuration and component parts to facilitate understanding of the requirements

3.1.1 System Description

The FOA provides for the optical mounting and operational maintenance of resident optics. These optics consist of vacuum windows, frequency conversion crystals, final focus lenses, diffractive optics and debris shields. The FOA interfaces directly to the outer surface of the target chamber. Four beamlines arranged in a 2x2 quad-array are incorporated into the FOA. With 192 beamlines this results in 48 FOA's populating the surface of the target chamber at prescribed locations. (These location may be found in SDR3, section 3.2.1.1.). In addition to providing mounting for said optical components, precision adjustment capability is required of these optics during operations. These include a precision 2 axis angular positioner at each beamline for the frequency conversion crystals and a z-axis translation capability for the focus lens/ frequency conversion which are mounted in a common cell. Subsystems and components of the FOA must meet design constraints on optical quality, neutron activation, vacuum compatibility, thermal control, cleanliness and operational concerns.

Furthermore, the FOA integrates two laser diagnostic and alignment subsystems. One laser diagnostic package consists of a diffractive grating, turning mirror and calorimeter. The other is an alignment subsystem for each beamline. This subsystem provides for 1w beam centering and alignment to the frequency conversion crystals. A provisional subsystem being evaluated is a vacuum isolation valve which will allow for the vacuum isolation of the FOA from the target chamber for servicing, maintenance and tasks requiring non-vacuum environment of the FOA while the chamber is at vacuum. This valve would increase the operational flexibility of the NIF. As mentioned previously, there is a requirement for a debris shields at the output side of the final optic assembly. These shields are to provide physical protection to the other optical elements of the FOA. Debris maybe in the form of projectiles and plasma emanating from the target region, the chamber walls, beam dumps and any other source in the chamber (diagnostics, inserters, etc). These shields are expected to be replaced often and so a means to allow for the rapid replacement is required to be designed into the system. Another element to be packaged with the debris shield is a beam smoothing optic. This is to address the need operational need of rapidly changing the phase plate characterisitic based on shot requirements. Other elements or subsystem of the FOA will also require scheduled and unscheduled maintenance and the FOA and subsystems are to be designed for replacement at a rate consistent with the overall NIF availability requirement.

3.1.2 System Functions

The FOA converts 1w light to the third harmonic through use of a type I/ type II KDP/ KD*P frequency conversion crystals which are mounted within an integrated optic module which in turn is attached to the target chamber through the 3w calorimeter chamber. Figure 3.1.2 is a schematic illustration of one of the four beamlines of the FOA. Each beamline first passes through a vacuum window, then on through the frequency conversion crystals (FCC), a final focus lens and finally through the debris shield before focus is achieved at chamber center. In addition provisions will be made for 3w calorimetry as well as beam centering alignment at the FCC. All of these subsystem need to operate in reliable manner consistent with the general overall reliability of the system. Also replaceable units should be designed to minimize the down-time of NIF. In summary the FOA is to perform the following functions:

- * Convert a 1w (1053nm) beam to a 3w (351nm) beam
- * Focus the 3w light onto a common focal area near the target chamber center
- * Disperse the residual 1w and 2w light away from the target laser entrance hole (LEH)
- * Provide required spot envelope at target
- * Provide for the mounting of the frequency conversion crystal, focus lens, debris shield and any diffractive optic included in the design
- * Provide a vacuum barrier for the target chamber
- * Provide the necessary mounting for laser diagnostics consisting of a 3w calorimeter and a 1w beam centering system
- * Provide thermal management for the frequency converter crystals

Figure 3.1.2: Schematic illustration of the Final Optic Assembly

3.1.3 System Diagrams

A cutaway isometric view of the FOA with major functional elements is shown in figure 3.1.3.

Figure 3.1.3: An isometric view of the functional elements of the Final Optic Assembly

WBS 1.8.1 Target Chamber: The FOA's mount directly to the outside of the target chamber. The FOA and target chamber share the same vacuum space and vacuum system. The target chamber must provide a stable optical platform for the FOA.

WBS 1.8.3 Target Diagnostic: The FOA's share the same surface of the chamber sphere as target diagnostic

WBS 1.8.4 Target Structure: The primary interface with this WBS element are the beamtubes which mount to input surface of the FOA.

WBS 1.8.5 Environmental Protection Systems: Components of the FOA, particularly the debris shields will be decontaminated by the EPS on a routine basis.

3.1.5 Major Subsystems

As described previously (section 3.1) the FOA consist of mechanical subsystems which are comprised of, or are integrated with optical elements or thermal/ mechanical subsystems which perform the appropriate tasks to meet system design requirements. The optical elements which are to mounted, aligned, adjusted and thermally controlled are the following:

1. Frequency Conversion crystals (FCC)
2. Final focus lens (FFL)
3. Diffractive optic (DO)
4. Debris shields (DS)
5. 1w vacuum window (VW)

Subsystems of the FOA which are considered either mechanical or thermal subsystems are listed below followed by an acronym which will be used throughout the course of this SSDR. Figure 3.1.5 indicates where these subsystems are located within the FOA.

1. The integrated optic module (IOM), which is further comprised of:
  - a. Final optic cell (FOC), provide mounting for optical elements consisting of FCC, FFL and DO.
  - b. FCC angular adjustment system (FAAS), allows for angular adjustment of the conversion crystals.
  - c. Final focus lens adjustment system (FLAS), allows for focus adjustment of the lens.
  - d. Debris shield system (DSS), provides for insertion, mounting and retrieval of shields.
  - e. Vacuum window system (VWS), provide a vacuum barrier to the target chamber.
  - f. FCC thermal control system (TCS), provides thermal control for the conversion crystals.
2. Structures/ vacuum chambers
  - a. Integrated optic module chamber (IOMC), a vacuum chamber which houses FOA subsystems.
  - b. 3w calorimeter chamber (3wCC), a vacuum chamber which houses the 3w calorimeter system
3. Laser diagnostics
  - a. 3w calorimeter system (3wCS), provides for energy measurement of the 3w beam.
  - b. 1w beam centering system (1wBCS), allows for alignment of the 1w beam.
4. Vacuum isolation valve (VIV), allow maintenance of FOA subsystems at atmospheric conditions.

Fig 3.1.5: Subsystems of the FOA identified.

3.2 Subsystem Requirements and Verification

The following sections define the minimum requirements which must be met by the Final Optic Assembly related to performance, physical characteristics, etc. The approach for verifying that the design and the hardware meets each requirement is listed for each.

3.2.1 Performance Characteristics

This section describes the performance characteristics of thermal/ mechanical subsystems of the FOA as described in section 3.1.5. The following table lists the performance characteristics associated with each of the identified components.

		Optic Mounting/ Position	Stability/ Stiffness	Thermal Control	Vacuum Compatibility	Cleanliness	Allowable Stress	External Loads	Neutron Activation
Mechanical Subsystems									
	FOC								
	FAAS								
	FLAS								
	DSS								
	VWS								
	TCS								
Structures									
	IOMC								
	3wCC								
	VIV								
Laser Diagnostics									
	3wCS								
	1wBCS								

Table 3.2.1: Performance Characteristics of the FOA Subsystems

3.2.1.01 Performance Characteristics - Mounting/ Position of Optical Elements

The FOA houses the optical elements described in section 3.1.5. The alignment of these elements can be considered to be broken into two parts. The first is the location or position of these elements with respect to each other. The second part is the tolerance on that position. The following table identifies what these values are for the optical elements of the FOA. The coordinate system used is shown in figure 3.1.3.

Table 3.2.1.01: Alignment criteria for FOA optical elements
(refer to figure 3.1.3 for description of coordinate system)

This table indicates the position of the final optic elements as they are assembled in the OAB with respect to a common reference.
The position values listed are referenced in the FOA - Optics Configuration drawing (AAA96-104900),

Optical Component	Position (mm or mrad)					
	x	y	z ¹	θ_x	θ_y	θ_z
Vacuum Window ²	0	0	7473	0		0
SHG ³	0	0	7035	0	10	0
THG ³	0	0	7019	0	10	0
Final Focus Lens ³	0	0	7000	0	0	0
Diffraction Optic ³	0	0	6645	0	10	0
Debris Shield ²	0	0	6625	0	0	0
Optical Component	+/- Tolerance (mm or urad)					
	x	y	z	θ_x	θ_y	θ_z
Vacuum Window ²	3	3	3	5000	5000	5000
SHG ^{3,4,5}	2	2	2	20	20	5000
THG ^{3,4}	2	2	2	20	20	5000
Final Focus Lens ³	0	0	0	0	0	5000
Diffraction Optic ³	3	3	3	10000	10000	10000
Debris Shield ²	3	3	3	30000	30000	30000

Notes:

- 1: These dimensions are at the input surface of the optical element with the origin at target chamber center.
- 2: These elements are not part of the final optic cell (FOC). Will be located through repeatable intermediate interfaces
- 3: These elements are assembled within the FOC, therefore can be located accurately with respect to each other.
- 4: SHG/THG tolerance includes crystal cutting errors, FOC fabrication tolerance, assembly tolerance, and off-line alignment
- 5: These numbers have been validated by tolerance study referenced in FOC Tolerance Study (NIF #'' jiii-kkkk-III))

3.2.1.02 Performance Characteristics - Alignment/ Adjustability of Optical Elements

As described in the text of 3.1.5 the FCC and the FLL have to be actively aligned or adjusted to the beamline during operation use. This is accomplished with the FAAS and the FLAS. The performance requirements of these subsystems is outlined in the following table.

Table 3.2.1.02: Adjustment requirement for the FAAS and FLAS
(refer to figure 3.1.3 for description of coordinate system)

This table indicates the alignment ranges, accuracies and resolutions of the final optic elements as they are automatically aligned during operations.

	+/- Range (mm or mrad)					
Optical Component	x	y	z	θ_x	θ_y	θ_z
Final Optic Cell ¹	0	0	50 ²	20 ³	20 ³	0

	+/- Accuracy (mm or urad)					
Optical Component	x	y	z	θ_x	θ_y	θ_z
Final Optic Cell	0.1 ⁴	0.1 ⁴	0.3	5	5	n/a

	+/- Resolution (mm or urad)					
Optical Component	x	y	z	θ_x	θ_y	θ_z
Final Optic Cell ¹	n/a	n/a	0.1	2	2	n/a

Notes:

- 1: The Final Optic Cell houses the SHG, THG, focus lens.
- 2: This is a minimum motion; Allow for center of travel as well as tolerance build-up from chamber interface.
- 3: This is motion allowance for fabrication tolerance on the target chamber and FOA assemblies.
- 4: This number maybe allowed to be larger over full range of travel, dependent on alignment procedure.

3.2.1.03 Performance Characteristics - Structural Stability

As shown in table 3.2.1 all subsystems of the FOA have to meet a mechanical stability requirement. The requirement is the position of the FFL shall not move more than 6 μ m laterally when subject external loading consisting of random vibration input as well as thermal loads. The random vibration input is applied at the base of the target chamber pedestal. The level of vibrational input is specified as a power spectral density curve of 10⁻¹⁰ g²/ Hz from 1 to 200 Hz. In addition the FCC shall not be displaced rotationally more than 5 μ rad). Other potential sources to be considered are acoustic sources (air ventilation) or ancillary hardware which may be required in and around the FOA (ie water cooling for the conversion crystals).

3.2.1.04 Performance Characteristics - Thermal

The primary thermal requirement is for the FCC. The TCS will meet the following requirements.

- 1) The TCS shall be capable of controlling the absolute temperature of the FCC crystals between 19.7C and 20.3C to within +/-0.1C (TBD).
- 2) The TCS shall hold the temperature of each crystal uniformly to +/-0.1C over the entire crystal.
- 3) The temperature of each crystal shall be held for a 2hr time period starting with start of alignment sequence to shot time.
- 4) The TCS shall be designed to cool the FCC to acceptable levels within a 2hr time period.

- 5) The design shall not preclude the possibility of an increase shot rate of 4 hr which would result in an approximately 1hr time window to maintain crystal temperature.

Additional consideration shall be given to internal sources of heat such as motors and actuators.

3.2.1.05 Performance Characteristics - Vacuum Compatibility

As shown in table 3.2.1 all subsystems of the FOA have to meet a vacuum compatibility requirement. These subsystems shall be designed to operate in a vacuum environment of 5×10^{-5} torr. Outgassing of internal surface shall be minimized. The mechanical design, fabrication techniques and material selection shall be done with due consideration of the requirement.

3.2.1.06 Performance Characteristics - Cleanliness

As shown in table 3.2.1 all subsystems of the FOA have to meet a cleanliness requirement. These subsystems shall be designed to operate and be compatible with a level 100 cleanliness specified in MIL -STD-1246C. Material selection, fabrication techniques and design choices shall be made with due consideration. Additionally all optical surfaces shall be maintained at level 50 except for the debris shield which is subjected to debris and emission from the target chamber.

Maintenance of cleanliness shall be provided during expected routine operations which will be performed on debris shields and other larger subsystems such as the the Integrated Optic Module.

3.2.1.07 Performance Characteristics - Allowable Stress

As shown in table 3.2.1 some of the subsystems of the FOA have to meet a stress requirement.

The mechanical design of these subsystems shall be based on the yield strength of ductile material or the ultimate strength of brittle materials. The factors of safety applied for peak stresses shall follow applicable LLNL design guides as well as any relevant industry or trade association code or rules except as noted. Some designs (notably the vacuum chambers) may require a buckling analysis, in this case the chamber shall be treated as an externally pressurized vessel and is covered under ASME Boiler and Pressure Vessel Code.

Note: The vacuum window shall be designed to minimize the maximum tensile stress of the glass window to less than 500 psi.

3.2.1.08 Performance Characteristics - External Loading

As shown in table 3.2.1 some of the subsystems of the FOA have to meet an external loading requirement. These loadings along with the design response are the following: 1) External atmospheric load; the FOA subassemblies subject to this loading condition will experience deformations and distortions. These deformation shall not unduly influence or impair the ability of these subsystems to meet there performance requirements. 2) Seismic load; the FOA and subsystems shall be designed to withstand a seismic input at the base of the target chamber pedestal (as specified in SDR003 section 3.3.01.2) consistent with a planned downtime of the overall facility (as specified in SDR003 section 3.2.3.5). 3) Random vibration input. (Please see section 3.2.1.01 of this SSDR).

3.2.1.09 Performance Characteristics - Neutron Activation

The design of all subsystem shall minimize the level of neutron activation. Material selection, choice of location of particular components of the subsystem shall be done with due consideration of the neutron environment consistent with section 3.3.2.6 (Safety - Radiation Protection)

3.2.1.10 Performance Characteristics - Debris Shields - Physical Protection

The debris shields shall protect the other optical elements of the FOA from plasma and vaporized target material generated from the target region.

3.2.1.11 Performance Characteristics - Debris Shield - Contamination Barrier

The debris shield shall provide a means to control the amount of tritium which is allowed to reach the final optics as well as other subsystems located within the IOM. A design goal to keep the activation of tritium on surfaces to less than 100dpm/cm².

3.2.1.12 Performance Characteristics - Debris Shields- Removal Rate

The debris shield removal system shall be designed to allow the safe and efficient manual removal of debris shields from the IOM. The DSS should allow for the removal to be accomplished in less than 1 hr time for the four debris shields per FOA.

3.2.1.13 Performance Characteristics - Vacuum Isolation Valve - Cycle Time

The VIV shall be designed to reduce the time associated with opening and closing the valve but done in manner consistent other design consideration (reliability and cleanliness). It is a design goal to allow the valve to be closed, opened and closed again within a TBD (provisional 2 minute) time frame.

3.2.2 Physical Characteristics of Subsystems

This section describes the physical nature of the identified subsystems of the FOA. These characteristic include parameters such as size, mass and general spacing requirements and limitations.

3.2.2.1 Physical Characteristics - Integrated Optic Module (IOM)

As described previously the IOM consists of:

1. Final optic cell (FOC)
2. FCC Angular adjustment system (FAAS)
3. Final focus lens adjustment system (FLAS)
4. Debris shield system (DSS)
5. Vacuum window assembly (VWS)\
6. Thermal Control System (TCS)

The outer housing of the IOM is the IOM chamber (IOMC). It shall provide vacuum housing in which to mount and attach the subsystem described above. The overall size of the chamber shall be consistent with these requirements as well as be sized so as to eliminate interferences with other hardware which is mounted on the surface of the target chamber, particularly other FOA's, target diagnostics and ancillary support equipment. The IOMC shall be designed with fixtures to aid and allow for the safe and efficient transport and handling of the IOM.

3.2.2.1.1 Physical Characteristics - Final Optic Cell (FOC)

The following are the pertinent physical characteristic of the FOC:

1. The FOC shall be designed large to enough to house resident optics yet fit within the IOM structure.
2. The FOC shall be designed with a mechanical hard aperture of 40cm x 40cm with 0.5cm (TBD) corner radii. This aperture shall be located in front of the frequency conversion crystals.
3. The mechanical hard aperture shall be made of material which can withstand the intensity, wavelength and power of the NIF beamline.
4. The mounting of the FCC within the FOC shall be allowed with a 0.5cm margin around the perimeter of the crystal

3.2.2.1.2 Physical Characteristics - FCC Angular Adjustment System (FAAS)

The following are the pertinent physical characteristic of the FAAS:

1. The FAAS shall be designed to carry the load of a single FOC and perform its required adjustment functions.

2. The FAAS shall be designed to not interfere with other FAAS's or other hardware within the IOM.
3. It is a design goal to allow for the local control of the alignment system for the FCC. This local control shall be in compliance with standard/ procedure set forth by the ICC.

3.2.2.1.3 Physical Characteristics - FFL Linear Adjustment System (FLAS)

The following are the pertinent physical characteristic of the FLAS:

1. The FLAS shall be designed to carry the load of 4 FOC's and 4 FAAS's and perform its required adjustment functions.
2. The FLAS shall be designed to not interfere with the DSS or other hardware within the IOM and 3wCC.
3. The nominal physical spacing of the four beamlines as described by a plane containing the midpoint of the final focus lenses shall be the following:

$s_{\text{long}} = 50.6 \text{ cm}$ (provisional)

$s_{\text{latitude}} = 57.5 \text{ cm}$ (provisional)

(please refer to figure 3.2.2.1.3 for clarification of the dimensions)

4. It is a design goal to allow for the local control of the alignment system for the FCC. This local control shall be in compliance with standard/ procedure set forth by the ICC

Figure 3.2.2.1.3: Center to center spacing of final optics focus lens

3.2.2.1.4 Physical Characteristics - Debris Shield System (DSS)

The following are the pertinent physical characteristic of the DSS:

Technical Information Department • Lawrence Livermore National Laboratory
University of California • Livermore, California 94551