231516

UCRL-ID-126990 Rev 2

**National Ignition Facility
SubSystem Design Requirements
Optical Mounts
SSDR 1.4.4**

M. Richardson

October 6, 1996

Lawrence
Livermore
National
Laboratory

This is an informal report intended primarily for internal or limited external distribution. The opinions and conclusions stated are those of the author and may or may not be those of the Laboratory.

Work performed under the auspices of the U.S. Department of Energy by the Lawrence Livermore National Laboratory under Contract W-7405-Eng-48.

DISCLAIMER

This document was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor the University of California nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or the University of California. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or the University of California, and shall not be used for advertising or product endorsement purposes.

**This report has been reproduced
directly from the best available copy.**

**Available to DOE and DOE contractors from the
Office of Scientific and Technical Information
P.O. Box 62, Oak Ridge, TN 37831
Prices available from (615) 576-8401, FTS 626-8401**

**Available to the public from the
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Rd.,
Springfield, VA 22161**

National Ignition Facility

Subsystem Design Requirements

Optical Mounts

SSDR 1.4.4

Revision 2
October 6, 1996

Prepared by:

M. Richardson, Optomechanical Systems Lead Engineer

Date

9/23/96

Reviewed:

J. Bowers, Beam Transport System Engineer

Date

9/25/96

R. Sawicki, NIF Special Equipment APE

Date

9/10/96

Engineering Review Board Approval:

S. A. Kumpan, NIF Project Engineer

Date

10/6/96

Table of Contents

Paragraph	Title
1.0	Scope
2.0	Applicable Documents
2.1	Applicable NIF Documents
2.1.1	Applicable NIF Project Documents
2.1.2	Applicable NIF Drawings
2.1.3	Interface Control Documents
2.2	Applicable US Government Orders, Codes, and Standards
2.2.1	DOE Orders
2.2.2	Other Government Regulations
2.3	Applicable National Consensus Codes and Standards
2.4	Applicable LLNL Standards
3.0	Subsystem Characteristics and Verification
3.1	Subsystem Definition
3.1.1	Subsystem Description
3.1.2	Subsystem Functions
3.1.3	Subsystem Diagrams
3.1.3.1	Subsystem Operating Modes
3.1.4	Subsystem Interfaces
3.1.4.01	LM1 Optical Mount Interfaces
3.1.4.02	LM2 Optical Mount Interfaces
3.1.4.03	Polarizer/LM3 Optical Mount Interfaces
3.1.4.04	Spatial Filter Lens Mounts Interfaces
3.1.4.05	Injection Mirror Mount Interfaces
3.1.4.07	Switchyard Mirror Mount Interfaces
3.1.4.09	Target Area Mirror Mounts
3.2	Requirements and Verification
3.2.1	Performance Characteristics
3.2.1.01	Spatial Filters
3.2.1.01.01	Spatial Filter Lens Translational Stability
3.2.1.01.02	Spatial Filter Lens Rotational Stability
3.2.1.01.03	Spatial Filter Lens Position Accuracy
3.2.1.01.04	Spatial Filter Lens Rotational Position accuracy
3.2.1.01.05	Stress Induced Birefringence
3.2.1.01.06	Lens Maximum Principle Stress
3.2.1.03	Injection Mirror
3.2.1.03.01	Injection Mirror Translational Stability
3.2.1.03.02	Injection Mirror Rotational Stability
3.2.1.03.05	Lens Stress Induced Birefringence
3.2.1.04	Cavity Mirror Mount Assemblies
3.2.1.04.01	LM1/LM2 Mounted Wavefront Distortion
3.2.1.04.02	Alignment Positioner Accuracy
3.2.1.04.03	Alignment Positioner Resolution
3.2.1.04.04	Alignment Positioner Range
3.2.1.04.05	Mirror Angular Stability
3.2.1.04.06	LM1/LM2 Mirror Position Accuracy
3.2.1.05	Polarizer/LM3 Mount Assemblies
3.2.1.05.01	Polarizer/LM3 Mounted Wavefront Distortion
3.2.1.05.02	Alignment Positioner Accuracy
3.2.1.05.03	Alignment Positioner Resolution

Table of Contents

Paragraph	Title
3.2.1.05.04	Alignment Positioner Range
3.2.1.05.05	Polarizer/LM3 Angular Stability
3.2.1.05.06	Polarizer/LM3 Mirror Position Accuracy
3.2.1.06	Beam Transport Turning Mirror Mount Assemblies
3.2.1.06.01	Beam Transport Turning Mirror Mounted Wavefront Distortion
3.2.1.06.02	Alignment Positioner Accuracy
3.2.1.06.03	Alignment Positioner Resolution
3.2.1.06.04	Alignment Positioner Range
3.2.1.06.05	Mirror Angular Stability
3.2.1.06.06	Mirror Position Accuracy
3.2.1.08	Number of Beams
3.2.2	Physical Characteristics
3.2.2.1	General Arrangement
3.2.2.1.1	Optomechanical Subsystem Architecture
3.2.2.1.2	General Arrangement Drawings
3.2.2.2	Optomechanical Subsystem General Configuration
3.2.2.2.1	Cassette Assemblies
3.2.2.2.2	Mirror Assemblies
3.2.3	Reliability, Availability, Maintainability
3.2.3.1	Lifetime
3.2.3.2	Replaceability
3.2.3.3	Inherent Availability
3.2.3.4	Reliability
3.2.3.5	Maintainability
3.2.3.6	Recovery From abnormal events
3.2.4	Environmental
3.2.4.1	Ambient Temperature/Humidity
3.2.4.2	Ambient Cleanliness
3.2.4.3	Ambient Vibration Environment
3.3	Design and Construction
3.3.01	Safety
3.3.01.1	Fail-Safe Design
3.3.02	Cleanliness
3.3.02.1	Internal Cleanliness
3.3.03	Future Modifications and Upgrades
3.3.04	Decommissioning
3.3.05	Human Factors
3.3.06	Interchangeability
3.3.07	Documentation and Records
3.3.08	Design Processes
3.3.09	Supervisory Control
3.4	Logistics
3.4.1	Spare Equipment
3.4.2	Maintenance Equipment
3.4.3	Bottom-Access Maintenance
4.0	QA Provisions
4.1	Q-Level Assigned
6.0	Revision Record

1.0 Scope

This SDDR establishes the performance, design, development, and test requirements for NIF Beam Transport Optomechanical Subsystems. Optomechanical Subsystems includes the mounts for the beam transport mirrors, LM1 - LM8, the polarizer mount, and the spatial filter lens mounts.

2.0 Applicable Documents

This section lists NIF Project Documents, DOE and other government orders, codes, and standards, and national consensus standards which are applicable to the Beam Transport Optomechanical Subsystem. Applicable LLNL standards are also being considered contingent upon the decision of final site selection.

2.1 Applicable NIF Documents

The following NIF Project Documents apply to the Beam Transport Optomechanical Subsystem as specifically referenced in later sections.

2.1.1 Applicable NIF Project Documents

National Ignition Facility Functional Requirements and Primary Criteria, Revision 1.4, L-15983-3, February, 1996

National Ignition Facility System Design Requirements, Laser System SDR002, Revision A, NIF-LLNL-96-228, L-21707-01

"Proposed Metrication Policy for NIF," memo from R. Sawicki, NIF-LLNL-96-038, L-21248-01, 21 January, 1996

NIF Grounding Plan, NIF-LLNL-94-211, L-17346-1

NIF-LLNL-93-044/L-15958-1, National Ignition Facility Quality Assurance Program Plan, November 1993

2.1.2 Applicable NIF Drawings

The following NIF Project drawings apply as specified in sections 3.2 to 3.6. The specified revision applies.

AAA-96-104905-0A, Layout, Beam Transport Configuration

AAA-96-100596-0B, LTAB NIF Optics Main Laser Optic System, 7/19/96

Parsons Drawing No CFG-201, "LTAB, Floor Plan at Level -0", 4/16/96

2.1.3 Interface Control Documents

Interface requirements between WBS level 1.4.4 and other subsystems are controlled through separate Interface Control Documents (ICDs).

2.2 Applicable US Government Orders, Codes, and Standards

2.2.1 DOE Orders

- 5700.6C - Quality Assurance
- 420.1 - Facility Safety
- 440.1 - Worker Protection Management for DOE Federal and Contractor Employees
- 5400.1 General Environmental Protection Program

2.2.2 Other Government Regulations

- MIL-STD 1246C - Product Cleanliness for Levels and Contamination Control Program

2.3 Applicable National Consensus Codes and Standards

- DOE-STD-1020-94 Natural Phenomena Hazards Design and Evaluation Criteria for DOE Facilities
- ANSI/ASME B1.1 Standard for bolt threads
- ASTM A307 Standard Specification for Carbon Steel Bolts and Studs, 60,000 psi Tensile Strength
- ASTM A325 Standard Specification for High Strength Bolts for Structural Steel Joints
- ASTM A36 Standard Specification for Structural Steel
- ASTM A449 Standard Specification for Quenched and Tempered Steel Bolts and Studs
- ASTM A490 Standard Specification for Heat-Treated Steel Structural Bolts, 150 ksi Minimum Tensile Strength
- ASTM A6 Chemical analysis for structural steel
- ASTM A751, F606 -testing methods for bolts and studs
- ASTM D 3951 (packaging of bolts and studs)
- ASTM F568, A563 Appurtenances for structural steel (nuts and bolts)

2.4 Applicable LLNL Standards

Pending final site selection, the following LLNL standards generally apply to NIF, and are assumed to apply to the optomechanical subsystem until determined otherwise.

LLNL M-012 Rev 7, Feb 1993, "Design Safety Standards -Mechanical Engineering"

LLNL M-010, March 1989, "Health and Safety Manual"

LLNL M-010 "Hazards Control Manual"

LLNL M-256 "Mechanical Engineering Design Practice"

LLNL "Mechanical Engineering Policy Procedures Manual"

3.0 Subsystem Characteristics and Verification

3.1 Subsystem Definition

The Beam Transport Optomechanical Subsystem provides the optical mounts for all full aperture optical elements, excluding the amplifiers, the pockels cells, and FOA's in each of the 192 beam lines. Each mount incorporates the articulation required by the alignment system to point the beams to Target Chamber center. The optical elements that are mounted in this subsystem include the cavity mirrors, polarizer, transport mirrors, and the spatial filter lenses.

3.1.1 Subsystem Description

The Optomechanical Subsystem optical mounts are packaged into cassettes to facilitate the bottom load maintenance concept to be utilized in the laser bays. The cavity mirrors and spatial filter lenses will be assembled into 4 high cassettes. The polarizer and laser mirror 3, LM3, will be assembled into cassettes in pairs. In the switchyard, mirror assemblies LM4 and LM5 will be mounted to the switchyard support structure. Target Area mirror assemblies, LM6, LM7, and LM8 will be mounted in 1 X 2 and 2 X 2 arrays on the Target Area support structure.

3.1.2 Subsystem Functions

The cavity mirror mount assemblies, located at both ends of the laser cavity, provide support and remote alignment of the cavity mirrors. These mirrors reflect the beam back and forth to accomplish multi-pass amplification. The transport turning-mirror mounts provide support and alignment of the mirrors that transport the beam from the laser cavity to the target. The NIF polarizer mount assembly provides support and remote alignment of the polarizer plate to Brewster's angle. The polarizer plate works in conjunction with the Pockels cell to switch the beam out of the laser cavity after four-pass amplification.

Cavity Mirror Mount Assemblies

- Provide support and remote alignment of the cavity mirrors.
- These mirrors reflect the beam back and forth to accomplish multi-pass amplification.

The LM1 optical mount locates and points the deformable mirror.

Laser Alignment Systems (WBS 1.7.1)

Laser alignment systems controls the stepper motor driven actuators to provide tip/tilt control of the mirror mount and two alignment light sources are located behind the deformable mirror.

Laser Bay Support Structures (WBS 1.4.3.2)

The cassette holding an array of LM1 optical mounts is mounted in the deformable mirror support structure on kinematic supports.

Optics Handling Equipment (WBS 1.1.1.3.2)

The LM1 cassette interfaces with the optics maintenance/transfer cart.

Optics Assembly Building (WBS 1.2.2.3)

The LM1 cassette and mounts interface with the assembly and alignment workstations in the Optics Assembly Building.

3.1.4.02 LM2 Optical Mount Interfaces

The LM2 optical mount interfaces include:

Mirrors (WBS 1.6.3)

The optical element is held in the mount.

Laser Alignment Systems (WBS 1.7.1)

Laser alignment systems controls the stepper motor driven actuators to provide tip/tilt control of the mirror mount.

Laser Bay Support Structures (WBS 1.4.3.2)

The cassette holding an array of LM2 optical mounts is mounted in the periscope support structure on kinematic supports.

Laser Beam Diagnostics (WBS 1.7.2)

The mid-chain diagnostic is located behind LM2. This requires that full aperture clearance be maintained through LM2 to the diagnostic.

Optics Handling Equipment (WBS 1.1.1.3.2)

The LM2 cassette interfaces with the optics maintenance/transfer cart.

Optics Assembly Building (WBS 1.2.2.3)

The LM2 cassette and mounts interface with the assembly and alignment workstations in the Optics Assembly Building.

3.1.4.03 Polarizer/LM3 Optical Mount Interfaces

The Polarizer/LM3 optical mount interfaces include:

Mirrors (WBS 1.6.3)

Polarizers (WBS 1.6.4)

The optical elements are held in the mounts.

Laser Alignment Systems (WBS 1.7.1)

Laser alignment systems controls the stepper motor-driven actuators to provide tip/tilt control of the LM3 mirror and polarizer mounts. There is an alignment light source located behind LM3 requiring a partial clear aperture.

Laser Bay Support Structures (WBS 1.4.3.2)

The cassette holding a polarizer and LM3 optical mounts is mounted in the periscope support structure on kinematic supports.

Optics Handling Equipment (WBS 1.1.1.3.2)

The LM3/polarizer cassette interfaces with the optics maintenance/transfer cart.

Optics Assembly Building (WBS 1.2.2.3)

The polarizer/LM3 cassette and mounts interface with the assembly and alignment workstations in the Optics Assembly Building.

3.1.4.04 Spatial Filter Lens Mounts Interfaces

The spatial filter lens mount interfaces include:

Lenses (WSB 1.6.2)

The optical elements are held in the mounts.

Spatial Filter Vacuum Vessels (WBS1.4.1)

The lens mounts mount to the ends of the vacuum vessels providing the vacuum seal, locating the lens in the beam line.

Interstage Beam Enclosures (WBS 1.4.1)

Access through the interstage enclosures will be required for the maintenance/transfer cart to remove and replace spatial filter lenses.

Optics Handling Equipment (WBS 1.1.1.3.2)

The spatial filter lens cassette interfaces with the optics maintenance/transfer cart.

Optics Assembly Building (WBS 1.2.2.3)

The spatial filter lens cassette and mounts interface with the assembly and alignment workstations in the Optics Assembly Building.

3.1.4.05 Injection Mirror Mount Interfaces

The injection mirror mount have the following interfaces:

Mirrors (WBS 1.6.3)

The optical elements are held in the mounts.

Beam Transport Vacuum Enclosures (WBS 1.4.1)

A 4 high array of injection mirrors mounted in cassettes are inserted through the top of the spatial filter vacuum enclosures.

TSF Tower Optic Assembly (WBS 1.7.1.2)

The injection mirror mount is mounted and aligned to the TSF tower optic assembly.

Optics Assembly Building (WBS 1.2.2.3)

The injection mirror mount cassette and mounts interface with the assembly and alignment workstations in the Optics Assembly Building.

3.1.4.07 Switchyard Mirror Mount Interfaces

The switchyard mirror mounts have the following interfaces:

Mirrors (WBS 1.6.3)

The optical elements are held in the mounts.

Support Structures (WBS 1.4.3)

The switchyard mirrors, LM4 and LM5, are mounted on the switchyard support structures.

Switchyard Beam Enclosures (WBS 1.4.1)

The switchyard beam enclosure mount to the mirror mount enclosure.

Optics Handling Equipment (WBS 1.1.1.3.2)

The switchyard mirror mount interfaces with the optics maintenance/transfer cart.

Optics Assembly Building (WBS 1.2.2.3)

The switchyard mirror mounts interface with the assembly and alignment workstations in the Optics Assembly Building.

3.1.4.09 Target Area Mirror Mounts

Target area mirror mounts have the following interfaces:

Mirrors (WBS 1.6.3)

The optical elements are held in the mounts.

Target area structures (WBS 1.8.4)

The target area mirror mounts interface with the target area mirror support structures and the target area beam tubes.

Beam Diagnostics (WBS 1.7.2)

Back scatter diagnostics are located behind LM8, requiring clearance for a full aperture beam through the mirror.

Optics Handling Equipment (WBS 1.1.1.3.2)

The target area mirror mount interfaces with the optics maintenance/transfer cart.

Optics Assembly Building (WBS 1.2.2.3)

The target area mirror mount interface with the assembly and alignment workstations in the Optics Assembly Building.

3.2 Requirements and Verification

The following sections define the minimum requirements which must be met by the Beam Transport Optomechanical Subsystem, related to performance, physical characteristics, etc.

3.2.1 Performance Characteristics

The X, Y, and Z directions for stability and position requirements are defined in the drawings listed in section 2.1.2.

3.2.1.01 Spatial Filters**3.2.1.01.01 Spatial Filter Lens Translational Stability**

Spatial filter lens, SF1 & SF2, translational stability shall be: $(\Delta x^2 + \Delta y^2)^{0.5} \leq 6 \mu\text{m}$ for the 2 hours after alignment and during a shot.

Spatial filter lens, SF3 & SF4, translational stability shall be: $(\Delta x^2 + \Delta y^2)^{0.5} \leq 7 \mu\text{m}$ for the 2 hours after alignment and before a shot, with SF4 translating $\leq 100 \mu\text{m}$ in the Z direction in the same period.

3.2.1.01.02 Spatial Filter Lens Rotational Stability

Spatial filter lens, SF1 - SF3, rotational stability shall be: $(\Delta Q_x^2 + \Delta Q_y^2)^{0.5} \leq 200 \mu\text{rad}$ over the 2 hr period after alignment and before a shot.

Spatial filter lens, SF4, rotational stability shall be: $(\Delta Qx^2 + \Delta Qy^2)^{0.5} \leq 0.7 \mu\text{rad}$ over the 2 hr period after alignment and before a shot.

3.2.1.01.03 Spatial Filter Lens Position Accuracy

All spatial filter lens, SF1-SF4, position accuracy shall be: $(\Delta x^2 + \Delta y^2)^{0.5} \leq 1\text{mm}$.

Spatial filter lens, SF1 & SF2, position accuracy shall be: $\Delta z \leq \pm 1\text{mm}$.

Spatial filter lens, SF3 & SF4, position accuracy shall be: $\Delta z \leq \pm 3\text{mm}$.

3.2.1.01.04 Spatial Filter Lens Rotational Position Accuracy

SF1 - SF3 Spatial filter lens rotational position accuracy shall be: $(\Delta Qx^2 + \Delta Qy^2)^{0.5} \leq 0.1^\circ$.

SF4 Spatial filter lens transverse rotational position accuracy shall be consistent with the requirements of the wavefront diagnostic subsystem.

All spatial filter lens, SF1-SF4, rotational position accuracy shall be: $\Delta Qz \leq \pm 1\text{mrad}$.

3.2.1.01.05 Stress Induced Birefringence

The stress induced birefringence shall be $\leq \text{TBD}$.

3.2.1.01.06 Lens Maximum Principle Stress

The spatial filter lens shall be mounted so that the maximum principle stresses under vacuum load are $\leq 700 \text{ psi}$ new and 800 psi after refinishing.

3.2.1.03 Injection Mirror

3.2.1.03.01 Injection Mirror Translational Stability

The Transport spatial filter beam-injection mirror "LM0" translational stability shall be: $\Delta x, \Delta y, \Delta z \leq 100 \mu\text{m}$.

3.2.1.03.02 Injection Mirror Rotational Stability

Transport spatial filter beam-injection mirror "LM0" rotational stability shall be:

$(\Delta Qx^2 + \Delta Qy^2)^{0.5} \leq 0.7 \mu\text{rad}$.

3.2.1.04 Cavity Mirror Mount Assemblies

3.2.1.04.01 LM1/LM2 Mounted Wavefront Distortion

Mounted wavefront distortion for LM1 and LM2 shall be TBD.

3.2.1.04.02 Alignment Positioner Linearity

Alignment positioners shall be linear within 3% for short travel distances, ~ 100 motor steps, and over the full range of travel.

3.2.1.04.03 Alignment Positioner Resolution

Alignment positioner resolution shall be: $\leq 0.1\text{-}\mu\text{rad}$ incremental adjustment.

3.2.1.04.04 Alignment Positioner Range

Alignment positioner range shall be: $\geq \pm 5 \text{ mrad}$.

3.2.1.04.05 Mirror Angular Stability

LM1 mirror angular stability shall be: $\leq 0.6 \mu\text{rad}$ over 2 hr.

LM2 mirror angular stability shall be: $\leq 0.7 \mu\text{rad}$ over 2 hr.

3.2.1.04.06 LM1/LM2 Mirror Position Accuracy

Installation position accuracy shall be: $(\Delta x^2 + \Delta y^2)^{0.5} \leq 3.0$ mm.

3.2.1.05 Polarizer/LM3 Mount Assemblies

3.2.1.05.01 Polarizer/LM3 Mounted Wavefront Distortion

Mounted wavefront distortion for the Polarizer and LM3 shall be TBD.

3.2.1.05.02 Alignment Positioner Linearity

Alignment positioner shall be linear within 3% for short travel distances, ~100 motor steps, and over the full range of travel.

3.2.1.05.03 Alignment Positioner Resolution

Alignment positioner resolution shall be: ≤ 0.1 μ rad incremental adjustment.

3.2.1.05.04 Alignment Positioner Range

Alignment positioner range shall be: $\geq \pm 5$ mrad.

3.2.1.05.05 Polarizer/LM3 Angular Stability

Polarizer/LM3 angular stability shall be: ≤ 0.6 μ rad over 2 hr.

3.2.1.05.06 Polarizer/LM3 Mirror Position Accuracy

Installation position accuracy shall be: $(\Delta x^2 + \Delta y^2)^{0.5} \leq 3.0$ mm.

Installation position accuracy shall be: $\Delta z \leq 3.0$ mm.

3.2.1.06 Beam Transport Turning Mirror Mount Assemblies

3.2.1.06.01 Beam Transport Turning Mirror Mounted Wavefront Distortion

Mounted wavefront distortion for the transport mirrors shall be TBD.

3.2.1.06.02 Alignment Positioner Linearity

Alignment positioner shall be linear within 3% for short travel distances, ~100 motor steps, and over the full range of travel.

3.2.1.06.03 Alignment Positioner Resolution

Alignment positioner resolution shall be: ≤ 0.1 - μ rad incremental adjustment.

3.2.1.06.04 Alignment Positioner Range

Alignment positioner range shall be: $\geq \pm 7.5$ mrad.

3.2.1.06.05 Mirror Angular Stability

Mirror angular stability shall be: ≤ 0.7 μ rad over 2 hr.

3.2.1.06.06 Mirror Position Accuracy

Installation position accuracy shall be: $(\Delta x^2 + \Delta y^2)^{0.5} \leq \text{TBD}$ (1 mm).

Installation position accuracy shall be: $\Delta z \leq \text{TBD}$ (1 mm).

3.2.1.08 Number of Beams

The optomechanical subsystem shall be configured to process 192 simultaneous beams.

3.2.2 Physical Characteristics

3.2.2.1 General Arrangement

3.2.2.1.1 Optomechanical Subsystem Architecture

The optomechanical subsystem shall incorporate the following basic architecture:

Figure 3.2.2.1.1: Optomechanical Mirror Locations.

3.2.2.1.2 General Arrangement Drawings

The optomechanical subsystem shall conform to the drawings indicated in section 2.1.2 which specify the general arrangement.

3.2.2.2 Optomechanical Subsystem General Configuration

3.2.2.2.1 Cassette Assemblies

The cavity mirrors and spatial filter lenses should be assembled in 4 x 1 cassettes to conform with the 4 x 2 laser bundle configuration.

The polarizer and laser mirror 3 (LM3) shall be assembled in 2 x 1 cassettes to conform with the 4 x 2 laser bundle configuration.

3.2.2.2.2 Mirror Assemblies

Laser mirrors 4 through 8 and the gas box windows shall be configured in 2 x 2, 2 x 1 or 1 x 2 arrays in as required to transport the 2 x 2 laser "quad" beams to target.

3.2.3 Reliability, Availability, Maintainability

3.2.3.1 Lifetime

The optomechanical subsystem shall be designed for a 30 year lifetime.

3.2.3.2 Replaceability

Any portion of the optomechanical subsystem which cannot reasonably be designed for 30-year lifetime shall be designed to be replaced or repaired at reasonable cost in a timely manner consistent with the overall availability of the optomechanical subsystem as stated in 3.2.3.3 and 3.2.3.5. The following components are line replaceable units:

- 1) LM1 cassette
- 2) LM2 cassette
- 3) Polarizer/LM3 cassette
- 4) SF1/SF2 cassette

- 5) SF3 cassette
- 6) SF4 cassette

All components with the same part number shall be interchangeable.

3.2.3.3 Inherent Availability

The optomechanical subsystem shall have a shot availability of at least 99.71 %. The system is unavailable when it is undergoing unplanned maintenance. Unplanned maintenance includes failure detection and active repair as well as logistic and administrative downtimes.

3.2.3.4 Reliability

The optomechanical subsystem shall have an overall reliability of 98.67%. Reliability is defined as the probability of meeting the minimum requirements of the experiment for each no-yield shot as stated in SDR2:3.2.3.4.

3.2.3.5 Maintainability

The optomechanical subsystem shall have a scheduled maintenance plan that fits within an overall annual plant goal of 69 days. The unplanned maintenance goal is 18 hours per year. Opportunistic maintenance activities are performed between shots and during other system downtimes.

3.2.3.6 Recovery From Abnormal Events

The time required for the optomechanical subsystem to recover from any abnormal event shall be less than the maximum times cited below, as a function of the expected yearly frequency of occurrence of the event.

<u>Expected Frequency of Occurrence Per Year, F</u>	<u>Maximum Recovery Time</u>
$F \geq 1$	24 hours
$1 > F > 1E-2$	1 week
$1E-2 > F \geq 5E-4$	3 months

Probabilities listed in DOE-STD-1020-94 shall be used for natural phenomena

3.2.4 Environmental

Maintenance plans for all optomechanical subsystems shall be capable of supporting a shot rate of one shot every eight hours and the plan shall not preclude shot rates of one shot every four hours.

3.2.4.1 Ambient Temperature/Humidity

All optomechanical subsystem components within the Laser and Target Building shall meet all requirements when operated at a temperature of $20^{\circ}\text{C} \pm 0.3^{\circ}\text{C}$, a relative humidity of 30% to 60%, and a pressure equal to ambient atmospheric pressure $\pm$ TBD cm water (to accommodate positive/negative air systems). Any components normally operated outside the LTAB Building shall meet all requirements when operated between -4.4°C (dry bulb, winter) and 20.6°C (wet bulb, summer) or 37.8°C (dry bulb, summer), and local atmospheric pressure.

3.2.4.2 Ambient Cleanliness

The optomechanical subsystem shall meet all requirements when operated within the NIF LTAB. The ambient cleanliness levels in pertinent areas of the LTAB are as follows:

Area Ambient Cleanliness Class
 Laser Bay 100,000
 Switch yard 100,000
 Target Bay 100,000

3.2.4.3 Ambient Vibration Environment

The optomechanical subsystem shall meet all requirements, while being exposed to ambient random vibration of $10^{-10} \text{ g}^2/\text{Hz}$, from 1 to 200 Hz, applied at the special-equipment mounting surface of the foundation of the Laser or Target Area building.

3.3 Design and Construction

The site for NIF has not yet been selected. The present design is therefore non-site-specific. For the purpose of Title I design of the Target Experimental System, it shall be assumed that NIF will be constructed at a site with the general infrastructure as available at candidate sites. Specific environmental assumptions are listed in the following sections.

3.3.01 Safety

The optomechanical subsystem shall be designed, constructed, and operated as part of the NIF such that it is a low-hazard, radiological component of the NIF. Compliance with this classification shall be verified through a Preliminary Hazard Analysis assessment of bounding accidents involving those radionuclides presenting the most significant hazards (see DOE Order 5481.1B, Safety Analysis Review System). Administrative controls shall be established prior to KD3 to ensure that inventory limits for a radiological low-hazard, non-nuclear facility are not exceeded.

Unless otherwise specified herein, all elements of the optomechanical subsystem shall meet the requirements of the LLNL Mechanical Engineering Design Safety Standards, Electrical Engineering Design Standards, and Laser safety standards.

3.3.01.1 Fail-Safe Design

Wherever reasonably possible, optomechanical subsystem shall be designed to fail safe upon inadvertent loss of power or other failure. A failure modes and effects (FMEA) analysis shall be conducted to ensure that critical failure modes are obviated or mitigated.

3.3.02 Cleanliness

3.3.02.1 Internal Cleanliness

The internal optomechanical assemblies shall be precision cleaned and assembled in a Class 100 clean room environment, per FED-STD-209D. During operation of the laser, the optical elements of the laser shall be maintained at a surface cleanliness level as defined by MIL-STD-1246C - Level 50. Permissible cleanliness degradation shall be budgeted across the assembly, measurement, transport, storage, installation and operation phases of laser construction. This budget is described in the document entitled, "Cleanliness Degradation Budgeting for the NIF Laser." The NVR (Non Volatile Residue) level for optical components shall conform to Level A of MIL-STD-1246C or 1 mg m^{-2} .

3.3.03 Future Modifications and Upgrades

As a design goal, the optomechanical subsystem shall provide for future reconfiguration and modification at minimum cost and with minimum effect on the overall operation of the facility as per section 3.2.1.22.2. of SDR 2.

3.3.04 Decommissioning

The optomechanical subsystem shall include considerations to allow cost effective future decommissioning of all structures and equipment.

3.3.05 Human Factors

The optomechanical subsystem shall be designed in an ergonomic fashion to ensure that human reliability during operation and maintenance is sustained at a level consistent with meeting overall availability and reliability objectives. Consistency in human interfaces should be maintained.

3.3.06 Interchangeability

Interchangeability of components shall be preserved as much as practical. Equipment with the same function and physical characteristics shall be interchangeable.

3.3.07 Documentation and Records

The optomechanical subsystem shall provide sufficient documentation to comply with the NIF Quality Assurance Plan, and DOE Order 5700.6C, Quality Assurance, Criterion-4 Documents and Records, which states:

"Documents shall be prepared, reviewed, approved, issued, used and revised to proscribe processes, specify requirements or establish design. Records shall be specified, prepared, reviewed approved and maintained."

Examples of documents that should be controlled include drawings, data files, calculations, specifications, computer codes, purchase orders, vendor supplied documents, procedures, work records and data sheets and test records. Revisions should be reviewed by the organizations that originally prepared and approved the documents. Controlled documents should be distributed to those doing the work.

3.3.08 Design Processes

Design shall be carried out using sound engineering principles and appropriate standards. Design work including changes shall incorporate applicable requirements and design bases. Interfaces shall be identified and controlled. The adequacy of design products shall be verified or validated by qualified individuals other than those who did the work. Verification and Validation work shall be completed before approval and implementation of the design.

3.3.09 Supervisory Control

The optomechanical subsystem shall provide for positioning control by the automatic alignment system. The control system shall be designed to provide control functions required for normal operation and maintenance.

3.4 Logistics**3.4.1 Spare Equipment**

As a part of the design/construction project, the optomechanical subsystem shall provide an initial complement of spare parts as required to activate the system.

3.4.2 Maintenance Equipment

As a part of the design/construction project, the optomechanical subsystem shall provide all equipment required to inspect, service, and maintain itself to meet the maintainability and availability requirements in §3.2.3. Maintenance equipment shall include all handling fixtures, lifting equipment, cleaning equipment and other special tools not otherwise available within NIF, that are necessary to perform any planned (scheduled or unscheduled) maintenance activity.

3.4.3 Bottom-Access Maintenance

As a design goal, all components within the laser bays should be accessed for maintenance from below.

4.0 QA Provisions

Quality Assurance for this subsystem will be determined by verification methods identified in §3, in combination with the identified Quality Level for individual components.

4.1 Q-Level Assigned

WBS element number	WBS element title	Assigned Q-level			Why not Q-level 3 ?
		1	2	3	
1.4.4.1	Switchyard Optical Mounts			√	
1.4.4.2	Periscope Mounts			√	
1.4.4.3	Spatial Filter Optical Hardware			√	
1.4.4.4	Optical Alignment Hardware			√	

6.0 Revision Record

Rev	Date	ECR#	By	Description of/Reason for Change
0	CDR	n/a		
A	6/4/96	n/a	Richardson	initial Title I issue
B	10/6/96	61	Richardson	final Title I update, many miscellaneous changes, TBDs eliminated

Technical Information Department • Lawrence Livermore National Laboratory
University of California • Livermore, California 94551