JUL 20 1998

CONTRACTOR REPORT

SAND98-1513
Unlimited Release

RECEIVED**JUL 27 1998****OSTI**

Review of Power Quality Applications of Energy Storage Systems

Shiva Swaminathan
Rajat K. Sen
Sentech, Inc.
4733 Bethesda Avenue
Suite 608
Bethesda MD 20814

Prepared by
Sandia National Laboratories
Albuquerque, New Mexico 87185 and Livermore, California 94550

Sandia is a multiprogram laboratory operated by Sandia Corporation,
a Lockheed Martin Company, for the United States Department of
Energy under Contract DE-AC04-94AL85000.

Approved for public release; distribution is unlimited.

Printed July 1998

Sandia National Laboratories**MASTER****DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED**

Issued by Sandia National Laboratories, operated for the United States Department of Energy by Sandia Corporation.

NOTICE: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government, any agency thereof, or any of their contractors or subcontractors. The views and opinions expressed herein do not necessarily state or reflect those of the United States Government, any agency thereof, or any of their contractors.

Printed in the United States of America. This report has been reproduced directly from the best available copy.

Available to DOE and DOE contractors from
Office of Scientific and Technical Information
P.O. Box 62
Oak Ridge, TN 37831

Prices available from (615) 576-8401, FTS 626-8401

Available to the public from
National Technical Information Service
U.S. Department of Commerce
5285 Port Royal Rd
Springfield, VA 22161

NTIS price codes
Printed copy: A03
Microfiche copy: A01

DISCLAIMER

**Portions of this document may be illegible
electronic image products. Images are
produced from the best available original
document.**

Review of Power Quality Applications of Energy Storage Systems*

Shiva Swaminathan
Rajat K. Sen
Sentech, Inc.
4733 Bethesda Avenue
Suite 608
Bethesda, MD 20814

Abstract

Under the sponsorship of the U.S. Department of Energy (DOE) Office of Utility Technologies, the Energy Storage Systems Analysis and Development Department at Sandia National Laboratories contracted Sentech, Inc., to assess the impact of power quality problems on the electricity supply system. This report contains the results of several studies that have identified the cost of power quality events for electricity users and providers. The large annual cost of poor power quality represents a national inefficiency and is reflected in the cost of goods sold, reducing U.S. competitiveness. The Energy Storage Systems (ESS) Program takes the position that mitigation merits the attention of not only the DOE but affected industries as well as businesses capable of assisting in developing solutions to these problems. This study represents the preliminary stages of an overall strategy by the ESS Program to understand the magnitude of these problems so as to begin the process of engaging industry partners in developing solutions.

*The work described in this report was performed for Sandia National Laboratories under Contract No. AV-5396.

ACKNOWLEDGMENTS

Sandia National Laboratories would like to thank Dr. Christine E. Platt of the U.S. Department of Energy's Office of Utility Technologies for the support and funding of this work. We would also like to acknowledge the National Power Laboratories, which conducted a study that provided data summaries for four types of power quality events and input from 130 user sites, and Duke Power, which conducted a study that provided detailed data from 198 industrial and commercial users, making it possible to derive approximations of the national impact of power quality events. Thanks are also due to Paul Butler of Sandia's Energy Storage Analysis and Development Department for providing valuable technical review before the final study was published.

Contents

1. Executive Summary	1-1
2. Overview	2-1
3. Problem Description	3-1
Scope of Power Quality Problems	3-1
The NPL Survey Results	3-4
Cost of Poor Power Quality to Customers	3-5
Estimation of National Cost of Poor Power Quality	3-8
4. Technology Options	4-1
Matching the Power Quality Problem with the Technology Solutions	4-2
Cost-Benefit Analysis Example	4-2
5. Conclusions	5-1
Appendix A. Graphical Illustration Of Power Quality Events	A-1

Figures

3-1 The CBEMA Curve	3-3
3-2 CBEMA Curve Analysis of the NPL Survey	3-6
3-3 Difference in Commercial and Industrial Customer Interruption Cost	3-8
4-1 Off-Line Configuration of Energy Storage Systems	4-1
4-2 Line-Interactive Configuration of Energy Storage Systems	4-2
4-3 On-Line Configuration of Energy Storage Systems	4-2

Tables

1-1. Mitigation Capabilities of Protection Devices	1-1
1-2. NPL Summary of Disturbances	1-2
1-3. Duke Power Survey on Cost of Power Quality Events	1-2
1-4. National Cost Estimate for Large Industrial Customers	1-3
3-1. Categories of Power Quality Variations	3-2
3-2. Summary of Power Quality Variation Categories and Causes*	3-3
3-3. Summary Overview of the CEA, NPL, and EPRI Power Quality Surveys	3-4
3-4. Definition of Events in NPL Survey	3-5
3-5. Duration Summary Statistics for All NPL Data	3-5
3-6. Events per Month Based upon All NPL Data and Individual Location Statistics	3-5
3-7. Components of Outage Costs by Scenario	3-7
3-8. National Cost Estimate for Large Industrial Customers	3-10
4-1. Individual Solutions to Single-Category Power Quality Events*	4-3
4-2. Power Quality Solutions and Their Ability to Protect against Events in Multiple Power Quality Categories ...	4-4
4-3. Competitiveness of Energy Storage Systems for Power Quality Applications	4-4

Acronyms and Abbreviations

ASD	adjustable speed drive
CBEMA	Computer Business Equipment Manufacturers Association
CEA	Canadian Electrical Association
DOE	U.S. Department of Energy
EPRI	Electric Power Research Institute
ESS	Energy Storage Systems
IEEE	Institute of Electrical and Electronics Engineers
NPL	National Power Laboratories
PC	personal computer
PG&E	Pacific Gas & Electric
RMS	root mean square
UPS	uninterruptible power supply
Var	volt-ampere reactive

1. Executive Summary

In America, electricity has become ubiquitous. It is present virtually everywhere there is a need, it is available in seemingly limitless quantities, and it performs an uncountable variety of tasks. However, unnoticed by most users, the electricity supply often exhibits imperfections. The magnitude and prevalence of these imperfections, together with the occasional total interruption or outage, constitute the ingredients of power quality.

Increased automation in homes and factories has increased the impact of power quality deviations. Power quality has been defined as any problem manifested in voltage, current, or frequency deviations that results in failure or misoperation of utility or end-user equipment. Examples of power quality events and of devices capable of protecting against their effects are shown in Table 1-1. Storage systems are seen to provide by far the broadest range of power quality protection.

While storage provides comprehensive protection, it may not be the economic choice for each of the power quality events listed in the table. However, because of their ability to detect and respond to the

energy deficiency in the supply source rapidly, energy storage systems are the preferred solution for voltage sags, undervoltages, and interruptions.

Data on the frequency of power quality disturbances are not widespread and are often proprietary. Three surveys conducted to determine the extent of power quality issues have been identified. While the detailed results of the surveys are not available in the public domain, data summaries have been published. The most useful summary for this study was published by the National Power Laboratories (NPL) and included data on 130 user sites consisting of 31% industrial, 24% small business, 18% multistory buildings, 17% residential, and 10% institutional. Table 1-2 summarizes NPL data for four types of power quality events. Because the data show great variance between the number of events in the best locations (zero) and the number in the worst locations (over 1,000 per month for three of the disturbances), it is likely that the median, rather than the average, is more representative of typical performance. Consequently, for this study, the more conservative median is used in subsequent analyses.

Table 1-1. Mitigation Capabilities of Protection Devices

	Power Quality Event								
	Impulsive- Transient	Oscillatory- Transient	Sag/- Swell	Under-/Over- voltage	Interruption	Harmonic Distortion	Voltage Flicker	Noise	Electrostatic Discharge
Surge arrestor	x	x							
Filter	x	x				x		x	x
Isolation transformer	x	x				x			
Constant voltage transformer			x	x					
Dynamic voltage restorer			x	x					
Backup generator					x				
Humidity control									x
Energy storage									
- Off-line	x	x	x	x	x		x	x	
- Line-interactive	x	x	x	x	x		x	x	
- On-line	x	x	x	x	x	x	x	x	x

Table 1-2. NPL Summary of Disturbances

	Best Locations (events/month)	Worst Locations (events/month)	Median (events/month)	Average (events/month)
Sags/Undervoltages (low RMS)	0	1,660	4.1	27.9
Swells/Overtages (high RMS)	0	1,450	3.4	13.9
Transients	0	1,166	15.7	63.5
Interruptions	0	10	1.0	1.3

Information regarding the cost to electricity customers of power imperfections is even less widely available than data on the imperfections. However, a survey conducted by Duke Power has been published that contains information suitable for deriving approximations of national impact. Duke surveyed 198 large industrial and commercial customers and collected information on the components of interruption costs under varying outage conditions. Analyzing the average interruption costs of the various outage conditions showed that the most costly occurrences resulted from electricity outages and voltage sags. The costs for these occurrences are summarized in Table 1-3, in which the greater impact of longer-duration events and the benefits of prior notice are clearly evident.

Few estimates of the national cost of power quality events have been attempted. An article in *Spectrum*, a publication of the Institute of Electrical and Electronics Engineers (IEEE), suggested a cost of \$25 billion, and an Electric Power Research Institute (EPRI) report estimated a cost of \$400 billion. The first value was based on 1.5–3% of sales of the U.S. manufacturing industry, and the second was based on estimates of idled employee-hours due to power quality problems in the commercial sector.

The combination of NPL and Duke Power data provides a third opportunity to estimate national impact,

in particular to estimate the national cost of power quality events that energy storage systems could resolve. Using the frequency of events from the NPL survey and extrapolating the Duke Power data to a national electricity level, a total cost (to large industrial customers) of U.S. power outages and voltage sags—and thus a potential power quality market for storage—can be developed. As shown in Table 1-4, the resulting estimate is approximately \$150 billion annual cost.

The \$150 billion value is developed using only undervoltage/sag and interruption data because these are the two categories of power quality problems in the Duke Power survey for which storage systems are a likely solution. Costs resulting from power quality problems in other categories are excluded. Thus the estimate is conservative in the sense that there may be cases where storage could provide cost-effective solutions for other power quality problems, possibly some not covered in the Duke survey.

It should be recognized that computing a national loss number with data from a single region can be a risky undertaking; opportunities to introduce error are relatively high. Nevertheless, it is noteworthy that the \$150 billion estimate falls between the estimates of \$25 billion and \$400 billion cited earlier. Whatever the actual number, one can postulate with increasing

Table 1-3. Duke Power Survey on Cost of Power Quality Events

	Event				
	4-Hr Outage, No Notice	1-Hr Outage, No Notice	1-hr Outage with Notice	Momentary Outage	Voltage Sag
Average cost of event	\$74,835	\$39,459	\$22,973	\$11,027	\$7,694

Table 1-4. National Cost Estimate for Large Industrial Customers

	Average Annual Cost to Large Industrial Customers	Estimated Cost for Duke Power Customer Group	Estimated Cost for National Customer Group
Undervoltages/sags	\$377,000	\$ 3.2B	\$ 114B
Interruptions	\$132,000	\$1.1B	\$39B
Total estimated U.S. cost (rounded):			\$150B

confidence that the market value of energy storage systems addressing power quality problems could total tens of billions of dollars annually.

The market for such systems has grown in the recent past because of the proliferation of microprocessor-controlled equipment and power electronic motor controls, which are susceptible to distortions in supply waveform. At present, part of the market is served by a variety of uninterruptible power supplies. Largely overlooked, however, are energy storage systems capable not only of meeting large industrial loads during interruptions but also of correcting for voltage magnitude variances and waveform imperfections. Such systems have been installed in recent

years, but large gaps persist in power ratings, protection durations, performance capabilities, flexible siting and operation, cost, and installation ease. Until these shortcomings are overcome, manufacturers and their customers will continue to experience higher than necessary costs.

The large annual cost of poor power quality represents a form of national inefficiency and is reflected in the cost of goods sold, reducing U.S. competitiveness. This cost is ultimately paid by consumers, both domestic and foreign. Its mitigation merits the attention of the affected industries as well as businesses capable of developing solutions and the U.S. Department of Energy (DOE).

2. Overview

The electric utility industry is expected by the public to provide a reliable and uninterrupted supply of electricity—a goal that the industry has achieved to a great extent. Although the reliability of the electricity supply system is high, there are occasional unscheduled outages caused by a variety of unpredictable events. Industries such as telecommunications that cannot tolerate unscheduled outages have installed backup generation and/or energy storage systems in order to alleviate the problem.

In recent years, with increased automation and greater use of microprocessor-controlled processes, industries have begun to realize that unscheduled outages are only one of many power quality problems. Very short perturbations (measured in milliseconds) in the supply waveform sometimes affect sensitive equipment, resulting in significant losses in productivity. The utility industry has begun to feel increased pressure from industrial customers not only to supply reliable and uninterrupted power, but also to ensure that the quality of the power supply is adequate for their equipment to operate smoothly. The deregulation pressures on the electric utility industry and the associated increases in customer choices only exacerbate the utility industry's need to provide the higher-quality power that their customers are demanding. EPRI has undertaken a major effort to analyze the nature and causes of the power quality problems.

A major thrust of the DOE's Energy Storage Systems (ESS) Program at Sandia is to minimize or eliminate

power quality and reliability problems that cost U.S. companies productivity and revenues. To accomplish this, the ESS Program conducts its own analyses and exchanges analyses with industry partners and various industry organizations. It then develops suitable projects to address power quality and reliability problems using energy storage technologies/solutions. For example, a mid-voltage power quality system is being developed to solve power quality problems at the substation (15-kV) level. The PQ2000, a 2-MW/15-sec power quality system, has demonstrated its ability to address power quality problems by protecting a lithograph plant in Homerville, Georgia, against short-duration power outages; it was designed to do the same at the utility level, and will soon do so at a Virginia utility. Power quality problems will also be mitigated with modular energy storage systems such as the 250-kW PM250 system and the Advanced Battery Energy Storage System (ABESS). These technologies are being advanced by the ESS Program and its partners and will offer benefits such as improved power plant operation and higher-reliability power for utility customers.

This study reviews the existing literature dealing with power quality issues and summarizes the nature, scope, and costs associated with poor power quality. It also discusses the technology options available to address power quality issues and identifies the role energy storage systems can play in mitigating these power quality problems.

3. Problem Description

The term power quality often means different things to different people. Electric utilities are primarily responsible for a reliable and uninterrupted supply of electricity, but this is just one facet of good power quality. The manufacturers of equipment define power quality as the characteristics of a power supply that are required to make end-user equipment work properly. These characteristics can be very different depending on the type of equipment and the manufacturing process in question. Since end users are ultimately affected by poor power quality, the definition of power quality must accommodate their concerns. Thus, an EPRI Power Quality Workbook¹ defines power quality as any problem manifested in voltage, current, or frequency deviations that results in failure or misoperation of utility or end-user equipment.

An ideal voltage supply is a pure sinusoidal waveform with constant magnitude and frequency. Several types of distortions in the power supply can be the cause of power quality problems. These distortions result from a wide variety of events ranging from switching events within the end-user facility to faults hundreds of miles away on the utility transmission line. Perturbations that fall within the category of power quality events can be categorized as transient disturbances, fundamental frequency disturbances, and variations in steady state. Table 3-1 lists power-quality-related events and defines the characteristics of those events. Graphical descriptions of these perturbations are provided in Appendix A.

The phenomena listed in Table 3-1 affect different equipment in different ways. Switching an air conditioner on may cause a sag in voltage, which might dim the lights momentarily. However, plugging in a coffee pot to the same receptacle as a PC might cause a voltage sag that could scramble data every time the heater of the coffee pot is turned on or off.²

Industrial equipment with microprocessor-based controls and power electronic devices that are sensitive to disturbances are affected most by poor power quality. Control systems can be affected by momentary voltage sags or small transient voltages, resulting in nuisance tripping of important processes. Furthermore, many of these sensitive loads are interconnected in

extensive networks and automated processes. This interconnected nature makes the whole system dependent on the most sensitive device when a disturbance occurs. Examples of industries with such interconnections include steel, plastic, glass, paper, and often chemical manufacturers.

A growing percentage of loads utilize power electronics in some type of power conversion process. Such systems generate harmonic currents that result in voltage distortion when they interact with the system impedance. Adjustable speed drives (ASDs), for example, can generate harmonics that can excite resonance with low-voltage capacitors and cause equipment failure. In addition to ASDs, factory efficiency upgrades and demand-side management initiatives often involve the application of equipment such as high-efficiency motors and electronic ballasts. These devices also have significant power quality compatibility issues. Changes in the load characteristics that result from the use of such equipment contribute further to the problems encountered by the end user.

Because microprocessor-based controls and power electronic devices are most susceptible to disturbances in voltage, the Computer Business Equipment Manufacturers Association (CBEMA)³ has defined the operational design range of voltage for computers. The CBEMA curve given in Figure 3-1 defines the tolerance of microprocessor-based equipment to voltage deviations.

Microprocessor-based equipment is typically designed to withstand and operate normally during disturbances as long as the event is within the shaded portion of the curve. The curve depicts the ability of equipment to withstand large voltage swings (100–200% under/over nominal voltage) for short durations (given in microseconds) and smaller voltage swings for longer durations.

Scope of Power Quality Problems

The types of power quality disturbances that may be present are highly dependent on location. If a facility is located at the end of a distribution feeder,

¹ "Power Quality—Electric Power Research Institute's Power Quality Workbook," TR-105500, April 1996.

² EPRI Journal, July/Aug 1991.

³ Presently known as the Information Technology Industry Council.

Table 3-1. Categories of Power Quality Variations

Major Category	Specific Category	Defining Characteristics
Transient Disturbances	IMPULSIVE TRANSIENTS	Unidirectional Typically <200 microseconds
	OSCILLATORY TRANSIENTS - low-frequency - medium-frequency - high-frequency	Decaying Oscillations <500 Hz 500–2000 Hz >2000 Hz
Fundamental Frequency Disturbances	SHORT-DURATION VARIATIONS - sags - swells	Duration 0.5–30 cycles 10%–90% nominal 105%–173% nominal
	LONG-DURATION VARIATIONS - undervoltages - overvoltages	>30 cycles
	INTERRUPTIONS - momentary - temporary - long-term	Complete loss of voltage <2 sec 2 sec–2 min >2 min
Variations in Steady State	HARMONIC DISTORTION	Continuous distortion (V or I) Components to 50th harmonic
	VOLTAGE FLICKER	Intermittent variations in 60-Hz voltage magnitude; frequency component <25 Hz
	NOISE	Continuous high-frequency component on voltage or current; freq: >3000 Hz

* Source: Power Quality Assessment Procedures, EPRI CU-7529 (December 1991).

depending on the loading level of the feeder, under-voltage may be prevalent at the location. Areas with high isokeraunic levels (high incidences of lightning) are more prone to surges. The reverse is also often observed; regions with high isokeraunic levels have transmission and distribution systems better designed to cope with lightning surges, resulting in lower incidences at the customer end. In addition, harmonics created by neighboring facilities may affect each other. Voltage sags could be experienced when large motors, like those in a sawmill, start up, drawing 2 to 3 times full load current, and dipping the voltage well below acceptable levels for up to 5 seconds. Table 3-2 lists the causes of the power quality events listed in Table 3-1.

In order to ascertain the impact of power quality problems, one must ascertain the frequency of these occurrences as well as determine how severe these disturbances must be to cause disruption of service and production.

There are three surveys of power quality problems that form the basis for much of the discussion related to power quality issues. Table 3-3 provides an overview of the scope of the surveys as well as the parameters measured. Detailed results of these surveys are not available in the public domain. The surveys conducted by the Canadian Electrical Association⁴

⁴ Canadian National Power Quality Survey, Canadian Electrical Association, Project 220 D 711A, August 1995.

Figure 3-1. The CBEMA Curve.

Table 3-2. Summary of Power Quality Variation Categories and Causes*

Category	Method Of Characterization	Cause
IMPULSIVE TRANSIENTS	Magnitude Duration	Lightning, load switching
OSCILLATORY TRANSIENTS	Waveforms	Lightning, line/cable switching, capacitor switching, transformer switching, load switching
SAGS/SWELLS	Waveforms, RMS vs. Time	Remote faults
UNDERVOLTAGES/ OVERVOLTAGES	RMS vs. Time	Overloading of feeder/motor starting, load changes, compensation changes
INTERRUPTIONS	Duration	Breaker operation/fault clearing, maintenance
HARMONIC DISTORTION	Waveforms, Harmonic Spectrums	Nonlinear loads, system response characteristic
VOLTAGE FLICKER	Magnitude Frequency of Modulation	Intermittent loads, arcing loads, motor starting
NOISE	Noise, Coupling Method, Frequency	Power electronic switching, arcing, electromagnetic radiation

* Source: Power Quality Assessment Procedures, EPRI CU-7529 (December 1991).

Table 3-3. Summary Overview of the CEA, NPL, and EPRI Power Quality Surveys

Survey	Monitor Period	Quantity of Data (Monitor Months)	Number of Sites	Measured Parameters
CEA	1991 to 1994	530	550	Voltage
NPL	1990 to 1995	1200	130	Voltage
EPRI	1993 to 1995	5691	277	Voltage & Current

(CEA) and the NPL⁵ can be purchased, while the most extensive survey conducted by EPRI⁶ is not available to non-EPRI members. Summary reports are available in the public domain for each of the three studies, with NPL reporting most of its survey data in an IEEE Industrial Application publication.⁷

The CEA survey, conducted in the service territories of 22 Canadian utilities, monitored residential, commercial, and light industrial customers for 25 days at their 120-V or 347-V service entrance panels. Heavy electricity users connected at voltages over 29 kV were not included in this study. The NPL study, in contrast, monitored a smaller number of sites over a longer period of time. It also included heavy industries (8 heavy industries and 33 light industries, in a survey sample of 130). Single-phase, line-to-neutral data were collected at the standard wall receptacle.

While the CEA and NPL surveys focused on the end user, the objective of the EPRI study was to describe the power quality levels on primary distribution systems in the U.S. The feeders monitored represented a diverse sampling of U.S. distribution systems, with voltage ratings from 4.16 kV to 34.5 kV and line lengths from 1 to 80 kilometers. The feeders also represented a wide geographic sampling of the nation, and included rural, suburban, and urban load densities and residential, commercial, and industrial load types. The feeder selection process identified a population of monitoring locations that would be an unbiased representation of the types of distribution feeders present across the U.S.

The NPL Survey Results

The sites surveyed in the NPL study included a wide range of building locations, building types, building ages, and population areas. It included locations where participants felt they had power quality problems and also those where a problem was not perceived. Of the 130 locations surveyed, 31% were industrial, 17% residential, 24% small businesses, 10% institutional, and 18% multistoried building customers. Table 3-4 defines the four events studied. The definitions of these events conform to the American National Standards Institute's ANSI C84.1-1989 standard, which defines normal conditions of voltage.

Table 3-5 lists the variations in event duration for the four types of disturbances recorded in the NPL survey. In interpreting the summary statistics in Tables 3-5 and 3-6, one should note that the distribution and site event occurrence rates for each category are highly skewed; thus, average or median values for these parameters clearly do not represent any kind of "typical" performances and should not be interpreted as such. However, for a preliminary estimation of the national cost of poor power quality, some of these numbers will be used later in this chapter under "Estimation of National Cost of Poor Power Quality."

Table 3-6 describes the frequency of events on a monthly basis at individual locations. It is apparent from Table 3-6 that transients are the most prevalent events, whereas interruptions account for less than 1% of all recorded disturbances. However, the table statistics do not reveal whether the event caused a disruption; nor do they describe the extent of losses.

Since the differences between the best and worst locations in Table 3-6 reflect highly skewed data, the average numbers do not necessarily represent typical performance. It is likely that the median values are more typical. The survey results also do not provide any indication of the variation of the frequency of occurrences between different customer classes.

⁵ National Power Laboratory Power Quality Study, Best Power Technology, Inc., Necedah, WI.

⁶ "An Assessment of Distribution System Power Quality," EPRI TR-106249, May 1996.

⁷ Douglas Dorr, "Point of Utilization Power Quality Study Results," *IEEE Transactions on Industrial Applications*, Vol. 31, No. 4, July/August 1995.

Table 3-4. Definition of Events in NPL Survey

Event/Disturbance	Voltage Level	Duration
Sag/Undervoltage (Low RMS)	<104 Vrms	>2048 μ s
Swell/Overvoltage (High RMS)	>127 Vrms	>2048 μ s
Transient	>100 Vpeak	$\geq$ 5-2048 μ s
Interruption (Outage)	0 Vrms	$\geq$ 4 ms

Table 3-5. Duration Summary Statistics for All NPL Data

	Minimum	Maximum	Median	Average
Sags/Undervoltages (Low RMS)	0.01 s	1.75 hr	0.26 s	2.1 s
Swells/Overvoltages (High RMS)	0.01 s	170 hr	60 s	44.2 min
Transients	< 1 μ s	>2048 μ s	21 μ s	63.4 μ s
Interruptions	0.004 s	71.1 hr	2.4 s	21.1 min

**Table 3-6. Events per Month Based upon
All NPL Data and Individual Location Statistics**

	Best Locations (events/month)	Worst Locations (events/month)	Individual Location Median (events/month)	Average (events/month)
Sags/Undervoltages (Low RMS)	0	1,660	4.1	27.9
Swells/Overvoltages (High RMS)	0	1,450	3.4	13.9
Transients	0	1,166	15.7	63.5
Interruptions	0	10.2	1.0	1.3

Since the differences between the best and worst locations in Table 3-6 reflect highly skewed data, the average numbers do not necessarily represent typical performance. It is likely that the median values are more typical. The survey results also do not provide any indication of the variation of the frequency of occurrences between different customer classes.

A CBEMA curve analysis of these events, as shown in Figure 3-2, results in 289 power line deviations per site per year (~24 events/site/month) falling somewhere outside the high and low threshold limits of the curve. Nineteen of such events lying outside the shaded region were transients, 164 were swells or overvoltages, 90 were sags or undervoltage condi-

tions, and 16 were interruptions. The median of the number of events given in Table 3-6 is comparable to this CBEMA curve analysis.

Cost of Poor Power Quality to Customers

Costs associated with power quality problems arise from lost production as well as other related disruptions suffered by customers, such as equipment damage, startup costs, etc. The costs of power-quality-related disruptions are largely dependent on the industrial and commercial activities that are impacted, the time of occurrence, and the duration of the event. Many electric utilities have conducted surveys of

Figure 3-2. CBEMA Curve Analysis of the NPL Survey (number of line deviations per site per year).

power-quality-related costs within their service territories. The detailed results are proprietary; however, summaries have been published.

The summary of a survey conducted by Duke Power⁸ is presented in Table 3-7. The utility surveyed 198 of its industrial and commercial customers and reported the results in terms of five types of reliability and power quality events. The magnitude and composition of the interruption costs change dramatically as a function of outage duration and type of problem.

The largest impact is obviously from long-duration outages, where approximately 90% of all production-related activity in a facility is affected. The corresponding numbers for voltage sags and momentary outages are 37% and 57% respectively. In all outage categories, more than 50% of the average total cost of the outage is due to lost product revenue (revenue change), with the remainder coming from damage to input feedstock and equipment.

Figure 3-3 illustrates the cost of distribution for industrial and commercial customers for a 1-hour outage on a summer afternoon without advance notice. The commercial and industrial customers of Duke Power surveyed had interruption costs ranging from \$0 to \$100,000 and from \$0 to over \$1 million, respectively.

Figure 3-3 illustrates that greater than 35% of all industrial and about 8% of all commercial customers surveyed experienced an interruption cost of greater than \$10,000 on a hot summer day. The sample size for this survey consisted of 210 large industrial and commercial customers and 1,080 small/medium industrial and commercial customers. It may be fair to assume that most of the 210 large customers surveyed will experience a loss of greater than \$10,000 per interruption lasting 1 hour and will experience at least the average costs listed in Table 3-7.

One must be extremely cautious in generalizing about the costs associated with power quality problems on the basis of only one survey's results. The costs are very site- and time-specific and depend to a very large extent on the type of equipment and industrial processes that are impacted. To add further perspective to the cost of power quality disturbances, references to two additional studies were located. A

⁸ Mike Sullivan, "Power Interruption Costs to Industrial and Commercial Consumers of Electricity," Commercial and Industrial Systems Technology Conference, 1996.

**Table 3-7. Components of Outage Costs by Scenario
(average of 198 large customers in the Duke Power service territory)***

Cost Element	4-Hr Outage, No Notice	1-Hr Outage, No Notice	1-Hr Outage With Notice	Momentary Outage	Voltage Sag
<u>Production Impacts</u>					
Production Time Lost (Hours)	6.67	2.96	2.26	0.70	0.36
Percentage of Work Stopped	91%	91%	91%	57%	37%
<u>Production Losses</u>					
Value of Lost Production	\$81,932	\$32,816	\$28,746	\$7,407	\$3,914
Percentage of Production Recovered	36%	34%	34%	19%	16%
Revenue Change	\$52,436	\$21,658	\$18,972	\$5,999	\$3,287
<u>Loss Due to Damage</u>					
Damage to Raw Materials	\$13,070	\$8,518	\$3,287	\$2,051	\$1,163
Hazardous Materials Cost	\$323	\$269	\$145	\$136	\$90
Equipment Damage	\$8,421	\$4,977	\$408	\$3,239	\$3,143
<u>Cost to Run Backup and Restart</u>					
Cost to Run Backup Generation	\$178	\$65	\$65	\$22	\$22
Cost to Restart Electrical Equipment	\$1,241	\$1,241	\$171	\$29	\$29
Other Restart Costs	\$401	\$368	\$280	\$149	\$74
<u>Savings</u>					
Savings on Raw Materials	\$1,927	\$645	\$461	\$166	\$114
Savings on Fuel and Electricity	\$317	\$103	\$85	\$12	\$9
Value of Scrap	\$2,337	\$874	\$450	\$228	\$140
<u>Labor Management Ap- proach During Recovery</u>					
Percentage Using Overtime	33%	26%	25%	7%	6%
Percentage Using Extra Shifts	1%	1%	0%	1%	1%
Percentage Working Labor More Intensively	3%	4%	4%	7%	4%
Percentage Rescheduling Operations	4%	5%	5%	0%	0%
Percentage Other	1%	2%	2%	1%	0%
Percentage Not Recovering	59%	62%	64%	84%	89%
<u>Labor Costs and Savings</u>					
Cost to Make Up Production	\$4,854	\$1,709	\$1,373	\$254	\$60
Cost to Restart	\$665	\$570	\$426	\$192	\$114
Labor Savings	\$2,139	\$644	\$555	\$0	\$0
<u>Average Total Costs</u>					
Total Costs	\$74,800	\$39,500	\$23,100	\$11,000	\$7,700

* Source: Mike Sullivan, Commercial and Industrial Systems Technology Conference, 1996.

Figure 3-3. Difference in Commercial and Industrial Customer Interruption Cost (Duke Power data).

survey carried out by Pacific Gas & Electric (PG&E) covered 51 industrial customers ranging from electronics, automotive, instrument, apparel, and transportation equipment manufacturers to petroleum refineries, metal mines, and real estate offices. The cost of a 15-second interruption at these facilities was estimated to average \$70,000 per customer, with the cost ranging from \$25,000 to \$270,000 per customer.⁹ Finally, a survey of residential customers in the New England Electric System indicated that 3% of homes in their service territory had PCs primarily for business. The study found a momentary interruption for a home-based business costs about \$25 per interruption. A survey of small commercial customers in Canada¹⁰ also provides useful insights, with that survey finding losses in the range of hundreds of dollars for interruptions lasting up to 1 hour.

Estimation of National Cost of Poor Power Quality

The foregoing discussion illustrates the difficulty of developing precise estimates of the national impact of

power quality problems. Prior estimates of the cost of poor power quality have ranged from \$25 billion to \$400 billion per year. The estimate of \$25 billion¹¹ was based on the assumption that 1.5 to 3 cents of every sales dollar in the U.S. manufacturing industry was spent on correcting power quality problems. The \$400 billion figure¹² was based on the estimate that employees were idle 37.3 million hours in 1991 due to power quality problems experienced by commercial customers. This idle time translates to an employee productivity loss, and therefore a loss to U.S. businesses, of \$400 billion.

Utilizing the NPL survey data on the frequency of power-quality-related events and Duke Power's estimation of its large industrial and commercial customers' productivity losses, it is possible to develop an estimate of the national cost of poor power quality in this sector. For purposes of this study, the loss incurred in the large industrial sectors as a result of momentary outages and voltage sags is of most interest, since energy storage systems provide the preferred comprehensive solution for these power quality problems. Thus the estimate provides a basis on which to assess this market segment for storage sys-

⁹ EPRI Signature, Summer 1995.

¹⁰ R.K. Subramaniam, "Understanding Commercial Losses Resulting from Electric Service Interruptions," *IEEE Transactions on Industrial Applications*, January/February 1993.

¹¹ Carel DeWinkel, "Storing Power for Critical Loads," *IEEE Spectrum*, June 1993.

¹² "Power Quality in Commercial Buildings," EPRI-BR105018.

tems. In the interest of taking a conservative approach, Sentech's estimate is limited to the industrial/large customer sector, because the disruptions caused in this sector are the costliest (as discussed earlier under "Cost of Power Quality to Customer"), and hence investment in storage systems by this sector may be justifiable.

The NPL survey data in Table 3-6 provide the average and median interruptions and sags/undervoltages recorded in all 130 sites surveyed but do not differentiate between customer classes. Comparison of averages and medians indicates that there are a disproportionately smaller number of sites experiencing very poor power quality compared to the greater number of sites with good power quality records. The use of the median number instead of the average removes much of this distortion in the survey data and will indicate the extent of disturbance experienced by at least 50% of survey participants. Therefore, the survey medians will be assumed to be representative of what is experienced by at least 50% of the larger industrial customers. Hence, from Table 3-6 it may be concluded that at least 50% of industrial customers experience 12 interruptions and 49 sags/undervoltages per year.¹³

The figures in Table 3-7 indicate that it is fair to assume that the large industrial customers (excluding large commercial customers) in Duke Power's service territory will incur an average cost of \$11,027 and \$7,694 for each occurrence of momentary outage and voltage sag, respectively. Multiplying the loss for each of these occurrences with the frequency of their occurrence¹⁴ results in an average loss of \$509,000 per year for each of Duke Power's large industrial customers. Given that there are 8,700¹⁵ large industrial customers in Duke Power's service territory, the total loss by this customer class will be on the order of \$4.4 billion.

The total industrial electricity sales in the U.S. and within Duke Power's service territory are 1,004 TWh and 28.2 TWh, respectively. If one were to extrapolate the estimated \$4.4 billion loss experienced by

large industrial customers in Duke Power's service territory to the entire U.S. using electricity sales to the industrial sector as a base, the result would be an estimated national loss of \$150 billion per year. This is summarized in Table 3-8.

It should be recognized that computing a national loss number with regional data can be a risky undertaking; the opportunities to introduce error are relatively high. Nevertheless, it is interesting to note that the \$150 billion value derived from the Duke Power and NPL data falls between the \$25 billion and \$400 billion figures cited earlier.

The extent of the \$150 billion loss that storage systems can address at present/near-term prices can be estimated as follows. The median loss incurred by each of the customers is \$509,000,¹⁶ which implies that 50% of the customers experienced a loss greater or equal to \$509,000 per year. Assuming that an annual loss of at least \$500,000 would have to be incurred for a large industrial customer to be able to justify the installation of large protective storage systems, the national market for storage equipment will be at least one-half the losses incurred annually by all large industrial customers, namely \$75 billion. The cost-benefit analysis for installing a storage system is provided later under "Cost-Benefit Analysis Example."

Whatever the actual number, one can postulate with increasing confidence that the annual market potential of energy storage systems addressing power quality problems should total tens of billions of dollars.

Unserved markets of this size beg explanation. The market for such systems has grown in the recent past because of the proliferation of versatile microprocessor-controlled systems and power electronic motor controls, which are susceptible to distortions in the supply waveform. At present, part of the market is served by a variety of uninterruptible power supplies. Largely overlooked, however, are energy storage systems capable not only of meeting large industrial loads during interruptions but also of correcting for voltage magnitude variances and waveform imperfections. Such systems have been installed in recent years, but large gaps persist in power ratings, protection durations, performance capabilities, flexible siting and operation, cost, and installation ease. Until

¹³ Twelve interruptions (12 months/year*1 event/month) and 49 sags/undervoltages (4.1 events/month*12 months/year) per year.

¹⁴ $[(12 * \$11,027) + (49 * \$7,694)] = \$509,000$

¹⁵ The EL&P Electric Utility Industry Directory—1995 indicates that Duke Power has 8,693 industrial/large customers among its total customer base of 1.7 million.

¹⁶ Median number of power quality disturbances experienced each year $\times$ average loss per disturbance.

Table 3-8. National Cost Estimate for Large Industrial Customers

	Average Annual Cost to Large Industrial Customers	Estimated Cost for Duke Power Customer Group	Estimated Cost for National Customer Group
Undervoltages/sags	\$377,000	\$ 3.2B	\$ 114B
Interruptions	\$132,000	\$ 1.1B	\$ 39B
Total estimated U.S. cost (rounded):			\$ 150B

these gaps are overcome, manufacturers and their customers will continue to experience higher than necessary costs.

The large annual cost of poor power quality represents a form of national inefficiency and is reflected

in the cost of goods sold, reducing U.S. competitiveness. The cost is ultimately paid by consumers, domestic and foreign. The mitigation of these costs merits the attention of the affected industries, businesses capable of developing solutions, and the DOE.

4. Technology Options

There are three general approaches to solving power quality problems:

- Eliminate or modify the source of the disturbances.
- Eliminate or modify the path for the disturbances between the source and the affected equipment.
- Protect the affected equipment.

Generally, consideration of all three options is necessary to develop a cost-effective solution. Determining the least-cost approach to mitigating power quality problems often requires that an industrial customer initiate an extensive internal survey to determine the nature of the problem. Such a survey is commonly done in partnership with the local utility, and the solutions that are implemented are often developed with strong input from the utility and in some instances even with financial assistance from the utility.

Many technology solutions exist to deal with the different power quality events. Devices that are commonly used for this purpose include the following:

• Surge arrestors	• Filters
• Isolation transformers	• Constant voltage transformers
• Uninterruptible power supply (UPS)/energy storage systems	• Backup generators
• Static Var systems	• Series capacitors
• Wiring and grounding	• Dynamic voltage restorer
• Shielding	• Humidity control

Energy storage systems can be placed off-line, in a line-interactive mode, or on-line to deal with power

quality problems. Off-line (also called standby) energy storage systems (see Figure 4-1) are cost-effective for small, less critical, stand-alone applications such as isolated PCs and peripherals. However, when an outage occurs in the utility supply, this configuration may not be able to switch to its storage power supply fast enough to prevent disturbances in highly sensitive equipment. If filters are present, standby systems will protect against most transients by limiting excess voltage, but their ability to protect against sags and surges is significantly less than on-line or line-interactive designs.

Line-interactive systems (see Figure 4-2) provide highly effective power conditioning and energy storage backup. Their voltage boost circuitry and fast-acting transfer switches protect against most voltage sags and surges and provide extremely quick response to disturbances. Transfer switches with response times of $\sim 1/4$ power cycle provide adequate protection for the most sensitive devices. The energy efficiency of line-interactive storage systems is higher than that of on-line systems and becomes an important cost-saving advantage when protecting hundreds of kilowatts of critical loads.

The on-line configuration (see Figure 4-3) provides the highest level of protection for critical loads. Off-line and line-interactive storage systems reduce the impact of transients, surges, and sags by either clipping the peaks, boosting power, or switching to storage energy backup. In contrast, on-line energy storage systems regenerate the sinewave and do not involve switching. The configuration protects against all utility disturbances because the system completely isolates the load from the utility supply at all times. Since on-line systems continuously condition input supply, they have relatively large parasitic losses.

Figure 4-1. Off-Line Configuration of Energy Storage Systems.

Figure 4-2. Line-Interactive Configuration of Energy Storage Systems.

Each of these energy storage configurations for power quality applications has its advantages and disadvantages. Prior to selecting a solution, the electricity provider or end user needs to define the power quality events that are most prevalent at the location and must estimate the damages caused by the events. The different solutions, including the storage option, can then be assessed in order to determine the most cost-effective solution.

To determine which device or combination of devices is appropriate, systematic monitoring of the facility, with the help of monitoring equipment and analysis of recorded data, is necessary.

Matching the Power Quality Problem with the Technology Solutions

Table 4-1 matches power quality events to the preferred technology solution to mitigate that particular event. Thus if impulsive transients were the only type of power quality event that was experienced by an industrial facility, Table 4-1 would indicate that surge arrestors, filters, and isolation transformers are the technology options available to the customer to deal

with the problem. Table 4-1 also lists the power quality events that only an energy storage system can address. These include interruptions, sags/swells, and over-/undervoltages. In each of these cases, supply of the electrical energy from external sources, such as a storage system, is required to deal with the problems.

Often a mitigation technology can provide solutions to multiple power quality events. Table 4-2 illustrates this point by showing the different power quality events that can be handled by each of the technology options discussed in Table 4-1. An energy storage system is only essential when an external source of electrical energy is necessary to deal with the power quality event, such as with an interruption. However, the same energy storage system can also service all of the other power quality events shown in Table 4-2.

Cost-Benefit Analysis Example

For illustrative purposes, the cost-effectiveness of energy storage systems is analyzed using the loss estimates given in Table 3-7 and the frequency of supply disturbances obtained from the NPL survey and listed in Table 3-6.

Figure 4-3. On-Line Configuration of Energy Storage Systems.

Table 4-1. Individual Solutions to Single-Category Power Quality Events*

Event Category	Method Of Characterization	Cause	Power Quality Solution
Impulsive Transients	Magnitude, Duration	Lightning, load switching	Surge arrestors, filters, isolation transformers
Oscillatory Transients	Waveforms	Lightning, line/cable switching, capacitor switching, transformer switching, load switching	Surge arrestors, filters, isolation transformers
Sags/Swells	Waveforms, RMS vs. Time	Remote faults	Constant voltage transformer, storage systems
Undervoltages/Overvoltages	RMS vs. Time	Motor starting, load changes, compensation changes	Dynamic voltage restorer, constant voltage transformer, storage systems
Interruptions	Duration	Breaker operation/fault clearing, equipment failure, maintenance	Backup generator, storage systems
Harmonic Distortions	Waveforms, Harmonic Spectrums	Nonlinear loads, system response characteristic	Filters, isolation transformer (zero sequence)
Voltage Flicker	Magnitude, Frequency of Modulation	Intermittent loads, arcing loads, motor starting	Static Var system, series caps
Noise	Coupling Method, Frequency	Power electronic switching, arcing, electromagnetic radiation	Wiring and grounding improvement, chokes, filters, shielding

* Source: Power Quality Assessment Procedures, EPRI CU-7529 (December 1991).

Table 4-3 shows the benefit an energy storage system can bring to a large industrial customer if the storage system can handle both momentary outages and voltage sags. Duke Power data show the average losses for these types of events to be \$11,027 and \$7,694 per event, respectively, while the power quality survey data in Table 3-6 indicate that the median number of momentary outages was 1 per month and the median number of voltage sags/swells was 4.1 per month.

Systems based on batteries or on superconducting magnetic energy storage that protect megawatt-scale loads for durations in seconds are now commercially available at a cost of \$1 to \$2 million. With an annual avoided cost of \$500,000 dollars and a payback period of 2 to 4 years, close to 50% of the large industrial customers (described earlier under "Estimation of National Cost of Poor Power Quality") in the U.S. may find storage systems economically attractive.

Table 4-2. Power Quality Solutions and Their Ability to Protect against Events in Multiple Power Quality Categories

Power Quality Solutions	Impulsive Transients	Oscillatory Transients	Sags/Swells	Under-voltages/Over-voltages	Interruptions	Harmonic Distortions	Voltage Flicker	Noise
Surge Arrestors	✓	✓						
Filters ^a	✓	✓				✓		✓
Isolation Transformers	✓	✓				✓		
Constant Voltage Transformers			✓	✓				
Dynamic Voltage Restorer			✓	✓				
Backup Generator					✓			
Energy Storage ^b								
- Off-line	✓	✓	✓	✓	✓		✓	✓
- Line-interactive	✓	✓	✓	✓	✓		✓	✓
- On-line	✓	✓	✓	✓	✓	✓	✓	✓

^a Different kinds of filters will be required to mitigate the different power quality problems.

^b For sags/swells, under-/overvoltages, and interruptions, the level of protection increases from off-line to line-interactive to on-line.

Table 4-3. Competitiveness of Energy Storage Systems for Power Quality Applications

BENEFIT: ANNUAL AVOIDED COST	
Momentary Outage: Avoided Cost (1 event per month * 12 months * \$11,027)	\$132,000
Voltage Sags: Avoided Cost (4.1 events per month * 12 months * \$7,694)	\$377,000
Total benefits per year	\$509,000
COST: CAPITAL COST OF EQUIPMENT	
Cost of commercially available 1-MW energy storage system capable of providing protection for a few seconds	\$1 million (1 MW = \$1M)
SIMPLE PAYBACK PERIOD	~2 years

5. Conclusions

Power quality issues have come to the forefront recently mainly because of the increased use of sophisticated microprocessor-controlled equipment in industrial processes. Systems with loads that are highly sensitive and interconnected in extensive networks are vulnerable because they are dependent on the most sensitive device in the system when a disturbance occurs. Surveys conducted by the electric utility industry demonstrate that manufacturers incur large losses as a result of poor power quality.

Power quality problems arise from a variety of events. There are a number of technology options that electricity suppliers as well as end users can use to mitigate power quality problems. It is imperative that careful investigation of the frequency of events and their economic impacts be undertaken. Often it would be most cost-effective to implement solutions only for those power quality problems that have severe economic impacts rather than installing systems capable of dealing with all power quality events.

Data on the frequency of system disturbances and their economic impacts can be obtained through systematic monitoring at end-user sites. Several such studies have been conducted; however, most of the results are considered to be proprietary and are thus not available in the public domain. Summaries of some of these surveys have been published that contain enough information to permit tentative conclusions to be drawn regarding the nature and frequency of power quality disturbances and the role energy storage systems can play in mitigating them. The survey data suggest that storage systems are well suited to handle problems arising from unscheduled momentary outages. These types of events, although less frequent, cause the most severe economic impact. An energy storage system installed to handle outages

can also reduce the impacts of voltage sags, under-voltages, and other disturbances. On-line storage systems are capable of eliminating all power quality-related problems, but such a comprehensive solution may be justified only for the more critical processes.

Preliminary estimates based on both the NPL and Duke Power surveys indicate that a 2-to-4-yr payback period for commercially available energy storage systems is feasible for the industrial customer experiencing typical disturbances. The data from these two surveys were used to obtain a rough estimate of \$150 billion as the annual losses incurred nationally by the industrial sector because of momentary outages and voltage sags, two events for which storage systems are the primary solution. This number is between the \$25 billion estimate made in an IEEE publication and the \$400 billion estimate made in an EPRI publication.

This study suggests that the accrued national benefit from mitigating power quality losses is very large. This conclusion is supported by studies conducted by EPRI and other entities. However, it is important to note that the numerical estimates of the benefits developed in this study are based on limited data and on extrapolation from the available information. The numerical estimates therefore serve only to establish an order of magnitude of the accrued benefits of mitigating power quality problems. To establish more precise estimates, it would be necessary to further refine the analysis with better, more complete data obtained through more detailed surveying or through greater access to surveys already conducted by electric utilities.

Graphical Illustration of Power Quality Events

Appendix A

Graphical Illustration Of Power Quality Events

IDEAL SUPPLY WAVEFORM

1. IDEAL SUPPLY WAVEFORM: An ideal supply waveform is a pure sinusoidal waveform with a constant amplitude and frequency.

TRANSIENTS

2. TRANSIENTS (Impulsive and Oscillatory): A transient is a surge in voltage or current that can have extremely short duration and high magnitude. Typically, surges are caused by switching operations or lightning. Surges can be generated by customers switching their own loads or may be caused by utility switching of capacitors, breakers, etc. Surges have always existed in power systems, but it is only in recent years that they have received attention mainly because of the sensitivity of electronic devices like VCRs and personal computers.

VOLTAGE SAG

3. VOLTAGE SAG: A momentary voltage dip that lasts for a fraction of a second or less is classified as a voltage sag. Voltage sags may be caused by faults on the transmission or distribution system or by the switching of loads with large amounts of initial starting/inrush current. Voltage sags may be sufficiently severe, especially in the case of faults, to cause sensitive loads to reset.

VOLTAGE SWELL

4. VOLTAGE SWELL: When a fault occurs on one phase of a 3-phase, 4-wire system, the other two phases rise in voltage relative to ground (about 20%). This steady-state rise in voltage is referred to as a swell. Voltage swells usually have duration of a fraction of a second or less.

UNDER/OVERVOLTAGE

5. UNDER/OVERVOLTAGE (Voltage Drop): A customer who experiences a long-duration (several seconds or longer) service voltage less than the proper nominal operating voltage limit can be considered to be experiencing an undervoltage situation. Similarly, a customer experiencing higher than nominal operating voltage can be considered to be experiencing overvoltage. Such a condition may be caused by a number of factors, such as overloaded or poor internal wiring, poor connections, compensation changes, and/or voltage drop/gain on the utility system.

POWER OUTAGE

6. INTERRUPTION (Power Outage): A power outage is a complete loss of voltage usually lasting from as short as a quarter cycle up to several hours, or in some cases even days. Outages are usually caused by the fault-induced operation of circuit breakers or fuses. Some of these interruptions might be classified as permanent, while others may be classified as temporary.

HARMONICS

7. HARMONICS: These are the nonfundamental frequency components of a distorted 60-Hz power wave. They have frequencies that are integral multiples of the 60-Hz fundamental frequency. Harmonics are not generally produced by the utility but rather by the customer's equipment. For example, a large nonlinear industrial load may produce harmonics that, if they are of sufficient magnitude, can travel back through the power system and affect other customers.

Distribution

ABB Power T&D Co., Inc.
Attn: P. Danfors
16250 West Glendale Drive
New Berlin, WI 53151

American Electric Power Service Corp.
Attn: C. Shih
1 Riverside Plaza
Columbus, OH 43215

Applied Power Corporation
Attn: Tim Ball
Solar Engineering
1210 Homann Drive, SE
Lacey, WA 98503

Ascension Technology
Attn: Edward Kern
Post Office Box 6314
Lincoln Center, MA 01773

Anchorage Municipal Light & Power
Attn: Meera Kohler
1200 East 1st Avenue
Anchorage, AK 99501

Bechtel Corporation
Attn: W. Stolte
P.O. Box 193965
San Francisco, CA 94119-3965

Berliner Kraft und Licht (BEWAG)
Attn: K. Kramer
Stauffenbergstrasse 26
1000 Berlin 30
GERMANY

Business Management Consulting
Attn: S. Jabbour
24704 Voorhees Drive
Los Altos Hills, CA 94022

C&D Charter Power Systems, Inc. (2)
Attn: Dr. Sudhan S. Misra
Attn: Dr. L. Holden
Washington & Cherry Sts.
Conshohocken, PA 19428

Argonne National Laboratories (2)
Attn: W. DeLuca
G. Henriksen
CTD, Building 205
9700 South Cass Avenue
Argonne, IL 60439

Arizona Public Service (2)
Attn: R. Hobbs
Herb Hayden
400 North Fifth Street
P.O. Box 53999, MS-8931
Phoenix, AZ 85072-3999

AVO International
Attn: Gary Markle
510 Township Line Rd.
Blue Bell, PA 19422

Babcock & Wilcox
Attn: Glenn Campbell
P.O. Box 785
Lynchburg, VA 24505

California State Air Resources Board
Attn: J. Holmes
Research Division
P.O. Box 2815
Sacramento, CA 95812

Calpine Corp.
Attn: R. Boucher
50 W. San Fernando, Ste. 550
San Jose, CA 95113

Chugach Electric Association, Inc. (2)
Attn: T. Lovas
J. Cooley
P.O. Box 196300
Anchorage, AK 99519-6300

Consolidated Edison (2)
Attn: M. Lebow
N. Tai
4 Irving Place
New York, NY 10003

Corn Belt Electric Cooperative
Attn: R. Stack
P.O. Box 816
Bloomington, IL 61702

Delphi Energy and Engine
Management Systems (3)
Attn: J. Michael Hinga
R. Galyen
R. Rider
P.O. Box 502650
Indianapolis, IN 46250

Alaska State Division Of Energy (3)
Attn: P. Frisbey
P. Crump
B. Tiedeman
333 West Fourth Ave, Suite 220
Anchorage, AK 99501-2341

EA Technology, Ltd.
Attn: J. Baker
Chester CH1 6ES
Capenhurst, England
UNITED KINGDOM

Eagle-Picher Industries
Attn: J. DeGruson
C & Porter Street
Joplin, MO 64802

Electrosource
Attn: Michael Dodge
P.O. Box 7115
Loveland, CO 80537

Eltech Research Corporation
Attn: Dr. E. Rudd
625 East Street
Fairport Harbor, OH 44077

Energetics, Inc. (3)
Attn: H. Lowitt
P. Taylor
L. Charles
7164 Gateway Drive
Columbia, MD 21046

Energetics, Inc. (4)
Attn: M. Farber
R. Scheer
J. Schilling
P. DiPietro
501 School St. SW, Suite 500
Washington, DC 20024

Energy and Environmental Economics, Inc.
Attn: Greg J. Ball
353 Sacramento St., Suite 1540
San Francisco, CA 94111

International Energy Systems, Ltd.
Attn: G. Barker
Chester High Road
Nestor, South Wirral
L64 UE UK
UNITED KINGDOM

East Penn Manufacturing Co., Inc.
Attn: M. Stanton
Deka Road
Lyon Station, PA 19536

Electric Power Research Institute (3)
Attn: S. Chapel
S. Eckroad
R. Schainker
P. O. Box 10412
Palo Alto, CA 94303-0813

Electrochemical Engineering Consultants, Inc.
Attn: P. Symons
1295 Kelly Park Circle
Morgan Hill, CA 95037

Electrochemical Energy Storage Systems, Inc.
Attn: D. Feder
35 Ridgedale Avenue
Madison, NJ 07940

Energy Systems Consulting
Attn: A. Pivec
41 Springbrook Road
Livingston, NJ 07039

Firing Circuits, Inc.
Attn: J. Mills
P.O. Box 2007
Norwalk, CT 06852-2007

General Electric Company
Attn: N. Miller
Building 2, Room 605
1 River Road
Schenectady, NY 12345

General Electric Drive Systems
Attn: D. Daly
1501 Roanoke Blvd.
Salem, VA 24153

GE Industrial & Power Services
Attn: Bob Zrebiec
640 Freedom Business Center
King of Prussia, PA 19046

Giner, Inc.
Attn: A. LaConti
14 Spring Street
Waltham, MA 02254-9147

Golden Valley Electric Association, Inc.
Attn: S. Haagensen
Box 71249
758 Illinois Street
Fairbanks, AK 99701

GNB Technologies (3)
Industrial Battery Company
Attn: G. Hunt
J. Szymborski
R. Maresca
Woodlake Corporate Park
829 Parkview Blvd.
Lombard, IL 60148-3249

Lawrence Berkeley Laboratory (3)
Attn: E. Cairns
K. Kinoshita
F. McLarnon
University of California
One Cyclotron Road
Berkeley, CA 94720

Longitude 122 West
Attn: S. Schoenung
1241 Hobart St.
Menlo Park, CA 94025

Lucent Technologies
Attn: C. Mak
3000 Skyline Drive
Mesquite, TX 75149

Lucent Technologies, Inc.
Attn: J. Morabito
Director, Global Research and Development
P.O. Box 636
600 Mountain Avenue
Murray Hill, NJ 07974-0636

GNB Technologies
World Headquarters
Attn: S. Deshpande
375 Northridge Road
Atlanta, GA 30350

Hawaii Electric Light Co.
Attn: C. Nagata
P.O. Box 1027
Hilo, HI 96720

ILZRO (3)
Attn: J. Cole
P. Moseley
C. Parker
P.O. Box 12036
Research Triangle Park, NC 27709

Imperial Oil Resources, Ltd.
Attn: R. Myers
3535 Research Rd NW
Calgary, Alberta
CANADA T2L 2K8

Innovative Power Sources
Attn: Ken Belfer
1419 Via Jon Jose Road
Alamo, CA 94507

Metlakatla Power & Light
Attn: H. Achenbach
P.O. Box 359
Metlakatla, AK 99926

Micron Corporation
Attn: D. Nowack
158 Orchard Lane
Winchester, TN 37398

ZBB Technologies, LTD.
Attn: Robert J. Parry
Managing Director
16 Emerald Tce.
West Perth
Western Australia 6005

National Renewable Energy Laboratory (6)
Attn: L. Flowers
J. Green
S. Hock
R. DeBlasio
B. Stafford
H. Thomas
1617 Cole Blvd.
Golden, CO 80401-3393

New York Power Authority
Attn: B. Chezar
1633 Broadway
New York, NY 10019

NC Solar Center
Attn: Bill Brooks
Corner of Gorman and Western
Box 7401 NCSU
Raleigh, NC 27695-740

Northern States Power
Attn: D. Zurn
414 Nicollet Mall
Minneapolis, MN 55401

NPA Technology
Attn: Jack Brown
Suite 700, Two University Place
Durham, NC 27707

Oak Ridge National Laboratory (3)
Attn: B. Hawsey, Bldg. 3025, MS-6040
J. Stoval, Bldg. 3147, MS-6070
J. VanCoevinger, Bldg. 3147, MS-6070
B. Kirby, Bldg. 3147, MS-6070
P.O. Box 2008
Oak Ridge, TN 37831

Public Service Company of New Mexico
Attn: J. Neal
Manager, Premium Power Services
Alvarado Square MS-BA52
Albuquerque, NM 87158

PEPCO
Attn: Brad Johnson
1900 Pennsylvania NW
Washington, DC 20068

Oglethorpe Power Company
Attn: C. Ward
2100 E. Exchange Place
P.O. Box 1349
Tucker, GA 30085-1349

Chief Technology Officer
Attn: Robert Wills
Advanced Energy Systems
Riverview Mill
Post Office Box 262
Wilton, NH 0308

Omnion Power Engineering Corporation
Attn: H. Meyer
2010 Energy Drive
P.O. Box 879
East Troy, WI 53120

Orion Energy Corp.
Attn: Doug Danley
10087 Tyler Place #5
Ijamsville, MD 21754

Public Service Company of New Mexico
Attn: R. Flynn
Senior Vice President
Alvarado Square MS-2838
Albuquerque, NM 87158

International Business and Technology
Services Inc.
Attn: J. Neal
Administrator Research and Development
9220 Tayloes Neck Rd.
Nanjemoy, MD 20662

Gridwise Engineering Company
Attn: B. Norris
121 Starlight Place
Danville, CA 94526

Pacific Northwest Laboratory (2)
Attn: J. DeSteeze, K5-02
D. Brown
Battelle Blvd.
Richland, WA 99352

Power Technologies, Inc.
Attn: P. Prabhakara
1482 Erie Blvd.
P.O. Box 1058
Schenectady, NY 12301

Puerto Rico Electric Power Authority
Attn: W. Torres
G.P.O. Box 4267
San Juan, Puerto Rico 00936-426

Solar Electric Specialists Co.
Mr. Jim Trotter
232-Anacapa St.
Santa Barbara, CA 93101

ENERTEC
Attn: D. Butler
349 Coronation Drive
Auchenflower, Queensland, 4066
P.O. Box 1139 Milton BC Qld 4064
AUSTRALIA

Southern Company Services, Inc. (2)
Research and Environmental Affairs
14N-8195
Attn: B. R. Rauhe, Jr.
K. Vakhshoorzadeh
600 North 18th Street
P.O. Box 2625
Birmingham, Al 35202-2625

Trace Technologies (2)
Attn: Michael Behnke
W. Erdman
6952 Preston Avenue
Livermore, CA 94550

TRACE Engineering
Attn: B. Roppenecker
President
5916 195th Northeast
Arlington, Washington 98223

RMS Company
Attn: K. Ferris
87 Martling Ave.
Pleasantville, NY 10570

Powercell Corporation (2)
Attn: Reznor I. Orr
Rick Winter
10 Rogers Street
Cambridge, MA 02142

Raytheon Engineers and Constructors
Attn: A. Randall
700 South Ash St.
P.O. Box 5888
Denver, CO 80217

Siemens Solar
Attn: Clay Aldrich
4650 Adohn Lane
Post Office Box 6032
Camarillo, CA 93011

R&D Associates
Attn: J. Thompson
2100 Washington Blvd.
Arlington, VA 22204-5706

California Energy Commission
Attn: Jon Edwards
1516 Ninth Street, MS-46
Sacramento, CA 95814

Sentech, Inc. (2)
Attn: R. Sen
K. Klunder
4733 Bethesda Avenue, Suite 608
Bethesda, MD 20814

Sentech, Inc.
Attn: Robert Reeves
9 Eaton Road
Troy, NY 12180

Santa Clara University
Attn: Charles Feinstein, Ph.D.
Department of Decision and Information
Sciences
Leavey School of Business and
Administration
Santa Clara, CA 95053

SAFT Research & Dev. Ctr.
Attn: Guy Chagnon
107 Beaver Court
Cockeysville, MD 21030

SEIA
Attn: S. Sklar
122 C Street NW
4th Floor
Washington, DC 20001-2104

Salt River Project (2)
Attn: H. Lundstrom
G.E. "Ernie" Palomino, P.E.
MS PAB 357, Box 52025
Phoenix, AZ 85072-2025

SRI International
Attn: C. Seitz
333 Ravenswood Ave.
Menlo Park, CA 94025

Southern California Edison
Attn: R. N. Schweinberg
6070 N. Irwindale Ave., Suite I
Irwindale, CA 91702

Stored Energy Engineering (2)
Attn: George Zink
J.R. Bish
7601 E. 88th Place
Indianapolis, IN 46256

Soft Switching Technologies
Attn: D. Divan
2224 Evergreen Rd., Ste. 6
Middleton, WI 53562

Stuart Kuritzky
347 Madison Avenue
New York, NY 10017

Solarex
Attn: G. Braun
630 Solarex Court
Frederick, MD 21701

Superconductivity, Inc. (2)
Attn: Jennifer Billman
Michael Gravely
P.O. Box 56074
Madison, WI 53705-4374

The Solar Connection
Attn: Michael Orians
P.O. Box 1138
Morro Bay, CA 93443

Switch Technologies
Attn: J. Hurwitch
4733 Bethesda Ave., Ste. 608
Bethesda, MD 20814

Trojan Battery Company
Attn: Jim Drizos
12380-Clark Street
Santa Fe Springs, CA 90670

Trace
Attn: Michael R. Behnke
6952 Precision Avenue
Livermore, CA 94550

U.S. Department of Energy
Attn: C. Platt
EE-12 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: P. Patil
Office of Transportation Technologies
EE-32 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: K. Heitner
Office of Transportation Technologies
EE-32 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: T. Duong
EE-32 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: R. Brewer
EE-10 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: J. Daley
EE-12 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: N. Rossmeissl
EE-13 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: Jim Rannels
Photovoltaic Program
EE-11 FORSTL
1000 Independence Ave., S.W.
Washington, DC 20585-0121

U.S. Department of Energy
Attn: J. P. Archibald
EE-90 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: M. B. Ginsberg
EE-90 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: G. Buckingham
Albuquerque Operations Office
Technology Development Division
P.O. Box 5400
Albuquerque, NM 87185

TU Electric
R&D Programs
Attn: James Fangue
P.O. Box 970
Fort Worth, TX 76101

University of Missouri - Rolla
Attn: M. Anderson
112 Electrical Engineering Building
Rolla, MO 65401-0249

U.S. Department of Energy
Attn: R. Eynon
Nuclear and Electrical Analysis Branch
EI-821 FORSTL
Washington, DC 20585

R. Weaver
777 Wildwood Lane
Palo Alto, CA 94303

U.S. Department of Energy
Attn: A. Jelacic
EE-12 FORSTL
Washington, DC 20585

U.S. Navy
Attn: Wayne Taylor
Code 83B000D
China Lake, CA 93555

U.S. Department of Energy
Attn: A. G. Crawley
EE-90 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: P. N. Overholt
EE-11 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: J. Cadogan
EE-11 FORSTL
Washington, DC 20585

U.S. Department of Commerce
Attn: Dr. Gerald P. Ceasar
Building 101, Rm 623
Gaithersburg, MD 20899

Virginia Power
Attn: Gary Verno
Innsbrook Technical Center
5000 Dominion Boulevard
Glen Ellen, VA 23233

Walt Disney World Design and Eng'g.
Attn: Randy Bevin
P.O. Box 10,000
Lake Buena Vista, FL 32830-1000

Yuasa, Inc. (3)
Attn: N. Magnani
F. Tarantino
G. Cook
P.O. Box 14145
2366 Bernville Road
Reading, PA 19612-4145

U.S. Department of Energy
Attn: A. Hoffman
Office of Utility Technologies
EE-10 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: R. Eaton
Golden Field Office
1617 Cole Blvd.
Building 17
Golden, CO 80401

Westinghouse
Attn: Tom Matty
P.O. Box 17230
Baltimore, MD 21023

Westinghouse STC
Attn: H. Saunders
1310 Beulah Road
Pittsburgh, PA 15235

W. R. Grace & Company
Attn: S. Strzempko
62 Whittemore Avenue
Cambridge, MA 02140

Yuasa-Exide, Inc.
Attn: R. Kristiansen
35 Loch Lomond Lane
Middleton, NY 10941-1421

Crescent EMC
Attn: R. B. Sloan
Executive Vice President
P.O. Box 1831
Statesville, NC 28687

HL&P Energy Services
Attn: George H. Nolin, CEM, P.E.
Product Manager Premium Power Services
P.O. Box 4300
Houston, TX 77210-4300

UFTO
Attn: Edward Beardsworth
951 Lincoln Ave.
Palo Alto, CA 94301-3041

The Technology Group, Inc.
Attn: Tom Anyos
63 Linden Ave.
Atherton, CA 94027-2161

ZBB Technologies, Inc.
Attn: P. Eidler
11607 West Dearborn
Wauwatosa, WI 53226-3961

ECG Consulting Group, Inc.
Attn: Daniel R. Bruck
Senior Associate
55-6 Woodlake Road
Albany, NY 12203

Westinghouse Electric Corporation
Attn: Gerald J. Keane
Manager, Venture Development
Energy Management Division
4400 Alafaya Trail
Orlando, FL 32826-2399

The Brattle Group
Attn: Thomas J. Jenkin
44 Brattle Street
Cambridge, MA 02138-3736

Exide Electronics
Attn: John Breckenridge
Director, Federal Systems Division
8609 Six Forks Road
Raleigh, NC 27615

Northern States Power Company
Attn: Gary G. Karn, P.E.
Consultant Electric Services
1518 Chestnut Avenue North
Minneapolis, MN 55403

Frost & Sullivan (2)
Attn: Steven Kraft
Dave Coleman
2525 Charleston Road
Mountain View, CA 94043

C&D Powercom
Attn: Larry S. Meisner
Manager Product Marketing
1400 Union Meeting Road
P.O. Box 3053
Blue Bell, PA 19422-0858

Distributed Utility Associates
Attn: Joseph Iannucci
1062 Concannon Blvd.
Livermore, CA 94550

SAFT America, Inc.
Attn: Ole Vigerstol
National Sales Manager
711 Industrial Blvd.
Valdosta, GA 13601

American Superconductor Corporation
Attn: S. Amanda Chiu, P.E.
Manager, Strategic Marketing
Two Technology Drive
Westborough, MA 01581

University of Texas at Austin
Attn: John H. Price
Research Associate
Center for Electromechanics
J. J. Pickel Research Campus
Mail Code R7000
Austin, TX 78712

U.S. Department of Energy
Attn: W. Butler
PA-3 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: J. A. Mazer
EE-11 FORSTL
Washington, DC 20585

VEDCO Energy
Attn: Rick Ubaldi
12 Agatha Lane
Wayne, New Jersey 07470

Intercon Limited (2)
Attn: David Warar
6865 Lincoln Avenue
Lincolnwood, IL 60646

Utility PhotoVoltaic Group
Attn: Steve Hester
1800 M Street, N.W.
Washington, DC 20036-5802

U.S. Department of Energy
Attn: P. Maupin
ER-14
G-343/GTN
Germantown, MD 20874-1290

Tampa Electric Company
Attn: Terri Hensley, Engineer
P.O. Box 111
Tampa, FL 33601-0111

U.S. Department of Energy
Attn: R. J. King
EE-11 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: A. O. Bulawka
EE-11 FORSTL
Washington, DC 20585

Southern California Edison
Attn: N. Pinsky
P.O. Box 800
2244 Walnut Grove Ave., Rm 418
Rosemead, CA 91770

U.S. Department of Energy
Attn: D. T. Ton
EE-11 FORSTL
Washington, DC 20585

U.S. Department of Energy
Attn: J. Galdo
EE-10 FORSTL
Washington, DC 20585

Queensland Department of Mines and Energy
Attn: N. Lindsay
Senior Project Officer
Energy Planning Division
GPO Box 194 Brisbane 4001, Qld. Australia

Utility Power Group
Attn: Mike Stern
9410-G DeSoto Avenue
Chatsworth, CA 91311-4947

Amber Gray-Fenner
7204 Marigot Rd. NW
Albuquerque, NM 87120

ABB Power T&D Company, Inc.
Attn: H. Weinerich
1460 Livingston Avenue
North Brunswick, New Jersey

MS-0513, R. Eagan (1000)
MS-0953, W.E. Alzheimer (1500)
MS-0953, J.T. Cutchen (1501)
MS-0741, S. Varnado (6200)
MS-0212, A. Phillips, (10230)
MS-0340, J. Braithwaite (1832)
MS-0343, W. Cieslak (1832)
MS-0613, A. Akhil (1525)
MS-0613, D. Doughty (1521)
MS-0614, E. Biniasiewicz (1522)
MS-0613, G. Corey (1525)
MS-0614, G.P. Rodriguez, (1523)
MS-0613, I. Francis (1525)
MS-0614, J.T. Crow (1523)
MS-0614, T. Unkelhaeuser (1523)
MS-0614, D. Mitchell (1522)
MS-0614, K. Grothaus (1523)
MS-0613, N. Clark (1525)
MS-0613 R. Jungst (1521)
MS-0704, P.C. Klimas (6201)
MS-0708, H. Dodd (6214)
MS-0752, M. Tatro (6219)
MS-0753, C. Cameron (6218)
MS-0753, R. Bonn (6218)
MS-0753, T. Hund (6218)
MS-0753, W. Bower (6218)
MS-1193, D. Rovang (9531)
MS-0614, A Jimenez (1523)
MS-0537, S. Atcitty (2314)
MS-0613, J.D. Guillen (1525)
MS-9403, Jim Wang (8713)
MS-0613, P. Butler (1525) (20)
MS-0619, Review & Approval Desk For DOE/OSTI (12690) (2)
MS-0899, Technical Library (4916) (2)
MS-9018, Central Technical Files (8940-2)