LA-UR-98- 3406
August 1998

RECEIVED

AUG 18 1999

ISOTOPE PRODUCTION FACILITY

OSTI

CONCEPTUAL THERMAL-HYDRAULIC DESIGN REVIEW AND SCOPING
CALCULATIONS

by

Kemal O. Pasamehmetoglu and Jeffrey D. Shelton

Los Alamos
NATIONAL LABORATORY

Photograph by Chris J. Lindberg

Los Alamos National Laboratory, an affirmative action/equal opportunity employer, is operated by the University of California for the U.S. Department of Energy under contract W-7405-ENG-36. By acceptance of this article, the publisher recognizes that the U.S. Government retains a nonexclusive, royalty-free license to publish or reproduce the published form of this contribution, or to allow others to do so, for U.S. Government purposes. The Los Alamos National Laboratory requests that the publisher identify this article as work performed under the auspices of the U.S. Department of Energy. Los Alamos National Laboratory strongly supports academic freedom and a researcher's right to publish; therefore, the Laboratory as an institution does not endorse the viewpoint of a publication or guarantee its technical correctness.

RECEIVED
AUG 18 1999
OSTI

ISOTOPE PRODUCTION FACILITY
CONCEPTUAL THERMAL-HYDRAULIC DESIGN REVIEW
AND SCOPING CALCULATIONS

by

Kemal O. Pasamehmetoglu and Jeffrey D. Shelton

Nuclear Systems Design and Analysis Group (TSA-10)
Los Alamos National Laboratory
Los Alamos, New Mexico

July 1998

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, make any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

TABLE OF CONTENTS

	PAGE
EXECUTIVE SUMMARY.....	iii
1. INTRODUCTION.....	1
2. DESCRIPTION OF THE TARGET GEOMETRY.....	1
3. PRESSURE DROP AND FLOW DISTRIBUTION.....	2
3.1. Pressure Drop across the Coolant Channels.....	3
3.2. Flow Distribution among the Channels.....	5
4. POWER AND ENTHALPY DISTRIBUTION.....	8
4.1. Power Distribution among the Target Plates.....	9
4.2. Enthalpy Distribution among the Coolant Channels.....	9
4.3. Lateral Heat-Flux Distribution.....	12
5. THERMAL-HYDRAULIC LIMITS CALCULATIONS.....	12
5.1. The No-Boiling Criterion.....	15
5.2. Onset of Flow Instability (OFI) Limit.....	19
5.3. Critical Heat Flux (CHF).....	20
6. CONCLUSIONS AND RECOMMENDATIONS	23

EXECUTIVE SUMMARY

The thermal-hydraulic design of the target for the Isotope Production Facility (IPF) is reviewed. In support of the technical review, scoping calculations are performed. The results of the review and scoping calculations are presented in this report.

Based on the findings, we recommend that the IPF target be designed for operations without boiling. This criterion is achievable by adequately designing the system-pressure, coolant-flow-rate, target-material-thickness, and beam-rastering schemes. Single-phase operations provide adequate safety margins to thermal excursion limits and minimize the corrosion of the target material.

A specific set of recommendations for the final design is provided at the end of this report. The major recommendations are as follows:

- A careful review of the flow distribution is required to ensure that the coolant is properly distributed to each channel. As a start, the inlet pipe size must be increased.
- The system pressure should be kept as high as possible to provide a large factor of safety for thermal-hydraulic limits. The minimum recommended pressure is 6 bars (87 psi).
- The heat-removal system must be designed to provide coolant velocities >3.5 m/s in the hot channel, with proper consideration of the material erosion issues.
- The power deposition of the beam should be kept as uniform as possible. The peak heat flux should be kept below ~ 3 MW/m².
- The current coolant gap of 2.5 mm (0.1 in.) is adequate. The coolant gap may be made smaller if the solid volume fraction becomes an issue.

1. INTRODUCTION

The purpose of the Isotope Production Facility (IPF) is to produce medical and research radioisotopes for the Department of Energy's (DOE's) Isotope Production and Distribution Program. The IPF will be located in experimental area A of the Los Alamos Neutron Science Center (LANSCE) complex at Los Alamos National Laboratory. The IPF will be attached to the LANSCE linear accelerator beam line and will use part of the beam produced by the accelerator. The beam energy will be ~100 million electron volts (MeV). The IPF is being designed for a maximum beam power of 50 kW (170,600 Btu/h).

In this report, the scoping calculations performed in support of the IPF thermal-hydraulic design review is presented. The scope of the review is limited to the thermal-hydraulic design of the IPF target. The heat-removal system outside the target is not reviewed. For the target geometry, the information provided within the conceptual design report (CDR) and the recent modifications to the CDR are used to construct a hypothetical target for scoping calculations. The geometric data used in the current analyses are summarized in Section 2. Within the IPF target, the following issues are considered:

- the flow distribution and pressure drop (discussed in Section 3);
- the power distribution and enthalpy distribution (discussed in Section 4) and
- the comparison of the thermal-hydraulic performance to limits (discussed in Section 5).

Through engineering evaluations and scoping calculations, preliminary design recommendations are made in Section 6.

2. DESCRIPTION OF THE TARGET GEOMETRY

The cross-sectional view of the target used in the current analysis is shown in Fig. 1. The target is made of target plates that are 13.97 cm (5.5 in.) wide and 15.24 cm (6 in.) long. The target itself is a 10.16-cm (4-in.)-diam disk held in the center of the target plates. The thickness of the target plates depends on the material used for a specific application and ranges between <1 mm (0.04 in.) and several centimeters. The raised ends of the target plates provide the coolant passages between the plates. The coolant channels are 11.43 cm (4.5 in.) wide, 15.24 cm (6 in.) long, and 0.25 cm (0.1 in.) thick.

To begin the design review and the scoping calculations, a target with a hypothetical thickness within the range quoted in the CDR was assumed. It also was assumed that 3.45 cm (1.36 in.) of target material and 1.02 cm (0.4 in.) of water are required to stop the beam (in addition to some small attenuation that would occur at the window). This corresponds to modeling four plates [each being 0.88 cm (0.34 in.)

thick] and five coolant channels as depicted in Fig. 1, in which the last coolant channel is beyond the beam penetration depth.

To optimize the target efficiency, the coolant volume fraction in the beam must be minimized. However, to remove the deposited power effectively, sufficient coolant flow is required through all of the channels. The CDR selected a 2.54-mm (0.1-in.) coolant gap (also used in the current scoping calculations) as a compromise between the production efficiency and adequate cooling considerations.

The beam hits the target horizontally. The plates are stacked vertically to the beam. The target is cooled by vertical upflow through the coolant channels.

3. PRESSURE DROP AND FLOW DISTRIBUTION

The total primary flow rate cited in the CDR is $7.56 \times 10^{-3} \text{ m}^3/\text{s}$ (120 gal./min). In the scoping calculations performed during the review, the flow rate through the most limiting channel is assumed to be $1.26 \times 10^{-3} \text{ m}^3/\text{s}$ (20 gal./min), resulting in a coolant velocity of 4.34 m/s (14.24 ft/s). For the hypothetical geometry shown in Fig. 1 and with uniform flow distribution among the channels, the total flow through the target would be $6.30 \times 10^{-3} \text{ m}^3/\text{s}$ (100 gal./min). The sensitivity of the scoping calculations to this assumption is discussed within this report.

The schematic depiction of the flow distribution is shown in Fig. 2. The flow is supplied to the lower plenum by a 7.62-cm (3-in.)-diam tube. The flow is split among the parallel coolant channels, and the coolant exits into the upper plenum. The flow

Fig. 1. Geometry depiction of the IPF target.

Fig. 2. Schematic illustration of flow through the target.

distribution among the channels depends on the pressure drop through the channels and the pressure distribution within the upper and lower manifolds. If the pressure distribution is uniform in the upper and lower manifolds, the manifolds will act as perfect plena. In this report, it is assumed that the upper and lower manifolds will be designed to provide a constant pressure drop across the parallel coolant channels.

3.1. Pressure Drop across the Coolant Channels

The pressure drop through the coolant channels is given by

$$\Delta P = \Delta P_{in} + \Delta P_f + \Delta P_{out} = \frac{1}{2} \rho V^2 \left\{ \left[K_{in} + \left(1 - \frac{V_{in}^2}{V^2} \right) \right] + f \frac{L}{D_H} + \left[K_{out} - \left(1 - \frac{V_{out}^2}{V^2} \right) \right] \right\} \quad , (1)$$

where

ΔP is the total pressure drop across the target ($P_{inlet} - P_{exit}$),

ΔP_{in} is the inlet form losses,

ΔP_f is the frictional losses through the coolant channel,

ΔP_{out} is the exit form losses,

ρ is the fluid density,

V is the coolant velocity in the channel,

K_{in} is the inlet loss coefficient,

V_{in} is the coolant velocity in the inlet manifold,

f is the friction factor in the coolant channels,

L is the length of the coolant channel,

D_H is the coolant channel's hydraulic diameter,

K_{out} is the outlet loss coefficient, and

V_{out} is the coolant velocity in the exit manifold.

The inlet and outlet form losses are obtained from Ref. 1 as

$$K_{in} = 0.42 \left[1 - \left(\frac{A}{A_{in}} \right)^2 \right] = 0.42 \left[1 - \left(\frac{\delta}{\Delta} \right)^2 \right] , \quad (2)$$

and

$$K_{out} = \left(1 - \frac{A}{A_{out}} \right)^2 = \left(1 - \frac{\delta}{\Delta} \right)^2 , \quad (3)$$

where

A is the flow area for the coolant channel,

A_{in} is the flow area in the inlet manifold,

δ is the coolant channel gap,

Δ is the equivalent gap per channel in the inlet and exit manifolds, and

A_{out} is the flow area in the exit manifold.

For the hypothetical geometry defined in Section 2, the gap thickness (δ) is 2.5 mm (0.1 in.) and the equivalent gap thickness at the inlet and exit (Δ) is $47.24/5 = 9.45$ mm (0.372 in.).

The friction factor (f) is obtained using the Blasius equation,² with a correction factor of 1.085 to account for the rectangular channel geometry.² The Reynolds number is defined based on the hydraulic diameter, which is approximated as

$$D_H \approx 2\delta .$$

The pressure drop through the target is calculated as a function of the coolant velocity in the channels. The results are shown in Fig. 3. As shown in this figure, the frictional pressure drop contributes negligibly to the total pressure drop. The total pressure drop is dominated by the form losses and the fluid acceleration at the inlet of the channel. The pressure drop at the inlet is greater than the overall pressure drop because of the pressure recovery that occurs at the exit. At the exit the pressure drop is negative (indicating a pressure increase) because the fluid deceleration dominates the exit form losses. The pressure drop in Fig. 3 shows the total pressure drop including the fluid acceleration and deceleration. The irreversible form and friction losses are shown in Fig. 4. Based on these scoping calculations, it is clear that the pressure drop across the channels is small and is dominated by the pressure drop at the inlet.

For a velocity of 4 m/s (13.1 ft/s) through the channel, the total pressure drop is 8.63 kPa (1.3 psig). The inlet pressure drop and the frictional pressure drop are 10.23 kPa (1.5 psig) and 1.47 kPa (0.2 psig), respectively. Thus, the frictional drop is <15% of the total pressure drop. The small contribution of the frictional drop to the total pressure drop is a strength in the design because

- the channel-to-channel flow distribution is less sensitive to the small geometric distortions within the channel and
- the design is less sensitive to Leddinegg flow instabilities that could occur as a result of subcooled boiling within a given channel.

The channel-to-channel flow distribution issue is discussed next. Flow instability limits are discussed in Section 5.

3.2. Flow Distribution among the Channels

The effect of small geometric variations on the flow distribution is considered first. An off-nominal channel with a gap thickness of δ' is assumed. The velocity through this channel is set to V' . If the conservation of mass and momentum equations for this channel for a given ΔP across the target are solved, the following relationship is obtained between V and V' :

$$\left(\frac{V'}{V}\right)^2 = \frac{0.42 \left[1 - \left(\frac{\delta}{\Delta}\right)^2\right] + \frac{C}{\left(\frac{\rho V 2\delta}{\mu}\right)^n} \frac{L}{2\delta} + \left(1 - \frac{\delta}{\Delta}\right)^2}{0.42 \left[1 - \left(\frac{\delta'}{\Delta}\right)^2\right] + \frac{C}{\left(\frac{\rho V' 2\delta'}{\mu}\right)^n} \frac{L}{2\delta'} + \left(1 - \frac{\delta'}{\Delta}\right)^2} , \quad (4)$$

Fig. 3. Channel pressure drop.

Fig. 4. Irreversible pressure losses through the target channel.

where μ is the dynamic viscosity and the friction factor is expressed in a generic form as

$$f = \frac{C}{Re^n} .$$

If the friction factor dominates the total pressure drop, Eq. (4) reduces to

$$\frac{V'}{V} = \left(\frac{\delta'}{\delta} \right)^{\frac{1+n}{2-n}} , \quad (5)$$

where $n = 1$ for laminar flow and $n = 0.25$ for turbulent flow. For $\delta'/\delta = 0.75$, V'/V is obtained as 0.56 and 0.814 for laminar and turbulent flows, respectively. Thus, for turbulent flow, the channel flow rates reduce by ~40%, as compared to the nominal channel; for laminar flow, this reduction is ~60%.

If the form losses dominate the total pressure drop (which is the case in the current design), Eq. (4) reduces to

$$\frac{V'}{V} = \sqrt{\frac{0.42 \left[1 - \left(\frac{\delta}{\Delta} \right)^2 \right] + \left(1 - \frac{\delta}{\Delta} \right)^2}{0.42 \left[1 - \left(\frac{\delta'}{\Delta} \right)^2 \right] + \left(1 - \frac{\delta'}{\Delta} \right)^2}} . \quad (6)$$

For $\delta'/\delta = 0.75$, V'/V is obtained as 0.96. Therefore, to minimize the sensitivity of the coolant velocity to geometric distortions, turbulent flow with the dominant pressure drop occurring at the inlet is the desired design option. For a flow rate of $1.26 \times 10^{-3} \text{ m}^3/\text{s}$ (20 gal./min) through the channel, the Reynolds number is $>27,000$ and for fluid temperatures is $>30^\circ\text{C}$ (86°F). Thus, the turbulent flow requirement is met adequately.

The next issue with respect to flow distribution is related to the design of the inlet and exit manifolds. For an even flow distribution, an even pressure distribution within the manifolds is needed. Given that the distance between the inlet and exit pipes and the bottom and the top of the target is rather small (on the order of 25.4 mm (1 in.)), it is not clear that a uniform pressure distribution will exist in the inlet and exit manifolds. Furthermore, the inlet pipe appears to be undersized. The potential effect of the inlet piping on the flow distribution is illustrated in Fig. 5, where the 76.2-mm (3-in.) inlet pipe is superimposed on the cross-sectional view of the target. Given that the distance between the exit of the inlet pipe and the bottom of the target is not long enough for full flow recovery, this figure illustrates clearly the potential for flow maldistribution in the lateral (X) direction. Adequate lateral

Fig. 5. Top view of the target in reference to the inlet pipe.

flow distribution may be achieved toward the top of the target. However, potential local overheating near the bottom of the target cannot be ruled out. Simple engineering solutions to this problem could be to increase the size of the inlet pipe, center the target adequately with respect to the inlet pipe, or increase the inlet manifold depth (distance between the inlet pipe exit and the bottom of the target) as much as possible. In increasing the inlet pipe size, the flow must be kept turbulent in the inlet pipe to alleviate any potential problems associated with boundary-layer effects with laminar flow.

As discussed in the next section, the power deposition in the target is biased toward the back plates. Because the back plate requires more cooling than the other plates, the design of the inlet and exit manifolds can be tailored to an uneven flow distribution, in which a larger fraction of the total flow is supplied to the back channel. The heat-removal efficiency, which is also discussed later, is a strong function of the coolant velocity and a weak function of the total flow rate. Thus, the velocity in the back channels must be increased compared to the front channels for a more efficient heat-removal system. This is not easy to achieve by simply changing the channel sizes because of the relative insensitivity of the velocity-to-channel size (as discussed previously). If a more efficient heat-removal scheme is desired by tailoring the flow distribution to the power distribution, a careful manifold design supported by hydraulic testing will be needed.

4. POWER AND ENTHALPY DISTRIBUTION

The next step in the review is to evaluate the power distribution among the target plates and the coolant channels.

4.1. Power Distribution among the Target Plates

Figure 2 on page L-6 of the CDR shows an assumed target material used to scale the power distribution. This material was assumed to degrade the beam twice as much as water degradation for the same thickness. Figure 6 shows a representation of the power distribution in the target system for the scoping calculations. Plates are numbered in the direction of the beam. The beam exit window and the coolant channel behind it are indicated as number 0. The channels shown in Fig. 6 represent the channel immediately behind the respective target plate.

The power deposition in the window and the coolant channel behind the window is assumed to be 6.2% of the total beam power [3.1 kW (10,580 Btu/h)]. The remaining beam power is distributed as follows:

- 85.6% of the beam power is deposited in the targets [42.8 kW (146,040 Btu/h)] and
- 8.2% of the beam power is deposited in the coolant [4.1 kW (13,990 Btu/h)].

By design, the last coolant channel behind target plate number 4 has no power deposition. For this example, slightly less than 40% of the total power is deposited in the last plate. The corresponding power is slightly less than 20 kW (68,240 Btu/h)]. In the subsequent calculations, 20 kW (68,240 Btu/h) of power deposition is assumed for the hottest target.

4.2. Enthalpy Distribution among the Coolant Channels

Part of the power is deposited in the target plates. Depending on the target material, a considerable fraction of the total beam power may be deposited directly into the coolant, as shown in Fig. 6. In addition, the power deposited into the target plates is removed by the coolant. Because the direct power deposited into the coolant as well

Fig. 6. Percent of total power (50 kW) deposited to the target system.

as the power removed from the plates is not uniform, the enthalpy rises in different channels will not be the same.

On an average basis, if a flow rate of $6.3 \times 10^{-3} \text{ m}^3/\text{s}$ (100 gal./min) is used to remove 50 kW (170,600 Btu/h) of power, the temperature rise of the coolant through the target would be 1.9°C (3.4°F). On a channel-by-channel basis, if a flow rate of $1.26 \times 10^{-3} \text{ m}^3/\text{s}$ (20 gal./min) is used to remove 20 kW (68,240 Btu/h) of power (as the worst-case channel), the temperature rise in the coolant would be 3.8°C (6.8°F). If we consider that highly subcooled fluid will be supplied to the target, the enthalpy rise through the target is of negligible concern. The major concern is associated with the wall heat fluxes and the fluid temperature rise through the thermal boundary layer near the wall, which is addressed in Section 5.

The power deposition through the target is not uniform. Subsequently, the power split between the two channels adjacent to a given target plate may not necessarily be uniform. To assess the effect of nonuniform power deposition in the beamwise direction, the sample problem illustrated in Fig. 7 is considered. As shown in this figure, the power density on the front face of the plate is assumed to be half of the power density on the rear face. The possibility of different heat-transfer coefficients on the front and rear surfaces as a result of different coolant velocities and coolant temperatures also is considered in the model. The results of the steady-state conduction problem are summarized in Table 1. As shown in Table 1, the calculations are performed for two types of materials with thermal conductivities (k) of

- $20 \text{ W/m}^\circ\text{C}$ ($11.6 \text{ Btu/h-ft}^\circ\text{F}$), which is typical of stainless steel; and
- $160 \text{ W/m}^\circ\text{C}$ ($92.4 \text{ Btu/h-ft}^\circ\text{F}$), which is typical of aluminum.

Fig. 7. Schematic illustration of the beamwise power distribution problem.

TABLE 1
RESULTS OF BEAMWISE POWER DISTRIBUTION ASSESSMENT

V_1 (m/s)	V_2 (m/s)	k (W/m-°C)	q_a (MW/m ²)	T_1 (°C)	T_2 (°C)	T_{max} (°C)	q_1/q_a	q_2/q_a
4.4	4.4	20	1.24	100	92	230	1.09	0.91
4.4	4.4	160	1.24	99	92	113	1.09	0.91
4.4	4.4	20	3.1	158	142	484	1.10	0.90
4.4	4.4	160	3.1	155	146	192	1.06	0.94
5.5	3.3	20	1.24	93	100	230	1.12	0.88
5.5	3.3	160	1.24	95	98	113	1.16	0.83

The average heat flux (q_a) corresponds to the heat flux if the total power is removed evenly from both the front and rear surfaces. The average heat flux of 1.24 MW/m² (393,000 Btu/h-ft²) corresponds to the case where the total power of 20 kW (68,240 Btu/h) is distributed evenly over the target area. The case with 3.1 MW/m² (982,700 Btu/h-ft²) corresponds to a lateral peaking factor of 2.5. Table 1 provides the results in terms of the surface temperatures (T_1 and T_2) and the ratio of the surface heat fluxes (q_1 and q_2) to the average heat flux. The maximum temperature (T_{max}) for the target also is provided.

The heat-transfer coefficients are obtained using a 50°C (122°F) constant fluid temperature. The heat-transfer coefficients are obtained using the Dittus-Boelter correlation³ with fluid properties evaluated at the film temperature (see the discussion in Section 5). The results show that with an equal heat-transfer coefficient on both surfaces, the heat-flux distribution remains within $\pm 10\%$ of the average heat flux for the conductivity and power density range investigated. Although the effects are small within the parametric range investigated, higher conductivity promotes more even heat-flux distribution. Finally, by varying the heat-transfer coefficients, the heat-flux distribution can be tailored to an effective heat-removal system; however, the results show that large variations in the heat-transfer coefficient are required to obtain small variations in the heat-flux distribution.

In conclusion, these calculations show that although there is a factor-of-two difference in the front and back power densities, the heat fluxes remain within $\pm 10\%$ of the average heat flux. Although using the average heat flux in the limit calculations is not conservative, the actual results are much closer to the average values than the values obtained by merely scaling the power density distribution.

4.3. Lateral Heat-Flux Distribution

In the previous section, the effect of beamwise power deposition on the power partitioning between the front and back channels was considered. In addition, there are lateral variations in the power deposition. The beam has a Gaussian profile with a large peak at the center. To provide a more uniform power deposition, the beam will be rastered over the 4-in.-diam circle. However, even for the rastered beam, there will be local power peaks. In this section, the effect of lateral power distribution on the lateral heat-flux distribution for a given surface is addressed. The main issue is whether thermal conduction can help in reducing the local peaks to provide a more uniform lateral heat-flux distribution.

Two cases are considered. For the first case, the total power of 20 kW (68,240 Btu/h) is deposited uniformly over the target. The target plate is assumed to be made of a high-conductivity material with a conductivity of 160 W/m-°C (92.4 Btu/h-ft-°F). Similar to the previous case, the surface heat-transfer coefficient is obtained using the Dittus-Boelter correlation. The fluid properties are evaluated at the bulk fluid temperature. The fluid temperature is set to 50°C (122°F). The results (Fig. 8) show that the conduction spreads the heat flux near the edges of the target but that the peak heat flux at the center is not affected. The step function shown in Fig. 8 corresponds to the radial heat-flux distribution without accounting for the conduction, which has the same shape as the power distribution.

The second case considers a Gaussian distribution for the power densities while keeping the total deposited power equal to 20 kW (68,240 Btu/h). As shown in Fig. 9, for high-conductivity target material reduction in the peak, flux may be achieved by properly accounting for the radial conduction. However, the reduction is negligible for materials with a conductivity similar to the stainless steel conductivity. Also, if the power peaking occurs at a radial location that is different from the center, a further reduction in the peak heat flux may be achieved because of the increased radial conduction area. In conclusion, the benefit of the radial conduction analysis depends on the rastering scheme used for the beam. Similar to the previous case, the surface heat-transfer coefficient is obtained using the Dittus-Boelter correlation. The fluid properties are evaluated at a bulk fluid temperature of 50°C (122°F).

5. THERMAL-HYDRAULIC LIMITS CALCULATIONS

The thermal-hydraulic limits are determined based on the target surface temperature and the corresponding heat flux. The following energy equation provides the relationship between the local surface heat flux (q) and the surface temperature (T_w):

Fig. 8. Radial temperature distribution with a uniform power deposition.

Fig. 9. Radial temperature distribution with a Gaussian power deposition.

$$T_w(z) = T_{\text{inlet}} + \underbrace{\frac{\int_0^z [q_1(z') + q_2(z')] dz}{\rho V A_c C_p}}_{\text{on the order of } 1^\circ\text{C}} + \underbrace{\frac{q(z)}{h(z)}}_{\text{on the order of } 100^\circ\text{C}}, \quad (7)$$

where

z is the coordinate parallel to the coolant flow;

T_{inlet} is the fluid inlet temperature;

q_1 and q_2 are the heat fluxes on the front and back surfaces of a channel;

A_c is the channel's cross-sectional area;

C_p is the specific heat of the coolant; and

h is the local convective heat-transfer coefficient.

As discussed earlier, the second term on the right-hand side of Eq. (7) represents the fluid temperature rise and is $\sim 1^\circ\text{C}$. The third term represents the film drop and is $\sim 100^\circ\text{C}$ (as discussed in the next section). Thus, for subsequent calculations, a constant fluid temperature is assumed and the wall temperature is approximated as

$$T_w(z) = T_f + \frac{q(z)}{h(z)}, \quad (8)$$

where T_f is the constant fluid temperature. In most scoping calculations presented in this report, T_f is assumed to be 50°C . However, based on the heat-removal system design requirement, T_f will be $\leq 35^\circ\text{C}$.

It is recommended that the IPF target be designed to operate without boiling on the surface. This criterion would provide a sufficient margin to any thermal excursion limits. In addition, potential corrosion of the target material (which is sensitized to corrosion by the proton beam) is minimized. The no-boiling criteria are discussed further in Section 5.1.

The backup criterion is to meet the thermal-excursion limits with a high degree of confidence. If the no-boiling criterion cannot be met or if it is violated during upset conditions, a sufficient safety margin to the thermal excursion limits must be maintained to prevent damage to the target. In parallel channels and under subcooled boiling conditions, thermal excursions may occur as a result of either the onset of flow instability (OFI) limit or the DNB limit.

The OFI and DNB limits are discussed in Sections 5.2 and 5.3, respectively.

5.1. The No-Boiling Criterion

The no-boiling criterion is implemented conservatively using $T_w = T_{\text{sat}}$ in Eq. (8), where T_{sat} is the fluid saturation temperature at the system pressure. To determine the single-phase heat-transfer coefficients, the Dittus-Boelter correlation³ may be used. In the original correlation, the fluid properties were evaluated at the bulk fluid temperature. However, subsequently developed and more accurate correlations use fluid properties evaluated at the film temperature (e.g., the Petukhov correlation³). At high heat fluxes of interest for this study, using the film temperature to evaluate the fluid properties is believed to be more accurate. An alternative would be to use the Sieder-Tate correlation,³ where a wall correction factor is applied based on the temperature dependence of the liquid viscosity.

A comparison of the Dittus-Boelter correlation with properties evaluated at bulk and film temperatures and the Sieder-Tate correlation is shown in Fig. 10 for $V = 3.5 \text{ m/s}$ and $T_f = 35^\circ\text{C}$. Figure 10 shows that the Sieder-Tate correlation is slightly more conservative as compared with the Dittus-Boelter correlation, where the fluid properties are evaluated at the film temperature. Using the Sieder-Tate correlation, we show the predicted wall temperatures as a function of fluid velocity and fluid temperature in Fig. 11. Figure 11 shows that within the parametric range investigated, the wall temperature becomes independent of the fluid temperature with increasing heat flux.

The use of circular tube correlations for fully developed thermal conditions introduces additional conservatism in the present prediction. In Fig. 12, a comparison of the Dittus-Boelter correlation with the Kays and Leung tabular model (for parallel plates) is presented in the form of the Nusselt numbers ratio. The ratio of the Nusselt number predicted by the Kays and Leung method to the Nusselt number predicted by Dittus-Boelter correlation is plotted as a function of the Reynolds number. As shown in this figure, the Dittus-Boelter correlation underestimates the heat transfer as calculated by the Kays and Leung correlation by ~5% for the Reynolds number of interest. This will lead to slightly higher calculated wall temperatures and a conservative estimate of the safety margin of the IPF thermal-hydraulic design.

Another issue is the thermal entry length. The heat-transfer correlations are developed under fully developed thermal conditions. In general, a fully developed temperature profile does not exist for nonuniform heat-flux distributions. Furthermore, because of the short length of the target system, the coolant in the channels does not become thermally developed. This enhances heat transfer, as shown in Fig. 13. In Fig. 13, two thermally developing heat-transfer models cited in Ref. 2 are listed. These models show that if the heat-flux peaking were to occur near the center of the target, the heat-transfer enhancement would be between 8% and 15%. In plotting Fig. 13, the Reynolds number is evaluated using $T_f = 50^\circ\text{C}$ and $V = 3.5 \text{ m/s}$.

Fig. 10. Comparison of the Dittus-Boelter and Sieder-Tate correlations.

Fig. 11. Effect of fluid temperature and velocity on the wall temperature.

Fig. 12. Comparison of the Dittus-Boelter correlation to the Kays and Leung correlation.

The system pressure required to meet the $T_w = T_{sat}$ criterion is shown in Fig. 14 for $V = 4.5$ m/s and $V = 3.5$ m/s. In these calculations, T_f is set to 35°C. The use of $T_w = T_{sat}$ criterion for incipient boiling is discussed further below.

For the onset of nucleate boiling (ONB), a certain amount of superheat is required on the heated wall. The required superheat depends on the surface roughness (nucleation cavity sizes) and the amount of dissolved gases in the fluid. The ONB correlation provided by Bergles and Rohsenow⁵ is plotted in Fig. 15. In this figure, the required wall superheat is shown as a function of system pressure and heat flux, and higher superheat is needed for higher heat fluxes. The Bergles-Rohsenow correlation conservatively envelops the nucleation cavity sizes that potentially exist on the wall. However, it does not account for the effect of the dissolved gases. The main reasons to operate without boiling are

- to avoid excessive corrosion for which dissolved gases are not expected to have appreciable effects; and
- to provide a large margin to thermal excursion (OFI and DNB). The studies in Refs. 6 and 7 show that for small-diameter channels, the effect of dissolved gases on OFI and CHF is negligible.

Thus, the conservatism associated with the $T_w = T_{sat}$ criterion as an ONB criterion may be relaxed if needed and the Bergles-Rohsenow correlation may be used as an ONB model.

Fig. 13. Effect of thermal-entry length on the heat-transfer coefficient.

Fig. 14. System pressure required to meet $T_w = T_{sat}$ criterion.

Fig. 15. Predicted wall superheat at the ONB.

5.2. Onset of Flow Instability (OFI) Limit

In the absence of prototypical tests, the Saha-Zuber model⁸ that predicts the onset of significant void (OSV) may be used cautiously, as a precursor to the OFI. The Saha-Zuber model predicts the OSV within $\pm 25\%$ over a wide parametric range. For a given heat flux, the bulk subcooling corresponding to the OSV can be calculated using the Saha-Zuber model. Using the data relevant to the IPF design, several plots were generated to display the results of the Saha-Zuber model. These graphs are presented as Figs. 16–18.

Figure 16 is a plot of the Saha-Zuber value of the amount of subcooling required for various values of the heat flux. The required bulk subcooling using the Saha-Zuber model and the upper-bound of the Saha-Zuber model is plotted in Fig. 16. Also shown in Fig. 16 is the conservative saturation temperature at the OSV, which assumes a conservative fluid temperature of 50°C . The corresponding system pressure is shown in Fig. 17, in which the minimum system pressure is shown to be limited to 1 atm. As shown in this figure, for heat fluxes $\leq 4 \text{ MW/m}^2$, operating even at atmospheric pressure provides an adequate safety margin to the OSV.

Figures 16 and 17 were generated using an inlet fluid temperature of 50°C and a fluid velocity of 4.5 m/s . However, within the range of interest, the required system pressures may be sensitive to the coolant velocity. Figure 18 gives a depiction of this

dependence for two values of the heat flux. As shown in Figure 18, for a low heat-flux situation, the coolant velocity has no noticeable effect on the required system pressure. As in the previous cases, the minimum system pressure is constrained to 1 atm in generating Fig. 18. For high heat fluxes, the coolant velocity plays a significant role in the required system pressure. For $q = 5 \text{ MW/m}^2$, the required system pressure can increase to 6 atm with a decreasing coolant velocity.

Thus, for the parametric range of interest in the IPF design, the OSV is not a serious concern. There is a considerable safety margin between the IPF operating point and the OSV limit. Furthermore, the OSV is a concern only as a precursor to the OFI. As discussed in Section 3, the pressure drop in the IPF design is dominated by the inlet pressure drop, with negligible contribution by the frictional pressure drop. Therefore, even at OSV, it is not likely that an OFI will occur.

5.3. Critical Heat Flux (CHF)

The next issue to consider is the heat-transfer instabilities, or CHF. The fluid is expected to be subcooled. Therefore, the expected CHF mechanism is DNB as opposed to dryout that could occur with saturated exit conditions.

The data currently available for the parameter ranges of interest are based on circular tube data. The following empirical correlations are considered to quantify the CHF for the IPF design:

- the Bowring-Macbeth correlation;⁵
- the modified Tong correlation;⁹
- the Vandervort et al. correlation;¹⁰ and
- the Knoebel correlation.⁹

Fig. 16. Subcooling and saturation temperatures at the OSV.

Fig. 17. The system pressure required to maintain the wall temperature below the saturation temperature.

Fig. 18. Velocity effect on required system pressure.

The parametric range for the correlations is provided in Table 2. The Knoebel correlation is not included in the table because its parametric range is not specified

in Ref. 9. However, the Knoebel correlation commonly is used to predict subcooled CHF in low-pressure systems and is shown to envelop the data presented in Ref. 9 conservatively. Figure 19 shows the predicted CHF by these correlations as a function of system pressure. In generating the data displayed in Fig. 19, the fluid temperature and velocity are set to 50°C and 4.5 m/s, respectively. Figure 19 shows that the most conservative predictions are provided by the Bowring-Macbeth and Knoebel correlations. Bowring-Macbeth is known to underpredict the subcooled CHF data. Based on the comparison of the Knoebel correlation with the subcooled CHF data in Ref. 9, Knoebel et al. also is expected to be conservative. Nonetheless, in the absence of prototypical data, a conservative prediction is required.

The correlations used for Fig. 19 are based on circular tube data. For rectangular channels, the use of circular tube models to predict the CHF may be nonconservative if boiling is allowed to occur at the corners. For the IPF target, the corner of the channels is in the unheated region and boiling will not occur near the corners. A special series of experiments, where the coolant channel is heated from one side and the corner effects are specifically isolated, is reported in Ref. 11. A 20-cm-long, 4-mm-wide copper plate was used for the tests. The gap for the coolant channel was 3.5 mm. The CHF data are obtained over the following parametric range:

Pressure: 0.49 to 3 MPa
 Mass Flux: 3750 to 27,000 kg/m²-s.
 Bulk subcooling: 30 to 160°C

The data for 4300 kg/m²-s show that the CHF is >10 MW/m² for subcooling in excess of 50°C, which provides additional confidence that the use of the Knoebel correlation, for instance, would provide conservative estimates for the CHF in the IPF target design.

TABLE 2
 PARAMETER RANGE FOR THE CHF CORRELATION

Parameter	Bowring-Macbeth ⁵	Modified Tong ⁹	Vandervort et al. ¹⁰
Pressure (MPa)	0.2–19	0.1–20	0.1–3
Mass Flux (kg/m ² s)	136–18,600	1300–40,000	3000–90,000
Diameter (mm)	2–45	2–20	0.3–3
L/D		10–50	1–40
Subcooling (°C)		50–150	0–200

Figure 19. Various CHF predictions for the IPF target system.

6. CONCLUSIONS AND RECOMMENDATIONS

Based on the review and scoping calculations performed for the IPF conceptual design, we have determined that operating the target under no-boiling conditions is possible. Also, a large margin of safety to thermal excursion limits (OFI and CHF) can be achieved. The following are some specific design recommendations for the final design.

Operations

The IPF target should be designed to avoid boiling. This will prevent uncertainty in the thermal excursion limits because of a lack of prototypical data. In addition, the absence of boiling prevents excessive corrosion.

Hydraulics

A careful review of the flow distribution is required to ensure the proper distribution of coolant to each channel. This includes investigating the use of a plenum design vs a manifold design. The inlet pipe to the target area should be increased from the current 3.0 in. in diameter to an inlet pipe >4.5 in. in diameter. In addition, testing may be required to ensure proper flow distribution, especially if uneven flow distribution to match the power distribution is desired.

System Pressure

As stated previously, the system pressure should be kept as high as possible to provide a large factor of safety for thermal-hydraulic limits. The minimum recommended pressure is 6 bars (87 psi).

Heat-Removal System

The heat-removal system must be designed to provide coolant velocities >3.5 m/s in the hot channel. This value may be increased if necessary because the pressure drop is small. However, erosion limits for the materials of interest must be considered for velocities >4 m/s.

The inlet coolant temperature also should be maintained as low as possible ($<50^{\circ}\text{C}$).

Rastering

The power deposition of the beam should be kept as uniform as possible. The peak heat flux should be kept $>\sim 3$ MW/m². If necessary, both radial and beamwise conduction should be accounted for in determining the local heat fluxes. Thinner plates may be required if the rastering technique is not sufficient to maintain the peak heat-flux limit.

Coolant Channel Thickness

The current coolant gap of 2.5 mm (0.1 in.) is adequate. The coolant gap may be made smaller if the solid volume fraction becomes an issue. However, the amount that the gap can be decreased is limited by the possible bowing and swelling of the target material.

Final Design Calculations

More specific calculations are required that pertain to the geometry, materials, a realistic rastering scheme, a realistic power deposition, and consideration of the window design.

Several optimization studies also could be performed. The plate thickness and coolant gap thickness could be varied in the beamwise direction to determine the most effective combination. In addition, a nonuniform flow distribution, using special orificing, could be tailored to the power distribution.

The scoping calculations provided in this report are based on normal, steady-state operating conditions. In the final design phase, the effect of the anticipated transients (such as a loss of flow and raster magnet failure) also need to be considered in determining the thermal-hydraulic limits.

Finally, the thermal stresses and erosion limits for the projected materials of the IPF target system need to be investigated.

REFERENCES

1. P. M. Gerhart and R. J. Gross, *Fundamentals of Fluid Mechanics* (Addison-Wesley Publishing Company, 1985).
2. S. Kakac, R. K. Shah, and W. Aung, *Handbook of Single-Phase Convective Heat Transfer* (John Wiley and Sons, New York, 1987).
3. J. P. Holman, *Heat Transfer* (McGraw-Hill, New York, 5th Edition, 1981).
4. W. M. Kays and E. Y. Leung, "Heat Transfer in Annular Passages: Hydrodynamically Developed Turbulent Flow with Arbitrarily Prescribed Heat Flux," *Int. J. Heat Mass Transfer*: 6, 537-557 (1963).
5. J. G. Collier, *Convective Boiling and Condensation* (McGraw-Hill, New York, 2nd Edition 1981).
6. J. E. Kennedy, "Onset of Flow Instability in Uniformly Heated Microchannels," Georgia Institute of Technology Master's Thesis (August 1997).
7. G. M. Roach, "Onset of Flow Instability and Critical Heat Flux in Uniformly Heated Microchannels," Georgia Institute of Technology Master's Thesis (June 1998).
8. P. Saha and N. Zuber, "Point of Net Vapor Generation and Vapor Void Fraction in Subcooled Boiling," *Proceedings of the 5th Int. Heat Transfer Conference*, Paper B4.7 (Tokyo, Japan, 1974).
9. G. P. Celata, M. Cumo, and A. Mariani, "Burnout in Highly Subcooled Water Flow Boiling in Small Diameter Tubes," *Int. J. Heat Mass Transfer*: 36, 1269-1285 (1994).
10. C. L. Vandervort, A. E. Bergles, and M. K. Jensen, "An Experimental Study of Critical Heat Flux in Very High Heat Flux Subcooled Boiling," *Int. J. Heat Mass Transfer*: 37 Suppl., 161-173 (1994).
11. Y. A. Zeigarnik, N. P. Privalov, and A. I. Klimov, "Critical Heat Flux with Boiling of Subcooled Water in Rectangular Channels with One-Side Supply of Heat," *Thermal Engineering* 28, 40-43 (1981).