APR 2 1999
Sta-4 58

ENGINEERING DATA TRANSMITTAL

Page 1 of 1
1. EDT 626277

2. To: (Receiving Organization) Distribution		3. From: (Originating Organization) SNF Project		4. Related EDT No.: N/A				
5. Proj./Prog./Dept./Div.:		6. Design Authority/ Design Agent/Cog. Engr.:		7. Purchase Order No.:				
Spent Nuclear Fuel Project		C. Van Katwijk		N/A				
8. Originator Remarks: N/A				9. Equip./Component No.: N/A				
				10. System/Bldg./Facility: Spent Nuclear Facility				
11. Receiver Remarks:				11A. Design Baseline Document? ☐ Yes ☒ No				
				12. Major Assm. Dwg. No.: N/A				
				13. Permit/Permit Application No.: N/A				
				14. Required Response Date: N/A				
15. DATA TRANSMITTED								
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	(F) Approval Design- Nator	(G) Reason for Trans- mittal	(H) Origi- nator Dispo- sition	(I) Receiv- er Dispo- sition
1	SNF-3928		0	Ashcroft Pressure Switch - Monitor for Low SCHe Purge Pressure	Q	2	1	N/A

16. KEY											
Approval Designator (F)		Reason for Transmittal (G)				Disposition (H) & (I)					
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)		1. Approval 2. Release 3. Information 4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)				1. Approved 2. Approved w/comment 3. Disapproved w/comment 4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged					
17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN
2	1	Designated Engineer	C. Van Katwijk								
2	1	Design Authority	R. Whitehurst	3/30/99							
2	1	QA	T. D. Hays	3/30/99							

18. C. Van Katwijk Signature of EDT Originator		19. T. Chob Authorized Representative for Receiving Organization		20. R. Whitehurst Design Authority/ Cognizant Manager		21. DOE APPROVAL (if required) Ctrl. No. ☐ Approved ☐ Approved w/comments ☐ Disapproved w/comments	
Date		Date		Date			

S

Ashcroft Pressure Switch – Monitor for Low SCHe Purge Pressure

Carl Van Katwijk
Numatec Hanford Co, Richland, WA 99352
U.S. Department of Energy Contract DE-AC06-96RL13200

EDT/ECN: 626277	UC: 620
Org Code: 2G300	Charge Code: 105559/A000
B&R Code: 39EW40400	Total Pages: 13

Key Words: Supply Bottle Pressure

Abstract: Ashcroft Pressure Switch – Monitor for Low SCHe Purge Pressure
CGI-SNF-D-13-P5-031

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

Release Approval

3/31/99
Date

DATE		ID: 58
STA: 4		
APR 2 1999		
Release Stamp		

Approved for Public Release

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. **NA** CGI No. **CGI-SNF-D-13-PS-031**

Page 1 of 12

Title: **ASHCROFT PRESSURE SWITCH - MONITOR FOR LOW SCHe
PURGE PRESSURE**

Section 1 Part Information

Item No.: NA	Manufacturer:	Supplier:
Mfg. Part/Model No.:	Supplier's P/N:	
Part Description:		
End Use Description:		

Section 2a Component Information

Equipment No.: SCHe- PSL-5*06, 5*25, 5*45, 5*65	Specification No.: W-441- P5, Rev. 2	Manufacturer: Ashcroft Instrument Division	Past P.O. No.: NA
Manufacturer's Part/ Model No.: LPS-N4-K-S-25-15 PSI.	Equipment Supplier (if different from manufacturer): TBD		Equip. Supplier's Part No.: NA

Component Description: These 0-15 psig pressure switches are located in the SCHe helium purge lines after PCV 5*23 (set for 15 psig) and before PCV 5*27 (set for 7 psig). The pressure switches monitor the pressure being maintained between the two PCVs and actuate on low pressure of 7.5 psig. This design is used for each of the SCHe supply lines (4). Electronic output signal is NON-SAFETY (GS).

Section 2b Qualified Vendor/Supplier Survey

- Is the Item available from a catalog from a qualified NQA1 or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)?
☐ YES (go to #2 below)
☒ NO (go to procedure step 5.3.2, proceed to dedicate item.)
Ans 12/21/98
- List of Candidate qualified suppliers or ISO 9000 suppliers
 company name and type contact name phone
NA

- Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR):
NA

Section 2c CGI Determination

- Question #1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
☐ YES (the Item is not commercial grade)
☒ NO (continue)
- Question #2: Is the Item used in applications other than nuclear facilities or activities?
☐ NO (the item is not commercial grade)
☒ YES (continue)

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. **NA**

CGI No. **CGI-SNF-D-13-P5-031**

Page 2 of 12

Title: **ASHCROFT PRESSURE SWITCH – MONITOR FOR LOW SCHe
PURGE PRESSURE**

3. Question #3: Is the Item ordered from manufacturer/supplier on the basis or specifications set forth in the manufacturers catalog?

☐ NO (the Item is not commercial grade)

☒ YES (continue)

☒ All three criteria have been satisfied. The Item meets the definition of commercial grade.

Section 2d Reason for Dedication

The above described Item is being Dedicated for use in the application cited for the following reason(s):

☒ Item is being purchased from a non ESL manufacturer supplier as commercial grade to be used in a Safety Class application.

☐ Item is being purchased from a non ESL manufacturer supplier as commercial grade to be used in a Safety Significant application.

☐ Item was purchased from a non ESL manufacturer supplier as commercial grade to be used in a Safety Class application.

☐ Item was purchased from a non ESL manufacturer supplier as commercial grade to be used in a Safety Significant application.

☐ Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:

1. **SCHe Pressure Boundary Integrity – Prevents helium leakage from the SCHe System.**

2. **Maintain pressure boundary after Seismic event.**

3.

B. Part/Component Functional Mode

Safety Function #1:

☐ Active – Mechanical or Electrical change of state is required to occur for the component to perform its safety function

☒ Passive – Change of state is not required for the component to perform its safety function

Safety Function #2:

☐ Active – Mechanical or Electrical change of state is required to occur for the component to perform its safety function.

☒ Passive – Change of state is not required for the component to perform its safety function

Safety Function #3:

☐ Active – Mechanical or Electrical change of state is required to occur for the component to perform its safety function.

☐ Passive – Change of state is not required for the component to perform its safety function

C. Host Component Safety Function (if applicable):

1. **NA**

2.

3.

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. NA CGI No. CGI-SNF-D-13-P5-031

Page 3 of 12

Title: ASHCROFT PRESSURE SWITCH - MONITOR FOR LOW SCHe
PURGE PRESSURE

D: Failure Mechanisms(s) and the effects on component or system safety function (see worksheet 1):

1. **Fracture of the switch body or of the piping connection - helium leakage from the SCHe System.**

2.

3.

4.

5.

Section 4 Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required:

Yes []

No [X]

Environmental Condition B

If yes: Environmental Qualification Requirements

Limiting Environmental Conditions:

Required Safety Functions:

Qualification Period:

Natural Phenomena Hazard (NPH) Design Required:

Yes [X]

No []

HNF-PRO-97, Rev. 0**W-441-P5, Rev. 2**

If yes: NPH Design Requirements

Performance Category: **PC-3**NPH Design Reqts.: **Seismic Condition B**Required Safety Functions: **Pressure Boundary Integrity**

Section 5 Component Functional Classification

[X] Safety Class (SC)

[] General Service

[] Safety Significant (SS)

If part/component classification is different from host component/system, document basis.

Section 6 [reserved]

Section 7 [reserved]

Section 8 References (for Functional Classification)

National Codes/Standards:

IEEE-344, ISA-S5.1, -S5.4, -S18.1, -S20

Safety Analysis Report (SAR):

HNF-SD-SNF-SAR-002, Rev. 4ADrawings: **H-1-82165, Rev. 2****HNF-SD-SNF-SEL-002, Rev. 4**
~~CVDF-SSD-003~~ *12/22/98*
*12/22/98*Vendor Manuals/Manufacturer/Supplier Information: **Ashcroft Instrument Division, L Series Switches, Bulletin SE-12**

Other:

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. **NA**CGI No. **CGI-SNF-D-13-PS-031**

Page 4 of 12

Title: **ASHCROFT PRESSURE SWITCH - MONITOR FOR LOW SCHe**
PURGE PRESSURE

Section 9 Critical Characteristics

Critical Characteristics Verification Document: Vendor Specifications, HNF-SD-SNF-SEL-002, Rev. 4	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Nameplate Data	Per Vendor Manual	1,IN	X	
Model Number	LPS-N4-K-S-25-15 PSI.	1,IN	X	
Manufacturer	Ashcroft Instruments	1,IN	X	
Process Connection	1/4 Inch FNPT, Bottom Mounted	1,IN	X	
Pressure Range	0-15 Psig	1,IN	X	
Enclosure	NEMA 4,4X	1,IN	X	
2. Physical Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Material, Body	Stainless Steel	1,T	X	
Material, Process Connection	Stainless Steel	1,T	X	
3. Performance Critical Characteristics (necessary & sufficient for reasonable assurance that the Item will perform its intended safety function(s))				
Pressure Boundary Integrity	No Leakage at Test Pressure of 165 Psig. Note 3.	1,T		X
Setpoint/Repeatability	NA			
Environmental	Note 1			
Seismic Condition B	Note 2	1,T		X
Switch Contact Rating	NA			
Insulation Resistance	NA			

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. NACGI No. CGI-SNF-D-13-P5-031

Page 5 of 12

Title: ASHCROFT PRESSURE SWITCH - MONITOR FOR LOW SCHE
PURGE PRESSURE

4. Notes and Legend:

1. The pressure switch is not subject to degradation at ambient conditions of 40°F and 60% RH or 115°F and 22% RH and is suitable for Environmental Condition B application.
2. Maintain pressure boundary after Seismic event.
W-441-P5, Rev. 2, Appendix I, page I-2, provides a seismic testing plan for these components at a seismic spectra TBD. "Confinement" leakage acceptance criteria is < 10-4 scc/sec.
3. Pressure test at 110% of system design pressure of 150 psig. Exposure to test pressure may seriously degrade the switch function. This test is considered to be a destructive test.

Acceptance Method:

1. Special Test and Inspection
1,I,N for Inspection
1,T for Test
2. Commercial Grade Survey
3. Source Verification
4. Vendor/Item History

Section 10 Initial Reviews and Approvals

Approvals:

Designated Engineer: *Edmund K. [Signature]* 12/22/98Design Authority: *Richard W. [Signature]* 12/21/98QA Engineer: *TD [Signature]* 12/22/98

Commercial Grade Item Upgrade Dedication Form

ECN No. NA CGI No. CGI-SNF-D-13-PS-031

Rev. No. 0

Page 6 of 12

Title: ASHCROFT PRESSURE SWITCH – MONITOR FOR LOW SCHePURGE PRESSURE

WORKSHEET 1

DETERMINATION OF FAILURE MECHANISMS/MODES

SECTION 1

Typical Failure Mechanisms	Definition	Applicable to Component under Evaluation
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.	Yes ☒ No ☐ ; If Yes, indicate failure Mode. <u>Failure of Transmitter Body or the Process Connection</u>
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.	Yes ☐ No ☒ ; If Yes, indicate failure Mode. _____
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.	Yes ☐ No ☒ ; If Yes, indicate failure Mode. _____
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.	Yes ☐ No ☒ ; If Yes, indicate failure Mode. _____
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	Yes ☐ No ☒ ; If Yes, indicate failure Mode. _____
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.	Yes ☐ No ☒ ; If Yes, indicate failure Mode. _____
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	Yes ☐ No ☒ ; If Yes, indicate failure Mode. _____
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.	Yes ☐ No ☒ ; If Yes, indicate failure Mode. _____
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.	Yes ☐ No ☒ ; If Yes, indicate failure Mode. _____
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.	Yes ☐ No ☒ ; If Yes, indicate failure Mode. _____
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.	Yes ☐ No ☒ ; If Yes, indicate failure Mode. _____
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.	Yes ☐ No ☒ ; If Yes, indicate failure Mode. _____

Section 2 Additional Failure Modes Applicable to the Component Under Evaluation

1. Process Connection/Body Break
2. _____

Commercial Grade Item Upgrade Dedication Form

ECN No. NACGI No. CGI-SNF-D-13-P5-031

Rev. No. 0

Page 7 of 12

Title: ASHCROFT PRESSURE SWITCH – MONITOR FOR LOW SCHe
PURGE PRESSURE

CHECKLIST 1

ACCEPTANCE METHOD 1

SPECIAL TEST/INSPECTION VERIFICATION

SECTION 1	
Item Description: Ashcroft Pressure Switch – Monitor For Low SCHe Purge Pressure System #: 13	Equip #: SCHe-PSL-5*06, 5*25, 5*45, 5*65 Model #: LPS-N4-K-S-25-15 PSI.
Manufacturer (Address/Phone): Ashcroft Instrument Division	Supplier (Address/Phone):
P.O. #	

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1

Insp	Test	Post-Test	
☒	☐	☐	1. Nameplate Data
☒	☐	☐	2. Model Number
☒	☐	☐	3. Manufacturer
☒	☐	☐	4. Process Connection
☒	☐	☐	5. Pressure Range
☒	☐	☐	6. Enclosure
☐	☒	☐	7. Material, Body
☐	☒	☐	8. Material, Process Connection
☐	☒	☐	9. Pressure Boundary Integrity
☐	☐	☐	10. Setpoint/Repeatability
☐	☒	☐	11. Seismic Condition B
☐	☐	☐	12. Switch Contact Rating
☐	☐	☐	13. Insulation Resistance

SECTION 3 BY INSPECTION

* See Attachment G of Desk Instruction for Sampling Size

Characteristic: **Nameplate Data**Sample Size*: **All Items**Acceptance Criteria: **Per Vendor Manual**

Receipt Inspection Plan / Report #: _____

References (see Section 7): **Ashcroft Instrument Division, L Series Switches, Bulletin Se-12**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. NA CGI No. CGI-SNF-D-13-P5-031

Page 8 of 12

Title: ASHCROFT PRESSURE SWITCH - MONITOR FOR LOW SCHE
PURGE PRESSURECharacteristic: **Model Number**Sample Size*: **All Items**Acceptance Criteria: **LPS-N4-K-S-25-15 PSI.**

Receipt Inspection Plan / Report #: _____

References (see Section 7): _____

Characteristic: **Manufacturer**Sample Size*: **All Items**Acceptance Criteria: **Ashcroft Instruments**

Receipt Inspection Plan / Report #: _____

References (see Section 7): _____

Characteristic: **Process Connection**Sample Size*: **All Items**Acceptance Criteria: **1/4 Inch FNPT, Bottom Mounted**

Receipt Inspection Plan / Report #: _____

References (see Section 7): _____

Characteristic: **Pressure Range**Sample Size*: **All Items**Acceptance Criteria: **0-15 PSIG**

Receipt Inspection Plan / Report #: _____

References (see Section 7): _____

Characteristic: **Enclosure**Sample Size*: **All Items**Acceptance Criteria: **NEMA 4,4X**

Receipt Inspection Plan / Report #: _____

References (see Section 7): _____

SECTION 4 BY SPECIAL TEST*** See Attachment G of Desk Instruction for Sampling Size**

Test To Be Performed by:

☐ Purchaser☐ Supplier/Manufacturer**☐ Other

Number of Items to be Tested:

Test/Inspection Location:

Characteristic for Test: **Material, Body**Acceptance Criteria: **Stainless Steel**Sample Size*: **Normal Sampling Size**

Actual Test Value:

Test Plan and Report #: _____ References (see Section 7): _____

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. NACGI No. CGI-SNF-D-13-P5-031

Page 9 of 12

Title: ASHCROFT PRESSURE SWITCH – MONITOR FOR LOW SCHe
PURGE PRESSURE

Characteristic for Test: **Material, Process Connection**Acceptance Criteria: **Stainless Steel**Sample Size*: **Normal Sampling Size**

Actual Test Value:

Test Plan and Report #: _____ References (see Section 7): _____

Characteristic for Test: **Pressure Boundary Integrity**Acceptance Criteria: **No Leakage at Test Pressure of 165 Psig**Sample Size*: **Destructively Test Only One Item**

Actual Test Value:

Test Plan and Report #: _____ References (see Section 7): _____

Characteristic for Test: **Seismic Condition B**Acceptance Criteria: **Maintain Pressure Boundary After Seismic Event. "Confinement" leakage acceptance criteria is < 10-4 scc/sec.**Sample Size*: **Normal Sampling Size**

Actual Test Value:

Test Plan and Report #: _____ References (see Section 7): _____

Characteristic for Test:

Acceptance Criteria:

Sample Size*:

Actual Test Value:

Test Plan and Report #: _____ References (see Section 7): _____

Characteristic for Test:

Acceptance Criteria:

Sample Size*:

Actual Test Value:

Test Plan and Report #: _____ References (see Section 7): _____

Characteristic for Test:

Acceptance Criteria:

Sample Size*:

Actual Test Value:

Test Plan and Report #: _____ References (see Section 7): _____

**If Supplier/Manufacturer or Other, Refer to CGI Checklist-2 for Support Information

Commercial Grade Item Upgrade Dedication Form

ECN No. NA

CGI No. CGI-SNF-D-13-PS-031

Title: ASHCROFT PRESSURE SWITCH – MONITOR FOR LOW SCHE
PURGE PRESSURE

Rev. No. 0

Page 10 of 12

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION:

Critical Characteristics				Verification Results							
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/IN	Procedure or RR#	Check- list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Nameplate Data	Per Vendor Manual	X									
Model Number	LPS-N4-K-S-25-15 PSI	X									
Manufacturer	Ashcroft Instruments	X									
PROCESS CONNECTION	1/4 Inch FNPT, Bottom Mounted	X									
Instrument Range	0-15 Psig	X									
Enclosure	NEMA 4, 4X	X									
Material, Body	Stainless Steel	X									
Material, Process Connection	Stainless Steel	X									
Switch Contact Rating	NA										
Insulation Resistance	NA										
Pressure Boundary Integrity	No Leakage at Test Pressure of 165 Psig.		X								
Set Point / Repeatability	NA										
Environmental	NA										
Seismic Condition B	Maintain Pressure Boundary		X								

Commercial Grade Item Upgrade Dedication Form

ECN No. NA

CGI No. CGI-SNF-D-13-P5-031

Title: ASHCROFT PRESSURE SWITCH - MONITOR FOR LOW SCHE
PURGE PRESSURE

Rev. No. 0

Page 11 of 12

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS	
Critical Characteristic	Disposition
3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.	
BUYER VERIFICATION	
Testing Agency Approval: _____ Date _____	Design Authority: _____ Date _____
Testing Agency QA Engineer: _____ Date _____	QA Engineer: _____ Date _____

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. NA CGI No. CGI-SNF-D-13-P5-031

Page 12 of 12

Title: ASHCROFT PRESSURE SWITCH – MONITOR FOR LOW SCHEPURGE PRESSURE

Section 6 Contacts/Phone Numbers

Name	Phone
Design Authority	()
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()

Section 7 Supporting Documentation for this Checklist

Initial Procurement Documents	For Critical Characteristics
☐ Drawings:	
☐ Manuals (specify type & number):	
☐ Design Calculations	
☐ Installation Instructions	
☐ Operation Instructions	
☐ Calibration Instructions	
☐ Manufacturer's Recommended Spare Parts List	
☐ Other:	
Procurement Documents	
☐ Certificate of Conformance/Compliance	
☐ Seismic Qualification Certificate	
☐ Environmental Qualification Certificate	
☐ Test Report (s):	
☐ Inspection Report (s):	
☐ CMTRs for ASME Pressure Retaining Materials	
☐ Valve Seat Leakage Report	
☐ Weld Records	
☐ Material Traceability Record	
☐ Other:	