ORNL/TM-1999/247

**OAK RIDGE
NATIONAL
LABORATORY**

**SCALE-4 Analysis of LaSalle
Unit 1 BWR Commercial
Reactor Critical
Configurations**

I. C. Gauld

MANAGED AND OPERATED BY
LOCKHEED MARTIN ENERGY RESEARCH CORPORATION
FOR THE UNITED STATES
DEPARTMENT OF ENERGY

Computational Physics and Engineering Division (10)

SCALE-4 Analysis of LaSalle Unit 1 BWR Commercial Reactor Critical Configurations

I. C. Gauld

Date Published: March 2000

Prepared by the
OAK RIDGE NATIONAL LABORATORY
Oak Ridge, Tennessee 37831
managed by
LOCKHEED MARTIN ENERGY RESEARCH CORP.
for the
U.S. DEPARTMENT OF ENERGY
under contract DE-AC05-96OR22464

CONTENTS

LIST OF FIGURES	v
LIST OF TABLES	vii
ABSTRACT	ix
1. INTRODUCTION	1
2. REACTOR DESCRIPTION	3
2.1. FUEL ASSEMBLY DESIGN DESCRIPTION	3
2.2. CONTROL BLADES	9
3. LASALLE UNIT 1 CRITICAL STATEPOINT DATA	13
3.1. REACTOR STATEPOINT CONDITIONS	13
3.2. FUEL ASSEMBLY CONFIGURATION	13
3.3. CONTROL CONFIGURATION	13
4. CRITICALITY ANALYSES	21
4.1. OVERVIEW OF THE METHODOLOGY	21
4.2. CODE VERSIONS AND COMPUTER PLATFORM	21
4.3. LS1 FUEL ASSEMBLY COMPOSITIONS	22
4.4. COMPOSITION DATA PROCESSING	22
4.5. CROSS-SECTION PROCESSING	23
4.6. GE8x8NB ASSEMBLY MODEL	24
4.7. LASALLE UNIT 1 REACTOR MODEL	26
4.8. SUMMARY OF KEY ANALYSIS APPROXIMATIONS	30
5. RESULTS AND DISCUSSION	31
6. CONCLUSIONS	35
7. REFERENCES	37
APPENDIX A: CSASI INPUT LISTING FOR ASSEMBLY C14, ZONE 4, SP11	41
APPENDIX B: GECKO FORTRAN UTILITY CODE LISTING	47
APPENDIX C: LS1K FORTRAN UTILITY CODE LISTING AND ASSEMBLY MAP	55
APPENDIX D: ABRIDGED KENO V.A INPUT LISTING FOR LS1 STATEPOINT CONFIGURATIONS	65

LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1.	GE8×8NB assemblies and control-cell arrangement	7
2.	GE8×8NB assembly axial section	8
3.	B ₄ C control-blade assembly	10
4.	LS1 reactor core structure and control-cell arrangement	11
5.	LS1 assembly locations for the Cycle 7 statepoint criticals	15
6.	LS1 assembly locations for the Cycle 8 statepoint criticals	16
7.	LS1 SP7 criticality control blade configuration	17
8.	LS1 SP8 criticality control blade configuration	17
9.	LS1 SP9 criticality control blade configuration	18
10.	LS1 SP10 criticality control blade configuration	18
11.	LS1 SP11 criticality control blade configuration	19
12.	KENO V.a GE8×8NB assembly model	25
13.	KENO V.a model of LS1 assembly group and control blades	27
14.	KENO V.a model of the LS1 SP11 critical configuration	28
15.	KENO3D visualization of the LaSalle Unit 1 Reactor – top view	29
16.	Calculated (k_c)-to-measured (k_m) k_{eff} values vs cycle burnup	33

LIST OF TABLES

<u>Table</u>		<u>Page</u>
1.	LaSalle Unit 1 fuel assembly and reactor data	4
2.	Fuel assembly descriptions for 10 axial nodes	5
3.	Fuel assembly cross-section properties	6
4.	Control blade specifications	9
5.	Statepoint criticality data	14
6.	Calculated k_{eff} for LS1 statepoints	32

ABSTRACT

Five commercial reactor criticals (CRCs) for the LaSalle Unit 1 boiling-water reactor have been analyzed using KENO V.a, the Monte Carlo criticality code of the SCALE 4 code system. The irradiated fuel assembly isotopics for the criticality analyses were provided by the Waste Package Design team at the Yucca Mountain Project in the United States, who performed the depletion calculations using the SAS2H sequence of SCALE 4. The reactor critical measurements involved two beginning-of-cycle and three middle-of-cycle configurations. The CRCs involved relatively low-cycle burnups, and therefore contained a relatively high gadolinium poison content in the reactor assemblies. This report summarizes the data and methods used in analyzing the critical configurations and assesses the sensitivity of the results to some of the modeling approximations used to represent the gadolinium poison distribution within the assemblies. The KENO V.a calculations, performed using the SCALE 44GROUPNDF5 ENDF/B-V cross-section library, yield predicted k_{eff} values within about 1% $\Delta k/k$ relative to reactor measurements for the five CRCs using general 8-pin and 9-pin heterogeneous gadolinium poison pin assembly models.

1. INTRODUCTION

As part of an ongoing program to develop and validate the criticality safety analysis methodology for the disposal of commercial spent nuclear fuel by the U.S. Department of Energy Office of Civilian Radioactive Waste Management (OCRWM), commercial reactor criticality (CRC) data for the LaSalle Unit 1 (LS1) boiling-water reactor (BWR) have been compiled to provide a database for code validation studies involving BWR-type fuel assemblies.¹

The critical reactor configurations for LS1 have been analyzed using the KENO V.a Monte Carlo criticality analysis code,² developed as part of the SCALE system.³ The reactor critical measurements were all performed following reactor shutdown, either at the beginning-of-cycle (BOC) or after a reactor trip during a cycle. The reactor conditions and state at the time the reactor first attains criticality is referred to as a statepoint (SP). These states involve zero-power conditions and are attained after sufficient cooling time to allow the fission product xenon inventory to decay. A total of five statepoints have been analyzed: two involving BOC conditions, and the remaining three involving a cycle burnup of less than 8000 MWd/MTU.

The GE8x8NB-type fuel assemblies in the LS1 reactor incorporate an integral burnable gadolinia (Gd_2O_3) poison in some of the fuel pins. The statepoint criticals were performed at BOC, or relatively low-cycle burnups, and consequently these measurements involved a significant number of reactor fuel assemblies with high concentrations of the burnable poison still present. The presence of gadolinium poison in the assemblies introduces a significant level of heterogeneity in the calculations. In addition, the critical statepoints were achieved with approximately 70% insertion of the boron carbide (B_4C) control blades in the core, making these highly heterogeneous critical configurations.

The primary objective of this report is to provide an independent criticality assessment of the LS1 statepoint criticals to verify previous analyses performed by the Yucca Mountain Project Waste Package Design team under OCRWM. The irradiated fuel assembly isotopics for the criticality analyses were obtained directly from the Waste Package Design team and served as a common reference point for the analyses. This report summarizes the calculated results obtained using KENO V.a, discusses the methods and approximations used in the criticality assessment model, and provides a brief discussion of the sensitivity of the criticality results to the methods and approximations used in representing the integrated burnable gadolinia rods in the assemblies.

2. REACTOR DESCRIPTION

LaSalle Unit 1 is a General Electric BWR with a rated power of 3323 MWt. Control of reactivity is accomplished in part by a combination of control blade movements and integral burnable gadolinia (Gd_2O_3) absorbers. The core has a total of 185 control blades. The reactor vessel internal shroud is a stainless steel cylinder, which surrounds the reactor core and serves as a barrier to separate the upward flow of the coolant through the reactor core from the downward flow of the coolant outside the core.

This section describes the general LS1 reactor design information relevant to the reactor configuration during the SP measurements and includes the fuel assembly design, control blade design, and fuel assembly compositions.

2.1. FUEL ASSEMBLY DESIGN DESCRIPTION

The LS1 reactor core contains 764 fuel assemblies. All fuel assemblies used in the LS1 reactor critical SP measurements were of the GE8×8NB (GE9)-type, designed and manufactured by General Electric. The assembly has ferrule-type spacer grids, a large-diameter central water rod that spans four fuel pin positions, axially zoned enrichment, and integral burnable gadolinia (Gd_2O_3) absorbers. Additionally, this fuel assembly has a 12-in. natural uranium blanket at the top of the assembly. The fuel assembly and fuel channel specifications are listed in Table 1. Figure 1 illustrates the GE8×8NB fuel-assembly and control-blade arrangement. Figure 2 illustrates some of the axial detail of the assembly.

The burnable gadolinia (Gd_2O_3) poison in the GE8×8NB fuel assemblies is integrated with the enriched uranium in a limited number (between 7 and 12) of assembly pins to reduce the reactivity of the fuel during the initial phase of reactor operation. In general, the effect of the gadolinium poison on k_{eff} is most significant during the initial 10 GWd/MTU of operation, after which the gadolinium absorber has been typically depleted to low concentrations.

The axially zoned enrichment of the fuel assemblies is approximated using 10 axial zones to represent the axial depletion effects. The height of each axial zone and fuel zone identifiers for each assembly type residing in the reactor during the critical measurements (Cycles 7 and 8) are listed in Table 2. The table provides composition identifiers or "cross sections" for each axial zone of the nine assembly types that resided in the reactor core during the five-statepoint measurements. These identifiers are used to cross reference the actual fuel zone compositions and configurations which are listed in Table 3. The assembly types, characterized by their unique axial enrichment and gadolinium poison pin arrangement, are referenced by number (1, 2, 4, 5, and 8-12) and also by alphanumeric designations (A-H, and J).

Table 1. LaSalle Unit 1 fuel assembly and reactor data

Description	Data
Fuel assembly array size and type	GE8×8NB (GE9B)
Number of fuel pins / assembly	60 (enriched axial zones) 48 – 60 (natural uranium axial end zones)
Number of water rods / assembly	1
Number of assemblies in core	764
Number of control blades in core	185
System pressure	1020 psia (7.03266 MPa)
Active fuel height (H)	381.00 cm
Pin pitch	1.6256 cm
Assembly pitch (P)	15.24 cm
Fuel pin cladding outer diameter (OD)	1.2268 cm
Fuel pin cladding inner diameter (ID)	1.06426 cm
Fuel pin clad thickness	0.08128 cm
Fuel pin cladding material	Zircaloy
Fuel pellet diameter	1.04394 cm
Fuel material	UO ₂
Water rod outside diameter	3.4036 cm
Water rod inside diameter	3.2004 cm
Water rod material	Zircaloy
Channel - inner width	13.4061 cm
- thickness Cycles 4–7	0.254 cm
- thickness Cycle 8	0.203 cm
Channel material	Zircaloy

Table 2. Fuel assembly descriptions for 10 axial zones

Cross-Section Reference Number by Zone										
Axial zone	Length (cm)	Type 8 (B) fuel	Type 9 (A) fuel	Type 10 (C) fuel	Type 11 (D) fuel	Type 12 (E) fuel	Type 1 (G) fuel	Type 2 (F) fuel	Type 4 (J) fuel	Type 5 (H) fuel
10 (Top)	15.24	106	100	112	127	122	117	145	145	139
9	15.24	107	101	113	128	123	150	134	146	140
8	45.72	108	102	114	129	124	118	135	147	141
7	45.72	109	103	115	130	125	119	136	148	142
6	45.72	110	104	115	131	126	120	137	149	143
5	45.72	110	104	115	131	126	120	137	149	143
4	45.72	110	104	115	131	126	120	137	149	143
3	60.96	111	105	116	132	124	121	138	147	144
2	45.72	111	105	116	132	124	121	138	147	144
1 (Bottom)	15.24	107	101	113	128	123	150	134	146	140
Total	381.0									

Table 3. Fuel assembly cross-section properties

Cross section ID	Number of fuel pins	Average enrichment (wt % ²³⁵ U)	Number of gadolinia pins	Gadolinia enrichment (wt %)	Channel thickness (in.)
100	48	0.71	0	0	0.100
101	60	0.71	0	0	0.100
102	60	3.50	4 / 6	5.0 / 4.0	0.100
103	60	3.65	6 / 6	5.0 / 4.0	0.100
104	60	3.65	4 / 6	5.0 / 4.0	0.100
105	60	3.50	7 / 3	5.0 / 4.0	0.100
106	49	0.71	0	0	0.100
107	60	0.71	0	0	0.100
108	60	3.23	9	3.0	0.100
109	60	3.37	2 / 9	4.0 / 3.0	0.100
110	60	3.37	9	3.0	0.100
111	60	3.23	5 / 4	4 / 3	0.100
112	51	0.71	0	0	0.100
113	60	0.71	0	0	0.100
114	60	3.27	4 / 5	5.0 / 4.0	0.100
115	60	3.38	4 / 5	5.0 / 4.0	0.100
116	60	3.27	9	5.0	0.100
117	49	0.71	0	0	0.100
150	60	0.71	0	0	0.100
118	60	3.45	9	4.0	0.100
119	60	3.62	2 / 9	5.0 / 4.0	0.100
120	60	3.62	9	4.0	0.100
121	60	3.45	5 / 4	5.0 / 4.0	0.100
122	51	0.71	0	0	0.100
123	60	0.71	0	0	0.100
124	60	3.39	7	4.0	0.100
125	60	3.50	9	4.0	0.100
126	60	3.50	7	4.0	0.100
127	51	0.71	0	0	0.100
128	60	0.71	0	0	0.100
129	60	3.39	2 / 5	4.0 / 3.0	0.100
130	60	3.50	4 / 5	4.0 / 3.0	0.100
131	60	3.50	2 / 5	4.0 / 3.0	0.100
132	60	3.39	7	4.0	0.100
133	51	0.71	0	0	0.100
134	60	0.71	0	0	0.100
135	60	3.46	7	4.0	0.100
136	60	3.58	2 / 7	5.0 / 4.0	0.100
137	60	3.58	7	4.0	0.100
138	60	3.46	4 / 3	5.0 / 4.0	0.100
139	50	0.71	0	0	0.080
140	60	0.71	0	0	0.080
141	60	3.63	8	4.0	0.080
142	60	3.88	2 / 8	5.0 / 4.0	0.080
143	60	3.88	8	4.0	0.080
144	60	3.63	8	5.0	0.080
145	48	0.71	0	0	0.080
146	60	0.71	0	0	0.080
147	60	3.63	10	5.0	0.080
148	60	3.90	12	5.0	0.080
149	60	3.90	10	5.0	0.080

Fig. 1. GE8x8NB assemblies and control blade arrangement.

Fig. 2. GE8x8NB assembly axial section.

2.2. CONTROL BLADES

The control blades used in LS1 during the statepoint criticals are bottom-entry blades having a cruciform shape (see Fig. 1). Each control blade has 84 stainless steel tubes containing B₄C as the active absorbing material. The reactor contains a total of 185 control blades, sufficient to cover most of the assembly groups (4 assemblies) in the core. The control-blade specifications were obtained from EPRI Report NP-240 (ref. 4) and are listed in Table 4. The control-blade design is shown in Fig. 3, and the arrangement of the blades with respect to the reactor core (bottom entry) is shown in Fig. 4.

In general, criticality is achieved with about 70 to 75% blade insertion (i.e., 25 to 30% of the blades withdrawn) for the cold critical conditions of the statepoint measurements. During full-power operation, however, significantly fewer control blades are required due to the changes in reactor conditions.

Table 4. Control blade specifications

Parameter	Specification
Shape	Cruciform
Structural material	SS-304
Control material	B ₄ C in SS-304 tubes
B ₄ C density (g/cm ³)	70.6% theoretical density = 1.78 g/cm ³ (0.706 × 2.52 g/cm ³)
Boron isotopic distribution	Natural abundance ¹⁰ B (18.431 wt %), ¹¹ B (81.569 wt %)
Active control length (cm)	363.2
Number of tubes per control blade group	84 (21 per individual blade)
Inner diameter of B ₄ C tubes (mm)	3.505
Outside diameter of tube sheath (mm)	4.775
Control blade full thickness (mm)	7.925
Control blade full span – from center (mm)	123.83
Control blade sheath thickness (mm)	1.422
Control blade inner thickness (mm)	5.081
Control blade inside length (mm)	102.55

Fig. 3. B₄C control-blade assembly.

Fig. 4. LS1 reactor core structure and control-blade arrangement.

3. LASALLE UNIT 1 CRITICAL STATEPOINT DATA

A reactor SP is defined as a point at which a reactor first achieves criticality during the startup (e.g., the critical state at the BOC or a restart during cycle operation). For restarts, these points are obtained after sufficient time following a reactor trip to allow the transient fission product xenon poison to decay. The reactor is considered to be at zero power at the statepoint, and thus there is no appreciable buildup of short-lived fission products associated with normal reactor operation. The reactor coolant temperature at the statepoints, and therefore the density, is also more closely associated with cold conditions than normal operating conditions.

3.1. REACTOR STATEPOINT CONDITIONS

This report assesses five reactor statepoints measured for the LS1 reactor. The SP data include the BOC of Cycle 7, two restarts during Cycle 7, the BOC for Cycle 8, and one restart during Cycle 8. A summary of the measured reactor conditions at each of the five reactor statepoints (designated SP7 – SP11) is provided in Table 5. The cycle number, the effective full-power days (EFPDs) during the cycle at which the startup occurred, the elapsed time since the reactor was shutdown, moderator temperature, and measured neutron multiplication factor (slightly supercritical based on the reactor period at the time of the statepoint), are provided for each statepoint.

3.2. FUEL ASSEMBLY CONFIGURATION

The LS1 reactor core contains a total of 764 fuel assemblies. The core loading configuration is approximately eighth-core symmetric, in general, because the control blades are moved in eighth-core symmetry. The analysis applied core symmetry to reduce the number of assemblies required for the depletion calculations from 764 to 119 assemblies for the Cycle 7 statepoints, and 116 assemblies for the Cycle 8 statepoints. The LS1 assembly configuration for the Cycle 7 statepoint criticals is shown in Fig. 5, and the configuration for the Cycle 8 statepoints is shown in Fig. 6. The nonsymmetric assemblies are shown explicitly in the quarter-core layout in the figures. The assembly sites shown in these figures with no assembly designation are eighth-core symmetric. The assembly types for each alphanumeric designation are defined in Table 2.

3.3. CONTROL CONFIGURATION

Figures 7 through 11 provide the LS1 core maps with the control blade group positions for each statepoint. Each box in the figures represents a control blade site (see Fig. 1) that includes four fuel assemblies.

The control blade positions in these figures are given in units of “notches” withdrawn. A notch represents 7.62 cm (3 in.) of blade movement. A “0” in a control blade site indicates the blade is fully inserted (from the bottom), with the bottom of the blade aligned with the bottom of the active fuel assembly. A total of 48 notch positions represent 365.8 cm; of axial control blade

coverage. The total active fuel length is 381.0 cm; therefore, with the blades fully inserted, the upper 15.2 cm of the fuel is not bladed. This portion of the GE8×8NB assemblies contains only natural enrichment uranium fuel. A control blade at position 20 indicates the blades are withdrawn, or lowered, 20 notches (152.4 cm) below the fully inserted position. A double-dash "--" in a control blade site represents a blade that is fully withdrawn. In general, about 140 of the 185 total control blades are fully inserted in the core at statepoint criticality.

Table 5. Statepoint criticality data

State point	Cycle	Criticality date (m/d/y)	Burnup (MWd/MTU)	EFPD	Down time (h)	k_{eff}^a	Moderator temperature (K)	Reactor period (s)
SP7	7	06/24/94	0.00	0.00	3024	1.00584	330.2	147
SP8	7	02/14/95	4728.4	193.20	120	1.00519	369.3	166
SP9	7	06/17/95	7507.28	306.75	140	1.00875	378.4	420
SP10	8	04/21/96	0.00	0.00	2064	1.00605	342.5	130
SP11	8	05/16/96	89.8	3.67	120	1.00574	351.2	327

^a k_{eff} determined from the measured reactor period.

j =	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
i = 16	C17 10	G15 1	D8 11	C19 10	C5 10	G16 1	D10 11	C25 10	C20 10	F17 2	C30 10	F18 2	D7 11	C29 10	A11 9
17		B10 8	G11 1	D5 11	G12 1	C7 10	G13 1	E8 12	G14 1	C23 10	F15 2	F16 2	C26 10	E9 12	A5 9
18	D1 11	G7 1	B2 8	G8 1	C27 10	G9 1	C6 10	G10 1	D9 11	F13 2	A6 9	F14 2	D19 11	D11 11	A12 9
19		D3 11	G4 1	C18 10	E12 12	E3 12	G5 1	D21 11	C15 10	G6 1	F12 2	C16 10	D17 11	E6 12	A8 9
20					C10 10	G3 1	E10 12	C24 10	E1 12	C1 10	F11 2	C9 10	D14 11	C21 10	B7 8
21						C11 10	F8 2	C12 10	F9 2	G2 1	F10 2	D15 11	E4 12	A1 9	B3 8
22					E5 12	F5 2	C13 10	F6 2	D20 11	F7 2	A4 9	D13 11	A3 9	A7 9	B9 8
23			G1 1			C3 10		D16 11	C28 10	D6 11	D18 11	C8 10	A9 9	B4 8	
24								C22 10	C2 10	E11 12	A2 9	C14 10	B5 8		
25			F4 2						E7 11	D12 11	A10 9	B1 8	B8 8		
26				F2 2		F3 2		D4 11				B6 8			
27	F1 2							C4 10							
28					D2 11	E2 12									
29															
30															

Fi
N

 Fuel Assembly Designation (Fi and Gi are fresh fuel assemblies in Cycle 7)
 Fuel Type (Types 1 and 2 are fresh fuel assemblies in Cycle 7)

Fig. 5. LS1 assembly locations for the Cycle 7 statepoint criticals.

j =	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30
i = 16	D4 11	H18 5	F3 2	D13 11	E6 12	J5 4	F17 2	E9 12	D15 11	J11 4	F6 2	F2 2	D10 11	E5 12	C4 10
17		D16 11	J6 4	G7 1	J12 4	F7 2	J4 4	F1 2	H10 5	E7 12	J10 4	H6 5	H7 5	E1 12	C5 10
18	F10 2		F4 2	H9 5	G12 1	J8 4	F14 2	J9 4	G14 1	H16 5	F16 2	H12 5	F15 2	D7 11	C2 10
19		G11 1		D12 11	D2 11	G15 1	J2 4	D3 11	E2 12	G5 1	H15 5	G9 1	D19 11	D21 11	C19 10
20				D14 11	G1 1	J13 4	G6 1	D11 11	G3 1	J7 4	H1 5	D20 11	D6 11	D9 11	C29 10
21						G10 1	H5 5	G4 1	J1 4	H2 5	C14 10	H11 5	F9 2	E8 12	C25 10
22							D8 11	J3 4	H13 5	G2 1	H17 5	H3 5	G16 1	E3 12	C1 10
23		F18 2		D5 11		G8 1		D18 11	D17 11	H8 5	H14 5	H4 5	E12 12	C26 10	
24				E4 12					D1 11	F11 2	G13 1	F5 2	C3 10		
25		E11 12								F13 2	C21 10	C27 10	C22 10		
26											C9 10				
27	F12 2								F8 2						
28									C12 10	C28 10					
29	E10 12														
30	C8 10			C17 10											

Fi
N

Fuel Assembly Designation (Hi and Ji are fresh fuel assemblies in Cycle 8)
Fuel Type (Types 4 and 5 are fresh fuel assemblies in Cycle 8)

Fig. 6. LS1 assembly locations for the Cycle 8 statepoint criticals.

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59					0	0	0	0	0	0	0					59
55				0	-	0	-	0	18	0	-	0				55
51			0	0	0	0	0	0	0	0	0	0	0			51
47		0	-	0	0	0	-	0	-	0	0	0	-	0		47
43	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	43
39	-	0	0	0	-	0	0	0	0	0	-	0	0	0	-	39
35	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	35
31	-	0	-	0	0	0	-	0	-	0	0	0	-	0	-	31
27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	27
23	-	0	0	0	-	0	0	0	0	0	-	0	0	0	-	23
19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	19
15		0	-	0	0	0	-	0	-	0	0	0	-	0		15
11			0	0	0	0	0	0	0	0	0	0	0			11
7				0	-	0	-	0	0	0	-	0				7
3					0	0	0	0	0	0	0					3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	

Fig. 7. LS1 SP7 criticality control-blade configuration.

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59					0	0	0	0	0	0	0					59
55				0	-	0	-	0	-	0	-	0				55
51			0	0	0	0	0	0	0	0	0	0	0			51
47		0	-	0	22	0	-	0	-	0	0	0	-	0		47
43	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	43
39	-	0	0	0	-	0	0	0	0	0	-	0	0	0	-	39
35	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	35
31	-	0	-	0	0	0	-	0	-	0	0	0	-	0	-	31
27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	27
23	-	0	0	0	-	0	0	0	0	0	-	0	0	0	-	23
19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	19
15		0	-	0	0	0	-	0	-	0	0	0	-	0		15
11			0	0	0	0	0	0	0	0	0	0	0			11
7				0	-	0	-	0	-	0	-	0				7
3					0	0	0	0	0	0	0					3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	

Fig. 8. LS1 SP8 criticality control-blade configuration.

Fig. 9. LS1 SP9 criticality control-blade configuration.

Fig. 10. LS1 SP10 criticality control-blade configuration.

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59					0	0	0	0	0	0	0					59
55				0	--	0	--	0	--	0	--	0				55
51			0	0	0	0	0	0	0	0	0	0	0			51
47		0	--	0	--	0	--	0	--	0	--	0	--	0		47
43	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	43
39	--	0	--	0	--	0	--	0	0	0	--	0	--	0	--	39
35	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	35
31	--	0	--	0	--	0	--	0	--	0	--	0	--	0	--	31
27	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	27
23	--	0	--	0	--	0	20	0	0	0	--	0	--	0	--	23
19	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	19
15		0	--	0	--	0	--	0	--	0	--	0	--	0		15
11			0	0	0	0	0	0	0	0	0	0	0			11
7				0	--	0	--	0	--	0	--	0				7
3					0	0	0	0	0	0	0					3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	

Fig. 11. LS1 SP11 criticality control-blade configuration.

4. CRITICALITY ANALYSES

This section discusses the KENO V.a criticality analysis models, fuel assembly composition data processing, cross-section processing, and the approximations used in the criticality analysis of the LS1 statepoint critical configurations.

4.1. OVERVIEW OF THE METHODOLOGY

The reactor criticality analyses were performed using a full-core model of the LS1 reactor with the Monte Carlo criticality code KENO V.a and the 44GROUPNDF5 cross-section library.⁵ The quasi eighth-core symmetry applied in the calculation of the irradiated fuel assembly compositions was also applied in the criticality calculations. This method reduced the number of unique assemblies from 764 to 119 for the Cycle 7 criticals, and 116 for the Cycle 8 criticals. The axial burnup variation of the assemblies was represented using 10 axial zones. Each criticality calculation therefore involved approximately 1200 unique-composition assembly zones.

Irradiated fuel compositions were not calculated as part of this study, but were generated by the Yucca Mountain Project Waste Package Design team.⁶ The depletion calculations were made using the SAS2H sequence of the SCALE 4 code system. These calculations followed the complete irradiation history for the assemblies that resided in the core for each of the SP measurements, during all cycles leading up to the measurements. The composition data were transmitted as data files consisting mainly of ORIGEN-S output for each fuel zone of each assembly.

The criticality analysis methodology involved the following steps:

1. obtaining the irradiated fuel assembly nuclide compositions from the data files,
2. processing the data into units and formats suitable for input to the SCALE Material Information Processor routines,
3. generating cross sections for each assembly axial zone based on the zone compositions and geometry using the Critical Safety Analysis Sequence CSASI,
4. preparing the KENO V.a full-core model based on the assembly locations and control blade configurations for the statepoints, and
5. using the KENO V.a model to calculate the effective multiplication factor k_{eff} for the system, and compare the results against the measured value.

4.2. CODE VERSIONS AND COMPUTER PLATFORM

The cross-section processing and criticality calculations were performed using the SCALE 4.4 code system, run on a DEC Alpha Workstation. Cross-section processing was performed using CSASI, version 4.3, and criticality calculations were performed using KENO V.a, version 4.1.

4.3. LS1 FUEL ASSEMBLY COMPOSITIONS

The fuel assembly compositions for each axial zone of the unirradiated fuel assemblies in the BOC critical configurations (SP7 and SP10) were obtained from the assembly composition data in Tables 2 and 3. All other assembly compositions were obtained from ref. 6.

The assembly locations in the Cycles 7 and 8 statepoint criticals are shown in the quarter-core layout in Figs. 5 and 6, respectively. The Cycle 7 core had 208 fresh fuel assemblies of type F and G; the Cycle 8 core had 248 fresh assemblies of type H and J. The assembly sites in these figures that have no assembly designation are symmetric in the one-eighth core. The nonsymmetric assemblies are shown in the lower quadrant of the core layout and were explicitly represented in the criticality model. Even though the reactor is quarter-core assembly symmetric, the KENO V.a model used in the analyses was based on a full-core representation in order to accurately capture the nonsymmetric control blade configuration.

4.4. COMPOSITION DATA PROCESSING

The irradiated fuel compositions⁶ were calculated by ORIGEN-S and archived primarily as the SAS2H⁷ input and ORIGEN-S⁸ output files, for each axial fuel zone of each fuel assembly. These files were processed as part of this work to extract the inventories into a format suitable for input to CSASI⁹ cross-section processing sequence and ultimately for use the criticality calculation using KENO V.a.

The mass (gram) inventories from the ORIGEN-S calculations were extracted from the output files and processed into atomic number densities using a utility code GECKO (Get Compositions for KENO from ORIGEN) written for this analysis, which automatically determined the total fuel volume for the case from the number of pins per assembly, the active fuel length, and fuel pin diameter. A listing of this utility is provided in Appendix B. The gram inventories represent the average compositions over all fuel pins, including any integrated burnable poison pins in the assembly. The gram quantities (M) were converted to atom density (ADEN) in units of atoms/(b-cm) using the equation

$$ADEN = \frac{M \times 0.60225}{AWT \times V},$$

where AWT is the atomic weight for the nuclide, and V is the total fuel volume. A limitation in obtaining the assembly inventories from the ORIGEN-S output files is that the inventories are printed to only two significant figures. This factor could potentially result in an error in composition specification of up to 0.5% for a given nuclide due to roundoff. For a fissile actinide such as ²³⁵U, this could result in an error in the neutron multiplication factor, where the calculational biases are typically at the percent level. It is recommended that either the binary ORIGEN-S composition interface, or the SAS2H card-image interface, be used in future assessments to store fuel compositions.

Since the number of nuclides in the ORIGEN-S nuclear database is much larger than that in the 44GROUPNDF5 cross-section library used with KENO V.a, automated selection criteria were applied during the processing. The criteria used by GECKO to select the actinide and fission product nuclides from the ORIGEN-S output were:

1. the nuclide must reside on the 44GROUPNDF5 cross-section library, and
2. the atomic number density must be greater than 10^{-8} atoms/(b-cm).

For the light-element tables, only gadolinium and europium (decay product) were selected. The burnable poisons are tracked by ORIGEN-S in the SAS2H depletion analysis as light elements, which allows the burnable-poison inventory to be determined separately from fission products for regions containing both burnable poison and fissionable material. This method has a particular importance to BWR-type CRC analyses in that it allows the burnable poison inventory to be determined separately from the fission product gadolinium, and distributed heterogeneously in only the gadolinium poison pins, allowing a more detailed assembly representation for the criticality calculations. To obtain the correct concentrations in the burnable poison rods the volume (V) used to derive the number densities must be adjusted to include only the poison rods.

The initial concentration of oxygen (as ^{16}O in the fuel) was not available from the ORIGEN-S output since it was omitted as a light-element input specification in the SAS2H input. The oxygen was therefore added automatically to each case by the GECKO utility at a fixed nominal atomic number density of 4.5497×10^{-2} atoms/b-cm.

The water-moderator density for each of the statepoints was based on the statepoint temperatures listed in Table 5 by interpolating on standard density tables for a system pressure of 1000 psia. The moderator densities for the SP7 – SP11 analyses were 0.9882, 0.9649, 0.9583, 0.9818, and 0.9768 g/cm³, respectively.

4.5. CROSS-SECTION PROCESSING

Neutron cross sections for the criticality analyses were obtained from the SCALE 44GROUPNDF5 library, a 44-group neutron cross-section library based on ENDF/B-V data, with ENDF/B-VI evaluations for ^{16}O , ^{154}Eu , and ^{155}Eu . The 44GROUPNDF5 library was developed specifically for criticality safety calculations involving LWR fuel.

The cross sections were processed for the KENO V.a criticality analyses using the Criticality Safety Analysis Sequence CSASI, a control sequence within the CSAS4 control module of SCALE. The CSASI sequence uses the BONAMI code to apply the Bondarenko resonance self-shielding method for nuclides with Bondarenko data; it then invokes NITAWL-II to perform Nordheim resolved resonance self-shielding corrections using the specified problem-dependent temperature. The microscopic cross sections for the nuclides in each mixture are subsequently combined in CSASI using the ICE module of SCALE to create a macroscopic cross section for each mixture. This step reduced significantly the number of cross sections handled by KENO V.a for a statepoint calculation.

For each statepoint calculation, approximately 1200 sequential CSASI runs (BONAMI/NITAWL-II/ICE) were performed to generate the macroscopic cross sections for

each assembly zone. The macroscopic cross sections incorporate the number densities and temperature for each fuel zone, and therefore no composition specifications were required in the KENO V.a case. Following each CSASI run, the WAX utility module was run to assign a unique cross-section identifier to the set based on the assembly ID (e.g., D4, J12, etc.) and axial position, and then append the cross section to a working library to build a single set of cross sections required for the criticality problem.

During the cross-section library processing, an undocumented array dimensional limit was exceeded in WAX, requiring a fix in WAX to handle up to the approximately 2400 cross-section sets needed for the heterogeneous assembly statepoint calculations. A typical CSASI input case, generated by the GECKO utility code, is listed in Appendix A. The GECKO code listing is given in Appendix B.

4.6. GE8×8NB ASSEMBLY MODEL

The GE8×8NB assemblies were assumed to have 60 pins in each axial fuel zone in the KENO V.a model. The natural enrichment uranium zones at each end of the assemblies actually contained between 48 and 60 pins. For these zones the number densities of the fuel were adjusted in order to conserve the total mass of the zone (for fuel zones with less than 60 pins). The actinide and fission product number densities within each zone were assumed to be spatially uniform over all assembly pins, and over the axial zone length.

The gadolinium poison was represented using two different assembly models, one that homogenized the poison in all of the assembly pins, and the other that explicitly represented the burnable poison pins in the assembly. In the homogeneous model, the gadolinium poison was simply distributed uniformly over all 60 pins of the fuel assembly.

In the heterogeneous model the gadolinium poison was placed in a limited number of pins as $\text{UO}_2/\text{Gd}_2\text{O}_3$ pins. The actual number of gadolinia pins per assembly axial zone is provided in Table 3, and ranges from 7 to 12 pins per assembly. However, the exact configuration of the pins in the assembly is proprietary information and was not available to ORNL. For the purposes of this study, the discrete pin model assumed 8 gadolinia pins per assembly in the criticality calculations. The pins were distributed symmetrically in the central ring of fuel pins, near the four corners of the assembly, as shown in Fig. 12. Although this is not the actual pin configuration, this model is assumed to be generally representative of BWR assemblies and sufficient to assess the importance of a heterogeneous poison pin representation for CRC calculations involving gadolinium poison-bearing assemblies.

The number densities of the gadolinium poison isotopes (and europium decay daughters) were calculated by GECKO using an assembly volume based on 8 poison pins per assembly for the heterogeneous assembly model.

The assembly fuel pin spacer grids were not included in the KENO V.a model since there was insufficient design information available to include them. The Zircaloy channels were modeled with a single thickness of 0.203 cm (0.08 in.), corresponding to the thickness of the Cycle 8 fuel assemblies.

Fig. 12. KENO V.a GE8x8NB assembly model.

4.7. LASALLE UNIT 1 REACTOR MODEL

A KENO V.a full-core model of the LS1 reactor model was developed using the 10-axial-zone assembly representation adopted in the previous analyses.¹ The reactor model explicitly represented the 764 fuel assemblies in the core, plus the approximately 140 control blades inserted into the core during the critical measurements. The quasi eighth-core symmetry reduced the number of unique assembly zones (compositions) in the model to about 1200. For calculations that explicitly represented the burnable gadolinium pins in the assembly (8 pins per assembly), two mixtures per axial fuel zone were required – one for the UO_2 pins; the second, for the $\text{UO}_2 / \text{Gd}_2\text{O}_3$ pins.

Each assembly axial zone was modeled using 10 units in the KENO V.a model, resulting in a total of about 12,000 units to define the unique assemblies for the problem. In addition, each assembly required 6 array entries to define the fuel pin arrangements, or about 7,000 arrays for the problem. A utility code, LS1K, was written to automate the preparation of the mixture, geometry, and array data blocks for the KENO V.a input. An assembly map with the assembly locations for each statepoint is required by the LS1K utility. The LS1K utility code listing and the assembly map for Cycle 8 are provided in Appendix C.

After constructing the 10 units representing the 10 axial zones of an assembly, the units were stacked in a vertical array to form the complete assembly unit having a length of 381.0 cm. The assembly interstitial water (see Fig. 12) was modeled with units that spanned the full active length of the complete assembly (381.0 cm). The control blades were constructed with five units each, one for each blade, and one unit at the center of the cruciform. The 21 B_4C rods in each control blade were modeled explicitly in the control blade models. Two control blade models were assembled – one to represent the fully inserted control blades; the other, to represent the single critical height control blade. An assessment of the impact of approximating the B_4C rods as a homogeneous mixture (with steel tube sheath and water) within the control blades indicated that homogenization resulted in about a 1% decrease in the k_{eff} compared to explicitly modeling the B_4C rods. A cross-section illustration of the KENO V.a assembly group and control blade model is shown in Fig. 13.

After each unique assembly unit and the interstitial water units were defined, the core configuration was assembled as a 59×59 unit array using the assembly configurations for the respective cycles (see Figs. 5 and 6). Thirty of the 59 row (and column) positions in the array contain the assembly units, with the remaining 29 units in each assembly row (or column) representing the water units between the assemblies. Between each of the 30 rows containing the assembly units were units containing the interstitial water. The control blade units were subsequently added to the array based on the control blade patterns for each critical statepoint (see Figs. 7 through 11). An abridged KENO V.a model input listed for the Cycle 8 SP11 critical configuration is provided in Appendix D. The total size of the full-core model is about 70,000 lines (not all lines are included in listing). A section view of the reactor core for the Cycle 8 SP11 critical configuration is illustrated in Fig. 14 showing the control blade configuration at a core elevation of 100 cm. A subsection of the KENO V.a core model, obtained using the KENO3D geometry visualization program, is illustrated in Fig. 15.

The region surrounding the reactor core was not modeled in detail. Due to the large physical size of the reactor core (4.6-m diam), only about 0.5% of the neutrons leak from the system, and therefore a detailed treatment to accurately model the reflection from the out-of-core components was not warranted for this analysis. For the criticality analysis, the reactor core was surrounded by 30 cm of water to approximate the reflection conditions close to the core.

Fig. 13. KENO V.a model of LS1 assembly group and control blades.

Fig. 14. KENO V.a model of the LS1 SP11 critical configuration.

Fig. 15. KENO3D visualization of the LaSalle Unit 1 Reactor – top view.

4.8. SUMMARY OF KEY ANALYSIS APPROXIMATIONS

The key analysis assumptions and modeling approximations in the KENO V.a criticality analysis of the LS1 statepoints are summarized in this section. Since the fuel irradiated compositions were not calculated as part of this work, the approximations and uncertainties do not extend to the depletion analysis methodology. Only the assumptions in the criticality analysis are summarized here. The key modeling assumptions are the following:

1. all assemblies contain 60 pins for all axial zones (assembly mass conserved),
2. the gadolinium poison pins in the enriched uranium assemblies were approximated using a discrete symmetric 8-pin arrangement (see Fig. 12) in all assemblies, and also an homogenized (60-pin) arrangement,
3. uniform actinide and fission product concentrations in all assembly fuel zones (no correction for control blade or gadolinium poison perturbations on fuel compositions),
4. uniform oxygen (as ^{16}O) concentrations were assumed for all assemblies,
5. fuel assembly pin spacer grids and end region details were not modeled,
6. reactor core reflection was approximated by thick water reflection,
7. channel thickness for the assemblies H and J (see Table 3) were assumed to be the same as earlier cycles (assemblies A – K),
8. quarter-core (quasi eight-core) symmetry, and
9. ten axial burnup zones.

5. RESULTS AND DISCUSSION

The neutron multiplication factors (k_{eff}) calculated by KENO V.a for each of the five statepoint critical configurations are listed in Table 6. These results are compared against the known k_{eff} values.*

The KENO V.a results are based on 500 generations of 1000 particles per generation, for a total of 500,000 particle histories. The criticality analysis execution time was about 20 minutes CPU time on the DEC Alpha workstation.

The criticality calculations performed using the homogenized model for the gadolinium poison in the assemblies demonstrate that distributing the poison uniformly in all fuel pins results in a substantial underprediction in the system k_{eff} for most statepoints. The degree of underprediction is most pronounced in the Cycle 8 statepoints, which have a high initial gadolinium poison loading compared with the Cycle 7 statepoints, due to a larger number of fresh assemblies in the BOC core (248 compared to 208) and the higher gadolinium enrichment in the Cycle 8 fresh assemblies. The SP9 measurement, performed at a Cycle 7 burnup of about 8000 MWd/MTU, is accurately predicted by the homogeneous model likely due to the substantial depletion of the initial gadolinium poison loading in the core.

The criticality calculations performed using a heterogeneous symmetric 8-Gd-pin model resulted in a significant improvement in the predicted k_{eff} . For the middle-of-cycle (MOC) statepoints SP8 and SP9, the predicted k_{eff} value is within 1% $\Delta k/k$ of measurement. For the BOC and low-cycle-burnup statepoints SP7, SP10, and SP11, which will have the highest gadolinium poison concentrations, the KENO V.a results are overpredicting by between 1 and 2.3% $\Delta k/k$.

The discrete gadolinium poison pins were modeled using an 8-pin assembly approximation (Fig. 12) since the actual pin arrangement is proprietary information. The 8-pin configuration was easily implemented due to the assembly symmetry and the number of Gadolinium pins is close to the actual number of pins based on an average over the assemblies in the reactor core. If the average number of gadolinium poison pins is calculated based on the fresh assemblies in the BOC cores (where the majority of the gadolinium poison resides), then the effective average number of pins is estimated to be about 8.3 pins, based on the 208 fresh F- and G-type assemblies in Cycle 7, and about 9.1 pins per assembly based on the 248 fresh H- and J-type assemblies in Cycle 8. The use of 8 pins per assembly in the criticality analysis model, although close to the Cycle 7 average, is less than the average for the Cycle 8 statepoints, and may potentially result in an under-representation of the gadolinium worth in the assemblies.

A detailed assessment of the applicability of using an average number of poison pins to represent all assemblies in the core is beyond the scope of this report. In addition, this report has not addressed the effect of the poison pin arrangement in the assembly compared with the actual assembly arrangements because the assembly configurations are proprietary. Poison pins located

* Note that the actual k_{eff} for the statepoint is slightly greater than 1, as determined from the reactor period at the statepoint reactor configuration.

in the inner region of the assembly will have a different associated worth compared with pins located near the outer edge of the assembly. Similarly, the pin locations relative to the control blades may also be important.

An additional set of KENO V.a calculations were performed using a 9-pin gadolinium poison pin model, with the additional pin located in the outer ring of pins in the assembly. These calculations were performed for the Cycle 8 statepoints SP10 and SP11 only, because the average number of pins in the Cycle 7 assemblies was closer to 8 pins. The results are plotted in Fig. 16 with the previous results. The two Cycle 8 statepoints are substantially improved with the 9-pin assembly model. The k_{eff} values, which showed a 2% discrepancy using the 8-pin representation, are predicted to within about 1% using the 9-pin approximation, indicating a significant degree of sensitivity to the average number of poison pins associated with the assemblies.

Table 6. Calculated k_{eff} for LS1 statepoints

State point	Cycle	Cycle burnup (MWd/MTU)	Measured k_{eff}	Calculated k_{eff} (homogeneous Gd model)	Calculated k_{eff} (8-pin Gd model)	Calculated k_{eff} (9-pin Gd model – Cycle 8 only)
SP7	7 (BOC)	0.00	1.00584	0.9740 ± 0.0010	1.0163 ± 0.0009	^a
SP8	7	4728.4	1.00519	0.9585 ± 0.0012	0.9992 ± 0.0010	^a
SP9	7	7507.28	1.00875	1.0029 ± 0.0010	1.0110 ± 0.0009	^a
SP10	8 (BOC)	0.00	1.00605	0.8972 ± 0.0010	1.0251 ± 0.0011	1.0154 ± 0.0009
SP11	8	89.8	1.00574	0.8978 ± 0.0011	1.0284 ± 0.0011	1.0175 ± 0.0009

^a Values were not reported.

▲ Cycle 7 Homogeneous Gd Model
 + Cycle 8 Homogeneous Gd Model
 ◆ Cycle 8 Symmetric 8-Gd pin Model
 □ Cycle 8 9-Gd pin Model
 ● Cycle 7 Symmetric 8-Gd pin Model

Fig. 16. Calculated (k_c)-to-measured (k_m) k_{eff} values vs cycle burnup.

6. CONCLUSIONS

The KENO V.a Monte Carlo results for five LS1 BWR critical configurations are within about 2% $\Delta k/k$ of the measured k_{eff} using a simplified assembly model that represents the gadolinium poison in a symmetric 8-pin arrangement. When the calculations for the Cycle 8 criticals are performed using a simplified 9-pin arrangement, a configuration closer to that of the fresh Cycle 8 assemblies, the results are improved to within approximately 1% for both reactor statepoints. These results suggest that the BWR CRCs can be predicted reasonably accurately without detailed information of the actual gadolinium pin distribution within the assemblies. More detailed calculations using the actual gadolinium pin distributions were not possible since the pin distributions for the assemblies in the LS1 CRCs were not available to ORNL for this work.

An homogenized representation of the gadolinium poison in the assembly generally results in a substantial underprediction in the k_{eff} . Uniformly distributing the gadolinium in all fuel pins gives the poison excessive weight in the calculations, due to the intermixing of poison in all fissile material regions and due to shelf-shielding effects. Only the SP9 configuration was well predicted with the homogeneous representation since the gadolinium poison is essentially depleted at the Cycle 7 burnup of about 8000 MWd/MTU, reducing the degree of heterogeneity in the assembly pin compositions.

Additional analyses are recommended to ensure that the approximations applied in these calculations have not significantly biased the results or produced offsetting biases. The sensitivity of the results to the average number of poison pins per assembly and the arrangement of the pins in the assemblies should be evaluated against a more detailed model that provides a closer representation of the actual assemblies (if this information is made available). It is also recommended that a sensitivity study of the key reactor state input parameters (e.g., moderator temperature and uniformity) be performed to determine the magnitude of state uncertainties on the results.

7. REFERENCES

1. CRWMS/M&O, *Summary Report of Commercial Reactor Criticality Data for LaSalle Unit 1*, Draft Report B-01717-5705-00138, Rev. B, Draft Report, prepared by for the U.S. Department of Energy, Yucca Mountain Site Characterization Project Office, July 1999.
 2. L. M. Petrie and N. F. Landers, "KENO V.a: An Improved Monte Carlo Criticality Program with Supergrouping," Vol. 2, Sect. F11 of *SCALE: A Modular Code System for Performing Standardized Computer Analyses for Licensing Evaluation*, NUREG/CR-0200, Rev. 5 (ORNL/NUREG/CSD-2/R5), Vols. I, II, and III, March 1997. Available from Radiation Safety Information Computational Center at Oak Ridge National Laboratory as CCC-545.
 3. *SCALE: A Modular Code System for Performing Standardized Computer Analyses for Licensing Evaluation*, NUREG/CR-0200, Rev. 5 (ORNL/NUREG/CSD-2/R5), Vols. I, II, and III, March 1997. Available from Radiation Safety Information Computational Center at Oak Ridge National Laboratory as CCC-545.
 4. General Electric Company, Core Design and Operating Data for Cycles 1 and 2 of Quad Cities 1, EPRI NP-240, Topical Report, November 1976.
 5. W. C. Jordan and S. M. Bowman, "SCALE Cross-Section Libraries," Vol. 3, Sect. M4 of *SCALE: A Modular Code System for Performing Standardized Computer Analyses for Licensing Evaluation*, NUREG/CR-0200, Rev. 5 (ORNL/NUREG/CSD-2/R5), Vols. I, II, and III, March 1997. Available from Radiation Safety Information Computational Center at Oak Ridge National Laboratory as CCC-545.
- David Henderson, Waste Package Design, Framatome Cogema Fuel Company, Las Vegas, Nevada, personal communication, 1999.
7. O. W. Hermann and C. V. Parks, "SAS2H: A Coupled One-Dimensional Depletion Analysis and Shielding Analysis Module," Vol. 1, Sect. S2 of *SCALE: A Modular Code System for Performing Standardized Computer Analyses for Licensing Evaluation*, NUREG/CR-0200, Rev. 5 (ORNL/NUREG/CSD-2/R5), Vols. I, II, and III, March 1997. Available from Radiation Safety Information Computational Center at Oak Ridge National Laboratory as CCC-545.
 8. O. W. Hermann and R. M. Westfall, "ORIGEN-S: SCALE System Module to Calculate Fuel Depletion, Actinide Transmutation, Fission Product Buildup and Decay, and Associated Radiation Source Terms," Vol. 2, Sect. F7 of *SCALE: A Modular Code System for Performing Standardized Computer Analyses for Licensing Evaluation*, NUREG/CR-0200, Rev. 5 (ORNL/NUREG/CSD-2/R5), Vols. I, II, and III, March 1997. Available from Radiation Safety Information Computational Center at Oak Ridge National Laboratory as CCC-545.

9. N. F. Landers and L. M. Petrie, "CSAS: Control Module for Enhanced Criticality Safety Analysis Sequences," Vol. 1, Sect. C4 of *SCALE: A Modular Code System for Performing Standardized Computer Analyses for Licensing Evaluation*, NUREG/CR-0200, Rev. 5 (ORNL/NUREG/CSD-2/R5), Vols. I, II, and III, March 1997. Available from Radiation Safety Information Computational Center at Oak Ridge National Laboratory as CCC-545.

APPENDIX A

CSASI INPUT LISTING FOR ASSEMBLY C14, ZONE 4, SP11

Appendix A

CSASI Input Listing for Assembly C14, Zone 4, SP11

```
=csasi
  C14          4 Assy-04, Node-01 {Cyc-08,      .0 to Cyc-08,    3.7 EFPD}
44groupndf5 latticecell
gd-152      4 0 2.3018E-06 351. end
gd-154      4 0 2.5123E-05 351. end
gd-155      4 0 9.9843E-08 351. end
gd-156      4 0 5.3162E-04 351. end
gd-157      4 0 8.6781E-08 351. end
gd-158      4 0 6.5962E-04 351. end
gd-160      4 0 3.4941E-04 351. end
u-234       1 0 3.7129E-06 351. end
u-235       1 0 1.6175E-04 351. end
u-236       1 0 1.0197E-04 351. end
u-237       1 0 3.3743E-08 351. end
u-238       1 0 2.0949E-02 351. end
np-237      1 0 9.5084E-06 351. end
pu-238      1 0 3.6297E-06 351. end
pu-239      1 0 9.7283E-05 351. end
pu-240      1 0 5.3169E-05 351. end
pu-241      1 0 2.2941E-05 351. end
pu-242      1 0 1.2137E-05 351. end
am-241      1 0 1.8640E-06 351. end
am-242m     1 0 2.7028E-08 351. end
am-243      1 0 2.3768E-06 351. end
cm-242      1 0 1.6727E-07 351. end
cm-244      1 0 6.6359E-07 351. end
cm-245      1 0 2.1761E-08 351. end
h-3         1 0 8.5565E-08 351. end
ge-76       1 0 2.6923E-08 351. end
se-77       1 0 5.9301E-08 351. end
se-78       1 0 1.9176E-07 351. end
se-80       1 0 9.8112E-07 351. end
br-81       1 0 1.4383E-06 351. end
se-82       1 0 2.3087E-06 351. end
kr-82       1 0 4.1237E-08 351. end
kr-83       1 0 2.7656E-06 351. end
kr-84       1 0 8.1980E-06 351. end
kr-85       1 0 1.4316E-06 351. end
rb-85       1 0 6.5916E-06 351. end
kr-86       1 0 1.2542E-05 351. end
sr-86       1 0 2.3333E-08 351. end
rb-87       1 0 1.6228E-05 351. end
sr-88       1 0 2.3027E-05 351. end
sr-89       1 0 1.9940E-07 351. end
y-89        1 0 3.0229E-05 351. end
sr-90       1 0 3.4281E-05 351. end
zr-90       1 0 2.6876E-06 351. end
y-91        1 0 3.3633E-07 351. end
zr-91       1 0 3.8244E-05 351. end
zr-92       1 0 4.0779E-05 351. end
zr-93       1 0 2.9459E-05 351. end
zr-94       1 0 4.7526E-05 351. end
zr-95       1 0 5.5340E-07 351. end
nb-95       1 0 4.0531E-07 351. end
mo-95       1 0 4.5467E-05 351. end
zr-96       1 0 4.8850E-05 351. end
mo-96       1 0 2.2240E-06 351. end
mo-97       1 0 4.5293E-05 351. end
mo-98       1 0 4.8609E-05 351. end
mo-99       1 0 2.9419E-08 351. end
tc-99       1 0 4.6373E-05 351. end
mo-100      1 0 5.3807E-05 351. end
ru-100      1 0 5.7756E-06 351. end
```

ru-101	1	0	4.4232E-05	351.	end
ru-102	1	0	4.3557E-05	351.	end
ru-103	1	0	2.5880E-07	351.	end
rh-103	1	0	2.5401E-05	351.	end
ru-104	1	0	2.9429E-05	351.	end
pd-104	1	0	1.2294E-05	351.	end
pd-105	1	0	2.0545E-05	351.	end
ru-106	1	0	4.0982E-06	351.	end
pd-106	1	0	1.4553E-05	351.	end
pd-107	1	0	1.1418E-05	351.	end
pd-108	1	0	7.4504E-06	351.	end
ag-109	1	0	4.5288E-06	351.	end
pd-110	1	0	2.1832E-06	351.	end
cd-110	1	0	1.8018E-06	351.	end
cd-111	1	0	1.1074E-06	351.	end
cd-112	1	0	5.7739E-07	351.	end
cd-114	1	0	5.8891E-07	351.	end
in-115	1	0	7.4261E-08	351.	end
cd-116	1	0	2.4044E-07	351.	end
sn-116	1	0	1.0596E-07	351.	end
sn-117	1	0	2.2151E-07	351.	end
sn-118	1	0	1.7759E-07	351.	end
sn-119	1	0	1.8418E-07	351.	end
sn-120	1	0	1.8018E-07	351.	end
sb-121	1	0	1.7808E-07	351.	end
sn-122	1	0	2.3064E-07	351.	end
te-122	1	0	1.0965E-08	351.	end
sb-123	1	0	2.0669E-07	351.	end
sn-124	1	0	3.8018E-07	351.	end
sb-125	1	0	2.4485E-07	351.	end
te-125	1	0	1.9746E-07	351.	end
sn-126	1	0	8.5800E-07	351.	end
te-126	1	0	1.5103E-08	351.	end
te-127m	1	0	1.2963E-08	351.	end
i-127	1	0	1.8755E-06	351.	end
te-128	1	0	4.0108E-06	351.	end
xe-128	1	0	1.0278E-07	351.	end
i-129	1	0	7.9404E-06	351.	end
te-130	1	0	1.6062E-05	351.	end
xe-130	1	0	3.5314E-07	351.	end
i-131	1	0	4.9741E-08	351.	end
xe-131	1	0	1.8578E-05	351.	end
te-132	1	0	2.9544E-08	351.	end
xe-132	1	0	4.7494E-05	351.	end
xe-133	1	0	8.5924E-08	351.	end
cs-133	1	0	5.0292E-05	351.	end
xe-134	1	0	6.4837E-05	351.	end
cs-134	1	0	3.3155E-06	351.	end
ba-134	1	0	3.1682E-06	351.	end
cs-135	1	0	1.5614E-05	351.	end
ba-135	1	0	1.5541E-08	351.	end
xe-136	1	0	9.6732E-05	351.	end
ba-136	1	0	6.9509E-07	351.	end
cs-137	1	0	5.0625E-05	351.	end
ba-137	1	0	3.4231E-06	351.	end
ba-138	1	0	5.3836E-05	351.	end
la-139	1	0	5.0252E-05	351.	end
ba-140	1	0	1.0754E-07	351.	end
la-140	1	0	1.5144E-08	351.	end
ce-140	1	0	5.1127E-05	351.	end
ce-141	1	0	1.9956E-07	351.	end
pr-141	1	0	4.5163E-05	351.	end
ce-142	1	0	4.5888E-05	351.	end
nd-142	1	0	8.7430E-07	351.	end
pr-143	1	0	9.8729E-08	351.	end
nd-143	1	0	3.0896E-05	351.	end
ce-144	1	0	5.3135E-06	351.	end
nd-144	1	0	4.9021E-05	351.	end
nd-145	1	0	2.6895E-05	351.	end
nd-146	1	0	2.7556E-05	351.	end
nd-147	1	0	3.7611E-08	351.	end
pm-147	1	0	5.2387E-06	351.	end

```

sm-147      1 0 4.9700E-06 351. end
nd-148      1 0 1.4226E-05 351. end
pm-148m     1 0 1.4943E-08 351. end
sm-148      1 0 4.9865E-06 351. end
sm-149      1 0 5.6819E-08 351. end
nd-150      1 0 6.7629E-06 351. end
sm-150      1 0 1.0844E-05 351. end
sm-151      1 0 4.2172E-07 351. end
sm-152      1 0 5.0339E-06 351. end
eu-153      1 0 4.3395E-06 351. end
sm-154      1 0 1.3255E-06 351. end
eu-154      1 0 7.1001E-07 351. end
gd-154      1 0 1.3126E-07 351. end
eu-155      1 0 1.8950E-07 351. end
eu-156      1 0 1.7562E-08 351. end
gd-156      1 0 2.9270E-06 351. end
gd-158      1 0 5.8893E-07 351. end
tb-159      1 0 7.6841E-08 351. end
gd-160      1 0 3.4864E-08 351. end
dy-161      1 0 1.0486E-08 351. end
o-16        1 0 4.5497E-02 351. end
arbm-zirc4  6.56 5 0 0 0 8016 0.12 24000 0.10 26000 0.20 50000 1.40
            40000 98.18 2 1.0 620.0 end
arbm-modr   0.9723      2 0 0 0
            1000      11.1900
            8016      88.81000
            3 1.0 560.3 end

end comp
squarepitch 1.62560 1.0642 1 3 1.2268 2 end
more data
res=4 cylinder 0.532 dan(4)=0.020 end
end
=wax
0$$ 41 e 1$$ 1 1t
2$$ 40 0 2t
end
=wax
0$$ 40 e 1$$ 2 1t
2$$ 41 0 2t
2$$ 2 2 2t
3$$ 1 4
4$$ 9031404 8031404 3t
end

```


APPENDIX B

GECKO FORTRAN UTILITY CODE LISTING

Appendix B

GECKO Fortran Utility Code Listing

```

c      program gecko2
c      ****
c      gecko2 - get compositions for keno from origen
c      utility code to read the origen formatted output file from sas2h
c      printed nuclide compositions are available in a standard
c      composition input form suitable for inclusion in a csas
c      case i.e., kenova
c      ****
c      integer id(29)
c      integer id19(600),id30(600)
c      integer nucl(600)
c      dimension nucid(2000),conc(2000),iprt(2000),aden(2000)
c      dimension iz(2000),xa(2000)
c      character*4 el(2000)
c      character*1 sta(2000)
c      character*3 mwt(2000)
c      dimension lib(3)
c      character*10 scid(600),hend*4
c      character*4 blank*3,buf*132,dash*1,title*132,buf6*6,celparm*80
c      character*4 totl,buf4,keywrd(4)
c      data dash,blank,totl /'-',' ','tota'/
c      data keywrd /'modu','npin','fuel','squa'/
c      character*29 units
c      data units /'nuclide concentrations, grams'/

c
c
c      read in acceptable nuclides for csas from standard composition lib
c      open(20,file='stdcmp',status='old')
c      open(5,status='unknown',form='formatted')
c      open(99,file='record',form='formatted',position='append')

c
c      isc=0
c      mx1=1
c      mx2=4
c      ivf=0
c      temp=351.
c      hend=' end'

c
c      do 12 i=1,600
c          read(20,end=20,fmt='(a10,i12)') scid(isc+1),nucl(isc+1)
c          write(6,*) scid,nucl
c          isc=isc+1
12 continue
20 continue
c      write(6,*) 'standard composition nuclides=',isc
c      print total number of nuclides in list
c
c      open(83,status='old',form='unformatted',file='ft83f001')
c      read(83) d1,nnuc,ngn,d2,d3,ngg
c      if (ngn.ne.44) write(6,*) ' --- error --- ngn ne 44'
c      if (nnuc.gt.600) write(6,*) ' --- error --- nnuc gt dim'
c      ng=ngg+ngn
c      do 30 i=1,nnuc
c          read(83) id,ft30
c          id19(i)=id(19)
c          id30(i)=nint(ft30)*10
c          mz=id19(i)/1000
c          mass=(id19(i)-mz*1000)
c          if (mass.gt.600) id30(i)=id30(i)+1
c          write(6,*) id19(i),mass,id30(i)
30 continue
c
c      *** start reading composition interface

```

```

c      npois = 0
      j = 1
      k = 0
      do
      read(5,10000,end=120) buf
      if (buf(5:8).eq.keywrd(1)) then
        read(5,10000,end=120) buf
        title = buf(5:100)
        goto 10
      endif
      end do

c
10 continue
  do
    read(5,10000,end=120) buf
    if (index(buf,keywrd(4)).gt.0) then
      loc = index(buf,keywrd(4))
      loc = loc + 24
      buf6 = buf(loc:loc+5)
c      write(6,*) 'fuelod=',buf6
      read(buf6,'(f6.3)') fd
      celparm(1:72)=buf(7:78)
      goto 18
    endif
  end do

c
18 continue
  do
    read(5,10000,end=120) buf
    if (index(buf,keywrd(2)).gt.0) then
      loc1 = index(buf,keywrd(2))
      loc1 = loc1 + 14
      buf4 = buf(loc1:loc1+2)
c      write(6,*) 'npin/assembly=',buf4
      read(buf4,'(i3)') npin
      loc2 = index(buf,keywrd(3))
      if (loc2.eq.0) goto 100
      loc2 = loc2 + 9
      buf6 = buf(loc2:loc2+5)
c      write(6,*) 'fuelength=',buf6
      read(buf6,'(f6.3)') fuelngth
      goto 40
    endif
  end do
  write(6,*) ' --- error --- keywords not found'
  go to 100

c
40  read(5,10000,end=120) buf
      ip = index(buf,units)
      if (ip.gt.0) then
c      start of nuclide concentrations
        read(5,10000,end=120) buf
        read(5,10000,end=120) buf
        42  read(5,10100,end=120) el(j),mwt(j),sta(j),xz,xa(j)
c      if (el(j).eq.totl) then
          write(6,*) 'match for total'
          k = k + 1
          lib(k) = j
          if (k.eq.3) goto 120
          go to 40
        endif
        if (el(j).eq.blank) then
          read(5,10000,end=120) buf
          read(5,10000,end=120) buf
          read(5,10000,end=120) buf
          read(5,10000,end=120) buf
          read(5,10000,end=120) buf
          go to 42
        endif
c      write(6,*) j,el(j),mwt(j),sta(j),xz,xa(j)
        read(mwt(j),'(i3)') iz(j)

```

```

        j = j + 1
        goto 42
    endif
    go to 40
c
120 continue
c
    do 122 i=1,3
122 lib(i)=lib(i) - 1
c
        iend = lib(3)
        afuel = (fd/2.)*(fd/2.)*3.141593
c
        set vol below based on npin=60 to conserve mass per assy
        apin = 60.0
        vol = afuel*apin*fuelngth
c
c
        prepare csasix case input
        write(6,10300) title
        do 70 i=1,iend
            call noah(ia,el(i))
            idn = ia*10000+iz(i)*10
            if (sta(i).eq.'m') idn = idn + 1
            write(6,*) el(i),mwt(i),sta(i),idn
c
c
            check for lite element gd and eu
            ipois = 0
            if (i.gt.lib(1)) goto 48
            if (ia.eq.64) ipois=1
            if (ia.eq.63) ipois=1
            if (ipois.eq.0) go to 70
            above rejects all non-poison lite elements
c
c
48      continue
c
        check that nuclid is on master library
        do 80 j=1,nnuc
            if (idn.ne.id30(j)) goto 80
            kdl9 = idl9(j)
c
            set standard composition name scid
            do 50 k=1,isc
                if (kdl9.eq.nucl(k)) goto 55
50      continue
c
            write(6,*) '--- no match on scid name for ',kdl9
            go to 70
c
c
55      continue
        vf = 1.
        if (ipois.eq.1) vf=8.0/apin
c
        scale factor for number densities of poison pins (8)
        aden(i)=xa(i)*0.60225/iz(i)/vol/vf
        if (aden(i).lt.1.0e-8) goto 70
        if (ipois.eq.1) then
            write(6,85) scid(k),mx2,ivf,aden(i),temp,hend
            npois = npois + 1
        else
            write(6,85) scid(k),mx1,ivf,aden(i),temp,hend
        endif
c
        above, allows simulation of lite element poisons if required
        goto 70
c
80      continue
c
        write(6,*) '--- following nuclide rejected ',idn
70      continue
c
        aden2 = 4.5497e-2
        write(6,85) scid(195),mx1,ivf,aden2,temp,hend
c
        above, write stdcmp for oxygen in fuel
c
c
        always write trace amount of gd to ensure mix 4 is present
        if (npois.eq.0) write(6,85) 'gd-156 ',mx2,ivf,1e-20,temp,hend
c
c
        write(6,10600)
        write(6,10700)
        write(6,10400)

```

```

        write(6,10200) celparm
        write(6,10800) mx2,fd/2.0,mx2
        write(6,10500)
c      write(6,*) title
c      write(6,*) 'litel=',lib(1),'act=',lib(2),'fp=',lib(3)
c      write(6,*) 'fuelod=',fd
c      write(6,*) 'npin/assembly=',npin
c      write(6,*) 'fuelength=',fuelngth
c      write(6,*) 'fuel volume=',vol
c
        call wax(title,ice)
        write(99,12000) title(1:10),ice,npin,fd,fuelngth
c
85      format(a10,2i2,1pe12.4,0pf5.0,a4)
86      format(2i6,i10,3x,a10,1pe12.4)
        close (83)
        close (20)
100     stop
10000   format(a132)
10100   format(3x,a4,a3,a1,1x,e9.2,50x,1x,e9.2)
10200   format(a72)
10300   format(7h=csasi ,/,a80,/,24h44groupndf5 latticecell)
10400   format(8hend comp)
10500   format(3hend)
10600   format(67harbm-zirc4 6.56 5 0 0 0 8016 0.12 24000 0.10
& 26000 0.20 50000 1.40 ,/,11x,27h40000 98.18 2 1.0 620.0 end )
10700   format(43harbm-modr 0.9723          2 0 0 0 /
& 11x,19h1000      11.1900 /
& 11x,19h8016      88.81000 /
& 11x,19h3 1.0 560.3 end )
10800   format(10hmore data /
& 4hres=,i1,10h cylinder ,f6.3,5h dan(,i1,12h)=0.020 end )
12000   format(6h asmb, a10,5h ice=,i7,6h npin=,i2,4h fd=,
& f6.3,4h fl=,f6.3)
        end
c
        subroutine noah(i,name)
        character name*4,nel*2
        character*2 ele(99),sta(2)
c
        data ele/ 'h','he','li','be','b','c','n','o','f','ne',
* 'na','mg','al','si','p','s','cl','ar','k','ca','sc','ti','v',
* 'cr','mn','fe','co','ni','cu','zn','ga','ge','as','se','br','kr',
* 'rb','sr','y','zr','nb','mo','tc','ru','rh','pd','ag','cd','in',
* 'sn','sb','te','i','xe','cs','ba','la','ce','pr','nd','pm','sm',
* 'eu','gd','tb','dy','ho','er','tm','yb','lu','hf','ta','w','re',
* 'os','ir','pt','au','hg','tl','pb','bi','po','at','rn','fr','ra',
* 'ac','th','pa','u','np','pu','am','cm','bk','cf','es'/
        data sta/ ' ','m '/
c
        nel = name(3:4)
        do 20 i=1,99
        if (nel.eq.ele(i)) return
20      continue
        write(6,*) 'no match for nuclide',name
        stop
        end
c
        subroutine wax(title,id)
        character*132 title
        character*1 buf,dash,blank,name(10)
        data name /'A','B','C','D','E','F','G','H','I','J'/
        data blank,dash /' ','-'/
c
        buf = blank
        i = 0
        do while(buf.eq.blank)
            i = i + 1
            buf = title(i:i)
        end do
        do 20 j=1,10
            if (buf.eq.name(j)) goto 40

```

```

20 continue
   write(6,*) ' --- error --- invalid name ',buf
   stop
40 id = j*10000
   i = i + 1
   read(title(i:i),'(i1)') n1
   i = i + 1
   buf = title(i:i)
   if (buf.eq.dash) then
      nas = n1
   else if (buf.eq.blank) then
      nas = n1
   else
      read(buf,'(i1)') n2
      nas = n1*10 + n2
   endif
   i = i + 10
   buf = blank
   do while(buf.eq.blank)
      i = i + 1
      buf = title(i:i)
   end do
   read(title(i:i+1),'(i2)') node
   id = id + nas*100 + node
   id1 = id + 9000000
   id2 = id + 8000000

c
   write(6,'(4h=wax)')
   write(6,'(20h0$$ 41 e 1$$ 1 1t )')
   write(6,'(20h2$$ 40 0 2t      )')
   write(6,'(3hend)')
   write(6,'(4h=wax)')
   write(6,'(20h0$$ 40 e 1$$ 2 1t )')
   write(6,'(20h2$$ 41 0 2t      )')
   write(6,'(20h2$$ 2 2 2t      )')
   write(6,'(10h3$$ 1 4 )')
   write(6,'(4h4$$ ,2(i8), 4h 3t )') id1,id2
   write(6,'(3hend)')
   return
end

```


APPENDIX C
LS1K FORTRAN UTILITY CODE LISTING
AND ASSEMBLY MAP

Appendix C

LS1K Fortran Utility Code Listing and Assembly Map

```

program ls1k
c *****
c builds kenova material, geometry, and array data blocks, and
c script files to generate material cross sections for the
c lasalle unit 1 crc calculations
c *****
character*1 blank,buf*20
character*5 map(15,15)
dimension imap(15,15),imap2(30,30)
dimension imapf(59,59)
dimension hz(10)
data hz /15.24,45.72,60.96,5*45.72,2*15.24/
c above, sets node heights
common /message/ iboc,ncyc
node = 10
imax = 15
jmax = 15
c
read(5,'(a20)') buf
write(6,*) 'preparing kenova data for ',buf(2:20)
read(5,'(15a5)') ((map(i,j),i=1,imax),j=1,jmax)
open(10,file='mixt',status='unknown',form='formatted')
open(11,file='geom',status='unknown',form='formatted')
open(12,file='array',status='unknown',form='formatted')
write(10,'(10hread mixt  )')
write(11,'(10hread geom  )')
write(12,'(10hread array )')
icnt = 0
nu = 0
iarr = 0
c --- reserve initial 9 mixes for structural and non-fuel matls
mix = 8
c --- set special mixt assignments for boc statepoints
iboc = 0
if (index(buf,'boc').gt.0) then
  iboc = 1
  j = index(buf,'cycle')
  if (j.eq.0) stop
  j = j + 5
  blank = buf(j:j)
  read(blank,'(i1)') ncyc
endif
c
aden = 1.
c above, aden set for macroscopic xsc
do 20 j=1,jmax
do 40 i=1,imax
do 60 n=1,node
c write(6,'(2x,a5)') map(i,j)(3:4)
  if (index(map(i,j),'X').gt.0) goto 40
c above, skip symmetric sites
  icnt = icnt + 1
  nu = nu + 1
c two mixtures per zone
  mix = mix + 2
c determine xsec id from assembly name
  call label(map(i,j),idxs)
  write(6,*) idxs
  idxs = idxs + n
c identifiers for u and u/gd pins
  idx1 = idxs + 9000000
  idx2 = idxs + 8000000
c --- write mixt file entry for mix/xsc map

```

```

        write(10,10000) mix,idx1,aden
        write(10,10400) mix+1,idx1,aden,idx2,aden
c
c --- write geometry data for each unit (nu)
        hzn = hz(n)
        write(11,10300) map(i,j),n,i+15,j+15,idxs
        write(11,10200) nu
        write(11,10500) mix,hzn,hzn,hzn
        nul = nu
c --- u pin complete
        nu = nu + 1
        write(11,10200) nu
        write(11,10500) mix+1,hzn,hzn,hzn
        nulp = nu
c --- u+gd pin complete
        nu = nu + 1
        write(11,10200) nu
        write(11,10510) mix,hzn,hzn
        nu2 = nu
c --- u "hole" inner pin complete
        nu = nu + 1
        write(11,10200) nu
        write(11,10520) hzn,hzn,hzn,(nu2,k=1,12)
        nu3 = nu
c --- water rod plus inner u pins complete
        nu = nu + 1
        iarr = iarr + 1
        write(11,10200) nu
        write(11,10530) iarr
        write(12,13000) iarr,(nul,k=1,4)
        nu4 = nu
c --- assembly corners (4x4) complete
        nu = nu + 1
        iarr = iarr + 1
        write(11,10200) nu
        write(11,10530) iarr
        write(12,13010) iarr,nul,nulp,(nul,k=1,4),nul,nulp
        nu5 = nu
c --- assembly left side complete
        nu = nu + 1
        iarr = iarr + 1
        write(11,10200) nu
        write(11,10530) iarr
        write(12,13010) iarr,nulp,(nul,k=1,5),nulp,nul
        nu6 = nu
c --- assembly right side complete
        nu = nu + 1
        iarr = iarr + 1
        write(11,10200) nu
        write(11,10530) iarr
        write(12,13012) iarr,nulp,nul,nul,nulp,(nul,k=1,4)
        nu7 = nu
c --- assembly bottom side complete
        nu = nu + 1
        iarr = iarr + 1
        write(11,10200) nu
        write(11,10530) iarr
        write(12,13012) iarr,(nul,k=1,4),nulp,nul,nul,nulp
        nu8 = nu
c --- assembly top side complete
c
c --- now, define general assembly
        nu = nu + 1
        iarr = iarr + 1
        write(11,10200) nu
        write(11,10540) iarr,hzn,hzn
        write(12,13020) iarr,nu4,nu8,nu4,nu5,nu3,nu6,nu4,nu7,nu4
c
60 continue
c --- all nodes complete, add assembly array (10 units per node)
        iarr = iarr + 1
        ilast = nu

```

```

write(12,13040) iarr,(ilast-10*(k-1),k=10,1,-1)
nu = nu + 1
write(11,10200) nu
write(11,10530) iarr
c --- store assembly node unit number in array imap to build core array
imap(i,j) = nu
c
40 continue
20 continue
c --- fill symmetric assembly sites (set as zero in imap)
do 80 j=1,jmax
do 90 i=1,imax
if (imap(i,j).eq.0) imap(i,j)=imap(j,i)
if (imap(i,j).eq.0) imap(i,j)=13000
90 continue
80 continue
c
icnt = icnt/node
write(6,*) icnt,' assemblies completed'
write(6,*) 'core map  imap(i,j)'
write(6,'(15a5)') ((map(i,j),i=1,15),j=1,15)
write(6,'(15i5)') ((imap(i,j),i=1,15),j=1,15)
c
c --- generate core layout using array imap
write(12,13100)
nu = 9000
write(12,13120) nu
c
c
c --- fill interstitial assembly locations with water units
do 120 j=1,jmax*2
do 140 i=1,imax*2
ixc = 0
iyc = 0
c
c test for x,y even,odd
if (mod(i,2).eq.0) ixc = 1
if (mod(j,2).eq.0) iyc = 1
if (ixc.eq.0) then
if (iyc.eq.0) imap2(i,j) = 13003
if (iyc.eq.1) imap2(i,j) = 13001
else
if (iyc.eq.0) imap2(i,j) = 13002
if (iyc.eq.1) imap2(i,j) = imap(i/2,j/2)
endif
c
c even/even locations are assemblies
c
140 continue
120 continue
c
c set locations of inserted cruxiform centres on map
c row 1 - alternate full insertion - imap2 id=90003
j = 1
do 200 i=1,30,8
200 imap2(i,j) = 90003
c add (42,31) blade site for cycle 7 only
imap2(13,j) = 90003
c
c row 5 - full insertion all sites
j = 5
do 220 i=1,30,4
220 imap2(i,j) = 90003
c
c row 9 - alternate full insertion
j = 9
do 240 i=1,30,8
240 imap2(i,j) = 90003
imap2(5,j) = 90003
c add (50,23) blade site for cycle 7 only
imap2(21,9) = 90003
c
c row 13 - full insertion all sites

```

```

      j = 13
      do 260 i=1,30,4
260  imap2(i,j) = 90003
c
c   row 17 - alternate full insertion
      j = 17
      do 280 i=1,26,8
280  imap2(i,j) = 90003
c   add (42,15) blade site for cycle 7 only
      imap2(13,j) = 90003
c
c   row 21 - full insertion all sites
      j = 21
      do 290 i=1,22,4
290  imap2(i,j) = 90003
c
c   row 25 - alternate full insertion
      j = 25
      do 300 i=1,18,8
300  imap2(i,j) = 90003
c
c   row 29 - full insertion all sites
      j = 29
      do 310 i=1,15,4
310  imap2(i,j) = 90003
c
c *** map image 1/4 core imap2 to full core image imapf
c
      do 400 i=30,59
      do 400 j=30,59
400  imapf(i,j) = imap2(i-29,j-29)
c
c   reflect to lower left quadrant
      do 420 i=1,29
      do 420 j=30,59
420  imapf(i,j) = imapf(60-i,j)
c
c   now reflect to upper half core from lower half
      do 440 i=1,59
      do 440 j=1,29
440  imapf(i,j) = imapf(i,60-j)
c
c *** add/modify locations for any non-symmetric blade sites
      isp = 7
      if (isp.eq.10 .or. isp.eq.11) then
c       withdraw control rod at blade site (26,39)
          imapf(26,22) = 13003
c       set critical control absorber height (26,23)
          imapf(26,38) = 100001
      else if (isp.eq.9) then
c       set critical control absorber at site (34,7)
          imapf(34,54) = 100001
      else if (isp.eq.8) then
c       set critical control absorber at site (18,47) cycle 7 sp8 only
          imapf(18,14) = 100001
      else if (isp.eq.7) then
c       set critical control absorber at site (18,47) cycle 7 sp7 only
          imapf(34,6) = 100001
c       add control rod at blade site (34,7)
          imapf(34,54) = 90003
      else
c       write(6,*) '--- error --- invalid statepoint ',isp
      endif
c
c *** now complete mapping of control blades
      lim = 59
      do 160 j=1,lim
      do 180 i=1,lim
          if (imapf(i,j).lt.90000) go to 180
c
c       if (imapf(i,j).eq.90003) then
c --- control rod 9C

```

```

        if (i.gt.1) imapf(i-1,j) = 13011
        if (i.lt.lim) imapf(i+1,j) = 13012
        if (j.gt.1) imapf(i,j-1) = 13009
        if (j.lt.lim) imapf(i,j+1) = 13010
        imapf(i,j) = 13013
    elseif (imapf(i,j).eq.100001) then
c ---      control rod 10A
        if (i.gt.1) imapf(i-1,j) = 13024
        if (i.lt.lim) imapf(i+1,j) = 13025
        if (j.gt.1) imapf(i,j-1) = 13022
        if (j.lt.lim) imapf(i,j+1) = 13023
        imapf(i,j) = 13026
    else
        write(6,*) 'invalid control rod id',imapf(i,j)
        stop
    endif
c
180 continue
160 continue
c
800 continue
c --- print array data for complete core
    write(12,'(10i6)') ((imapf(i,j),i=1,59),j=1,59)
    write(12,'(10h end fill  )')
    write(14,'(59i6)') ((imapf(i,j),i=1,59),j=1,59)
    close(10)
    close(11)
    close(12)
    stop
10000 format(4hmix= ,i4,4h      ,i8,f5.1)
10100 format(10hread geom  )
10110 format(10hend geom  )
10200 format(4hunit,i6 )
10300 format(1h'/ 17h'--- uo2-gd pin  , a5,6h node=i2,
      1 9h (site i= ,i2,4h, j=,i2,7h) xsc=,i7 )
10400 format(4hmix= ,i4,4h      ,2(i8,f5.1))
10500 format(
      1 lx,'cylinder ',i4,' 1 0.5321 ',f5.2,' 0.0'/
      2 lx,'cylinder 2 1 0.6134 ',f5.2,' 0.0'/
      3 lx,'cuboid 3 1 4p0.8128 ',f5.2,' 0.0' )
10510 format(
      1 lx,'cylinder ',i4,' 1 0.5321 ',f5.2,' 0.0'/
      2 lx,'cylinder 2 1 0.6134 ',f5.2,' 0.0' )
10520 format(
      1 lx,'cylinder 3 1 1.6002 ',f5.2,' 0.0'/
      2 lx,'cylinder 2 1 1.7018 ',f5.2,' 0.0'/
      3 lx,'cuboid 3 1 4p3.2512 ',f5.2,' 0.0'/
      4 lx,'hole ',i5,' 2.4384 2.4384 0.0'/
      5 lx,'hole ',i5,' 2.4384 0.8128 0.0'/
      6 lx,'hole ',i5,' 2.4384 -0.8128 0.0'/
      7 lx,'hole ',i5,' 2.4384 -2.4384 0.0'/
      8 lx,'hole ',i5,' 0.8128 -2.4384 0.0'/
      9 lx,'hole ',i5,' -0.8128 -2.4384 0.0'/
      a lx,'hole ',i5,' -2.4384 -2.4384 0.0'/
      b lx,'hole ',i5,' -2.4384 -0.8128 0.0'/
      c lx,'hole ',i5,' -2.4384 0.8128 0.0'/
      d lx,'hole ',i5,' -2.4384 2.4384 0.0'/
      e lx,'hole ',i5,' -0.8128 2.4384 0.0'/
      f lx,'hole ',i5,' 0.8128 2.4384 0.0' )
10530 format(
      1 lx,'array ',i4,' 3*0' )
10540 format(
      1 lx,'array ',i4,' -6.5024 -6.5024 0.0'/
      2 lx,'cuboid 3 1 4p6.7031 ',f5.2,' 0.0'/
      3 lx,'cuboid 2 1 4p6.9061 ',f5.2,' 0.0' )
13000 format(
      1 4hara= ,i4,27h nux=2 nuy=2 nuz=1 fill /
      2 4i6,12h end fill )
13010 format(
      1 4hara= ,i4,27h nux=2 nuy=4 nuz=1 fill /
      2 8i6,12h end fill )
13012 format(

```

```

1 4hara= ,i4,27h nux=4 nuy=2 nuz=1 fill /
2 8i6,12h end fill )
13020 format(
1 4hara= ,i4,27h nux=3 nuy=3 nuz=1 fill /
2 3i6/ 3i6/ 3i6,12h end fill )
13040 format(
1 4hara= ,i4,27h nux=1 nuy=1 nuz=10 fill /
2 5i6/ 5i6,12h end fill )
13100 format(
1 37h'--- reactor core array - layout map )
13120 format(
1 4hara= ,i4,27h nux=59 nuy=59 nuz=1 fill )
end

c
subroutine label(asmby,idxs)
character*5 asmby
character*1 buf,blank,dash,name(10)
data name /'A','B','C','D','E','F','G','H','I','J'/
data blank,dash /' ','-'/
common /message/ iboc,ncyc
buf = blank
i = 0
do while(buf.eq.blank)
i = i + 1
buf = asmby(i:i)
end do
do 20 j=1,10
if (buf.eq.name(j)) goto 40
20 continue
write(6,*) ' --- error --- invalid name ',buf
stop
40 idxs = j*10000
c --- if boc sp -
if (iboc.eq.1) then
if (ncyc.eq.7) then
if (j.eq.6) return
if (j.eq.7) return
else if (ncyc.eq.8) then
if (j.eq.8) return
if (j.eq.10) return
endif
endif
c
i = i + 1
read(asmby(i:i),'(i1)') n1
i = i + 1
buf = asmby(i:i)
if (buf.eq.dash) then
m = n1
else if (buf.eq.blank) then
m = n1
else
read(buf,'(i1)') n2
m = n1*10 + n2
endif
idxs = idxs + m*100
return
end

```


Cycle 8 Assembly Map

=cycle8

D4	H18	F3	D13	E6	J5	F17	E9	D15	J11	F6	F2	D10	E5	C4
X	D16	J6	G7	J12	F7	J4	F1	H10	E7	J10	H6	H7	E1	C5
F10	X	F4	H9	G12	J8	F14	J9	G14	H16	F16	H12	F15	D7	C2
X	G11	X	D12	D2	G15	J2	D3	E2	G5	H15	G9	D19	D21	C19
X	X	X	D14	G1	J13	G6	D11	G3	J7	H1	D20	D6	D9	C29
X	X	X	X	X	G10	H5	G4	J1	H2	C14	H11	F9	E8	C25
X	X	X	X	X	X	D8	J3	H13	G2	H17	H3	G16	E3	C1
X	F18	X	D5	X	G8	X	D18	D17	H8	H14	H4	E12	C26	X
X	X	X	E4	X	X	X	X	D1	F11	G13	F5	C3	X	X
X	E11	X	X	X	X	X	X	X	F13	C21	C27	C22	X	X
X	X	X	X	X	X	X	X	X	X	C9	X	X	X	X
F12	X	X	X	X	X	X	X	F8	X	X	X	X	X	X
X	X	X	X	X	X	X	X	C12	C28	X	X	X	X	X
E10	X	X	X	X	X	X	X	X	X	X	X	X	X	X
C8	X	X	C17	X	X	X	X	X	X	X	X	X	X	X

end

APPENDIX D

ABRIDGED KENO V.A INPUT LISTING

FOR LS1 STATEPOINT CONFIGURATIONS

Appendix D

Abbreviated KENO V.a Input Listing for LS1 Statepoint Configurations

```
=kenova
keno-v.a model of lasalle unit 1 8x8 BWR - cycle 8 SP11
read parm
npg=1000 gen=503 nsk=5 nub=no fdn=no tme=120
xsc=14 lib=40
lng=2000000 nb8=9000
run=yes plt=no
end parm
read mixt
mix=2 2 1.
mix=3 3 1.
mix=4 4 1.
mix=5 5 1.
' start fuel mixt
mix= 10      9040401  1.0
mix= 11      9040401  1.0 8040401  1.0
mix= 12      9040402  1.0
mix= 13      9040402  1.0 8040402  1.0
mix= 14      9040403  1.0
mix= 15      9040403  1.0 8040403  1.0
mix= 16      9040404  1.0
mix= 17      9040404  1.0 8040404  1.0
mix= 18      9040405  1.0
mix= 19      9040405  1.0 8040405  1.0
mix= 20      9040406  1.0
mix= 21      9040406  1.0 8040406  1.0
.
.
.
(2309 lines deleted)
.
.
.
mix=2329      9031710  1.0 8031710  1.0
end mixt
'
read geom
'
'--- uo2-gd pin    D4 node= 1 (site i=16, j=16) xsc= 40401
unit      1
cylinder  10 1  0.5321  15.24  0.0
cylinder  2 1  0.6134  15.24  0.0
cuboid    3 1  4p0.8128  15.24  0.0
unit      2
cylinder  11 1  0.5321  15.24  0.0
cylinder  2 1  0.6134  15.24  0.0
cuboid    3 1  4p0.8128  15.24  0.0
unit      3
cylinder  10 1  0.5321  15.24  0.0
cylinder  2 1  0.6134  15.24  0.0
unit      4
cylinder  3 1  1.6002   15.24  0.0
cylinder  2 1  1.7018   15.24  0.0
cuboid    3 1  4p3.2512  15.24  0.0
hole      3  2.4384  2.4384  0.0
hole      3  2.4384  0.8128  0.0
hole      3  2.4384 -0.8128  0.0
```

```

hole      3      2.4384 -2.4384  0.0
hole      3      0.8128 -2.4384  0.0
hole      3     -0.8128 -2.4384  0.0
hole      3     -2.4384 -2.4384  0.0
hole      3     -2.4384 -0.8128  0.0
hole      3     -2.4384  0.8128  0.0
hole      3     -2.4384  2.4384  0.0
hole      3     -0.8128  2.4384  0.0
hole      3      0.8128  2.4384  0.0
unit      5
array     1      3*0
unit      6
array     2      3*0
unit      7
array     3      3*0
unit      8
array     4      3*0
unit      9
array     5      3*0
unit     10
array     6      -6.5024 -6.5024  0.0
cuboid    3 1    4p6.7031 15.24  0.0
cuboid    2 1    4p6.9061 15.24  0.0
'--- uo2-gd pin    D4 node= 2 (site i=16, j=16) xsc= 40402
unit     11
cylinder  12 1    0.5321  45.72  0.0
cylinder  2 1      0.6134  45.72  0.0
cuboid    3 1    4p0.8128  45.72  0.0
unit     12
cylinder  13 1    0.5321  45.72  0.0
cylinder  2 1      0.6134  45.72  0.0
cuboid    3 1    4p0.8128  45.72  0.0
unit     13
cylinder  12 1    0.5321  45.72  0.0
cylinder  2 1      0.6134  45.72  0.0
unit     14
cylinder  3 1    1.6002    45.72  0.0
cylinder  2 1    1.7018    45.72  0.0
cuboid    3 1    4p3.2512  45.72  0.0
hole      13      2.4384  2.4384  0.0
hole      13      2.4384  0.8128  0.0
hole      13      2.4384 -0.8128  0.0
hole      13      2.4384 -2.4384  0.0
hole      13      0.8128 -2.4384  0.0
hole      13     -0.8128 -2.4384  0.0
hole      13     -2.4384 -2.4384  0.0
hole      13     -2.4384 -0.8128  0.0
hole      13     -2.4384  0.8128  0.0
hole      13     -2.4384  2.4384  0.0
hole      13     -0.8128  2.4384  0.0
hole      13      0.8128  2.4384  0.0
unit     15
array     7      3*0
unit     16
array     8      3*0
unit     17
array     9      3*0
unit     18
array    10      3*0
unit     19
array    11      3*0
unit     20
array    12      -6.5024 -6.5024  0.0
cuboid    3 1    4p6.7031  45.72  0.0
cuboid    2 1    4p6.9061  45.72  0.0
'--- uo2-gd pin    D4 node= 3 (site i=16, j=16) xsc= 40403
unit     21
cylinder  14 1    0.5321  60.96  0.0
cylinder  2 1      0.6134  60.96  0.0
cuboid    3 1    4p0.8128  60.96  0.0

```

```

unit 22
cylinder 15 1 0.5321 60.96 0.0
cylinder 2 1 0.6134 60.96 0.0
cuboid 3 1 4p0.8128 60.96 0.0
unit 23
cylinder 14 1 0.5321 60.96 0.0
cylinder 2 1 0.6134 60.96 0.0
unit 24
cylinder 3 1 1.6002 60.96 0.0
cylinder 2 1 1.7018 60.96 0.0
cuboid 3 1 4p3.2512 60.96 0.0
hole 23 2.4384 2.4384 0.0
hole 23 2.4384 0.8128 0.0
hole 23 2.4384 -0.8128 0.0
hole 23 2.4384 -2.4384 0.0
hole 23 0.8128 -2.4384 0.0
hole 23 -0.8128 -2.4384 0.0
hole 23 -2.4384 -2.4384 0.0
hole 23 -2.4384 -0.8128 0.0
hole 23 -2.4384 0.8128 0.0
hole 23 -2.4384 2.4384 0.0
hole 23 -0.8128 2.4384 0.0
hole 23 0.8128 2.4384 0.0
unit 25
array 13 3*0
unit 26
array 14 3*0
unit 27
array 15 3*0
unit 28
array 16 3*0
unit 29
array 17 3*0
unit 30
array 18 -6.5024 -6.5024 0.0
cuboid 3 1 4p6.7031 60.96 0.0
cuboid 2 1 4p6.9061 60.96 0.0
'--- uo2-gd pin D4 node= 4 (site i=16, j=16) xsc= 40404
unit 31
cylinder 16 1 0.5321 45.72 0.0
cylinder 2 1 0.6134 45.72 0.0
cuboid 3 1 4p0.8128 45.72 0.0
unit 32
cylinder 17 1 0.5321 45.72 0.0
cylinder 2 1 0.6134 45.72 0.0
cuboid 3 1 4p0.8128 45.72 0.0
unit 33
cylinder 16 1 0.5321 45.72 0.0
cylinder 2 1 0.6134 45.72 0.0
unit 34
cylinder 3 1 1.6002 45.72 0.0
cylinder 2 1 1.7018 45.72 0.0
cuboid 3 1 4p3.2512 45.72 0.0
hole 33 2.4384 2.4384 0.0
hole 33 2.4384 0.8128 0.0
hole 33 2.4384 -0.8128 0.0
hole 33 2.4384 -2.4384 0.0
hole 33 0.8128 -2.4384 0.0
hole 33 -0.8128 -2.4384 0.0
hole 33 -2.4384 -2.4384 0.0
hole 33 -2.4384 -0.8128 0.0
hole 33 -2.4384 0.8128 0.0
hole 33 -2.4384 2.4384 0.0
hole 33 -0.8128 2.4384 0.0
hole 33 0.8128 2.4384 0.0
unit 35
array 19 3*0
unit 36
array 20 3*0
unit 37
array 21 3*0

```

```

unit 38
  array 22 3*0
unit 39
  array 23 3*0
unit 40
  array 24 -6.5024 -6.5024 0.0
  cuboid 3 1 4p6.7031 45.72 0.0
  cuboid 2 1 4p6.9061 45.72 0.0
'
'--- uo2-gd pin D4 node= 5 (site i=16, j=16) xsc= 40405
unit 41
  cylinder 18 1 0.5321 45.72 0.0
  cylinder 2 1 0.6134 45.72 0.0
  cuboid 3 1 4p0.8128 45.72 0.0
unit 42
  cylinder 19 1 0.5321 45.72 0.0
  cylinder 2 1 0.6134 45.72 0.0
  cuboid 3 1 4p0.8128 45.72 0.0
unit 43
  cylinder 18 1 0.5321 45.72 0.0
  cylinder 2 1 0.6134 45.72 0.0
unit 44
  cylinder 3 1 1.6002 45.72 0.0
  cylinder 2 1 1.7018 45.72 0.0
  cuboid 3 1 4p3.2512 45.72 0.0
  hole 43 2.4384 2.4384 0.0
  hole 43 2.4384 0.8128 0.0
  hole 43 2.4384 -0.8128 0.0
  hole 43 2.4384 -2.4384 0.0
  hole 43 0.8128 -2.4384 0.0
  hole 43 -0.8128 -2.4384 0.0
  hole 43 -2.4384 -2.4384 0.0
  hole 43 -2.4384 -0.8128 0.0
  hole 43 -2.4384 0.8128 0.0
  hole 43 -2.4384 2.4384 0.0
  hole 43 -0.8128 2.4384 0.0
  hole 43 0.8128 2.4384 0.0
unit 45
  array 25 3*0
unit 46
  array 26 3*0
unit 47
  array 27 3*0
unit 48
  array 28 3*0
unit 49
  array 29 3*0
unit 50
  array 30 -6.5024 -6.5024 0.0
  cuboid 3 1 4p6.7031 45.72 0.0
  cuboid 2 1 4p6.9061 45.72 0.0
'
'--- uo2-gd pin D4 node= 6 (site i=16, j=16) xsc= 40406
unit 51
  cylinder 20 1 0.5321 45.72 0.0
  cylinder 2 1 0.6134 45.72 0.0
  cuboid 3 1 4p0.8128 45.72 0.0
unit 52
  cylinder 21 1 0.5321 45.72 0.0
  cylinder 2 1 0.6134 45.72 0.0
  cuboid 3 1 4p0.8128 45.72 0.0
unit 53
  cylinder 20 1 0.5321 45.72 0.0
  cylinder 2 1 0.6134 45.72 0.0
unit 54
  cylinder 3 1 1.6002 45.72 0.0
  cylinder 2 1 1.7018 45.72 0.0
  cuboid 3 1 4p3.2512 45.72 0.0
  hole 53 2.4384 2.4384 0.0
  hole 53 2.4384 0.8128 0.0
  hole 53 2.4384 -0.8128 0.0
  hole 53 2.4384 -2.4384 0.0

```



```

hole 53 0.8128 -2.4384 0.0
hole 53 -0.8128 -2.4384 0.0
hole 53 -2.4384 -2.4384 0.0
hole 53 -2.4384 -0.8128 0.0
hole 53 -2.4384 0.8128 0.0
hole 53 -2.4384 2.4384 0.0
hole 53 -0.8128 2.4384 0.0
hole 53 0.8128 2.4384 0.0
unit 55
array 31 3*0
unit 56
array 32 3*0
unit 57
array 33 3*0
unit 58
array 34 3*0
unit 59
array 35 3*0
unit 60
array 36 -6.5024 -6.5024 0.0
cuboid 3 1 4p6.7031 45.72 0.0
cuboid 2 1 4p6.9061 45.72 0.0
'--- uo2-gd pin D4 node= 7 (site i=16, j=16) xsc= 40407
unit 61
cylinder 22 1 0.5321 45.72 0.0
cylinder 2 1 0.6134 45.72 0.0
cuboid 3 1 4p0.8128 45.72 0.0
unit 62
cylinder 23 1 0.5321 45.72 0.0
cylinder 2 1 0.6134 45.72 0.0
cuboid 3 1 4p0.8128 45.72 0.0
unit 63
cylinder 22 1 0.5321 45.72 0.0
cylinder 2 1 0.6134 45.72 0.0
unit 64
cylinder 3 1 1.6002 45.72 0.0
cylinder 2 1 1.7018 45.72 0.0
cuboid 3 1 4p3.2512 45.72 0.0
hole 63 2.4384 2.4384 0.0
hole 63 2.4384 0.8128 0.0
hole 63 2.4384 -0.8128 0.0
hole 63 2.4384 -2.4384 0.0
hole 63 0.8128 -2.4384 0.0
hole 63 -0.8128 -2.4384 0.0
hole 63 -2.4384 -2.4384 0.0
hole 63 -2.4384 -0.8128 0.0
hole 63 -2.4384 0.8128 0.0
hole 63 -2.4384 2.4384 0.0
hole 63 -0.8128 2.4384 0.0
hole 63 0.8128 2.4384 0.0
unit 65
array 37 3*0
unit 66
array 38 3*0
unit 67
array 39 3*0
unit 68
array 40 3*0
unit 69
array 41 3*0
unit 70
array 42 -6.5024 -6.5024 0.0
cuboid 3 1 4p6.7031 45.72 0.0
cuboid 2 1 4p6.9061 45.72 0.0
'--- uo2-gd pin D4 node= 8 (site i=16, j=16) xsc= 40408
unit 71
cylinder 24 1 0.5321 45.72 0.0
cylinder 2 1 0.6134 45.72 0.0
cuboid 3 1 4p0.8128 45.72 0.0
unit 72

```

```

cylinder 25 1 0.5321 45.72 0.0
cylinder 2 1 0.6134 45.72 0.0
cuboid 3 1 4p0.8128 45.72 0.0
unit 73
cylinder 24 1 0.5321 45.72 0.0
cylinder 2 1 0.6134 45.72 0.0
unit 74
cylinder 3 1 1.6002 45.72 0.0
cylinder 2 1 1.7018 45.72 0.0
cuboid 3 1 4p3.2512 45.72 0.0
hole 73 2.4384 2.4384 0.0
hole 73 2.4384 0.8128 0.0
hole 73 2.4384 -0.8128 0.0
hole 73 2.4384 -2.4384 0.0
hole 73 0.8128 -2.4384 0.0
hole 73 -0.8128 -2.4384 0.0
hole 73 -2.4384 -2.4384 0.0
hole 73 -2.4384 -0.8128 0.0
hole 73 -2.4384 0.8128 0.0
hole 73 -2.4384 2.4384 0.0
hole 73 -0.8128 2.4384 0.0
hole 73 0.8128 2.4384 0.0
unit 75
array 43 3*0
unit 76
array 44 3*0
unit 77
array 45 3*0
unit 78
array 46 3*0
unit 79
array 47 3*0
unit 80
array 48 -6.5024 -6.5024 0.0
cuboid 3 1 4p6.7031 45.72 0.0
cuboid 2 1 4p6.9061 45.72 0.0

```

'--- uo2-gd pin D4 node= 9 (site i=16, j=16) xsc= 40409

```

unit 81
cylinder 26 1 0.5321 15.24 0.0
cylinder 2 1 0.6134 15.24 0.0
cuboid 3 1 4p0.8128 15.24 0.0
unit 82
cylinder 27 1 0.5321 15.24 0.0
cylinder 2 1 0.6134 15.24 0.0
cuboid 3 1 4p0.8128 15.24 0.0
unit 83
cylinder 26 1 0.5321 15.24 0.0
cylinder 2 1 0.6134 15.24 0.0
unit 84
cylinder 3 1 1.6002 15.24 0.0
cylinder 2 1 1.7018 15.24 0.0
cuboid 3 1 4p3.2512 15.24 0.0
hole 83 2.4384 2.4384 0.0
hole 83 2.4384 0.8128 0.0
hole 83 2.4384 -0.8128 0.0
hole 83 2.4384 -2.4384 0.0
hole 83 0.8128 -2.4384 0.0
hole 83 -0.8128 -2.4384 0.0
hole 83 -2.4384 -2.4384 0.0
hole 83 -2.4384 -0.8128 0.0
hole 83 -2.4384 0.8128 0.0
hole 83 -2.4384 2.4384 0.0
hole 83 -0.8128 2.4384 0.0
hole 83 0.8128 2.4384 0.0
unit 85
array 49 3*0
unit 86
array 50 3*0
unit 87
array 51 3*0
unit 88

```

```

array 52 3*0
unit 89
array 53 3*0
unit 90
array 54 -6.5024 -6.5024 0.0
cuboid 3 1 4p6.7031 15.24 0.0
cuboid 2 1 4p6.9061 15.24 0.0
'--- uo2-gd pin D4 node=10 (site i=16, j=16) xsc= 40410
unit 91
cylinder 28 1 0.5321 15.24 0.0
cylinder 2 1 0.6134 15.24 0.0
cuboid 3 1 4p0.8128 15.24 0.0
unit 92
cylinder 29 1 0.5321 15.24 0.0
cylinder 2 1 0.6134 15.24 0.0
cuboid 3 1 4p0.8128 15.24 0.0
unit 93
cylinder 28 1 0.5321 15.24 0.0
cylinder 2 1 0.6134 15.24 0.0
unit 94
cylinder 3 1 1.6002 15.24 0.0
cylinder 2 1 1.7018 15.24 0.0
cuboid 3 1 4p3.2512 15.24 0.0
hole 93 2.4384 2.4384 0.0
hole 93 2.4384 0.8128 0.0
hole 93 2.4384 -0.8128 0.0
hole 93 2.4384 -2.4384 0.0
hole 93 0.8128 -2.4384 0.0
hole 93 -0.8128 -2.4384 0.0
hole 93 -2.4384 -2.4384 0.0
hole 93 -2.4384 -0.8128 0.0
hole 93 -2.4384 0.8128 0.0
hole 93 -2.4384 2.4384 0.0
hole 93 -0.8128 2.4384 0.0
hole 93 0.8128 2.4384 0.0
unit 95
array 55 3*0
unit 96
array 56 3*0
unit 97
array 57 3*0
unit 98
array 58 3*0
unit 99
array 59 3*0
unit 100
array 60 -6.5024 -6.5024 0.0
cuboid 3 1 4p6.7031 15.24 0.0
cuboid 2 1 4p6.9061 15.24 0.0
unit 101
array 61 3*0
'--- uo2-gd pin H18 node= 1 (site i=17, j=16) xsc= 81801
unit 102
cylinder 30 1 0.5321 15.24 0.0
cylinder 2 1 0.6134 15.24 0.0
cuboid 3 1 4p0.8128 15.24 0.0
unit 103
cylinder 31 1 0.5321 15.24 0.0
cylinder 2 1 0.6134 15.24 0.0
cuboid 3 1 4p0.8128 15.24 0.0
unit 104
cylinder 30 1 0.5321 15.24 0.0
cylinder 2 1 0.6134 15.24 0.0
unit 105
cylinder 3 1 1.6002 15.24 0.0
cylinder 2 1 1.7018 15.24 0.0
cuboid 3 1 4p3.2512 15.24 0.0
hole 104 2.4384 2.4384 0.0
hole 104 2.4384 0.8128 0.0
hole 104 2.4384 -0.8128 0.0

```

```

hole 104 2.4384 -2.4384 0.0
hole 104 0.8128 -2.4384 0.0
hole 104 -0.8128 -2.4384 0.0
hole 104 -2.4384 -2.4384 0.0
hole 104 -2.4384 -0.8128 0.0
hole 104 -2.4384 0.8128 0.0
hole 104 -2.4384 2.4384 0.0
hole 104 -0.8128 2.4384 0.0
hole 104 0.8128 2.4384 0.0
unit 106
array 62 3*0
unit 107
array 63 3*0
unit 108
array 64 3*0
unit 109
array 65 3*0
unit 110
array 66 3*0
unit 111
array 67 -6.5024 -6.5024 0.0
cuboid 3 1 4p6.7031 15.24 0.0
cuboid 2 1 4p6.9061 15.24 0.0

```

(49,636 lines deleted)

```

unit 12000
'--- non-fuelled lattice sites
cuboid 3 1 4p6.9061 381.0 0.0
'-----inter-assembly water-----
unit 12001
'--- assembly interstitial water (top/bottom)
cuboid 3 1 2p0.7139 2p6.9061 381.0 0.0
unit 12002
'--- assembly interstitial water (left/right)
cuboid 3 1 2p6.9061 2p0.7139 381.0 0.0
unit 12003
'--- assembly interstitial water (intersection)
cuboid 3 1 4p0.7139 381.0 0.0
unit 12004
'--- b4c rod unit --- inserted control rod
cylinder 5 1 0.1753 365.8 0.0
cylinder 4 1 0.2388 365.8 0.0
cuboid 3 1 4p0.244 365.8 0.0
unit 12005
'--- b4c rod unit --- critical control blade (20 notches)
cylinder 5 1 0.1753 213.4 0.0
cylinder 4 1 0.2388 213.4 0.0
cuboid 3 1 4p0.244 213.4 0.0
'-----inserted control blade-----
unit 12009
'--- control blade (top)

```

```

array 8002      -0.244 -4.6203 0.0
cuboid 4 1 2p0.3962 6.9060 -4.7625 365.8 0.0
cuboid 3 1 2p0.7139 2p6.9061 381.0 0.0

```

```

unit 12010
'--- control blade (bottom)
array 8002      -0.244 -5.6350 0.0
cuboid 4 1 2p0.3962 4.7625 -6.9060 365.8 0.0
cuboid 3 1 2p0.7139 2p6.9061 381.0 0.0

```

```

unit 12011
'--- control blade (left)
array 8001      -4.6203 -0.244 0.0
cuboid 4 1 6.9060 -4.7625 2p0.3962 365.8 0.0
cuboid 3 1 2p6.9061 2p0.7139 381.0 0.0

```

```

unit 12012
'--- control blade (right)
array 8001      -5.6350 -0.244 0.0
cuboid 4 1 4.7625 -6.9061 2p0.3962 365.8 0.0
cuboid 3 1 2p6.9061 2p0.7139 381.0 0.0

```

```

unit 12013
'--- control blade (intersection)
cuboid 4 1 4p0.7139 365.8 0.0
cuboid 3 1 4p0.7139 381.0 0.0

```

```

'-----critical control blade-----
unit 12022
'--- control blade (top)
array 8004      -0.244 -4.6203 0.0
cuboid 4 1 2p0.3962 6.9060 -4.7625 213.4 0.0
cuboid 3 1 2p0.7139 2p6.9061 381.0 0.0

```

```

unit 12023
'--- control blade (bottom)
array 8004      -0.244 -5.6350 0.0
cuboid 4 1 2p0.3962 4.7625 -6.9060 213.4 0.0
cuboid 3 1 2p0.7139 2p6.9061 381.0 0.0

```

```

unit 12024
'--- control blade (left)
array 8003      -4.6203 -0.244 0.0
cuboid 4 1 6.9060 -4.7625 2p0.3962 213.4 0.0
cuboid 3 1 2p6.9061 2p0.7139 381.0 0.0

```

```

unit 12025
'--- control blade (right)
array 8003      -5.6350 -0.244 0.0
cuboid 4 1 4.7625 -6.9061 2p0.3962 213.4 0.0
cuboid 3 1 2p6.9061 2p0.7139 381.0 0.0

```

```

unit 12026
'--- control blade (intersection)
cuboid 4 1 4p0.7139 213.4 0.0
cuboid 3 1 4p0.7139 381.0 0.0

```

```

global unit 13000
'--- reactor core
array 9000 3*0.0
reflector 3 1 6r30. 1

```

```

end geom
read array
ara= 1 nux=2 nuy=2 nuz=1 fill
    1 1 1 1 end fill
ara= 2 nux=2 nuy=4 nuz=1 fill
    1 2 1 1 1 1 2 end fill
ara= 3 nux=2 nuy=4 nuz=1 fill
    2 1 1 1 1 1 2 1 end fill

```

```

ara= 4 nux=4 nuy=2 nuz=1 fill
2 1 1 2 1 1 1 end fill
ara= 5 nux=4 nuy=2 nuz=1 fill
1 1 1 1 2 1 1 end fill
ara= 6 nux=3 nuy=3 nuz=1 fill
5 9 5
6 4 7
5 8 5 end fill
ara= 7 nux=2 nuy=2 nuz=1 fill
11 11 11 11 end fill
ara= 8 nux=2 nuy=4 nuz=1 fill
11 12 11 11 11 11 11 end fill
ara= 9 nux=2 nuy=4 nuz=1 fill
12 11 11 11 11 11 12 end fill
ara= 10 nux=4 nuy=2 nuz=1 fill
12 11 11 12 11 11 11 end fill
ara= 11 nux=4 nuy=2 nuz=1 fill
11 11 11 11 12 11 11 end fill
ara= 12 nux=3 nuy=3 nuz=1 fill
15 19 15
16 14 17
15 18 15 end fill
ara= 13 nux=2 nuy=2 nuz=1 fill
21 21 21 21 end fill
ara= 14 nux=2 nuy=4 nuz=1 fill
21 22 21 21 21 21 21 end fill
ara= 15 nux=2 nuy=4 nuz=1 fill
22 21 21 21 21 21 22 end fill
ara= 16 nux=4 nuy=2 nuz=1 fill
22 21 21 22 21 21 21 end fill
ara= 17 nux=4 nuy=2 nuz=1 fill
21 21 21 21 22 21 21 end fill
ara= 18 nux=3 nuy=3 nuz=1 fill
25 29 25
26 24 27
25 28 25 end fill
ara= 19 nux=2 nuy=2 nuz=1 fill
31 31 31 31 end fill
ara= 20 nux=2 nuy=4 nuz=1 fill
31 32 31 31 31 31 31 end fill
ara= 21 nux=2 nuy=4 nuz=1 fill
32 31 31 31 31 31 32 end fill
ara= 22 nux=4 nuy=2 nuz=1 fill
32 31 31 32 31 31 31 end fill
ara= 23 nux=4 nuy=2 nuz=1 fill
31 31 31 31 32 31 31 end fill
ara= 24 nux=3 nuy=3 nuz=1 fill
35 39 35
36 34 37
35 38 35 end fill
ara= 25 nux=2 nuy=2 nuz=1 fill
41 41 41 41 end fill
ara= 26 nux=2 nuy=4 nuz=1 fill
41 42 41 41 41 41 41 end fill
ara= 27 nux=2 nuy=4 nuz=1 fill
42 41 41 41 41 41 42 end fill
ara= 28 nux=4 nuy=2 nuz=1 fill
42 41 41 42 41 41 41 end fill
ara= 29 nux=4 nuy=2 nuz=1 fill
41 41 41 41 42 41 41 end fill
ara= 30 nux=3 nuy=3 nuz=1 fill
45 49 45
46 44 47
45 48 45 end fill
ara= 31 nux=2 nuy=2 nuz=1 fill
51 51 51 51 end fill
ara= 32 nux=2 nuy=4 nuz=1 fill
51 52 51 51 51 51 51 end fill
ara= 33 nux=2 nuy=4 nuz=1 fill
52 51 51 51 51 51 52 end fill
ara= 34 nux=4 nuy=2 nuz=1 fill
52 51 51 52 51 51 51 end fill

```

```

ara= 35 nux=4 nuy=2 nuz=1 fill
51 51 51 51 52 51 51 52 end fill
ara= 36 nux=3 nuy=3 nuz=1 fill
55 59 55
56 54 57
55 58 55 end fill
ara= 37 nux=2 nuy=2 nuz=1 fill
61 61 61 61 end fill
ara= 38 nux=2 nuy=4 nuz=1 fill
61 62 61 61 61 61 61 62 end fill
ara= 39 nux=2 nuy=4 nuz=1 fill
62 61 61 61 61 61 62 61 end fill
ara= 40 nux=4 nuy=2 nuz=1 fill
62 61 61 62 61 61 61 61 end fill
ara= 41 nux=4 nuy=2 nuz=1 fill
61 61 61 61 62 61 61 62 end fill
ara= 42 nux=3 nuy=3 nuz=1 fill
65 69 65
66 64 67
65 68 65 end fill
ara= 43 nux=2 nuy=2 nuz=1 fill
71 71 71 71 end fill
ara= 44 nux=2 nuy=4 nuz=1 fill
71 72 71 71 71 71 71 72 end fill
ara= 45 nux=2 nuy=4 nuz=1 fill
72 71 71 71 71 71 72 71 end fill
ara= 46 nux=4 nuy=2 nuz=1 fill
72 71 71 72 71 71 71 71 end fill
ara= 47 nux=4 nuy=2 nuz=1 fill
71 71 71 71 72 71 71 72 end fill
ara= 48 nux=3 nuy=3 nuz=1 fill
75 79 75
76 74 77
75 78 75 end fill
ara= 49 nux=2 nuy=2 nuz=1 fill
81 81 81 81 end fill
ara= 50 nux=2 nuy=4 nuz=1 fill
81 82 81 81 81 81 81 82 end fill
ara= 51 nux=2 nuy=4 nuz=1 fill
82 81 81 81 81 81 82 81 end fill
ara= 52 nux=4 nuy=2 nuz=1 fill
82 81 81 82 81 81 81 81 end fill
ara= 53 nux=4 nuy=2 nuz=1 fill
81 81 81 81 82 81 81 82 end fill
ara= 54 nux=3 nuy=3 nuz=1 fill
85 89 85
86 84 87
85 88 85 end fill
ara= 55 nux=2 nuy=2 nuz=1 fill
91 91 91 91 end fill
ara= 56 nux=2 nuy=4 nuz=1 fill
91 92 91 91 91 91 91 92 end fill
ara= 57 nux=2 nuy=4 nuz=1 fill
92 91 91 91 91 91 92 91 end fill
ara= 58 nux=4 nuy=2 nuz=1 fill
92 91 91 92 91 91 91 91 end fill
ara= 59 nux=4 nuy=2 nuz=1 fill
91 91 91 91 92 91 91 92 end fill
ara= 60 nux=3 nuy=3 nuz=1 fill
95 99 95
96 94 97
95 98 95 end fill
ara= 61 nux=1 nuy=1 nuz=10 fill
10 20 30 40 50
60 70 80 90 100 end fill
ara= 62 nux=2 nuy=2 nuz=1 fill
102 102 102 102 end fill
ara= 63 nux=2 nuy=4 nuz=1 fill
102 103 102 102 102 102 102 103 end fill
ara= 64 nux=2 nuy=4 nuz=1 fill
103 102 102 102 102 102 103 102 end fill
ara= 65 nux=4 nuy=2 nuz=1 fill

```

```

103 102 102 103 102 102 102 102 end fill
ara= 66 nux=4 nuy=2 nuz=1 fill
102 102 102 102 103 102 102 103 end fill
ara= 67 nux=3 nuy=3 nuz=1 fill
106 110 106
107 105 108
106 109 106 end fill
.
.
.

```

(16,431 lines deleted)

```

'--- control rod b4c arrays
' fully inserted
ara=8001 nux=21 nuy=1 nuz=1 fill 21r12004 end fill
ara=8002 nux=1 nuy=21 nuz=1 fill 21r12004 end fill
' critical height rod
ara=8003 nux=21 nuy=1 nuz=1 fill 21r12005 end fill
ara=8004 nux=1 nuy=21 nuz=1 fill 21r12005 end fill
'
'--- reactor core array - layout map
ara=9000 nux=59 nuy=59 nuz=1 fill
12000 12001 12000 12001 12000 12001 12000 12001 12000 12001
12000 12001 12000 12001 12000 12001 8787 12009 7878 12001
6868 12009 11716 12001 4343 12009 2929 12001 11615 12009
11615 12001 2929 12009 4343 12001 11716 12009 6868 12001
7878 12009 8787 12001 12000 12001 12000 12001 12000 12001
12000 12001 12000 12001 12000 12001 12000 12001 12000 12002
12003 12002 12003 12002 12003 12002 12003 12002 12003 12002
12003 12002 12003 12002 12003 12011 12013 12012 12003 12011
12013 12012 12003 12011 12013 12012 12003 12011 12013 12012
12003 12011 12013 12012 12003 12011 12013 12012 12003 12011
12013 12012 12003 12002 12003 12002 12003 12002 12003 12002
12003 12002 12003 12002 12003 12002 12003 12002 12000 12001
12000 12001 12000 12001 12000 12001 12000 12001 12000 12001
12000 12001 9797 12001 8686 12010 7777 12001 6767 12010
5555 12001 4242 12010 2828 12001 11514 12010 11514 12001
2828 12010 4242 12001 5555 12010 6767 12001 7777 12010
8686 12001 9797 12001 12000 12001 12000 12001 12000 12001
12000 12001 12000 12001 12000 12001 12000 12002 12003 12002
12003 12002 12003 12002 12003 12002 12003 12002 12003 12002
12003 12002 12003 12002 12003 12002 12003 12002 12003 12002
12003 12002 12003 12002 12003 12002 12003 12002 12003 12002
12003 12002 12003 12002 12003 12002 12003 12002 12003 12002
12003 12002 12003 12002 12003 12002 12000 12001 12000 12001
12000 12001 12000 12001 12000 12001 11413 12001 11312 12009
9696 12001 8585 12001 7676 12001 6666 12009 5454 12001
4141 12001 2727 12001 1313 12009 1313 12001 2727 12001
4141 12001 5454 12009 6666 12001 7676 12001 8585 12001
9696 12009 11312 12001 11413 12001 12000 12001 12000 12001
12000 12001 12000 12001 12000 12002 12003 12002 12003 12002
12003 12002 12003 12002 12003 12002 12003 12011 12013 12012
12003 12002 12003 12002 12003 12011 12013 12012 12003 12002
12003 12002 12003 12011 12013 12012 12003 12002 12003 12002
12003 12011 12013 12012 12003 12002 12003 12002 12003 12011
12013 12012 12003 12002 12003 12002 12003 12002 12003 12002
12003 12002 12003 12002 12000 12001 12000 12001 12000 12001
12000 12001 12000 12001 10807 12001 11211 12010 9595 12001
8484 12001 7575 12001 6565 12010 5353 12001 4040 12001
2626 12001 11110 12010 11110 12001 2626 12001 4040 12001
5353 12010 6565 12001 7575 12001 8484 12001 9595 12010
11211 12001 10807 12001 12000 12001 12000 12001 12000 12001
12000 12001 12000 12002 12003 12002 12003 12002 12003 12002
12003 12002 12003 12002 12003 12002 12003 12002 12003 12002

```


12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12000	12001	12000	12001	12000	12001	12000	12001
11009	12009	10706	12001	10201	12009	9494	12001	8383	12009
7474	12001	6464	12009	5252	12001	3939	12009	2525	12001
1111	12009	1111	12001	2525	12009	3939	12001	5252	12009
6464	12001	7474	12009	8383	12001	9494	12009	10201	12001
10706	12009	11009	12001	12000	12001	12000	12001	12000	12001
12000	12002	12003	12002	12003	12002	12003	12002	12003	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12002	12003	12002	12003	12002	12003	12002
12000	12001	12000	12001	10908	12001	10807	12001	10706	12010
10605	12001	10100	12010	9393	12001	8282	12010	7373	12001
6363	12010	5151	12001	3838	12010	10504	12001	1010	12010
1010	12001	10504	12010	3838	12001	5151	12010	6363	12001
7373	12010	8282	12001	9393	12010	10100	12001	10605	12010
10706	12001	10807	12001	10908	12001	12000	12001	12000	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12000	12001
12000	12001	10403	12009	10302	12001	10201	12001	10100	12001
9999	12009	9292	12001	8181	12001	7272	12001	6262	12009
9898	12001	3737	12001	2323	12001	909	12009	909	12001
2323	12001	3737	12001	9898	12009	6262	12001	7272	12001
8181	12001	9292	12009	9999	12001	10100	12001	10201	12001
10302	12009	10403	12001	12000	12001	12000	12002	12003	12002
12003	12011	12013	12012	12003	12002	12003	12002	12003	12011
12013	12012	12003	12002	12003	12002	12003	12011	12013	12012
12003	12002	12003	12002	12003	12011	12013	12012	12003	12002
12003	12002	12003	12011	12013	12012	12003	12002	12003	12002
12003	12011	12013	12012	12003	12002	12003	12002	12003	12011
12013	12012	12003	12002	12003	12002	12000	12001	9797	12001
9696	12010	9595	12001	9494	12001	9393	12001	9292	12010
9191	12001	8080	12001	9090	12001	6161	12010	8989	12001
3636	12001	8888	12001	808	12010	808	12001	8888	12001
3636	12001	8989	12010	6161	12001	9090	12001	8080	12001
9191	12010	9292	12001	9393	12001	9494	12001	9595	12010
9696	12001	9797	12001	12000	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	8787	12009	8686	12001	8585	12009
8484	12001	8383	12009	8282	12001	8181	12009	8080	12001
7979	12009	7070	12001	6060	12009	4848	12001	3535	12009
2121	12001	707	12009	707	12001	2121	12009	3535	12001
4848	12009	6060	12001	7070	12009	7979	12001	8080	12009
8181	12001	8282	12009	8383	12001	8484	12009	8585	12001
8686	12009	8787	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	7878	12010	7777	12001	7676	12010	7575	12001
7474	12010	7373	12001	7272	12010	7171	12001	7070	12010
6969	12001	5959	12010	4747	12001	3434	12010	2020	12001
606	12010	606	12001	2020	12010	3434	12001	4747	12010
5959	12001	6969	12010	7070	12001	7171	12010	7272	12001
7373	12010	7474	12001	7575	12010	7676	12001	7777	12010
7878	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002

12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
6868	12001	6767	12001	6666	12009	6565	12001	6464	12001
6363	12001	6262	12009	6161	12001	6060	12001	5959	12001
5858	12009	5757	12001	3333	12001	1919	12001	505	12009
505	12001	1919	12009	3333	12001	5757	12009	5858	12001
5959	12001	6060	12001	6161	12009	6262	12001	6363	12001
6464	12001	6565	12009	6666	12001	6767	12001	6868	12002
12003	12002	12003	12011	12013	12012	12003	12002	12003	12002
12003	12011	12013	12012	12003	12002	12003	12002	12003	12011
12013	12012	12003	12002	12003	12002	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12002
12003	12002	12003	12011	12013	12012	12003	12002	12003	12002
12003	12011	12013	12012	12003	12002	12003	12002	5656	12001
5555	12001	5454	12010	5353	12001	5252	12001	5151	12001
5050	12010	4949	12001	4848	12001	4747	12001	4646	12010
4545	12001	3232	12001	4444	12001	404	12010	404	12001
4444	12010	3232	12001	4545	12010	4646	12001	4747	12001
4848	12001	4949	12010	5050	12001	5151	12001	5252	12001
5353	12010	5454	12001	5555	12001	5656	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	4343	12009	4242	12001
4141	12009	4040	12001	3939	12009	3838	12001	3737	12009
3636	12001	3535	12009	3434	12001	3333	12009	3232	12001
3131	12009	1717	12001	3030	12009	3030	12001	1717	12009
3131	12001	3232	12009	3333	12001	3434	12009	3535	12001
3636	12009	3737	12001	3838	12009	3939	12001	4040	12009
4141	12001	4242	12009	4343	12011	12013	12012	12003	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	2929	12010	2828	12001	2727	12010
2626	12001	2525	12010	2424	12001	2323	12010	2222	12001
2121	12010	2020	12001	1919	12010	1818	12001	1717	12010
1616	12001	202	12010	202	12001	1616	12010	1717	12001
1818	12010	1919	12001	2020	12010	2121	12001	2222	12010
2323	12001	2424	12010	2525	12001	2626	12010	2727	12001
2828	12010	2929	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	1515	12001	1414	12001	1313	12009	1212	12001
1111	12001	1010	12001	909	12009	808	12001	707	12001
606	12001	505	12009	404	12001	303	12001	202	12001
101	12009	101	12001	202	12001	303	12001	404	12009
505	12001	606	12001	707	12001	808	12009	909	12001
1010	12001	1111	12001	1212	12009	1313	12001	1414	12001
1515	12002	12003	12002	12003	12011	12013	12012	12003	12002
12003	12002	12003	12011	12013	12012	12003	12002	12003	12002
12003	12011	12013	12012	12003	12002	12003	12002	12003	12011
12013	12012	12003	12002	12003	12002	12003	12011	12013	12012
12003	12002	12003	12002	12003	12011	12013	12012	12003	12002
12003	12002	12003	12011	12013	12012	12003	12002	12003	12002
1515	12001	1414	12001	1313	12010	1212	12001	1111	12001
1010	12001	909	12010	808	12001	707	12001	606	12001
505	12010	404	12001	303	12001	202	12001	101	12010
101	12001	202	12001	303	12001	404	12010	505	12001
606	12001	707	12001	808	12010	909	12001	1010	12001
1111	12001	1212	12010	1313	12001	1414	12001	1515	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002

12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	2929	12009
2828	12001	2727	12009	2626	12001	2525	12009	2424	12001
2323	12009	2222	12001	2121	12009	2020	12001	1919	12009
1818	12001	1717	12009	1616	12001	202	12009	202	12001
1616	12009	1717	12001	1818	12009	1919	12001	2020	12009
2121	12001	2222	12009	2323	12001	2424	12009	2525	12001
2626	12009	2727	12001	2828	12009	2929	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12011	12013	12012	4343	12010	4242	12001
4141	12010	4040	12001	3939	12010	3838	12001	3737	12010
3636	12001	3535	12010	3434	12001	3333	12010	3232	12001
3131	12010	1717	12001	3030	12010	3030	12001	1717	12010
3131	12001	3232	12010	3333	12001	3434	12010	3535	12001
3636	12010	3737	12001	3838	12010	3939	12001	4040	12010
4141	12001	4242	12010	4343	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
5353	12001	5252	12001	5151	12001	5050	12009	4949	12001
4848	12001	4747	12001	4646	12009	4545	12001	3232	12022
4444	12001	404	12009	404	12001	4444	12009	3232	12001
4545	12009	4646	12001	4747	12001	4848	12001	4949	12009
5050	12001	5151	12001	5252	12001	5353	12009	5454	12001
5555	12001	5656	12002	12003	12002	12003	12011	12013	12012
12003	12002	12003	12002	12003	12011	12013	12012	12003	12002
12003	12002	12003	12011	12013	12012	12003	12024	12026	12025
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12002	12003	12002	12003	12011	12013	12012
12003	12002	12003	12002	12003	12011	12013	12012	12003	12002
12003	12002	6868	12001	6767	12001	6666	12010	6565	12001
6464	12001	6363	12001	6262	12010	6161	12001	6060	12001
5959	12001	5858	12010	5757	12001	3333	12023	1919	12001
505	12010	505	12001	1919	12010	3333	12001	5757	12010
5858	12001	5959	12001	6060	12001	6161	12010	6262	12001
6363	12001	6464	12001	6565	12010	6666	12001	6767	12001
6868	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
7878	12009	7777	12001	7676	12009	7575	12001	7474	12009
7373	12001	7272	12009	7171	12001	7070	12009	6969	12001
5959	12009	4747	12001	3434	12009	2020	12001	606	12009
606	12001	2020	12009	3434	12001	4747	12009	5959	12001
6969	12009	7070	12001	7171	12009	7272	12001	7373	12009
7474	12001	7575	12009	7676	12001	7777	12009	7878	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	8787	12010
8686	12001	8585	12010	8484	12001	8383	12010	8282	12001
8181	12010	8080	12001	7979	12010	7070	12001	6060	12010
4848	12001	3535	12010	2121	12001	707	12010	707	12001
2121	12010	3535	12001	4848	12010	6060	12001	7070	12010
7979	12001	8080	12010	8181	12001	8282	12010	8383	12001
8484	12010	8585	12001	8686	12010	8787	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002

12003	12002	12003	12002	12003	12002	12000	12001	9797	12001
9696	12009	9595	12001	9494	12001	9393	12001	9292	12009
9191	12001	8080	12001	9090	12001	6161	12009	8989	12001
3636	12001	8888	12001	808	12009	808	12001	8888	12001
3636	12001	8989	12009	6161	12001	9090	12001	8080	12001
9191	12009	9292	12001	9393	12001	9494	12001	9595	12009
9696	12001	9797	12001	12000	12002	12003	12002	12003	12011
12013	12012	12003	12002	12003	12002	12003	12011	12013	12012
12003	12002	12003	12002	12003	12011	12013	12012	12003	12002
12003	12002	12003	12011	12013	12012	12003	12002	12003	12002
12003	12011	12013	12012	12003	12002	12003	12002	12003	12011
12013	12012	12003	12002	12003	12002	12003	12011	12013	12012
12003	12002	12003	12002	12000	12001	12000	12001	10403	12010
10302	12001	10201	12001	10100	12001	9999	12010	9292	12001
8181	12001	7272	12001	6262	12010	9898	12001	3737	12001
2323	12001	909	12010	909	12001	2323	12001	3737	12001
9898	12010	6262	12001	7272	12001	8181	12001	9292	12010
9999	12001	10100	12001	10201	12001	10302	12010	10403	12001
12000	12001	12000	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12003	12002	12003	12002	12003	12002	12003	12002
12003	12002	12000	12001	12000	12001	10908	12001	10807	12001
10706	12009	10605	12001	10100	12009	9393	12001	8282	12009
7373	12001	6363	12009	5151	12001	3838	12009	10504	12001
1010	12009	1010	12001	10504	12009	3838	12001	5151	12009
6363	12001	7373	12009	8282	12001	9393	12009	10100	12001
10605	12009	10706	12001	10807	12001	10908	12001	12000	12001
12000	12002	12003	12002	12003	12002	12003	12002	12003	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12011	12013	12012	12003	12011	12013	12012
12003	12011	12013	12012	12003	12011	12013	12012	12003	12011
12013	12012	12003	12002	12003	12002	12003	12002	12003	12002
12000	12001	12000	12001	12000	12001	12000	12001	11009	12010
10706	12001	10201	12010	9494	12001	8383	12010	7474	12001
6464	12010	5252	12001	3939	12010	2525	12001	1111	12010
11									

```

12000 12001 12000 12001 12000 12001 12000 12001 9797 12001
8686 12009 7777 12001 6767 12009 5555 12001 4242 12009
2828 12001 11514 12009 11514 12001 2828 12009 4242 12001
5555 12009 6767 12001 7777 12009 8686 12001 9797 12001
12000 12001 12000 12001 12000 12001 12000 12001 12000 12001
12000 12001 12000 12002 12003 12002 12003 12002 12003 12002
12003 12002 12003 12002 12003 12002 12003 12002 12003 12011
12013 12012 12003 12011 12013 12012 12003 12011 12013 12012
12003 12011 12013 12012 12003 12011 12013 12012 12003 12011
12013 12012 12003 12011 12013 12012 12003 12002 12003 12002
12003 12002 12003 12002 12003 12002 12003 12002 12003 12002
12003 12002 12000 12001 12000 12001 12000 12001 12000 12001
12000 12001 12000 12001 12000 12001 12000 12001 8787 12010
7878 12001 6868 12010 11716 12001 4343 12010 2929 12001
11615 12010 11615 12001 2929 12010 4343 12001 11716 12010
6868 12001 7878 12010 8787 12001 12000 12001 12000 12001
12000 12001 12000 12001 12000 12001 12000 12001 12000 12001
12000

```

```

end fill

```

```

' end lattice description

```

```

end array

```

```

read bounds xyf=void zfc=void end bounds

```

```

read plot pic=mat

```

```

xul=0 yul=456.0 zul=200.0 xlr=456.0 ylr=0 zlr=200.0

```

```

uax=1 vdn=-1 nax=300 end plot

```

```

end data

```

```

end

```


INTERNAL DISTRIBUTION

1. S. M. Bowman	24. B. D. Murphy
2. B. L. Broadhead	25-29. C. V. Parks
3-8. W. C. Carter	30. L. M. Petrie
9. M. D. DeHart	31. R. T. Primm
10. R. J. Ellis	32. R. W. Roussin
11. M. B. Emmett	33. J. C. Ryman
12-16. I. C. Gauld	34. C. H. Shappert
17. J. C. Gehin	35. J. C. Wagner
18. O. W. Hermann	36. R. M. Westfall
19. D. T. Ingersoll	37. R. Q. Wright
20. M. A. Kuliasha	38. Laboratory Records-RC
21. S. K. Lichtenwalter	39-40. Laboratory Records for Submission to
22. S. B. Ludwig	OSTI
23. G. E. Michaels	41. Central Research Library

EXTERNAL DISTRIBUTION

42. M. G. Bailey, Office of Nuclear Material Safety & Safeguards, U.S. Nuclear Regulatory Commission, MS 13 D13, Washington, DC 20555
43. L. Barrett, Office of Civilian Radioactive Waste Management, RW-232 20545, U.S. Department of Energy, Washington, DC 20545
44. C. J. Benson, Bettis Atomic Power Laboratory, P.O. Box 79, West Mifflin, PA 15122
45. M. C. Brady-Raap, P.O. Box 1950, MISN R1-43, Richland, WA 99352
46. R. J. Cacciapouti, Yankee Atomic Electric Co., 1617 Worcester Rd., Framington, MA 01701
47. D. E. Carlson, U.S. Nuclear Regulatory Commission, Spent Fuel Project Office, MS 13 D13, Washington, DC 20555
48. J. Clark, 2650 Park Tower Drive, Suite 800, Vienna, VA 22180
49. J. Conde, Consejo de Seguridad Nuclear, Justo Dorado, 11, 28040 Madrid, Spain
50. D. R. Connors, Bettis Atomic Power Laboratory, P.O. Box 79, West Mifflin, PA 15122
51. W. Davis, Framatome Cogema Fuels, 1261 Town Center Drive, Las Vegas, NV 89134
52. T. W. Doering, Framatome Cogema Fuels, 1261 Town Center Drive, Las Vegas, NV 89134
53. P. Finck, Argonne National Lab., 9700 S. Cass Ave., Bldg. 360, Argonne, IL 60439

54. H. Geiser, Wissenschaftlich-Technische Ingenieurberatung GmbH, P.O. Box 13 40, 52410 Julich, Federal Republic of Germany
55. N. Gulliford, Winfrith Technology Centre, 306/A32, AEA Technology PLC, Winfrith, Dorchester, Dorset DT2 8DH
56. S. Hanauer, U.S. Department of Energy, RW-22, Washington, DC 20545
57. L. Hassler, Babcock & Wilcox, P.O. Box 10935, Lynchburg, VA 24506-0935
58. D. Henderson, Framatome Cogema, 1261 Town Center Drive, Las Vegas, NV 89134
59. G. Kirchner, University of Bremen, FB 1 Postfach 330440, D-W-2800 Bremen 33, Federal Republic of Germany
60. C. Kouts, Office of Civilian Radioactive Waste Management, RW-36, U.S. Department of Energy, Washington, DC 20545
61. W. H. Lake, Office of Civilian Radioactive Waste Management, U.S. Department of Energy, RW-46, Washington, DC 20585
62. D. Lancaster, 2650 Park Tower Drive, Suite 800, Vienna, VA 22180
63. Y. L. Liu, Argonne National Laboratory, 9700 S. Cass Ave., Bldg.308, Argonne, IL 60439-4825
64. M. Mason, Transnuclear, Two Skyline Drive, Hawthorne, NY 10532-2120
65. A. Michaels, Electric Power Research Institute, 3412 Hillview Ave., Palo Alto, CA 94304
66. M. Mount, Lawrence Livermore National Laboratory, P.O. Box 808, Livermore, CA 94550
67. Dominic Napolitano, NISYS Corporation, 4233 Pleasant Hill Road, Suite 200, Duluth, GA 30096
68. C. W. Nilsen, Office of Nuclear Material Safety and Safeguards, U.S. Nuclear Regulatory Commission, MS 10 K8, Washington, DC 20555
69. P. Noel, Framatome Cogema, 1261 Town Center Drive, Las Vegas, NV 89134
70. Office of the Assistant Manager for Energy Research and Development, Department of Energy Oak Ridge Operations (DOE-ORO), P.O. Box 2008, Oak Ridge, TN 37831
71. N. L. Osgood, U.S. Nuclear Regulatory Commission, Office of Nuclear Materials Safety and Safeguards, MS 13 D13, Washington, DC 20555
72. O. Ozer, Electric Power Research Institute, 3412 Hillview Ave., Palo Alto, CA 94304
73. V. A. Perin, U.S. Nuclear Regulatory Commission, Office of Nuclear Materials Safety and Safeguards, MS T7 F3, Washington, DC 20555
74. M. Rahimi, U.S. Nuclear Regulatory Commission, Office of Nuclear Materials Safety and Safeguards, MS T7 F3, Washington, DC 20555
75. D. Salmon, Framatome Cogema, 1261 Town Center Drive, Las Vegas, NV 89134
76. E. Sartori, OECD Data Bank, 12 Bd des Iles, 92130 Issy-les-Moulineaux, France
77. M. Smith, U.S. Department of Energy, Yucca Mountain Project Office, 101 Convention Center Dr., Las Vegas, NV 89190
78. M. Smith, Virginia Power Co., P.O. Box 2666, Richmond, VA 23261
79. H. Taniuchi, Kobe Steel, Ltd., 2-3-1 Shinhamma, Arai-Cho, Takasago, 676 Japan
80. D. A. Thomas, Framatome Cogema, 1261 Town Center Drive, Las Vegas, NV 89134
81. P. Thorne, BNFL, Nuclear and Radiological Safety, R101 Rutherford House, Risley Warrington, WA3 6AS
82. M. E. Wangler, U.S. Department of Energy, EH-33.2, Washington, DC 20585-0002

83. A. Wells, 2846 Peachtree Walk, Duluth, GA 30136
84. W. Weyer, Wissenschaftlich-Technische Ingenieurberatung GMBH, Mozartstrasse 13, 5177 Titz-Rodingen, Federal Republic of Germany
85. B. H. White, IV, U.S. Nuclear Regulatory Commission, Spent Fuel Project Office, MS 13 D13, Washington, DC 20555
86. J. Williams, Office of Civilian Radioactive Waste Management, U.S. Department of Energy, RW-46, Washington, DC 20545
87. M. L. Williams, LSU Nuclear Science Center, Baton Rouge, LA 70803
88. C. J. Withee, U.S. Nuclear Regulatory Commission, Spent Fuel Project Office, MS 13 D13, Washington, DC 20555
89. R. Yang, Electric Power Research Institute, 3412 Hillview Ave., Palo Alto, CA 94304