Disclaimer

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference therein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed therein do not necessarily state or reflect those of the United States Government or any agency thereof.

Acknowledgments

The US DOE National Energy Technology Laboratory (NETL) would like to acknowledge the contributions of workshop participants, listed in Appendix A, for sharing their knowledge and providing valuable input for NETL's sensor and control program.

NETL would also like to thank the keynote speakers for stimulating presentations that served as a basis for the breakout discussions, SAIC Conference Management for organizing the workshop, and volunteer facilitators and note keepers for documenting participant input.

Contents

Executive Summary

I Introduction

II General Session Summary

III Breakout Session Summary I—Power Generation Technologies

III A. Sensor and Control Needs for Advanced Combustion and Gasification

III B. Sensor and Control Needs for Turbines

III C. Sensor and Control Needs for Environmental Controls

III D. Sensor and Control Needs for Fuel Cells

IV Breakout Session Summary II—Sensor/Control Technologies

IV A. Physical Measurements/Diagnostic Maintenance Sensors

IV B. Chemical/Emission Sensors and Instrumentation

IV C. Advanced Controls

List of Abbreviations

Appendix A: List of Participants

Appendix B: Visuals From Keynote Speakers

Robert Romanosky, NETL Power Systems Advanced Research Product Manager, *Welcome, Presentation of Workshop Goals, Overview of Vision 21*

Robert Frank, Director of EPRI's Instrumentation and Control Center, *Current Research and Needs—Future Sensors and Controls Needs for the Power Industry*

Galen Fisher, Principal Research Scientist for Delphi Automotive Systems,
Automotive Sensors for Improved On-Board Control and Diagnostics”

Carl Bauer, NETL Office of Coal & Environmental Systems Associate
Director, *An Overview of NETL and the Office of Coal and Environmental
Systems*

Appendix C: Workshop Agenda and Workshop Discussion Topics With Questions

List of Tables

- 1 High-Priority Sensor Needs for Advanced Combustion and Gasification
- 2 High-Priority Control Needs for Advanced Combustion and Gasification
- 3 High-Priority Sensor and Control Needs for Turbines
- 4 High-Priority Sensor and Control Needs for Environmental Control Technologies
- 5 General Specifications for High-Temperature Measurement
- 6 Potential Technologies for High-Temperature Measurement
- 7 Potential Technologies To Determine Solid Flow Rate
- 8 Technologies To Monitor Flame Quality
- 9 High-Priority Chemical and Emission Sensor Technologies and Applications

Executive Summary

Higher operating efficiencies, emission reductions, improved reliability, and lower operating costs are benefits that the power industry can realize with the utilization of sensors and controls. However, for the power industry to derive the maximum benefit from sensors and controls, improvements in existing technologies and novel approaches to challenging measurements are needed.

Recognizing the importance of sensors and controls, the U.S. Department of Energy (DOE) National Energy Technology Laboratory (NETL) sponsored a sensors and controls workshop on April 17 to 18, 2001, in Washington, DC. The workshop focused on identifying technology needs in sensors and controls for existing fossil-energy power plants as well as future facilities conceived under the Vision 21 Program. Forty-six experts from 29 organizations, including private industry, research laboratories, academia, and government agencies, attended the workshop.

The meeting opened with keynote speakers from NETL and the private sector. NETL officials spoke of the Vision 21 and advanced research programs. Speakers from the Electric Power Research Institute (EPRI) and Delphi Automotive Systems Research Laboratory discussed the improvements realized with their respective operation through the use of sensors and controls.

NETL keynote speakers Robert Romanosky and Carl Bauer emphasized that developing sensor and control systems plays a critical role in DOE Office of Fossil Energy Vision 21 Program, clean coal activities under the Power Plant Improvement Initiative, and the proposed Clean Coal Power Initiative. The Vision 21 Program is aimed at providing technologies for ultra-clean fossil-fuel-based energy production with 60- to 75-percent efficiencies and near zero emissions. The program also uses a modular approach to present opportunities to not only generate power, but also co-produce clean fuels, chemicals, steam, and other useful products. The ultra-high efficiency and environmental performance goals of the Vision 21 Program mean that facilities must operate at optimum conditions, while adapting in real-time to changes in load and feedstock. These are challenging performance goals. They will require advanced control and sensing systems that can be adapted and optimized in real time. To improve the overall plant performance of existing power plants, one of the most cost-effective methods is to update the sensor and control systems.

Robert Frank, Director of the Instrumentation and Control Center for EPRI, presented the results of a demonstration project that retrofitted the Tennessee Valley Authority (TVA) Kingston Station Power Plant Unit 9 with updated sensors and controls. Benefits derived from that project included improvements in heat rate, reduction in loss-on-ignition and nitrogen oxides (NO_x) emissions, and improved plant reliability and responsiveness. Mr. Frank also discussed potential benefits available to existing U.S. fossil-based power systems. It was estimated that a 1-percent improvement in efficiency gained from a controls-and-sensors retrofit would result in

\$409 million in annual fuel savings. A 1-percent increase in availability, as a benefit of improved control and accurate sensing, would result in an additional 5,000 MW of capacity without the addition of power generation equipment.

Galen Fisher of Delphi Automotive Systems Research Laboratory discussed the benefits—improved efficiency and reduced emissions—that sensors, controls, and diagnostics have brought to the automotive industry.

Parallel discussions were held on advanced combustion/gasification, turbines, fuel cells, and environmental controls to identify and prioritize near-term (0–5 years) and long-term (5–15 years) needs. Near-term needs may improve existing power-plant performance as well as meet Vision 21 Program goals. Long-term needs are aimed primarily at supporting the Vision 21 Program. Following identification of prioritized needs, breakout sessions were held on emerging sensor and control technologies.

Workshop participants recommended that sensors need to be developed or improved for on-line or in-situ applications under harsh conditions (high temperature, high pressure, corrosive environment, and presence of particulate). Sensor development needs to focus on robustness and accuracy, while balancing longevity with cost. Self-diagnostic and drift quantification capabilities of individual sensors will be an essential feature of new “smart” sensors.

Balancing the fuel/air ratio in combustion systems is a key to improving power generation efficiency and reducing emissions. To achieve an optimum fuel/air ratio where thermal NO_x formation is lowest and flame stability is acceptable, several areas of measurement and control are of interest: flame quality, fuel supply, physical conditions, and chemical composition of the combustion zone. Flame quality data can be extracted by a variety of methods, including acoustic, electrical, and optical technologies. However, the challenge is to transform the data into meaningful information that can be used by the control system.

In the area of fuel supply, accurate on-line measurement of solid fuel flow needs to be developed. While microwave, electric, and acoustic technologies have been attempted, more work is still needed. In addition to flow rate, feedstock characterization was identified as a long-term need for use with advanced control systems. As alternative fuels are being utilized, this measurement will grow in importance. Accurate on-line feed-stock characterization should help proper mixing of fuels, ensure appropriate heat content, allow predictive control of the combustion process, and manage contaminants appropriately throughout the system.

Accurate monitoring of the physical conditions within combustion and gasification systems remains a high-priority need, because current on-line technologies cannot withstand the harsh conditions, particularly those found inside gasifiers and turbines. While the specific applications for a gasifier and turbine differ, the primary need is to develop materials and technologies capable of accurately detecting gas path and surface temperatures (as high as 3,000 °F for gasifiers and 4,000 °F for turbines) in high-pressure corrosive environments.

Sensors to monitor chemical composition, primarily emission constituents, remain a high priority. On-line, in-situ measurement systems capable of performing near the combustion zone

are seen as essential for an active, integrated control system where emission information is used as real-time input for plant-operation adjustments. Examples include on-line mercury measurements, in-situ NO_x sensors, and on-line particulate monitors (size and concentration). While some of these methods are commercially available, most measurement tools have been designed for stack monitoring and need to be improved for use near the combustion zone.

The development and implementation of advanced controls were discussed in every session and were identified as important needs for both existing and future power generation facilities. Participants recognized that existing facilities could benefit substantially from implementing advanced computerized control systems that are commercially available. Identified areas of interest included integrated control for total plant optimization, improved modeling of combustion and instability, standardization, and dynamic controls. To facilitate DOE's Vision 21 Program with its modular yet interdependent components, an umbrella approach was deemed appropriate. A high-level control system may also be used to track feedstock supply, system output, maintenance, and cost. At the individual modular-system level, the need to develop smart feedback or feed-forward controls utilizing neural networks and predictive models was discussed. Validation of models was also deemed an important feature of advanced controls development.

Valuable information was gained from the participants' input at the workshop. Information sharing was viewed as mutually beneficial for NETL's sensors and controls program as well as the participants. The information compiled in this report will assist in aligning NETL's Advanced Research Program development efforts in sensors and controls with both the DOE Vision 21 Program and future funding considerations. While it is recognized that more discussions are needed, particularly in the areas of advanced controls and emerging sensor technology, the information contained in this report may serve as a basis for the research and development community to focus its efforts more effectively in the higher priority areas.

I Introduction

The U.S. Department of Energy (DOE) National Energy Technology Laboratory (NETL) is the nation's largest fossil-fuel research organization. NETL leads DOE's efforts to develop cleaner, more efficient, and more cost-effective technologies for fossil fuel uses. One of these efforts is the development of advanced process control strategies and technologies, including advanced sensors and intelligent controls, so that power generation equipment operates in a safe, efficient, and environmentally sound manner. NETL has recognized that innovations in sensors and controls are needed as a concurrent effort to foster the full-scale implementation of new, more efficient power generation technologies. In addition, existing power plants benefit greatly with installations of new sensors and controls. Retrofits of this kind replace outdated instrumentation and controls of limited capability and result in many high value benefits at comparably low costs.

Specific benefits for both existing and future power generation facilities include lower operating and maintenance costs, higher efficiencies, reduced emissions, enhanced responsiveness to market and load fluctuations, and increased availability. These benefits are significant, especially in a deregulated market with high demands for power.

An example of the benefits obtained from upgrading instrumentation and controls is the Tennessee Valley Authority (TVA) Kingston Plant Unit 9 where a distributed control system and modern instrumentation increased the heat rate, improved loss on ignition (LOI), reduced nitrogen oxides (NO_x), and led to overall improvement in plant performance.

Improved performance leads to significant savings and profits. Approximately \$409 million can be saved annually in existing fossil-based power plants in the United States by implementing advanced sensor and control technology. This estimate, provided by the Electric Power Research Institute (EPRI), was based on a 1-percent increase in efficiency. Other benefits include improved plant availability and enhanced responsiveness to load changes. A 1-percent increase in availability will make an additional 5,000 megawatts (MW) of capacity available without major capital investments. Higher efficiency will improve control of NO_x and carbon monoxide (CO) emissions and reduce greenhouse gases and solid waste. Increased efficiency reduces fuel costs for individual plants, which positively impacts the facility's competitiveness in the open market. For a 500 MW unit similar to the Kingston Number 9 Unit, approximately \$390,000 can be saved in fuel per year with a 1-percent increase in efficiency through the use of advanced sensor and control technology. A 1-percent increase of availability for the same plant will generate an additional profit of \$1.5 million at a retail price of \$0.06/kWh.

To tap these potential benefits, NETL is supporting advancements in sensor and control technology, including sponsoring a 2-day workshop on April 17 to 18, 2001, in Washington, D.C. The workshop aimed to identify and prioritize sensor and control needs for power generation technologies. The purpose was to identify those needs that enhance the performance of existing facilities and enable the full-scale implementation of Vision 21 power generation

technologies. Short-term (0-5 years) development priorities would support existing and future facilities, and a long-term (5-15 years) goals would primarily support the Vision 21 Program.

A summary of the general session is provided along with information from seven individual breakout sessions. Four sessions focused on the sensor and control needs for advanced combustion and gasification, turbines, fuel cells, and environmental control technologies. Follow-up sessions focused on the relevant technologies and issues in (1) physical measurement and diagnostic sensors, (2) chemicals and emission sensors, and (3) advanced controls.

NETL's Power Systems Advanced Research Program, in the Office of Coal and Environmental Systems, will use the information to shape their program in sensors and controls. This program is aimed at supporting novel or revolutionary technologies that will drive advancements in sensors and controls. The program will also capitalize on NETL's ability to screen and accept risk associated with novel technologies as well as the ability to deploy successful sensor and control technologies concurrent with advanced power generation technologies.

II General Session Summary

General session presentations provided an overview of NETL's programs and outlined the benefits derived from implementing advanced instrumentation sensors and controls. Robert Romanosky, Product Manager for Power Systems Advanced Research at NETL, and Carl Bauer, Associated Director for the Office of Coal and Environmental Programs, introduced NETL and the DOE Vision 21 Program. The importance of advanced sensors and controls with respect to the Vision 21 Program, and the opportunities for novel approaches through the Advanced Research Program, were discussed. Robert Frank, Director of EPRI's Instrumentation and Control Center, described current activities in instrumentation, sensors, and control deployment. He presented the benefits from retrofitting TVA's Kingston 500-MW unit with advanced controls and instrumentation. Galen Fisher, of Delphi Automotive Systems, described the sensors and controls used in automobiles to improve the fuel efficiency, reduce emissions, and enhance diagnostic capability. The four presentations illustrated the importance of sensors and control research, and gave the attendees useful background information for the breakout discussions.

Robert Romanosky conveyed the goals of the workshop and the roles that sensor and control development plays in the Power Systems Advanced Research (PSAR) and Vision 21 programs. The PSAR program is crosscutting research and development (R&D) that bridges the gap between fundamental science and advanced engineering by supporting research that overcomes technical barriers and explores innovative concepts. NETL's instrumentation, sensors and controls systems (ISCS) programs will collaborate and crosscut other areas to develop technologies applicable to power generation and environmental control technologies. The PSAR program also encompasses programs in coal utilization science, materials, metallurgical processes, bioprocessing, university coal research, historically black colleges and universities (HBCU), and small business innovative research (SBIR). The Vision 21 Program is a long-range, industry-driven effort to develop ultra-clean, fossil-fuel-based energy plants with unprecedented efficiency. Sensors and controls have been identified as an enabling technology for Vision 21 plants.

Carl Bauer introduced NETL's missions and programs, emphasizing the dramatic growth in world energy use. To meet the growing need for affordable, clean energy, the abundant U.S. coal resources need to be tapped. The environmental issues related to fossil-energy power systems will continue to be addressed. Technology efforts like those at NETL have helped to significantly reduce pollutant emissions since 1970, including sulfur oxides (SO_x), NO_x , and particulate matter from coal powered plants. Current programs are aimed towards multi-pollutant control, including fine particulates ($\text{PM}_{2.5}$) and mercury, and greenhouse gas reduction.

The time-phased and market-driven strategy consists of the following three phases:

1. Develop environmental control and efficiency improvement technologies for existing fleets by 2005;

2. Develop next generation gasification, advanced combustion systems, improved materials, and advanced sensors and controls for retrofit/re-powering markets by 2010; and
3. Integrate advanced enabling technologies, including gas separation, carbon dioxide (CO₂) capture, fuel cells, advanced turbines, novel gasifiers for Vision 21 plants, and carbon sequestration by 2015.

Robert Frank described the research and development activities at EPRI's instrumentation and control (I&C) center at the Kingston Fossil Plant near Knoxville, Tennessee. The I&C center participated in retrofitting TVA's Kingston Unit 9 with a distributed control system (DCS) and upgraded the instrumentation. The retrofit significantly improved heat rate, reduced loss on ignition (LOI), and reduced NO_x emissions. The improvements generated financial and environmental benefits. To illustrate the potential benefits obtained from sensors and controls, Mr. Frank said that a 1-percent improvement in efficiency will yield over \$390,000 in savings in fuel costs for an average 500-MW plant. A more significant benefit is the improvement of plant availability and agility. A 1-percent increase in plant availability will generate \$1.5 million in additional gross profit for a 500-MW plant at a retail price of \$0.06/kWh. Other benefits include reduced emissions, solid waste, and disposal costs.

Galen Fisher of Delphi Automotive Systems discussed the improved fuel efficiency and emission performance obtained through the integrated use of advanced sensors and controls. The automobile's integrated control and sensor system may serve as a reference for other industries that convert fossil energy to power. Approximately 12 different sensors are utilized in the power train of today's automobiles to keep the air and fuel ratio at an optimum range. Sensor outputs for airflow, temperature, fuel, and oxygen content in the exhaust gas are fed to a control system to maintain an optimum air/fuel (A/F) ratio while driving. Sensor and control systems are also important for emission performance: a three-way catalytic converter that reduces CO, NO_x, and hydrocarbon emissions. Because the three-way catalytic converter for reducing emissions only works at a very narrow range in A/F ratio, the successful reduction of all three pollutants depends critically on the accurate closed-loop control of the A/F ratio. The automobile's electronic control module and sensors provide this accurate closed-loop control of the A/F ratio.

Virtual Schematic of Vision 21 Energy Plant

III Breakout Session Summary I Power Generation Technologies

III.A Sensor and Control Needs for Advanced Combustion and Gasification

Sensor and control needs for advanced combustion and gasification include existing and future facilities. The discussion focused on systems that utilize coal as the primary feedstock. The needs identified for advanced combustion and gasification are similar, but sensor specifications and applications differ, since conditions in a gasifier are more severe than those found in a boiler. General instrumentation and sensor needs are outlined in Table 1. Table 2 outlines participant feedback for advanced controls. The data were not assigned a priority because of time limitations.

R&D on diagnostics and distributed sensing were identified as needs; however, these points were not discussed in detail because of time limitations and lower priority. The session concluded with the following general recommendations from the participants:

- Rugged, robust, and reliable sensors are essential for the complex and harsh environment of advanced, Vision 21 combustion and gasification technologies. Instrumentation and sensors should (1) include self-calibrating capabilities and have high reliability and longevity; (2) be designed for and operate at high pressures and high temperatures; and (3) be corrosion resistant. However, cost should be balanced with performance and longevity.

- Development of combustion stoichiometry controls and required sensors for air and fuel staging are necessary for the near term and long term.
- Solid and gas fuel flow actuators must be developed to close feedback loops.
- DOE needs to work with industry to develop standards for sensors and controls. Such standards will facilitate modularity.

Table 1: High-Priority Sensor Needs for Advanced Combustion and Gasification

Sensor Need	Purpose	Time Frame	Comments
Flame Imaging Sensor	Flame image is an important indicator of combustion status. It can be used to check the A/F ratio for improved efficiency and lower emissions.	0-5 years	<ul style="list-style-type: none"> • Optimal sensor should be spatially resolved and provide a three-dimensional account of the flame. • May monitor one or all characteristics, including species, temperature, uniformity, flame shape.
Particulate Sensor On-line Particle Measurement Instrumentation	<p>Particulate sensors are used for both pre- and post-combustion processes.</p> <p><u>Pre-combustion applications:</u></p> <ul style="list-style-type: none"> • Monitor fuel particle size for complete combustion. • Improve fuel sizing operations. • Monitor particulate in gas stream to protect turbines. <p><u>Post-combustion applications:</u></p> <ul style="list-style-type: none"> • Fine particulate (PM_{2.5}) monitoring and control (also see Table 4). • Dust/soot control (e.g., diesel soot). 	0-5 years and 5-15 years	<ul style="list-style-type: none"> • Sensing/determining particle size is a high priority. • Measuring/determining particulate concentration is a high priority. • Particle velocity is another important property. • Low-density stream for post-combustion applications, and dense stream for pre-combustion applications. • Flue gas application for combustion (also see Table 4). • High temperatures, elevated pressures, and corrosive conditions expected in gasification applications.
Solid Feedstock Flow Measurement On-line Solid Feedstock Analysis	<p>Solid feedstock flow is another important quantity to be measured to control A/F ratio, so that better efficiency and lower emissions can be achieved.</p> <p>Feedstock analysis will further quantify the Btu and other components in the fuel stream for efficient combustion and effective emission reduction. Analysis is also important for fuel blending to facilitate usage of opportunity fuels.</p>	0-5 years 5-15 years	<ul style="list-style-type: none"> • Must withstand high temperatures. • Must be an on-line measurement. • Coal is the primary solid fuel for flow measurement. • Alternative fuel flow measurement is a long-term need. • Improvement to solid level indication is also needed. • Btu, composition, water/moisture, contaminants are properties for on-line feedstock characterization. • Monitor on-line fuel contaminants such as mercury.
Emission, Toxic, Contaminant Sensors	Emission control is a major concern for combustion and gasification. In addition to analyzing feedstock as discussed above, measurement of the combustion product (also see Table 4) is required to control combustion/gasification. Other contaminants (such as alkali) will cause equipment deterioration: e.g., fouling, deposition, and corrosion.	0-5 years	<ul style="list-style-type: none"> • On-line sensors for real time monitoring and control. • Ability to operate under harsher conditions than in the stack. • Detect total mercury and speciated forms. • Combined flue gas sensing (e.g., NO_x, SO₂, Hg). • On-line gaseous alkali monitor for gasification. • Detect carbon content in ash. • Tar monitor.

Table 2. High-Priority Control Needs for Advanced Combustion and Gasification

Control Need	Purpose	Time Frame	Comments
Fast Boiler Control and Lean Burn Control	Fast boiler control can accommodate changes in demand and feedstock. Lean burn control is aimed at minimizing NO _x emissions.	0-5 years	<ul style="list-style-type: none"> • Response time for actuators is a limiting factor that should be addressed. • Some commercial packages for fulfilling this purpose need be examined.
Solid Flow Control	Controlling solid flow is an important component in adjusting and maintaining the A/F ratio.	0-5 years and 5-15 years	<ul style="list-style-type: none"> • Solid feedstock and coal flow splitter by metering or actuation. • Achieve homogeneous gas/particle flow.
Closed Loop A/F Control and Optimization	Closed loop control can more accurately control A/F ratio to enhance efficiency and reduce NO _x emissions.	0-5 years	<ul style="list-style-type: none"> • Similar to needs listed above. • Improve overall system control by controlling A/F ratio and NO_x emissions. • Downstream systems will perform better. • Closed-loop control will require actuators with fast response time and high accuracy.
Signal Standardization	Signal standardization will permit open communication and systems integration.	0-5 years and 5-15 years	<ul style="list-style-type: none"> • Standardize signals to control system for entire plant.
Neural nets, Dynamic Controls, And Predictive Control	More advanced controls are aimed at making the system more adaptive to changes in load and feedstock.	0-5 years and 5-15 years	<ul style="list-style-type: none"> • Capture operator's knowledge. • Smart logic-based controls and real-time optimization. • Simultaneously respond to rapid changes in feedstock, load demand, and other transients. • Need adequate number of sensors or instrumentation to support advanced controls.

III.B Sensor and Control Needs for Turbines

The gas turbine breakout session discussed several sensors and control needs that were identified from previous reports or workshops. A discussion topic list, provided in Appendix C, was reviewed by the participants and prioritized with primary consideration for natural gas turbines.

Participants identified an overwhelming need to develop sensors that are in-situ, non-intrusive, or embedded to provide a real-time account of turbine operation and component status. However, one of the primary barriers is the limited access to penetrate the turbine with in-situ methods. Embedding sensors are a potential area for development, but the basic need is to develop materials, technologies, or approaches that can withstand high temperatures and respond rapidly. After overcoming the barriers of access and temperature, a total sensing approach is desired to enhance the operation and reliability of gas turbines. Although turbine manufacturers did not participate, participants acknowledged that implementation of in-situ or embedded sensors will likely proceed through manufacturers.

High-priority items were ranked as near-term goals to enhance the operation of existing turbines as well as facilitate the development of new turbines. (See Table 3 on the next page.)

III.C Sensor and Control Needs for Environmental Controls

New or significantly improved technologies, sensors, or controls are to facilitate the operation of environmental control technologies. For this breakout session, some of the environmental control technologies considered were electrostatic precipitators (ESPs) and

Table 3. High-Priority Sensor and Control Needs for Turbines

Sensor or Control Need	Purpose	Time Frame	Comments
Particulate Sensor	Monitor particulate in fuel and inlet flows to turbine.	0-5 years	<ul style="list-style-type: none"> • Low ppm level particulate sensor for fuel and air flows. • Used for general turbine operation and protection.
Fast Pressure Sensor	Monitor operation and performance of turbine.	0-5 years	<ul style="list-style-type: none"> • Millisecond response time needed. • Able to detect or measure absolute or differential pressure.
Air- and Fuel-Flow Sensors	To control individual nozzle or burner for system optimization.	0-5 years	<ul style="list-style-type: none"> • Couple with other sensors for closed-loop control. • Flow sensors are to maintain high efficiency and reduce emissions.
Flame Monitor	Needed to monitor and control combustion to maintain high efficiency and ensure reliability.	0-5 years	<ul style="list-style-type: none"> • Monitor combustion zone, flame stability. • High temperatures may be a barrier for some on-line continuous technologies.
Temperature Sensor	Temperature sensors give key information on working medium and equipment status.	0-5 years	<ul style="list-style-type: none"> • Monitor surface temperature (up to 4,000 °F). • Monitor gas path temperature (up to 4,500 °F). • Materials limitations.
Sensor to Monitor Thermal Barrier Coating	To protect turbine components.	0-5 years	<ul style="list-style-type: none"> • On-line monitoring of thermal barrier coating degradation. • Sensors will likely need to be embedded. • High temperature in the hot-gas-path region.
Control Algorithms and Software	Real time, rapid, and remote data collection and analysis to optimize operation and predict maintenance.	0-5 years	<ul style="list-style-type: none"> • Work is ongoing in this area but focused only on the turbine operation. • Transient conditions, startups, and shutdowns may also benefit from rapid data collection and interpretation.
Integrated Controls	Optimize turbine operation with balance-of-plant operations.	0-5 years	<ul style="list-style-type: none"> • Does not appear to be a technical challenge. • Should be examined further given the new plant construction and expected growth.
Diagnostic Sensors	To monitor health of turbine components.	0-5 years 5-15 years	<ul style="list-style-type: none"> • Off-line technologies are an option but on-line is preferred. • Specific diagnostics sensors other than those mentioned above need to be identified and prioritized. • Support a total sensing system for maximum performance.

selective catalytic reduction (SCR) systems for NO_x control. Protecting fuel cells from catalyst poisons was also discussed. The regulation and control of mercury and the potential for carbon dioxide management through carbon sequestration were discussed as evolving environmental control technology areas.

Specific areas of interest in sensors and controls for environmental controls are listed on the next page.

- • Mercury
- • NO_x
- • Particulate
- • Alkali
- • Ammonia
- • Flame quality
- • Feedstock characterization
- • Carbon monoxide, carbon dioxide
- • Hydrogen, hydrogen chloride
- • Integrated and predictive controls
- • Ash quality
- • SO_x
- • Water quality

Table 4 (on the next page) lists the higher-priority sensor and control needs; however, the relative importance of these measurements may shift as developments in the technology progress. Ash quality, sulfur dioxide, and water quality were also identified, but were not assigned a high priority relative to the other sensor and control needs.

III.D Sensor and Control Needs for Fuel Cells

The following were identified as generic sensor needs for fuel cells:

- • Flow within the fuel-cell stack
- • Hydrogen (H₂)
- • Carbon monoxide (CO)
- • Hydrogen chloride (HCl)
- • Oxygen (O₂)
- • Sulfur species
- • Stack temperature with rapid response times

Participants in this session referred to the report *Sensor Needs and Requirements for Proton-Exchange Membrane and Fuel Cell Systems and Direct-Injection Engines* published by Lawrence Livermore National Laboratory. They felt that the report addressed the needs adequately and provided specifications for the proton-exchange membrane (PEM) fuel cell. The session did not have the expected attendees, therefore participants opted to forgo a detailed discussion. It was concluded that while fuel-cell development is highly proprietary, sensor development is an opportunity for shared technology development between vendors and manufacturers. More discussion is needed on other types of fuel cells (e.g., solid oxide).

**Table 4. High-Priority Sensor and Control Needs for
Environmental Control Technologies**

Sensor or Control Need	Purpose	Time Frame	Comments
Mercury	Mercury emission is expected to be regulated. Sensors and instrumentation are needed to monitor emissions and facilitate the operation of mercury control technologies.	0-5 years 5-15 years	<ul style="list-style-type: none"> Proposed as a regulated constituent. Continuous emissions monitoring (CEM) system potentially required on power plants by 2007. Mercury analyzers are being developed and offered commercially, but accuracy improvements are needed. Quantifying the speciated forms of mercury (elemental, oxides, and chloride) is desired. Mercury chemistry research is under way.
NO _x	An important regulated constituent. Monitoring NO _x near the combustion zone would provide real-time NO _x data to optimize NO _x control.	0-5 years 5-15 years	<ul style="list-style-type: none"> Commercially available analyzer is an extractive stack measurement where conditions are moderate. Develop accurate in-situ NO_x sensors for high temperatures and harsher conditions than stacks. Use data for closed-loop control to optimize combustion and NO_x control systems.
Particulate	Regulation of fine particulate (PM _{2.5}) is expected, and reliable monitoring technologies are needed.	0-5 years 5-15 years	<ul style="list-style-type: none"> Continuous on-line monitoring is desired but is a substantial challenge. Detect particle size, distribution, and concentration. Spatial resolution desired over point measurements.
CO, HCl	To protect the catalyst in proton exchange membrane (PEM) fuel cells.	0-5 years 5-15 years	<ul style="list-style-type: none"> Concern for PEM fuel cells; develop concurrently. Micro-sensor with high accuracy is needed. Not a concern for solid oxide or molten carbonate fuel cells.
Integrated and Predictive Controls	Current environmental sensors and analyzers are used to monitor emissions at the stack only. Integration of real-time data into plant control is expected to be more efficient and effective.	0-5 years 5-15 years	<ul style="list-style-type: none"> Integrate environmental monitoring systems with combustion and steam control systems. Use sensors/controls for combustion system to predict emissions and guide operation of the environmental control technologies, such as SCR and selective non-catalytic reduction (SNCR) systems.
Ammonia	Ammonia is used for NO _x control technologies. A sensor is needed to reduce ammonia slip.	0-5 years	<ul style="list-style-type: none"> Optimize operation of SCR and SNCR systems. Combined with NO_x sensor for high-temperature operation for closed-loop control. Prevent ash contamination.
CO ₂	CO ₂ sequestration technologies need sensors to monitor operation and leakage.	5-15 years	<ul style="list-style-type: none"> Develop concurrently with carbon sequestration technologies. Investigate technologies to further define need.
Alkali	Gaseous alkali is corrosive, and needs to be monitored to protect high-temperature systems.	5-15 years	<ul style="list-style-type: none"> Measuring gaseous alkali would facilitate preventative maintenance. Applicable to high-temperature systems, such as gasifiers and turbines.
Feedstock Characterization	Controlling emissions would be better achieved by on-line feedstock characterization to track fuel variation, fuel blending, and A/F ratio.	5-15 years	<ul style="list-style-type: none"> Supports Vision 21 Program and alternative fuel utilization. On-line solid fuel characterization will be a challenge. Can be used for predictive and dynamic control.

IV Breakout Session Summary II

Sensor/Control Technologies

IV.A Physical Measurements/Diagnostic Maintenance Sensors

Substantial improvements in basic physical measurements are needed in advanced power generation technologies where the environment is extremely harsh. While the specifications for a particular sensor vary with the power generation technology, the barriers associated with the measurements are similar. Hence, overcoming a barrier, such as high temperature materials, would benefit all applications irrespective of the specifications.

Previously identified sensor needs, listed below, are classified as physical or diagnostic measurement needs.

Physical Measurements

- • Temperature
- • Solids flow
- • Flame quality
- • Pressure

Diagnostic Measurements

- Corrosion
 - Thermal barrier coating failure
- Component degradation
 - Alkali
- Sensor self-diagnostic capability
- Refractory contouring

Because of time limitations, discussions focused on identifying emerging technologies for high-temperature measurement, solids flow, and flame quality. The general specifications for high temperature measurements outlined by participants are listed in Table 5.

Table 5. General Specifications for High-Temperature Measurement

Power Generation Technology	Temperature	Pressure	Other
Gasification	3,000 °F	600 psi	• Slagging and reducing environment, particulates present.
Turbine (gas path)	4,500 °F	400 psi	• Fast response, oxidizing environment.
Turbine (surface)	4,000 °F	400 psi	• Fast response, oxidizing environment .
Combustion	1,500 °F	100 psi	• Spatial resolution, oxidizing environment, particulates present.

These general specifications can be further defined to evaluate a specific technology and application. For any application, the measurement technology must (1) be able to quantify drift, (2) self calibrate, and (3) be highly robust. Longevity goals outlined for the power generation technology include

- years for combustion,
- 1 year for gasifiers, and
- 500 hours for turbines (near-term) and 1 year (long-term).

The primary barrier identified for high-temperature measurements is the temperature limitations of the materials themselves. Work is under way to develop new materials and approaches. Barriers for non-contact optical technologies used to measure temperature include dirty windows, penetration into vessels, optical path contamination, light pipe chemical degradation, black body interference, low emissivity, and high cost. Of these, the primary issue is fouling of the optical window or ports, followed by cost for full-scale implementation. Table 6 lists potential or emerging technologies for high-temperature measurements.

Table 6. Potential Technologies for High-Temperature Measurement

Technology	Type	Comment
Thermocouple	Contact	<ul style="list-style-type: none"> • Thermocouples extend to 2,054 °C (3,729 °F) in a benign atmosphere. Wires limited to 3,500 °F in inert atmosphere and 1,200 °F in oxidizing environment. • Need sheaths that resist corrosion and erosion. However, response times may be slow.
Sapphire Probe/Fiber Optics	Contact	<ul style="list-style-type: none"> • Sapphire probe/fiber optics can operate at temperature of 2,200 °C (3,992 °F) in a harsh atmosphere. • Issues for high-temperature gasification applications currently being addressed include corrosion, vibration, performance near upper temperature limitation, response in slagging environment. • Commercially available up to 1,200 °C (2,192 °F) in oxidizing atmosphere.
Other Contact Technologies	Contact	<ul style="list-style-type: none"> • Resistive transmission, resistance change, resistance temperature detector (RTD) 650 °C (1,202 °F) limit. • Thin film thermocouples, Johnson Noise.
Two-Color Infrared Absorption	Non-contact	<ul style="list-style-type: none"> • Gas path measurement performs well in clean gas atmosphere with black body interference. • Used in steel mill gas-stream application up to 3,000 °F, but is separated from a corrosive or reducing atmosphere and operates at ambient pressure. • Using mid infrared (IR) tunable laser.
Phosphor Thermometry	Contact	<ul style="list-style-type: none"> • Point, imaging, and surface measurement. • Up to 1,200 °C (2,160 °F) for surface measurement. • Current focus is to adapt technology for slagging gasifiers. • Hydrogen sulfide may poison the phosphor material.
Infrared Pyrometer	Non-contact	<ul style="list-style-type: none"> • Prototype developed by Texaco and tested to 4,500 °F at lab and pilot scale. • Being prepared for field testing at Tampa Electric's Polk Power Station.
Time Domain Refractometer	Non-contact	<ul style="list-style-type: none"> • Uses a probe and has length limitation, tested to 1 m.
Gas-Phase Acoustic	Non-contact	<ul style="list-style-type: none"> • Low frequency, not sensitive to particulate. Tested and used at temperatures ranging from 2,200 to 3,300 °F at atmospheric pressure. • Sensitive to types of gas, but material is not a barrier. • Relating acoustic data to temperature is application-specific.
Other Non-Contact Approaches	Non-contact	<ul style="list-style-type: none"> • FT/IR pyrometer, millimeter wave pyrometer, coherent anti-Stokes Raman scattering (CARS) system, and low-frequency pulse, broadband

Several types of flows and flow regimes exist in a power generation facility. The critical flows identified include flow in a fuel cell, steam flow at high temperature, multiphase flow, solids flow, and energy content flow. The focus of the group's discussion was limited to solids flow with interest in balancing the A/F ratio to individual burners. Potential technologies for solid flow measurement are listed in Table 7.

General specifications identified for solids flow measurement include:

- Temperatures ranging from 200 to 350 °F,
- Pressures ranging from 0 to 400 psi,
- Response time of 1 s to 1 min,
- Five percent relative accuracy,
- Up to 14 in. inside diameter (ID) and 20,000 lb/hr for individual burners, and
- Continuous measurement.

Table 7. Potential Technologies To Determine Solid Flow Rate

Technology	Comments
Microwave	<ul style="list-style-type: none"> • Relative measurement, sensitive to moisture and particle size. • Pipe geometry may affect measurement. Complex system to extract flow rate data. • Cost may be high. Being tested in the field. • No other competing technologies closer to commercialization.
Static Charge	<ul style="list-style-type: none"> • Particles gather static charge as they move. • Moisture and rank dependent; outside interference. • Problems with alternative feedstocks may occur. • Being field tested and may be a low-cost technology.
Passive Acoustic	<ul style="list-style-type: none"> • Uses accelerometer at elbow to provide a relative measurement. • Technique is under development and a potentially low-cost approach. • Frequency interference needs to be examined.
Active Acoustic	<ul style="list-style-type: none"> • Technology to measure velocity and density. • Doppler to measure velocity and ultrasonic (500 kHz to 1 MHz) for density. • Two measurements stand alone. A relative measurement. • Technology is not commercial. Potentially a low-cost approach.
Beam Deflection	<ul style="list-style-type: none"> • Measures momentum. • Material probe deflection. • Material and sampling issues. • Erosion is a problem.
Metering Valves	<ul style="list-style-type: none"> • Commercially available. • Size limitations and maintenance issues. Not flow responsive.
Optical Technologies	<ul style="list-style-type: none"> • Can be used for dilute phases. Not applicable to coal feed pipes. • Measure flow at the surface. These technologies require windows.

Temperature and flow are basic measurements needed to control and optimize processes. Monitoring the flame control in combustion and turbine processes is also a primary function that facilitates control and optimization. The goal associated with measurement is to collect real-time data on flame characteristics and provide closed-loop active control of the combustion process and individual burners. Because of the high interest in this area, technologies to monitor flame quality were discussed and are summarized in Table 8.

Several technologies appear to be available to extract information about the flame. However, translating the data (without manual interpretation) into meaningful signals for the control system needs to be addressed. In addition, experience with implementing, operating and maintaining flame monitoring systems needs to be collected to document the benefits and identify improvement areas.

Table 8. Technologies To Monitor Flame Quality

Technology	Comments
Flame Ionization	<ul style="list-style-type: none">• Used to detect flashback in a turbine. Currently being tested on a turbine test rig.• Sensor is expected to be low cost, simple, and durable.• Technology is being investigated by NETL in-house researchers.• Efforts focus on relating signal to useful information for flame quality and control.
Chemi-Luminescence	<ul style="list-style-type: none">• Commercially available at reasonable cost.• Barriers associated with the accessibility of the turbine.
Flicker (High) Frequency	<ul style="list-style-type: none">• Commercially available at low cost.• More applicable to boilers.• Untried on turbines because of flame access issues.
Cameras CCD, IR, UV	<ul style="list-style-type: none">• Commercially available.• Unclear about sampling rate and timely electronic data interpretation.• Software and models need to be developed or debugged.• Issues with port access, port location, and maintaining line of sight need to be addressed, but are application-dependent.
Photo-Acoustic Laser	<ul style="list-style-type: none">• Commercially available, but at high cost.• Has been attempted. Can be coupled with laser excitation to gain information.• Wave guides can be used to “listen” and gather specific data.• Used in automotive applications to detect leaks.• Data interpretation is a barrier.
Passive Acoustic	<ul style="list-style-type: none">• Has been attempted at an R&D level, but not on a full-scale combustion system.• Need to test on a single burner to develop pattern recognition.• Use chaotic processes and apply to neural net to relate acoustic data for control purposes.• Cost is expected to be low.

Micro-electrical mechanical (MEM) devices were also discussed briefly at the closure of the physical measurements/diagnostic maintenance sensors session. It was recognized that MEM devices have many useful applications and possibilities. However, the direct application of today’s MEM devices for power generation systems may not be appropriate for the near term, primarily because of their temperature limitations (600 °C/1,080 °F). In some cases, the presence of particulate in a stream or gas sample precludes the use of MEM devices. It was agreed that they are an exciting and promising field and may prove to be very useful for diagnostic purposes in power generation technologies. For the near term, MEM devices will act as an enabling technology that may help to reduce the size and cost of other instruments. A long-term goal is to identify suitable materials that withstand the higher temperatures found in today’s power generation systems.

IV.B Chemical/Emission Sensors and Instrumentation

The specific sensor needs for environmental controls were identified in a previous breakout session along with other chemical sensors that would benefit power generation technologies. In this session, several high-priority chemical and emission sensor needs were discussed and are summarized in Table 9.

Table 9. High-Priority Chemical and Emission Sensor Technologies and Applications

Mercury	Development Objective	<ul style="list-style-type: none"> On-line or in-situ stack CEM for total mercury (0-5 years). On-line/in-situ technologies to measure speciated forms of mercury (0-15 years).
	General Comment	<ul style="list-style-type: none"> Total mercury expected to be regulated in the near term. Mercury chemistry evaluation will help development of measurement technologies. Detect mercury species (elemental, oxides, chloride) in addition to total mercury. Mercury analyzers for feedstock contaminants is an option. Measurement will help to develop mercury abatement technologies. Performance of existing mercury analyzers is unproven.
	Status	<ul style="list-style-type: none"> Laboratory technologies exist. On-line technologies for total mercury are entering marketplace.
NO _x	Development Objective	<ul style="list-style-type: none"> Reliable in-situ sensors suitable for stack emissions as well as accurate measurements close to the combustion zone.
	General Comment	<ul style="list-style-type: none"> Regulated constituent. In-situ sensors at stack remain a high near-term priority. In-situ sensors to monitor the combustion zone (near- and long-term goal). Combustion zone sensors will make SCR/SNCR systems more efficient. In-situ sensors close to combustion zone can optimize combustion processes. Combustion zone sensors need to withstand elevated temperatures (700-2,300 °F), particulate, and other potentially interfering combustion gases. NO_x sensors are not commercially available or proven. Instrumentation validation for emission reporting can be very challenging. NO_x mapping helps staged combustion and special A/ F control. Sensors can be used to monitor exhaust gases from turbine.
	Status	<ul style="list-style-type: none"> Stack CEMs are commercially available. Extractive systems most common.
Particulate	Development Objective	<ul style="list-style-type: none"> Develop on-line technologies to measure particulate (2-10 µm) concentration and size distribution. Spatial resolution also desired.
	General Comment	<ul style="list-style-type: none"> Need to detect/measure particle size, concentration, and size and spatial distribution. Regulated emission. Beneficial to monitor performance of filters used in gasification and other gas cleanup technologies. Beneficial for turbine and fuel cell operation.
	Status	<ul style="list-style-type: none"> Current technologies use filter collection that can only measure total particulate with batch measurement.
CO	Development Objective	<ul style="list-style-type: none"> Detect low concentration levels of CO.
	General Comment	<ul style="list-style-type: none"> Required to tolerate 1,500 °F, 200 psi, and oxidizing, reducing environment, and variable O₂ content. High priority for low-concentration measurement in fuel cell operation. Can be used to monitor boiler and gasifier operation.
	Status	<ul style="list-style-type: none"> Extractive systems available.
HCl	Development Objective	<ul style="list-style-type: none"> Detect low concentration levels of HCl.
	General Comment	<ul style="list-style-type: none"> Required to measure at ppb level. Needed in the inlet of fuel cells and to monitor syngas cleanup.
	Status	<ul style="list-style-type: none"> Sensor not currently commercially available.
Alkali	Development Objective	<ul style="list-style-type: none"> Detect concentration of gaseous alkali species.
	General Comment	<ul style="list-style-type: none"> No reliable analyzer for low-level measurement currently exists. Needed for high-temperature atmospheres present in gasifiers. Help to protect turbine blades and facilitate preventative maintenance. Enhance on-line diagnostic capability. Sampling and analyzing gas at elevated temperatures is a barrier for accurate measurement.
	Status	<ul style="list-style-type: none"> Currently not commercially available.

The following considerations were offered relative to the sensor needs outlined above and other gaseous species present in fossil-fuel based systems:

- Gas measurement sensors must be capable of operating at high temperature (3,000 °F).
- Monitoring hydroxy/methoxy (OH/CH) radicals for combustion controls should be included for temporal or spatial resolution.
- Spatially resolved sensors will provide the necessary data to validate models.
- Multi-component sensor arrays in a single sensing unit coupled with artificial intelligence to speciate and quantify gases is an emerging technology. Sensor-array electronic-noise-pattern recognition technologies could eliminate or minimize interference.
- Significant improvements in real-time gas analysis technologies have been made, but areas still open for improvement include tunable laser, robust in-situ probes, better sampling systems, low-cost gas speciation, and on-line solid fuel feedstock characterization.

IV.C Advanced Controls

The importance of advanced controls was discussed throughout the workshop. Controls are a component of a facility or a unit that interact with and affect all aspects of its operation. Thus, improving controls presents opportunities to influence cost, power output, and environmental performance.

Participants in this session touched on several key issues and offered a wealth of suggestions for both existing and future facilities. The discussion notes have been divided into three categories: Vision 21 systems, existing facilities, and general considerations. It was recognized that while a lot of information was gained in this session, more discussion is needed

in the area of controls to develop the ideas and suggestions in greater detail, particularly for standardized communication and Vision 21 systems.

Considerations for Advanced Controls for a Vision 21 Modular Facility

- The Vision 21 modular system will require an advanced, multi-level control system with a high degree of integration and utilizing a master/supervisory control-system approach.
- Multi-level control systems need to include control of the individual devices, followed by unit, process, system, and plant.
- The master/supervisory control system should include cost, supply, maintenance, load demand, eco-factors, emissions, and efficiency.
- A whole system approach, which includes integrated, multi-level advanced controls, must also include the relationship of the sensors and actuation with the control system. Improvements in sensors and actuators need to occur to derive the benefit from using advanced controls. The use of advanced control logic can compensate for areas where sensing is not available or for slow response times of sensors and actuators.
- Evaluations of Vision 21 systems are needed to determine specific areas for control system development.
- Control system development needs to be broader than just fuel cells, turbines, gasifiers, or boilers.
- System development should define, develop, and characterize performance with the following characteristics: timely, flexible, capable of dealing with complex system, robust, algorithmic, and smart.
- Simulation and engineering models are needed so options for control can be evaluated effectively.
- Highly integrated, multi-level advanced controls will need standardized communication to sense, control, and respond in a timely fashion.
- Advanced control systems will need self-diagnostic capabilities.
- Predictive controls, neural networks, and other advanced controls will benefit from total sensing systems with temporal and spatial resolutions.

Considerations for Advanced Controls to Improve Existing Facilities

- There are many opportunities for current facilities to improve performance through control.
- Retrofitting is essential, and upgrades need to include digital controls.
- Several options for upgrading or replacing outdated control systems are commercially available.
- Unit upgrades are occurring along with installations of SCR and SNCR systems.
- Existing facilities need to evaluate their individual operations to determine specific improvement opportunities.
- The use of neural networks and other advanced control algorithms can prove to be highly beneficial for existing facilities.
- Universities are positioned for collaborative efforts to assist in system improvements, such as development of algorithms to overcome a specific problem.

General Considerations for Advanced Controls

- Technical and non-technical barriers associated with total system integration need to be evaluated.
- Integrating environmental monitoring into the operational control system should be considered. Emission measurement made closer to the combustion region will enable collection of real-time data so that it can be utilized by the control system in a timely manner, thus providing tighter emissions controls.
- Concurrent with sensor and control development, opportunities to improve actuation should be pursued. Without fast and accurate actuation, the benefits of an advanced control system will be less than expected.
- Controlling dynamics is important and universities are positioned to assist with these issues.
- Whole system simulators are a good stepping stone and benchmark for advanced controls.
- Shortcomings in high temperature and pressure measurements exacerbate control difficulties.

List of Abbreviations

A/F	air/fuel
CARS	coherent anti-Stokes Raman scattering (system)
CEM	continuous emissions monitoring (system)
DCS	distributed control system
DOE	U.S. Department of Energy
EPRI	Electric Power Research Institute
ESP	electrostatic precipitator
FT	Fourier Transform
HBCU	historically black colleges and universities
I&C	instrumentation and control
ID	inside diameter
IR	infrared
ISCS	instrumentation, sensors, and controls systems
LOI	loss on ignition
MEM	micro-electrical mechanical
NETL	National Energy Technology Laboratory
NO _x	nitrogen oxides
OH/CH	hydroxy/methoxy
PEM	proton-exchange membrane
PSAR	Power Systems Advanced Research (program)
RTD	resistance temperature detector
SBIR	Small Business Innovative Research
SNCR	selective non-catalytic reduction
SCR	selective catalytic reduction
SO _x	sulfur oxides
TVA	Tennessee Valley Authority

•