57A-4

ENGINEERING DATA TRANSMITTAL

1. EDT

626267

[illegible]

16. KEY					
Approval Designator (F)		Reason for Transmittal (G)		Disposition (H) & (I)	
E, S, Q, D or N/A (see WHC-CM-3-5, Sec.12.7)		1. Approval 2. Release 3. Information	4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)	1. Approved 2. Approved w/comment 3. Disapproved w/comment	4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged

[illegible]

18. <u>C. Van Katwijk</u> <u>2-9-99</u> Signature of EDX Date Originator	19. <u>T. Choho</u> <u>2/2/99</u> Authorized Representative Date for Receiving Organization	20. <u>J. J. Irwin</u> <u>2/1/99</u> Design Authority/ Date Cognizant Manager	21. DOE APPROVAL (if required) Ctrl. No. ☐ Approved ☐ Approved w/comments ☐ Disapproved w/comments

S

Fisher SCHe Pressure Control Valves 5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, 5*86

Carl Van Katwijk
Numatec Hanford Co, Richland, WA 99352
U.S. Department of Energy Contract DE-AC06-96RL13200

EDT/ECN: 626267

UC: 620

Org Code: 2G300

Charge Code: 105559/A000

B&R Code: 39EW40400

Total Pages: 13

Key Words: Pressure valves – SCHe MCO

Abstract: Fisher SCHe Pressure Control Valves
CGI-SNF-D-13-P5-021

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

Release Approval

Date

Release Stamp

[Signature] 4/1/99

Approved for Public Release

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. **NA** CGI No. **CGI-SNF-D-13-P5-021**

Page 1 of 12

Title: **FISHER SCHe PRESSURE CONTROL VALVES**

5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, 5*86

SNF 3894

Section 1: Part Information

Item No.: NA	Manufacturer:	Supplier:
Mfg. Part/Model No.:	Supplier's P/N:	
Part Description:		
End Use Description:		

Section 2a: Component Information

Equipment No.: SCHe-PCV-5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, & 5*86	Specification No.: W-441-P5, Rev. 2	Manufacturer: Fisher Controls	Past P.O. No.: NA
Manufacturer's Part/Model No.: 95L-128W/1E3925 27022 Yellow for PCV-5*47, 5*67, 5*84, & 5*86 95L- 129W/1E3926 27012 Green for PCV-5*08, 5*27, 5*80, and 5*82	Equipment Supplier (if different from manufacturer): TBD		Equip. Supplier's Part No.: NA

Component Description: **These valves are self-operated spring-loaded 1/4-inch pressure-control valves made of 316 stainless steel. In combination, these valves provide preferred normal and SCHe MCO flowpaths because of their different pressure settings.**

Section 2b: Commercial Availability of the Item

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)?

☐ YES (go to #2 below)

☒ NO (go to procedure step 5.3.2, proceed to dedicate Item)

2. List of Candidate qualified suppliers or ISO 9000 suppliers - **NA**
company name & type contact name phone

NA

3. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): **NA**

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. **NA** CGI No. **CGI-SNF-D-13-P5-021**

Page 2 of 12

Title: **FISHER SCHe PRESSURE CONTROL VALVES**

5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, 5*86

SNF 3894

Section 2a CGI Determination

1. Question #1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?
☐ YES (the Item is not commercial grade)
☒ NO (continue)
2. Question #2: Is the Item used in applications other than nuclear facilities or activities?
☐ NO (the item is not commercial grade)
☒ YES (continue)
3. Question #3: Is the Item ordered from manufacturer/supplier on the basis or specifications set forth in the manufacturers catalog?
☐ NO (the Item is not commercial grade)
☒ YES (continue)

☒ All three criteria have been satisfied. The Item meets the definition of commercial grade.

Section 2a Reason for Dedication

The above described item is being Dedicated for use in the application cited for the following reason(s)

- ☒ Item is being purchased from a non ESL manufacturer supplier as commercial grade to be used in a Safety Class application.
- ☐ Item is being purchased from a non ESL manufacturer supplier as commercial grade to be used in a Safety Significant application.
- ☐ Item was purchased from a non ESL manufacturer supplier as commercial grade to be used in a Safety Class application.
- ☐ Item was purchased from a non ESL manufacturer supplier as commercial grade to be used in a Safety Significant application.
- ☐ Other ('like-for-like', similar, substitution, replacement evaluation)

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:

1. **PCV-5*08, 27, 47, and 67 provide final stage pressure reduction of the SCHe from the SCHe helium bottles. Valves PCV-5*80, 82, 84, and 86 provide pressure regulation from non-SCHe storage to the SCHe system. Together, these valves provide the hierarchy of preferred SCHe flow paths and function to prevent a H₂ explosion.**

2. **SCHe pressure boundary/confinement.**

3. **Maintain critical function during and after Seismic event.**

B. Part/Component Functional Mode:

Safety Function #1:

☒ Active – Mechanical or Electrical change of state is required to occur for the component to perform its safety function

☐ Passive – Change of state is not required for the component to perform its safety function

Safety Function #2:

☐ Active – Mechanical or Electrical change of state is required to occur for the component to perform its safety function.

☒ Passive – Change of state is not required for the component to perform its safety function

Safety Function #3:

☐ Active – Mechanical or Electrical change of state is required to occur for the component to perform its safety function.

☒ Passive – Change of state is not required for the component to perform its safety function

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. NA CGI No. CGI-SNF-D-13-P5-021

Page 3 of 12

Title: FISHER SCHe PRESSURE CONTROL VALVES5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, 5*86

SNF 3894

C. Host Component Safety Function (if applicable):

1.

2.

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):

1. **Valve seizure – failure of valve to operate as required. Valves PCV-5*80 and 5*82 provide redundant primary option flowpaths from the facility helium supply at 8 psig. PCV-5*08 and 5*27 provide the secondary option flowpaths from SCHe helium bottles at 7 psig. PCV-5*84 and 5*86 provide the tertiary option flowpaths from the facility helium supply at 3 psig, and PCV-5*47 and 5*67 provide the final option of SCHe from the SCHe bottles at 2 psig.**

2. **Valve body rupture - One train of SCHe would be lost. See 1 above for the four options which provide redundancy for SCHe flow.**

3.

Section 4 Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required:

Yes [ ]

No [X]

Environmental Condition B

If yes: Environmental Qualification Requirements

Limiting Environmental Conditions:

Required Safety Functions:

Qualification Period:

Natural Phenomena Hazard (NPH) Design Required:

Yes [X]

No [ ]

If yes: NPH Design Requirements

Performance Category: **PC-3**NPH Design Req'ts.: **Seismic Condition A**Required Safety Functions: **Prevent H2 Explosion; Pressure/Boundary Confinement**

HNF-PRO-97, Rev. 0

WHC-SD-CN-DGS-3006

Section 5 Component Functional Classification

[X] Safety Class (SC)

[ ] General Service

[ ] Safety Significant (SS)

If part/component classification is different from host component/system, document basis.

Section 6 (Reserved)

Section 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards:

ASME B 31.1**B16 Series**

Safety Analysis Report (SAR):

HNF-SD-SNF-SAR-002, Rev. 4A Drawings: **H-1-82165, Rev. 2****HNF-SD-SNF-SEL-002, Rev. 4**Vendor Manual/Manufacturer/Supplier Information: **Fisher Bulletin 71.4:98**Other: **NA**

12/18/98

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. NA CGI No. CGL-SNF-D-13-P5-021

Page 4 of 12

Title: FISHER SCHe PRESSURE CONTROL VALVES

5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, 5*86

SNF 3894

Section 9 - Critical Characteristics

Critical Characteristics Verification Document: Vendor Specifications; HNF-SD-SNF-SEL-002, Rev. 4	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Fisher Controls	1, IN	X	
Part/Model Number	95L-128W/1E3925 27022 Yellow or 95L-129W/1E3926 27012 Green	1, IN	X	
Nameplate Data	Per Vendor Manual	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Valve Body Material	Stainless Steel	1, T	X	
Process Connection	1/4" NTP	1, IN	X	
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Pressure Boundary	Pressure Test @ 165 Psig (No Leakage) Note 3	1, T		X
Valve Opening Pressure PCV-5*80 & 5*82 95L-129W/1E3926 27012 Green	Nominal 8 Psig	1, T		X
Valve Opening Pressure PCV-5*08 & 5*27 95L-129W/1E3926 27012 Green	Nominal 7 Psig	1, T		X
Valve Opening Pressure PCV-5*47 & 5*67 95L-128W/1E3925 27022 Yellow	Nominal 2 Psig	1, T		X
Valve Opening Pressure PCV-5*84 & 5*86 95L-128W/1E3925 27022 Yellow	Nominal 3 Psig	1, T		X
Environmental	Note 1			
Seismic Condition A	Note 2	1, T		X

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. NA CGI No. CGI-SNF-D-13-P5-021

Page 5 of 12

Title: FISHER SCHe PRESSURE CONTROL VALVES

5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, 5*86

SNF 3894

4. Notes and Legend:

1. The Pressure Control Valve and Fluoroelastomer Diaphragm and Nitrile O-ring are not subject to degradation at environmental conditions of 40°F and 60% RH or 115°F and 22% RH and are suitable for Condition B application.
2. Maintain critical function during and after Seismic event. W-441-P5, Rev. 2, Appendix I, page I-2, provides a seismic testing plan for these components at a seismic spectra TBD.
3. Pressure Test at 110% of design accident condition pressure of 150 psig.

Acceptance Method:

1. Special Test and Inspection
1, IN for Inspection
1, T for Test
2. Commercial Grade Survey
3. Source Verification
4. Vendor/Item History

Section 10 Initial Review and Approval

Approvals:

Designated Engineer: C. Van Blarney 12/21/98

Design Authority: J. P. Wain 12/16/98

QA Engineer: W. H. Hays 12/21/98

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. NA CGI No. CGI-SNF-D-13-P5-021

Page 6 of 12

Title: FISHER SCHe PRESSURE CONTROL VALVES

5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, 5*86

SNF 3894

WORKSHEET 1 DETERMINATION OF FAILURE MECHANISMS/MODES

SECTION 1

Typical Failure Mechanisms	Definition	Applicable to Component under Evaluation	
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.	Yes [ ] Mode _____	No [X]; If Yes, indicate failure
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.	Yes [ ] Mode _____	No [X]; If Yes, indicate failure
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.	Yes [ ] Mode _____	No [X]; If Yes, indicate failure
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.	Yes [ ] Mode _____	No [X]; If Yes, indicate failure
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	Yes [ ] Mode _____	No [X]; If Yes, indicate failure
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.	Yes [ ] Mode _____	No [X]; If Yes, indicate failure
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	Yes [X] Mode Valve Seizure	No [ ]; If Yes, indicate failure
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.	Yes [ ] Mode _____	No [X]; If Yes, indicate failure
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.	Yes [ ] Mode _____	No [X]; If Yes, indicate failure
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.	Yes [ ] Mode _____	No [X]; If Yes, indicate failure
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.	Yes [ ] Mode _____	No [X]; If Yes, indicate failure
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.	Yes [ ] Mode _____	No [X]; If Yes, indicate failure

Section 2: Additional Failure Modes Applicable to the Component Under Evaluation

1.	Valve Body Break
2.	
3.	
4.	
5.	

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. NA CGI No. CGI-SNF-D-13-P5-021

Page 7 of 12

Title: FISHER SCHe PRESSURE CONTROL VALVES

5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, 5*86

SNF 3894

CHECKLIST 1

ACCEPTANCE METHOD 1

SPECIAL TEST/INSPECTION VERIFICATION

SECTION 1	
Item Description: Fisher SCHe Pressure Control Valves System #: 13	Equip #: PCV-5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, & 5*86 Model #: 95L-128W/1E3925 27022 Yellow for PCV-5*47, 5*67, 5*84, & 5*86 95L- 129W/1E3926 27012 Green for PCV-5*08, 5*27, 5*80, and 5*82
Manufacturer (Address/Phone): Fisher-Rosemount, Inc 8200 Market Blvd. Chanhassen, MN 55317 P.O. #	Supplier (Address/Phone):

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	Post-Test	
☒	☐	☐	1. Manufacturer
☒	☐	☐	2. Part/Model Number
☒	☐	☐	3. Nameplate Data
☐	☒	☐	4. Valve Body Material
☒	☐	☐	5. Process Connection
☐	☒	☐	6. Pressure Boundary
☐	☒	☐	7. Valve Opening Pressure PCV-5*80 & 5*82 -- 95L-129W/1E3926 27012 Green
☐	☒	☐	8. Valve Opening Pressure PCV-5*08 & 5*27 -- 95L-129W/1E3926 27012 Green
☐	☒	☐	9. Valve Opening Pressure PCV-5*47 & 5*67 -- 95L-128W/1E3925 27022 Yellow
☐	☒	☐	10. Valve Opening Pressure PCV-5*84 & 5*86 -- 95L-128W/1E3925 27022 Yellow
☐	☒	☐	11. Seismic Condition A

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. NA CGI No. CGI-SNF-D-13-P5-021

Page 8 of 12

Title: FISHER SCHe PRESSURE CONTROL VALVES

5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, 5*86

SNF 3894

SECTION 3 BY INSPECTION

* See Attachment G of Desk Instruction for Sampling Size

Characteristic: **Manufacturer**

Sample Size*: **All Items**

Acceptance Criteria: **Fisher Controls**

Receipt Inspection Plan / Report #: _____

References (see Section 7): _____

Characteristic: **Part/Model Number**

Sample Size*: **All Items**

Acceptance Criteria: **95L-128W/1E3925 27022 Yellow**
or 95L-129W/1E3926 27012 Green

Receipt Inspection Plan / Report #: _____

References (see Section 7): _____

Characteristic: **Nameplate Data**

Sample Size*: **All Items**

Acceptance Criteria: **Per Vendor Manual**

Receipt Inspection Plan / Report #: _____

References (see Section 7): **Vendor Bulletin 71.4:98**

Characteristic: **Process Connection**

Sample Size*: **All Items**

Acceptance Criteria: **¼" NTP**

Receipt Inspection Plan / Report #: _____

References (see Section 7): _____

SECTION 4 BY SPECIAL TEST

* See Attachment G of Desk Instruction for Sampling Size

Test To Be Performed by:

☐ Purchaser

☐ Supplier/Manufacturer**

☐ Other

Number of Items to be Tested:

Test/Inspection Location:

Characteristic for Test: **Valve Body Material**

Acceptance Criteria: **Stainless Steel**

Sample Size*: **Normal Sampling Size**

Actual Test Value:

Test Plan and Report #: _____ References (see Section 7): _____

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. NA CGI No. CGI-SNF-D-13-P5-021

Page 9 of 12

Title: FISHER SCHe PRESSURE CONTROL VALVES5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, 5*86

SD+ 3894

Characteristic for Test: Pressure Boundary**Acceptance Criteria: Pressure Test @ 165 Psig (No Leakage)****Sample Size*: Destructively Test Only One Item****Actual Test Value:****Test Plan and Report #:** _____ **References (see Section 7):** _____**Characteristic for Test: Valve Opening Pressure PCV-5*80 & 5*82 -- 95L-129W/1E3926 27012 Green****Acceptance Criteria: Nominal 8 Psig****Sample Size*: Normal Sampling Size****Actual Test Value:****Test Plan and Report #:** _____ **References (see Section 7):** _____**Characteristic for Test: Valve Opening Pressure PCV-5*08 & 5*27 -- 95L-129W/1E3926 27012 Green****Acceptance Criteria: Nominal 7 Psig****Sample Size*: Normal Sampling Size****Actual Test Value:****Test Plan and Report #:** _____ **References (see Section 7):** _____**Characteristic for Test: Valve Opening Pressure PCV-5*47 & 5*67 -- 95L-128W/1E3925 27022 Yellow****Acceptance Criteria: Nominal 2 Psig****Sample Size*: Normal Sampling Size****Actual Test Value:****Test Plan and Report #:** _____ **References (see Section 7):** _____**Characteristic for Test: Valve Opening Pressure PCV-5*84 & 5*86 -- 95L-128W/1E3925 27022 Yellow****Acceptance Criteria: Nominal 3 Psig****Sample Size*: Normal Sampling Size****Actual Test Value:****Test Plan and Report #:** _____ **References (see Section 7):** _____**Characteristic for Test: Seismic Condition A****Acceptance Criteria: Maintain Critical Function During and After Seismic Event****Sample Size*: Normal Sampling Size****Actual Test Value:****Test Plan and Report #:** _____ **References (see Section 7):** _____****If Supplier/Manufacturer or Other, Refer to CGI Checklist-2 for Support Information**

Commercial Grade Item Upgrade Dedication Form

ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P5-021</u>	Rev. No. 0
Title: <u>FISHER SCHE PRESSURE CONTROL VALVES</u>		Page 10 of 12
<u>5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, 5*86</u>		<u>SNF 3894</u>

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS

ITEM DESCRIPTION:

Critical Characteristics					Verification Results						
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/TN	Procedure or RR#	Check- list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Fisher Controls	X									
Part/Model Number	95L-128W/1E3925 27022 Yellow or 95L-129W/1E3926 27012 Green	X									
Nameplate Data	Per Vendor Manual	X									
Valve Body Material	Stainless Steel	X									
Process Connection	¼" NTP	X									
Pressure Boundary	Pressure Test @ 165 Psig (No Leakage)		X								
Valve Opening Pressure PCV-5*80 & 5*82 95L-129W/1E3926 27012 Green	Nominal 8 Psig		X								
Valve Opening Pressure PCV-5*08 & 5*27 95L-129W/1E3926 27012 Green	Nominal 7 Psig		X								
Valve Opening Pressure PCV-5*47 & 5*67 95L-128W/1E3925 27022 Yellow	Nominal 2 Psig		X								
Valve Opening Pressure PCV-5*84 & 5*86 95L-128W/1E3925 27022 Yellow	Nominal 3 Psig		X								

Rev. No. 0	Page 11 of 12
	SLD 3894

Page 11 of 12

Title: FISHER SCHe PRESSURE CONTROL VALVES

Title: FISHER SCHe PRESSURE CONTROL VALVES

FISHER SCHE PRESSURE CONTROL VALV
5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, 5*86

12/18/98

Commercial Grade Item Upgrade Dedication Form

Rev. No. 0

ECN No. NA CGI No. CGI-SNF-D-13-P5-021

Page 12 of 12

Title: FISHER SCHE PRESSURE CONTROL VALVES

5*08, 5*27, 5*47, 5*67, 5*80, 5*82, 5*84, 5*86

SNF 3894

Section 6 Contacts/Phone Numbers

Name	Phone
Design Authority	( )
QA	( )
QC	( )
Cog - Engineer	( )
CGI Engineer	( )
Procurement Engineer	( )
Other	( )

Section 7 Supporting Documentation for this Checklist

Initial Procurement Documents	For Critical Characteristics
☐ Drawings:	
☐ Manuals (specify type & number):	
☐ Design Calculations	
☐ Installation Instructions	
☐ Operation Instructions	
☐ Calibration Instructions	
☐ Manufacturer's Recommended Spare Parts List	
☐ Other:	
Procurement Documents	
☐ Certificate of Conformance/Compliance	
☐ Seismic Qualification Certificate	
☐ Environmental Qualification Certificate	
☐ Test Report (s):	
☐ Inspection Report (s):	
☐ CMTRs for ASME Pressure Retaining Materials	
☐ Valve Seat Leakage Report	
☐ Weld Records	
☐ Material Traceability Record	
☐ Other:	