ENGINEERING CHANGE NOTICE

Page 1 of 2

1. ECN 662315

Proj.
ECN

2. ECN Category (mark one) Supplemental ☐ Direct Revision ☒ Change ECN ☐ Temporary ☐ Standby ☐ Supersedure ☐ Cancel/Void ☐	3. Originator's Name, Organization, MSIN, and Telephone No. T. Nuxall, CVDF, R3-86, 372-3739		4. USQ Required? ☐ Yes ☒ No	5. Date 9/2/00
	6. Project Title/No./Work Order No. SNF/W-441 Spent Nuclear Fuel Cold Vacuum Drying		7. Bldg./Sys./Fac. No. CVDF 142-K	8. Approval Designator Q
	9. Document Numbers Changed by this ECN (includes sheet no. and rev.) See block 13a		10. Related ECN No(s). N/A	11. Related PO No. N/A
12a. Modification Work ☐ Yes (fill out Blk. 12b) ☒ No (NA Blks. 12b, 12c, 12d)	12b. Work Package No. N/A	12c. Modification Work Complete N/A Design Authority/Cog. Engineer Signature & Date	12d. Restored to Original Condition (Temp. or Standby ECN only) N/A Design Authority/Cog. Engineer Signature & Date	
13a. Description of Change SCHe SNF-3893, Rev. 1, SNF-3895, Rev. 2, SNF-3920, Rev. 2, SNF-3921, Rev. 4, SNF-3922, Rev. 1, SNF-3924, Rev. 1, SNF-3925, Rev. 1, SNF-3927, Rev. 3, SNF-3928, Rev. 2, SNF-3929, Rev. 5, SNF-3931, Rev. 2, SNF-3932, Rev. 3, SNF-4627, Rev. 2 Updated document numbers and deleted revision numbers. USQ Approval: CX B.1 from AP-NS-4-001-15.				
13b. Design Baseline Document? ☐ Yes ☒ No				
14a. Justification (mark one) Criteria Change ☐ Design Improvement ☒ Environmental ☐ Facility Deactivation ☐ As-Found ☐ Facilitate Const ☐ Const. Error/Omission ☐ Design Error/Omission ☐				
14b. Justification Details Editorial changes for configuration control. The design verification method for SS/SC components is by independent review in accordance with EN-6-027-01. Documentation of this review is accomplished by the independent review approval signature provided on page 2 of this ECN.				
15. Distribution (include name, MSIN, and no. of copies) See distribution sheet.				

RELEASE STAMP SEP 32 2000 (JLB 9/3/00)	
DATE STA # 19	HANFORD RELEASE ID: 15

[illegible]

Whitey SCHe Ball Valves - Provide Test Port Isolation

Prepared for the U.S. Department of Energy
Assistant Secretary for Environmental Management

Project Hanford Management Contractor for the
U.S. Department of Energy under Contract DE-AC06-96RL13200

Fluor Hanford

P.O. Box 1000
Richland, Washington

SNF-3931
Revision 3

ECN 662315

Whitey SCHe Ball Valves - Provide Test Port Isolation

Project No: W-441

Document Type: RPT

Division: SNF

C Miska
FH

Date Published
September 2000

Prepared for the U.S. Department of Energy
Assistant Secretary for Environmental Management

Project Hanford Management Contractor for the
U.S. Department of Energy under Contract DE-AC06-96RL13200

Fluor Hanford
P.O. Box 1000
Richland, Washington

Chris Braden
Release Approval

9/3/00
Date

Release Stamp

SNF-3931
Rev 3

TRADEMARK DISCLAIMER

Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

This report has been reproduced from the best available copy.

Printed in the United States of America

Total Pages: 15

Page 1

SNF-3931, WHITEY SCHe BALL VALVES - PROVIDE TEST PROT ISOLATION

A-7320-005 (10/97)

Commercial Grade Item Upgrade Dedication Form		SNF-3931, Rev. 3
ECN No. NA	CGI No. CGI-SNF-D-13-P5-035	Page 1 of 11
Title: WHITEY SCHe BALL VALVES – PROVIDE TEST PORT ISOLATION		

Section 1 Part Information															
Item No.: NA	Manufacturer: NA	Supplier: NA													
Mfg. Part/Model No.: NA		Supplier's P/N: NA													
Part Description: NA															
End Use Description: NA															
Section 2a Component Information															
Equipment No.: SCHe-V-*102,*103, *104,*105 He-V-*094,*096, *098,*100	Specification No.: SNF-5304 (W-441-P5)	Manufacturer: Whitey Co./ Swagelok	Past P.O. No.: NA												
Procurement and/or Model No.: SS-43VC04-5452-TR	Equipment Supplier (if different from manufacturer): TBD	Equip. Supplier's Part No.: NA													
Component Description: These valves are 1/4" ball valves fabricated of 316 stainless steel. Packing is TFE (standard). They are used as normally closed isolation valves for test ports in the SCHe System between the gage root valve and the pressure indicator.															
Section 2b Commercial Availability of the Item															
<p>1. Is the Item available from a catalogue of a qualified NQA1 supplier? (coordinate with project CGI interface Engineer or BTR)</p> <p>☐ YES (go to #2 below)</p> <p>☒ NO (go to procedure step 6.3.2, proceed to dedicate Item.)</p> <p>If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate with project CGI interface Engineer or BTR)</p> <p>☐ YES (go to #2 below, then go to procedure step 6.3.2, proceed to dedicate Item)</p> <p>☒ NO (go to procedure step 6.3.2, proceed to dedicate Item.)</p>															
<p>2. List of Candidate qualified suppliers or ISO 9000 suppliers</p> <table border="0"> <tr> <td>company name & type</td> <td>contact name</td> <td>phone</td> </tr> <tr> <td colspan="3">NA</td> </tr> <tr> <td colspan="3">_____</td> </tr> <tr> <td colspan="3">_____</td> </tr> </table>				company name & type	contact name	phone	NA			_____			_____		
company name & type	contact name	phone													
NA															

3. Recommended Procurement Strategy(coordinate with project CGI interface Engineer or BTR): NA															

Commercial Grade Item Upgrade Dedication Form		SNF-3931, Rev. 3
ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P5-035</u>	Page 2 of 11
Title: <u>WHITEY SCHe BALL VALVES – PROVIDE TEST PORT ISOLATION</u>		

Section 2c CGI Determination	
1. Question #1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?	☐ YES (the Item is not commercial grade) ☒ NO (continue)
2. Question #2: Is the Item used in applications other than nuclear facilities or activities?	☐ NO (the item is not commercial grade) ☒ YES (continue)
3. Question #3: Is the Item ordered from manufacturer/supplier on the basis or specifications set forth in the Published product information (e.g., manufacturer's catalog)?	☐ NO (the Item is not commercial grade) ☒ YES (continue)
☒ All three criteria have been satisfied. The Item meets the definition of commercial grade.	
Section 2d Reason for Dedication	
The above described Item is being Dedicated for use in the application cited for the following reason(s):	
☒	Item is being purchased from a non ESL manufacturer supplier as commercial grade to be used in a Safety Class application.
☐	Item is being purchased from a non ESL manufacturer supplier as commercial grade to be used in a Safety Significant application.
☐	Item was purchased from a non ESL manufacturer supplier as commercial grade to be used in a Safety Class application.
☐	Item was purchased from a non ESL manufacturer supplier as commercial grade to be used in a Safety Significant application.
☐	Other ('like-for-like', similar, substitution, replacement evaluation)
Section 3 Failure Effects Evaluation	
A. Part/Component Safety Function:	
1. Prevents air leakage/loss of SCHe during normal operation. Prevent H₂ Explosion	
2. Pressure boundary integrity/confinement.	
3. Maintain critical function before and after seismic event.	
B. Part/Component Functional Mode:	
Safety Function #1:	
☐	Active – Mechanical or Electrical change of state is required to occur for the component to perform its safety function
☒	Passive – Change of state is not required for the component to perform its safety function
Safety Function #2:	
☐	Active – Mechanical or Electrical change of state is required to occur for the component to perform its safety function.
☒	Passive – Change of state is not required for the component to perform its safety function
Safety Function #3:	
☐	Active – Mechanical or Electrical change of state is required to occur for the component to perform its safety function.
☒	Passive – Change of state is not required for the component to perform its safety function

Commercial Grade Item Upgrade Dedication Form		SNF-3931, Rev. 3
ECN No. NA	CGI No. CGI-SNF-D-13-P5-035	Page 3 of 11
Title: WHITEY SCHe BALL VALVES – PROVIDE TEST PORT ISOLATION		

C. Host Component Safety Function (if applicable): NA		
1.		
D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):		
1. Valve Body Break/Pressure boundary failure. Could result in a loss of SCHe supply from the affected bottle and manifold to the MCO or air intrusion during vacuum operation.		
Section 4 Environmental & Natural Phenomena Hazard Design		
Environmental Qualification Required:	If yes: Environmental Qualification Requirements	
Yes []	Limiting Environmental Conditions:	
No [X]	Required Safety Functions:	
Environmental Condition B	Qualification Period:	
Natural Phenomena Hazard (NPH) Design Required:	If yes: NPH Design Requirements	
Yes [X]	Performance Category: PC-3	
No []	NPH Design Req'ts.: Seismic Condition A	
HNF-PRO-97	Required Safety Functions: Maintain pressure boundary/confinement, prevent H₂ explosion.	
SNF-5304		
Section 5 Component Functional Classification		
[X] Safety Class (SC)	[] General Service	[] Safety Significant (SS)
If part/component classification is different from host component/system, document basis. NA		
Section 6 (Reserved)		
Section 7 (Reserved)		
Section 8 References (for Functional Classification)		
National Codes/Standards:	Safety Analysis Report (SAR):	Drawings: H-1-82165
ASME B31.3	HNF-SD-SNF-SAR-002	HNF-SD-SNF-SEL-002
Vendor Manual/Manufacturer/Supplier Information: Whitey Co. WHITEY "40" Series Ball Valves, W-1288, July, 1992		
Other: NA		

Commercial Grade Item Upgrade Dedication Form		SNF-3931, Rev. 3
ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P5-035</u>	Page 4 of 11
Title: <u>WHITEY SCHe BALL VALVES – PROVIDE TEST PORT ISOLATION</u>		

Section 9 Critical Characteristics				
Critical Characteristics Verification Document: Vendor's Manual; HNF-SD-SNF-SEL-002	Acceptance Criteria/Tolerances	Acceptance Method	ID	Function
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Nameplate - Manufacturer	Whitey Co. / Swagelok (Note 5)	1, IN	X	
Valve-Component Number-Procurement and/or Model Number	SS-43VC04-5452-TR, (Per SNF-5304, Section H, Design Data Sheet)	1, IN	X	
"A" Dimension	Nominal 2.12 inches	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Valve Body Material	Stainless Steel (Note 4)	1, IN 1, T	X	
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Pressure Boundary Integrity	Pressure Test at 165 psig (No Bubbles Note 3)	1, T		X
Valve Seat Leakage	Bubble-tight standard $< 10^{-3}$ ml He/sec	1, T		X
Environmental	Note 1			
Seismic Condition A	Note 2	1, T		X
3. Notes and Legend:		Acceptance Method:		
<ol style="list-style-type: none"> The ball valve Teflon packing is not subject to degradation from the 40°F and 60% RH or 115°F and 22% RH conditions and is suitable for Environmental Condition B application. Maintain critical function before and after seismic event. SNF-5304, Appendix I, page I-2, provides a seismic testing plan for these components at a seismic spectra SNF-4895. Equipment that has been shaker-table tested should not be installed in a plant (Ref. IEEE Standard 344-1984, Section 7). Consequently, the seismic test constitutes a destructive test. Pressure test at 110% of 150 psig system design pressure. Material verification acceptance method may be by either inspection or test. Either Whitey or Swagelok is acceptable. 		<ol style="list-style-type: none"> Special Test and Inspection 1, IN for Inspection 1, T for Test Commercial Grade Survey Source Verification Vendor/Item History 		

Section 10 Initial Review and Approval	
Approvals:	
Designated Engineer:	<i>Charles J. Van der Vliet 9/2/00</i>
Design Authority:	<i>Mike 9/2/00</i>
QA Engineer:	<i>Harold M. Chapin 9/2/00</i>

Teflon trademark of E.I. du Pont de Nemours and Company
(5108 9/3/00)

Commercial Grade Item Upgrade Dedication Form		SNF-3931, Rev. 3
ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P5-035</u>	Page 5 of 11
Title: <u>WHITEY SCHe BALL VALVES – PROVIDE TEST PORT ISOLATION</u>		

WORKSHEET 1 DETERMINATION OF FAILURE MECHANISMS/MODES		
SECTION 1		
Typical Failure Mechanisms	Definition	Applicable to Component under Evaluation
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.	Yes [] No [X]; If Yes, indicate failure Mode. _____
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.	Yes [] No [X]; If Yes, indicate failure Mode. _____
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.	Yes [] No [X]; If Yes, indicate failure Mode. _____
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.	Yes [] No [X]; If Yes, indicate failure Mode. _____
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	Yes [] No [X]; If Yes, indicate failure Mode. _____
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.	Yes [] No [X]; If Yes, indicate failure Mode. _____
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.	Yes [] No [X]; If Yes, indicate failure Mode. _____
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.	Yes [] No [X]; If Yes, indicate failure Mode. _____
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.	Yes [] No [X]; If Yes, indicate failure Mode. _____
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.	Yes [] No [X]; If Yes, indicate failure Mode. _____
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.	Yes [] No [X]; If Yes, indicate failure Mode. _____
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.	Yes [] No [X]; If Yes, indicate failure Mode. _____
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation		
1. <u>Valve Body Break</u>		
2. _____		

Commercial Grade Item Upgrade Dedication Form		SNF-3931, Rev. 3
ECN No. NA	CGI No. CGI-SNF-D-13-P5-035	Page 6 of 11
Title: WHITEY SCHe BALL VALVES – PROVIDE TEST PORT ISOLATION		

**CHECKLIST 1
ACCEPTANCE METHOD 1
SPECIAL TEST/INSPECTION VERIFICATION**

SECTION 1			
Item Description: Whitey SCHe Ball Valve		Equip #: SCHe-V-*102,*103,*104,*105 He-V-*094,*096,*098,*100	
System #: 13		Procurement and/or Model #: SS-43VC04-5452-TR	
Manufacturer (Address/Phone): Whitey Co. 318 Bishop Road Highland Heights, OH 44143 P.O. #		Supplier (Address/Phone):	
SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.			
Insp	Test	Post-Test	
[X]	[]	[]	1. Nameplate - Manufacturer
[X]	[]	[]	2. Valve-Component Number-Procurement and/or Model Number
[X]	[]	[]	3. "A" Dimension
[X]	[X]	[]	4. Valve Body Material (Verification may be by either inspection or test)
[]	[X]	[]	5. Pressure Boundary Integrity
[]	[X]	[]	6. Valve Seat Leakage
[]	[X]	[]	7. Seismic Condition A
SECTION 3 BY INSPECTION			
* See Attachment H of Desk Instruction for Sampling Size			
Characteristic: Nameplate - Manufacturer			
Sample Size*: All Items			
Acceptance Criteria: Whitey Co. / Swagelok (Either Whitey or Swagelok is acceptable)			
Receipt Inspection Plan / Report #: _____			
References (see Section 8): _____			
Characteristic: Valve-Component Number-Procurement and/or Model Number			
Sample Size*: All Items			
Acceptance Criteria: SS-43VC04-5452-TR, (Per SNF-5304, Section H, Design Data Sheet)			
Receipt Inspection Plan / Report #: _____			
References (see Section 8): Whitey Co.- Whitey "40" Series Ball Valves, W-1288, July, 1992			

Commercial Grade Item Upgrade Dedication Form		SNF-3931, Rev. 3
ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P5-035</u>	Page 7 of 11
Title: <u>WHITEY SCHe BALL VALVES – PROVIDE TEST PORT ISOLATION</u>		

Characteristic: "A" Dimension Sample Size*: All Items Acceptance Criteria: Nominal 2.12 inches Receipt Inspection Plan / Report #: _____ References (see Section 8): _____

Characteristic: Valve Body Material Sample Size*: Normal Sampling Size Acceptance Criteria: Stainless Steel Receipt Inspection Plan / Report #: _____ References (see Section 8): _____
--

SECTION 4 BY SPECIAL TEST

* See Attachment H of Desk Instruction for Sampling Size	
Test To Be Performed by: ☐ Purchaser ☐ Supplier/Manufacturer** ☐ Other	Number of Items to be Tested: Test/Inspection Location:

Characteristic for Test: Pressure Boundary Integrity Acceptance Criteria: Pressure Test at 165 psig (No Bubbles) Sample Size*: Normal Sampling Size Actual Test Value: Test Plan and Report #: _____ References (see Section 8): _____
--

Characteristic for Test: Valve Seat Leakage Acceptance Criteria: Bubble-tight Standard < 10⁻³ ml He/sec Sample Size*: Normal Sampling Size Actual Test Value: Test Plan and Report #: _____ References (see Section 8): _____

Commercial Grade Item Upgrade Dedication Form		SNF-3931, Rev. 3
ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P5-035</u>	Page 8 of 11
Title: <u>WHITEY SCHe BALL VALVES – PROVIDE TEST PORT ISOLATION</u>		

Characteristic for Test: **Seismic Condition A**

Acceptance Criteria: **Maintain Critical Function Before and After Seismic Event**

Sample Size*: **SNF-5304, Appendix I, page I-2, provides the seismic testing plan for these components. The seismic testing is conducted for one complete panel with the components assembled on the panel and tested as a complete assembly. The test seismically qualifies the entire assembly, including mountings, piping, and components. The number of components tested is dictated by the panel assembly design.**

Actual Test Value:

Test Plan and Report #: _____

References (see Section 8): _____

****If Supplier/Manufacturer or Other, Refer to CGI Checklist-2 for Support Information**

Commercial Grade Item Upgrade Dedication Form		SNF-3931, Rev. 3
ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P5-035</u>	Page 9 of 11
Title: <u>WHITEY SCHe BALL VALVES – PROVIDE TEST PORT ISOLATION</u>		

Section 5 Test / Inspection Summary (Acceptance Method 1)											
1. SUMMARY OF VERIFIED CRITICAL CHARACTERISTICS, THEIR VERIFICATION METHODS, AND RESULTS											
ITEM DESCRIPTION:											
Critical Characteristics						Verification Results					
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/IN	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Nameplate - Manufacturer	Whitey Co./Swagelok (Either Whitey or Swagelok is acceptable)	X									
Valve-Component Number-Procurement and/or Model Number	SS-43VC04-5452-TR, (Per SNF-5304, Section H, Design Data Sheet)	X									
"A" Dimension	Nominal 2.12 inches	X									
Valve Body Material	Stainless Steel	X									
Pressure Boundary Integrity	Pressure Test at 165 psig (No Bubbles)		X								
Valve Seat Leakage	< 10 ⁻³ ml He/sec @ 150 psig		X								
Seismic Condition A	Maintain Critical Function Before and After Seismic Event.		X								

Commercial Grade Item Upgrade Dedication Form		SNF-3931, Rev. 3
ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P5-035</u>	Page 10 of 11
Title: <u>WHITEY SCHe BALL VALVES – PROVIDE TEST PORT ISOLATION</u>		

2. DISPOSITION OF UNVERIFIED OR FAILED CRITICAL CHARACTERISTICS	
Critical Characteristic	Disposition
3. SIGNATURE INDICATES ALL CRITICAL CHARACTERISTICS VERIFIED SATISFACTORY OR ACCEPTABLY DISPOSITIONED AND COMMERCIAL GRADE DEDICATION IS SATISFACTORY AND COMPLETE.	
BUYER VERIFICATION	
Testing Agency Approval: _____ Date _____	Design Authority: _____ Date _____
Testing Agency QA Engineer: _____ Date _____	QA Engineer: _____ Date _____

Commercial Grade Item Upgrade Dedication Form		SNF-3931, Rev. 3
ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P5-035</u>	Page 11 of 11
Title: <u>WHITEY SCHe BALL VALVES – PROVIDE TEST PORT ISOLATION</u>		

Section 6 Contacts/Phone Numbers	
Name	Phone
Design Authority	()
QA	()
QC	()
Cog - Engineer	()
CGI Engineer	()
Procurement Engineer	()
Other	()
Section 7 Supporting Documentation for this Checklist	
Initial Procurement Documents	For Critical Characteristics
☐ Drawings:	
☐ Manuals (specify type & number):	
☐ Design Calculations	
☐ Installation Instructions	
☐ Operation Instructions	
☐ Calibration Instructions	
☐ Manufacturer's Recommended Spare Parts List	
☐ Other:	
Procurement Documents	
☐ Certificate of Conformance/Compliance	
☐ Seismic Qualification Certificate	
☐ Environmental Qualification Certificate	
☐ Test Report (s):	
☐ Inspection Report (s):	
☐ CMTRs for ASME Pressure Retaining Materials	
☐ Valve Seat Leakage Report	
☐ Weld Records	
☐ Material Traceability Record	
☐ Other:	