S

ENGINEERING CHANGE NOTICE

1. ECN 185697

Page 1 of 2

Proj.
ECN

2. ECN Category (mark one)		3. Originator's Name, Organization, MSIN, and Telephone No.		4. USQ Required?	5. Date
Supplemental ☐ Direct Revision ☒ Change ECN ☒ Temporary ☐ Standby ☐ Supersedure ☐ Cancel/Void ☐		Mark A. Beck Integrated Technology and Process Laboratory, T6-07, 373-2182		☐ Yes ☒ No	6/4/99
		6. Project Title/No./Work Order No.		7. Bldg./Sys./Fac. No.	8. Approval Designator
		Test Plan for Tank 241-C-104 Retrieval Testing		222-S Laboratory	NA
		9. Document Numbers Changed by this ECN (includes sheet no. and rev.)		10. Related ECN No(s).	11. Related PO No.
		HNF-4094 Rev 0			
12a. Modification Work		12b. Work Package No.	12c. Modification Work Completed		12d. Restored to Original Condition (Temp. or Standby ECNs only)
☐ Yes (fill out Blk. 12b) ☒ No (NA Blks. 12b, 12c, 12d)		N/A	NA Design Authority/Cog. Engineer Signature & Date		NA Design Authority/Cog. Engineer Signature & Date
13a. Description of Change					
Due to additions the page numbers of some items may be different than Rev 0					
pg 3 changed to add Tc-99 (Liquid Scintillation and ICP/M) on composite					
pg 5 changed caustic leach and water wash to more closely reflect specification 12 of the TWRS Privatization contract.					
pg 8 changed, Document changes to be documented by a revision.					
pg 9 changed intermediate schedule date changes, Final completion date not changed.					
13b. Design Baseline Document? ☐ Yes ☒ No					
14a. Justification (mark one)		14b. Justification Details			
Criteria Change ☒ Design Improvement ☐ Environmental ☐ Facility Deactivation ☐ As-Found ☐ Facilitate Const. ☐ Const. Error/Omission ☐ Design Error/Omission ☐		See changes			
15. Distribution (include name, MSIN, and no. of copies)					
D.L. Herting T6-07 (1) G.J. Bogen R3-75 (1) L.L. Lockrem T6-07 (1) M.A. Beck T6-06 (1) T.W. Crawford R3-73 (1) K.M. Hall R2-12 (1) J.S. Garfield R3-73 (1) R.A. Kirkbride R3-73 (1) K.D. Wiemers A0-21 (1) J.H. Baldwin R3-73 (1)					
RELEASE STAMP					
DATE STA 4 JUN 9 1999 HANFORD RELEASE ID: 58					

ENGINEERING CHANGE NOTICE

Page 2 of 2

1. ECN (use no. from pg. 1)

185697

16. Design Verification Required

☐ Yes
☒ No

17. Cost Impact

ENGINEERING

Additional ☐ \$ _____
Savings ☐ \$ _____

CONSTRUCTION

Additional ☐ \$ _____
Savings ☐ \$ _____

18. Schedule Impact (days)

Improvement ☐ _____
Delay ☒ 0

19. Change Impact Review: Indicate the related documents (other than the engineering documents identified on Side 1) that will be affected by the change described in Block 13. Enter the affected document number in Block 20.

SDD/DD	☐	Seismic/Stress Analysis	☐	Tank Calibration Manual	☐
Functional Design Criteria	☐	Stress/Design Report	☐	Health Physics Procedure	☐
Operating Specification	☐	Interface Control Drawing	☐	Spares Multiple Unit Listing	☐
Criticality Specification	☐	Calibration Procedure	☐	Test Procedures/Specification	☐
Conceptual Design Report	☐	Installation Procedure	☐	Component Index	☐
Equipment Spec.	☐	Maintenance Procedure	☐	ASME Coded Item	☐
Const. Spec.	☐	Engineering Procedure	☐	Human Factor Consideration	☐
Procurement Spec.	☐	Operating Instruction	☐	Computer Software	☐
Vendor Information	☐	Operating Procedure	☐	Electric Circuit Schedule	☐
OM Manual	☐	Operational Safety Requirement	☐	ICRS Procedure	☐
FSAR/SAR	☐	IEFD Drawing	☐	Process Control Manual/Plan	☐
Safety Equipment List	☐	Cell Arrangement Drawing	☐	Process Flow Chart	☐
Radiation Work Permit	☐	Essential Material Specification	☐	Purchase Requisition	☐
Environmental Impact Statement	☐	Fac. Proc. Samp. Schedule	☐	Tickler File	☐
Environmental Report	☐	Inspection Plan	☐		☐
Environmental Permit	☐	Inventory Adjustment Request	☐		☐

20. Other Affected Documents: (NOTE: Documents listed below will not be revised by this ECN.) Signatures below indicate that the signing organization has been notified of other affected documents listed below.

Document Number/Revision

Document Number/Revision

Document Number/Revision

21. Approvals

Signature	Date	Signature	Date
Design Authority		Design Agent	
Cog. Eng. D. L. Herting <i>Dan Herting</i>	6/7/99	PE	
Cog. Mgr. L. L. Lockrem <i>L. Lockrem</i>	6/9/99	QA	
QA		Safety	
Safety		Design	
Environ.		Environ.	
Other T. W. Crawford <i>T. W. Crawford</i>	6/7/99	Other	
K. M. Hall <i>Kathleen M. Hall</i>	6/9/99		

DEPARTMENT OF ENERGY

Signature or a Control Number that tracks the Approval Signature

ADDITIONAL

[illegible]

S

Test Plan for Tank 241-C-104 Retrieval Testing

D.L. Herting, M.A. Beck and J.F. O'Rourke
Numatec Hanford Corporation
Richland, WA 99352
U.S. Department of Energy Contract DE-AC06-96RL13200

EDT/ECN: 185697 UC: 2030
Org Code: 82800 Charge Code: 105434
B&R Code: EW31300010 Total Pages: 11

Key Words: high-level waste, privatization, waste feed delivery, dilution sludge, settling rate, viscosity, particle size

Abstract: Tank 241-C-104 has been identified as one of the first tanks to be retrieved for high-level waste pretreatment and immobilization. Retrieval of the tank waste will require dilution. Laboratory tests are needed to determine the amount of dilution required for safe retrieval and transfer of feed. The proposed laboratory tests are described in this document.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

Release Approval Date 6/9/99

Approved For Public Release

CONTENTS

1.0 INTRODUCTION.....	2
2.0 DESCRIPTION OF TEST	3
2.1 Shear Strength.....	3
2.2 Composite Sample	3
2.3 Dilution Levels.....	3
2.4 Density and Settling Rate Measurements	4
2.5 Viscosity and Particle Size Distribution	4
2.6 Chemical Composition	5
2.7 Sludge Washing and Caustic Leaching.....	5
2.8 Sludge Composition as a Function of Settling.....	5
3.0 QUALITY ASSURANCE	8
4.0 SAFETY.....	8
5.0 WASTE HANDLING	8
6.0 SCHEDULE AND DELIVERABLES	9
7.0 REFERENCES.....	9

TABLES

Table 1. Liquid Phase Analyses for Composite Sample at Target Dilution	6
Table 2. Centrifuged Solids Analyses for Composite Sample at Target Dilution	7

1.0 INTRODUCTION

Tank 241-C-104 has been selected as a Phase I source tank for High Level Waste sludge feed for vitrification. The 530 kgal tank contains 295 kgal of sludge, which will be sluiced to the double-shell tank 241-AY-102. From there, smaller batches of sludge (100 kgal) will be delivered to the vitrification contractor.

Rheological data are needed to develop engineering plans for the sluicing and pumping operations. Chemical composition data are needed to verify the ability to meet contract feed specifications. Other physical data are needed to support computational fluid dynamics modeling of sludge mobilization using mixer pumps.

The laboratory tests outlined in this Test Plan are designed to obtain all these types of data. The tests are based on test requirements established by Process Engineering (Nguyen 1999a).

Tank C-104 was core-sampled twice in July 1996, and three times in August 1998. The 1996 core samples were subjected to a typical suite of analytical measurements, which are reported in the Tank Characterization Report (Baldwin 1997). They show marked vertical inhomogeneity in color, texture, and chemical composition. Concentrations of major elements like aluminum, iron, and zirconium vary by an order of magnitude or more from one sharply-defined layer to another within the waste.

Core 247 from the 1998 sampling event was reserved for the process testing described in this Test Plan. Five segments were taken, representing the full depth of the sludge in the tank. Based on the percent recovery of the samples, core 247 was judged to be a better representation of the tank inventory than the 1996 core samples. Based on the physical appearance of the samples, segments 1, 2, 4, and 5 were divided into half-segment fractions. Segment 3 was divided into four fractions. All of the fractions have been stored undisturbed in sample jars since early September, 1998. All of the yield strength measurements will be performed before any sample mixing takes place. Other testing will be done on composite samples as described in detail later in the Test Plan.

2.0 DESCRIPTION OF TEST

2.1 Shear Strength

A Haake M5 viscometer will be used for the rheological measurements. Use of the viscometer is governed by procedure number LA-519-105. For shear strength, the Haake M5 will be equipped with an FL-1000 shear vane. To determine the shear strength of a material, the FL-1000 is inserted into a sample and rotated at a slow constant speed. Shear strength is defined as the force required to cause shear failure in the material.

Shear strength measurements will be performed on all twelve sample jars (half- and quarter-segment samples) before any of the samples are disturbed. All measurements will be done at ambient hotcell temperature (typically around 28 °C).

2.2 Composite Sample

All other testing (besides shear strength) will be performed on aliquots taken from a composite sample. To prepare the composite, each half-segment or quarter-segment sample jar will be mixed. Then equal fractions by weight from each half-segment sample and half as much from each quarter-segment sample will be combined into a 500 mL jar. The composite sample will then be re-mixed. An aliquot of the undiluted composite will be submitted for Tc-99 by Liquid Scintillation and ICP/MS. Two identical composite jars will be needed for the testing, each containing about 400 mL of sample. Approximately 75% of the sample from each of the 12 jars will be used, and the remaining 25% will be left in the original jars for other potential characterization needs or process testing needs.

2.3 Dilution Levels

Retrieval of the sludge from tank C-104 will require dilution to transport the sludge to tank AY-102. The diluent used for the laboratory tests will be inhibited water (0.01 M in NaOH and 0.01 M in NaNO₂).

Process Development has assigned a "target dilution" for the transport of C-104 sludge, such that the diluted sludge will contain 100 grams of solids per liter of diluted sludge (100 g/L). Physical measurements (density, settling rate, viscosity, particle size distribution) will be done on sludge at the target dilution level and at one dilution level on either side of the target (60 g/L and 140 g/L). The amount of diluent required to reach the target dilution will be calculated from the existing characterization data for the sludge. The actual dilution levels achieved will be measured and reported.

2.4 Density and Settling Rate Measurements

Density measurements will be provided for bulk sample, liquid phase, and settled solids for each of the three dilution levels of the composite sample. These measurements will be derived from the samples used for settling rate tests. The bulk density of the undiluted sludge can be calculated from the bulk density of the diluted samples.

For each test, 100 mL of diluted sludge will be poured into a tared graduated cylinder, and allowed to settle for at least one week. The position of the interface between settled solids and supernatant liquid will be recorded as often as there is a significant change, which may be hourly near the beginning of the test and daily near the end of the test. At the conclusion of the test, a sample of the supernatant liquid will be analyzed for density by procedure LA-510-112.

The bulk density is derived from the total weight and volume of the diluted sludge sample in the 100 mL graduated cylinder. The liquid phase density, determined by analysis, is used to calculate the weight of the supernatant liquid in the graduated cylinder, which gives the weight of the settled solids by difference. The settled solids density is calculated from the measured volume and calculated weight of the settled solids.

2.5 Viscosity and Particle Size Distribution

Viscosity and particle size distribution measurements will be made on the undiluted composite sample and at each of the three dilution levels. The viscosity will also be measured for supernatant liquid from the diluted sludge at the target dilution. Particle size distribution will also be measured on the sludge fractions partitioned by relative settling rates (see Section 2.8).

For viscosity measurements, the Haake M5 viscometer will be equipped with the MV-1 coaxial cylinder sensor system. Viscosity is calculated by measuring the torque on the inner cylinder as a function of its rotational speed. The MV-1 sensor is water-jacketed to allow precise temperature control. Viscosity measurements will be made at ambient hotcell temperature, and at 45 and 65 °C.

A Horiba LA-910 Particle Size Analyzer will be used for the particle size distribution analyses. The Horiba LA-910 uses laser diffraction to determine the volume distribution of particles with sizes ranging from 0.02 μm to 1020 μm . Laboratory technology procedure LT-519-105 will be followed for the particle size distribution analyses. The particles are diluted with enough supernatant liquid to make a well-separated suspension. All measurements will be made at ambient room temperature (typically around 25 °C).

2.6 Chemical Composition

Duplicate samples of diluted sludge at the target dilution will be separated by centrifugation at ambient temperature into supernatant liquid and centrifuged solids fractions. Centrifuged samples will be examined to determine whether they contain any floating (or otherwise separate) organic layer. Supernatant liquid samples will be analyzed for the “envelope B” list of analytes shown in Table 1 (Nguyen 1999b). The solids will be analyzed according to the “envelope D” list shown in Table 2 (Nguyen 1999a).

2.7 Sludge Washing and Caustic Leaching

Solids preparation:

Vacuum filtration of the C-104 composite (as specified in DOE –RL, 1996 Specification 12.2.2.2) is not possible with the currently available material. A subsample of the composite will be centrifuged to remove the liquids prior to the wash and leach tests.

Aqueous Insoluble Determination: per DOE –RL, 1996 Specification 12.2.2

Duplicate samples of centrifuged solids will be washed three times with inhibited water at a 4:1 volume ratio of water to solids. The washes will be done for eight hours each at 80 to 90 °C and ambient pressure. The slurry will be centrifuged at ambient temperature to separate the solid and liquid phases. The solids remaining after the final contact/centrifugation will be analyzed for the following subset of the analytes in Table 2: TGA (direct sample), ICP (after acid digest), and ⁹⁹Tc by liquid scintillation (after fusion digest).

Caustic Insoluble Determination per DOE –RL, 1996 Specification 12.2.3.2:

Two more samples of centrifuged solids will be leached once with 3 M NaOH at a 3:1 NaOH to solids volume ratio for eight hours at 80 to 90 °C. The slurry will be centrifuged at ambient temperature to separate the solid and liquid phases. The leach step will be followed by two inhibited water washes, again for eight hours at 80 to 90 °C and centrifuged as above. The centrifuged solids will be analyzed for the same subset as the washed solids above.

Liquid phase samples from the wash and leach tests are not analyzed.

2.8 Sludge Composition as a Function of Settling

Duplicate samples of sludge at the target dilution level will be poured into 100 mL graduated cylinders and allowed to settle. When approximately one-third of the solids have settled to the bottom of the cylinder, the remaining slurry (the unsettled portion) is

transferred to new graduated cylinders and allowed to settle. When approximately one-half of the remaining solids (the second one-third of the original solids) have settled, the remaining slurry is decanted into centrifuge cones. The first and second fractions are also transferred from the graduated cylinders to centrifuge cones.

The original slurry is now divided into three fractions (in duplicate), with the fractions differentiated by the settling rates of the solids. All of the cones are centrifuged, and the solids are analyzed for the following: TGA and particle size distribution (direct sample); and ICP/AES, GEA, and AT/TB (after fusion).

Table 1. Liquid Phase Analyses¹ for Composite Sample at Target Dilution

Procedure	Method	Analytes
LA-505-161	ICP/AES	Ag, Al, As, B, Ba, Be, Bi, Ca, Cd, Ce, Co, Cr, Cu, Fe, K, La, Li, Mg, Mn, Mo, Na, Nd, Ni, P, Pb, Pd, Pr, Rb, Rh, Ru, S, Sb, Se, Si, Sm, Sr, Ta, Te, Th, Ti, Tl, U, V, W, Y, Zn, Zr
LA-533-105	IC	Br ⁻ , Cl ⁻ , F ⁻ , NO ₂ ⁻ , NO ₃ ⁻ , C ₂ O ₄ ²⁻ , PO ₄ ³⁻ , SO ₄ ²⁻
LA-510-112	specific gravity	density
LA-325-104	CVAA	Hg
LA-342-100	persulfate/ combustion	TIC/TOC
LA-212-106	pH	pH
LA-514-114	TGA	%H ₂ O
LA-211-102	titration	OH ⁻
LA-506-101	ICP/MS	⁹⁹ Tc, ¹²⁶ Sn, Total Cs, ^{233/235} U, ²³⁷ Np, ^{238/239/240/241/242} Pu, ²⁴³ Am
LA-438-101	Liquid Scintillation	⁹⁹ Tc
LA-548-121	GEA	¹³⁷ Cs, ⁶⁰ Co, ^{152/154/155} Eu, ¹²⁵ Sb
LA-220-101	Separation & beta counting	⁹⁰ Sr
LA-508-101	alpha/beta counting	total alpha/total beta (AT/TB)

¹ Acronym definitions:

ICP/AES – inductively coupled plasma atomic emission spectroscopy

IC – ion chromatography

CVAA – cold vapor atomic absorption

TGA – thermogravimetric analysis

ICP/MS – inductively coupled plasma mass spectroscopy

AEA – alpha energy analysis

GEA – gamma energy analysis

Table 2. Centrifuged Solids Analyses for Composite Sample at Target Dilution

Procedure	Method	Prep	Analytes
LA-505-161	ICP/AES	acid digest	Ag, Al, As, B, Ba, Be, Bi, Ca, Cd, Ce, Co, Cr, Cu, Fe, K, La, Li, Mg, Mn, Mo, Na, Nd, Ni, P, Pb, Pd, Pr, Rb, Rh, Ru, S, Sb, Se, Si, Sm, Sr, Ta, Te, Th, Ti, Tl, U, V, W, Y, Zn, Zr
LA-505-161	ICP/AES	fusion	same as above
LA-533-105	IC	water digest	Br ⁻ , Cl ⁻ , F ⁻ , NO ₂ ⁻ , NO ₃ ⁻ , C ₂ O ₄ ²⁻ , PO ₄ ³⁻ , SO ₄ ²⁻
LA-325-104	CVAA	direct	Hg
LA-342-100	persulfate/ combustion	direct	TIC/TOC
LA-514-114	TGA	direct	%H ₂ O
LA-695-102	colorimetry	direct	CN ⁻
LA-211-102	titration	water digest	OH ⁻
LA-631-001	ion selective electrode	water digest	NH ₃
LA-506-101	ICP/MS	fusion	⁹⁹ Tc, ¹²⁶ Sn, Total Cs, ^{233/235} U, ²³⁷ Np, ^{238/239/240/241/242} Pu, ²⁴³ Am
LA-953-104	Separation/ AEA	fusion	²⁴¹ Am, ^{243/244} Cm
LA-438-101	Liquid Scintillation	fusion	⁹⁹ Tc
LA-548-121	GEA	fusion	¹³⁷ Cs, ⁶⁰ Co, ^{152/154/155} Eu, ¹²⁵ Sb
LA-218-114	liquid scintillation	fusion	³ H
LA-348-104	liquid scintillation	fusion	¹⁴ C
LA-220-101	Separation & beta counting	fusion	⁹⁰ Sr
LA-378-103	separation GEA	fusion	¹²⁹ I
LA-508-101	alpha/beta counting	fusion	total alpha/total beta (AT/TB)

3.0 QUALITY ASSURANCE

Based on the requirements in "Review and Approval of Documents", HNF-PRO-233, this Test Plan is assigned Approval Designator N/A. Approval signatures are required from the author, immediate manager, and customer.

All testing will follow the "Process Chemistry and Statistics Quality Assurance Plan", WHC-SD-CP-QAPP-018, Rev. 0 (Meznarich 1996). Specific laboratory instructions will be reviewed and approved by Process Chemistry management, 222-S Radiological Control, and 222-S Environmental prior to initiation of testing. The instructions will be recorded in a controlled laboratory notebook before work begins; observations and data will be recorded as the work is done.

In addition to the duplicate testing described in Section 2, standard laboratory quality control protocols will apply to the analytical work. These include (wherever appropriate) one duplicate, one spike, one standard, and one blank per batch of samples analyzed.

Changes to this document will be documented by a revision, a copy of which will go to all the recipients of revision 0.

4.0 SAFETY

All of the safety requirements that apply to this Test Plan are described in "Development of Instrumentation, Methods and Performance of Process Testing", Hanford Analytical Services Laboratory Operating Procedure LO-140-100, Rev. C-0, released July 28, 1998.

5.0 WASTE HANDLING

Three waste streams are expected to be generated from this test program. Stream #1 is the waste resulting from analysis of samples. Each waste generated from these routine analyses will be handled in accordance with the instructions in the procedures for the respective analyses.

Stream #2 is the used and left-over tank waste material. This material, expected to be less than 1 kg, will be discarded to the 219-S Building tanks via a hotcell drain, per procedure LO-100-107, "Cubicle Housekeeping, Waste Disposal, and Management", and in compliance with 222-S Laboratory Standing Order 98-016, Rev. 1, "Accounting for Solids Generated from Routine Work and Sample Disposal Activities in 222-S Hotcells", December 31, 1998.

Stream #3 is the solid hotcell waste consisting of used centrifuge cones, used sample vials, and used plastic syringes. This waste will be rinsed with water, loaded into waste cans, removed from the hotcell, and disposed of according to LO-100-151.

Other than the waste streams just described, there will be no accumulating of hazardous waste. Therefore, no Waste Stream Fact Sheet or Waste Compatibility Assessment documentation will be required.

6.0 SCHEDULE AND DELIVERABLES

This revision to the Test Plan is scheduled to be issued by June 7, 1999. Management approval for the specific laboratory instructions will be obtained by June 14, 1999. Laboratory work will commence by June 15, 1999.

A complete report of the test results will be issued in the form of a draft supporting document by September 1, 1999. Informal interim status reports will be issued to the customer via e-mail on a biweekly basis.

7.0 REFERENCES

- Baldwin, J. H. (1997), *Tank Characterization Report for Single-Shell Tank 241-C-104*, HNF-SD-WM-ER-679, Rev. 0, Lockheed Martin Hanford Corporation, Richland, Washington.
- DOE-RL (1996), *TWRS Privatization*, Contract Number DE-RP06-96RL13308, U.S Department of Energy, Richland, Washington.
- Meznarich, H. K. (1996), *Process Chemistry & Statistics Quality Assurance Plan*, WHC-SD-CP-QAPP-018, Rev. 0, Westinghouse Hanford Company, Richland, Washington.
- Nguyen, D. M. (1999a), *Data Quality Objectives for TWRS Privatization Phase 1: Confirm Tank T is an Appropriate Feed Source for High-Level Waste Feed Batch X*, HNF-1558, Rev. 1, PSDQO-02, Lockheed Martin Hanford Corporation, Richland, Washington.
- Nguyen, D. M. (1999b), *Data Quality Objectives for TWRS Privatization Phase 1: Confirm Tank T is an Appropriate Feed Source for Low-Activity Waste Feed Batch X*, HNF-1796, Rev. 2, PSDQO-01, Lockheed Martin Hanford Corporation, Richland, Washington.