ENGINEERING CHANGE NOTICE

Page 1 of 21. ECN **663720**Proj.
ECN

2. ECN Category (mark one)		3. Originator's Name, Organization, MSIN, and Telephone No.		4. USQ Required?		5. Date	
Supplemental ☐ Direct Revision ☒ Change ECN ☐ Temporary ☐ Standby ☐ Supersedeure ☐ Cancel/Void ☐		A. Artzer, CVDF, X3-78, 372-2785		[X] Yes ☐ No		10/12/00	
		6. Project Title/No./Work Order No.		7. Bldg./Sys./Fac. No.		8. Approval Designator	
		SNF/W-441, Spent Nuclear Fuel Cold Vacuum Drying		CVDF 142K		S ^N Q	
		9. Document Numbers Changed by this ECN (includes sheet no. and rev.)		10. Related ECN No(s).		11. Related PO No.	
		SNF-3929, Rev. 7		N/A		N/A	
12a. Modification Work		12b. Work Package No.		12c. Modification Work Complete		12d. Restored to Original Condition (Temp. or Standby ECN only)	
☐ Yes (fill out Blk. 12b) ☒ No (NA Blks. 12b, 12c, 12d)		N/A		N/A		N/A	
		Design Authority/Cog. Engineer Signature & Date		Design Authority/Cog. Engineer Signature & Date			
13a. Description of Change				13b. Design Baseline Document? ☐ Yes ☒ No			
SCHe Changed Equipment ID No. from SCHe-PCV-5*05 to 5*04; changed Regulator Component Number-Procurement and/or Model Number from "412-2800-0XA" to "412-2800-0XA or 412-2800-01-XA"; Deleted CCs for Relief Valve Manufacturer/Model No., Pigtail Manufacturer/Model No. / Connection Size / Length, and Panel Mount Kit Manufacturer/Model No. and placed information in Note 5. Changed from Outlet Connection "1/4" NPT Male" to "1/4" NPT Female". Changed Supplier from "TBD" to "Olympic Tool & Engineering". Revised Sampling Size referenced docs from "Attachment H, Table H-1 of Desk Instruction" to "Appendix D, Table D-1 of EN 6-035-01".				SC			
USQ Approval: <u>CVD-00-2132</u>							
14a. Justification (mark one)				14b. Justification Details			
Criteria Change ☐ Design Improvement ☒ Environmental ☐ Facility Deactivation ☐ As-Found ☐ Facilitate Const ☐ Const. Error/Omission ☐ Design Error/Omission ☐				Change required to correct equipment P&ID number, and to clarify information about the model number for the regulator. The design verification method for SC/SS components is by independent review in accordance with EN-6-027-01. Documentation of this review is accomplished by the independent review approval signature provided on page 2 of this ECN.			
15. Distribution (include name, MSIN, and no. of copies)						RELEASE STAMP	
See distribution sheet.							

ENGINEERING CHANGE NOTICE						Page 2 of 2		1. ECN (use no. from pg. 1) 663720																																				
16. Design Verification Required ☒ Yes ☐ No		17. Cost Impact <table><thead><tr><th colspan="3">ENGINEERING</th><th colspan="3">CONSTRUCTION</th></tr><tr><th>Additional</th><th>[N/A]</th><th>\$</th><th>Additional</th><th>[N/A]</th><th>\$</th></tr></thead><tbody><tr><td>Savings</td><td>[N/A]</td><td>\$</td><td>Savings</td><td>[N/A]</td><td>\$</td></tr></tbody></table>						ENGINEERING			CONSTRUCTION			Additional	[N/A]	\$	Additional	[N/A]	\$	Savings	[N/A]	\$	Savings	[N/A]	\$	18. Schedule Impact (days) Improvement [N/A] Delay [N/A]																		
ENGINEERING			CONSTRUCTION																																									
Additional	[N/A]	\$	Additional	[N/A]	\$																																							
Savings	[N/A]	\$	Savings	[N/A]	\$																																							
19. Change Impact Review: Indicate the related documents (other than the engineering documents identified on Side 1) that will be affected by the change described in Block 13. Enter the affected document number in Block 20.																																												
SDD/DD		☐	Seismic/Stress Analysis		☐	Tank Calibration Manual		☐																																				
Functional Design Criteria		☐	Stress/Design Report		☐	Health Physics Procedure		☐																																				
Operating Specification		☐	Interface Control Drawing		☐	Spares Multiple Unit Listing		☐																																				
Criticality Specification		☐	Calibration Procedure		☐	Test Procedures/Specification		☐																																				
Conceptual Design Report		☐	Installation Procedure		☐	Component Index		☐																																				
Equipment Spec.		☐	Maintenance Procedure		☐	ASME Coded Item		☐																																				
Const. Spec.		☐	Engineering Procedure		☐	Human Factor Consideration		☐																																				
Procurement Spec.		☐	Operating Instruction		☐	Computer Software		☐																																				
Vendor Information		☐	Operating Procedure		☐	Electric Circuit Schedule		☐																																				
OM Manual		☐	Operational Safety Requirement		☐	ICRS Procedure		☐																																				
FSAR/SAR		☐	IEFD Drawing		☐	Process Control Manual/Plan		☐																																				
Safety Equipment List		☐	Cell Arrangement Drawing		☐	Process Flow Chart		☐																																				
Radiation Work Permit		☐	Essential Material Specification		☐	Purchase Requisition		☐																																				
Environmental Impact Statement		☐	Fac. Proc. Samp. Schedule		☐	TICKLER FILE		☐																																				
Environmental Report		☐	Inspection Plan		☐	N/A		☐																																				
Environmental Permit		☐	Inventory Adjustment Request		☐			☐																																				
20. Other Affected Documents: (NOTE: Documents listed below will not be revised by this ECN.) Signatures below indicate that the signing organization has been notified of other affected documents listed below. <table><thead><tr><th>Document Number/Revision</th><th>Document Number/Revision</th><th>Document Number Revision</th></tr></thead><tbody><tr><td>N/A</td><td></td><td></td></tr></tbody></table>									Document Number/Revision	Document Number/Revision	Document Number Revision	N/A																																
Document Number/Revision	Document Number/Revision	Document Number Revision																																										
N/A																																												
21. Approvals <table><thead><tr><th>Signature</th><th>Date</th><th>Signature</th><th>Date</th></tr></thead><tbody><tr><td>Design Authority C. Miska</td><td>10-18-00</td><td>Design Agent</td><td></td></tr><tr><td>Cog. Eng. N/A</td><td></td><td>PE</td><td></td></tr><tr><td>Cog. Mgr. C. Haller</td><td>10/19/2000</td><td>QA</td><td></td></tr><tr><td>QA R. K. Ramsgate</td><td>10/18/00</td><td>Safety</td><td></td></tr><tr><td>Safety J. R. Breslin</td><td>10-19-00</td><td>Design</td><td></td></tr><tr><td>Environ.</td><td></td><td>Environ.</td><td></td></tr><tr><td>Other</td><td></td><td>Other</td><td></td></tr><tr><td>Independent Review JM Bazzell & W Russell</td><td>→ 10/19/00</td><td></td><td></td></tr></tbody></table> <div>DEPARTMENT OF ENERGY Signature or a Control Number that tracks the Approval Signature ADDITIONAL</div>									Signature	Date	Signature	Date	Design Authority C. Miska	10-18-00	Design Agent		Cog. Eng. N/A		PE		Cog. Mgr. C. Haller	10/19/2000	QA		QA R. K. Ramsgate	10/18/00	Safety		Safety J. R. Breslin	10-19-00	Design		Environ.		Environ.		Other		Other		Independent Review JM Bazzell & W Russell	→ 10/19/00		
Signature	Date	Signature	Date																																									
Design Authority C. Miska	10-18-00	Design Agent																																										
Cog. Eng. N/A		PE																																										
Cog. Mgr. C. Haller	10/19/2000	QA																																										
QA R. K. Ramsgate	10/18/00	Safety																																										
Safety J. R. Breslin	10-19-00	Design																																										
Environ.		Environ.																																										
Other		Other																																										
Independent Review JM Bazzell & W Russell	→ 10/19/00																																											

DISTRIBUTION SHEET

[illegible]

Concoa SCHe Pressure Regulators & Reotemp Pressure Gauge (SCHe Tank Outlet)

Prepared for the U.S. Department of Energy
Assistant Secretary for Environmental Management

Project Hanford Management Contractor for the
U.S. Department of Energy under Contract DE-AC06-96RL13200

Fluor Hanford

P.O. Box 1000
Richland, Washington

SNF-3929
Revision 8

ECN 663720

Concoa SCHe Pressure Regulators & Reotemp Pressure Gauge (SCHe Tank Outlet)

Project No: W-441

Division: SNF

C. R. Miska
Fluor Hanford, Inc.

Date Published
October 2000

Prepared for the U.S. Department of Energy
Assistant Secretary for Environmental Management

Project Hanford Management Contractor for the
U.S. Department of Energy under Contract DE-AC06-96RL13200

Fluor Hanford
P.O. Box 1000
Richland, Washington

Chris Braden
Release Approval

10/19/00)
Date

OCT 19 2000		
DATE:		ID:
STA.		(5)
#19		

Release Stamp

TRADEMARK DISCLAIMER

Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

This report has been reproduced from the best available copy.

Printed in the United States of America

Total Pages: 14

SNF-3929, Rev. 8

Commercial Grade Item Upgrade Dedication Form		SNF-3929, Rev. 8
ECN No. NA	CGI No. CGI-SNF-D-13-P5-032	Page 1 of 10
Title: Concoa SCHe Pressure Regulators & Reotemp Press. Gauge (SCHe Tank Outlet)		

Section 1 Part Information			
Item No.: N/A		Manufacturer: N/A	
Mfg. Part/Model No.: N/A		Supplier: N/A	
Supplier's P/N: N/A			
Part Description: N/A			
End Use Description: N/A			
Section 2a Component Information			
Equipment No.: SCHe-PCV-5*04, 5*23, 5*43, 5*63; PI-5*02, 5*21, 5*41, 5*61	Specification No.: SNF-5304 (W-441-P5)	Manufacturer: Concoa, Reotemp	Past P.O. No.: N/A
Procurement and/or Model No.: Concoa: 412-2800-0XA or 412-2800-01-XA Reotemp: PR-25-S-1-A-4-P34-D	Equipment Supplier (if different from manufacturer): Olympic Tool & Engineering		Equip. Supplier's Part No.: N/A
Component Description: Dual Stage Pressure Regulator to Maintain Steady Delivery Pressure Over Wide Range of He Tank Pressure. Pressure Gauges give Indication of Purge Line Pressure.			
Section 2b Commercial Availability of the Item			
<p>1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)? ☐ YES (go to #2 below) ☒ NO (go to procedure step 6.3.2, proceed to dedicate Item)</p> <p>If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate w/ project CGI Interface Engineer or BTR):</p> <p>☐ YES (go to #2 below, procedure step 6.3.2, dedicate Item) ☒ NO (procedure step 6.3.2, dedicate Item)</p>			
2. List of Candidate qualified suppliers or ISO 9000 suppliers: N/A			
3. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): N/A			
Section 2c CGI Determination			
CGI Determination Questions:			
#1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?			
☐ YES (the Item is not commercial grade) ☒ NO (continue)			
#2: Is the Item used in applications other than nuclear facilities or activities?			
☐ NO (the item is not commercial grade) ☒ YES (continue)			
#3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?			
☐ NO (the item is not commercial grade) ☒ YES (continue)			
[X] All three criteria have been satisfied. The Item meets the definition of commercial grade.			
Section 2d Reason for Dedication			
The above Commercial Grade (CG) described item is being Dedicated for use in the application cited for the following reason(s):			
X	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.		
	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.		
	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.		
	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.		
	Other ('like-for-like', similar, substitution, replacement evaluation)		

Commercial Grade Item Upgrade Dedication Form		SNF-3929, Rev. 8
ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P5-032</u>	Page 2 of 10
Title: Concoa SCHe Pressure Regulators & Reotemp Press. Gauge (SCHe Tank Outlet)		

Section 3 Failure Effects Evaluation	
A. Part/Component Safety Function:	
1. Prevent MCO Overpressurization	
2. Prevent Thermal Runaway and H2 explosion .	
3. Maintain critical function before and after seismic event.	
B. Part/Component Functional Mode:	
Safety Function #1: ☐ Active ☒ Passive	Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function
Safety Function #2: ☐ Active ☒ Passive	Passive - Change of state is not required for the component to perform its safety function
Safety Function #3: ☐ Active ☒ Passive	
C. Host Component Safety Function (if applicable): N/A	
1.	
D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):	
1. Valve Body/Process Connection break - loss of boundary, air in-leakage.	
2. Diaphragm/Body Failure - loss of regulating function.	

Section 4 Environmental & Natural Phenomena Hazard Design	
Environmental Qualification Required:	If yes: Environmental Qualification Requirements
Yes ☐	Limiting Environmental Conditions:
No ☒ Environmental Condition B	Required Safety Functions:
	Qualification Period:
Natural Phenomena Hazard (NPH) Design Required:	If yes: NPH Design Requirements
Yes ☒	Performance Category: PC-3
No ☐	NPH Design Req'ts.: Seismic Condition A
HNF-PRO-97	Required Safety Functions: MCO Overpressurization, Thermal Runaway and H2 Explosion prevention, Maintain Critical Function Before and After Seismic Event
SNF-5304	

Section 5 Component Functional Classification			
X	Safety Class (SC)		General Service (GS)
			Safety Significant (SS)
If part/component classification is different from host component/system, document basis. N/A			

Sections 6 and 7 (Reserved)	
Section 8 References (for Functional Classification)	
National Codes/Standards: ASME B31.3	
Safety Analysis Report (SAR): HNF- 3553, Annex B	
Drawings: H-1-82165, H-1-82367, HNF-SD-SNF-SEL-002	
Vendor Manual/Manufacturer/Supplier Information: Catalog Cut Sheets: Concoa 412 Series Regulator, Reotemp Pressure Gauges	

Commercial Grade Item Upgrade Dedication Form		SNF-3929, Rev. 8
ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P5-032</u>	Page 3 of 10
Title: Concoa SCHe Pressure Regulators & Reotemp Press. Gauge (SCHe Tank Outlet)		

Section 9 Critical Characteristics				
Critical Characteristics	Acceptance Criteria/Tolerances	Acc. Method	ID	Function
Concoa Pressure Regulator:				
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Nameplate - Manufacturer	Concoa	1, IN	X	
Regulator Component Number-Procurement and/or Model Number	412-2800-0XA or 412-2800-01-XA; (Per SNF-5304, Design Data Sheet) (Note 5)	1, IN	X	
Helium Leak Certification (supplied with regulator)	Documentation of leakage < 1 X 10 ⁻⁸ scc/sec, (ditto above)	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Regulator Body Material	Brass (Note 4)	1, IN, 1, T	X	X
Regulator Outlet Connection	1/4" NPT Female	1, IN	X	
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Setpoint	Maintain delivery pressure of 25 ± 2.5 psig at a pressure no less than 3000 psig but not more than 3600 psig for 96 hours.	1, T		X
Concoa Relief Valve Setpoint (adjust to 50 psig as necessary)	50 ± 5 psig	1, T		X
Reotemp Pressure Gauges:				
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Nameplate - Manufacturer	Reotemp	1, IN	X	
Component Number-Procurement and/or Model Number	PR-25-S-1-A-4-P34-D	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
Dial Size	2.5" Diameter Nominal	1, IN	X	
Outlet Connection	1/4" NPT	1, IN	X	
Mounting	Bottom Mounting	1, IN	X	
Tube & Socket Material	316 SS	1, IN, 1, T	X	X
Pressure Range	0-5000 psig	1, IN	X	
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Accuracy	Certification of Calibration shows accuracy at least 1.6% of Full Scale per the documentation.	1, IN	X	
All Items:				
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Pressure Boundary	Pressure Test at 4400 psig for >10 minutes; Reduce pressure to 4000 psig, perform snoop test (No Leakage-No Bubbles) Note 3	1, T		X
Environmental	Note 1			
Seismic Condition A	Note 2	1, T		X

Commercial Grade Item Upgrade Dedication Form

SNF-3929, Rev. 8

ECN No. NACGI No. CGI-SNF-D-13-P5-032Page 4 of 11 10Title: Concoa SCHe Pressure Regulators & Reotemp Press. Gauge (SCHe Tank Outlet)hmc
10/18/00

4. Notes and Legend:

1. The Concoa PCVs have stainless diaphragms and the Reotemp has stainless steel whenever contact with fluids. These materials are not subject to degradation at 40°F and 60% RH or 115°F and 22% RH and are suitable for condition B Application.
2. Maintain critical function before and after seismic event. SNF-5304, Appendix I, page I-2, provides a seismic testing plan for these components at a seismic spectra SNF-4895. Equipment that has been shaker-table tested should not be installed in a plant (Ref. IEEE Standard 344-1984, Section 7). Consequently, the seismic test constitutes a destructive test.
3. Pressure test at 110% component internal pressure of 4000 psig.
4. Material verification acceptance method may be by either inspection or test.
5. Model No: 412-2800-01-XA is an assembly of catalog nos. i.e. Regulator Concoa 412-2800-0XA, no gauges, with pigtail (Concoa / 529-0058-CGA-680 / 1/4" MNPT / 3"), 50 psi relief valve (Concoa / 534-2922-50), Panel Mounting Kit (Concoa / 550-0002) and factory relief valve port plugged.

Rev. 4: All pages: added Concoa Regulator, added new forms and revised note 1 and added note 5 (Pg. 3 only). Deleted Matheson Regulator.

Rev. 5: Added Reotemp Pressure Gauges.

Rev. 6: Updated reference documentation.

Rev. 7: Per OTE NCR #5354 Disposition: Revised Regulator Model No. from "412-2800-01-XA" to "412-2800-0XA", Pigtail Manufacturer/Model No. from "529-0058-680 (316 Stainless Steel Inner Core, 3850 psig, 2 foot length)" to "529-0058-CGA-680 (PTFE Inner Core, 4500 psig, 3 foot length)", and Concoa Relief Valve Setpoint from " ± 5 psig" to " 50 ± 5 psig". Revised pressure regulator test pressure range from "100 to 3000 psig" to "a minimum of 3000, not to exceed 3600 psig."

Rev. 8: Changed Equipment ID No. from SCHe-PCV-5*05 to 5*04; changed Regulator Component Number-Procurement and/or Model Number from "412-2800-0XA" to "412-2800-0XA or 412-2800-01-XA"; Deleted CCs for Relief Valve Manufacturer/Model No., Pigtail Manufacturer/ Model No. / Connection Size / Length, and Panel Mount Kit Manufacturer/Model No. and placed information in Note 5. Changed from Outlet Connection "1/4" NPT Male" to "1/4" NPT Female". Changed Supplier from "TBD" to "Olympic Tool & Engineering". Revised Sampling Size referenced docs from "Attachment H, Table H-1 of Desk Instruction" to "Appendix D, Table D-1 of EN 6-035-01".

Acceptance Method:

1. Special Test and Inspection
 - 1, IN for Inspection
 - 1, T for Test
 - 1, A for Analysis
2. Commercial Grade Survey
3. Source Verification
4. Vendor/Item History

Section 10 Initial Review and Approval

Approvals:

Designated Engineer:

Ana pu telecom for
Carl Van Katwijk 10/12/00

QA Engineer:

Hank M. Chapin 10/18/00

Design Authority:

Luna 10/18/00

Other:

10/17/00

Commercial Grade Item Upgrade Dedication Form		SNF-3929, Rev. 8
ECN No. NA	CGI No. CGI-SNF-D-13-P5-032	Page 5 of 10
Title: Concoa SCHe Pressure Regulators & Reotemp Press. Gauge (SCHe Tank Outlet)		

Worksheet 1 - Determination of Failure Mechanisms

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation	
		X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.		
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.		
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.		
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.		
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.		
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation			
1. Regulator, Hose or Gauge Body Break			
2. Diaphragm Break/Failure			

Commercial Grade Item Upgrade Dedication Form		SNF-3929, Rev. 8
ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P5-032</u>	Page 6 of 10
Title: Concoa SCHe Pressure Regulators & Reotemp Press. Gauge (SCHe Tank Outlet)		

Checklist 1 - Acceptance Method 1 - Special Test/Inspection Verification

SECTION 1		
Item Description: SCHe Tank Pressure Regulator and associated equipment System #: 13		Equip #: SCHe-PCV-5*04, 5*23, 5*43, 5*63; PI-5*02, 5*21, 5*41, 5*61 Procurement and/or Model #: Concoa: 412-2800-0XA or 412-2800-01-XA; Reotemp: PR-25-S-1-A-4-P34-D
Manufacturer Concoa 1502 Harpers Road Virginia Beach, VA 23454 800-225-0473 Fx: 757-422-3125 e-mail@concoa.com	(Address/Phone): Reotemp 11568 Sorrento Valley Rd, Suite 10 San Diego, CA 92121 USA Toll-Free: (800) 648-7737 Phone: (619) 481-7737 Fax: (619) 481-7415 Email: reotemp@reotemp.com	Supplier (Address/Phone): Olympic Tool & Engineering W. 21 Sanderson Way Shelton WA 98584 Phone 360-426-7878 Fax 360-432-0747

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.			
Insp	Test	Post-Test	
X			1. Nameplate - Manufacturer
X			2. Component Number-Procurement and/or Model Number
X			3. Body Material (Verification may be by either inspection or test)
X			4. Outlet Connection
X			5. Helium Leak Certification
X			6. Dial Size
X			7. Mounting
X			8. Pressure Range
X			9. Accuracy
	X		10. Pressure Boundary
	X		11. Setpoint
	X		12. Relief Valve Setpoint
	X		13. Seismic Condition A

SECTION 3 BY INSPECTION * See Appendix D, Table D-1 of EN 9-035-01 for Sampling Size. References (See Section 7)	
Concoa Pressure Regulator:	
Characteristic: Manufacturer	Sample Size*: 100%
Acceptance Criteria: Concoa	Receipt Inspection Plan / Report #:
Characteristic: Component Number-Procurement and/or Model Number	Sample Size*: 100%
Acceptance Criteria: 412-2800-0XA or 412-2800-01-XA (Per SNF-5304, Design Data Sheet)	
Receipt Inspection Plan / Report #:	
Characteristic: Body Material	Sample Size*: 100%
Acceptance Criteria: Brass	Receipt Inspection Plan / Report #:
Characteristic: Outlet Connection	Sample Size*: 100%
Acceptance Criteria: 1/4" NPT Female	Receipt Inspection Plan / Report #:
Characteristic: Helium Leak Certification (supplied with regulator)	Sample Size*: 100%
Acceptance Criteria: < 1 X 10⁻³ scc/sec	Receipt Inspection Plan / Report #:

Commercial Grade Item Upgrade Dedication Form		SNF-3929, Rev. 8
ECN No. NA	CGI No. CGI-SNF-D-13-P5-032	Page 7 of 10
Title: Concoa SCHe Pressure Regulators & Reotemp Press. Gauge (SCHe Tank Outlet)		

Reotemp Pressure Gauge:		
Characteristic: Manufacturer		Sample Size*: 100%
Acceptance Criteria: Reotemp	Receipt Inspection Plan / Report #:	
Characteristic: Component Number-Procurement and/or Model Number		Sample Size*: 100%
Acceptance Criteria: PR-25-S-1-A-4-P34-D	Receipt Inspection Plan / Report #:	
Characteristic: Dial size		Sample Size*: 100%
Acceptance Criteria: 2.5" Diameter Nominal	Receipt Inspection Plan / Report #:	
Characteristic: Outlet Connection		Sample Size*: 100%
Acceptance Criteria: 1/4" NPT	Receipt Inspection Plan / Report #:	
Characteristic: Mounting		Sample Size*: 100%
Acceptance Criteria: Bottom Mounting	Receipt Inspection Plan / Report #:	
Characteristic: Tube & Socket Material		Sample Size*: 100%
Acceptance Criteria: 316 SS	Receipt Inspection Plan / Report #:	
Characteristic: Pressure Range		Sample Size*: 100%
Acceptance Criteria: 0-5000 psig	Receipt Inspection Plan / Report #:	
Characteristic: Accuracy		Sample Size*: 100%
Acceptance Criteria: Certificate of Calibration by manufacturer show accuracy to be at least 1.6% of full scale		
Receipt Inspection Plan / Report #:		
Section 4 By Special Test * See Appendix D, Table D-1 of EN 5-005-01 for Sampling Size References (See Section 7)		
Characteristic for Test: Pressure Boundary		Samp Size*: ☐ Normal ☐ Reduced ☐ Tightened
Acceptance Criteria: Pressure Test @ 4400 psig for >10 min.; Reduce Pressure to 4000, perform snoop test (No Leakage-No Bubbles)		
Actual Test Value:	Test Plan and Report #:	
Characteristic for Test: Setpoint		Samp Size*: ☒ Normal ☐ Reduced ☐ Tightened
Acceptance Criteria: Maintain delivery pressure of 25 ± 2.5 psig at a pressure no less than 3000 psig but not more than 3600 psig for 96 hours.		
Actual Test Value:	Test Plan and Report #:	
Characteristic for Test: Relief Valve Setpoint		Samp Size*: ☒ Normal ☐ Reduced ☐ Tightened
Acceptance Criteria: 50 ± 5 psig		
Actual Test Value:	Test Plan and Report #:	
Characteristic for Test: Seismic Condition A		Samp Size*: ☐ Normal ☐ Reduced ☐ Tightened
Acceptance Criteria: Maintain critical function before and after seismic event		
Sample Size*: SNF-5304, Appendix I, page I-2, provides the seismic testing plan for these components. The seismic testing is conducted for one complete panel with the components assembled on the panel and tested as a complete assembly. The test seismically qualifies the entire assembly, including mountings, piping, and components. The number of components tested is dictated by the panel assembly design.		
Actual Test Value:	Test Plan and Report #:	

Commercial Grade Item Upgrade Dedication Form		SNF-3929, Rev. 8
ECN No. NA	CGI No. CGI-SNF-D-13-P5-032	Page 8 of 10
Title: Concoa SCHe Pressure Regulators & Reotemp Press. Gauge (SCHe Tank Outlet)		

**If Supplier/Manufacturer or Other, Refer to CGI Checklist-2 for Support Information

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. Summary of Verified Critical Characteristics, Their Verification Methods, and Results

ITEM DESCRIPTION: Regulator									
Critical Characteristics					Verification Results				
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or R/R#	Check-List ID	Number Tested	Number Failed	Verifying Organization
Nameplate - Manufacturer	Concoa	X		1, IN					Printed Name Signature
Model Number	412-2800-0XA or 412-2800-01-XA, (Per SNF-5304, Design Data Sheet)	X		1, IN					Date
Body Material	Brass	X		1, IN					
Outlet Connection	1/4" NPT Female	X		1, IN					
Pressure Boundary	Pressure Test at 4400 psig for >10 min; Reduce to 4000, perform snoop test (No Leakage-No Bubbles)		X	1, T					
Setpoint	Maintain delivery pressure of 25 ± 2.5 psig at a pressure no less than 3000 psig but not more than 3600 psig for 96 hours.		X	1, T					
Concoa Relief Valve Setpoint (adjust to 50 psig as necessary)	50 ± 5 psig		X	1, T					
Seismic Condition A	Maintain Critical Function Before and After Seismic Event.		X	1, T					

2. Disposition of Unverified or Failed Critical Characteristics

Critical Characteristic	Disposition

3. Signature Indicates All Critical Characteristics Verified Satisfactory or Acceptably Dispositioned and Commercial Grade Dedication is Satisfactory and Complete.

Testing Agency Approval: _____	Date: _____	Design Authority: _____	Date: _____
Testing Agency QA Engineer: _____	Date: _____	QA Engineer: _____	Date: _____
BUYER VERIFICATION			

Commercial Grade Item Upgrade Dedication Form		SNF-3929, Rev. 8
ECN No. <u>NA</u>	CGI No. <u>CGI-SNF-D-13-P5-032</u>	Page 9 of 10
Title <u>Concoa SCHe Pressure Regulators & Reotemp Press. Gauge (SCHe Tank Outlet)</u>		

Section 5 Test / Inspection Summary (Acceptance Method 1)											
1. Summary of Verified Critical Characteristics, Their Verification Methods, and Results											
ITEM DESCRIPTION: Pressure Gauge											
Critical Characteristics					Verification Results						
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/N	Procedure or R/R#	Checklist ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Nameplate - Manufacturer	Reotemp	X		1, IN							
Component Number- Procurement and/or Model Number	PR-25-S-1-A-4-P34-D	X		1, IN							
Dial Size	2.5" Diameter Nominal	X		1, IN							
Outlet Connection	1/4" NPT	X		1, IN							
Mounting	Bottom Mounting	X		1, IN							
Tube & Socket Material	316 SS	X		1, IN							
Pressure Range	0-5000 PSIG	X		1, IN							
Accuracy	Certificate of Calibration shows accuracy at least 1.6% of Full Scale per the documentation		X	1, IN							
Pressure Boundary	Pressure Test at 4400 psig (No Leakage-No Bubbles)		X	1, T							
Seismic Condition A	Maintain Critical Function Before and After Seismic Event		X	1, T							
2. Disposition of Unverified or Failed Critical Characteristics										Disposition	
Critical Characteristic											
3. Signature Indicates All Critical Characteristics Verified Satisfactory or Acceptably Dispositioned and Commercial Grade Dedication is Satisfactory and Complete.											
Testing Agency Approval: _____						Design Authority: _____			BUYER VERIFICATION		
Testing Agency QA Engineer: _____						QA Engineer: _____			Date _____		

Commercial Grade Item Upgrade Dedication Form		SNF-3929, Rev. 8
ECN No. NA	CGI No. CGI-SNF-D-13-P5-032	Page 10 of 10
Title: Concoa SCHe Pressure Regulators & Reotemp Press. Gauge (SCHe Tank Outlet)		

Section 6 Contacts / Phone Numbers		
Title	Name	Phone
Design Authority		
QA		
QC		
Cog - Engineer		
CGI Engineer	Larry Price	372-8770
Procurement Engineer		
Other		
Section 7 Supporting Documentation for This Checklist		
Initial Procurement Documents		For Critical Characteristics
☐	Drawings:	
☐	Manuals (specify type & number):	
☐	Design Calculations	
☐	Installation Instructions	
☐	Operation Instructions	
☐	Calibration Instructions	
☐	Manufacturer's Recommended Spare Parts List	
☒	Other: : Catalog Cut Sheets: Concoa 412 Series Regulator, Reotemp Pressure Gauges	All
Procurement Documents		
☐	Certificate of Conformance/Compliance	
☐	Seismic Qualification Certificate	
☐	Environmental Qualification Certificate	
☐	Test Report (s):	
☐	Inspection Report (s):	
☐	CMTRs for ASME Pressure Retaining Materials	
☐	Valve Seat Leakage Report	
☐	Weld Records	
☐	Material Traceability Record	
☐	Other:	