IEA Annex 26: Advanced Supermarket Refrigeration/Heat Recovery Systems

Final Report Volume 1 – Executive Summary

Canada
Denmark
Sweden
United Kingdom
United States (Operating Agent)

Compiled by

Van D. Baxter
Oak Ridge National Laboratory
Oak Ridge, TN, USA

April, 2003

List of Contributors

This volume of the IEA Annex 26 final report contains a detailed summary of the Annex activities including principal conclusions from each participant. The following persons provided the information for this report.

Canada - Daniel Giguère
Natural Resources Canada
CANMET Energy Technology Centre –Varennnes (CETC)
1615 Lionel-Boulet Blvd., Box 4800
Varennnes, Québec J3X 1S6
Canada
1-450-652-5015 phone
1-450-652-5177 fax
daniel.giguere@nrcan.gc.ca

Vasile Minea
Hydro Québec, Institut de recherché
Laboratoire des technologies de l'énergie (LTE)
600, avenue de la Montagne
Shawinigan, Québec G9N 7N5
Canada
1-819-539-1400, ext 1507 phone
1-819-539-1409 fax
minea.vasile@lte.ireq.ca

Denmark - Hans Jørgen Høgaard Knudsen
Department of Mechanical Engineering
Technical University of Denmark
Nils Koppels Allé
DTU – Building 402
DK-2800 Kgs. Lyngby, Denmark
45-45-254121 phone
45-45-935215 fax
hk@mek.dtu.dk

Sweden - Per Lundqvist & Jaime Arias
The Royal Institute of Technology
Department of Energy Technology
Div. of Applied Thermodynamics
and Refrigeration
S-100-44 Stockholm, Sweden
46-8-790-7452 phone (Lundqvist)
46-8-790-8642 phone (Arias)
46-8-20-3007 fax

perlundq@egi.kth.se
jaime@thermo.kth.se

UK - Alison Crompton
Faber Maunsell
Marlborough House
Upper Marlborough Road
St Albans, Hertfordshire AL1 3UT
United Kingdom
44-20-8784-5586 phone
44-20-8784-5562 fax
alison.crompton@fabermaunsell.com

John Palmer
Faber Maunsell
Beaufort House
94/96 Newhall Street
Birmingham B3 1PB
United Kingdom
44-121-262-6750 phone
44-121-262-1999 fax
john.palmer@fabermaunsell.com

US - Van D. Baxter
Steven K. Fischer
Oak Ridge National Laboratory
Box 2008, Bldg 3147, MS-6070
Oak Ridge, TN 37831-6070
USA
1-865-574-2104 phone (Baxter)
1-865-574-2017 phone (Fischer)
1-865-574-9329 or 9338 fax
vdb@ornl.gov
fis@ornl.gov

David H. Walker
Foster-Miller, Inc.
350 Second Avenue
Waltham, MA 02451
1-781-684-4237 phone
1-781-890-3489 fax
dwalker@foster-miller.com

Table of Contents

List of Contributors	ii
Table of Contents	iv
List of Figures	vi
List of Tables	vi
Introduction to IEA Annex 26	1
Background	2
General summary of system technology approaches to reduce supermarket TEWI	5
<u>Secondary loop type systems</u>	6
<i>Estimates of cost premium</i>	<i>9</i>
<i>Estimates of TEWI reduction</i>	<i>10</i>
<u>Distributed compressor refrigeration system</u>	10
<i>Estimates of cost premium</i>	<i>12</i>
<i>Estimates of TEWI reduction</i>	<i>12</i>
<u>Low charge multiplex systems</u>	12
<i>Estimates of cost premium</i>	<i>14</i>
<i>Estimates of TEWI reduction</i>	<i>14</i>
<u>Advanced self-contained systems</u>	14
<i>Estimates of cost premium</i>	<i>15</i>
<i>Estimates of TEWI reduction</i>	<i>15</i>
<u>HVAC integration approaches</u>	15
Country report summaries	18
<u>Canada - CANMET Energy Technology Centre –Varennnes (CETC–Varennnes) of</u>	
<u>Natural Resources Canada</u>	18
<u>Canada - Hydro-Quebec Research Institut, Laboratoire des technologies de l’énergie</u>	
<u>(LTE)</u>	20
<i>Total Heat Recovery (“System1-phase1”)</i>	<i>21</i>
<i>Total Heat Recovery (“System2–phase1”)</i>	<i>21</i>
<i>High Speed Defrost</i>	<i>23</i>
<i>Liquid Pumping and Injection</i>	<i>23</i>
<i>Geothermal Cooling</i>	<i>24</i>
<i>Further Developments</i>	<i>24</i>
<u>Denmark</u>	25
<u>Sweden</u>	27
<u>United Kingdom</u>	33
<i>Secondary Systems</i>	<i>33</i>
<i>Defrost</i>	<i>34</i>

<i>CHP/CCHP</i>	35
<i>Case and Store Environment Interaction</i>	36
<i>UK Overall Conclusions</i>	37
<u>United States</u>	37
<i>System analysis summary</i>	38
<i>Payback estimates</i>	40
<i>Field test summary</i>	41
Supermarket energy use screening level model	42
Overall Summary	42
<u>Canada</u>	43
<u>Denmark</u>	43
<u>Sweden</u>	44
<u>United Kingdom</u>	44
<u>United States</u>	45
<u>Summary comments</u>	45
References	46
Acknowledgements	47
Appendix A - Case Study Summaries	48
<u>Canada - LTE</u>	48
<u>Denmark</u>	62
<u>United States</u>	66

List of Figures

Fig. 1. Layout of a typical modern supermarket.....	3
Fig. 2. Total equivalent warming impact (TEWI) for low temperature supermarket refrigeration in North America.	4
Fig. 3. Multiplex refrigeration system.....	5
Fig. 4. Elements of the secondary loop refrigeration system.....	7
Fig. 5. Propane/carbon dioxide cascade refrigeration system.....	8
Fig. 6. Distributed compressor refrigeration system schematic.	11
Fig. 7. Low-charge multiplex system compressor rack concept 1.	13
Fig. 8. Low-charge multiplex system compressor rack concept 2.	13
Fig. 9. Roof top heat pump unit.	17
Fig. 10. Plate heat exchangers (HX) for heat pump evaporators and refrigeration desuperheaters and subcooler.....	17
Fig. 11. Results from CyberMart.....	29
Fig. 12. Indoor temperature, outdoor temperature and indoor relative humidity in Hedemora and Sala.....	30
Fig. 13. Temperatures, relative humidity and compressor power in Sala.	31
Fig. 14. Temperatures in a deep freeze cabinet and indoor and outdoor temperatures during four days in July in Hedemora.....	32
Fig. 15. Refrigeration energy usage in The United Kingdom by end use.	33
Fig. 16. Example of freezer case type tested by UK team in environmental chamber to determine impact of store temperature, relative humidity and ventilation mode (conventional or displacement) on performance.....	36
Fig. A1. Comparison of energy use of Fakta Beder store (with cascade refrigeration system) to that of eight other Fakta stores (with conventional R404A DX refrigeration systems); July 2000 through February 2002.	65

List of Tables

Table 1. Predicted Energy Consumption for Low-Charge Refrigeration Systems.....	39
Table 2. Total Equivalent Warming Impact (TEWI) for Supermarket Refrigeration.....	40

Annex 26 Final Report

Advanced Supermarket Refrigeration/Heat Recovery Systems

Executive Summary

Introduction to IEA Annex 26

With increased concern about the impact of refrigerant leakage on global warming, a number of new supermarket refrigeration system configurations requiring significantly less refrigerant charge are being considered. In order to help promote the development of advanced systems and expand the knowledge base for energy-efficient supermarket technology, the International Energy Agency (IEA) established IEA Annex 26 (Advanced Supermarket Refrigeration/Heat Recovery Systems) under the *IEA Implementing Agreement on Heat Pumping Technologies*. Annex 26 focuses on demonstrating and documenting the energy saving and environmental benefits of advanced systems design for food refrigeration and space heating and cooling for supermarkets. Advanced in this context means systems that use less energy, require less refrigerant and produce lower refrigerant emissions. Stated another way, the goal is to identify supermarket refrigeration and HVAC technology options that reduce the total equivalent warming impact (TEWI) of supermarkets by reducing both system energy use (increasing efficiency) and reducing total refrigerant charge.

The Annex has five participating countries: Canada, Denmark, Sweden, the United Kingdom, and the United States. The working program of the Annex has involved analytical and experimental investigation of several candidate system design approaches to determine their potential to reduce refrigerant usage and energy consumption. Advanced refrigeration system types investigated include the following:

- distributed compressor systems – small parallel compressor racks are located in close proximity to the food display cases they serve thus significantly shortening the connecting refrigerant line lengths;
- secondary loop systems – one or more central chillers are used to refrigerate a secondary coolant (e.g. brine, ice slurry, or CO₂) that is pumped to the food display cases on the sales floor;
- self-contained display cases – each food display case has its own refrigeration unit;
- low-charge direct expansion – similar to conventional multiplex refrigeration systems but with improved controls to limit charge.

Means to integrate store HVAC systems for space heating/cooling with the refrigeration system have been investigated as well. One approach is to use heat pumps to recover refrigeration waste heat and raise it to a sufficient level to provide for store heating needs. Another involves use of combined heating and power (CHP) or combined cooling, heating, and power (CCHP) systems to integrate the refrigeration, HVAC, and power services in stores. Other methods including direct recovery of refrigeration reject heat for space and water heating have also been examined.

A workshop on advanced supermarket refrigeration was held October 2-4, 2000 in Stockholm. Reports were made by Annex participants and other invited experts on the status of refrigeration research and development activities in the US and Europe. The workshop proceedings (in cd-rom format) are available from the IEA Heat Pump Centre (Lundqvist, ed, 2000).

This report provides an account of the results of the work programs of the Annex participants. This volume gives an executive summary of the results. Full details are given in the individual country reports in volume 2.

Background

Supermarkets are one of the most energy-intensive types of commercial buildings. Significant energy is used to maintain chilled and frozen food in both product display cases and storage refrigerators. The refrigeration systems also produce a large amount of rejected heat that can be recovered and used by heat pumps or other equipment to provide space and water heating for store requirements. There is a wide range in size of supermarkets among the Annex 26 countries. In Europe stores range in size from about 500 m² to 3000 m² or somewhat larger. Stores are typically larger in Canada and the US ranging from a minimum of about 1000 m² to 10000 m². Plant capacities range from 30-60 kW for small markets to over 400 kW for the largest stores. Similarly, annual energy use ranges from about 100,000 kWh/y for the smaller stores to 1.5 million kWh/y or more for the largest.

Refrigeration is the largest component of supermarket energy use, accounting for half or more of the store total. Perishable products must be kept refrigerated during display and for storage. Compressors and condensers account for 60-70% of refrigeration energy consumption. The remainder is consumed by the display and storage cooler fans, display case lighting, evaporator defrosting, and for anti-sweat heaters used to prevent condensate from forming on doors and outside surfaces of display cases.

Figure 1 shows a representative layout for a supermarket showing refrigerated display cases and storage areas located generally around the store perimeter. The most commonly used refrigeration system for supermarkets today is the multiplex direct expansion (DX) system. All display cases and cold store rooms use direct expansion air-refrigerant coils that are connected to the system compressors in a remote machine room located in the back or on the roof of the store. This requires thousands of meters of pipe with case connections that have historically been designed for ease and rapidity of service rather than low leakage. This practice is changing for new supermarkets with more emphasis on reducing leakage. Heat rejection is usually done with air-cooled condensers because these are the least cost to install and maintain. Evaporative condensers can be used as well and will reduce condensing temperature and system energy consumption. However, they carry the burden of increased maintenance effort and cost. In either case, system controls are usually set to allow the condensing temperature to float with the outdoor dry bulb (or wet bulb) temperature, usually to a minimum level of around 21°C (about the lowest condensing temperature for reciprocating compressors which are the most common type used in supermarkets).

The amount of refrigerant needed to charge multiplex DX systems is very large - typically 4-5 kg/kW of refrigeration capacity. The large amount of piping and pipe joints required can also result in large refrigerant losses – historically 30% or more of the total charge annually. New systems can achieve annual refrigerant leakage rates of around 15% or somewhat lower (Sand, et al, 1997). The large refrigerant charge and high loss rate for multiplex direct expansion refrigeration systems results in high values of TEWI (total equivalent warming impact) with direct refrigerant loss impact accounting for about half of the total as shown in Figure 2.

Figure 1 – Layout of a typical modern supermarket

Figure 3 shows the major elements of a multiplex refrigeration system. Multiple compressors operating at the same saturated suction temperature are mounted on a skid, or rack, and are piped with common suction and discharge refrigeration lines. Using multiple compressors in parallel provides a means of capacity control, since the compressors can be selected and cycled as needed to meet the refrigeration load.

ORNL 02-03970/abh

Figure 2 – Total equivalent warming impact (TEWI) for low temperature supermarket refrigeration in North America

Figure 3 – Multiplex refrigeration system

General summary of system technology approaches to reduce supermarket TEWI

Part of the UK's contribution to the Annex was a detailed review of existing technologies and new technologies for supermarkets (see UK country report, Volume 2). The bottom line from this state of the art review of advanced supermarket refrigeration is that there are a number of areas in which significant energy savings may be realized and environmental impact reduced. From the overall design of the energy supply, from CHP and CCHP, through to the interaction of the store environment and the cabinets, savings can be made. These factors offer a wide range of opportunities to bring about reductions in the energy use and TEWI of supermarket refrigeration systems.

The advanced supermarket refrigeration systems described in this section are designed primarily to reduce the amount of refrigerant needed for operation and thereby the amount of annual refrigerant loss. This is generally accomplished by use of secondary refrigerants in a secondary loop type system, reduction of refrigerant connecting line length between compressors and display cases, improved refrigerant management and flow controls, or a combination of these approaches. Advantages and disadvantages of these systems with respect to energy efficiency and possible cost implications are briefly discussed in this section also. These issues are dealt with in more

comprehensive fashion in the individual country reports. Four generic system types have been investigated as part of the Annex 26 work effort. They are secondary loop, distributed, low-charge multiplex, and advanced self-contained systems.

Secondary loop type systems

Secondary loop refrigeration systems can take many forms, but they generally employ one or more chillers to refrigerate a secondary fluid that is then pumped to the display cases and storage rooms. Figure 4 shows the elements of one secondary loop approach. In this case the chillers, similar in configuration to multiplex compressor racks, provide chilled secondary refrigerant for the cases. The discharge of the compressors is to a common manifold and the discharge gas is piped to a remote condenser, normally located on the roof above the machine room. The use of evaporative condensing can produce the lowest average condensing temperature with lower fan energy than seen with air-cooled condensers, thus minimizing overall energy consumption especially in warmer climate areas. Primary refrigerant charge requirement can be reduced to about 10-15% of that needed for conventional direct expansion system. A variation on the system shown in Figure 4 is to use a secondary fluid on the heat rejection (condenser) side of the chiller as well as on the refrigeration (evaporator) side. This approach can reduce primary refrigerant requirements to less than 5% of direct expansion but would introduce an additional secondary heat exchanger thermodynamic energy penalty to the system and increase energy usage.

Secondary loop systems have features that tend to improve the efficiency of the primary system. These include close coupling of the compressors to the chiller evaporators, and the ability to subcool the primary refrigerant with the secondary fluid (brine) and use the warmed brine to defrost the case heat exchangers.

Figure 4 - Elements of the secondary loop refrigeration system

For large stores secondary loop systems generally use at least two separate secondary fluid loops and chillers – one each for the low temperature (frozen food) cases and storage rooms and medium temperature (chilled food) cases and rooms. Using only two fluid loops for refrigeration, however means that all display cases and storage coolers must operate with these two temperatures. The use of multiple secondary fluid loops with temperatures more closely matching the case air temperature requirements can improve energy efficiency because it raises the effective average evaporator temperature of the system. The US country report includes an analysis of such a system using four different fluid loops. It must be stated however, that each loop will require a separate chiller and controls and that will increase the system cost.

Another approach to secondary systems is the cascade-type system. Figure 5 schematically illustrates one example of a cascade system. The high temperature loop (using propane as the refrigerant in this illustration) removes heat from the low temperature loop (using CO₂) condenser and also chills a brine (propylene glycol), which is circulated to the chilled food cases. The CO₂ refrigerates the frozen food cases through direct expansion evaporators. Other combinations of refrigerants are possible for this system concept.

Figure 5 - Propane/carbon dioxide cascade refrigeration system (from Danish country report)

The following is a listing of several candidate fluids for use in secondary loop systems that have been investigated in prior studies (Melinder, 2000; Kazachki, et al, 1997; Hrnjak, 1996; Hrnjak, 2000; Horton, 2002; Sherwood, 1999). Under Annex 26 some detailed property measurements and comparisons were conducted by the UK team (see country report in Volume 2).

Ethylene glycol/water
 Propylene glycol/water
 Potassium Formate/water
 Pekasol 50
 Freezium
 Hycool
 Trichloroethylene
 Inhibited alkali ethanate solution
 Tyfoxit
 Hydrofluoroether
 HFE-L-13938
 HFE-7100
 Cyclohexene
 D-Limonene
 Polydimethylsiloxane (Silicon Oil)
 Syltherm
 Dowtherm
 Synthetic Isoparaffinic Petroleum Hydrocarbons
 Therminol

No single one of these fluids can be considered ideal for all secondary refrigerant applications. Those most widely used in supermarket systems appear to be propylene glycol/water solutions for medium temperature loops and potassium formate/water solutions for low temperature loops. However, some analytical studies indicate thermal and pressure drop advantages for HFE-7100 over potassium formate solutions for low temperature applications -- below about -20 °C (Sherwood, 1999; Horton, 2002). Liquid CO₂ is also seeing increasing use as a secondary fluid for both temperature levels particularly in Europe. Means must be considered to deal with internal tube pressures in CO₂ systems in the event of power outages or other failures.

Estimates of cost premium. A number of studies have been conducted to estimate cost premiums with the added cost estimates ranging from none to about 40%. A study by Sherwood (1999) compared installed costs for a secondary loop and a multiplex direct expansion system for a low-temperature system typical of North American supermarkets -- about 80 kW total cooling capacity. The secondary system used NH₃ in the primary loop and HFE-7100 as the brine while the DX used R-404A. Installation cost (material and labor) for the DX system was the actual figure taken from the refrigeration schedule for the store. Costs for the secondary loop system were estimated based on interviews with supermarket industry professionals. This study considered the total cost of the system (including cases, piping, refrigerant, brine, and labor in addition to the compressor rack or primary chiller) with the exception of the condenser subsystem. It was determined that installed costs for both approaches were equal -- i.e., 0% cost premium for the secondary approach.

Vana (2000) noted in discussions at the Annex 26 workshop that installation cost premiums for secondary loop approaches (using R404A or R507 as primary refrigerant and propylene glycol or potassium formate brines for secondary loops) were about 15% for typical US markets. He also noted that maintenance costs for the secondary system should be less. Horton (2002) conducted an operating (energy and maintenance) cost comparison between secondary loop (NH₃ primary/HFE-7100 secondary) and multiplex DX (R22 medium temperature/R404A low temperature) systems and concluded that maintenance costs were 25% lower and operating costs 15% lower for the secondary approach. All of the operating savings were attributed to the high efficiency of the NH₃ primary system -- high enough to overcome the secondary pumping power and heat transfer penalties in this analysis.

A cost and payback analysis is included in the US country report for secondary loop (R507 primary/ propylene glycol and potassium formate secondary brines) and multiplex DX (R22/R404A) systems serving a supermarket with a 330 kW refrigeration load. The DX system was assumed to have standard air-cooled condensers while the secondary system was assumed to have evaporative condensers (to minimize energy use). The secondary system had an estimated installation cost premium of \$147,000 US that was based on interviews with engineering departments of two supermarket companies. Payback in this case ranged from 8 to 17 years depending on climate conditions. More details are given in the US report (in Volume 2).

The Danish country report (Volume 2) compares installation costs and operating efficiencies for a cascade system based on that shown in Figure 5 and R404A DX systems. A test system installed in a small store (30 kW load) was estimated to cost

about 20% more than a traditional DX system and to have about the same energy efficiency. With more experience for installers the premium is estimated to drop to under 15%. For larger systems (90 kW) the premium is estimated to be 10% or less.

Estimates of TEWI reduction. TEWI reduction estimates from the investigations carried out under Annex 26 range from <10% to about 60% compared to the multiplex DX/air-cooled condensing baseline. The wide range in TEWI estimates is attributable to assumptions made about the overall system design (compressor type, heat rejection approach, selection of secondary fluid, etc.) and operation. Secondary loop systems must be designed and operated carefully with an eye to minimizing the inherent secondary heat exchange and pumping power penalties in order to achieve the greatest TEWI benefit.

Distributed compressor refrigeration system

Figure 6 shows a diagram of the distributed compressor refrigeration system. The big difference between this system and conventional multiplex systems is that several small compressor racks are located in cabinets that are distributed throughout the store and close-coupled to the display case lineups or storage rooms they serve. With this approach the long lengths of piping needed to connect the cases with large remote compressor racks in a machine room are eliminated. The cabinets may be placed either at the end of a case lineup on the sales floor or behind the cases around the perimeter of the store.

With this arrangement, the saturated suction temperature (SST) employed for each compressor cabinet can closely match the evaporator temperature of the display cases and walk-in coolers to which it is connected. This is not always possible with conventional multiplex systems, since a single rack will often provide refrigeration to display cases with three or four different evaporator temperatures. Each compressor rack of a multiplex system must operate at a SST value that will satisfy the temperature requirements of all display cases connected to it. The better temperature matching seen with distributed refrigeration can benefit the energy consumption of the overall system.

The refrigerant charge requirement for the distributed system is much less than for multiplex systems. The reduction in charge is due to the shortening of the suction and liquid lines to the display cases. If a secondary fluid loop is used for heat rejection (as shown in Figure 6) then the refrigerant heat rejection piping to a remote condenser and its associated charge is eliminated as well. With a secondary loop for heat rejection, the refrigerant charge required for a distributed system would be about 30-35% of that required for multiplex systems. If separate rooftop condensers are used for each cabinet, the total charge requirement will be about 50-60% that of multiplex systems. A secondary heat rejection loop will result in higher condensing temperatures and energy consumption than if direct roof top condensers are used.

Figure 6 - Distributed compressor refrigeration system schematic

Each compressor cabinet in a distributed system is similar to a multiplex rack only smaller. All necessary electrical and piping connections are provided within the cabinet, such that the only field connections are the refrigerant liquid and suction lines, fluid inlet and outlet piping for heat rejection, and electric service wiring. Multiple compressors of several sizes are employed, which are piped in parallel so that multiplex operation can be used to match the refrigeration capacity to the load. Usually, three to five compressors are installed in each cabinet. The cabinets are equipped with discharge and suction manifolds for parallel piping of the compressors. The suction manifold can be divided so that multiple suction temperatures can be provided from a single cabinet.

Current distributed refrigeration systems generally employ scroll compressors, because of the very low noise and vibration levels encountered with this type of compressor. These characteristics are necessary if the compressor cabinets are located in

or near the sales area. Current refrigeration scroll compressors are typically less efficient at evaporating and condensing temperatures of interest for supermarket refrigeration than the reciprocating types used in most conventional systems. However, they do have several features that can offset this efficiency disadvantage in system applications and potentially yield system efficiency improvements. For instance, scroll compressors have no valves, and, therefore, can be operated at significantly lower condensing temperatures than can reciprocating compressors. The lowest condensing temperature possible is at a suction-to-discharge pressure ratio of two (2), which means for supermarket systems that the lowest condensing temperature possible is on the order of 10 – 15 °C.

The close coupling of the display cases to the distributed refrigeration cabinets has other ramifications to energy consumption. The shorter suction lines mean that the pressure drop between the case evaporator and the compressor suction manifold should be less than that seen with conventional multiplex systems, which means that the compressors' SST will be closer to the display case evaporator temperature. Typically, the SST of conventional multiplex racks will be 1-2.5 °C less than the case evaporator temperature. SST values for the distributed system will be about 0.5-1 °C less than the case evaporator temperature. The shorter suction lines also mean that less heat gain to the return gas should be experienced. The cooler return gas has a higher density and results in higher compressor mass flow rates, which means that less compressor on time is needed to satisfy the refrigeration load. The return gas temperature rise expected for distributed refrigeration systems is normally on the order of 3 to 9 °C, depending on the distance between the compressor cabinet and the display cases and the evaporator temperature of the display cases. A greater return gas temperature rise is seen in low temperature systems than is seen in medium temperature. In comparison, the return gas temperature rise typically seen with multiplex systems falls between 20 and 35 °C, due to the longer length of suction lines employed. The liquid temperature can also be adversely affected by line length if subcooling is employed. Heat gain to a subcooled liquid line will result in a rise in liquid refrigerant temperature before reaching the display cases.

Estimates of cost premium. The US country report includes cost and payback estimates for this system. Installed cost for a distributed (using a secondary fluid loop and evaporative cooling tower for condenser heat rejection) was estimated at \$60,000 (about 15%) over a baseline multiplex DX system (R22/R404A with air-cooled condensers) for a supermarket with a 330 kW refrigeration load. Payback ranged from about 3 to 7 years depending on location.

Estimates of TEWI reduction. Potential TEWI reductions from this work range from a high of about 60% (analytical estimate for well designed system) to 40% (from a field test). As in the secondary loop case, careful attention to design and operation is essential to achieving maximum benefits.

Low charge multiplex systems.

Several approaches have been taken by refrigeration system manufacturers to reduce the refrigerant charge required by traditional multiplex system compressor racks. These approaches reduce the overall system refrigerant charge but retain the long connecting lines between compressors and display cases. Figures 7 and 8 illustrate two such low charge multiplex rack options.

Figure 7 – Low-charge multiplex system compressor rack concept 1

Figure 8 – Low-charge multiplex system compressor rack concept 2

The first system (Figure 7) limits refrigerant charge by minimizing the refrigerant inventory in the receiver during normal operation (the receiver's primary function in this design is to provide refrigerant storage during system servicing). Total charge required for this system is expected to be about 2/3 that of a conventional multiplex system. This charge control approach also can yield some energy savings because it can allow the system compressors to operate at lower condensing temperatures than would normally be the case. The control valve and ambient temperature sensor are intended to maintain a constant temperature difference between the condenser outlet liquid and the ambient. Liquid refrigerant flow through the valve is vaporized by heat exchange with the discharge manifold. Any refrigerant not vaporized is stored in the receiver. Saturated discharge temperatures can be as low as about 5 °C for low temperature racks and about 15 °C for medium temperature racks. Normally reciprocating compressors are limited to minimum condensing temperatures of about 21 °C and scroll compressors to a minimum of about 15 °C.

The second charge control approach (Figure 8) tries to reduce charge to the minimum needed for correct operation of the system evaporators. A mixture of vapor and liquid refrigerant is sent to each display case lineup and storage room. Operation of the evaporators is done using a combination of relay and balancing valves to control refrigerant flow and evaporation. Refrigerant mixture flow to each case lineup is controlled at the compressor rack. Total refrigerant charge required by this approach is expected to be as little as 30% of that needed by conventional multiplex systems and the energy efficiency is claimed to equal that of conventional systems. Heat reclaim can be done with a heat exchanger and fluid loop as shown in Figure 8.

Estimates of cost premium. System economic analysis in the US country report (Volume 2) assumed the installed cost for this system type to be the same as for baseline multiplex DX systems (if both use the same type condenser).

Estimates of TEWI reduction. TEWI could be reduced by from 20% to over 40% by these systems (compared to the baseline) if the charge reduction and energy saving targets can be achieved in real systems.

Advanced self-contained systems.

A self-contained refrigeration system consists of display cases or storage coolers each having their own condensing units. Self-contained systems are presently used in supermarkets for a limited number of cases, where the cases are in a location inaccessible to the central refrigeration piping. An example is a refrigerated beverage case placed at the cash registers for spot sales. Self-contained units are also employed as add-on cases or for temporary display of special sales items. Present self-contained display cases use small reciprocating compressors and air-cooled condensers. Heat is rejected directly into the sales area. Only a limited number of self-contained units of this type can be employed before noise and heat rejection levels interfere with store operation. Problems of this type caused store designers in the past to go to the remote machine room approach now used in most supermarkets.

The self-contained system approach could be attractive for reduction of refrigerant charge. It is estimated that the total charge for a supermarket could be

reduced to about 5-10% that of conventional multiplex systems if self-contained systems were used for all refrigeration needs.

An advanced self-contained system could be formulated using water-cooled condensers and a fluid loop for heat rejection to eliminate concerns of heat rejection in the store sales area. The compressor noise issue will still be a factor, but can be addressed by the use of scroll compressors. Until recently, scroll compressors were available only in a vertical configuration, which was not suitable for placement in display cases. Now, horizontal scroll compressors have been introduced, which could be employed for this purpose. These horizontal scrolls are capable of continuous unloading for capacity control and maintenance of a suction pressure set point.

Estimates of cost premium. No referencable cost studies have been found for this system approach. The system can be assumed to be an extreme case of the distributed compressor approach, however, and therefore the cost premium over multiplex DX could be assumed to be similar as well.

Estimates of TEWI reduction. No definite estimate has been made for this system type. However, as above it could potentially achieve the same TEWI reductions as the distributed system if efficient enough small compressors and other system components can be found or developed to keep the system energy use on a par with or better than that of the baseline DX system.

HVAC integration approaches

The large amount of heat rejected by the refrigeration system in a typical supermarket offers an attractive resource for use in store space heating. Integration approaches examined during the course of this Annex have included straightforward heat reclaim, use of heat pumps integrated with the refrigeration system, and use of CHP or CCHP systems.

During a meeting of the Annex in Canada a supermarket with a heat reclaim system was visited. The store had two R22 multiplex refrigeration compressor racks (one each for medium temperature and low temperature loads) with two condensers in series. In winter, primary condensing is done in a plate heat exchanger with water on the other side. The water from the medium temperature rack heat exchanger is piped to coils in the HVAC air ducts and used for store heating. Heat from the low temperature rack is used for store water heating and for reheat for the store dehumidification system in summer. An auxiliary boiler is included in the HVAC system to cover times when heat from the refrigeration condenser cannot meet the store heating load. According to the installer, the propane boiler was not needed during the first winter (01/02) of operation. The refrigeration system saturated discharge temperature is allowed to float to a minimum of about 27 °C under most conditions. In periods of high space heat demand, the refrigeration system condensing temperature is raised as necessary (to a maximum of 35 °C with some negative impact on refrigeration compressor energy use) to meet the store heating demand. In summer the refrigeration system uses a conventional rooftop air-cooled condenser for heat rejection. Also according to the installer this system has about 3% higher cost than a conventional refrigeration/HVAC system (Bastrash, 2002).

The use of heat pumps represents an excellent way to utilize refrigeration reject heat for space heating. Two different heat pump integration approaches have been examined by individual Annex participants. One involves direct integration of the heat

pump evaporator(s) and refrigeration system condenser(s) and the second utilizes water-source heat pumps (WSHP) where water-cooled condensers and water/glycol loops are used for refrigeration system heat rejection. The heat pumps can be installed in the glycol/water loop and use the rejected heat to provide space heating. Either method enables reclamation of a very large portion of the reject heat without requiring elevation of the condensing temperature of the refrigeration system as can happen with conventional heat reclaim approaches. Refrigeration system energy savings achieved by low head pressure operation can be realized along with the energy benefits seen through heat reclaim.

An example of the first type was also seen during the Annex meeting in Canada. The refrigeration system is a traditional R22 multiplex system with two racks (low temperature and medium temperature) and both used a common set of two condensers in series. Figures 9 and 10 illustrate this heat pump integration approach. In winter, the discharge gas from the refrigeration compressors goes first through three plate heat exchangers which serve to desuperheat and precondense the gas. Final condensing is accomplished in a conventional rooftop air-cooled condenser. The other side of the three heat exchangers serve as the evaporators for three rooftop heat pumps which supply space heating to the store. A fourth rooftop heat pump is similarly integrated with the liquid line exiting the air-cooled condenser via a fourth plate heat exchanger. This heat pump subcools the liquid refrigerant leaving the refrigeration system condenser and uses the recovered heat for store space heating. In summer, the refrigeration system uses the air-cooled condenser exclusively and the heat pumps use their own condensers to reject heat from space cooling loads. The refrigeration system also includes a liquid refrigerant pump to boost the pressure of the refrigerant before it is sent to the cases. The pump is included because with the heat pump integration the refrigeration system head pressure is allowed to float to about 15 °C minimum saturated discharge temperature. According to the installer the system cost for that store is about 8% more than what a conventional refrigeration and HVAC system would have cost (Kantchev, 2002). Some details of this system are included in Canada's country report where it is identified as the LMP system.

Figure 9 – Roof top heat pump unit

Figure 10 – Plate heat exchangers (HX) for heat pump evaporators and refrigeration desuperheaters and subcooler

The use of WSHPs in conjunction with water-loop heat rejection for the refrigeration system was examined by the US (see US country report, Volume 2). An analysis was performed for a supermarket HVAC system where conventional rooftop air-conditioner/gas heating units and water-source heat pumps were examined and compared. The combination of a water-cooled distributed compressor refrigeration system with water-source heat pumps was predicted to save about 10-20% in overall operating (refrigeration plus HVAC energy) costs depending on local climate and utility rates when compared to the baseline air-cooled multiplex DX refrigeration system with conventional rooftop HVAC units. The added installation cost for the WSHP approach was estimated to be about \$25,000 US (about 30%) over the conventional rooftop unit system.

CHP/CCHP system concepts were studied in detail by the UK team. They concluded that CCHP has an improved load match compared to CHP, when used with absorption chilling for building cooling. Integral cascade vapor compression systems within each display case integrated with the absorption system provide food refrigeration. Primary energy savings are around 15%, and there is a TEWI reduction of more than 50% compared with conventional supermarket systems.

The impact that store ambient conditions can have on refrigeration system and case energy use was illustrated by part of the UK team effort. Environmental chamber tests of low and medium temperature case systems show that an increase in ambient temperature from 19 to 22 °C increases system energy use by 20%. Increasing RH from 35 to 50% at an ambient of 22 °C increased the medium temperature case energy use by 15% but had no effect on the freezer case.

Country report summaries

Following are summarized key results from the work programs carried out by each country under Annex 26. Full details of these projects can be found in the individual country reports.

Canada - CANMET Energy Technology Centre –Varennnes (CETC–Varennnes) of Natural Resources Canada

The CETC–Varennnes contribution to the Annex included a supermarket showcase with a fully integrated HVAC/Refrigeration system using secondary fluid on condenser and evaporator sides, the organization of an advisory committee, one workshop for the Canadian refrigeration industry and two research projects directly related to supermarket refrigeration.

There are approximately 31,000 retail food stores in Canada 7,150 of which are considered large supermarkets – with a floor cover area of over 1,000 m². Supermarkets are among the most energy intensive buildings in the commercial sector with a total energy consumption of more than 800 kWh-equivalent/m²/year (and increasing with time). Refrigeration represents about 50% of the electrical energy consumption of a supermarket, costing on average \$150,000 CND per year for a typical large size supermarket (2000 m²). The typical refrigeration system contains approximately 750 kg of synthetic refrigerant equivalent to 2,000 tonnes of CO₂ in terms of greenhouse gas

effect. Refrigerant losses are on average, 25% per year of the total charge. The refrigeration sector is currently facing several major challenges such as: the legislated replacement of synthetic refrigerants that have negative environmental impacts; the increasing cost of refrigerants; the poor efficiency of equipment that are not adapted to Canadian climatic conditions; new regulations for refrigerated product storage and transportation; and a lack of innovation and adequate expertise in Canada to address these issues.

CTEC signed an agreement with a major Canadian supermarket chain to develop a supermarket technology showcase in a Montreal area in the end of 2003. The project's objective is to develop innovative integrated HVAC&R technologies and practices suitable for Canadian climatic conditions, using compact and hermetic refrigeration systems using secondary fluid for the evaporator and condenser sides, and to demonstrate them in partnership with a major chain of supermarkets in Canada. These demonstrations will provide the opportunity to get a better understanding of their technical requirements such as design, installation, commissioning, and performance as well as their non-technical barriers (knowledge transfer to energy consultants and technical operators, costs, procurements, etc.). The selected measures should result in reductions in operating and maintenance costs, refrigerant leakage and, indirectly, food spoilage. Secondary fluid systems will contain less refrigerant and fewer potential refrigerant leak locations, resulting in a substantial reduction in the emission of greenhouse gases. This project is part of a strategy to transfer technology and disseminate know-how.

CTEC organized meetings of an Industry Advisory Panel consisting of supermarket and refrigeration sector representatives. The objective of these committees is to provide advice for case studies, laboratory experiments or demonstration projects in accordance with the Canadian supermarket sector needs. The committee's invited membership includes companies representing retailers, compressor rack manufacturers, display case manufacturers, supermarket refrigeration control manufacturers, consulting engineers and government agencies. The Industry Advisory Panel participants understand and are pleased with the Annex 26 strategy to increase the energy efficiency/heat recovery of supermarket refrigeration systems, while reducing the overall refrigerant charge and potential leaks.

More than 85 people attended the first Canadian Workshop on Refrigeration Systems on March 11, 2003 in Montreal. The event was sponsored by CETC-Varenes and the Office of Energy Efficiency (OEE), in collaboration with Agence de l'efficacité énergétique (AEE), Hydro-Québec, Manitoba Hydro and BC Hydro. With a possible reduction of 1.4 Mt equivalent CO₂/year by 2010, refrigeration in supermarkets has a great potential of energy efficiency and greenhouse gas emission reductions. The refrigeration industry (equipment manufacturers, food retailers, design engineers, mechanical contractors, utilities) sees this as an opportunity. The event allowed the identification of proven and emerging refrigeration technologies and the validation of the supermarkets' interests. In addition, six discussion groups shared ideas on how to lift barriers for adoption of the energy efficient refrigeration technologies. The information collected will provide CETC-Varenes and OEE with new ways to facilitate the adoption of the technologies developed.

A laboratory test bench was developed to test novel methods of providing refrigeration for the food marketing industry. In the first series of tests, CETC is expected

to develop the knowledge to operate refrigeration systems at minimal head pressure and maintaining controllability of refrigeration system using an electronic expansion valve. Results from this work will validate or further improved the accuracy of refrigeration equipment models and will help to transfer the know-how to refrigeration experts. Some technical papers will be published soon.

During the year 2000, CTEC started a new strategic project scheduled to last four years. The main objective is to construct and perform experiments on a liquid CO₂ secondary fluid loop test bench. The secondary objectives are development of basic know-how (technical documentation, simulation models, experimental data) and demonstration of the technologies feasibility to potential partners. CTEC got a CFD program (Computational Fluid Dynamic) to model complex problems related to refrigeration technologies. A major partner from the carbon dioxide industry has joined the research team to realise this project.

Canada - Hydro-Quebec Research Institut, Laboratoire des technologies de l'énergie (LTE)

The contribution of LTE covered the following areas:

- Development of two improved methods for total heat recovery in cold climates.
- Development of a high-speed defrost technique.
- Effective use of liquid pumping and injection.
- Further research on systems having low refrigerant charges and reduced supplementary costs and energy consumption.

In Canada, supermarkets are one of the most energy-intensive types of commercial buildings, and the major source of electric energy use and demand comes from refrigeration systems (around 50 %), of which compressors and condensers account for 60-70 %. Also, the majority of conventional supermarkets take partial advantage of the large amount of heat rejected, by using this heat for space or water heating. Generally, a conventional heat reclaim coil located in the central air handler allows recovery of approximately 35 % to 45 % of total heat rejection. However, this amount of heat is not sufficient to completely eliminate the use of fossil fuel combustion (natural gas, propane) during the coldest periods of the year. Moreover, at the present time, an issue facing the industry is the phase-out of ozone depleting refrigerants and the reduction of refrigerant charge and leakage, because a typical supermarket may experience refrigerant leakage of 10 % to 30 % per year.

The main objective of the LTE project was to experimentally document the benefits of two improved heat recovery systems developed in Canada, and to compare their performances with those of existing multiplex systems. Specific aims were to measure the energy usage for both low and medium-temperature zones and for total store, as the main system operating parameters and overall energy performances. An ultimate goal was the further development of options to reduce total equivalent warming impact (TEWI) of supermarkets by reducing the total refrigeration charge and leakage risks. LTE Laboratory worked with three retailers and two Canadian manufacturers on development and field testing of two commercial prototypes. The "*System 1-phase 1*" (known as *RSD*) comprises a method to maximize the heat recovery capability for space and water

heating, and a new, high-speed defrost concept. The “*System2-phase I*” (known as *LMP*) proposes a new heat recovery and air-conditioning/dehumidifying method involving intermediate heat exchangers and multifunctional refrigerant-to-air heat pumps. These systems represented the first phase of their respective development processes. They have already been further improved, particularly in order to reduce total refrigerant charge and leak hazards. Three new supermarkets were extensively instrumented in order to compare a number of operating parameters, high-efficiency features such as heat recovery, defrosting, sub-cooling and liquid pumping, and to quantify energy performances (compressors and store energy consumption and demand, etc.). Two of the stores monitored, having approximately the same size and energy usage, (basically, electric refrigeration and natural gas cooking) were equipped with above-mentioned improved refrigeration systems, and a third one was used as a new baseline supermarket. In these stores, food is stored prior to transfer to the store in walk-in storage areas, and a variety of display cases are located at the periphery. A continuous monitoring of these systems was performed over a 12-month period (2000 – 2001).

Total Heat Recovery (“System1-phase1”). This heat recovery method consists of bi-directional valves to supply discharge superheated vapour to condensers (in winter), or to a groundwater cooling device (in summer), depending on the outdoor temperature, or to heat reclaim coils for air or domestic hot water heating, when required. A parallel installed modulating valve equipped with an outside temperature sensor adjusts the discharge pressure depending on the outside temperature, and automatically re-directs a predetermined quantity of superheated vapour to the heat reclaim coils by means of a simple, economical and efficient method. If the system controller requires heating during the winter cold months, the modulating valve will direct some or all of the refrigerant to the heat recovery coils in order to cover up to 100 % of the space heating demand. The last heat reclaim coil and remote condensers are separately connected to a main receiver where the liquids flow at approximately the same pressure, independently of one another. Prior to being fed to the evaporators, the liquid is further sub-cooled by an internal heat exchanger equipped with special thermostatic expansion valves.

Total Heat Recovery (“System2-phase1”). In conventional supermarket refrigeration systems, the condensing pressure and temperature are subject to ambient air temperature. During the cold periods of the year, even if there is a possibility of reducing condensing pressure, a high level is artificially maintained in order to provide sufficient pressure differential for proper operation of the expansion valves, and for heat reclaim. The “*System2-phase1*” heat recovery concept provides an original method to maximize the extraction of the condensing heat by using heat pumps. Refrigeration system superheated vapour is first directed to four intermediate plate heat exchangers that also serve as evaporators for heat recovery heat pumps where a minimum suction pressure, corresponding at about 10 °C refrigeration condensing temperature, is maintained. When store space heating is required, the plate heat exchangers and their respective refrigerant-to-refrigerant heat pumps are activated. Sensible (superheat) and, if necessary, latent heat are removed from the hot discharge gas of the refrigeration system, which is then fed to the remote air condensers. The heat extraction from the superheated vapour is effected without excessively increasing the discharge pressure, thus allowing a reduction of the refrigeration compressor energy consumption as compared to conventional heat reclaim methods. In air conditioning mode, the plate heat exchangers aren’t used, and heat

removed from the store is rejected outdoors through each heat pump's own condenser.

The heat recovery system is completely independent of the refrigeration system, and it is possible to extract total condensing heat without affecting its normal operating conditions. Each heat pump includes a heat exchanger for space heating, and the same coil is used for air re-heating in dehumidification mode. The heat pump's condenser and air conditioning coil are not operational in heating mode, and special inlet pressure valves maintain a minimum suction pressure. Refrigeration system liquid returns from the remote condensers to a liquid delivery unit (including a refrigerant pump) where static pressure is increased before supplying the display cases, and a small quantity can be injected into the common discharge line during the summer. Low condensing pressures during the cold periods of the year are compensated for by the pressure increase provided by the liquid delivery system.

Inside the heat pump dedicated to sub-cooling/heat reclaim, the evaporator removes heat from the condensed liquid of the main refrigeration system before it is sent to the display cases and storage coolers/freezers. When this heat pump operates in heat recovery mode, its own intermediate plate heat exchanger plays the role of an evaporator, and the discharge line goes to an air-heating coil for store space heating. It should be noted that this heat pump-heat reclaim concept is easily adaptable to any existing refrigeration system using a liquid delivery system.

Results

- With lower compressor energy consumption, the 12-month field monitoring proved that fossil fuel consumption for space heating in supermarkets has been completely eliminated in both cases.
- "*System1-phase1*" raised the head pressures/condensing temperatures during the heating demand periods as high as they were in the baseline system with conventional heat reclaim devices, and also modified refrigerant flow and controls to eliminate current limitation of heat reclaim capability and giving priority to the heat reclaim mode. A modulating valve operating on the ambient temperature optimizes this process by varying head pressures as a function of the actual heating demand and the outdoor temperature variation.
- The "*System2-phase 1*" was capable of reducing discharge pressures to an almost constant level (about 29 % lower than the other system), without compromising its own heat reclaim method. The discharge pressures were lowered to about 125 psig during the winter, but the thermodynamic level of the heat reclaim was increased by using heat pumps as a cascade stage. Savings in compressor energy consumption were however obtained, mainly by using four refrigerant-to-air heat pumps having average coefficients of performance of around 3.0.
- The total annual specific energy consumption (kWh/y/m^2) of the *refrigeration compressors* represented 32.5 % ("*System1-phase1*") and 34 % ("*System2-phase1*", including the four heat pumps), of to each store's total electrical energy usage, compared to the current average in Canada, of 39 %. These performances were obtained even if the "*System1 - phase1*" was slightly penalized by the use of less efficient screw compressors, excessive fouling and lack of proper maintenance of groundwater heat exchangers. "*System2-phase1*" was also penalized by the heat pump's supplementary energy

consumption, even when compensated for by lower head pressure operation in winter. Simultaneously, the total annual specific electrical energy consumption (vs. sales area) of improved *supermarkets* was reduced by 6 %, and the corresponding energy costs, including power demand cost, by 12.9 % and 17.9 % respectively, compared to the baseline monitored supermarket.

High Speed Defrost. “System 1-phase1” system includes a high speed defrost concept capable of performing defrost cycles in a short period of time. In fact, the major disadvantages of conventional defrosting methods are their fairly lengthy cycles, because of a low-pressure differential across the evaporators, adverse effects on foodstuffs and compressors (energy cost increases, overheating, reduced technical life). As in conventional systems, when a refrigeration zone goes into a defrost cycle; superheated vapour is fed to the outlet of the evaporator coil. The return line of the defrost circuit is provided with a second valve which is open during the defrost cycle. This valve connects the return line to a special auxiliary receiver, which has a sufficient volume to take the full refrigerant charge and protect the compressors during and after each defrost cycle. The auxiliary receiver is connected to the low suction pressure header by means of a solenoid valve. By using an auxiliary receiver, a pressure differential can be created across the evaporator coils within a range of about 200 to 700 kPa, thus achieving quick defrost. In order to keep the main receiver supplied with sufficient quantities of liquid, it is necessary to periodically flush the auxiliary receiver during the refrigeration cycle. When the refrigerant temperature is below a predetermined value, normally -1°C , the refrigerant liquid is directed to the main receiver. A pressure differential of about 200 kPa is created in order to have sufficient pressure to flush out most of the liquid accumulated in the auxiliary receiver. If the liquid is above -1°C , it is sent to the remote condensers and then back into the main receiver. The auxiliary receiver is also provided with a level detector. When the liquid level reaches a predetermined value, the flushing circuit will operate during the next refrigeration cycle. A second level detector feeds an alarm that produces both a visual and an acoustic signal.

Results

- The new high-speed defrost method proposed by “*System1-phase1*” reduced defrost cycle time by about 85 % compared with a conventional hot gas defrost method. Immediate beneficial effects were a better quality and about 50 % less perishable food losses. The actual maximum deformation of a representative case evaporator during a fast defrost cycle represents about 56 % of the elastic limit of existing materials, but the long-term effects are not known, nor are they known for existing conventional systems.
- Because of the high speed defrost, it was estimated that is possible to reduce the number of the refrigeration lines and consequently, the total refrigerant quantity by up to 15 %.

Liquid Pumping and Injection. A simple, reliable liquid delivery technology developed in Canada can improve refrigeration efficiency, reduce compression ratios and work, and allow refrigeration systems to better operate with floating condensing pressures, depending on outdoor temperatures. This technology generally produces energy savings of up to 35 %, but creates difficulties in the area of heat recovery, especially when total condensing heat reclaim is required, because the air to be heated is warmer than the refrigerant to be cooled. Accordingly, when heat reclaim is required, the

condensing pressure has to be artificially raised in order to achieve proper heat transfer, thus losing the benefits of the liquid delivery system. However, by combining liquid pumping with the new "System2 – phase1" heat recovery method, it was expected that head pressures would not be artificially raised when heating is required. Refrigerant pumping pressurizes the liquid refrigerant enough to compensate for any pressure losses between the receiver and the expansion valve, and thus eliminates the formation of vapour. The liquid pump is a sealed unit, with no moving seals to wear out or leak. The "System2 – phase 1" new heat recovery concept allows the use of the same equipment (heat pumps) for air conditioning and sub-cooling purposes, and also improves the efficiency of the liquid pumping technology. It is well known that the compressor's energy consumption and efficiency are a function of the ratio between the condensing and evaporating pressures. By lowering the condensing temperature to 16 °C or even 10 °C, the compressor energy consumption and power diminish, and its refrigeration capacity increases. Moreover, because the pressure of the pump is usually higher than the compressor discharge, the injection of a small percentage of the liquid (6 – 10 %) back into the discharge line was possible. Thus, for ambient temperatures above 24 °C, the temperature of the discharge vapour was reduced, and the efficiency of the condenser increased. The liquid injection means lower velocity through the condenser, lower pressure drop, reduction of the discharge temperature, an increase in the area of the condenser used for condensing, and increased system capacity.

Result

- Liquid pumping technology used by "System2 - phase1" helped this new heat recovery technique by increasing the liquid pressure by about 180 kPa during the cold periods when the head pressure decreased to 860 kPa.

Geothermal Cooling. During the hottest periods of the year, condensing heat from the "System1–phase1" refrigeration system was rejected to the ground instead to the ambient air in order to reduce energy consumption and thus optimize the overall efficiency of the system. This concept allowed the reduction of the compressor's head pressures and condensing temperatures, because the cooling fluid will be groundwater at an average temperature of about 8°C (46.4°F) instead the ambient air at more than 30°C (86°F). This objective was achieved by using supply and discharge groundwater wells. Two refrigerant-to-water heat exchangers for both low and medium temperature racks were employed. The main disadvantage of this energy efficiency method is the risk of clogging of the groundwater heat exchangers, which involves additional costs for periodical maintenance. However, the energy savings may generally justify the initial investment and supplementary maintenance.

Further Developments. The major weakness of the proposed systems lies in the large of refrigerant required, and the associated environmental disadvantages (1,400 to 2,300 kg for total sales area of 3,000 to 5,600 m²). Even if the "System1 – phase1" has demonstrated that the developed high speed defrost method enables a reduction in refrigerant charge of up to 15 %, it isn't considered sufficient. Therefore, the main objective of future systems improvement is to reduce total refrigerant quantity and leakage risks, and also to replace the HCFC-22 by alternative fluids, in order to develop new environmentally low-TEWI systems.

(i) The "System1 – phase2" improved system, available since 2001, was developed by retaining both prior innovations (integral heat recovery and high speed defrost). It aims to

replace the actual HCFC-22 fluid with a good replacement having no, or lower environmental impact (e.g., R-404a). The central refrigeration system was divided into several smaller, ultra-compact units that can be installed on the roof (distributed compressor approach). The previous conventional central refrigeration room was thus completely eliminated, and the space created could be used for commercial activities. This arrangement reduces total refrigeration piping length and number of fittings, thermal insulation and electric piping by 60%, and total refrigerant charge by 30 – 40%, because of the proximity of display cases and of heat reclaim coils, reduced diameters and length. Thus, the additional costs are lowered by 40 % compared to the previous system. These cabinets are insulated and equipped with their own heating and cooling devices (21°C in winter and 32°C in summer). Additional ventilation or make-up air and evacuation devices aren't needed. “*System1 – phase3*” improved system aims also to retain the main previously analysed innovations, and also to reduce the refrigerant charge by 60 % or more compared with the first method. This concept retains the same small cabinets, but each high temperature side (condensers and heat reclaim) uses closed loops with circulation pumps and anti-freeze secondary fluid, storage tanks and controls. These condensing circuits can transfer heat directly to each heated space, or can use water-to-air heat pumps. Reduction of additional costs is estimated at 50 % compared to the first improved system.

(ii) “*System2 – phase2*” aims to maintain heat recovery by heat pumps, but to improve the liquid delivery system (horizontal receiver installed outdoors with improved level control), accelerate the defrost cycles by increasing the refrigerant flow rate, and reduce the additional cost by about 10 % compared to the previous concept. On the other hand, “*System2 -phase3*” aims to develop a simplified heat recovery method without heat pumps, a zoned defrost concept, and to reduce the refrigerant charge by up to 30 % and the additional cost by 80 % compared to the first improved system.

Summary information on the phase 1 test systems is included in Appendix A. Full details on the tested and improved systems may be found in the Canada country report.

Denmark

There is a great deal of concern in Denmark about the use of HFCs due to concerns about their impact on the environment in the long term, especially the contribution to global warming. In the opening speech to the IIR conference on “Applications for Natural Refrigerants”, Aarhus, Denmark (1996) the Danish Minister for Environment and Energy, Svend Auken, in his conclusion said: “It is therefore my sincere hope that in ten years’ time, not a single fridge, freezer or cooling plant is being built in Denmark that requires HFCs or other greenhouse gases.” Recently an announcement (in Danish; Bekendtgørelse, BEK nr. 552 of July 2., 2002) has been issued which forbid the use of certain industrial warming potential gasses, which includes the HFC’s. From January 1, 2006 the use of HFC’s is no longer allowed in new products. Exemptions are the use in refrigeration plants, heat pumps, air conditioning plants and dehumidifiers with refrigerant charge between 0.15 kg and 10 kg and compact heat recovery plant factory assembled with charge less than 50 kg. According to this rule conventional multiplex refrigeration systems cannot be used in supermarkets after January 2006.

Besides the phase out in 2006 for new plants HFCs are charged a CO₂ tax. In Denmark emission of carbon dioxide (CO₂) has been taxed since May 15, 1992. Starting January 1, 2001 following the Kyoto protocol Denmark extended the CO₂ tax to include industrial greenhouse gasses (HFCs, PFCs and SF₆) based on the global warming potential (GWP) of each gas. The tax is US\$ 0.0127 (DKK 0.10) pr. kg CO₂ with CO₂ by definition having the GWP of 1 with a maximum tax of US\$ 50.95 (DKK 400) pr. kg (Danish law #49 of December 21, 2000).

In view of what is stated above it is obvious why the Danes are searching for natural refrigerant substitutes for HFCs. Several supermarket case studies have been done in Denmark with a primary focus on increasing energy efficiency and applying natural refrigerants (like hydrocarbons, ammonia, and CO₂). In one small Danish supermarket the old refrigeration plant was replaced with a cascade plant. Propane was used as the high temperature refrigerant (-14/+30°C) while CO₂ was used at the low temperature level (-32/-11°C). Direct expansion of CO₂ is used in the freezer cases while a brine circuit with propylene glycol is used in the coolers. Total energy consumption decreased by 10% with the new plant, however it must be noted that the old plant was worn out. Based on the results from this initial demonstration a second propane/ CO₂ cascade plant was built in a medium-size supermarket and just started operation in late 2001. The test supermarket is part of a chain of about 250 similar shops so it has been possible to compare the propane/carbon dioxide plant with newer traditional plants with the same cooling capacity. Energy use of the demonstration store has been compared to that of eight similar stores in the same chain and found to be about the same as that of the most efficient of the newest conventional stores. It is estimated that the additional cost for a propane/ CO₂ cascade plant for a medium sized Danish supermarket (30 kW freezing load and 60 kW cooling load) will amount to approximately 10% or less of the total installation. Details of this second demonstration are included in Appendix A.

A third demonstration plant has recently been started in a new supermarket in which carbon dioxide is used in both the low temperature and medium temperature cases. This approach eliminates the secondary propylene glycol circuit with its thermodynamic efficiency penalty. The plant has 190 kW cooling capacity and 60 kW freezing capacity, and the condenser heat is utilized to supply the shop with all of its space heating and sanitary hot water needs. The refrigeration plant is a cascade plant with R404A in the high temperature stage and CO₂ in the low temperature stage. R404A is used in this plant because the equipment is installed in the basement of the store where it is difficult to get permission to install flammable or toxic refrigerants. Both the freezer cases and fresh food cases are cooled by direct evaporation of CO₂. Liquid CO₂ is pumped directly to the fresh food cases while CO₂ is direct expanded into the freezer cases. The amount of R404A in this demonstration is only about 10% of that needed by conventional direct expansion systems for stores of this size. Taking into account the Danish tax on R404A this reduction reduces the investment in refrigerant by about US\$ 37,000. (DKK 290,000). The total investment in the refrigeration plant is approximately 10% higher than a conventional HFC-plant taking into account the reduced refrigerant cost. This demonstration has been underway since February 2002. A comparison with similar shops in the area with conventional refrigeration systems shows significantly lower energy consumption. In November 2002 a second plant built in according with this concept has been set in operation.

In the future a project with title, "Energy efficient design and control of the secondary side of an indirect refrigeration system with natural refrigerant" will be performed.

Sweden

Swedish activities for Annex 26 have been aimed at improving supermarket energy efficiency in several different ways. These have included development of a detailed computer model and analyses of full stores to examine different secondary loop system designs and heat recovery approaches including impact of climate effects particularly relative humidity. Several full-scale demonstration projects have been undertaken examining different secondary loop systems and display cases with advanced features such as automatic night covers.

Increased sales in supermarkets, stricter environmental legislation for CFC and HCFC refrigerants and a major consideration of the use of energy and the effect on the environment have influenced the supermarket sector during the last year in Sweden. Sales in supermarkets have increased 4.6 % during year 2001 in comparison with the year 2000 [30]. The consumption of deep-frozen products in supermarkets during 2001 was 231788 metric tons while during 2000 it was 216427 metric tons, which is an increase of 7%. The increase in sales in supermarkets places a demand on more cabinets, cold rooms and refrigeration systems that increase the energy consumption from food stores.

Supermarkets are using large amounts of energy; approximately 3% of the electric energy consumed in Sweden is used in supermarkets (1,8 TWh/year). A breakdown of the energy usage shows that, typically, 47% is used for medium and low temp refrigeration, 27% for illumination, 13% for fans and climate control, 3% for kitchen, 5% for outdoor usage and 5% for other uses.

Refrigeration systems, display cases, indoor climate control and illumination are the areas with the greatest potential for improvement. Since the energy systems of a supermarket are relatively complex, improvements in one subsystem affects other systems, thus making an analysis of potential improvements non-additive. Typical efficiency improvements may involve refrigeration systems, heat recovery, more efficient illumination, more efficient display cases with night lids, more efficient control, floating condensation etc.

Several new system solutions such as completely, partially and cascade secondary loop (or indirect) systems have been developed and introduced in recent years in Sweden to lower the refrigerant charge and, at the same time, minimize potential refrigerant leakage.

Growing interest in secondary loop systems has led to the development of some new secondary refrigerants based on potassium formate and potassium acetate alone or mixed. Another very promising development is CO₂ as a secondary refrigerant. This technology is implemented in more than 30 supermarkets throughout Sweden. CO₂ systems require much lower tube diameters and the pressure drop is negligible when compared to conventional systems. A third promising development in this field is ice slurries. These systems offer additional advantages with enhanced thermal capacity and a "built-in" thermal storage in the system without increased pressure drop if ice-slurry with the right consistence is produced.

Secondary systems and the minimization of refrigerant charge may lead to an unwanted trade off in overall energy efficiency. Theoretical calculations confirm this due to the obvious extra temperature differences introduced in the system. An evaluation using a concept like TEWI (Total Equivalent Warming Impact) may be used to estimate the overall environmental impact.

In 1998 the Department of Energy Technology of the Royal Institute of Technology of Sweden started a project in co-operation with different companies and the Swedish National Energy Administration. Modelling and field measurements of supermarket energy systems have been undertaken in the research project “The energy efficient supermarket” for more than four years. The results have been part of the Swedish contribution to the IEA Annex 26.

The overall aim of the project “The energy efficient supermarket” is to develop a sound simulation model where different system solutions can be compared in detail with focus on energy usage, environmental impact (TEWI) and LCC (Life Cycle Cost).

The program, “CyberMart” is built in modules dealing with subsystems such as in- and outdoor climate, display cases, cooling and freezing rooms, refrigeration machinery, the building envelope etc. CyberMart is a day-to-day simulation program that allows the user to see the variation of different variables such as compressor power, refrigeration capacity and temperatures in the supermarket during one year.

The model is currently under validation with four different supermarkets in Sweden in cooperation with COOP and ICA, two major Swedish supermarket chains. The model development activities are now treating issues such as illumination, indoor climate and heat recovery, comfort cooling etc. Interesting issues to study are the potentials in heat recovery in the winter, moisture control/dehumidification and floating condensation. Additional Field measurements intended to validate data are currently being set up. A window for calculation of energy consumption is shown in Figure 11. The diagram shows the results from the simulation of the compressor power of the intermediate and low temperature systems during one year.

Figure 11 - Results from CyberMart

The influence of the outdoor temperature on the indoor relative humidity of air is an important factor to take in consideration when dimensioning refrigeration and heat recovery systems in supermarkets. Lower outdoor temperature and moisture affect the compressor power and the dry cooler fluid approach temperature.

Figure 12 - Indoor temperature, outdoor temperature and indoor relative humidity in Hedemora and Sala

Measurement of indoor temperatures, outdoor temperatures and indoor relative humidity from two supermarkets in the cities of Hedemora and Sala are shown in Figure 12. The distance between the cities is about 60 km. The results confirm the dependence of relative humidity on outdoor temperature. The indoor relative humidity in both supermarkets follows the variation of outdoor temperature during the period of study.

Figure 13 - Temperatures, relative humidity and compressor power in Sala

The variations of temperatures, moisture and compressor power during week 32 in August 1999 in the supermarket in the city of Sala are shown in Figure 13. In the figure it is possible to see the influence of night covering of the display cases and defrosting on the compressor power. The cabinets are defrosted with electrical defrost. The compressor power is reduced between 10 and 20 % by the night covering of the cabinets. The covering occurs automatically when the supermarket closes at 21.00 and ends at 8.00 in the morning. The positive effect on energy saving of night covering is dependent on the quality of the curtains. Night covering is an efficient method to reduce infiltration and radiation loss in cabinets.

The influence of high indoor temperatures on compressor power has been studied in the supermarket in the city of Hedemora. The high investment cost of the air conditioning system and a short period of higher outdoor temperatures during the summer have affected the decision of install AC in many supermarkets in Sweden.

Figure 14 - Temperatures in a deep freeze cabinet and indoor and outdoor temperatures during four days in July in Hedemora

Figure 14 presents indoor temperatures, outdoor temperatures and air return temperatures in four sections of a deep-freeze cabinet during four days in July 2001. The outdoor temperatures are above 30°C during a long part of the day and this affects the indoor temperatures. The values of indoor temperatures during the day are above 25°C, which is the dimensioning indoor temperature of the display cases. The maximum indoor temperature is 28°C, which occurs on the 5th of July at around 17:00 o'clock. The air return temperatures in three sections are above -20°C and one of them has air return temperatures higher than -15°C during the day. If the temperature of the products is assumed 1°C higher than the air return temperature, which is a reasonable supposition, then the temperature of the product should be about -14°C at an air return temperature of -15°C. According to the National Food Administration, which regulates and supervises the food area in Sweden, the maximum temperature of freeze products is -18°C. The date for the minimum durability, or use-by date, of frozen food is calculated at a temperature of -18°C. Higher product temperature implicates a risk of the multiplication of bacteria in the frozen food that might cause illness to the consumers. The results from Figure 12 confirm the necessity of air conditioning during the warmer days in the summer in Sweden.

The economy and overall energy efficiency of supermarkets, in cold climates, benefit from heat recovery. In theory, the necessary heat can always be supplied from the condensers. Practical experiences show that in real systems only 40 % – 70 % of the necessary heat is recovered. There are many reasons for this but the most important are on/off regulation, low cooling load during cold days, poorly designed heat recovery systems and non-communication control systems for refrigeration and HVAC.

United Kingdom

Storing and displaying refrigerated goods accounts for a considerable amount of energy use in the UK. Figure 15 shows the breakdown of the end use of refrigeration energy. Of the total of 24,000 GWh, refrigerated retail display cabinets overall consume some 7,740 GWh per year in the UK. This provides a great incentive to improve the energy efficiency of refrigerated supermarket display units. In addition to this there is also the requirement to reduce the emission of environmentally damaging refrigerants that contribute to the total equivalent warming impact.

Figure 15 - Refrigeration energy usage in The United Kingdom by end use

Reported here are a summary of the Phase 2 studies and the overall analysis of the current position regarding the available technologies. Full details of the Phase I technology review and Phase 2 detailed studies are included in the UK country report. The second phase of the UK contribution covered four research areas:

- secondary refrigerant systems
- alternative defrost approaches
- interactions between the store environment and the cabinet case
- combined heat and power and combined heating, cooling and power applications in supermarkets.

This summary records the main points that were concluded from each of the four studies carried out. Each area of research was carried out by an organisation specialising in refrigeration technology. The areas where further research may be useful have also been identified.

Secondary Systems. Secondary refrigerant systems offer the potential of reduced total equivalent warming impact (TEWI) as a consequence of reduced refrigerant leakage of high ozone depleting potential (ODP) refrigerants. However, it is recognised that there

may be additional energy requirements to operate this type of system because of greater temperature gradients and increased pumping power.

Field monitoring data from a typical supermarket was used to validate a refrigeration simulation model, and a detailed investigation of the thermal and fluid properties of secondary refrigerant fluids was made. This enabled simulations to be carried out to assess the feasibility of a wide range of secondary systems and refrigerants in a typical supermarket. A key finding of the simulation was that the energy use of the secondary systems simulated would typically be greater than for other systems and as a consequence they would deliver higher operational CO₂ emissions. In terms of overall TEWI, the secondary system using R290 (propane) would reduce the TEWI by 8% over a 15-year life compared to an R22 direct system with 15% refrigerant leakage. The benefit of a reduced TEWI of a secondary system is lessened as the leakage rate of the equivalent direct system decreases.

The project has shown that there is sufficient knowledge of secondary fluid properties to be able to design an effective system. However, careful optimisation will be needed for a secondary system to become more attractive both financially and in terms of TEWI, so further research is recommended into the optimisation of secondary systems.

Further research needs. Secondary systems using pumpable ice have been tried in the UK but further work is needed to establish if it is a viable option. Research is also needed to address the issues of store layout and pipework arrangements with the specific aim of reducing the capital cost of the secondary system.

The use of CO₂ as the secondary refrigerant needs to be researched in the UK context. The current situation is not clear with respect to the health and safety issues and the performance of the systems in operation. Cascade systems have been used in the USA and may have some energy benefits and the possibility of using these in the UK should be investigated.

If changes in legislation force the adoption of lower Global Warming Potential (GWP) refrigerants then retailers may wish to investigate secondary systems further. The options for improvement include: system design (store layout to reduce pipework capital costs); pumpable ice; CO₂; and cascade systems. Reference should be made to experience in North America and Scandinavia where some of these approaches have been adopted.

Defrost. The energy used for defrosting evaporator coils in supermarkets can amount to 30% of the operating energy. Alternative means of reducing the defrost energy have been researched by laboratory studies of different defrosting techniques and control strategies. Studies were carried out in both high and low temperature applications and the following defrost techniques were considered:

- off-cycle
- hot/cool gas
- electric.

However, not all techniques can be used in all circumstances, for example, off-cycle is not appropriate in low temperature applications, leaving a choice of gas or electric defrost.

The findings showed that, for high temperature applications, the cheapest and least energy consuming means of defrost is 'off-cycle'. This method of defrost is widely

used in the industry. For low temperature applications, the use of gas defrosting is more energy efficient than electric defrost but the considerable extra capital costs lead to long payback periods, up to 28 years. Consequently, electric defrost is most commonly used for low temperature applications in the UK.

The length and frequency of the defrost cycle has a significant effect on the energy use of a refrigerated cabinet. The normal procedure of a fixed number of cycles per day is wasteful of energy because the time period between defrosts may be either too long - thereby reducing the frosted evaporator efficiency before defrost - or too short which provides unnecessary defrost events. In addition, the length of defrost can be excessive and this wastes further energy, and risks adverse effects on the product quality and life. Optimised defrost cycles could reduce energy use by between 25 and 50%, where electric defrost is employed. Work is under way to develop controls to achieve this.

The optimum defrosting cycle will depend on the cabinet type and store conditions and a means of control that relates to these parameters would lead to significant energy savings.

Further research needs. A number of issues for further research were revealed by these studies. Liquid defrosting for low temperature applications should be further researched as it is potentially a more effective and energy efficient technique.

Methods of determining the need for defrosting should be investigated and these should take into account the avoidance of simultaneous defrosting of a number of units leading to high electrical loads. Evaporator design has an influence on the formation of ice and should also be researched in order to avoid or reduce the incidence of frosting.

CHP/CCHP. Combined heat and power and combined cooling, heat and power are potentially efficient methods of providing the energy for supermarkets. A simulation model has been developed that allows the energy and heat flows in a supermarket to be modelled and will predict energy and cost savings arising from a range of measures taken to improve efficiency of supply or use of energy. The model was tested against a store using CHP and then used to evaluate a range of options.

The studies showed that currently available equipment can be used satisfactorily but needs to be carefully optimised for the specific store in which it is being installed. The cost effectiveness of CHP/CCHP is sensitive to the fuel costs and in particular the ratio of the gas and electricity costs. Additionally the number of hours for which the plant operates in a year is a key determinant of the cost effectiveness.

Further research needs. Determining the heat and power load profiles of a wider range of stores would assist in developing a clearer view of the potential for CHP in supermarkets.

The design of the refrigeration system with the use of CHP and CCHP needs to be investigated as novel approaches may provide a better match of heat and power usage. For example, gas engine prime movers for vapour compression machines can be attractive and the potential for their use should be examined.

The simulation model that has been developed in the context of this research could be made available for retailers and other interested parties to carry out feasibility studies on future stores.

Case and Store Environment Interaction. This project was based on the premise that the internal environment of the store, in which the refrigerated display cabinet is located, can have a significant bearing on the energy use and performance. The temperature and humidity of the air and its movement around the cabinet are all likely to influence the energy use. A store environment was measured and the conditions were recreated in the laboratory. Tests were then carried out with these different internal environmental parameters to investigate their impact on energy use. Two different cases were tested in the laboratory – an integral (self-contained open front chiller unit and an open well (coffin-type) freezer with a row of half-height glass door shelves above the open well (see Figure 16).

Figure 16 - Example of freezer case type tested by UK team in environmental chamber to determine impact of store temperature, relative humidity and ventilation mode (conventional or displacement) on performance

The results showed that for the freezer tested varying the store's temperature, relative humidity and ventilation mode and rate had little impact on the energy consumption of the unit. It may be surmised that although the rate of frost formation on the evaporator was dependent on the ambient relative humidity, whilst the defrost initiation and duration were preset, no significant impact on the energy use for defrost was observed.

For the chilled cabinet the energy consumption was more dependent on the store conditions. A change of store temperature from 19 to 22°C increased the energy use by up to 20%. At the higher temperature of 22°C the relative humidity of the store environment increased the energy consumption by 15%, when raised from 35%rh to 50% rh. Increased ventilation around the chiller could also lead to some increase in energy use.

Overall, relative humidity is not as much of a significant factor in energy use as was initially expected from the literature review. This is probably because the rh values in the UK are typically much lower than in the USA, where the other research had been carried out.

An additional finding was that reduction of the voltage supply to the cabinet had a large effect on the electricity use. Reducing the voltage from 240 to 220 volts resulted in a saving in energy of approximately 10% without any loss in performance. This effect has also been observed in stores, and current practice is to reduce voltage supply to the whole store in order to make savings.

Further research needs. The use of high velocity air supply in aisles in order to mix the stagnant cool air needs to be investigated particularly to ascertain the impact on customer comfort. This needs to be studied in the context of customers' expectations of comfort levels in stores and particularly adjacent to refrigerated display areas.

Research is required into controlling anti-sweat heaters by methods other than time control. The control of the anti-sweat heaters is an area in which there is a potentially large energy saving to be made.

The design and manufacture of cabinets is a major issue that warrants further examination. The tendency is to provide standard solutions that are not being developed in line with the aims of improving energy efficiency. To overcome this needs the active participation of manufacturers in the realistic testing and measurement of in-store operation in future trials.

UK Overall Conclusions. These projects have confirmed that many of the practices the retailers currently have in place are the most cost effective e.g. the use of DX systems at low leakage rates, and electric and off-cycle defrosting. However, some of the more expensive and/or innovative technologies could further reduce the TEWI of supermarket refrigeration.

A number of issues remain to be addressed in order to achieve these potential savings in all applications. There also appears to be great scope for considering the whole system – from power supply to refrigerated goods display in a store environment – as a single system to be optimised; rather than a collection of individual components each acting in isolation. Of particular note are:

- Defrost methods and control strategies – which has great retrofit potential
- Secondary system optimisation
- Store environmental conditions for comfort and cabinet energy use
- Variable speed compressors.

United States

The US contribution to the Annex included an analysis of several low-charge refrigeration system options, a field test of a distributed compressor refrigeration system,

and development of a spreadsheet-based refrigeration system model. Summaries of the analyses and the field test results are given below. The spreadsheet model is described briefly below and more fully in the US country report. Full details of the analyses and field test projects are given in the US country report. Appendix A provides some summary information on the field tests as well.

There are over 100,000 retail food markets in the United States. Of these almost 33,000 are supermarkets – stores with over \$2 million in sales annually and generally having much more than 1000 m² of sales floor area. Total annual electricity consumption for refrigeration alone in all US supermarkets combined is about 35-40 billion kWh.

System analysis summary. A 3720 m² supermarket based on the layout in Figure 1 was simulated and energy consumption estimates were made for a baseline air-cooled multiplex refrigeration system which uses R22 for the medium temperature compressor rack and R404A for the low temperature compressor rack and four advanced, low charge systems (Walker and Baxter, 2003). The advanced systems investigated included distributed compressor (R404A), secondary loop (R507, primary refrigerant), low-charge multiplex (same refrigerants as baseline), and advanced self-contained (R404A). The secondary loop system modeled included four separate temperature loops operating at temperatures of -30, -18, -7, and -1 °C with a potassium formate brine in the lowest temperature loop and propylene glycol brine in the higher temperature loops. The low-charge multiplex system modeled was based on the system described in Figure 7.

Total refrigeration load was 328 kW (82 kW for frozen foods and 246 kW for fresh foods). The baseline system charge was 1360 kg or 4.15 kg/kW load. Both the distributed compressor system (with secondary loop for heat rejection and evaporative cooling tower) and the secondary loop system (with evaporative condensing) achieved similar results with annual energy savings of 11.3% and 10.4%, respectively, compared to the baseline for a Washington, DC location. The low-charge multiplex refrigeration system (with an evaporative condenser) showed annual energy savings of 11.6% compared to the baseline system. No energy savings were estimated for the advanced, self-contained system. Refrigerant charge reductions were 67% for the distributed compressor system, 85% for the secondary loop system, and 33% for the low-charge multiplex system. Energy savings results are summarized in Table 1.

Table 1 - Predicted Energy Consumption for Low-Charge Refrigeration Systems				
System	Heat Rejection	Annual Energy (kWh)	Energy Savings (kWh)	% Savings vs baseline
Multiplex (baseline)	Air-Cooled Condenser	976,800	-	-
Multiplex	Evap. Condenser	896,400	80,400	8.2
Low-Charge Multiplex	Evap. Condenser	863,600	113,100	11.6
Distributed	Water-Cooled Condenser, Evap Rejection	866,100	110,700	11.3
Secondary Loop	Evap. Condenser	875,200	101,600	10.4
Advanced Self-Contained	Water-Cooled Condenser, Evap Rejection	1,048,300	-	-
Secondary Loop	Water-Cooled Condenser, Evap Rejection	959,700	17,100	1.8
Results for supermarket at Washington, DC location				

Use of evaporative heat rejection (evaporative condenser or cooling tower) was the principal driver for energy savings for all of the advanced systems compared to the baseline case. The energy consumption of the multiplex baseline system would be about 8.2% lower if equipped with an evaporative condenser instead of the air-cooled condenser.

An environmental assessment of these refrigeration systems was also made through a TEWI analysis for a 15-year life. The lowest TEWIs were achieved by the distributed compressor system and the secondary loop systems with estimated CO₂ emission reductions compared to the baseline multiplex system (multiplex with air-cooled condensing) of 13- 14 million kg, or about 57 - 60%. The low-charge multiplex system had estimated TEWI reductions of about 43% compared to the baseline system for a 15% annual refrigerant loss rate. Replacing the air-cooled condenser with an evaporative condenser on the baseline system resulted in an estimated TEWI reduction of about 3% due to the energy savings from operation at lower condensing temperatures. TEWI results are summarized in Table 2.

Table 2 - Total Equivalent Warming Impact (TEWI) for Supermarket Refrigeration								
System	Condensing	Charge, kg/kW	Primary Refrigerant	Leak (%)	Annual kWh	TEWI (million kg of CO ₂)		
						Direct	Indirect ^a	Total
Multiplex	Air-Cooled (baseline)	4.15	R404A /R-22 ^b	30 (15)	976,800	13.62 (6.81)	9.52 (9.52)	23.14 (16.33)
	Evaporative	4.15		30	896,400	13.62	8.74	22.36
Low-Charge Multiplex	Evaporative	2.77	R404A /R-22 ^b	30	863,600	9.08	8.42	17.50
				15	863,600	4.54	8.42	12.96
Distributed Compressors	Water-Cooled, Evap. Tower	1.24	R404A	5	866,100	1.00	8.44	9.44
Secondary Loop	Evaporative	0.69	R507 ^c	10	875,200	1.13	8.54	9.67
				5	875,200	0.56	8.54	9.10
	Water-Cooled, Evap. Tower	0.27	R507 ^c	5	959,700	0.23	9.36	9.59
				2	959,700	0.09	9.36	9.45
Results for Washington, DC location – 15 year service life								

^aConversion factor = 0.65 kg CO₂/kWh

^b1/3 R404A (low temp), GWP = 3260; 2/3 R22 (medium temp), GWP = 1700

^cR507, GWP = 3300

One observation from this study is that further efforts to reduce total global warming impacts for the distributed and secondary loop systems would benefit more from reduction in energy usage (through efficiency increases or load reductions) than from further reduction in direct impact (from refrigerant losses). This based on the fact that the direct (refrigerant loss) portion of the estimated TEWI for these systems only comprises about 10% of the total.

Payback estimates. A simple payback analysis was conducted based on the results from the analysis project. Estimated installed cost premiums for the distributed compressor, secondary loop, and low-charge multiplex refrigeration systems were \$60,000 (about 15%), \$147,000 (about 35%), and \$0, respectively compared to the baseline air-cooled multiplex DX system. These estimates were based on actual construction budgets supplied by the engineering departments of two supermarket chains. It should be noted that the actual installed cost of any refrigeration system will vary greatly, depending upon many factors, such as: purchasing arrangements between the supermarket and refrigeration equipment vendors; whether or not display cases are purchased in conjunction with the refrigeration system; special system features or configuration requested by the supermarket; and unique installation requirements of each site.

The cost premium for the water-source heat pumps used for heat recovery in refrigeration systems that use a secondary fluid heat rejection loop was estimated to be \$25,000 (about 30%) over a conventional system consisting of roof top air-conditioners/gas heaters. The cost premium includes water piping for the heat pumps and

over-sizing of the refrigeration heat rejection system to allow heat pump heat rejection during space cooling.

Simple paybacks for refrigeration operation only were estimated for each of the low-charge systems at four different locations in the US. Operating cost savings for the refrigeration systems include the savings obtained for reduced energy use and refrigerant leakage. Water costs are included for all systems employing evaporative heat rejection. The payback period for the low-charge multiplex system is immediate, since no installed cost premium exists. Paybacks for the distributed compressor system ranged from 3.4 to 7.0 years, while the payback for the secondary loop system ranged from 8.3 to 16.8 years. In addition simple payback was estimated for a distributed refrigeration system in combination with water-source heat pumps for store HVAC compared to a baseline multiplex refrigeration system with air-cooled condensers and rooftop air-condensers with gas heat for HVAC. These pay back periods ranged from 4.2 years to 7.8 years depending upon local outdoor climate conditions. The combined payback for refrigeration and HVAC savings was less than that for refrigeration savings alone for cold climate locations because of increased space heating savings. Combined paybacks were lower for refrigeration system alone in the warmer climate locations because space heating is not as significant at these locations.

Field test summary. A field test was conducted to compare the performance of a conventional multiplex system and a distributed compressor refrigeration system. Two supermarkets in the vicinity of Worcester, Massachusetts were the sites utilized for the field test. One store was equipped with a multiplex refrigeration system that had three compressor racks and air-cooled condensers. At the second store, a low-refrigerant-charge distributed refrigeration system was installed that consisted of 10 compressor cabinets. Heat rejection for the compressor cabinets was accomplished through water-cooled condensers piped to a fluid loop that used dry fluid coolers. The second store also had water-source heat pumps for space heating and cooling that were piped into the fluid loops. Both sites were instrumented to determine energy consumption, refrigeration and heating, ventilating and air conditioning (HVAC) loads, and numerous system state points to characterize operation.

Energy consumption of the two refrigeration systems was compared for winter and summer time periods from May 2001 through February 2002. The data show that overall energy consumption for the tested multiplex system was about 8% lower than that of the distributed compressor system tested in winter and 14% lower in summer – in contrast to the analytical projections. For summer operation the multiplex system efficiencies (COPs) were 34.7 and 18.5% higher than those of the distributed system for low and medium temperature refrigeration, respectively. For winter operation the multiplex system COPs were higher than those of the distributed system by 12.1 and 22.2% for low and medium temperature refrigeration, respectively. These results are disappointing because the distributed compressor system did not perform as well as the analytical results suggested it could. This does not mean the advanced system is fatally flawed, but there are several reasons for its poor performance relative to the baseline system tested. First, the tested distributed system used dry cooling towers for heat rejection rather than wet towers as assumed in the analysis. Second, the technique used to provide subcooling for the scroll compressors in the low temperature cabinets of the distributed system simply did not work. Finally, the baseline multiplex system tested was more efficient

than the one modeled in the analytical case study. This had the effect of degrading the relative performance of the advanced vs. baseline system in the field test as compared to the analysis.

A one-year TEWI analysis of each test system was conducted. The charge sizes were estimated at 1360 kg of refrigerant for the multiplex system and 454 kg for the distributed system. Actual refrigerant leakage rates for the systems were not known so rates of 20% and 5 % were used in the analysis for the multiplex and distributed systems, respectively. The analysis showed that the distributed system had about a 40% lower TEWI than the multiplex system over the combined summer and winter test periods despite its higher energy consumption.

Field test results for the water-source heat pumps show that the amount of heat recovered from the refrigeration system was about 25.9% of the total heat rejection. This amount is considerably less than the capability of the heat pumps, which can recover as much as 59.8% of the rejected heat from the refrigeration system. The ambient conditions during this time period were very mild so that the amount of space heat needed for the store was much less than normally seen. Despite limited operation, the water-source heat pumps were able to displace approximately 37,346 m³ of natural gas usage at the test store for the winter period evaluated. The value of this displacement is dependent upon the utility rates for electricity and gas. For this particular site, the estimated energy cost savings seen over this winter period were \$3,171.

Supermarket energy use screening level model

The model discussed herein was developed by the US as part of its role as the Annex operating agent.

The model consists of a set of Excel[®] spreadsheets and was developed to provide tools to assist supermarket planners and engineers to compare the relative energy and refrigerant requirements for alternative designs of their refrigeration systems. The spreadsheets have been completed for multiplexed direct expansion and secondary loop refrigeration systems; an additional spreadsheet may be developed in the future for distributed refrigeration systems.

A users' manual for the model is included Volume 2 as part of the US country report. Users must specify or select information about the display cases and walk-in coolers/freezers, secondary loop piping and fluids, and type of condenser. All calculations of fluid viscosity, friction factors, pressure drops, compressor power, and secondary fluid loop pumping power are built into the model. Model validation exercises have been performed using data from the baseline multiplex DX system tested in Massachusetts. Results of the validation are included in the users manual in the US country report.

Overall Summary

The five participating countries in Annex 26 have carried out a significant amount of research on supermarket refrigeration and heat recovery systems – an estimated \$5

million US total effort. A few major conclusions and observations are noted (by country along with some summary comments) in this section from the analyses and testing programs conducted. Before proceeding, however, it must be noted that these conclusions are subject to the assumptions used in the analyses and the particular locations and installations of the field test systems. These specific results should not be considered to be generalizable to all store sizes and locations. However, they do provide a good relative indication of the energy savings and TEWI reduction potential of the low-charge refrigeration systems.

Canada

Hydro Quebec's laboratory (LTE) is field-testing two advanced systems and a baseline multiplex DX system. One advanced approach uses a multiplex DX system with heat reclaim for space and water heating and ground water to supplement heat rejection. The other has heat pumps integrated to provide space heating for the store and subcooling for the refrigeration system. In winter, the discharge gas from the refrigeration compressors goes first through three plate heat exchangers that serve to desuperheat and precondense the gas. The three heat exchangers also serve as evaporators for rooftop heat pumps that supply space heating to the store. Using heat pumps for heat recovery places no minimum limit on refrigeration system condensing pressure, as is the case for traditional heat recovery approaches. A fourth rooftop heat pump is integrated with the liquid line exiting the air-cooled condenser via a fourth plate heat exchanger. This heat pump subcools the refrigerant leaving the condenser and uses the recovered heat for store space heating. Initial baseline tests in 1999-2000 showed that both advanced approaches achieved about 6% lower specific energy consumption (kWh/m²/yr) compared to the baseline store.

In addition CETC-Varennes is partnering with Loblaws (Canadian supermarket chain) to install a refrigeration showcase in a new 9000 m² store in 2003. Refrigeration for all cases will be provided by a secondary loop system (the frozen food cases will have self-contained refrigeration systems with horizontal scroll compressors and will reject heat to the main secondary loop system). Refrigeration heat recovery will be used for store heating.

Denmark

A propane/carbon dioxide demonstration plant has been built in a medium-size supermarket. Propane is used as the high temperature refrigerant (-14/+30°C) while carbon dioxide is used at the low temperature level (-32/-11°C). Carbon dioxide is used directly to perform the cooling in the freezers while a brine circuit with propylene glycol is used in the coolers. Energy consumption in the test store is similar to that of other new stores in the same chain of markets with conventional systems. The additional cost for a propane/carbon dioxide cascade plant for this size store is estimated at approximately 15% of the total installation. A second test store (190 kW chilled food load, 60 kW frozen food load) with a cascade system using R404A as the high temperature refrigerant and R744 (carbon dioxide) for the lower stage has been monitored also. The CO₂ is used to cool both frozen food and chilled food cases, thus the amount of R404A required is only about 120 kg or about 10% of what a conventional DX system would require resulting in initial refrigerant cost savings of about \$37,000US due to high Danish taxes

on HFCs. The total system cost was about 10% more than a conventional DX but showed 15-20% lower energy use than similar stores with R404A DX systems. The store used recovered heat from the refrigeration system for heating and required no back up during the test period.

Sweden

Sweden's work for the Annex is part of their national program Eff-Sys under a project "Energy Efficient Solutions for Supermarkets in Theory and Practice." They have developed a computer model (Cybermart) for system predesign and have carried out field measurements in four supermarkets to validate the model. Sweden's analyses indicate that well designed advanced secondary loop systems do not compromise energy efficiency compared to conventional DX systems. The analyses also show that two-loop secondary systems with subcooling of the low temperature loop are more efficient than cascade systems. Major conclusions from the field test results include the following.

- Standard secondary loop systems with subcooling of the low temperature loop primary refrigerant by the medium temperature brine have efficiency advantages over cascade systems.
- Night covering of display cases reduces energy consumption by 10-20%
- Practical experience with heat recovery to date show that only about 40-70% of stores' heating needs are supplied by refrigeration heat recovery, primarily due to very low refrigeration loads during winter and unoptimized control systems.
- Air-conditioning is needed in Swedish stores even if the cooling season is very short to avoid food quality problems. When the store ambient exceeds 25 °C food in display cases will exceed code minimum temperatures and shelf life is halved.

United Kingdom

Four research activities have been completed. The first is an evaluation of combined heat and power, and combined cooling, heating, and power schemes for supermarkets. CCHP has an improved load match compared to CHP, when used with absorption chilling. Cascade vapor compression systems integrated with the absorption system provide case refrigeration. Primary energy savings are around 15%, and there is a TEWI reduction of more than 50%. A second study involved comparison of various secondary systems with standard DX systems. Results from that study indicated that secondary loop systems use about 30% more energy mostly due to secondary pumping power. TEWI for secondary systems was estimated to be 8% lower than a DX baseline system, assuming the reference case had a 15% annual refrigerant leakage rate and a 15 year service life. Capital costs were estimated to be about 20% higher for the secondary approach. The third study was an investigation of the effect of various store conditions on case performance. Environmental chamber tests of low and medium temperature case systems show that an increase in ambient temperature from 19 to 22 °C increases system energy use by 20%. Increasing RH from 35 to 50% at an ambient of 22 °C increased the medium temperature case energy use by 15% but had no effect on the freezer case. Large savings were observed when the voltage was dropped from 240V to 220V, with no negative impact on product temperature. Finally analytical and experimental investigations of defrost methods and alternative control strategies were carried out. Studies looking at the frequency and duration of defrost cycles showed that the current

cycles are suited to relatively warm internal temperatures and high relative humidities (22°C and 60% RH), and for different internal conditions, a lower frequency would be sufficient. For electric defrost, optimized cycles and controls could reduce energy use by 25-50%, and better termination controls on completion of defrosting would reduce energy use still further.

United States

A 3720 m² supermarket was simulated and TEWI and energy consumption estimates were made for a baseline air-cooled multiplex refrigeration system and advanced systems. Total refrigeration load was 328 kW with a refrigerant charge of 4.15 kg/kW load. The distributed compressor, low-charge multiplex, and secondary loop systems (with four independent secondary loops) all achieved estimated annual energy savings of about 11%. Use of evaporative heat rejection was the principal driver for these energy savings - baseline system energy consumption was 8.2% lower with an evaporative condenser. The lowest TEWIs were achieved by the distributed system and the secondary loop systems with CO₂ emission reductions of about 13 - 14 million kg, or 57 - 60%. The low-charge multiplex system had estimated TEWI reductions of about 24% or 43% depending upon the refrigerant loss assumption. An analysis of an integrated water source heat pump and distributed compressor refrigeration system showed about 13% operating cost savings compared to a baseline air-cooled multiplex refrigeration system with conventional rooftop HVAC units.

Summary comments

Analyses carried out under the Annex 26 project and individual country programs have shown that both energy savings (over 10%) and TEWI reductions (up to 60%) are possible with low-charge refrigeration systems as compared to the most prevalent type baseline -- a multiplex DX system with air-cooled condensers. Savings are possible with distributed compressor systems, secondary loop systems, and low-charge multiplex systems. The secondary loop system option was the most thoroughly investigated advanced low-charge alternative in this Annex (all participants studied this option to some extent). Energy consumption comparisons with the baseline ranged from up to 30% greater energy use to about 10% savings. Use of evaporative heat rejection approaches (condensers or cooling towers) to reduce condensing temperatures is a key to obtaining maximum energy savings for all of the systems studied. Evaporative condensers (or cooling towers) will impose greater maintenance efforts and costs, however. Proper design and implementation of advanced low-charge systems is essential if energy savings are to be realized.

In general further efforts to reduce total global warming impacts (TEWI) of the advanced low-charge systems examined here would benefit more from reduction in energy usage (through efficiency increases or load reductions) than from further reduction in direct impact (from refrigerant losses).

Recovery of refrigeration system rejected heat was shown to be able to provide from about 40% to all of space and water heat needs for the test stores examined in this Annex. The amount of waste heat that is effectively applied to the space and water heat requirements at a given site will depend upon the size of the coincident refrigeration load and the refrigeration/HVAC control system's ability to effectively manage the heat

recovery process. The integration of heat pumps with refrigeration systems was shown to be an excellent means for recovering refrigeration waste heat and reducing overall store energy use. Heat-pump-based heat recovery does not require the refrigeration system condensing temperature to be maintained artificially high to facilitate heat recovery.

Available cost studies show installed cost premiums for secondary loop systems range from 0% to about 35% while distributed compressor systems show about a 15% premium. The low-charge multiplex approach is estimated to cost no more than current multiplex systems. It should be noted that the actual installed cost of any supermarket refrigeration system will be highly dependent upon many factors, not the least of which are the complex relationships between supermarket companies and equipment suppliers. These factors include negotiated purchasing arrangements, inclusion of display cases with system purchase, special system features, and unique installation requirements (site specific). If/when any of the advanced systems studied begin to obtain increased market share, the price differential with the current baseline can be expected to decrease somewhat due to the pressures of these market forces.

References

Danish law #49, December 21, 2000. Act amending the Act on taxes on certain chloroflouro-carbons and halons (CFC tax). (Tax on the industrial greenhouse gasses HFCs, PFCs and SF₆).

Bashtrash, S., 2002. Personal communication to Annex 26 participants during supermarket system tour near Montreal, April.

Horton, W. T., 2002. Modeling of secondary loop refrigeration systems in supermarket applications, HL 2002-3, Report # 52571-1, Purdue University, W. Lafayette, IN, April.

Hrnjak, P., 1996. "Secondary Coolants for Low Temperature Supermarket Refrigeration", presentation given at EPRI Supermarket Refrigeration Design Review Panel Meeting, ComEd Commercial Center, Oak Brook, IL. May 3.

Hrnjak, P., 2000. "Heat transfer issues in laminar flow of single-phase secondary refrigerants through the pipes," Proceedings of the IEA Annex 26 Workshop, Stockholm, Sweden, October. P. Lundqvist, ed.

Kantchev, J., 2002. . Personal communication to Annex 26 participants during supermarket system tour near Montreal, April.

Kazachki, G., E. Bayoglu, and C. Gage, 1997. "Comparative Evaluation of Heat-Transfer Fluids for Secondary Loop Systems", presentation given at the International Conference on Ozone –Protection Technologies, Baltimore, MD, November 13.

Lundqvist P., ed 2000. Proceedings of the IEA Annex 26 Workshop: Advanced Supermarket Refrigeration/Heat Recovery Systems, IEA Heat Pump Centre, Sittard, The Netherlands. (Cd-rom format only), ISBN# 90-73741-39-4.

Melinder, A., 2000. "Update on Secondary Refrigerants for Indirect Systems", Proceedings of the IEA Annex 26 Workshop, Stockholm, Sweden, October. P. Lundqvist, ed.

Sand J. R., Fischer S. K., and Baxter V. D., 1997. Energy and global warming impacts of HFC refrigerants and emerging technologies, Alternative Fluorocarbons Environmental Acceptability Study and U. S. Department of Energy, Washington, DC, USA.

Sherwood, G. J., 1999. Design and analysis of secondary refrigeration systems, MS Thesis, University of Minnesota, March.

Vana, J., 2000, "Comparison of secondary and multiplex DX equipment," Proceedings of the IEA Annex 26 Workshop, Stockholm, Sweden, October. P. Lundqvist, ed.

Walker D. H. and Baxter V. D., 2003. "Analysis of advanced, low-charge refrigeration systems for supermarkets," ASHRAE Trans. V. 109, pt. 1.

Acknowledgements

The Annex Operating Agent gratefully acknowledges the support and contributions of the lead investigators from each Annex 26 participant: V. Minea and D. Giguère of Canada; Prof. H. J. H. Knudsen of Denmark, Prof. P. Lundqvist of Sweden, and A. Crompton and J. Palmer of the United Kingdom. Thanks are also expressed to US contributors S. Fischer and D. Walker. The US Department of Energy, Office of Building Technology, State and Community Programs sponsored U. S. activities for IEA Annex 26 under contract DE-AC05-00OR22725 with UT-Battelle, LLC.

Appendix A – Case Study Summaries

This appendix is included to give the reader some summary details for a few of the stores that were the objects of case studies under Annex 26. For full details on the studies one should consult the individual country reports in Volume 2.

Canada – LTE

Test store 1 (“System1-phase1”) -- *METRO – Messier*, Montreal

Test store 2 (“System2-phase1”) -- *IGA – Crevier*, Montreal

Conventional store (“CON”) -- *METRO – Bordeleau*, Montreal

- “System1-phase1” – multiplex system with reciprocating compressors for low temperature loads and screw compressors for medium temperature loads. New total heat reclaim technique for space and hot water heating. High speed hot gas defrost method.
- “System2-phase1” – improved multiplexed system with reciprocating compressors. Cascade heat pumps coupled with the refrigeration system to recover rejected heat for store heating in winter. Dedicated heat pump for mechanical sub-cooling. Refrigerant liquid pumping.
- “CON” – multiplex, conventional heat reclaim and defrost.

Store and system design details

Store Areas and Refrigeration Capacities as function of Saturated Suction Temperatures

System	Total Area	Sale Area	Low/Dual Temperatures				Medium Temperatures				
	- ft ²	- ft ²	- 37 °C kW	- 32 °C kW	- 29 °C kW	-26 °C kW	-12 °C kW	-9 °C kW	-7 °C kW	-1 °C kW	7 °C kW
System1	38,000	28,302	7.15	28.34	8.54	13.63	-	82.77	134.4	11.58	35.43
System2	40,900	30,838	4.61	9.02	56.33	-	3.61	118.0	155.3	9.50	-
CON	18,000	12,200	-	35.57	-	-	-	45.70	78.61	-	-

- store operating hours (hours open per day): 14 hours/day.
- total traffic or sales volume: average traffic - 10 000 per week
- estimated total primary refrigerant charge (estimate): R-22, 1500 – 1800 kg
- estimate of annual loss of primary refrigerant: 15% of charge

”System I-phase I”: Display Cases and Walk-in Boxes – Low Temperature Rack

(SST - Saturated Suction Temperature; CST - Condensing Saturated Temperature)

No	Dimensions	Description	Capacity	SST	CST
-	ft	-	Btu/h	°F	°F
1	8'	Frozen Tomb	10 860	-25	105
2	12'	Frozen Tomb	13 380	-25	105
3	15 doors	Ice Cream	25 500	-25	105
4	12 doors	Grocery	18 000	-15	105
5	14 doors	Meat	21 000	-15	105
6A	5 doors	Fish	7 500	-15	105
6B	3 doors	Bakery	4 500	-20	105
7A	26'x15'x8'	Grocery	12 500	-25	105
7B	26'x15'x8'	Grocery	12 500	-25	105
8	20'x13'x8'	Meat	15 900	-20	105
9	11'x8'x8'	Bakery	8 750	-20	105
10	12'	Frozen Tomb	3 960	-25	105
11		Spare 10 %	18 000	-25	105
13A	8'+2 (bouts)	Ice Cream	12 200	-35	105
13B	8'+2 (bouts)	Ice Cream	12 200	-35	105

”System I-phase I”: Display Cases and Walk-in Boxes – Medium Temperature
(SST - Saturated Suction Temperature; CST - Condensing Saturated Temperature)

No.	Dimensions	Description	Capacity	SST	CST
-	ft	-	Btu/h	°F	°F
20	28	Fresh Meat	44 800	15	110
21	36	Fresh Meat	57 600	15	110
22A	14	Delicatessen	15 400	15	110
22B	14	Delicatessen	15 400	15	110
23A	14	Cheese	10 850	15	110
23B	14	Cheese	10 850	15	110
24A	8	Pizza	9 600	15	110
24B	8	Spare	10 600	15	110
24C	8	Spare	2 400	20	110
24D	8	Spare	2 400	20	110
25	36	Delicatessen	52 800	15	110
26A	8	Fish	9 600	15	110
26B	8	Bakery	9 600	15	110
27	12	Start-up	9 300	15	110
28	Spare 10 %	-	26 000	15	110
29	A/C	AC offices	79 800	45	110
30A	30'x20'x10'	<i>Meat</i>	17 550	20	110
30B	30'x20'x10'	<i>Meat</i>	17 550	20	110
31A	10'x9'x8'	<i>Fish</i>	8 200	20	110
31B	10'x9'x8'	<i>Delicatessen</i>	8 200	20	110
31C	12'x8'x8'	<i>Bakery</i>	8 000	20	110
32A	8	Meat	3 040	20	110
32B	24	Delicatessen Service	9 120	20	110
33A	26'x18'x8'	<i>Milk</i>	11 300	20	110
33B	26'x18'x8'	<i>Milk</i>	11 300	20	110
34A	36	Milk	47 700	20	110
34B	12	Wine	15 900	20	110
35	38	Milk	50 360	20	110
36	40	Milk	53 000	20	110
37	44	Beer	63 800	20	110
38A	8	Fruits	3 800	20	110
38B	20	Fruits	26 500	20	110
39	48	Fruits	37 440	20	110
40	24'x15'x8'	<i>Fruits</i>	20 150	20	110
41A	608	<i>Preparing</i>	19 760	30	110
41B	608	<i>Preparing</i>	19 760	30	110
42	Spare 10 %	-	41 000	20	110
43	-	Sub-cooling	41 084	40	110
TOTAL	-	-	901 514	-	-

”System I-phase I: Characteristics of the Low Temperature Compressors

Compressor	SST	Model	Power	Capacity	THR	RLA	kW
-	°F	-	hp	Btu/h	Btu/h	A	-
Copeland	-25	3DA3-0600-TFE	6	28 661	44 545	10,5	4,6
Copeland	-25	4DA3-1000-TSE	10	48 307	75 860	17,5	8
Copeland	-25	4DL3-1500-TSE	15	64 685	101 098	20,9	10,7
Copeland	-25	3DS3-1000-TFE	10	46 399	71 891	16,8	7,4
Copeland	-35	3DF3-0900-TFE	9	29 470	49 160	16,5	5,7
TOTAL	-	-	50	217 522	342 554	82,2	36,4

”System I-phase I: Characteristics of the Medium Temperature Compressors

Compressor	TSS	Model	Power	Capacity	THR	RLA	kW
-	°F	-	hp	Btu/h	Btu/h	A	-
Carlyle	15	06TAH078C2EA	40	323 173	408 548	51,4	37,2
Carlyle	15	06TAH078C2EA	40	323 173	408 548	51,4	37,2
Carlyle	15	06TAH078C2EA	40	323 173	408 548	51,4	37,2
TOTAL	-	-	120	969 519	1 225 644	154,2	111,6

”System I-phase I: Characteristics of the Air-Cooled Condensers

	Low Temperature	Medium Temperature
Model	CLD057	FDFCT-180-R
Capacity	424 800 Btu/h	1 800 000 Btu/h
AC Circuit; Control	8,4 A; 575 V/3 ph; 120 V/30 A	575 V/3 ph; 120 V/30 A

”System 1-phase I”: Example of Monitored Parameters

Type of Parameter	Observation
Store Total Power (kW)	-
Compressor’s Power (kW)	Both DT and MT Compressor
Total Electrical Power (kW)	LT and MT Compressor
Suction Pressures (psig)	Both DT and MT Refrigeration Line
Discharge Pressures (psig)	Both DT and MT Refrigeration Line
Suction Temperatures (°C)	Both DT and MT Refrigeration Line
Discharge Temperatures (°C)	Both DT and MT Refrigeration Line
Liquid Temperatures (°C)	Both DT and MT Refrigeration Line
Liquid Pressures (psig)	Both DT and MT Refrigeration Line
Cold Water Temperatures (°C)	Entering/Leaving Storage Tank
Groundwater Temperature (°C)	Entering/Leaving Plate Heat Exchanger
Control Valves Status (on/off)	Defrost, Heat Recovery, Flushing, etc.

”System 1-phase I”: Example of Calculated Thermodynamic and Energy Parameters

Type of Parameter	Observation
Mass Enthalpies (kJ/kg)	Both DT and MT Line (Suction, Discharge, Liquid)
Total Refrigerant Flow-rate (kg/s)	Both DT and MT Refrigeration Line
Title of Two-phase Refrigerant (%)	Both DT and MT Refrigeration Line
Refrigeration Power (kW)	Both DT and MT Refrigeration Line
Condensing Power (kW)	Both DT and MT Refrigeration Line
Refrigeration Load (kWh)	Both DT and MT Refrigeration Line
Energy Rejected from Condensers (kWh)	Both DT and MT Refrigeration Line
Refrigeration Efficiency	Both DT and MT Refrigeration Line
Saturated Suction (SST) and Discharge (SDT) Temperatures (°C)	Both DT and MT Refrigeration Line
Compressor Consumed Energy (kWh)	Both DT and MT Refrigeration Line
Energy Consumption (kWh)	Both DT and MT Refrigeration Line
Operating Time: Heat Reclaim, Defrost; Condenser; Geothermal	Space and Water Heating Systems
Defrost Cycle Status and Operating Time (sec/hr; hrs/day)	Fresh Meat Case and Cold Room; Ice Cream

“System2 – phase1”: Characteristics of Dual (Low & Medium) Temperature Compressors (THR - Total Heat Rejection; EER – Energy Efficiency Ratio)

Compressor	TSS	Model	Condensing temperature	SUCTION Capacity	THR	EER
-	°F	-	°F	Btu/h	Btu/h	-
COP/Discuss (22) L/T	-35	2DA3-060E-TFE-200	100	16 000	27 270	5,07
COP/Discuss (22) L/T	-25	3DB3-075E-TFE-200	100	37 000	55 490	6,76
COP/Discuss (22) L/T	-20	2DL3-040E-TFE-200	100	25 000	36 380	7,07
COP/Discuss (22) L/T	-20	3DS3-100E-TFE-200	100	56 000	82 320	7,1
COP/Discuss (22) L/T	-20	3DS3-100E-TFE-200	100	56 000	82 320	7,1
COP/Discuss (22) L/T	-20	4DA3-100E-TSE-200	100	59 000	88 510	6,93
COP/Discuss (22) M/T	15	3DB3-100E-TFE-200	100	107 000	136 100	12,71
COP/Discuss (22) M/T	15	3DS3-150E-TFE-200	100	142 000	181 100	12,32
COP/Discus (22) M/T	15	4DA3-2000-TSE-200	100	150 000	190 800	12,54
Total	-35	-	-	16 000	-	-
	-25	-	-	37 000	-	-
	-20	-	-	195 000	-	-
	15	-	-	399 000	-	-
Total Unit	-	-	-	-	880 200	-

“System2 – phase1”: Characteristics of Medium Temperature Compressors (THR - Total Heat Rejection; EER – Energy Efficiency Ratio)

Compressor	TSS	Model	Condensing Temperature	SUCTION Capacity	THR	EER
-	°F	-	°F	Btu/h	Btu/h	-
COP/Discuss (22) M/T	20	2DA3-075E-TFE-200	100	83 000	103 600	13,78
COP/Discuss (22) M/T	20	3DB3-100E-TFE-200	100	120 000	149 300	13,82
COP/Discuss (22) M/T	20	3DL3-150E-TFE-200	100	159 000	199 200	13,34
COP/Discuss (22) M/T	20	4DH3-2500-TSE-200	100	222 000	276 800	13,69
Total	20	-	-	584 000	-	-
	-	-	-	-	729 000	-

“System2 – phase1”: Display Cases and Walk-in Boxes –Low Temperature

No.	Description	Capacity	SST
-	-	Btu/h	°F
13	Ice Cream	15 720	- 35
11	Pastry and Frozen Meat	5 280	- 25
4	Ice Cream 5 doors	25 500	- 25
10	Bakery and Frozen Crustaceous	16 680	- 20
8	Frozen Meat and Fish	21 720	- 20
3	Frozen Products	10 860	- 20
5	Frozen Products	23 160	- 20
6	Frozen Meat	17 640	- 20
7	Frozen Bakery	20 760	- 20
9	Frozen Meat and Fish	27 000	- 20
2	Frozen Products	24 000	- 20
1	Frozen Products	22 500	- 20
12	Spare	7 894	- 20

“System2 – phase1”: Display Cases and Walk-in Boxes – Medium Temperature
(SST : Saturated Suction Temperature)

No.	Description	Capacity	SST
-	-	Btu/h	°F
41	Combined Service. “BAS”	12 320	10
41	Shelves of Prepared Meals	7 200	15
41	Flowers	6 240	20
52	Prepared Meals	5 080	15
52	Delicatessen and mets préparés	12 420	20
31	Fresh Meat	30 280	15
30	Fresh Meat	44 800	15
32	Fresh Meat, Fish and Crustaceous	33 960	15
33	Delicatessen	52 800	15
34	Delicatessen	38 400	15
38	Prepared Meals	43 200	15
37	Pizza	31 200	15
38	Prepared Meals	11 670	20
35	Wine	26 500	20
35	Delicatessen	26 500	15
40	Vinaigrettes	37 100	20
46	Fruits and Vegetables	43 680	20
36	Fruits and Vegetables	18 720	20
42	Fruits and Vegetables	44 160	20
50	Milk Products	50 340	20
49	Milk Products	31 800	20
48	Milk Products	47 700	20
53	Milk Products	71 520	20
51	Beer	68 900	20
44	Milk	22 650	20
43	Fresh Meat and Fish	39 090	20
45	Bakery; Fruits and Vegetables	36 990	20
47	Preparation Area	32 400	30

“System2 – phase1”: Example of Monitored Parameters

Type of Parameter	Observation
Store Total Power (kW)	-
Compressor Power (kW)	Each Low and Dual Compressor
Rack Power (kW)	LT and MT Compressor
Heat Recovery and Sub-Cooling Heat Pump Power (kW)	Each Unit
Suction Pressures (psig)	Very Low, Low and Medium
Common Discharge Pressures and Defrost Discharge (psig)	Each Rack
Suction Temperatures (°C)	Very Low, Low and Medium
Common Discharge Temperatures (°C)	DT/MT
Defrost Discharge Temperatures (°C)	DT/MT
Liquid Defrost Return Temperatures (°C)	DT/MT
Liquid Temperatures (°C)	DT/MT
Liquid Pressures (psig)	DT/MT
Liquid Pump Pressures (psig)	Entering/Leaving each LP
Control Valves Status (on/off)	Defrost, Heat Recovery, Flushing, etc.
Hot Gas Temperature at Plate Heat Exchangers Outlet (°C)	Each Unit
Natural Gas Valve Status (on/off)	Each Unit

“System2 – phase1”: Example of Calculated Parameters

Type of Parameter	Observation
Mass Enthalpies (kJ/kg)	LT/DT (Suction, Discharge and Liquid0
Compression Mass Enthalpy Variation (kJ/kg)	LT/DT
Saturated Suction and Discharge Temperatures (°C)	Low and Dual Temperature
Compressor Energy Consumption (kWh)	Each Low and Dual Compressor
Total Energy Consumption (kWh)	Each Low and Dual Compressors
Heat Pumps Operating Time (sec/hr; hrs/day)	Space and Water Heating Systems
Defrost Status and Duration (sec/hr; hrs/day)	Fresh Meat Case and Cold Room; Ice Cream

“System *CON*” : Display Cases and Walk-in Boxes – Low Temperature

Circuit	Description	Capacity	Operation Temperatures	
			Evaporation	Condensing
-	-			
		Btu/h	°F	°F
1	Different Products	25 500	- 25	105
2	Ice Cream	22 100	- 25	105
3	Different Product	11 500	- 25	105
4	Fish	25 680	- 25	105
5	Meat	2 640	- 25	105
7	Meat	19 260	- 25	105
8	Meat	9 000	- 25	105
9	Pastry	5 700	- 25	105
Total	-	121 380	-	-

“System CON” : Display Cases (15 °F - Medium Temperature)

Circuit	Description	Capacity	Operation Temperatures	
			Evaporation	Condensing
-	-		°F	°F
		Btu/h	°F	°F
19	Fresh Meat	57 600	15	110
11	Delicatessen	16 140	15	110
12	Fish	9 600	15	110
13	Mets cuisinés	24 000	15	110
14	Delicatessen	14 400	15	110
15	Cheese	10 800	15	110
20	Meat	23 400	15	110
Total	-	155 940	-	-

“System CON” : Display Cases (20 °F - Medium Temperature)

Circuit	Description	Capacity	Operation Temperatures	
			Evaporation	Condensing
-	-		°F	°F
		Btu/h	°F	°F
17	Pastry	9 600	20	110
18	Farm Delicatessen	10 500	20	110
18	Milk	63 600	20	110
20	Beer	21 200	20	110
21	Jus/Vegetables	37 100	20	110
21	Refrigerated Table	5 600	20	110
22	Fruits/Vegetables	40 300	20	110
23	Milk	11 500	20	110
24	Delicatessen	4 500	20	110
25	Fruits/Vegetables	10 000	20	110
26	Beer	19 000	20	110
27	Meat	24 505	20	110
28	Fruits/Vegetables	10 800	20	110
Total	-	268 205		

“System-CON”: Monitored Parameters

Type of Parameter	Observation
Compressor Power (kW)	LT and MT Compressors
Electrical Oven Power – Cooking (kW)	Ovens #1, 2 and 3
Suction Temperature (°C)	Low and Medium Temperature Racks
Common Discharge Temperature (°C)	Each Rack
Hot Gas Temperature – Heat Reclaim (°C)	Entering and Leaving HR Coil
Defrost Valves Status (on/off)	Freezing Products; Fresh Meat

Based on the measured parameters, several thermodynamic, energy and performance calculations were performed ().

“System-CON”: Thermodynamic, Energy and Performance Calculated Parameters

Type of Parameter	Observation
Energy Consumption of Compressor (kW)	Low and Medium Temperature Compressors
Total Refrigeration Consumed Energy (kWh)	Low and Medium Temperature Compressors
Cooking Energy Consumption (kWh)	Each Electrical Oven
Duration and Defrost Status (sec/hr; hrs/day)	Four Refrigeration Display Cases

Annual energy consumption

Total Store's Natural Gas Consumption vs. Sale Area

System	Sale Area	Total Consumption		Equivalent Energy		Total Natural Gas Cost (CAN\$)	
		m^3/y	m^3/ft^2	GJ/y (kWh/y)	GJ/ ft^2/y (kWh/ ft^2/y)	\$/y	\$/ ft^2/y
Syst-1	28,302	45,179	1.59	1.6 (4.4×10^6)	5.6×10^{-5} (155)	22,534	0.80
Syst-2	30,838	35,625	1.15	1.27 (3.5×10^6)	4.12×10^{-5} (113)	17,860	0.58

Total Store Annual Electrical Energy Consumption and Costs (Including Demand Power Cost) vs. Sale Area (CAN\$)

System	Sale Area	Total Store Electrical Energy Consumption (including compressors and heat pumps)			Total Store Electrical Energy Cost (Power : 11,97 \$/kW)		
		kWh/y	kWh/ $ft^2.y$	vs. CON.1 (%)	\$/y	\$/ $ft^2.y$	vs. CON.1 (%)
Syst-1	28,302	2,770,873	97.9	+ 2.4	157,704	5.6	- 12.5
Syst-2	30,838	2,768,775	89.8	- 5.7	163,411	5.3	- 17.2
CON.1	12,200	1,095,462*	95.5*	-	78 440*	6.4*	-

* Without Electrical Cooking

Annual Compressor Electrical Energy Consumption and Costs (Including Power Demand Cost) – vs. Sale Area (CAN\$)

System	Sale Area	Compressors	Total Energy Consumption (Compressors only)			Total Electrical Energy Cost (Compressors only)	
			kWh/y	% of Total Store Cons.	kWh/ ft^2 .y	\$/y	\$/ ft^2 .y
	ft^2	-					
Syst-1	28,302	Low Temp.	264,906	9.6	9.4	15,077	0.53
		Medium T.	637,299	23	22.5	36,262	1.28
		TOTAL compressors	902,205	32.5	31.9	51,339	1.81
Syst-2	30,838	Low/Dual T.	423,291	15.3	13.7	24,982	0.81
		Medium T.	206,298	7.5	6.69	12,172	0.39
		TOTAL compressors	629,589	22.7	20.4	37,154	1.2
		Heat Pumps	313,805	11.3	10.2	18,521	0.6
		TOTAL	943,394	34.0	30.6	55,675	1.8
CON.	12,200	TOTAL compressors	355,721	30.6*	29.2	23,995	1.97

* Excluding electrical cooking.

Denmark

Fakta market in Beder, Denmark (newest store in the Fakta chain as of July 2001)

Store details

Size - 490 m² sales area (720 m² total area)

Operating hours/day – 12 hours/day

Lighting load – 12.18 kW indoor; 1 kW outdoor

Refrigeration system

Type – This is a cascade system using propane as the refrigerant for the higher temperature loads (–14/25°C) and CO₂ as the refrigerant for the lower temperature loads (–32/–10°C). The propane cycle rejects heat through an air-cooled condenser at the roof of the supermarket while the CO₂ condenses in a cascade heat exchanger that also serves as one of two evaporators for the propane cycle. CO₂ is used directly (direct expansion) in the low-temperature (LT) cabinets and cold stores of the supermarket, while the propane circuit chills propylene glycol brine in its second evaporator. The glycol is pumped in a closed system to the high-temperature (HT) cabinets and cold stores.

Design capacity - 33 kW at -14°C evaporating temperature, propane circuit (21 kW for HT cabinets, 12 kW for CO₂ circuit condenser); 10 kW at -32°C evaporating temperature, CO₂ circuit

Primary refrigerant type and charge – 10 kg propane; 6 kg CO₂

Secondary refrigerant type and charge – 120 l propylene glycol

Estimated annual losses – propane circuit, 2% of charge; CO₂ circuit, 15% of charge

Propane system components

Description	Supplier
2 compressors	Bitzer, 4T-8.2P
Air-cooled condenser	ECO FCE 071C63
Plate heat exchanger	R290/PGI: 21 kW, Swep, B25x70
Plate heat exchanger	R290/R744: 10 kW, Swep V27x80 HP
Plate heat exchanger	R290/R290: 2 kW, Swep, B12x70
Plate heat exchanger	R290/PG: 3 kW, Swep B27x50
Electronic expansion valve	Danfoss ETRE – 30 kW
Electronic expansion valve	Siemens Staefa – 14 kW

CO₂ system components

Description	Supplier
Compressor for CO ₂	Bitzer, X2KC-3.2, BSE 55
Expansion valve	AKV (nozzle 2-4)
Safety pressure switches	KP 5
Filter dryer	DU 303

Display cases

	Air on	Refrigeration load [W]		Dimensions
	[°C]	Medium (+2°C)	Low (-20°C)	LxBxH [mm ³]
Storage (glass doors to shop)	-2°C	4500	-	5100x3300x2360
Storage, frozen food (doors)	-26°C	-	4200	3600x3300x2450
Storage, ice cream (doors)	-28°C		2800	2100x3300x2450
Vertical cabinet (no doors)	-2°C	14400	-	10 m in length
Horizontal case	-27°C		2200	3750x1000x960
Horizontal case	-27°C		800	1985x1000x960
Horizontal case	-2°C	1400		3750x1000x960
Horizontal case	-2°C	700		1985x1000x960
Total		21000	10000	

* Type of defrost method: Electric resistance

HVAC system

Type – ventilation only; 2.62 kW power input

System operating data

Saturated discharge and suction temperatures

Propane system:	
Condensation Temperature:	25°C (avg.) / 22°C (min) / 30°C (max)
Evaporation temperature:	-14°C (avg.)
Capacity (design):	33 kW
CO2 system:	
Condensation Temperature:	-11°C (avg.)
Evaporation temperature:	-32,5°C (avg.)
Capacity (design):	10 kW
Brine PG(40%):	
Outlet temperature:	-8°C
Return temperature:	-2°C
Capacity (design):	21 kW

System energy use and weather conditions

Total store energy consumption, July 2001

	pcs	kW/pcs	Hours/day	kWh/ July
Refrigeration plant	1	-	24	8682
In store lighting	210	0,058	12	4531
Out store lighting	10	0,1	12	372
Ventilation store	1	2,62	14	1137
Tellers	3	0,4	12	446
Bottle machine	1	1	1	31
Various	1	2	12	372
Total				15571

Refrigeration system energy consumption detail, July 2001

Consumer	Energy consumption [kWh for July]
Propane compressor 1	3565
Propane compressor 2	1240
CO ₂ compressor	605
Cases and cabinet:	
Lighting	107
Ventilation	487
Storage rooms:	
Lighting	391
Ventilation	744
Brine pump:	126
Heaters (Edge):	1116
Defrost (cases, cabinet and storage)	84
Ventilation condenser	140
Electronics	78
Total	8682

The average outdoor temperature during the July 2001 period was 17.9 °C. Store indoor temperature averaged 22.5 °C. Energy consumption of the refrigeration system in the Fakta Beder store compared to eight similar Fakta supermarkets with conventional R404A direct expansion refrigeration systems is illustrated in Figure A1. The time period plotted begins in July 2000 and ends in February 2002.

Figure A1 – Comparison of energy use of Fakta Beder store (with cascade refrigeration system) to that of eight other Fakta stores (with conventional R404A DX refrigeration systems); July 2000 through February 2002.

United States

Test store – Distributed compressor refrigeration system

Size – 4830 m² sales area

Operating hours – 168 hrs/week

Refrigeration system

The system consists of several small compressor cabinets distributed throughout the store and located close to the loads they serve. Heat rejection is done via a water/glycol loop that connects the compressor cabinets to roof-mounted cooling towers (dry type). Water source heat pumps are integrated into the condenser cooling loop and recover the refrigeration waste heat in winter to heat the store space.

Distributed Refrigeration System Compressors (capacities are in kW for saturated evaporating and condensing temperatures shown) All compressor cabinets use refrigerant R-404A				
Cabinet A Low Temperature			Cabinet C Low Temperature	
Compressors		Capacity: -32°C & 41°C		Capacity: -27°C & 41°C
A-1	ZF15K4	4.8	C-1	ZF15K4 6.3
A-2	ZF15K4	4.8	C-2	ZF15K4 6.3
A-3	ZF15K4	4.8	C-3	ZF15K4 6.3
A-4	ZF18K4	5.7	C-4	ZF15K4 6.3
A-5	ZF18K4	5.7	C-5	ZF15K4 6.3
Cabinet B Low Temperature			Cabinet D Low Temperature	
		Capacity: -32°C & 41°C		Capacity: -32°C & 41°C
B-1	ZF13K4	3.9	D-1	ZF15K4 5.2
B-2	ZF13K4	3.9	D-2	ZF15K4 5.2
B-3	ZF15K4	4.8	D-3	ZF15K4 5.2
		Capacity: -26°C & 41°C	D-4	ZF15K4 5.2
B-4	ZF15K4	6.1	D-5	ZF15K4 5.2
B-5	ZF18K4	7.3	D-6	ZF18K4 6.2
B-6	ZF18K4	7.3		
Cabinet E Medium Temperature			Cabinet G Medium Temperature	
		Capacity: -6.7°C & 43°C		Capacity: -8.3°C & 43°C
E-1	ZS38K4	12.0	G-1	ZS38K4 11.3
E-2	ZS38K4	12.0	G-2	ZS38K4 11.3
E-3	ZS45K4	14.4	G-3	ZS38K4 11.3
E-4	ZS45K4	14.4	G-4	ZS38K4 11.3
E-5	ZS45K4	14.4	G-5	ZS38K4 11.3
E-6	ZS45K4	14.4	G-6	ZS45K4 13.5

Cabinet F Low/Medium Temperature Capacity: -6.7°C & 43°C			Cabinet H Low/Medium Temperature Capacity: -15°C & 43°C		
F-1	ZF09K4		H-1	ZS26K4E	6.2
		Capacity: -8.3°C & 43°C	H-2	ZS26K4E	6.2
F-2	ZS30K4	9.2			Capacity: 1.7°C & 43°C
F-3	ZS30K4	9.2	H-3	ZS38K4E	15.9
F-4	ZS30K4	9.2	H-4	ZS38K4E	15.9
F-5	ZS38K4	11.3	H-5	ZS45K4E	19.1
Cabinet I Medium Temperature Capacity: -8.3°C & 43°C			Cabinet J Low/Medium Temperature Capacity: -6.7°C & 43°C		
I-1	ZS38K4E	12.0	J-1	ZF11K4E	3.6
I-2	ZS38K4E	12.0	J-2	ZF13K4E	4.2
I-3	ZS45K4E	14.4	J-3	Zf13K4E	4.2
I-4	ZS45K4E	14.4			Capacity: -9.4°C & 43°C
I-5	ZS45K4E	14.4	J-4	ZS38K4E	10.8
			J-5	ZS38K4E	10.8
			J-6	ZS38K4E	10.8

Primary refrigerant type and charge – R-404A; estimated at about 410 kg total
Secondary refrigerant type and charge – ethylene glycol on condenser fluid loop;
total charge unknown
Estimated annual losses – primary refrigerant annual loss estimated at 5% of total
charge

Display case line ups, storage and preparation room areas, and miscellaneous loads
connected to compressor cabinets

Circuit	Case Length, No. of Doors, or Walk-in Floor Area	Design Refrigeration Load (kW)
Cabinet A Sat. Suction Temp -32°C		
Walk-in Freezer	94.1 m ²	22.3
Cabinet B Sat. Suction Temp -32°C		
Walk-in Freezer	47 m ²	11.1
Cabinet B Sat. Suction Temp -26°C		
Reach-in Frozen Food	23 Doors	10.1
Cabinet C Sat. Suction Temp -26°C		
Reach-in Frozen Food	52 Doors	19.8
Multi-Deck Frozen Food	2.4 m	3.5
Cabinet D Sat. Suction Temp -32°C		
Multi-Deck Frozen Meat	17 m	16.7
Multi-Deck Frozen Fish	8.5 m	7.0
Walk-in Frozen Fish	13.4 m ²	3.5
Cabinet E Sat. Suction Temp -6.7°C		
Multi-Deck Dairy	36.6 m	47.1
Multi-Deck Cheese	4.3 m	5.5

Walk-in Dairy	79.6 m ²	18.2
Cabinet F Sat. Suction Temp -8.3°C		
Service Deli	25.6 m	7.6
Multi-Deck Cheese	6.1 m	8.4
Isle Deli	4.9 m	11.3
Walk-in Deli	14.2 m ²	4.5
Walk-in Raw	4.5 m ²	1.4
Cabinet F Sat. Suction Temp -29°C		
Walk-in Deli Freezer	7.5 m ²	1.8
Cabinet G Sat. Suction Temp 8.3°C		
Single-Deck Meat	7.3 m	3.3
Multi-Deck Meat	20.7 m	26.9
Floral Display	7.3 m	9.1
Multi-Deck Deli	8.5 m	12.4
Single-Deck Fish	4.9 m	5.2
Walk-in Fish	10.2 m ²	3.2
Cabinet H Sat. Suction Temp 35°F		
Meat Prep Room	6,144 ft ²	153,600
Cabinet H Sat. Suction Temp -15°C		
Ice Maker		10.6
Cabinet I Sat. Suction Temp -6.7°C		
Multi-Deck Produce	35.4 m	36.0
Table Fish	4.6 m	2.2
Walk-in Produce	91.4 m ²	19.5
Cabinet J Sat. Suction Temp -9.4°C		
Walk-in Meat	98.1 m ²	23.2
Walk-in Bakery	11.1 m ²	5.8
Cabinet J Sat. Suction Temp -29°C		
Walk-in Freezer Meat	9.3 m ²	2.2
Walk-in Freezer Bakery	13.4 m ²	3.2
Multi-Deck Bakery	4.3 m	4.6
All Compressor Cabinets employ R-404A as the refrigerant		

Baseline store – Conventional multiplex direct expansion refrigeration system

Size – 4830 m² sales area

Operating hours – 168 hrs/week

Refrigeration system

The system consists of three compressor racks - one for the low temperature load with seven compressors and two for the medium temperatures loads with six compressors each. All compressors are reciprocating type and the rack with highest suction temperature (Rack C) supplies mechanical subcooling to the other two racks.

Multiplex Refrigeration System Compressors
Low Temp System Rack A
Main Compressors -29°C SST R-404A Comp1 4DL3-150E-TSK Comp2 4DL3-150E-TSK Comp3 4DL3-150E-TSK Comp4 4DL3-150E-TSK Satellite Compressors -34°C SST R-404A Comp5 3DF3-090E-TFD Comp6 3DF3-090E-TFD Comp7 2DL3-040E-TFD
Medium Temp System Rack B
Main Compressors -6.7°C SST R-22 Comp1 3DA3-0750-TFD Comp2 3DA3-0750-TFD Comp3 3DA3-0750-TFD Comp4 2DD3-0500-TFD Satellite Compressors -8.3°C SST R-22 Comp5 3DS3-1500-TFD Comp6 3DF3-1200-TFD
Medium Temp System Rack C
Main Compressors -6.7°C SST R-22 Comp 1 3DS3-1500-TFD Comp 2 3DA3-0750-TFD Satellite Compressors 1.7°C SST R-22 Comp 3 3DS3-1500-TFD Comp 4 3DS3-1500-TFD Comp 5 3DF3-1200-TFD Comp 6 2DL3-0750-TFD

Display case line ups, storage and preparation room areas, and miscellaneous loads connected to compressor racks

Circuit	Case Length, No. of Doors, or Walk-in Floor Area	Design Refrigeration Load (kW)
Rack A Low Temperature - Sat. Suction Temp -29°C Refrigerant - R404A		
Reach-in Frozen Food	76 Doors	33.4
Multi-Deck Frozen Meat	12.2 m	17.7
Multi-Deck Frozen Fish	5.5 m	8.0
Multi-Deck Bakery	3.7 m	5.3
Walk-in Freezers	85.9 m ²	20.3
Ice Maker		10.6
Rack A Low Temperature - Sat. Suction Temp -34°C		
Coffin Ice Cream	31.6 m	21.9
Coffin Shrimp	4.9 m	1.7
Walk-in Ice Cream	16.7 m ²	5.0
Rack B Medium Temperature - Sat. Suction Temp -6.7°C Refrigerant - R22		
Reach-in Dairy	46 Doors	18.3
Single-Deck Produce	17.1 m	15.6
Multi-Deck Produce	7.3 m	9.4
Service Meat & Deli	19.5 m	6.9
Multi-Deck Deli	14.6 m	20.5
Coffin Cheese & Deli	4.9 m	7.3
Tables Fish	6.1 m	2.9
Cooler Floral	13 m ²	3.1
Floral Display	2.4 m	3.0
Rack B Medium Temperature - Sat. Suction Temp -8.3°C		
Bakery Display	4.6 m	3.7
Multi-Deck Meat	20.7 m	26.9
Isle Cheese & Deli	17.1 m	18.6
Isle Ready Meals	15.8 m	16.8
Rack C Medium Temperature - Sat. Suction Temp -6.7°C Refrigerant - R22		
Walk-in Coolers	204.0 m ²	57.9
Rack C Medium Temperature - Sat. Suction Temp 1.7 °C		
Meat Prep Room	93.8 m ²	41.4
Produce Prep Room	48.3 m ²	11.4
Mechanical Subcooling		106.0

Primary refrigerant type and charge –

R-404A in low temperature system; estimated at about 454 kg total

R-22 in medium temperature system; estimated 908 kg total

Estimated annual losses –refrigerant annual loss estimated at 20% of total charge

System operating data & measured energy use

Energy Consumption Comparison between Multiplex and Distributed Refrigeration Systems – May 2001 through February 2002

Energy Consumption (kWh/day)				
	Distributed	Multiplex	Difference	% Difference
May-Aug				
LT	1306.4	1290.2	16.2	1.2
Compressor				
MT	1594	1201.2	392.8	24.6
Compressor				
Heat Reject	702.7	608.4	94.3	13.4
Total	3603.2	3100.5	502.7	14.0
Nov - Feb				
LT	863.2	957.9	-94.7	-11.0
Compressor				
MT	951.3	635.9	315.4	33.2
Compressor				
Heat Reject	316.1	364.4	-48.3	-15.3
Total	2130.5	1958.2	172.3	8.1

Average State Points, Refrigeration Loads, and efficiencies for the Multiplex and Distributed Refrigeration Systems – May 2001 through February 2002

	May - Aug		Nov – Feb	
	Distributed	Multiplex	Distributed	Multiplex
Low Temp				
SST (°C)	-26.6	-28.4	-27.3	-29.0
SDT (°C)	32.2	28.2	16.1	21.7
Return Temp (°C)	-11.4	-16.6	-8.7	-11.7
Liquid Temp (°C)	26.2	14.3	13.8	10.2
Ref Load (kW)	100.0	133.5	90.6	113.1
Comp Power (kW)	54.4	53.8	36.0	39.9
COP	1.84	2.48	2.52	2.83
Med Temp				
SST (°C)	-8.8	-5.1	-10.3	-6.6
SDT (°C)	33.6	28.5	22.3	19.4
Return Temp (°C)	8.0	9.4	6.8	9.6
Liquid Temp (°C)	29.4	20.1	19.5	14.6
Ref Load (kW)	213.9	191.4	158.6	129.8
Comp Power (kW)	66.4	50.1	39.6	26.5
COP	3.22	3.82	4.01	4.90

TEWI Analysis for the Field Test Results – May 2001 through February 2002

	Refrigerant Leakage (kg)		Energy (kWh)	TEWI (kg CO2)		
	R-404A	R-22		Direct	Indirect	Total
May - August Multiplex	30.3	60.3	381,300	202,055	247,845	449,900
Distributed	7.7		443,169	24,895	288,060	312,954
Difference						136,046
Nov - Feb Multiplex	30.3	60.3	234,960	202,055	152,724	354,779
Distributed	7.7		255,600	24,895	164,034	188,929
Difference						165,850
Multiplex leak rate estimated at 20%/yr						
Distributed leak rate estimated at 5%/yr						

Field Test Results for the Water-Source Heat Pumps

Space Heating Performance (November 2001 - February 2002)

	Average Heat Recovered (kW)	Average Space Heat Load (kW)	Heat Pump Energy (kWh)	Gas Displaced (m ³)
November 01	72.7	95.6	17,236	8,076
December 01	86.0	111.7	20,531	9,807
January 02	88.5	115.7	21,004	10,080
February 02	90.0	118.6	20,295	9,383
Total			79,066	37,346

Amount of heat recovered estimated at 25.9% of total refrigeration system heat rejection during the period. The heat pumps could recover up to about 60% of the rejected heat.