2. To: (Receiving Organization) Distribution		3. From: (Originating Organization) SNF CVD Project		4. Related EDT No.: N/A							
5. Proj./Prog./Dept./Div.: SNF Project W-441		6. Design Authority/Design Agent/Cog. Engr.: G. Singh		7. Purchase Order No.: N/A							
8. Originator Remarks: Initial Release - The design verification method for SS/SC components is by independent review in accordance with EN-6-027-01. Documentation of this review is accomplished by the independent reviewer approval signature on page 1 of this EDT.				9. Equip./Component No.: N/A							
				10. System/Bldg./Facility: 142K/CVDF							
				12. Major Assm. Dwg. No.: N/A							
				13. Permit/Permit Application No.: N/A							
11. Receiver Remarks: N/A		11A. Design Baseline Document? ☐ Yes ☒ No		14. Required Response Date:							
USQ NO. CVD-00-0227908 4/26/00											
15. DATA TRANSMITTED											
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	(F) Approval Designator	(G) Reason for Transmittal	(H) Originator Disposition	(I) Receiver Disposition			
1	SNF-6263	N/A	0	Diesel Generator Control Panel Components: Wiring , Terminals	S ^N Q	2	1	NA			
16. KEY											
Approval Designator (F)		Reason for Transmittal (G)			Disposition (H) & (I)						
E, S, Q, D OR N/A (See WHC-CM-3-5, Sec. 12.7)		1. Approval 2. Release 3. Information 4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)			1. Approved 2. Approved w/comment 3. Disapproved w/comment 4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged						
17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN
2	1	Design Authority	G. Singh	4/25/00				See Distribution			
		Design Agent									
2	1	Cog. Eng.	C. Van Katwijk	4/26/00							
2	1	Cog. Mgr.	T. Choho	4/26/00							
2	1	QA	H. Chafin	4/26/00		*		Approval for C.S. Hallen		4/26/00	
2	1	Safety	J. Brehm	4/26/00		*		Approval authorizes parallel preparation			
2	1	Ind. Reviewer	JH Bussell	4/26/00				of USQ screen w/implementation of 221P			
18. Signature of EDT Originator		19. Authorized Representative for Receiving Organization		20. Design Authority/Cognizant Manager		21. DOE APPROVAL (if required)					
T. Nuxall		T. Choho		G. Singh		Ctrl No. _____					
Date		Date		Date		☐ Approved					
						☐ Approved w/comments					
						☐ Disapproved w/comments					

SNF-6263
Revision 0

Diesel Generator Control Panel Components: Wiring, Terminals

Prepared for the U.S. Department of Energy
Assistant Secretary for Environmental Management

Project Hanford Management Contractor for the
U.S. Department of Energy under Contract DE-AC06-96RL13200

Fluor Hanford

P.O. Box 1000

Richland, Washington

Diesel Generator Control Panel Components: Wiring, Terminals

Carl Van Katwijk
Fluor Hanford, Inc.

Date Published
April 2000

Prepared for the U.S. Department of Energy
Assistant Secretary for Environmental Management

Project Hanford Management Contractor for the
U.S. Department of Energy under Contract DE-AC06-96RL13200

Fluor Hanford

P.O. Box 1000
Richland, Washington

Release Approval Date 4/26/00

EDT-629023
10 total pages.

TRADEMARK DISCLAIMER

Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

This report has been reproduced from the best available copy. Available in paper copy and microfiche.

Available electronically at <http://www.doe.gov/bridge>. Available for a processing fee to the U.S. Department of Energy and its contractors, in paper, from:
U.S. Department of Energy
Office of Scientific and Technical Information
P.O. Box 62
Oak Ridge, TN 37831-0062
phone: 865-576-8401
fax: 865-576-5728
email: reports@adonis.osti.gov(423) 576-8401

Printed in the United States of America

SNF-6263, TWO
10 total pages.

Commercial Grade Item Upgrade Dedication Form

SNF-6263, Rev. 0

ECN No. N/A CGI No. CGI-SNF-D-20-1-C1-066

Page 1 of 8

Title: **Diesel Generator Control Panel - Wiring, terminals****Section 1 Part Information**

Item No.: N/A	Manufacturer: N/A	Supplier: N/A
Mfg. Part/Model No.: N/A	Supplier's P/N: N/A	
Part Description: N/A		
End Use Description: N/A		

Section 2a Component Information

Equipment No.: Diesel Generator Control Panel Components: Wiring and cable, Terminals	Specification No.: W-441-C1, W-379 SNF/CSB spec for Diesel Generator	Manufacturer: Therm-O-Link Inc. & Panduit Corp.	Past P.O. No.: N/A
Procurement and/or Model No.: Wiring and cable: SIS-12-65-T	Equipment Supplier (if different from manufacturer): N/A		Equip. Supplier's Part No.: N/A

Component Description: **Diesel Generator Control Panel - electrical distribution materials****Section 2b Commercial Availability of the Item**

1. Is the Item available from a catalogue from a qualified NQA1 supplier or ISO 9000 supplier (coordinate with project CGI interface Engineer or BTR)? ☐ YES (go to #2 below) ☒ NO (go to procedure step 6.3.2, proceed to dedicate Item)
If not available from a qualified NQA1 supplier, is it available from an ISO 9000 supplier? (coordinate w/ project CGI Interface Engineer or BTR): ☐ YES (go to #2 below, dedicate Item) ☒ NO (dedicate Item)

2. List of Candidate qualified suppliers or ISO 9000 suppliers: **N/A**1. Recommended Procurement Strategy (coordinate with project CGI interface Engineer or BTR): **N/A****Section 2c CGI Determination**

CGI Determination Questions:

#1: Is the Item subject to design or specification requirements that are unique to nuclear facilities or activities?

☐ YES (the Item is not commercial grade) ☒ NO (continue)

#2: Is the Item used in applications other than nuclear facilities or activities?

☐ NO (the item is not commercial grade) ☒ YES (continue)

#3: Is the Item ordered from manufacturer/supplier on the basis of specifications set forth in the manufacturer's catalog?

☐ NO (the item is not commercial grade) ☒ YES (continue)☒ All three criteria have been satisfied. The Item meets the definition of commercial grade.**Section 2d Reason for Dedication**

The above Commercial Grade (CG) described Item is being Dedicated for use in the application cited for the following reason(s):

	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.
	Item is being purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.
	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Class application.
X	Item was purchased from a non-ESL manufacturer supplier as CG to be used in a Safety Significant application.
	Other ('like-for-like', similar, substitution, replacement evaluation)

Commercial Grade Item Upgrade Dedication Form

SNF-6263, Rev. 0

ECN No. N/ACGI No. CGI-SNF-D-20-1-C1-066

Page 2 of 8

Title: Diesel Generator Control Panel - Wiring, terminals

Section 3 Failure Effects Evaluation

A. Part/Component Safety Function:

1. **Provide power supply to instruments and signal channels from safety related instruments in the control panel that provides and maintains standby electrical power to the Cold Vacuum Drying Facility.**

B. Part/Component Functional Mode:

Safety Function #1:	☐	Active	☒	Passive
Safety Function #2:	☐	Active	☐	Passive
Safety Function #3:	☐	Active	☐	Passive

Active - Mechanical or Electrical change of state is required to occur for the component to perform its safety function

Passive - Change of state is not required for the component to perform its safety function

C. Host Component Safety Function (if applicable): N/A

1.

D. Failure Mode(s) and the effects on component or system safety function (see Worksheet 1):

1. **Fracture, material fatigue, insulation breakdown or loose connection leads to wiring short/open circuit and loss of signal channel.**

Section 4 Environmental & Natural Phenomena Hazard Design

Environmental Qualification Required:

Yes ☐No ☒**Environmental Condition A**

If yes: Environmental Qualification Requirements

Limiting Environmental Conditions:

Required Safety Functions:

Qualification Period:

Natural Phenomena Hazard (NPH) Design Required:

Yes ☒No ☐**HNF-PRO-97, Rev. 0, W-441-C1**

If yes: NPH Design Requirements

Performance Category: **PC-2**

NPH Design Req'ts.:

Required Safety Functions: **Seismic 3/1 Protection for adjacent SS SSCs - Containment**

Section 5 Component Functional Classification

Safety Class (SC)

General Service

☒

Safety Significant (SS)

If part/component classification is different from host component/system, document basis. **N/A**

Sections 6 and 7 (Reserved)

Section 8 References (for Functional Classification)

National Codes/Standards: **NEC**Safety Analysis Report (SAR): **HNF- 3553, Rev. 0/Annex B**Drawings: **H-1-83978, Sht. 2, O/M Manual (Nutherm DWG. 59723)**Vendor Manual/Manufacturer/Supplier Information: **Catalog Cut Sheets - Therm-O-Link Inc. Panduit Corp.**

Commercial Grade Item Upgrade Dedication Form

SNF-6263, Rev. 0

ECN No. N/A

CGI No. CGI-SNF-D-20-1-C1-066

Page 3 of 8

Title: **Diesel Generator Control Panel - Wiring, terminals**

Section 9 Critical Characteristics

Critical Characteristics	Acceptance Criteria/Tolerances	Acc.Method	ID	Function
Wiring/Cable:				
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Therm-O-Link, Inc.	1, IN	X	
Model Number, Size	SIS-12-65-T	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
SIS-12-65-T; Markings, O.D., No. of Strands, material	UL12 ga. SIS 90°C 600V, Nominal 0.162", 65 strand, tinned conductor	1, IN	X	
Terminals:				
1. Item Identification Critical Characteristics (necessary for reasonable assurance that the Item delivered is the Item specified)				
Manufacturer	Panduit corp.	1, IN	X	
Model No.	PN10-10R	1, IN	X	
2. Physical Critical Characteristics (for reasonable assurance that the Item delivered is the Item specified)				
PN10-10R; Terminal Stud size/ Color code/ Nominal dimensions "A" & "W", / rating	10 / Yellow / Nominal 1.08 inch, 0.38inch / 600V, ≥ 90°C	1, IN	X	
All items:				
3. Performance Critical Characteristics (for reasonable assurance that the Item will perform its intended safety function(s))				
Environmental	Note 1			
Seismic Condition A	Note 2			
Notes and Legend:		Acceptance Method:		
1. These materials are not subject to degradation at 60°F and 40% RH or 75°F and 25% RH and are suitable for Condition A Application.		1. Special Test and Inspection		
2. Maintain critical function before and after Seismic event. Seismic certification does not apply to wiring and terminals. Wiring installation has been seismically certified by analysis (Ref. Nutherm Report #7713-SCE submittal W-379-1015)		1, IN for Inspection 1,T for Test		
		2. Commercial Grade Survey		
		3. Source Verification		
		4. Vendor/Item History		

Section 10 Initial Review and Approval

Approvals:

Designated Engineer

C. van Kleeberg 4/26/00

QA Engineer:

Harold M. Chapin 4/26/00

Design Authority:

AS 4/26/00

Other:

4/26/00

Commercial Grade Item Upgrade Dedication Form

SNF-6263, Rev. 0

ECN No. N/A

CGI No. CGI-SNF-D-20-1-C1-066

Page 4 of 8

Title: **Diesel Generator Control Panel - Wiring, terminals**

WORKSHEET 1

DETERMINATION OF FAILURE MECHANISMS

Section 1			
Typical Failure Mechanisms	Definition	X = Applicable to Component under Evaluation X?	Indicate Failure Mode
Fracture	Separation of a solid accompanied by little or no macroscopic plastic deformation.	X	Fracture or material fatigue-loss of signal channel provided by the wiring
Corrosion	The gradual deterioration of a material due to chemical or electrochemical reactions, such as oxidation, between the material and its environment.	X	Deterioration of the insulation resulting in a short and loss of power.
Erosion	Destruction of materials by the abrasive action of moving fluids, usually accelerated by the presence of solid particles carried with the fluid.		
Open Circuit	An electrical circuit that is unintentionally broken so that there is no complete path for current flow.	X	An unintentional break of the wire would result in a loss of power.
Short Circuit	An abnormal connection by which an electrical current is connected to ground, or to some conducting body, resulting in excessive current flow.	X	An unintentional connection to ground would result in a loss of power.
Blockage	Clogging of a filtering medium resulting in the inability to perform its purification function or blockage of flow.		
Seizure	Binding of a normally moving item through excessive pressure, temperature, friction, jamming.		
Unacceptable Vibration	Mechanical oscillations produced are beyond the defined permissible limits due to unbalancing, poor support, or rotation at critical speeds.		
Loss of Properties	A loss of mechanical and physical properties of a material due to exposure to high temperatures, radiation exposure.		
Excess Strain	Under the action of excessive external forces the material of the part has been deformed or distorted.		
Mechanical Creep	From prolonged exposure to high temperature and stress, the object will show a slow change in its physical (shape and dimension) and mechanical characteristics.		
Ductile Fracture	Fracture characterized by tearing of metal accompanied by appreciable gross plastic deformation.		
Section 2 Additional Failure Modes Applicable to the Component Under Evaluation			
1. Structural Failure that affects neighboring SS or SC SSCs.			

Commercial Grade Item Upgrade Dedication Form

SNF-6263, Rev. 0

ECN No. N/A CGI No. CGI-SNF-D-20-1-C1-066

Page 5 of 8

Title: **Diesel Generator Control Panel - Wiring, terminals****Checklist 1 – Acceptance Method 1 – Special Test/Inspection Verification**

SECTION 1	
Item Description: Diesel Generator Control Panel System #: 20-6	Equip #: DG Cntl. Pnl. Components: Wiring and cable, Terminal Procurement and/or Model #: SIS-12-65-T , PN10-10R
Manufacturer (Address/Phone): Therm-O-Link Inc. & Panduit	Supplier (Address/Phone):

SECTION 2 CRITICAL CHARACTERISTICS TO BE VERIFIED BY METHOD 1.

Insp	Test	Post-Test	
X			1. Manufacturer
X			2. Model Number
X			3. Markings, O.D., No. of strands, material
X			4. Terminal Stud size/ Color code/ Nominal dimensions "A" & "W" / rating

SECTION 3 BY INSPECTION * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)**Wiring/Cable:**

Characteristic: Manufacturer Acceptance Criteria: Therm-O-Link Inc.	Receipt Inspection Plan / Report #:	Sample Size*: 100%
Characteristic: Markings, Model Number, Size, No strands, material Acceptance Criteria: UL, SIS-12-65-T, 90°C 12 ga, 65 strand, tinned conductor	Receipt Inspection Plan / Report #:	Sample Size*: 100%
Characteristic: Acceptance Criteria	Receipt Inspection Plan / Report #:	Sample Size*: 100%

Termination:

Characteristic: Manufacturer Acceptance: CriteriaPanduit	Receipt Inspection Plan / Report #:	Sample Size*: 100%
Characteristic: Model Number, Terminal size, Color code, Nominal dimensions "A" & "W", rating Acceptance Criteria: PN10-10R, 10, yellow, 1.08" & 0.38, 600V, ≥ 90°C	Receipt Inspection Plan / Report #:	Sample Size*: 100%
		Sample Size*: 100%

Section 4 By Special Test * See Attachment H, Table H-1 of Desk Instruction for Sampling Size; References (See Section 7)

Characteristic for Test:	Samp Size*: ☒ Normal ☐ Reduced ☐ Tightened
Acceptance Criteria:	
Actual Test Value:	Test Plan and Report #:

**If Supplier/Manufacturer or Other, Refer to CGI Checklist-2 for Support Information

4/26/00

Commercial Grade Item Upgrade Dedication Form

SNF-6263, Rev. 0

ECN No. N/A CGI No. CGI-SNF-D-20-1-C1-066

Page 6 of 8

Title: Diesel Generator Control Panel - Wiring, terminals

Section 5 Test / Inspection Summary (Acceptance Method 1)

1. Summary Of Verified Critical Characteristics, Their Verification Methods, and Results

ITEM DESCRIPTION: Wiring and Cable					Verification Results						
Critical Characteristics			Critical Characteristics				Verification Results				
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/IN	Procedure or RQ#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Therm-O-Link, Inc.	X		1, IN							
Model No., Size, Type	SIS-12-65-T, 12 ga. SIS	X		1, IN							
SIS-12-65-T: Markings, O.D., No. of Strands, material	UL, SIS, 12ga, 0.162, 65 strand, tinned conductor, 90°c 600V	X		1, IN							

2. Disposition Of Unverified or Failed Critical Characteristics

Critical Characteristic	Disposition

3. Signature Indicates All Critical Characteristics Verified Satisfactory or Acceptably Dispositioned and Commercial Grade Dedication Is Satisfactory and Complete.

Testing Agency Approval: _____	Design Authority: _____	Date _____
Testing Agency QA Engineer: _____	QA Engineer: _____	Date _____

Commercial Grade Item Upgrade Dedication Form

SNF-6263, Rev. 0

ECN No. N/A CGI No. CGI-SNF-D-20-1-C1-066

Page 7 of 8

Title: Diesel Generator Control Panel - Wiring, terminals

Section 5 Test / Inspection Summary (Acceptance Method 1)											
1. Summary Of Verified Critical Characteristics , Their Verification Methods, and Results											
ITEM DESCRIPTION: Disconnect Switch											
Critical Characteristics					Verification Results						
Critical Characteristics	Acceptance Criteria/Tolerances	ID	Function	Method T/IN	Procedure or RR#	Check-list ID	Number Tested	Number Failed	Verifying Organization	Printed Name Signature	Date
Manufacturer	Panduit	X		1, IN							
Model No.	PN10-10R	X		1, IN							
PN-10-10R; Terminal stud size, Color code, dimensions "A" & "W"	10, yellow, Nominal 1.08 inch, 0.38 inch,	X		1, IN							
2. Disposition Of Unverified or Failed Critical Characteristics										Disposition	
Critical Characteristic											
Verify documentation for terminal rating for 600V ≥ 90°C											
3. Signature Indicates All Critical Characteristics Verified Satisfactory or Acceptably Dispositioned and Commercial Grade Dedication Is Satisfactory and Complete.											
Testing Agency Approval:					Design Authority:			Date		Date	
Testing Agency QA Engineer:					QA Engineer:			Date		Date	

Commercial Grade Item Upgrade Dedication Form

SNF-6263, Rev. 0

ECN No. N/A CGI No. CGI-SNF-D-20-1-C1-066

Page 8 of 8

Title: **Diesel Generator Control Panel - Wiring, terminals****Section 6 Contacts / Phone Numbers**

Title	Name	Phone
Design Authority		
QA		
QC		
Cog - Engineer		
CGI Engineer	Carl van Katwijk	376-9385
Procurement Engineer		
Other		

Section 7 Supporting Documentation for This Checklist

Initial Procurement Documents		For Critical Characteristics
☐	Drawings:	
☐	Manuals (specify type & number):	
☐	Design Calculations	
☐	Installation Instructions	
☐	Operation Instructions	
☐	Calibration Instructions	
☐	Manufacturer's Recommended Spare Parts List	
X	Other: : Catalog Cut Sheets Therm-O-Link and Panduit	All
Procurement Documents		
☐	Certificate of Conformance/Compliance	
☐	Seismic Qualification Certificate	
☐	Environmental Qualification Certificate	
☐	Test Report (s):	
☐	Inspection Report (s):	
☐	CMTRs for ASME Pressure Retaining Materials	
☐	Valve Seat Leakage Report	
☐	Weld Records	
☐	Material Traceability Record	
☐	Other:	

DISTRIBUTION SHEET

To Distribution	From SNF-CVD	Page 1 of 1
Project Title/Work Order W-441, CGI Package		Date 4/25/00
		EDT No. 629023
		ECN No. N/A

[illegible]