QA: QA

TDR-WER-NU-000002 REV 00 ICN 01 |

December 2001 |

Subsurface Contamination Control

By
YuChien Yuan

Prepared for:
U.S. Department of Energy
Yucca Mountain Site Characterization Office
P.O. Box 30307
North Las Vegas, Nevada 89036-0307

Prepared by:
Bechtel SAIC Company, LLC
1180 Town Center Drive
Las Vegas, Nevada 89144

Under Contract Number
DE-AC08-01RW12101

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor any of their contractors, subcontractors or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or any third party's use or the results of such use of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Prepared by:

Y. Yvan
Subsurface Facilities, BSC

12/12/01
Date

Checked by:

M.N. Haas
Subsurface Facilities, BSC

12/12/01
Date

Approved by:

R. Boutin, Manager
Subsurface Facilities, BSC

12/12/01
Date

CHANGE HISTORY

<u>Revision Number</u>	<u>Interim Change No.</u>	<u>Effective Date</u>	<u>Description of Change</u>
00	00	11/16/01	Initial issue.
00	01	12/30/01 12/21/01 01/07/02	A unit typo has been corrected on p. 24.

INTENTIONALLY LEFT BLANK

CONTENTS

	Page
ACRONYMS AND ABBREVIATIONS	x
1. OBJECTIVE AND SCOPE	1
2. QUALITY ASSURANCE	3
3. METHOD	5
3.1 METHODOLOGY FOR LRCL DERIVATION	5
3.1.1 Equations	5
3.1.2 ALARA Requirements	7
3.2 METHODOLOGY FOR RELEASE ESTIMATE AND ITS DETECTABILITY	8
3.2.1 WP Leakage Model	8
3.2.2 Release Detectability	9
4. DESIGN INPUTS	11
4.1 DESIGN PARAMETERS	11
4.1.1 Emplacement Drift Ventilation Parameters	11
4.1.2 WP Design Parameters for Release Estimates	11
4.1.3 Radiological Parameters	11
4.1.4 Gas Properties	12
4.1.5 Minimum Levels of Detectability	13
4.1.6 Constants and Conversion Factors	13
4.2 ASSUMPTIONS	14
4.2.1 Pathway of Exposure	14
4.2.2 Particle Deposition	14
4.2.3 WP Fill Gas	14
4.2.4 Receptor Locations	14
4.2.5 Atmospheric Dispersion Factors (χ/Q)	15
4.2.6 Resuspension Rate	15
4.2.7 Respirable Fraction	15
4.2.8 Repository Worker Work Hours	15
4.2.9 Average Number of Workers during Emplacement Phase	15
4.2.10 WP Surface Area	16
4.2.11 WP Leakage Path Length	16
4.2.12 WP Internal Temperature	16
4.2.13 Average Annual WP Emplacement Rate	16
4.2.14 Access Main Ventilation Rate	16
4.2.15 Shaft Exhaust Ventilation Rate	17
4.2.16 Release Evaluation Source Terms	17
4.2.17 Release Fractions	18
4.2.18 Leakpath Factor	19
4.2.19 Radioactive Decay from WP Surface Contamination	19

4.2.20	Barometric Pressure	19
4.3	CRITERIA	20
4.4	CODES AND STANDARDS	20
4.4.1	10 CFR 20	20
4.4.2	49 CFR 173.443 Contamination Control	21
4.4.3	ANSI N14.5-97. 1998	21
4.4.4	ANSI N42.18-1980. 1985	21
4.4.5	10 CFR 63 (66 FR 55732)	21
5.	USE OF COMPUTER SOFTWARE AND MODELS	22
6.	ANALYSIS	24
6.1	DERIVATION OF LRCL	24
6.1.1	Single-Radionuclide LRCL	24
6.1.2	ALARA Evaluation	25
6.1.2.1	Offsite Maximum Individual Dose	25
6.1.2.2	Worker Dose	26
6.1.2.3	Total Collective Worker Dose	27
6.2	WP RELEASE AND ITS DETECTABILITY	28
6.2.1	Example 1: Leak-tight Hole Diameter	28
6.2.2	Example 2: WP Internal Pressure	29
6.2.3	Example 3: WP Leakage Rate	29
6.2.4	Example 4: Radionuclide Concentration and Detectability	31
7.	CONCLUSIONS	33
7.1	DERIVED LRCL	33
7.2	POTENTIAL WP LEAK AND ITS DETECTABILITY	33
8.	REFERENCES	36
8.1	DOCUMENTS CITED	36
8.2	CODES, STANDARDS, REGULATIONS	38
8.3	PROCEDURES	38
APPENDIX A – CALCULATION OF AVERAGE 21-PWR SOURCE TERMS		A-1
APPENDIX B – DETERMINATION OF WP LEAK-TIGHT HOLE DIAMETER		B-1
APPENDIX C – CALCULATION OF WP INTERNAL PRESSURE		C-1
APPENDIX D – CALCULATION OF 21-PWR WP LEAKAGE RATE		D-1
APPENDIX E – CALCULATION OF RADIONUCLIDE CONCENTRATIONS IN RAISE		E-1

FIGURES

	Page
1. WP Leakage Rate as a Function of Hole size and Temperature	30

TABLES

	Page
1. Airborne Effluent Limits and Derived Air Concentrations	12
2. Gas Properties	12
3. Viscosity of Helium	13
4. Minimum Levels of Detectability	13
5. Radionuclide Source Terms for Release Evaluation	18
6. SourceTerm Release Fractions by Radionuclide Group	19
7. Derivation of LRCL	25
8. Worker ALARA Dose Calculation	27
9. Air Leakage Rates (cm ³ /s) under Reference Conditions	28
10. WP Internal Pressure (Pa) as a Function of Temperature and % Fuel Rupture	29
11. 21-PWR WP Leakage Rates	30
12. Estimated Radionuclide Concentration in Raise	32

INTENTIONALLY LEFT BLANK

ACRONYMS AND ABBREVIATIONS

ALARA	As Low As is Reasonably Achievable
ANSI	American National Standards Institute
AP	Administrative Procedure
BSC	Bechtel SAIC Company, LLC
CEDE	committed effective dose equivalent
LRCL	Limiting Radioactive Contamination Levels
CRWMS M&O	Civilian Radioactive Waste Management System Management and Operations
DAC	Derived Air Concentration
DOE	U.S. Department of Energy
ECL	effluent concentration limits
MGR	Monitored Geologic Repository
MLD	Minimum Level of Detectability
NRC	U.S. Nuclear Regulatory Commission
PWR	Pressurized Water Reactor
TBV, TBD	to-be-verified, to-be-determined
TEDE	total effective dose equivalent
WP	Waste Package

UNITS OF MEASURE

Atm abs	Atmosphere absolute
Bq	Becquerel
Ci	Curie
cm	centimeter
°C	degree Celsius (Centigrade)
cP	centiPoise
d	day
dpm	disintegrations per minute

UNITS OF MEASURE (continued)

g	gram
hr	hour
J	Joule
km	kilometer
K	degree Kelvin
μCi	microCurie
μm	micrometer, micron
m	meter
M	Mole
mBar	millibar
mol	mole
mrem	millirem
MTU	metric tons uranium
MWd	megawatt-day
mSv	milliSievert
N	Newton
Pa	Pascal
pCi	picoCurie
rem	roentgen equivalent man
s or sec	second
yr	year
ref.cm ³ /s	Reference cubic centimeter per second: A volume of one cubic centimeter of dry air per second at 1 atmosphere absolute pressure and 25 °C.

INTENTIONALLY LEFT BLANK

1. OBJECTIVE AND SCOPE

There are two objectives of this report, “*Subsurface Contamination Control*”. The first is to provide a technical basis for recommending limiting radioactive contamination levels (LRCL) on the external surfaces of waste packages (WP) for acceptance into the subsurface repository. The second is to provide an evaluation of the magnitude of potential releases from a defective WP and the detectability of the released contents.

The technical basis for deriving LRCL has been established in *Retrieval Equipment and Strategy for WP on Pallet* (CRWMS M&O 2000g, 6.3.1). This report updates the derivation by incorporating the latest design information of the subsurface repository for site recommendation (see Subsections 4.2.14 and 4.2.15). The derived LRCL on the external surface of WPs, therefore, supercede that described in CRWMS M&O 2000g. The derived LRCL represent the average concentrations of contamination on the external surfaces of each WP that must not be exceeded before the WP is to be transported to the subsurface facility for emplacement.

The evaluation of potential releases is necessary to control the potential contamination of the subsurface repository and to detect prematurely failed WPs. The detection of failed WPs is required in order to provide reasonable assurance that the integrity of each WP is intact prior to MGR closure. An emplaced WP may become breached due to manufacturing defects or improper weld combined with failure to detect the defect, by corrosion, or by mechanical penetration due to accidents or rockfall conditions. The breached WP may release its gaseous and volatile radionuclide content to the subsurface environment and result in contaminating the subsurface facility. The scope of this analysis is limited to radioactive contaminants resulting from breached WPs during the preclosure period of the subsurface repository.

This report:

- Documents a method for deriving LRCL on the external surfaces of WP for acceptance into the subsurface repository.
- Provides a table of derived LRCL for nuclides of radiological importance.
- Provides an as low as is reasonably achievable (ALARA) evaluation of the derived LRCL by comparing potential onsite and offsite doses to documented ALARA requirements.
- Provides a method for estimating potential releases from a defective WP.
- Provides an evaluation of potential radioactive releases from a defective WP that may become airborne and result in contamination of the subsurface facility.
- Provides a preliminary analysis of the detectability of a potential WP leak to support the design of an airborne release monitoring system.

INTENTIONALLY LEFT BLANK

2. QUALITY ASSURANCE

The development of this report was conducted under the *Technical Work Plan for Subsurface Design Section FY01 Work Activities* (CRWMS M&O 2001); which was prepared in accordance with procedure AP-2.21Q, *Quality Determinations and Planning for Scientific, Engineering, and Regulatory Compliance Activities*. Specifically, it follows the work activities described in Subsurface Facility Lower Temperature Pre-closure Safety Support Work Package Number 12112124ML of the work plan in *Technical Work Plan for Subsurface Design Section FY 01 Work Activities* (CRWMS M&O 2001, p. 15). This activity has been evaluated in accordance with AP-SV.1Q *Control of the Electronic Management of Information*. The activity evaluation of this work package (CRWMS M&O 2001, pp. A-20 to A-21) has determined that the activities addressed in this report are subject to the requirements of the *Quality Assurance Requirements and Description* (DOE 2000, p. 2.2), since the radiological concerns addressed in this report generate data to be used to assess the potential dispersion of radioactive materials (CRWMS M&O 2001, p. A-21). This report is written in accordance with AP-3.11Q, *Technical Reports*.

The implementation of the recommended LRCL on the external surfaces of WPs concerns MGR radiological control/safety (AP-3.11Q, p. 11) as well as subsurface worker health and safety. Therefore, this report is subject to technical baseline change in accordance with items 5.2d 2) and 3) of AP-3.11Q. A Baseline Change Proposal (T2001-0153) has been prepared in accordance with AP-3.4Q, *Level 3 Change Control*.

INTENTIONALLY LEFT BLANK

3. METHOD

The methodologies used in the development of this report are detailed in the following Subsections. Subsection 3.1 presents the methodology used to derive the LRCL on the external surfaces of WPs for acceptance into the subsurface facility for emplacement. Subsection 3.2 presents the methodology used to evaluate the magnitude of potential releases from a breached WP and the detectability of the released contents.

3.1 METHODOLOGY FOR LRCL DERIVATION

The derivation of the LRCL on the external surface of waste packages is similar to that described in *Retrieval Equipment and Strategy for WP on Pallet* (CRWMS M&O 2000g, 6.3.1). Final Rule 10 CFR Part 63.111(a)(1) (66 FR 55732) requires that the geologic repository operations area to meet the requirements stated in Title 10 of the Code of Federal Regulations (CFR) part 20. 10 CFR 20.1101(d) requires a licensee to implement the ALARA requirements such that the individual member of the public likely to receive the highest dose will not be expected to receive a total effective dose equivalent (TEDE) in excess of 10 mrem (0.1 mSv) per yr from the air emissions. To estimate the highest dose to the individual member of the public, the release locations and the quantity of release from all MGR facilities are required. Since the total number of release points and their locations have not been determined, a conservative screening technique outlined in Regulatory Guide 4.20 *Constraint on Releases of Airborne Radioactive Materials to the Environment for Licensees Other Than Power Reactors* (1996) is used in this report to derive the LRCL. This screening technique, which is acceptable by NRC for demonstrating compliance with 10 CFR 20.1101(d), conservatively assumes that the air concentration at the boundary receptor is equal to the air concentration calculated at the point of release (Regulatory Guide 4.20 1996, Subsection 2.1). This is analogous to demonstrating that the annual average concentrations of radioactive material released in gaseous effluents at the location of the exhaust do not exceed the values specified in Table 2 of Appendix B to 10 CFR Part 20 which are the airborne effluent concentration limits (ECL). 10 CFR 20.1302(b)(2)(i) requires that the annual average concentrations of radioactive material released in gaseous effluents at the boundary of the unrestricted area do not exceed the ECL values (see Subsection 4.4.1).

3.1.1 Equations

The airborne release at the shaft exhaust due to contamination on WP surfaces may be derived based on the following parameters:

- A: The surface area of the average WP, (m^2)
- N: The average number of WPs emplaced per year, (1/yr)
- C_s : The initial contamination levels on the surface of WP, ($\text{dpm}/100 \text{ cm}^2$ or Ci/m^2)

The mass balance equation for WP surface contamination in the repository with respect to time resulting from emplacement operation is:

$$\frac{dC_R}{dt} = NC_s A - kC_R \quad (\text{Eq. 1})$$

where:

- C_R = time dependent surface contamination on the WPs
- k = $\lambda + \omega$
- λ = radioactive decay constant (1/yr)
- ω = re-suspension rate of the surface contamination (1/yr)

The solution for equation (1) at time t following the start of emplacement operation is:

$$C_R = \frac{NC_s A}{k} (1 - e^{-kt}) \quad (\text{Eq. 2})$$

Because the WP inventory in the repository builds up during emplacement operations, the WP surface contamination and the potential re-suspended release at the final year of operation will be at a maximum level. If T represents the last operation year, the potential re-suspended release per year during the final year of operation is:

$$R = NC_s A \frac{\omega}{k} (1 - e^{-kT}) \quad (\text{Eq. 3})$$

Based on the above equation the maximum value of R occurs when T approaches a very large number and if radioactive decay is negligible (Subsection 4.2.19) or:

$$R = NC_s A \quad (\text{Eq. 4})$$

The average annual concentration at a receptor location, C_a (Ci/m³), conservatively assuming little or no deposition of released material from the WPs to the exhaust shaft (Assumption 4.2.2), may be calculated as:

$$C_a = 3.17 \times 10^{-8} \sum_i^M R_i (\chi/Q)_i \quad (\text{Eq. 5})$$

- where: M = total number of release points
- $(\chi/Q)_i$ = atmospheric dispersion factor at a receptor from release point i , (s/m³)
- R_i = release from point i
- i = release point index
- 3.17×10^{-8} = conversion from second to year (s/yr)
- = $1/[365 \text{ (d/yr)} \times 24 \text{ (hr/d)} \times 3600 \text{ (s/hr)}]$

Eq.5 may be used to derive LRCL if R_i and $(\chi/Q)_i$ are known.

As described in Subsection 3.1, since the total number of release points and their locations have not been determined, a conservative screening technique provided by NRC in Regulatory Guide 4.20 (1996) is used to derive the LRCL. This screening technique conservatively assumes that

the air concentration at the site boundary receptor is equal to the air concentration calculated at the location of the exhaust. This is analogous to demonstrating that the annual average concentrations of radioactive material released in gaseous effluents at the location of the exhaust do not exceed the values of ECL.

At the ventilation exhaust shaft, the average annual concentration is:

$$C_a = R/V = (N C_s A)/V \quad (\text{Eq. 6})$$

where V is the ventilation flow rate in m^3/yr of the ventilation shaft exhaust and C_s represents the LRCL for all WPs.

Setting the exhaust concentration, C_a , to the effluent concentration limit, ECL, and solving for the LRCL or C_s , yields the following:

$$C_s = (\text{ECL} \times V)/(A \times N) \quad (\text{Eq. 7})$$

Equation (7) is derived for calculating a single-radionuclide LRCL. The approach used in deriving Eq. 7 is very conservative because the LRCL are applied equally to all WPs.

When applying the derived single-radionuclide LRCL for survey of a decontaminated WP, the sum-of-fractions rule may be applied (Regulatory Guide 4.20 1996, Subsection 2.2). That is, the summation of the fractional LRCL of radionuclides remaining on a WP should not be greater than unity, or

$$\sum_i \frac{C_i}{C_{s,i}} \leq 1 \quad (\text{Eq. 8})$$

where C_i is the average concentration of the i th nuclide on the surface of the WP and $C_{s,i}$ is the single-radionuclide LRCL derived for the i th nuclide.

The calculation of $C_{s,i}$ for radionuclides of radiological importance is made in Subsection 6.1.

3.1.2 ALARA Requirements

The ALARA requirements applicable to the derived LRCL are those outlined in the *Monitored Geologic Repository Project Description Document* (Curry, P.M. 2001, Subsections 5.3.3, 5.3.4 and 5.3.5). The specific requirements are presented in Subsection 4.3.

The applicable codes and standards and ALARA dose requirements stated by NRC are presented in Subsection 4.4.

To demonstrate that the derived LRCL will be ALARA, the annual offsite and onsite individual doses are estimated in Subsection 6.1.2 and compared with the applicable dose requirements (see Subsections 4.3 and 4.4.1). Dose estimates are made assuming that the average contamination level on the external surfaces of each WP is at the derived LRCL.

3.2 METHODOLOGY FOR RELEASE ESTIMATE AND ITS DETECTABILITY

This Section presents the methodology used to estimate the amount of radioactive material that may be released from a breached WP and its detectability during the preclosure period. The methodology for estimating release is based primarily on the container leakage model described in *American National Standard for Radioactive Materials — Leakage Tests on Packages for Shipment* (ANSI N14.5-97, 1998, Annex B). The model is presented in Subsection 3.2.1. The method used to evaluate release detectability is presented in Subsection 3.2.2 and is based on the ventilation design of the subsurface facility and the minimum levels of detectability (MLD) for radionuclides in gaseous effluent streams as specified by ANSI N42.18-1980 (1985, Table 1).

It should be recognized that the radioactive contents of a WP would be released into the environment only if they are first released to the WP interior voids and subsequently escaped from the voids to the external environment. This would require a breach of the WP outer barrier, inner shell and waste form container. Gas leakage through a small leak depends on properties of the gas and the characteristics of the leakage path. Pressure difference is the driving force for a WP leak. Release of suspended particles from the WPs is caused by particle entrainment in the escaping gas.

3.2.1 WP Leakage Model

This Subsection summarizes the leakage model provided by the ANSI (ANSI N14.5-97 1998, Annex B). The model is used in this report for estimating the leakage rate L (cm^3/sec) from a breached WP, or the pathway through the WP cavity to the external environment.

The equations described in ANSI N14.5-1997 (1998, pages 27-28) are modeled based on a straight circular tube leakage path and represent flow that is in the free molecular and/or continuum flow regimes.

The equations used by ANSI N14.5-1997 to estimate volume leakage rate from a container (or in this report, a WP) of releasable material inside the WP void are:

$$L = (F_c + F_m) (P_u - P_d) P_a / P_u \quad (\text{Eq. 9})$$

$$F_c = \frac{2.49 \times 10^6 D^4}{\alpha \mu} \quad (\text{Eq. 10})$$

$$F_m = \frac{3.81 \times 10^3 D^3 \sqrt{T/M}}{\alpha P_a} \quad (\text{Eq. 11})$$

where

- α = leakage hole length, cm
- μ = viscosity of the leaking gas, cP
- D = leakage hole diameter, cm
- T = fluid absolute temperature, K

M = molecular weight, grams per mole
P_a = average stream pressure = $0.5(P_u + P_d)$, atm abs
P_u = fluid upstream pressure, atm abs
P_d = fluid downstream pressure, atm abs
L = volumetric leakage rate, cm³/s
F_c = coefficient of continuum flow conductance per unit pressure, cm³/atm-s
F_m = coefficient of free molecular flow conductance per unit pressure, cm³/atm-s

3.2.2 Release Detectability

The method used in this report to evaluate detectability of released material is based on the ventilation design of the subsurface facility and the MLD for radionuclides in gaseous effluent streams as specified by ANSI N42.18-1980 (1985, Table 1). The MLDs specified by the ANSI N42.18-1980 are applicable for instruments designed to continuously monitor radioactivity in gaseous effluent streams. The sensitivity of using air samples to detect potential leaks is evaluated by comparing the released concentrations to the MLD for radionuclides in gaseous effluent streams. The radionuclide concentrations in the effluent streams are estimated based on the gaseous leakage rates, the WP radioactive contents, the release fractions, and the subsurface ventilation flow rates. The input parameters used in this report for evaluating release detectability are included in Subsection 4.

INTENTIONALLY LEFT BLANK

4. DESIGN INPUTS

All technical product input and sources of the input used in the development of this report are documented in this section. The qualification status of the input is indicated in the Document Input Reference System database in accordance with AP-3.15Q, Rev 3, ICN 0, *Managing Technical Product Inputs*.

4.1 DESIGN PARAMETERS

The design parameters used in this report are identified and provided in the following Subsections. All of the following parameters are used either in Section 6 or the Appendices.

4.1.1 Emplacement Drift Ventilation Parameters

The emplacement drift and raise ventilation airflow rates are taken from *Site Recommendation Subsurface Layout* (BSC 2001b) and are provided as follows:

- Emplacement Drift airflow rate: $15 \text{ m}^3/\text{s}$ (BSC 2001b, Subsection 6.2.4.2)
- Emplacement Raise airflow rate: $2 \times 15 \text{ m}^3/\text{s} = 30 \text{ m}^3/\text{s}$ (BSC 2001b, Subsection 6.2.4.2)

4.1.2 WP Design Parameters for Release Estimates

The 21-Pressurized Water Reactor (PWR) WP is used in Subsection 6.2 as a representative WP configuration for estimating source terms and potential releases. This WP configuration is appropriate because it represents the largest projected quantity of WP inventory (Curry, P.M. 2001, p. 5-9 and p. 5-10) to be placed in the repository. The design parameters associated with the 21-PWR WP configuration are provided as follows:

- Number of fuel rod per assembly: 208 (CRWMS M&O 2000f, p. III-3)
- Number of assembly per WP: 21 (CRWMS M&O 2000f, p. III-3)
- WP void volume: 4.38 m^3 (CRWMS M&O 2000f, p. III-3)
- PWR fuel rod void volume: 35 cm^3 (CRWMS M&O 2000f, p. III-3)
- Initial helium gas moles in WP void: 179.1 (CRWMS M&O 2000f, p. III-3)
- Initial helium gas moles in fuel rod void: 0.117 (CRWMS M&O 2000f, p. III-3).

4.1.3 Radiological Parameters

The LRCL are derived only for those radionuclides that were found to contribute collectively to more than 99% of the total effective dose equivalent from inhalation following a non-mechanistic design basis event. The specific calculation used to obtain the radionuclide lists is described in page 26 of the *Software Qualification Report for RSAC-5 Version 5.2 the Radiological Safety Analysis Computer Program* (CRWMS M&O 1998, p. 26). Table 1 lists the individual radionuclides selected, their airborne ECL (Column 1 of Table 2 of Appendix B to 10 CFR 20) and their derived air concentrations (DAC) (Column 3 of Table 1 of Appendix B to 10 CFR 20). Cs-137 is included because it has relatively high inventory in the spent nuclear

fuel. Gaseous radionuclides such as tritium and Kr-85 are excluded from the table because they would not be present as surface contamination on a WP. The airborne ECL represents the concentration, which if inhaled continuously over the course of a year, would produce a TEDE of 50 mrem (10 CFR 20, Appendix B). The ECL values are used in Subsection 6.1 to derive the LRCL. The DAC values are used in Subsections 6.1.2.2 and 6.1.2.3 to calculate repository worker doses.

Table 1. Airborne Effluent Limits and Derived Air Concentrations

	ECL ^a	DAC ^b
Radionuclide	Ci/m ³	Ci/m ³
Co-60	5×10^{-11}	1×10^{-8}
Sr-90	6×10^{-12}	2×10^{-9}
Cs-137	2×10^{-10}	6×10^{-8}
Pu-238	2×10^{-14}	3×10^{-12}
Pu-239	2×10^{-14}	3×10^{-12}
Pu-240	2×10^{-14}	3×10^{-12}
Pu-241	8×10^{-13}	1×10^{-10}
Am-241	2×10^{-14}	3×10^{-12}
Cm-244	3×10^{-14}	5×10^{-12}

NOTES: ^a Source: 10 CFR 20 Appendix B, Column 1 of Table 2. This column lists the "radionuclide concentrations which, if inhaled ... continuously over the course of a year, would produce a total effective dose equivalent (TEDE) of 50 mrem." For conservatism, the lowest or most restrictive listed values are used in this report.

^b Source: 10 CFR 20 Appendix B, Column 3 of Table 1. For conservatism, the lowest or most restrictive listed values are used in this report.

4.1.4 Gas Properties

The values of molecular weight (M) and viscosity (μ) for air and helium (at 298 K and 1 atm abs.) provided in ANSI N14.5-1997 (1998, p. 28) are reproduced in Table 2:

Table 2. Gas Properties

Gas Name	M (g-mol)	μ (cP)
Air	29	0.0185
Helium	4.0	0.0198

Source: ANSI N14.5-1997 (1998, p. 28)

The viscosity of gas at low-density range is dependent on temperature and not on pressure (Bird et al. 1960, p. 24). The viscosity (μ) of helium at 300, 350 and 500 °C calculated using the chart provided in Perry et al. (1984, p. 3-248) are provided in Table 3:

Table 3. Viscosity of Helium

Temperature (°C)	Viscosity (cP)
300	0.030
350	0.032
500	0.038

4.1.5 Minimum Levels of Detectability

The values of minimum level of detectability (MLD) in gaseous effluent streams provided by ANSI N42.18-1980 (1985, Table 1) are presented in Table 4. These MLDs are applicable for instruments designed to continuously monitor radioactivity in gaseous effluent streams.

Table 4. Minimum Levels of Detectability

Radionuclide	MLD ^a ($\mu\text{Ci}/\text{cm}^3$)
Co-60	8×10^{-11}
Kr-85	3×10^{-7}
Sr-90	4×10^{-12}
Cs-137	5×10^{-12}
Pu-238	2×10^{-12}
Pu-239	2×10^{-12}

NOTES: ^a Source: ANSI N42.18-1980 (1985, Table1)

4.1.6 Constants and Conversion Factors

The following constants and conversion factors are used in this report:

Gas-law Constant: $8.3144 \text{ J mol}^{-1} \text{ K}^{-1}$ (Source: Perry et al. 1984, p. 1-18)

1 Atmosphere (atm) = 101,325 Pa (or N/m^2) (Source: Perry et al. 1984, p. 1-15)

1 Bar = 0.9869 Atmosphere (atm) (Source: Perry et al. 1984, p. 1-15)

4.2 ASSUMPTIONS

All of the following assumptions are used either in Subsection 6.1 for the derivation of LRCL, or in Subsection 6.2, and the Appendices for the estimation of WP leakage rates and concentrations.

4.2.1 Pathway of Exposure

For ALARA offsite dose calculations, only inhalation doses are considered. The potential doses from external radiation exposure, ingestion, air and water immersion, and contaminated soil are not considered significant and are based on the dose calculation results of *Design Basis Event Frequency and Dose Calculation for Site Recommendation* (CRWMS M&O 2000b, p. 45) which states that the majority (more than 77%) of the total dose from Category 1 events is derived from the inhalation pathway.

This assumption is appropriate because the calculated dose is so low (see Subsection 6.1.2) that a rough estimate is sufficient to support the conclusions of the ALARA evaluations. This assumption is used in Subsection 6.1.

4.2.2 Particle Deposition

In airborne concentration calculations, no deposition is assumed. This assumption is appropriate because zero deposition is conservative in the absence of site-specific data. This assumption is used in Subsection 3.1.1. For potential deposition of suspended radioactive materials on the ground surface of the repository, it is assumed that the Radiation Protection Program of the repository will minimize the spreading of radioactive contamination between work areas and will maintain radiation exposures ALARA.

4.2.3 WP Fill Gas

Helium gas will be used to provide an inert atmosphere within the WP. This assumption is based on the current WP design requirement described in the *Uncanistered Spent Nuclear Fuel Disposal Container System Description Document* (BSC 2001c, Subsection 2.4.3) and is used in Section 6.2 for WP leakage calculations.

4.2.4 Receptor Locations

The maximum offsite public dose receptor is assumed to be at a distance of 8 km from the release point. The maximum onsite surface worker dose receptor is assumed to be at a distance of 100 m from the release point. These distances are conservative and are consistent with the distances used in the *Design Basis Event Frequency and Dose Calculation for Site Recommendation* (CRWMS M&O 2000b, p. 14). The average onsite surface worker dose receptor is assumed to be at a distance of 3000 m from the release point. This distance represents the minimum distance from a subsurface exhaust shaft to the Waste Handling Building and is estimated from Figure I-19 of the *Engineering Files for Site Recommendation* (CRWMS M&O 2000a, Figure I-19).

These assumed receptor locations are used in Subsection 6.1 for onsite worker and offsite public dose calculations.

4.2.5 Atmospheric Dispersion Factors (χ/Q)

The " χ/Q " value of 3.19×10^{-7} (s/m³) is conservatively based on the value at 7.5 km and is used in Subsection 6.1.2.1 to calculate the maximum offsite public dose at 8 km (Assumption 4.2.4). The " χ/Q " values of 4.77×10^{-4} (s/m³) and 1.23×10^{-6} (s/m³), respectively, are used in Subsection 6.1.2.1 to calculate the maximum surface worker dose at 100 m and the average surface worker dose at 3 km (Assumption 4.2.4). These " χ/Q " values are taken from *Calculations of Acute and Chronic "Chi/Q" Dispersion Estimates for a Surface Release* (CRWMS M&O 1999a, p. 23-24) and were calculated based on Yucca Mountain site-specific meteorological data. These factors are appropriate because they were calculated based on Yucca Mountain site-specific data and are the most conservative " χ/Q " values at the assumed receptor locations.

4.2.6 Resuspension Rate

It is assumed in the WP contamination resuspension calculations that the resuspension rate is 4×10^{-5} /hr. This resuspension factor is the bounding value recommended for aerodynamic entrainment of powders from unyielding surfaces for indoors or outdoors exposed to ambient conditions following an event (DOE 1994a, p. 5-7). This assumption is used in worker dose calculations presented in Subsection 6.1.2.

4.2.7 Respirable Fraction

It is assumed in the dose calculations that all released or suspended radioactive particles are respirable. This assumption is used in Subsection 6.1.2 for dose calculations and is appropriate because it yields the most conservative dose values.

4.2.8 Repository Worker Work Hours

The repository worker is assumed to spend full time (2,000 hr) at the repository site. This value is appropriate because it bounds the number of hours a typical worker will spend inside the repository. This assumption is used in Subsection 6.1.2.2 for worker dose calculations.

4.2.9 Average Number of Workers during Emplacement Phase

The average number of full time subsurface facility workers during the emplacement period is 90. This number is taken from the most recent conceptual design engineering file, *FEIS Update to Engineering File – Subsurface Repository* (CRWMS M&O 2000d, p. 6-13). The average number of full time surface facility workers during the emplacement period is 1305. This number is taken from *Repository Surface Design Engineering Files Report Supplement* (CRWMS M&O 2000i, Table 6-2.). These input values are appropriate because they represent the latest design information available and a rough estimate is sufficient to support the conclusions of the ALARA collective worker dose evaluation. These average worker numbers are used in Subsection 6.1.2.3 for collective worker dose calculations.

4.2.10 WP Surface Area

The WP surface area is assumed to be 32 m². This area was determined by comparison of projected WP inventory and surface areas of all WP categories to be placed in the repository (CRWMS M&O 2000g, p. 63). This surface area size is greater than 98% (CRWMS M&O 2000g, Table 3) of the projected WP inventory; therefore, it is conservative to use this value to derive the LRCL in Subsection 6.1.1.

4.2.11 WP Leakage Path Length

The WP leakage path length is assumed to be 7 cm. This length represents the combined length of the stainless steel inner cylinder thickness of 5 cm and an alloy 22 outer cylinder thickness of 2 cm (BSC 2001c, Criterion 1.2.1.4). This assumption is used in Subsection 6.2 and Appendix D for WP leakage rate calculations.

4.2.12 WP Internal Temperature

The WP internal temperatures are assumed to be 300, 350 and 500 °C for WP potential release calculations. The internal temperatures of 300 and 350 °C are used to calculate potential releases under normal conditions. The 500 °C is used to calculate releases from a hypothetical abnormal event: a short-term exposure to fire (BSC 2001c, Criterion 1.2.1.6). This assumption is used to provide a range of potential WP internal temperatures and pressures during the preclosure period and is consistent with the current WP temperature requirements (BSC 2001c, Criterion 1.2.1.6). These temperatures are appropriate because they demonstrate that a change in WP temperature would only produce a minor change in the calculated release and will not change the conclusions of the WP release analysis (see Subsection 6.2.3). This assumption is used in Subsection 6.2 and Appendices.

4.2.13 Average Annual WP Emplacement Rate

The average number of WPs emplaced annually is assumed to be 605. This number is taken from the assumption made in *Retrieval Equipment and Strategy for WP on Pallet* (CRWMS M&O 2000g, p. 21). It represents an upper bound estimate of the WP emplacement rate. This assumption is used in Subsection 6.1.

4.2.14 Access Main Ventilation Rate

The ventilation rate in the Access Main during normal operations is assumed to be 45.6 m³/s.

This ventilation rate is calculated based on the 1 m/s minimum airflow velocity for human access during normal operations assumed in *Site Recommendation Subsurface Layout* (BSC 2001b, Subsection 5.2.7.1). Using an Access Main diameter of 7.62 m (BSC 2001b, Subsection 6.3.2.1) the volumetric flow rate of: $1 \text{ m/s} \times 3.1416 \times 3.81^2 \text{ m}^2 = 45.6 \text{ m}^3/\text{s}$ is obtained. This assumption is used in Subsection 6.1.2.2.2 for subsurface worker dose calculations. This assumption is appropriate because it provides a conservative estimate for dilution of released material in the Access Main and therefore provides a conservative estimate of routine subsurface worker dose.

4.2.15 Shaft Exhaust Ventilation Rate

The Shaft Exhaust ventilation rate is assumed to be 715 m³/s. This ventilation rate is taken from *Overall Ventilation System Flow Network Calculation for Site Recommendation* (BSC 2001a, Subsection 5.1.4) and is used in Subsection 6.1 for deriving WP contamination limits. This assumption is appropriate because it represents the latest design of the repository for site recommendation.

4.2.16 Release Evaluation Source Terms

For WP release and detection evaluation, the average fuel source terms (fission gases, volatiles, and fuel particulates) are taken from *PWR Source Term Generation and Evaluation* (CRWMS M&O 1999b, Attachment X). These source terms are derived based on PWR fuel with 4% initial enrichment, 48 GWd/MTU burnup, and 25-year decay period (CRWMS M&O 1999b, p. 24). The maximum expected crud concentration, represented by Co-60, is 140 µCi/cm² at the time of discharge (ANSI N14.5-97 1998, p. 46). Using a conservative surface area of a single fuel assembly of 449,003 cm² (CRWMS M&O 1999b, p. 25) and a decay half-life of 5.271 yr taken from *Radioactive Decay Data Tables, A Handbook of Decay Data for Application to Radiation Dosimetry and Radiological Assessments* (Kocher, D.C. 1981, p. 78), the total quantity of crud (Co-60) is estimated to be 63 Ci per assembly at the time of discharge and 2.35 Ci at 25 years following discharge. The calculation of the radionuclide source terms in the average 21-PWR WP is provided in Appendix A. Table 5 lists the radionuclide source terms in the average PWR spent fuel assembly and the 21-PWR WP. The individual radionuclides listed in Table 5 are for release detection evaluations. The radionuclides selected are those radiologically important radionuclides listed in Table 1 and those also with specific minimum level of detectability (MLD) values provided by ANSI N42.18-1980 (1985, Table 1) (see Table 4). Kr-85 is included because it is an inert gas with relatively high inventory in the spent nuclear fuel. These isotopes are appropriate for evaluating WP release detectability since the source terms are representative of the fuel to be emplaced and the actual release would be dependent on the specific fuel which has failed and the time of release. These are used in Subsection 6.2 and Appendices D and E for leakage rate calculations.

Table 5. Radionuclide Source Terms for Release Evaluation

Nuclide	Avg PWR ^a Curies/ Assembly	Avg PWR ^b Curies/WP	Nuclide Totals	Avg PWR ^c Curies/ Assembly	Avg PWR ^b Curies/WP
Kr-85	1.13E+03	2.37E+04	Total Gases	1.24E+03	2.61E+04
Cs-137	4.11E+04	8.63E+05	Total Volatiles	6.83E+04	1.43E+06
Sr-90	2.72E+04	5.71E+05	Total Fines	3.24E+04	6.81E+05
Pu-238	2.29E+03	4.81E+04	Total Crud	2.35E+00	4.93E+01
Pu-239	1.77E+02	3.72E+03			
Co-60 (Crud)	2.35E+00 ^c	4.93E+01			

NOTES: ^aSource: (Appendix A, Table A-1).

^bAverage Curies per WP = Average Curies per Assembly x 21 Assembly.

^cAverage Crud per assembly = $140 (\mu\text{Ci}/\text{cm}^2) \times 449,003 (\text{cm}^2) e^{-(0.693/5.271) \times 25} \times 10^{-6} (\text{Ci}/(\mu\text{Ci}))$.

4.2.17 Release Fractions

The following assumptions are made consistent with the release fractions used in ANSI (ANSI N14.5-97 1998, p. 46) and the NRC (NRC 2000, p. 9-12):

- 3% of the fuel rods are assumed to develop cladding breaches that could cause the release of gases, volatiles, and particulates in the gap region. All radionuclides present in the fuel rod gap are assumed to be released in the event of a cladding breach.
- Of the total fuel assembly radioactive inventory, the following fractions are assumed to be present in the fuel rod gap:
 - 0.3 of fission gases
 - 2×10^{-4} for volatile materials
 - 3×10^{-5} for fuel particles.

For crud, 15% of the surface contamination is assumed to become loose from the fuel surfaces under normal conditions. All loose crud is assumed to be available for release.

Since the purpose is to evaluate the detectability of a defective WP leak, the release fractions under normal conditions assumed by the ANSI and NRC are used in this report (Subsection 6.2) to estimate the potential releases.

Table 6 summarizes the source term release fractions that are used to perform the WP release calculations in Subsection 6.2. The release fraction, except for crud, is a fraction of total nuclide inventory within a spent fuel rod, and is applicable only to the failed fuel rods in a WP.

Table 6. SourceTerm Release Fractions by Radionuclide Group

Radionuclide Group		Release Fraction ^a
Gases	Tritium (H-3)	0.3
	Noble Gas (Kr-85)	0.3
	Iodine (I-129)	0.3
Volatiles	Cesium (Cs-134, Cs-137)	2×10^{-4}
	Strontium (Sr-90)	2×10^{-4}
	Ruthenium (Ru-106)	2×10^{-4}
Crud	Cobalt (Co-60)	0.15 / 1.0 ^b
Fuel Fines	Particulates	3×10^{-5}

NOTES: ^aSource: (NRC 2000, Table 9.2) for all release conditions; (ANSI N14.5-97 1998, p. 46).

^bUse 0.15 for normal and off-normal conditions and 1.0 for accident conditions.

4.2.18 Leakpath Factor

A leakpath factor of 0.1 is assumed in calculating particulate radionuclide releases from a WP in Subsection 6.2. This leakpath factor represents the fraction of airborne particulate radionuclides that leaves a WP after the action of depletion mechanisms such as precipitation, gravitational settling of the released particulate material, or agglomeration, through the confinement barrier including partial plugging of the leak hole. The 0.1 leakpath factor is the recommended value in *Leakpath Factors for Radionuclide Releases from Breached Confinement Barrier* (CRWMS M&O 2000e, Section 6) for particulate source term released from a WP.

4.2.19 Radioactive Decay from WP Surface Contamination

Radioactive decay is assumed negligible in deriving LRCL in Section 3.1.1. This assumption is appropriate because it yields the most restrictive or the smallest LRCL.

4.2.20 Barometric Pressure

The barometric pressure inside the repository is assumed to be 890 mBars (or $890 \times 10^{-3} \times 0.9869 = 0.8783$ atm). This barometric pressure is based upon data presented in the *Ventilation System Radon Review* (CRWMS M&O 2000j, Figure 3). This assumption is appropriate because the data were taken from the Exploratory Studies Facility of the repository and the actual atmospheric pressure would be dependent on the weather condition at the time of release. This assumption is used in Appendix D for calculating potential WP leakage rates.

4.3 CRITERIA

Criteria applicable to this report are taken from the *Disposal Container Handling System Description Document* (CRWMS M&O 2000c) and the *Monitored Geologic Repository Project Description Document* (Curry, P.M. 2001).

The *Disposal Container Handling System Description Document* (CRWMS M&O 2000c, Subsection 1.2.1.8) requires that the system shall decontaminate the WP surface to less than (TBD-0169) dpm/100 cm² prior to delivery to the Waste Emplacement/Retrieval System.

The *Monitored Geologic Repository Project Description Document* (Curry, P.M. 2001, Subsections 5.3.3, 5.3.4 and 5.3.5) requires that

- For all workers entering radiological control areas of the repository, radiological exposure shall be maintained ALARA, in accordance with an approved radiological protection program.
- Any MGR system or process with an expected exposure to an individual exceeding 250 mrem/yr or an expected collective exposure exceeding 1 person-rem/yr TEDE, shall receive a formal assessment in accordance with the ALARA program.
- Any MGR system or process where the dose to an individual member of the public is expected to exceed 10 mrem/yr TEDE from air emissions shall receive a formal assessment in accordance with the ALARA program.

4.4 CODES AND STANDARDS

The following codes and standards appear in this report:

4.4.1 10 CFR 20

- 20.1302(b) requires that “A licensee shall show compliance with the annual dose limit in Sec. 20.1301 by (1) Demonstrating by measurement or calculation that the total effective dose equivalent to the individual likely to receive the highest dose from the licensed operation does not exceed the annual dose limit; or (2) Demonstrating that (i) The annual average concentrations of radioactive material released in gaseous and liquid effluents at the boundary of the unrestricted area do not exceed the values specified in Table 2 of Appendix B to Part 20.”
- 20.1101(d) requires that “To implement the ALARA requirements of Sec. 20.1101(b), and notwithstanding the requirements in Sec. 20.1301 of this part, a constraint on air emissions of radioactive material to the environment, excluding Radon-222 and its daughters, shall be established by licensees ... such that the individual member of the public likely to receive the highest dose will not be expected to receive a total effective dose equivalent in excess of 10 mrem (0.1 mSv) per year from these emissions.”

4.4.2 49 CFR 173.443 Contamination Control.

(Table 11) Non-Fixed External Radioactive Contamination-Wipe Limits.

Contaminant	Maximum permissible limits		
	Bq/cm ²	μCi/cm ²	Dpm/cm ²
Beta and gamma emitters and low toxicity alpha emitters	0.4	10 ⁻⁵	22
All other alpha emitting radionuclides	0.04	10 ⁻⁶	2.2

4.4.3 ANSI N14.5-97. 1998.

American National Standard for Radioactive Materials — Leakage Tests on Packages for Shipment, Annex B.

4.4.4 ANSI N42.18-1980. 1985.

Specification and Performance of On-Site Instrumentation for Continuously Monitoring Radioactivity in Effluents, Table 1.

4.4.5 10 CFR 63 (66 FR 55732)

63.111(a)(1) requires that the geological repository operations area must meet the requirements of 10 CFR Part 20.

5. USE OF COMPUTER SOFTWARE AND MODELS

The only computer software related to the development of this report is the qualified radiological safety analysis program RSAC-5 Version 5.2, CSCI: 30067 V5.2 (CRWMS M&O 1998). As described in Subsection 4.1.3, the result of a calculation performed in the *Software Qualification Report for RSAC-5 Version 5.2 the Radiological Safety Analysis Computer Program* (CRWMS M&O 1998, p. 26) was used as basis for selecting the radiologically important radionuclides. No other acquired or developed scientific software, as defined by AP-SI.1Q, *Software Management*, is used in this report.

Microsoft Excel 97, a spreadsheet computational software, was the only software used in this calculation. Excel was used for release and concentration calculations provided in Appendices A through E. Excel is a commercial spreadsheet program designed to assist in performing calculations. The program provides built-in mathematical functions together with user-defined formulas to automate the calculation process. Output values are automatically updated as input data are added or changed. The user-defined formulas for the spreadsheets provided in Appendices C & D are described in Subsection 3.2. The formulas used in spreadsheets for leakage rate calculations were verified in accordance with the procedure AP-SI.1Q to be working correctly by hand calculations. Microsoft Excel 97 is an exempt software product in accordance with Section 2.1, of AP-SI.1Q, *Software Management*.

The computer hardware used in this calculation is a DELL Precision 420 desktop personal computer (CRWMS-M&O Tag Number 117479).

INTENTIONALLY LEFT BLANK

6. ANALYSIS

6.1 DERIVATION OF LRCL

This Section derives the LRCL on the external surfaces of WPs for acceptance into the subsurface repository. The derived LRCL represent the concentration levels of radioactivity on the external surfaces of a WP that must not be exceeded before the WP is transported to the subsurface repository. The derivation of LRCL is based on the requirement that the annual average concentrations of radioactive material released at the repository shaft exhaust do not exceed the airborne ECL specified in Table 1 (see Subsection 3.1).

The LRCL, C_s (Ci/m²), are derived based on the methodology described in Subsection 3.1, applicable input parameters in Subsection 4.1, and applicable assumptions in Subsection 4.2. Specifically, Eq. 7 of Subsection 3.1 is used to calculate these C_s values:

$$C_s = (ECL \times V)/(A \times N) \quad (\text{Eq. 12})$$

where:

- A = surface area of the average WP = 32 m² (Subsection 4.2.10)
- V = ventilation flow rate from the exhaust shaft = 715 m³/s (Subsection 4.2.15)
- N = average number of WPs emplaced per yr = 605 /yr (Subsection 4.2.13)
- ECL = airborne effluent concentration limit (Table 1)

6.1.1 Single-Radionuclide LRCL

The single-radionuclide LRCL are calculated in Table 7 using Eq. 12 above. The calculated LRCL for radionuclides of radiological importance are listed in Table 7, columns (3) and (4), respectively, in $\mu\text{Ci}/\text{cm}^2$ and dpm/100 cm².

Table 7 lists the LRCL derived for individual radionuclides that are radiologically significant (see Subsection 4.1.3). The table can be extended to any other radionuclide of concern that may be present on the WP surface. Gaseous radionuclides such as tritium and Kr-85 are excluded from the table because they would not be present as surface contamination on a WP. The surface contamination limit derived for Co-60 is 1,300,000 dpm/100 cm². This limit may be applied to WPs contaminated with crud materials. The most restrictive LRCL for alpha and beta/gamma emitters present in Table 7 are 520 dpm/100 cm² (Am-214, Pu-238, Pu-239, and Pu-240) and 21,000 dpm/100 cm² (Pu-241), respectively. The 520 dpm/100 cm² limit derived for alpha emitters is about 2.4 times higher than the maximum permissible limits of 220 dpm/100 cm² listed in Table 11 (Non-Fixed External Radioactive Contamination-Wipe Limits) as specified in the U.S. Department of Transportation's 49 CFR 173.443 for transportation packages (see Subsection 4.4.2). The 21,000 dpm/100 cm² limit derived for beta/gamma emitters is about 9.5 times higher than the maximum permissible limits of 2,200 dpm/100 cm² also listed in Table 11 of 49 CFR 173.443. It should be noted that for exclusive use transport, as stated in 49 CFR 173.443, 10 times the Table 11 limits may be applied.

The derived single-radionuclide LRCL in Table 7 should be considered as the "limiting levels" for the radionuclides of concern. During confirmation survey of a WP, the most restrictive LRCL for alpha and beta/gamma emitters as presented in Table 7 may be used to demonstrate compliance.

Table 7. Derivation of LRCL

Nuclide	(1) Airborne ECL	(2) Derived LRCL	(3) Derived LRCL	(4) Derived LRCL & Type of Radiation emitter
	Ci/m ³	Ci/m ²	μCi/cm ²	dpm/ 100 cm ²
Co-60	5.0E-11	5.8E-05	5.8E-03	1,300,000 (β-γ)
Sr-90	6.0E-12	7.0E-06	7.0E-04	160,000 (β-γ)
Cs-137	2.0E-10	2.3E-04	2.3E-02	5,200,000 (β-γ)
Pu-238	2.0E-14	2.3E-08	2.3E-06	520 (α)
Pu-239	2.0E-14	2.3E-08	2.3E-06	520 (α)
Pu-240	2.0E-14	2.3E-08	2.3E-06	520 (α)
Pu-241	8.0E-13	9.3E-07	9.3E-05	21,000 (β-γ)
Am-241	2.0E-14	2.3E-08	2.3E-06	520 (α)
Cm-244	3.0E-14	3.5E-08	3.5E-06	780 (α)

NOTES: (1) Table 1.

(2) Eq. 12: $(1) \times 715 \text{ (m}^3/\text{s)} \times 3600 \text{ (s/hr)} \times 24 \text{ (hr/d)} \times 365 \text{ (d/yr)} / [605 \text{ (WP/yr)} \times 32 \text{ m}^2/\text{WP}]$.

(3) $(2) \times 1\text{E}6 \text{ (}\mu\text{Ci/Ci)} / 1\text{E}4 \text{ (cm}^2/\text{m}^2)$.

(4) $(3) \times 2.22\text{E}6 \text{ (dpm/}\mu\text{Ci)} \times 100 \text{ cm}^2$.

6.1.2 ALARA Evaluation

To demonstrate that the derived LRCL will be ALARA, the annual offsite and onsite individual doses are estimated in this section and compared with the applicable dose requirements described in Subsection 4.3. Dose estimates are made assuming that the average contamination level on the external surfaces of each WP is at the LRCL.

6.1.2.1 Offsite Maximum Individual Dose

An offsite maximum individual dose is estimated assuming an individual residing at 8000 m from the release point (Assumption 4.2.4) and the maximum chronic atmospheric dispersion factor ($3.19\text{E-}7 \text{ s/m}^3$) for ground level releases (Assumption 4.2.5). Based upon the maximum allowable annual release corresponding to a limiting ECL dose of 50 mrem/yr at the exhaust, the estimated committed effective dose equivalent (CEDE) to the exposed offsite individual is calculated to be 0.011 mrem/yr ($50 \text{ mrem/yr} \times 3.19\text{E-}7 \text{ s/m}^3 \times 715 \text{ m}^3/\text{s}$). This dose is much less than the 10 mrem/yr dose requirement for public exposure; therefore, the derived contamination limits would comply with the ALARA public dose requirement (Subsection 4.3).

6.1.2.2 Worker Dose

The worker dose is calculated by the equation provided in Regulatory Guide 8.34 (1992, Subsection 3.3) as:

$$H_{i,E} = 5 C_i t / 2000 \text{ DAC}_i \quad (\text{Eq. 13})$$

where: $H_{i,E}$ = committed effective dose equivalent from radionuclide i (rems)
 C_i = airborne concentration of radionuclide i to which the worker is exposed ($\mu\text{Ci}/\text{cm}^3$ or Ci/m^3)
 DAC_i = derived air concentration for nuclide i ($\mu\text{Ci}/\text{cm}^3$ or Ci/m^3 , Table 1)
 T = duration of the exposure (2000 hours, Subsection 4.2.8)
2000 = number of hours in a work year
5 = committed effective dose equivalent from annual intake of 1 annual limit on intake or 2000 DAC-hours (rems)

6.1.2.2.1 Surface Worker Dose

The annual maximum dose to a hypothetical surface worker is calculated assuming this individual works full time (2000 hr/yr, Subsection 4.2.8) at 100 m from the exhaust shaft (Subsection 4.2.4), the maximum chronic atmospheric dispersion factor ($4.77\text{E-}4 \text{ s}/\text{m}^3$) for ground level releases (Subsection 4.2.5) and the residual contamination level on WP are at the LRCL shown in Table 7.

The annual average dose to a surface worker is calculated assuming this individual works full time (2000 hr/yr, Subsection 4.2.8) at 3 km from the exhaust shaft (Subsection 4.2.4), the maximum chronic atmospheric dispersion factor ($1.23\text{E-}6 \text{ s}/\text{m}^3$) for ground level releases (Subsection 4.2.5), and the residual contamination level on WP are at the LRCL shown in Table 7.

The calculation of annual doses (in mrem/yr) received by the average and maximum surface workers using Eq. 13 above is shown in Table 8. The estimated maximum and average annual surface worker doses from the contamination present on the WPs at the LRCL listed in Table 7 are 14 mrem/yr and 0.035 mrem/yr, respectively (shown in columns (4) and (5) of Table 8, respectively). The maximally exposed surface worker dose is about 6% of the 250 mrem/yr ALARA dose criterion; therefore, a formal ALARA assessment is not required (Subsection 4.3).

6.1.2.2.2 Subsurface Worker Dose

The annual dose to a subsurface worker is calculated assuming that the individual worker works full time at the repository Access Main (Subsection 4.2.8), the ventilation airflow of $45.6 \text{ m}^3/\text{s}$ (Subsection 4.2.14), and the residual contamination level on all WPs is at the LRCL shown in Table 7. Airborne radioactive contamination in the Access Main could result from mechanical disturbance of the deposited material on the WPs during transport and entrainment in moving air adjacent to the surface. The resuspension rate of the deposited contamination has been conservatively assumed to be at 0.00004 per hour (Assumption 4.2.6).

The calculation of annual doses (in mrem/yr) received by the subsurface worker using Eq. 13 is shown in Table 8. The estimated annual worker dose from the contamination present on the WPs at the concentration limits listed in Table 7 is 0.36 mrem/yr maximum (shown in column (7) of Table 8). This dose is less than 1% of the 250 mrem/yr ALARA dose criterion for the maximally exposed worker; therefore, a formal ALARA assessment is not required (Subsection 4.3).

6.1.2.3 Total Collective Worker Dose

The total collective repository worker dose is calculated by summing the total collective subsurface worker dose and the total collective surface worker dose. The total collective subsurface worker dose is calculated by multiplying the total number of subsurface workers of 90 (Assumption 4.2.9) that is required during the waste emplacement period and the individual subsurface worker dose of 0.00036 rem/yr calculated in Table 8. The total collective subsurface worker dose therefore is $90 \times 0.00036 = 0.032$ person-rem/yr. The total collective surface worker dose is calculated by multiplying the total number of surface workers of 1305 (Assumption 4.2.9) estimated for the waste emplacement period and the average individual surface worker dose of 0.000035 rem/yr calculated in Table 8. The total collective surface worker dose therefore is $1305 \times 0.000035 = 0.046$ person-rem/yr. Summing up the total collective subsurface and surface worker doses, the total collective repository worker dose is $0.031 \text{ person-rem/yr} + 0.046 \text{ person-rem/yr} = 0.078 \text{ person-rem/yr}$. This total collective dose is less than 8% of the 1 person-rem/yr ALARA collective dose criterion; therefore, a formal ALARA assessment is not required (Subsection 4.3).

Table 8. Worker ALARA Dose Calculation

Nuclide	(1) Derived LRCL	(2) DAC	(3) Radionuclide Concentration at 100 m	(4) Maximum Surface Worker Dose at 100 m (CEDE)	(5) Average Surface Worker Dose at 3 km (CEDE)	(6) Radionuclide Concentration in Access Main	(7) Subsurface Worker Dose (CEDE)
	(Ci/m ²)	(Ci/m ³)	(Ci/m ³)	(mrem/yr)	(mrem/yr)	(Ci/m ³)	(mrem/yr)
Co-60	5.8E-05	1.0E-08	1.7E-11	8.5E+00	2.2E-02	4.5E-13	2.3E-01
Sr-90	7.0E-06	2.0E-09	2.0E-12	5.1E+00	1.3E-02	5.4E-14	1.4E-01
Cs-137	2.3E-04	6.0E-08	6.8E-11	5.7E+00	1.5E-02	1.8E-12	1.5E-01
Pu-238	2.3E-08	3.0E-12	6.8E-15	1.1E+01	2.9E-02	1.8E-16	3.0E-01
Pu-239	2.3E-08	3.0E-12	6.8E-15	1.1E+01	2.9E-02	1.8E-16	3.0E-01
Pu-240	2.3E-08	3.0E-12	6.8E-15	1.1E+01	2.9E-02	1.8E-16	3.0E-01
Pu-241	9.3E-07	1.0E-10	2.7E-13	1.4E+01(max)	3.5E-02 (max)	7.3E-15	3.6E-01(max)
Am-241	2.3E-08	3.0E-12	6.8E-15	1.1E+01	2.9E-02	1.8E-16	3.0E-01
Cm-244	3.5E-08	5.0E-12	1.0E-14	1.0E+01	2.6E-02	2.7E-16	2.7E-01

- Notes:
- (1) Table 7, column (2)
 - (2) Table 1 (10 CFR 20, Appendix B, Table 1, Column 2)
 - (3) $(1) \times 605 \text{ (WP/yr)} \times 32 \text{ (m}^2\text{/WP)} \times 3.17\text{E-8 (yr/s)} \times 4.77\text{E-4 (s/m}^3\text{)}$
 - (4) Eq. 13 (with $t=2000$): $5 \text{ (rem/yr)} \times (3) / (2) \times 1000 \text{ (mrem/rem)}$
 - (5) $(4) \times 1.23\text{E-6 (s/m}^3\text{)} / 4.77\text{E-4 (s/m}^3\text{)}$
 - (6) $(1) \times 32 \text{ (m}^2\text{/WP)} \times 0.00004 \text{ (1/hr)} / 3600 \text{ (s/hr)} / 45.6 \text{ (m}^3\text{/s)}$
 - (7) Eq. 13 (with $t=2000$): $5 \text{ (rem/yr)} \times (6) / (2) \times 1000 \text{ (mrem/rem)}$

6.2 WP RELEASE AND ITS DETECTABILITY

During the preclosure phase of the subsurface facility, an emplaced WP could become breached. The breached WP may release its gaseous, volatile, and particulate radionuclide contents to the subsurface facility. To control potential contamination inside the subsurface facility, a sensitive and well-designed airborne radioactivity monitoring system would be required for detecting leaks from WPs.

Four illustrating examples are used in this section for estimating potential WP leaks and their detectability. The potential releases are estimated based on the method described in Subsection 3.2, applicable design parameters in Subsection 4.1, and applicable assumptions in Subsection 4.2. The sensitivity of using air samples to detect potential leaks is evaluated by comparing the released concentrations to the MLD for radionuclides in effluent streams as specified in Table 4. The 21-PWR WP is used as a representative WP configuration for estimating the source terms and their potential release rates (Subsection 4.1.2).

The first example is used to determine the leak-tight hole diameter. The second example estimates potential internal pressure buildup inside a WP due to rupture of fuel rods. The third example is used to examine the sensitivity of leakage rate to hole size and WP temperature. The fourth example is used to evaluate radionuclide concentrations in the ventilation raise arising from potential leaks and their detectability.

6.2.1 Example 1: Leak-tight Hole Diameter

Leak-tight is defined in ANSI N14.5-97 (1998, p. 1) as a degree of package containment that in a practical sense precludes any significant release of radioactive materials. This degree of containment is achieved by demonstration of a leakage rate less than or equal to 1×10^{-7} ref.cm³/s, of air at an upstream pressure of 1 atmosphere (atm) absolute (abs) and a downstream pressure of 0.01 atm abs or less. The leakage rate of 1 ref.cm³/s is defined as a volume of one cubic centimeter of dry air per second at 1 atmosphere absolute pressure and 25°C. Table 9 was generated using air as the medium and equations presented in Subsection 3.2. The detailed calculations of air leakage rates are provided in Appendix B.

Table 9. Air Leakage Rates (cm³/s) under Reference Conditions

Leak Hole Diameter (cm)	Leakage Rate (cm ³ /s)
1.00E-05	1.82E-12
1.00E-04	2.69E-09
2.82E-04	9.95E-08
1.00E-03	1.13E-05
1.00E-02	9.79E-02
1.00E-01	9.63E+02

Source: Appendix B Table B-2

The result of this example indicates that any leak holes with diameters less than or equal to 0.00028 cm may be specified as leak-tight according to the above definition.

6.2.2 Example 2: WP Internal Pressure

Pressure difference is the driving force for a WP leak. This example estimates potential internal pressure buildup inside a WP due to rupture of fuel rods. The method and parameters used to calculate the internal pressure in the 21-PWR WP are described in *Preclosure Design Basis Events Related to Waste Packages* (CRWMS M&O 2000f, Attachment. III).

The internal pressure in the WP is calculated according to the ideal gas law. The detail of the calculation performed is shown in Appendix C. The results of the calculations are summarized in Table 10. The results indicate that WP internal pressure increases with increasing temperature and fuel rupture rate. Increasing fuel rupture rate from 3% to 100% would increase the internal pressure by a factor of 3.4. For the same fuel rupture rate, increasing fuel temperature from 25 °C to 600° C would increase the internal pressure by a factor of about 3.

Table 10. WP Internal Pressure (Pa) as a Function of Temperature and % Fuel Rupture

Temperature (°C)	% Fuel Rupture				
	100%	50%	25%	10%	3%
25	3.78E+05	2.42E+05	1.72E+05	1.30E+05	1.10E+05
50	4.10E+05	2.62E+05	1.87E+05	1.41E+05	1.19E+05
100	4.73E+05	3.03E+05	2.16E+05	1.63E+05	1.38E+05
200	6.00E+05	3.84E+05	2.73E+05	2.06E+05	1.74E+05
300	7.27E+05	4.65E+05	3.31E+05	2.50E+05	2.11E+05
350	7.90E+05	5.06E+05	3.60E+05	2.71E+05	2.30E+05
400	8.53E+05	5.46E+05	3.89E+05	2.93E+05	2.48E+05
500	9.80E+05	6.28E+05	4.47E+05	3.37E+05	2.85E+05
570	1.07E+06	6.84E+05	4.87E+05	3.67E+05	3.11E+05
600	1.11E+06	7.09E+05	5.05E+05	3.80E+05	3.22E+05

NOTES: Source: Appendix C Table C-2
Pressure unit Pa = Pascal

6.2.3 Example 3: WP Leakage Rate

This example is used to examine the sensitivity of leakage rate to hole size and WP temperature. For illustration purposes, 3% of the fuel rods are assumed to develop cladding breaches that could cause the release of gases, volatiles, and particulates in the gap region (Assumption 4.2.17).

Table 11 was generated using equations presented in Subsection 3.2, and the applicable design parameters and assumptions provided in Subsections 4.1 and 4.2, respectively. The details of the calculations are shown in Appendix D. A graphical representation of the leakage rate calculations is shown in Figure 1.

The conclusion reached from Figure 1 is that leakage rate is significantly more sensitive to variations in leakage hole size than to WP temperature.

Table 11. 21-PWR WP Leakage Rates

Temperature (°C)	Leak Hole Diameter (cm)	Leakage Rate (cm ³ /s)	Gas Leak Rate (Ci/s)	Volatile Leak Rate (Ci/s)	Fine Leak Rate (Ci/s)	Crud Leak Rate (Ci/s)	Total Leak Rate (Ci/s)
300	1.00E-05	3.87E-12	2.08E-16	7.60E-19	5.41E-20	6.53E-19	2.09E-16
	1.00E-04	4.79E-09	2.57E-13	9.40E-16	6.69E-17	8.08E-16	2.59E-13
	1.00E-03	1.39E-05	7.48E-10	2.74E-12	1.95E-13	2.35E-12	7.53E-10
	1.00E-02	1.05E-01	5.66E-06	2.07E-08	1.47E-09	1.78E-08	5.70E-06
	1.00E-01	1.02E+03	5.48E-02	2.00E-04	1.43E-05	1.72E-04	5.51E-02
350	1.00E-05	4.27E-12	2.29E-16	8.38E-19	5.97E-20	7.20E-19	2.31E-16
	1.00E-04	5.23E-09	2.81E-13	1.03E-15	7.32E-17	8.83E-16	2.83E-13
	1.00E-03	1.49E-05	7.98E-10	2.92E-12	2.08E-13	2.51E-12	8.03E-10
	1.00E-02	1.11E-01	5.97E-06	2.19E-08	1.56E-09	1.88E-08	6.01E-06
	1.00E-01	1.08E+03	5.77E-02	2.11E-04	1.50E-05	1.81E-04	5.81E-02
500	1.00E-05	5.32E-12	2.86E-16	1.05E-18	7.44E-20	8.98E-19	2.88E-16
	1.00E-04	6.39E-09	3.43E-13	1.26E-15	8.94E-17	1.08E-15	3.45E-13
	1.00E-03	1.71E-05	9.17E-10	3.36E-12	2.39E-13	2.88E-12	9.23E-10
	1.00E-02	1.24E-01	6.65E-06	2.44E-08	1.73E-09	2.09E-08	6.70E-06
	1.00E-01	1.19E+03	6.40E-02	2.34E-04	1.67E-05	2.01E-04	6.45E-02

Source: Appendix D Table D-4.

Figure 1. WP Leakage Rate as a Function of Hole size and Temperature

6.2.4 Example 4: Radionuclide Concentration and Detectability

To control potential contamination at the subsurface repository and to detect prematurely failed WPs, a sensitive and well-designed airborne radioactivity monitoring system would be required for detecting WP leaks. The detection of failed WPs may be required in order to provide reasonable assurance that the integrity of WP is intact prior to MGR closure. A sensitive and fast response detection system may be necessary because the radioactive gaseous or particulate matter could quickly escape in the event that the WP develops a flaw. This example evaluates the detectability of radionuclide concentrations in the ventilation raise arising from potential WP leaks. The ventilation raise is selected because it channels the exhaust air directly from emplacement drifts to the repository exhaust.

The sensitivity of using air sampling to detect potential leaks is evaluated by comparing the released concentrations in the raise to the minimum levels of detectability for radionuclides in effluent streams as specified in Table 4. Table 12 summarizes the radionuclide concentrations generated using the volumetric leakage rates listed in Table 11, the radionuclide source terms listed in Table 5, and the raise airflow rate of 30 m³/s described in 4.1.1. The details of the calculation performed are provided in Appendix E.

A comparison of the raise concentrations and the minimum level of detectabilities shown in Table 12 indicates that a continuous air monitoring system may not be sensitive enough to detect the presence of any radionuclides from small WP leaks (e.g., a leak hole diameter smaller than about 0.001 – 0.01 cm). The minimum levels of detectability listed in Table 12 refer to the sensitivities for detection of an effluent stream for individual nuclides and represent what is reasonably obtainable consistent with state-of-the-art measurements. The numerical values apply at the detector locations and use continuous monitoring instruments. Since significant amounts of radon concentrations are expected to be present in the ventilation raises (averages ranged from 29 to 43 pCi/L, CRWMS M&O, 2000h, p. 24), the minimum level of detectability will need to be re-assessed with consideration given to interference from these natural sources.

Table 12. Estimated Radionuclide Concentration in Raise

Temperature (°C)	Leak Hole Diameter (cm)	Radionuclide Concentration in Raise (Ci/m ³)					
		Kr-85	Cs-137	Sr-90	Pu-238	Pu-239	Co-60 (Crud)
300	1.00E-05	6.29E-18	1.52E-20	1.01E-20	1.27E-22	9.85E-24	2.18E-20
	1.00E-04	7.77E-15	1.89E-17	1.25E-17	1.58E-19	1.22E-20	2.69E-17
	1.00E-03	2.26E-11	5.49E-14	3.63E-14	4.59E-16	3.55E-17	7.84E-14
	1.00E-02	1.71E-07	4.15E-10	2.75E-10	3.47E-12	2.68E-13	5.93E-10
	1.00E-01	1.66E-03	4.02E-06	2.66E-06	3.36E-08	2.60E-09	5.74E-06
350	1.00E-05	6.93E-18	1.68E-20	1.11E-20	1.40E-22	1.09E-23	2.40E-20
	1.00E-04	8.50E-15	2.06E-17	1.36E-17	1.72E-19	1.33E-20	2.94E-17
	1.00E-03	2.41E-11	5.86E-14	3.88E-14	4.89E-16	3.78E-17	8.36E-14
	1.00E-02	1.81E-07	4.38E-10	2.90E-10	3.66E-12	2.83E-13	6.26E-10
	1.00E-01	1.75E-03	4.23E-06	2.80E-06	3.54E-08	2.73E-09	6.05E-06
500	1.00E-05	8.64E-18	2.10E-20	1.39E-20	1.75E-22	1.35E-23	2.99E-20
	1.00E-04	1.04E-14	2.52E-17	1.67E-17	2.10E-19	1.63E-20	3.59E-17
	1.00E-03	2.77E-11	6.73E-14	4.45E-14	5.62E-16	4.35E-17	9.61E-14
	1.00E-02	2.01E-07	4.88E-10	3.23E-10	4.08E-12	3.16E-13	6.97E-10
	1.00E-01	1.94E-03	4.70E-06	3.11E-06	3.93E-08	3.04E-09	6.71E-06
Min. Level Detectability^a (Ci/m³)		3E-07	5E-12	4E-12	2E-12	2E-12	8E-11

NOTES: ^aSource of minimum detectability: Subsection 4.1.5 (Table 4).

Raise flow rate = 30 m³/s (Subsection 4.1.1).

7. CONCLUSIONS

This report may be affected by technical product input information that requires confirmation. Any changes to the report that may occur as a result of completing the confirmation activities will be reflected in subsequent revisions. The status of the input information quality may be confirmed by review of the Document Input Reference System database. The conclusions provided in this section can only be used as preliminary information to assist future design analyses relative to efforts required for decontaminating WPs before transporting to the subsurface repository, and designing an airborne radioactivity monitoring system for detecting potential leaks from emplaced WPs.

7.1 DERIVED LRCL

Preliminary single-radionuclide LRCL on the external surface of WPs (Table 7) were derived for acceptance of WPs into the subsurface repository. The derivation of LRCL was based on the requirement that the airborne concentrations at the repository exhaust shall not exceed the airborne ECL. The LRCL derived for crud (Co-60) is 1,300,000 dpm/100 cm². The most restrictive LRCL derived for alpha and beta/gamma emitters are 520 dpm/100 cm² and 21,000 dpm/100 cm², respectively. These most restrictive LRCL may be used to demonstrate WP suitability for emplacement in the repository. This may be accomplished in any one of a number of ways including remote surveys, by operational performance experience, or by system layout design that would inherently prevent any possible surface contamination. Remote surveys, if used, would require additional support analysis to determine the useful statistical limits on sampling frequency, detectability, bias, and error.

To demonstrate that the derived LRCL will comply with the ALARA requirements, the annual maximum doses to hypothetical individuals, both onsite and offsite, were calculated assuming that the average surface contamination on the WPs is at the LRCL shown in Table 7. The results of the calculations indicate that with surface contamination at these levels, the potential maximum doses to these hypothetical onsite and offsite individuals would be a very small fraction of the ALARA dose requirements. The maximum TEDE to offsite individual was estimated to be 0.011 mrem/yr. This dose is much less than the 10 mrem/yr ALARA dose requirement for public exposure. The maximum surface and subsurface worker doses were also calculated. The maximally exposed surface and subsurface worker doses were estimated to be about 6% and 1%, respectively, of the 250 mrem/yr ALARA worker dose criterion that would require a formal ALARA assessment. The collective worker dose was calculated using the number of workers estimated to be present during the emplacement period of the repository. The maximum collective worker dose was estimated to be less than 8% of the 1 person-rem/yr dose criterion that would require a formal ALARA assessment.

7.2 POTENTIAL WP LEAK AND ITS DETECTABILITY

Potential radioactive releases from a defective WP were evaluated based on the release model described in *American National Standard for Radioactive Materials — Leakage Tests on Packages for Shipment* (ANSI N14.5-97 1998, Annex B). Four illustrating examples, based on design configuration of the 21-PWR WP, were used to evaluate the potential quantities of

release, the resulting radionuclide concentrations in the ventilation raise, and their detectabilities. The evaluations indicate that the potential quantities of release from a defective WP are heavily dependent on the size of leak hole and less on the WP temperature. A leak hole size with diameter smaller than 0.00028 cm may be classified as leak-tight for the 21-PWR WP, according to the definition of leak-tight specified by the ANSI N14.5-97 (1998, p.1).

The results of an evaluation of radionuclide concentrations in the ventilation raise indicate that a continuous air monitoring system may be used for detecting large potential leaks from accidents involving severe WP damages. The minimum detectable leak size was estimated to be about 0.01 cm in diameter. It should be noted, however, that the detectability of the air sampling system for WP leaks could be complicated by interference of two other sources: (1) a potential release from WP surface contamination, which is indistinguishable from a WP leak and (2) the existence of radon and its progeny, which is expected to be present in significant amounts during the preclosure period.

INTENTIONALLY LEFT BLANK

8. REFERENCES

8.1 DOCUMENTS CITED

Bird, R.B.; Stewart, W.E.; and Lightfoot, E.N. 1960. *Transport Phenomena*. New York, New York: John Wiley & Sons. TIC: 208957.

BSC (Bechtel SAIC Company) 2001a. *Overall Ventilation System Flow Network Calculation for Site Recommendation*. CAL-SVS-HV-000002 REV 00. Las Vegas, Nevada: Bechtel SAIC Company. ACC: MOL.20010821.0073.

BSC (Bechtel SAIC Company) 2001b. *Site Recommendation Subsurface Layout*. ANL-SFS-MG-000001 REV 00 ICN 02. Las Vegas, Nevada: Bechtel SAIC Company. ACC: MOL.20010411.0131.

BSC (Bechtel SAIC Company) 2001c. *Uncanistered Spent Nuclear Fuel Disposal Container System Description Document*. SDD-UDC-SE-000001 REV 01 ICN 01. Las Vegas, Nevada: Bechtel SAIC Company. ACC: MOL.20010927.0070.

CRWMS M&O 1998. *Software Qualification Report for RSAC-5 Version 5.2 the Radiological Safety Analysis Computer Program*. CSCI: 30067 V5.2. DI: 30067-2003, Rev. 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.19990721.0325.

CRWMS M&O 1999a. *Calculations of Acute and Chronic "Chi/Q" Dispersion Estimates for a Surface Release*. TDR-MGR-MM-000001 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000106.0439.

CRWMS M&O 1999b. *PWR Source Term Generation and Evaluation*. BBAC00000-01717-0210-00010 REV 01. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000113.0333.

CRWMS M&O 2000a. *Engineering Files for Site Recommendation*. TDR-WHS-MD-000001 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000607.0232.

CRWMS M&O 2000b. *Design Basis Event Frequency and Dose Calculation for Site Recommendation*. CAL-WHS-SE-000001 REV 01. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000627.0214.

CRWMS M&O 2000c. *Disposal Container Handling System Description Document*. SDD-DCH-SE-000001 REV 01 ICN 01. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000807.0080.

CRWMS M&O 2000d. *FEIS Update to Engineering File - Subsurface Repository*. TDR-EBS-MD-000007 REV 00 ICN 01. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000612.0058.

CRWMS M&O 2000e. *Leakpath Factors for Radionuclide Releases from Breached Confinement Barriers*. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000901.0021.

CRWMS M&O 2000f. *Preclosure Design Basis Events Related to Waste Packages*. ANL-MGR-MD-000012 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000725.0015.

CRWMS M&O 2000g. *Retrieval Equipment and Strategy for WP on Pallet*. ANL-WES-ME-000006 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20001002.0150.

CRWMS M&O 2000h. *Subsurface Radon Calculations*. CAL-SSM-NU-000003 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20001220.0016.

CRWMS M&O 2000i. *Repository Surface Design Engineering Files Report Supplement*. TDR-WHS-EV-000001 REV 00 ICN 1. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000626.0025.

CRWMS M&O 2000j. *Ventilation System Radon Review*. CAL-SSM-NU-000002 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000510.0167.

CRWMS M&O 2001. *Technical Work Plan for Subsurface Design Section FY 01 Work Activities*. TWP-MGR-MG-000001 REV 01 ADDENDUM D. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20010417.0455.

Curry, P.M. 2001. *Monitored Geologic Repository Project Description Document*. TDR-MGR-SE-000004 REV 02 ICN 02. Las Vegas, Nevada: Bechtel SAIC Company. ACC: MOL.20010628.0224.

DOE (U.S. Department of Energy) 1994. *Analysis of Experimental Data*. Volume 1 of *Airborne Release Fractions/Rates and Respirable Fractions for Nonreactor Nuclear Facilities*. DOE-HDBK-3010-94. Washington, D.C.: U.S. Department of Energy. TIC: 233366.

DOE (U.S. Department of Energy) 2000. *Quality Assurance Requirements and Description*. DOE/RW-0333P, Rev. 10. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: MOL.20000427.0422.

Kocher, D.C. 1981. *Radioactive Decay Data Tables, A Handbook of Decay Data for Application to Radiation Dosimetry and Radiological Assessments*. DOE/TIC-11026. Washington, D.C.: U.S. Department of Energy. TIC: 228074.

NRC (U.S. Nuclear Regulatory Commission) 2000. *Standard Review Plan for Spent Fuel Dry Storage Facilities*. NUREG-1567. Washington, D.C.: U.S. Nuclear Regulatory Commission. TIC: 247929.

Perry, R.H.; Green, D.W.; and Maloney, J.O., eds. 1984. *Perry's Chemical Engineers' Handbook*. 6th Edition. New York, New York: McGraw-Hill. TIC: 246473.

Regulatory Guide 4.20, Rev. 0. 1996. *Constraint on Releases of Airborne Radioactive Materials to the Environment for Licensees Other Than Power Reactors*. Washington, D.C.: U.S. Nuclear Regulatory Commission. Readily available.

Regulatory Guide 8.34, Rev. 0. 1992. *Monitoring Criteria and Methods to Calculate Occupational Radiation Doses*. Washington, D.C.: U.S. Nuclear Regulatory Commission. Readily available.

8.2 CODES, STANDARDS, REGULATIONS

10 CFR 20. Energy: Standards for Protection Against Radiation. Readily available.

49 CFR 173. Transportation: Shippers—General Requirements for Shipments and Packagings. Readily available.

66 FR 55732. Disposal of High-Level Radioactive Wastes in a Proposed Geologic Repository at Yucca Mountain, NV. Final Rule 10 CFR Part 63. Readily available.

ANSI N14.5-97. 1998. *American National Standard for Radioactive Materials — Leakage Tests on Packages for Shipment*. New York, New York: American Nuclear Standards Institute. TIC: 247029.

ANSI N42.18-1980. 1985. *Specification and Performance of On-Site Instrumentation for Continuously Monitoring Radioactivity in Effluents*. New York, New York: Institute of Electrical and Electronics Engineers. TIC: 205004.

8.3 PROCEDURES

AP-2.21Q, Rev. 1, ICN 0, BSCN 001. *Quality Determinations and Planning for Scientific, Engineering, and Regulatory Compliance Activities*. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: MOL.20010212.0018.

AP-3.11Q, Rev. 2, ICN 0. *Technical Reports*. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: MOL.20010405.0010.

AP-3.15Q, Rev. 3, ICN 0. *Managing Technical Product Inputs*. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: MOL.20010801.0318.

AP-3.4Q, Rev. 2, ICN 2. *Level 3 Change Control*. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: MOL.20010927.0066.

AP-SI.1Q, Rev. 3, ICN 2, ECN 1. *Software Management*. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: MOL.20011030.0598.

AP-SV.1Q, Rev. 0, ICN 2. *Control of the Electronic Management of Information*. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: MOL.20000831.0065.

INTENTIONALLY LEFT BLANK

APPENDIX A

CALCULATION OF AVERAGE 21-PWR WP SOURCE TERMS

INTENTIONALLY LEFT BLANK

APPENDIX A – CALCULATION OF AVERAGE 21-PWR SOURCE TERMS

The average fuel source terms (fission gases, volatiles, and fuel particulates) are taken from *PWR Source Term Generation and Evaluation* (CRWMS M&O 1999b, Attachment X), based on PWR fuel with 4% initial enrichment, 48 GWd/MTU burnup, and 25 yr decay period (CRWMS M&O 1999b, p. 24). Table A-1 lists the radionuclide source terms and their totals in the average PWR spent fuel assembly and the 21-PWR WP.

Table A.1. Average 21-PWR WP Source Terms

Nuclide	Avg PWR ^a Curies/ Assembly	Avg PWR ^b Curies/WP	Nuclide	Avg PWR ^a Curies/ Assembly	Avg PWR ^b Curies/WP
Gases			Fuel fines (continued)		
H-3	1.14E+02	2.39E+03	Eu-155	5.15E+01	1.08E+03
C-14	3.32E-01	6.97E+00	Fe-55	3.46E+00	7.27E+01
Kr-85	1.13E+03	2.37E+04	Nb-93m	1.30E+01	2.73E+02
I-129	2.19E-02	4.60E-01	Nb-94	8.39E-01	1.76E+01
Total Gases	1.24E+03	2.61E+04	Ni-59	2.09E+00	4.39E+01
			Ni-63	2.52E+02	5.29E+03
Volatiles			Np-237	2.47E-01	5.19E+00
Cs-134	2.52E+01	5.29E+02	Pa-231	2.97E-05	6.24E-04
Cs-135	3.50E-01	7.35E+00	Pd-107	8.41E-02	1.77E+00
Cs-137	4.11E+04	8.63E+05	Pm-147	1.19E+02	2.50E+03
Sr-90	2.72E+04	5.71E+05	Pu-238	2.29E+03	4.81E+04
Ru-106	1.23E-02	2.58E-01	Pu-239	1.77E+02	3.72E+03
Total Volatiles	6.83E+04	1.43E+06	Pu-240	3.18E+02	6.68E+03
			Pu-241	2.46E+04	5.17E+05
Fuel fines			Pu-242	1.64E+00	3.44E+01
Ac-227	1.61E-05	3.38E-04	Sb-125	9.71E+00	2.04E+02
Am-241	1.98E+03	4.16E+04	Se-79	4.57E-02	9.60E-01
Am-242m	6.39E+00	1.34E+02	Sm-151	2.11E+02	4.43E+03
Am-243	2.20E+01	4.62E+02	Sn-126	3.85E-01	8.09E+00
Cd-113m	7.66E+00	1.61E+02	Tc-99	8.98E+00	1.89E+02
Cl-36	6.80E-03	1.43E-01	Th-230	1.48E-04	3.11E-03
Cm-242	5.26E+00	1.10E+02	U-232	2.04E-02	4.28E-01
Cm-243	1.03E+01	2.16E+02	U-233	3.79E-05	7.96E-04
Cm-244	1.36E+03	2.86E+04	U-234	6.77E-01	1.42E+01
Cm-245	3.07E-01	6.45E+00	U-235	7.37E-03	1.55E-01
Cm-246	1.04E-01	2.18E+00	U-236	1.72E-01	3.61E+00
Co-60	3.13E+02	6.57E+03	U-238	1.48E-01	3.11E+00
Eu-154	6.71E+02	1.41E+04	Zr-93	8.94E-01	1.88E+01
			Total Fines	3.24E+04	6.81E+05

NOTES: ^aSource: (CRWMS M&O 1999b, Attachment X).^bAverage Curies per WP = Average Curies per Assembly x 21 Assembly.

INTENTIONALLY LEFT BLANK

APPENDIX B

DETERMINATION OF WP LEAK-TIGHT HOLE DIAMETER

INTENTIONALLY LEFT BLANK

APPENDIX B – DETERMINATION OF WP LEAK-TIGHT HOLE DIAMETER

The determination of the WP leak-tight hole diameter is based on the ANSI N14.5-97 (1998) definition of leak-tight (ANSI N14.5-97 1998, p. 1). Leak-tight is defined in ANSI N14.5-97 (1998) as

“a degree of package containment that in a practical sense precludes any significant release of radioactive materials. This degree of containment is achieved by demonstration of a leakage rate less than or equal to 1×10^{-7} ref.cm³/s, of air at an upstream pressure of 1 atmosphere (atm) absolute (abs) and a downstream pressure of 0.01 atm abs or less.”

In this appendix the reference air leakage rates for a range of leak hole diameters are calculated first to determine the WP leak-tight hole diameter. The leak-tight hole diameter is then used to calculate two sets of WP air leakage rate for pressure conditions other than the referenced condition defined above for comparison.

The equations used to calculate the volume leakage rate from a WP are equations 9, 10 and 11 as described in Subsection 3.2:

$$L = (F_c + F_m) (P_u - P_d) P_a / P_u \quad (\text{Eq. B-1})$$

$$F_c = \frac{2.49 \times 10^6 D^4}{\alpha \mu} \quad (\text{Eq. B-2})$$

$$F_m = \frac{3.81 \times 10^3 D^3 \sqrt{T/M}}{\alpha P_a} \quad (\text{Eq. B-3})$$

where

α = leakage hole length, cm

μ = viscosity, cP

D = leakage hole diameter, cm

T = standard temperature, 298 K

M = molecular weight, grams per mole

P_a = average stream pressure = $0.5(P_u + P_d)$, atm abs

P_u = fluid upstream pressure, atm abs

P_d = fluid downstream pressure, atm abs

L = volumetric leakage rate, cm³/s

F_c = coefficient of continuum flow conductance per unit pressure, cm³/atm-s

F_m = coefficient of free molecular flow conductance per unit pressure, cm³/atm-s

Table B-1 below summarizes the input parameters used for leakage rate calculations. The actual leakage rate calculations using equations B-1, B-2 and B-3 for various leakage hole diameters are provided in Table B-2.

Table B-1. Leak-tight Calculation Parameters

Parameter	Symbol	Value	Source Section
Gas medium	N/A	air	App. B, p. B-1
Viscosity of air at 298 K (cP)	μ	1.85E-02	Subsection 4.1.4
Pressure upstream (atm)	P_u	1.00E+00	App. B, p. B-1
Pressure downstream (atm)	P_d	1.00E-02	App. B, p. B-1
Average pressure (atm)	P_a	5.05E-01	$0.5(P_u + P_d)$
Standard Temperature (K)	T	2.98E+02	App. B, p. B-1
Air Molecular weight (gmol)	M	2.90E+01	Subsection 4.1.4
leakage hole length, cm	α	7.00E+00	Subsection 4.2.11
WP Void volume (cm ³)	V	4.38E+06	Subsection 4.1.2

Table B-2. Leakage Rate Calculations to Determine Leak-tight Hole Diameter

Note: Leak-tight is defined as leakage rate < 1.0E-7(cm ³ /s) (p. B-1)			
D Leak Hole Diameter (cm)	F _c (Eq. B-1)	F _m (Eq. B-2)	L (Eq. B-3) Leakage Rate (cm ³ /s)
1.00E-05	1.92E-13	3.45E-12	1.82E-12
1.00E-04	1.92E-09	3.45E-09	2.69E-09
2.82E-04	1.22E-07	7.75E-08	9.95E-08
1.00E-03	1.92E-05	3.45E-06	1.13E-05
1.00E-02	1.92E-01	3.45E-03	9.79E-02
1.00E-01	1.92E+03	3.45E+00	9.63E+02

Verification Calculations:

Verification calculations using D = 2.82E-04 cm

$$F_c = 2.49E6 \times (2.82E-4)^4 / (7 \times 1.85E-2) = 1.216E-7$$

$$F_m = 3.81E3 \times (2.82E-4)^3 \times (298/29)^{0.5} / (7 \times 0.505) = 7.75E-8$$

$$L = (1.216E-7 + 7.75E-8) \times (1 - 0.01) \times 0.505 / 1 = 9.95E-8$$

Based on the definition of leak-tight and the results of the leakage rate calculations, it can be determined that for a 21-PWR WP any leak hole sizes with diameters less than 0.00028 cm may be classified as leak-tight.

The WP leak-tight air leakage rates for upstream pressure of 2 and 3 atm and downstream pressure of 1 atm are calculated below for comparison with the reference leak-tight air leakage rate of $1.0\text{E-}07 \text{ cm}^3/\text{s}$.

The leak-tight air leakage rates are calculated using the leak-tight hole diameter of 0.00028 cm determined above and equations B-1, B-2 and B-3. The calculations are provided in Table B-3.

Table B-3. Leak-tight Leakage Rate Calculations

Note: leak-tight hole diameter = 0.00028 cm				
P_u (atm)	P_d (atm)	F_c (Eq. B-1)	F_m (Eq. B-2)	L (Eq. B-3) Leakage Rate (cm^3/s)
2	1	$1.18\text{E-}07$	$2.55\text{E-}08$	$1.08\text{E-}07$
3	1	$1.18\text{E-}07$	$1.92\text{E-}08$	$1.83\text{E-}07$

Verification Calculations:

Verification calculations using $P_u = 3 \text{ atm}$

$$F_c = 2.49\text{E}6 \times (2.8\text{E-}4)^4 / (7 \times 1.85\text{E-}2) = 1.182\text{E-}7$$

$$P_a = 0.5 \times (3+1) = 2$$

$$F_m = 3.81\text{E}3 \times (2.8\text{E-}4)^3 \times (298/29)^{0.5} / (7 \times 2) = 1.915\text{E-}8$$

$$L = (1.182\text{E-}7 + 1.915\text{E-}8) \times (3 - 1) \times 2 / 3 = 1.831\text{E-}7$$

INTENTIONALLY LEFT BLANK

APPENDIX C

CALCULATION OF WP INTERNAL PRESSURE

INTENTIONALLY LEFT BLANK

APPENDIX C – CALCULATION OF WP INTERNAL PRESSURE

The calculation of the internal pressure in the 21-PWR WP is based on the approach described in *Preclosure Design Basis Events Related to Waste Packages* (CRWMS M&O 2000f, Attachment III).

The internal pressure P in the WP is calculated according to the ideal gas law:

$$P = nRT/V \quad (\text{Eq. C-1})$$

where

- n = the number of helium moles in the WP
- R = gas constant
- T = the WP inside temperature
- V = the WP void volume

Table C-1 below summarizes the input parameters used for pressure calculation. As indicated in *Preclosure Design Basis Events Related to Waste Packages* (CRWMS M&O 2000f, p. III-3 and p. III-4), the number of helium gas moles listed in Table C-1 are conservative values and would lead to overestimating the pressure in the WP.

The internal pressure calculations using equation C-1 for various fuel rod failure rates are provided in Table C-2.

Table C-1. Summary of Design Parameters for Appendix C

Parameter	Value ^a
Number of assembly per WP	21
PWR number of rods per assembly	208
WP void volume	4.38 m ³
PWR fuel rod void volume	35 cm ³
Initial helium gas moles in WP void	179.1
Initial helium gas moles in fuel rod	0.117
Gas law constant	8.3144 J mol ⁻¹ K ⁻¹

NOTES: ^(a) Source: Subsection 4.12

Table C-2. Calculation Sheet for WP Internal Pressure

% Fuel failed, F	100%	50%	25%	10%	3%
(1) Void VOL (m ³), V	4.53E+00	4.46E+00	4.42E+00	4.40E+00	4.38E+00
(2) Final Gas Moles, n	6.91E+02	4.35E+02	3.07E+02	2.30E+02	1.94E+02
Temperature (°C) , T	(3) Pressure, P (Pascal)				
25	3.78E+05	2.42E+05	1.72E+05	1.30E+05	1.10E+05
50	4.10E+05	2.62E+05	1.87E+05	1.41E+05	1.19E+05
100	4.73E+05	3.03E+05	2.16E+05	1.63E+05	1.38E+05
200	6.00E+05	3.84E+05	2.73E+05	2.06E+05	1.74E+05
300	7.27E+05	4.65E+05	3.31E+05	2.50E+05	2.11E+05
350	7.90E+05	5.06E+05	3.60E+05	2.71E+05	2.30E+05
400	8.53E+05	5.46E+05	3.89E+05	2.93E+05	2.48E+05
500	9.80E+05	6.28E+05	4.47E+05	3.37E+05	2.85E+05
570	1.07E+06	6.84E+05	4.87E+05	3.67E+05	3.11E+05
600	1.11E+06	7.09E+05	5.05E+05	3.80E+05	3.22E+05

NOTES: (1) $V = 4.38 \text{ (m}^3\text{)} + 0.000035 \text{ (m}^3\text{)} \times 208 \text{ (rods/assy)} \times 21 \text{ (assy/WP)} \times F$.

(2) $n = 179.1 \text{ (moles)} + 0.117 \text{ (moles/rod)} \times 208 \text{ (rods/assy)} \times 21 \text{ (assy/WP)} \times F$.

(3) $P = n \text{ (mol)} \times 8.3144 \text{ (J mol}^{-1} \text{ K}^{-1}\text{)} \times (273+T) \text{ (K)} / V \text{ (m}^3\text{)}$.

Verification Calculations:

Verification calculations using $F = 3\%$, $T = 300^\circ\text{C}$

$$(1) V = 4.38 + 0.000035 \times 208 \times 21 \times 0.03 = 4.3846$$

$$(2) n = 179.1 + 0.117 \times 208 \times 21 \times 0.03 = 194.43$$

$$(3) P = 194.43 \times 8.3144 \times (273+300) / 4.3846 = 211263$$

INTENTIONALLY LEFT BLANK

APPENDIX D

CALCULATION OF 21-PWR WP LEAKAGE RATE

INTENTIONALLY LEFT BLANK

APPENDIX D – CALCULATION OF 21-PWR WP LEAKAGE RATE

The equations used to calculate the volume leakage rate from a WP are equations 9, 10, and 11 as described in Subsection 3.2:

$$L = (F_c + F_m) (P_u - P_d) P_a / P_u \quad (\text{Eq. D-1})$$

$$F_c = \frac{2.49 \times 10^6 D^4}{\alpha \mu} \quad (\text{Eq. D-2})$$

$$F_m = \frac{3.81 \times 10^3 D^3 \sqrt{T/M}}{\alpha P_a} \quad (\text{Eq. D-3})$$

where

α = leakage hole length, cm

μ = viscosity, cP

D = leakage hole diameter, cm

T = fluid absolute temperature, K

M = molecular weight, grams per mol

P_a = average stream pressure = $0.5(P_u + P_d)$, atm abs

P_u = fluid upstream pressure, atm abs

P_d = fluid downstream pressure, atm abs

L = volumetric leakage rate, cm^3/s

F_c = coefficient of continuum flow conductance per unit pressure, $\text{cm}^3/\text{atm-s}$

F_m = coefficient of free molecular flow conductance per unit pressure, $\text{cm}^3/\text{atm-s}$

Table D-1 summarizes the input parameters used for leakage rate calculations. The leakage rate calculations using the above equations for various WP temperatures and leakage hole diameters are provided in Table D-2. Table D-3 presents the WP release source term calculations. The calculation of WP radioactive source term releases is provided in Table D-4.

Table D-1. WP Leakage Rates Calculation Parameters

Note: 3 % Fuel rod Failed Case (Assumption 4.2.16)

Inputs		WP Temperature (°C)		
Parameter	Symbol	300 C	350 C	500 C
Viscosity (cP) ^(a)	μ	3.00E-02	3.20E-02	3.80E-02
Pressure upstream (P _a) ^(b)	P _u	2.11E+05	2.30E+05	2.85E+05
Pressure upstream (atm) ^(c)	P _u	2.09E+00	2.27E+00	2.81E+00
Pressure downstream (atm) ^(d)	P _d	8.78E-01	8.78E-01	8.78E-01
Average pressure (atm) ^(e)	P _a	1.48E+00	1.57E+00	1.85E+00
Temperature (K) ^(f)	T	5.73E+02	6.23E+02	7.73E+02
Helium molecular weight (gmol) ^(g)	M	4.00E+00	4.00E+00	4.00E+00
Path length (cm) ^(h)	α	7.00E+00	7.00E+00	7.00E+00
WP void volume (cm ³) ⁽ⁱ⁾	V	4.38E+06	4.38E+06	4.38E+06

NOTES: ^(a) Source: Table 3, Subsection 4.1.4

^(b) Source: Table C-2

^(c) $P_u \text{ (atm)} = P_u(P_a) / 1.01E5 \text{ (P}_a\text{/atm)}$ (Subsection 4.1.6)

^(d) Source: Subsection 4.2.20

^(e) $P_a = 0.5 (P_u + P_d)$

^(f) $T(K) = 273 + T(C)$

^(g) Source: Table 2, Subsection 4.1.3

^(h) Source: Subsection 4.2.11

⁽ⁱ⁾ Source: Subsection 4.1.2

Table D-2. Calculation Sheet for WP Volumetric Leakage Rate

WP Internal Temperature (°C)	Leak Hole Diameter (cm)	(1) F_c (Eq. D-1)	(2) F_m (Eq. D-2)	(3) L (Eq. D-3) Leakage Rate (cm ³ /s)
300	1.00E-05	1.19E-13	4.40E-12	3.87E-12
	1.00E-04	1.19E-09	4.40E-09	4.79E-09
	1.00E-03	1.19E-05	4.40E-06	1.39E-05
	1.00E-02	1.19E-01	4.40E-03	1.05E-01
	1.00E-01	1.19E+03	4.40E+00	1.02E+03
350	1.00E-05	1.11E-13	4.32E-12	4.27E-12
	1.00E-04	1.11E-09	4.32E-09	5.23E-09
	1.00E-03	1.11E-05	4.32E-06	1.49E-05
	1.00E-02	1.11E-01	4.32E-03	1.11E-01
	1.00E-01	1.11E+03	4.32E+00	1.08E+03
500	1.00E-05	9.36E-14	4.10E-12	5.32E-12
	1.00E-04	9.36E-10	4.10E-09	6.39E-09
	1.00E-03	9.36E-06	4.10E-06	1.71E-05
	1.00E-02	9.36E-02	4.10E-03	1.24E-01
	1.00E-01	9.36E+02	4.10E+00	1.19E+03

NOTES: (1) Calculated based on Eq. D-2 and parameters listed in Table D-1.

(2) Calculated based on Eq. D-3 and parameters listed in Table D-1.

(3) Calculated based on Eq. D-1, values of (1) & (2) and P_u & P_d listed in Table D-1.

Verification Calculations:

Verification calculations using $D = 1.00E-03$ cm, $T = 350$ °C

$$F_c = 2.49E6 \times (1.0E-3)^4 / (7 \times 3.2E-2) = 1.1116E-5$$

$$F_m = 3.81E3 \times (1.0E-3)^3 \times (623/4)^{0.5} / (7 \times 1.5742) = 4.7549E-5/11.0 = 4.32E-6$$

$$L = (1.1116E-5 + 4.32E-6) \times (2.27 - 0.8783) \times 1.5742 / 2.27 = 1.49E-5$$

Table D-3. WP Source Term Calculation Sheet

Nuclide	(1) Ci per WP	(2) Failed Activity (Ci)	(3) Gap Release Fraction	(4) Gap Activity (Ci)
Gases	2.61E+04	7.84E+02	3.00E-01	2.35E+02
Volatiles	1.43E+06	4.30E+04	2.00E-04	8.61E+00
Fines	6.81E+05	2.04E+04	3.00E-05	6.13E-01
Crud	4.93E+01	4.93E+01	1.50E-01	7.39E+00
Total Activity	2.14E+06	6.43E+04	N/A	2.52E+02

NOTES: (1) Source: Table 5, Subsection 4.2.16.

(2) (1) x 3% fuel rod failed (for Gases, Volatiles and Fines; Assumption 4.2.17). For Crud: (1) x 100%.

(3) Source: Table 6, Subsection 4.2.17.

(4) (2) x (3).

Table D-4. WP Leakage Rate Calculation Sheet

WP Internal Temperature (°C)	Leak Hole Diameter (cm)	(1) Leakage Rate (cm ³ /s)	(2) Gas Leak Rate (Ci/s)	(3) Volatile Leak Rate (Ci/s)	(4) Fine Leak Rate (Ci/s)	(5) Crud Leak Rate (Ci/s)	(6) Total Leak Rate (Ci/s)
300	1.00E-05	3.87E-12	2.08E-16	7.60E-19	5.41E-20	6.53E-19	2.09E-16
	1.00E-04	4.79E-09	2.57E-13	9.40E-16	6.69E-17	8.08E-16	2.59E-13
	1.00E-03	1.39E-05	7.48E-10	2.74E-12	1.95E-13	2.35E-12	7.53E-10
	1.00E-02	1.05E-01	5.66E-06	2.07E-08	1.47E-09	1.78E-08	5.70E-06
	1.00E-01	1.02E+03	5.48E-02	2.00E-04	1.43E-05	1.72E-04	5.51E-02
350	1.00E-05	4.27E-12	2.29E-16	8.38E-19	5.97E-20	7.20E-19	2.31E-16
	1.00E-04	5.23E-09	2.81E-13	1.03E-15	7.32E-17	8.83E-16	2.83E-13
	1.00E-03	1.49E-05	7.98E-10	2.92E-12	2.08E-13	2.51E-12	8.03E-10
	1.00E-02	1.11E-01	5.97E-06	2.19E-08	1.56E-09	1.88E-08	6.01E-06
	1.00E-01	1.08E+03	5.77E-02	2.11E-04	1.50E-05	1.81E-04	5.81E-02
500	1.00E-05	5.32E-12	2.86E-16	1.05E-18	7.44E-20	8.98E-19	2.88E-16
	1.00E-04	6.39E-09	3.43E-13	1.26E-15	8.94E-17	1.08E-15	3.45E-13
	1.00E-03	1.71E-05	9.17E-10	3.36E-12	2.39E-13	2.88E-12	9.23E-10
	1.00E-02	1.24E-01	6.65E-06	2.44E-08	1.73E-09	2.09E-08	6.70E-06
	1.00E-01	1.19E+03	6.40E-02	2.34E-04	1.67E-05	2.01E-04	6.45E-02

NOTES: (1) Source: Table D-3 (last col.).

(2) (1) (cm³/s) x 2.35E+02 (Ci, gap activity, Table D-3) / 4.38E+06 (cm³, WP void Vol., Table D-1).

(3) (1) (cm³/s) x 8.61E+00 (Ci, gap activity) / 4.38E+06 (cm³, WP void Vol) x 0.1 (Leakpath factor).

(4) (1) (cm³/s) x 6.13E-01 (Ci, gap activity) / 4.38E+06 (cm³, WP void Vol) x 0.1 (Leakpath factor).

(5) (1) (cm³/s) x 7.39E+00 (Ci, gap activity) / 4.38E+06 (cm³, WP void Vol) x 0.1 (Leakpath factor).

(6) (2) + (3) + (4) + (5).

Leakpath factor = 0.1 (Subsection 4.2.18)

INTENTIONALLY LEFT BLANK

APPENDIX E

CALCULATION OF RADIONUCLIDE CONCENTRATIONS IN RAISE

INTENTIONALLY LEFT BLANK

APPENDIX E – CALCULATION OF RADIONUCLIDE CONCENTRATIONS IN RAISE

The calculation of radionuclide concentrations in the emplacement drift ventilation raises is based on the average ventilation flow rate of 30 m³/s (Subsection 4.1.1), the WP volumetric leakage rate (Table D-2), the radionuclide source terms (Table 5) and the leakpath factor of 0.1 (Subsection 4.2.18). Table E-1 presents the calculation sheet for radionuclide source terms based on the assumption that 3% of fuel rods failed (Subsection 4.2.17). The calculation of radionuclide concentrations in the ventilation raise is presented in Table E-2.

Table E-1. Radionuclide Source Terms Calculation Sheet

Nuclide	(1) Ci per WP	(2) Failed Activity (Ci)	(3) Gap Release Fraction	(4) Gap Activity (Ci)
Kr-85	2.37E+04	7.12E+02	3.00E-01	2.14E+02
Cs-137	8.63E+05	2.59E+04	2.00E-04	5.18E+00
Sr-90	5.71E+05	1.71E+04	2.00E-04	3.43E+00
Pu-238	4.81E+04	1.44E+03	3.00E-05	4.33E-02
Pu-239	3.72E+03	1.12E+02	3.00E-05	3.35E-03
Co-60 (crud)	4.93E+01	4.93E+01	1.50E-01	7.39E+00

NOTES: (1) Source: Table 5, Subsection 4.2.16.

(2) (1) x 3% fuel rod failed (for Kr, Cs, Sr and Pu) (Subsection 4.2.17).

For crud (1) x 100%.

(3) Source: Table 6, Subsection 4.2.17.

(4) (2) x (3).

Table E-2. Ventilation Raise Radionuclide Concentration Calculation Sheet

WP Internal Temperature (°C)	Leak Hole Diameter (cm)	(1) Volumetric Leakage Rate (cm ³ /s)	(2) Kr-85 Conc. (Ci/m ³)	(3) Cs-137 Conc. (Ci/m ³)	(4) Sr-90 Conc. (Ci/m ³)	(5) Pu-238 Conc. (Ci/m ³)	(6) Pu-239 Conc. (Ci/m ³)	(7) Co-60 (Crud) Conc. (Ci/m ³)
300	1.00E-05	3.87E-12	6.29E-18	1.52E-20	1.01E-20	1.27E-22	9.85E-24	2.18E-20
	1.00E-04	4.79E-09	7.77E-15	1.89E-17	1.25E-17	1.58E-19	1.22E-20	2.69E-17
	1.00E-03	1.39E-05	2.26E-11	5.49E-14	3.63E-14	4.59E-16	3.55E-17	7.84E-14
	1.00E-02	1.05E-01	1.71E-07	4.15E-10	2.75E-10	3.47E-12	2.68E-13	5.93E-10
	1.00E-01	1.02E+03	1.66E-03	4.02E-06	2.66E-06	3.36E-08	2.60E-09	5.74E-06
350	1.00E-05	4.27E-12	6.93E-18	1.68E-20	1.11E-20	1.40E-22	1.09E-23	2.40E-20
	1.00E-04	5.23E-09	8.50E-15	2.06E-17	1.36E-17	1.72E-19	1.33E-20	2.94E-17
	1.00E-03	1.49E-05	2.41E-11	5.86E-14	3.88E-14	4.89E-16	3.78E-17	8.36E-14
	1.00E-02	1.11E-01	1.81E-07	4.38E-10	2.90E-10	3.66E-12	2.83E-13	6.26E-10
	1.00E-01	1.08E+03	1.75E-03	4.23E-06	2.80E-06	3.54E-08	2.73E-09	6.05E-06
500	1.00E-05	5.32E-12	8.64E-18	2.10E-20	1.39E-20	1.75E-22	1.35E-23	2.99E-20
	1.00E-04	6.39E-09	1.04E-14	2.52E-17	1.67E-17	2.10E-19	1.63E-20	3.59E-17
	1.00E-03	1.71E-05	2.77E-11	6.73E-14	4.45E-14	5.62E-16	4.35E-17	9.61E-14
	1.00E-02	1.24E-01	2.01E-07	4.88E-10	3.23E-10	4.08E-12	3.16E-13	6.97E-10
	1.00E-01	1.19E+03	1.94E-03	4.70E-06	3.11E-06	3.93E-08	3.04E-09	6.71E-06

NOTES: Raise airflow rate = 30 m³/s (Subsection 4.1.1).

WP void volume = 4.38E+06 cm³ (Subsection 4.1.2).

Leakpath factor = 0.1 (Subsection 4.2.18)

(1) Source: Table D-2 (last col.).

(2) (1) (cm³/s) x 2.14E+02 (Ci, gap activity, Table E-1) / 4.38E+06 (cm³) / 30 m³/s.

(3) (1) (cm³/s) x 5.18E+00 (Ci, gap activity, Table E-1) / 4.38E+06 (cm³) x 0.1 (Leakpath factor) / 30 m³/s.

(4) (1) (cm³/s) x 3.43E+00 (Ci, gap activity, Table E-1) / 4.38E+06 (cm³) x 0.1 (Leakpath factor) / 30 m³/s.

(5) (1) (cm³/s) x 4.33E-02 (Ci, gap activity, Table E-1) / 4.38E+06 (cm³) x 0.1 (Leakpath factor) / 30 m³/s.

(6) (1) (cm³/s) x 3.35E-03 (Ci, gap activity, Table E-1) / 4.38E+06 (cm³) x 0.1 (Leakpath factor) / 30 m³/s.

(7) (1) (cm³/s) x 7.39E+00 (Ci, gap activity, Table E-1) / 4.38E+06 (cm³) x 0.1 (Leakpath factor) / 30 m³/s.

INTENTIONALLY LEFT BLANK