

2
JUL 21 1999

ENGINEERING DATA TRANSMITTAL

Page 1 of 1
1. EDT 623398

2. To: (Receiving Organization) Distribution		3. From: (Originating Organization) Equipment Engineering		4. Related EDT No.: N/A	
5. Proj./Prog./Dept./Div.: DST System/Integrity Assessment		6. Design Authority/Design Agent/Cog. Engr.: CE Jensen		7. Purchase Order No.: N/A	
8. Originator Remarks: This EDT Transmits the data listed in Block 15 for review and approval preparatory to release.				9. Equip./Component No.: N/A	
11. Receiver Remarks:				10. System/Bldg./Facility: 200E/Tank Farms	
11A. Design Baseline Document? <input type="radio"/> Yes <input checked="" type="radio"/> No				12. Major Assm. Dwg. No.: N/A	
				13. Permit/Permit Application No.: N/A	
				14. Required Response Date: ASAP	

15. DATA TRANSMITTED					(F)	(G)	(H)	(I)
(A) Item No.	(B) Document/Drawing No.	(C) Sheet No.	(D) Rev. No.	(E) Title or Description of Data Transmitted	Approval Designator	Reason for Transmittal	Originator Disposition	Receiver Disposition
1	HNF-4818	N/A	0	Final Results of Double-Shell Tank 241-AY-102 Ultrasonic Inspection	E	1	1	

16. KEY		
Approval Designator (F)	Reason for Transmittal (G)	Disposition (H) & (I)
E, S, Q, D OR N/A (See WHC-CM-3-5, Sec. 12.7)	1. Approval 2. Release 3. Information 4. Review 5. Post-Review 6. Dist. (Receipt Acknow. Required)	1. Approved 2. Approved w/comment 3. Disapproved w/comment 4. Reviewed no/comment 5. Reviewed w/comment 6. Receipt acknowledged

17. SIGNATURE/DISTRIBUTION (See Approval Designator for required signatures)											
(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN	(G) Reason	(H) Disp.	(J) Name	(K) Signature	(L) Date	(M) MSIN
		Design Authority				1	1	DC Pfluger	<i>[Signature]</i>	7/20/99	R1-56
		Design Agent									
1	1	Cog. Eng. CE Jensen	<i>[Signature]</i>	20 July 1999	R1-56						
1	1	Cog. Mgr. DB Smet	<i>[Signature]</i>	7-28-99	R1-56						
		QA									
		Safety									
1	1	Env. PC Miller	<i>[Signature]</i>	7/20/99							

18. Signature of EDT Originator: <i>[Signature]</i> Date: 20 July 1999		19. Authorized Representative for Receiving Organization: <i>[Signature]</i> Date: 7/21/99		20. Design Authority/Cognizant Manager: <i>[Signature]</i> Date: 7-28-99		21. DOE APPROVAL (if required) Ctrl No. _____ <input type="radio"/> Approved <input type="radio"/> Approved w/comments <input type="radio"/> Disapproved w/comments	
--	--	--	--	--	--	---	--

Final Results of Double-Shell Tank 241-AY-102 Ultrasonic Inspection

C. E. Jensen

Lockheed Martin Hanford Corporation, Richland, WA 99352
U.S. Department of Energy Contract DE-AC06-87RL10930

EDT/ECN: EDT 623398 UC: 2000
Org Code: 74700 Charge Code: 106701/CA40
B&R Code: EW3130000 Total Pages: 59


Key Words: ultrasonic, tank integrity, examination, 241-AY-102, 102-AY, inspection, wall thinning, UT testing, tank wall, UT, integrity assessment, ultrasonic inspection

Abstract: This document presents the results and documentation of the nondestructive ultrasonic examination of tank 241-AY-102. A tank inspection supplier was retained to provide and use an ultrasonic examination system (equipment, procedures, and inspectors) to scan a limited area of double-shell tank 241-AY-102 primary tank wall and welds. The inspection found some indication of insignificant general and local wall thinning with no cracks detected.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: WHC/BCS Document Control Services, P.O. Box 1970, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

[Signature] 7/21/99
Release Approval Date Release Stamp



Approved for Public Release

FINAL RESULTS OF DOUBLE-SHELL TANK
241-AY-102
ULTRASONIC INSPECTION

Prepared By: *R. W. Lysher* Date *7/19/99*
R. W. Lysher, COGEMA Engineering Corporation

Reviewed By: *T. S. Hundal* Date *7/19/99*
T. S. Hundal, Washington State Registered Professional Engineer
COGEMA Engineering Corporation

Approved By: *K. V. Scott* Date *7/19/99*
K. V. Scott, Manager
COGEMA Engineering Corporation

**Final Results of Double-Shell Tank 241-AY-102
Ultrasonic Inspection**

July 13, 1999

Prepared by
R. W. Lysher
COGEMA Engineering Corporation

for

Lockheed Martin Hanford Corporation
Richland, Washington

**Final Results of Double-Shell Tank 241-AY-102
Ultrasonic Inspection**

Table of Contents

1.0 Introduction.....	4
2.0 Objective/Scope.....	5
3.0 Examination Equipment Description.....	5
4.0 Performance Demonstration Tests	6
5.0 Ultrasonic Examination Description.....	6
6.0 General Requirements and Inspection Criteria	7
7.0 Indication Reporting Criteria	7
8.0 Equipment Set-up at AY Tank Farm	8
9.0 Examination Results	8
10.0 Evaluation of Examination Results.....	10
11.0 Findings and Conclusions	11
12.0 References	12
Figure 1 Comparison of As-Measured and ASTM-Specified Plate Thickness with Waste Level, DST 241-AY-102.....	13
Figure 2 Schematic of Inspection Set-up 241-AY-102.....	14
Attachment 1 Ultrasonic Examination of Double-Shell Tank 241-AY-102	
Attachment 2 241-AY-102 Double-Shell Tank Ultrasonic Examination Data Reports With Data Sheets	

**Double-Shell Tank System Integrity Assessment:
FINAL RESULTS OF DOUBLE-SHELL TANK 241-AY-102 ULTRASONIC
INSPECTION**

1.0 INTRODUCTION

In May 1996, the Tank Waste Remediation System (TWRS) Decision Board recommended, and the U.S. Department of Energy-Richland Operations Office (DOE-RL) agreed, that the condition of the double-shell tanks (DST) should be determined by ultrasonic (UT) inspection of a limited area in six of the 28 DSTs. The Washington State Department of Ecology (WDOE) has agreed with the strategy of limited UT inspection of six DSTs. Data collected during the UT inspections will be used to assess the condition of the tanks, judge the effects of past corrosion control practices, and satisfy a regulatory requirement to periodically assess the integrity of waste tanks.

In November 1996, the primary and secondary walls of DST 241-AW-103 were remotely examined to determine if Hanford DST walls could be inspected without removing the existing surface rust and scale. The successful completion of this inspection represented the first UT inspection of a Hanford DST (Leshikar 1997).

Based on the results of the initial inspection, a statement of work (SOW)(Pfluger 1999) was prepared for the remaining DST inspections scheduled for Fiscal Year (FY) 1999. The service of COGEMA Engineering Corporation (COGEMA Engineering) was retained to provide an UT examination system (equipment, procedures, and inspectors) and perform the inspection.

Tank 241-AY-102 was selected as one of the six sample tanks that represent the complete 28-tank population. The tank began receiving waste in 1976 and is currently classified as a dilute waste tank (DN). The current tank level is approximately 185 inches (Hanlon 1999). From 1976 to present, the waste temperature in the tank has not exceeded 123°F with the average temperature holding at approximately 68°F. Although the tanks are expected to have similar performance, the selection of tanks is purposely biased towards tanks whose primary walls may be more likely to be degraded by corrosion. The tank selection criteria (Schwenk and Scott 1996) considered variables that may influence corrosion, such as waste physical characteristics, waste chemistry, temperature, and age. Tank 241-AY-102 was chosen because it is older, had significant waste height fluctuations, and the material of construction is more conducive to cracking in the knuckle region.

2.0 OBJECTIVE / SCOPE

This report presents the results of the UT examination of DST 241-AY-102 with attention focused on the primary tank wall base metal and welds. Issuance of this report meets FY 1999 Performance Agreement TWR 6.3.1. The criteria, deliverables, and responsibilities for the UT examination are described in Pfluger 1999.

3.0 EXAMINATION EQUIPMENT DESCRIPTION

P-scan – P-scan is the name of the computerized pulse-echo UT inspection system used by the examination vendor. The P-scan system is manufactured by Force Institute in Denmark. It acquires data from zero and angle beam transducers mounted on the crawler, allows real-time analysis, and records the data in electronic memory for post inspection analysis. Force Institute has designated “P-scan mode” to represent the angle beam (flaw length) view and “T-scan mode” to represent the zero beam (thickness) view. T-scan mode is used for normal operation and, if crack-like indications are detected, the P-scan mode is employed. More information on the procedure for the P-scan system is found in Jensen 1999.

Crawler (UT Scanner) – The crawler is a remotely-controlled device that delivers the ultrasonic sensors to the tank walls (Figure 2). It weighs approximately 30 pounds and has dimensions of approximately 21” wide x 18” long x 6” high. The crawler attaches to the tank wall with two pairs of magnetic wheels. A traveling bridge on the crawler is outfitted with ultrasonic sensors. As the crawler moves slowly forward, the sensors glide from side-to-side over the tank wall surface. Water couplant is continuously fed to each transducer at a rate needed to maintain an acceptable signal.

Overview Camera – This camera was deployed to observe the area immediately around the inspection area and to aid crawler deployment in the annulus.

Sideview Camera – This camera and light system were installed in a riser adjacent to the inspection riser to provide an overall view of the inspection process.

Data Acquisition Control Center – A pull-type trailer was used to house the crawler controls, video monitors, and the data collection and evaluation hardware. The trailer was located outside the AY tank farm boundary fence (Figure 2).

Deployment Tool – This device was specifically designed to insert and retrieve the scanner from the DST annular space. The scanner sits on a platform that is manually lowered to the appropriate elevation. That platform has cables attached that can be controlled to move the scanner platform into contact with the examination surface. The scanner is then driven onto the surface. The deployment tool is retracted until scanner removal is required.

4.0 PERFORMANCE DEMONSTRATION TESTS

Prior to field use, COGEMA Engineering's UT examination system satisfactorily completed a performance demonstration test (PDT). The test was performed prior to examination of tank 241-AN-107 in FY 1998 (Pfluger 1998). The test was conducted to qualify personnel, test procedures, and ensure the equipment's ability to detect and size wall thinning, pits, and cracks in a series of test plates with artificial and natural defects. The PDT was performed on an actual tank mockup located in the 306E facility located in the Hanford site 300 area. This mockup also demonstrated the successful deployment and retrieval of the equipment. Pacific Northwest National Laboratory report (Attachment 1) PNNL-12233 *Ultrasonic Examination of Double-Shell Tank 241-AY-102* provides details of the complete examination and brief evaluation of the PDT.

5.0 ULTRASONIC EXAMINATION DESCRIPTION

5.1 Primary Wall and Weld Inspection

The tank inspection was performed under Job Control System (JCS) work package 2E-98-02406/W during early calendar year 1999. All work steps, guidelines, procedures, personnel responsibilities, and protocol for the inspection (Pfluger 1999) were included in the subject work package.

An updated version of the remotely-controlled, steerable crawler was used to deliver the UT sensors to the tank wall. The crawler was deployed through a 24-inch annulus inspection riser number 18B. The crawler attached to the tank wall with two pairs of magnetic wheels. A traveling bridge on the crawler was outfitted with UT sensors. As the crawler moved slowly forward, the sensors glided from side-to-side over the inspection surface. Water couplant was continuously fed to each transducer at a rate needed to attain an acceptable signal. For examination of the wall, one dual element 0° transducer and two 45° shear wave transducers were used. To detect cracks perpendicular to welds, two opposing 45° shear wave transducers were directed parallel to the weld. To detect cracks parallel to the weld, a 60° shear-wave transducer was directed toward the weld and a dual element 0° transducer was also included. Welds were examined from both sides of the weld crown.

Data and images from both systems were returned to a control center located just outside the AY tank farm fence (Figure 2). The control center housed the crawler controls, video monitors, and data collection and evaluation software/hardware. The UT inspector continuously monitored the signal for reportable indications. The inspection was viewed by a camera and lighting system deployed in an adjacent riser.

6.0 GENERAL REQUIREMENTS AND INSPECTION CRITERIA

The FY 1999 Performance Agreement TWR 6.3.1 is stated below:

“The contractor shall perform ultrasonic examination of four double-shell tanks (primary walls straight portion) to the extent described in HNF-2820, “*Engineering Task Plan for the Ultrasonic Inspection of Hanford Double-Shell Tanks*”. Completion is met when ultrasonic examination on four double-shell tanks is performed, a report of examinations/observations is reviewed and approved by FDH, and the report is submitted to RL by July 31, 1999. The report shall include the extent of the examination, discussion of observations, findings, and conclusions.”

Areas to be examined on the primary tank were identified in the SOW (Pfluger 1999) as:

Primary Tank Wall:

- A vertical strip, approximately 30 inches wide by 35 feet long. The vertical strip may be comprised of one or more strips whose total width is approximately 30 inches. (The distance from the tank upper haunch transition to the lower knuckle is approximately 35 feet).
- 20 feet of the cylinder-to-lower knuckle weld.
- One vertical weld joining the lowest shell course plates (approximately 10 feet).
- One vertical weld joining the next to the lowest shell course plates (approximately 10 feet).

7.0 INDICATION REPORTING CRITERIA

COGEMA Engineering was required to report to the customer the following anomalies (Pfluger 1999):

- Wall thinning that exceeded 10% of the nominal plate thickness
- Pit depths that exceeded 25% of the nominal wall thickness
- Cracks that exceeded 0.18 inches in depth.

8.0 EQUIPMENT SET-UP AT AY TANK FARM

Prior to performing the actual examination, the riser shield plug was removed and replaced with a sheetmetal cover.

A temporary structure, constructed of scaffolding, was erected around the riser to provide the means for deploying the UT equipment (Figure 2). A central I-Beam was secured to the top of the scaffolding and supported a single-line sheave. A manual cable winch was secured to the base with the cable running up to the sheave in a single-line hoisting method for maneuvering the equipment into position. The weather during the examination was cool to moderate so a second temporary structure was erected near the inspection riser. This "tent" was constructed of round tubing and covered with weather resistant material and housed the inspection overview video equipment, deployment tool and video monitor (Figure 2). The tent provided adverse weather protection for the equipment and crew. The control cables leading from the trailer were run along the ground to the equipment located at the riser. The cable was sleeved with plastic to prevent possible contamination

9.0 EXAMINATION RESULTS

The Inspection Data Sheets and an interpretation of the data by a COGEMA Engineering Level III qualified inspector are included in Attachment 2. Tank 241-AY-102 (typical of all double-shell tanks) was fabricated from carbon steel plate. The location of plates as identified in the PNNL report is as follows (See Attachment 1):

Primary knuckle (top) – Connects dome of tank to side-wall.

Primary wall – Consists of (from top to bottom):

Top Transition Plate – approximately 3 feet, 3 inches tall, 3/8" nominal thickness

Plate #1 – approximately 9 feet, 10 inches tall, 1/2" nominal thickness

Plate #2 – approximately 9 feet, 10 inches tall, 1/2" nominal thickness

Plate #3 – approximately 9 feet tall, 3/4" nominal thickness

Primary knuckle (bottom) – Connects side-wall of tank to primary tank bottom.

All tank welds are in the "as-welded" condition. The primary tanks exterior surface varies from mill scale to a coating of rust caused by the normal weathering of carbon steel. The tank surface also contains chalk marks from hydrostatic test and miscellaneous material identifier markings from construction. In some places, streaks from concrete pouring can be found.

The following pages contain tables that present the data as a percent (%) of nominal wall thickness, which was derived from the "241-AY-102 Double-Shell Tank Ultrasonic Examination Data Reports With Data Sheets" (Attachment 2) and Pacific Northwest National Laboratory report PNNL-12233 (Attachment 1) "Ultrasonic Examination of Double-Shell Tank 241-AY-102".

Table 1 Tank 241-AY-102 Ultrasonic Examination Primary Tank Wall, Scan 1 (Attachment 2)			
Plate	Design Nominal Thickness (inches)	Measured Minimum Thickness (inches)	% Wall Thinning
Plate #1	0.375	0.395	N/A
Plate #2	0.50	0.495	1.0% of nominal thickness
Plate #3	0.50	0.495	1.0% of nominal thickness
Plate #4	0.75	0.735	2.0% of nominal thickness

Table 2 Tank 241-AY-102 Ultrasonic Examination Primary Tank Wall, Scan 2 (Attachment 2)			
Plate	Design Nominal Thickness (inches)	Measured Minimum Thickness (inches)	% Wall Thinning
Plate #1	0.375	0.383	N/A
Plate #2	0.50	0.485	3.0% of nominal thickness
Plate #3	0.50	0.485	3.0% of nominal thickness
Plate #4	0.75	0.734	2.1% of nominal thickness

Weld	Design Nominal Thickness (inches)	Measured Minimum Thickness (inches)	% Wall Thinning
Vertical Plate #3	0.50	0.465	7% of nominal thickness
Vertical Plate #4	0.750	0.722	3.7% of nominal thickness
Horizontal Between Plate #2and #3	0.50	0.485	3.0% of nominal thickness

Note 1: PNNL evaluated the data and concluded that no wall thinning, pitting, or cracking is present. Refer to PNNL-12233 *Ultrasonic Examination of Double Shell Tank 241-AY-102* (see Attachment 1).

Note 2: Although the data is reported to three decimal places, the accuracy of the data, based on the results of the performance demonstration test is ± 0.020 inch for wall thickness.

10.0 EVALUATION OF EXAMINATION RESULTS

The results of the Tank 241-AY-102 UT examination indicated no reportable wall thinning, pitting, or cracks. Attachment 1 contains the report prepared by PNNL that analyzes the data gathered from Tank 241-AY-102 UT examination. Figure 1 shows the history of waste level matched with the "as-found" measurements of the primary tank wall generated from the inspection data sheets (Attachment 2). Each wall thickness measurement plotted on the figure is the average of all data collected over a 1-foot long by 15-inch wide scan area. No apparent wall thinning, pitting, and cracking.

PNNL UT examination experts independently evaluated (Attachment 1) the hard copy scans and inspection data sheets and concurred with the COGEMA Engineering interpretation (see Attachment 2). The following is a summary of the results associated with the areas examined. The data have been reviewed and approved by W. H. Nelson, COGEMA Engineering Level III qualified inspector (Attachment 2):

Primary Tank Wall Thinning/Pitting/Cracking:

- No reportable thinning, pitting, or cracking was detected.

Primary Tank Horizontal and Vertical Welds:

- No reportable thinning, pitting, or cracking was detected.
- Scans of the heat affected zones (HAZ) between Plate #2 and #3 revealed no pitting, or crack-like indications.
- Welds between Plate #3 and #4 and the lower knuckle weld could not be examined because of surface roughness and contamination (weld and concrete splatter)

11.0 FINDINGS AND CONCLUSIONS

- The absence of cracks in the plate and HAZ indicates that the pre-service material quality control, weld stress relief treatment, and waste chemistry controls have been effective in preventing cracks.
- Since there were no significant changes in the wall thickness and no cracks were detected at any location, corrosion due to suspected mechanisms is probably not occurring to any significant degree. However, uncertainty on conditions that lead to corrosion degradation, particularly stress corrosion cracking, suggest additional data on other tanks are needed to gain confidence that this result can be applied to the general tank population.

12.0 REFERENCES

Hanlon, B.M., 1999, *Waste Tank Summary Report for Month Ending April 30, 1999*, HNF-EP-0182-121, Fluor Daniel Hanford, Inc., Richland, Washington.


Jensen, C. E., 1999, *Final Results of Double-Shell Tank 241-AN-105 Ultrasonic Inspection*, HNF-4816, Rev. 0, Lockheed Martin Hanford Corporation, Richland, Washington

Leshikar, G.A., 1997, *Final Report - Ultrasonic Examination of Tank 241-AW-103 Walls*, HNF-SD-WM-TRP-282, Rev. 1, SGN Eurisys Services Corporation, Richland, Washington.


Pflugger, D.C., 1998, *Final Results of Double-Shell Tank 241-AN-107 Ultrasonic Inspection*, HNF-3353, Rev. 0, Lockheed Martin Hanford Corporation, Richland, Washington

Pflugger, D.C., 1999, *Engineering Task Plan for the Ultrasonic Inspection of Hanford Double-Shell Tanks*, HNF-2820, Rev. 1, Lockheed Martin Hanford Corporation, Richland, Washington

Schwenk, E.B., and Scott, K.V., 1996, *Description of Double-Shell Tank Selection Criteria for Inspection*, WHC-SD-WM-ER-529, Rev. 0, Westinghouse Hanford Company, Richland, Washington.



241-AY-102



Primary Wall Thickness (Inches)

- Avg. Thk - Scan #2
- Avg. Thk - Scan #1
- - - Nominal Thickness

Figure 1 - Comparison of As-Measured and ASTM-Specified Plate Thickness with Waste Level, DST 241-AY-102

ZJJAAY102.DWG




Figure 2 - Schematic of Inspection Set-up 241-AY-102

ATTACHMENT 1

Ultrasonic Examination of Double Shell Tank 241-AY-102

PNNL-12233

Ultrasonic Examination of Double Shell Tank 241-AY-102

G. J. Posakony

A. F. Pardini

June 1999

Prepared for

Lockheed Martin Hanford Corporation

Richland, Washington 99352

Pacific Northwest National Laboratory

Richland, Washington 99352

Summary

COGEMA Engineering Corporation (COGEMA), under a contract from Lockheed Martin Hanford Corporation (LMHC), performed an ultrasonic examination of selected portions of Tank 241-AY-102. The purpose of this examination was to provide information that could be used to evaluate the integrity of the wall of the primary tank. To implement the examination, COGEMA contracted with Swain Distribution, Inc. (Swain) of Searcy, Arkansas for the qualified personnel, ultrasonic instrumentation, and remote-controlled mechanical crawler that were to be used in performing this examination. The equipment provided by Swain included the Force Industries, Inc. P-Scan Model PSP-3 ultrasonic flaw detector system and the Force Industries AWS-5D remote, digitally controlled, magnetic-wheel mechanical crawler. The P-Scan Model PSP-3 is the same ultrasonic system used in the inspections of Tanks 241-AW-103, AN-105, and AN-107, but the magnetic wheel crawler was upgraded to Model AWS-5D. The ultrasonic procedure for the examination of the double-shell tanks at Hanford was developed by Swain personnel and approved by Mr. Wesley Nelson. Mr. Nelson is COGEMA's American Society for Nondestructive Testing (ASNT) Certified Level III in ultrasonic testing (UT) and was the UT Level III authority for this project.

Reports PNNL-11971 and PNNL-12198 provide details on the examination requirements, ultrasonic inspection procedure, personnel qualification requirements, and the results from AN-107 and AN-105. For details and information on the performance demonstration test (PDT), please refer to the referenced PNNL reports.

The ultrasonic examination of Tank 241-AY-102 was designed to inspect the wall of the primary tank to detect wall thinning, pit corrosion, and cracks in the tank wall as well as cracks, wall thinning, and other anomalies in the heat-affected zone (HAZ) of vertical, horizontal, and knuckle welds. In Tank 241-AY-102 selected portions of the primary tank wall were examined and these results were used as a representative sampling of conditions in the remainder of the primary tank.

Figure S.1 is a sketch of the portions of Tank 241-AY-102 that were ultrasonically examined. The wall of the primary tank is 32-ft high and is made up of four rings of plates that have been welded together. The ultrasonic examination consisted of inspecting two 15-in.-wide vertical strips the full 32-ft height of the tank to detect wall thinning and any cracking or other anomalies that might be in the wall of the primary tank. In addition, the weld zones of selected vertical and horizontal welds were inspected to detect and characterize any cracks that might lie parallel or perpendicular to the welds. The sketch shows the vertical scan paths for the two ultrasonic plate thickness and plate crack examinations. These scans were separated by approximately 6-in. The sketch also shows the top weld (primary tank to dome weld), vertical and horizontal welds, and knuckle weld. In performing the examinations, the remote-controlled, magnetic wheel crawler was installed in the annulus of the double-shell tank through the 24-in. riser.




Figure S.1. Sketch of Vertical Scan Paths No. 1 and No. 2 Used for the Ultrasonic Examination of the Primary Tank Wall of 241-AY-102

The shell of Tank 241-AY-102 consists of four cylindrical rings. The top ring (Plate #1) is 4-ft high and has a nominal wall thickness of 0.375 in. The second and third rings (Plate #2 and Plate #3) are 10-ft high and have a nominal wall thickness of 0.500 in. Plate #4 is 8-ft high and has a nominal wall thickness of 0.75 in.^(a)

Two separate ultrasonic examinations were made for each of the scan paths of the tank wall shown in Figure S.1. The first examination (0-degree, straight-beam transducer) was designed to detect wall thinning and the presence of cracks. The second examination (± 45 -degree, angle-beam transducers) was designed to characterize any cracking that might be present in the wall of the primary tank.

A summary of the results is given below. More details are found in the body of the report.

- Plate #1—Scan Paths No. 1 and No. 2—the first examination of this plate recorded wall thickness (nominal 0.375 in.) ranging from a minimum of 0.383 in. to a maximum of 0.405 in. In the second examination, neither scan detected crack-like indications were in the wall of the primary tank.
- Plate #2—Scan Paths No. 1 and No. 2—the first examination of this plate recorded wall thickness (nominal 0.500 in.) ranging from a minimum of 0.485 in. to a maximum of 0.514 in. In the second examination, neither scan detected crack-like indications were in the wall of the primary tank.
- Plate #3—Scan Paths No. 1 and No. 2—the first examination of this plate recorded wall thickness (nominal 0.500 in.) ranging from a minimum of 0.485 in. to a maximum of 0.518 in. In the second examination, neither scan detected crack-like indications were in the wall of the primary tank.
- Plate #4—Scan Paths No. 1 and No. 2—the first examination of this plate recorded wall thickness (nominal 0.75 in.) ranging from a minimum of 0.735 in. to a maximum of 0.748 in. In the second examination, neither scan detected crack-like indications were in the wall of the primary tank.
- Several feet of vertical welds in Plates #3 and #4 were examined with 0-degree, ± 45 -degree and 60-degree transducers. No crack-like indications, wall thinning or pitting was detected in the HAZ of the welds in these examinations.
- Twenty feet of horizontal weld between Plates #2 and #3 were examined using the same technique used for the vertical welds. No crack-like indications, wall thinning or other indications were found in the HAZ of this weld.
- Welds between Plate #3 and #4 and the lower knuckle weld could not be examined because of surface roughness and contamination (weld and concrete splatter).

(a) Note: All historical dimensioning for the design, development, and construction of this tank are in English units; consequently, English units are the primary units used in this report. For conversion to metric, use 1.0 in. equals 25.4 mm.

Contents

Summary	iii
1.0 General Information.....	1
1.1 Specific Requirements	1
2.0 Results of the Examinations of the Vertical Wall of the Primary Tank 241-AY-102	1
3.0 Results Recorded in the Examination of Selected Vertical and Horizontal Welds	5
4.0 Concluding Comments.....	5

Figures

S.1 Sketch of Vertical Scan Paths No. 1 and No. 2 Used for the Ultrasonic Examination of the Primary Tank Wall.....	iv
---	----

Tables

1. Data from the Vertical UT Scan Paths on the Primary Tank Wall, Plate #1.....	3
2. Data from the Vertical UT Scan Paths on the Primary Tank Wall, Plate #2.....	3
3. Data from the Vertical UT Scan Paths on the Primary Tank Wall, Plate #3.....	4
4. Data from the Vertical UT Scan Paths on the Primary Tank Wall, Plate #4.....	4

1.0 General Information

The requirements for the ultrasonic examination of the wall of Tank 241-AY-102 were to detect, characterize (identify, size, and locate) and record measurements made of wall thickness, pitting or cracking in the wall or in the heat-affected zone (HAZ) of the welds in the primary tank. Any conditions that exceeded the requirements set forth below were to be reported for further examination.

1.1 Specific Requirements

Measurements that are to be specifically recorded include the following:

- Wall thinning that exceeds 10% of the nominal thickness of the plate
- Pits with depths that exceed 25% of the plate thickness
- Stress-corrosion cracks located on the inner wall of the primary tank or in the HAZ of welds that exceed a depth of 0.18 in.

The accuracy requirements for depth measurements for the different types of defects includes:

- Wall thinning—measure thickness within ± 0.02 in.
- Pits—size depths within ± 0.05 in.
- Cracks—size the depth of cracks on the inner wall surfaces within ± 0.100 in.
- Location—locate all reportable indications within ± 1.0 in.

Data to be recorded on disk and hard copies of all measurements are to be provided to PNNL and LMHC.

2.0 Results of the Examinations of the Vertical Wall of the Primary Tank 241-AY-102

Figure S.1 shows the two vertical scan paths taken on the full height of the tank. Each of the paths was 15-in. wide, providing a total of 30-in. coverage of the cylindrical section of the tank for the full height (32-ft) from the top weld to the knuckle weld. Two separate 15-in. wide scans (traverse direction on the scanning bridge of the mechanical crawler) were made. The first examination provided a measurement of wall thinning and/or pit corrosion using a straight beam (0-degree) transducer. The

second examination used two 45-degree opposing transducers and provided information on any cracks in the plates of the wall of the primary tank. Tables 1 through 4 describe the results of the two vertical examinations of the primary tank wall.

To initiate the examination, the remote mechanical crawler was inserted through the 24-in. riser and lowered until the magnetic wheels attached to the wall of the primary tank. The examination was then initiated by maneuvering the remote crawler until the transducer(s) were positioned at the top weld between the tank shell and the dome. The mechanical scanner was programmed to traverse a 15-in. scan, index down the tank wall and repeat the sequence until the entire height of the tank was examined. Pressurized water was used as a couplant between the transducer and the tank wall. The scan index (down the vertical wall) was 0.10 in. There were 120 traverse scans were taken for every foot of the height of the tank. The encoder on the scanner divided the 15-in. length of the traverse scan into pixels estimated to be 0.125-in. wide or 120 pixels. The ultrasonic data acquisition system recorded 14400 pixels for every foot of vertical scan path. Hard copy information was provided on an ultrasonic C-scan plot for each 12 by 15-in. area scanned. The analyst used this information in conjunction with the software program to determine and record the minimum value in each 12 by 15-in. area. The values in Tables 1 through 4 are the minimum values recorded in each area for the two scan paths. These values are part of the data recorded by the analyst on the "Automated Thickness Data Report." While only the minimum thickness is recorded on these reports, data are available to measure any individual pixel or point in the area scanned. In addition to the minimum thickness value reported, the tables also provide information regarding the results of the angle-beam examination that was designed to detect any cracking that might have been present in the tank wall. In the angle beam examination, two 45-degree angle-beam transducers were used. These angle-beam transducers were separated by approximately 5 in. and their beams were directed toward one another to obtain a volumetric inspection of the tank wall.

The tables provide information on the distance down from the top weld and the results obtained from the ultrasonic examination at each level. Interpreting the data in Table 1 from Plate #1, in the 1-ft section below the top weld (between the shell and the dome) the minimum thickness recorded was 0.398 in. in Scan Path No. 1 and 0.405 in Scan Path No. 2. The minimum wall thickness recorded in this 4-ft transition plate in Scan Path No. 2 between 2 and 3 ft. from the top weld where a value of 0.383 was measured. The nominal wall thickness was reported to be 0.375 in. and all thicknesses measured were above this value. The results of the 45-degree angle-beam examination recorded in the table showed no crack-like indications in either scan. Similar data interpretation can be made in the Tables 2, 3, and 4.

A review of the information in the tables shows that no anomalous conditions were detected by the ultrasonic examination. It is believed that these results are a representative sampling of the condition in the wall of the primary tank. No examination was performed on other portions of the primary or secondary tanks.

Table 1. Data from the Vertical UT Scan Paths on the Primary Tank Wall, Plate #1

Distance from the Top Weld (ft)	Results from the Ultrasonic Examination of Plate #1. Vertical Scan Path No. 1		Results from the Ultrasonic Examination of Plate #1. Vertical Scan Path No. 2	
	Minimum Thickness Recorded in Area Scanned (in.)	45-Degree Angle Beam Examination	Minimum Thickness Recorded in Area Scanned (in.)	45-Degree Angle Beam Examination
0 to 1	0.398	No crack-like indications were detected in this plate	0.405	No crack-like indications were detected in this plate
1 to 2	0.398		0.395	
2 to 3	0.395		0.383	
3 to 4	0.398		0.390	

Table 2. Data from the Vertical UT Scan Paths on the Primary Tank Wall, Plate #2

Distance from the Top Weld (ft)	Results from the Ultrasonic Examination of Plate #2. Vertical Scan Path No. 1		Results from the Ultrasonic Examination of Plate #2. Vertical Scan Path No. 2	
	Minimum Thickness Recorded in Area Scanned (in.)	45-Degree Angle Beam Examination	Minimum Thickness Recorded in Area Scanned (in.)	45-Degree Angle Beam Examination
4 to 5	0.495	No crack-like indications were detected during the examination of this plate	0.493	No crack-like indications were detected during the examination of this plate
5 to 6	0.500		0.493	
6 to 7	0.510		0.495	
7 to 8	0.510		0.498	
8 to 9	0.503		0.498	
9 to 10	0.503		0.498	
10 to 11	0.508		0.493	
11 to 12	0.518		0.490	
12 to 13	0.514		0.485	
13 to 14	0.514		0.493	

Table 3. Data from the Vertical UT Scan Paths on the Primary Tank Wall, Plate #3

Distance from the Top Weld (ft)	Results from the Ultrasonic Examination of Plate #3. Vertical Scan Path No. 1		Results from the Ultrasonic Examination of Plate #3. Vertical Scan Path No. 2	
	Minimum Thickness Recorded in Area Scanned (in.)	45-Degree Angle Beam Examination	Minimum Thickness Recorded in Area Scanned (in.)	45-Degree Angle Beam Examination
14 to 15	0.500	No crack-like indications were detected during the examination of this plate	0.490	No crack-like indications were detected during the examination of this plate
15 to 16	0.518		0.485	
16 to 17	0.510		0.490	
17 to 18	0.508		0.488	
18 to 19	0.508		0.490	
19 to 20	0.508		0.490	
20 to 21	0.503		0.490	
21 to 22	0.498		0.490	
22 to 23	0.495		0.493	
23 to 24	0.510		0.498	

Table 4. Data from the Vertical UT Scan Paths on the Primary Tank Wall, Plate #4

Distance from the Top Weld (ft)	Results from the Ultrasonic Examination of Plate #4. Vertical Scan Path No. 1		Results from the Ultrasonic Examination of Plate #4. Vertical Scan Path No. 2	
	Minimum Thickness Recorded in Area Scanned (in.)	45-Degree Angle Beam Examination	Minimum Thickness Recorded in Area Scanned (in.)	45-Degree Angle Beam Examination
24 to 25	0.735	No crack-like indications were detected during the examination of this plate	0.739	No crack-like indications were detected during the examination of this plate
25 to 26	0.748		0.739	
26 to 27	0.757		0.743	
27 to 28	0.739		0.743	
28 to 29	0.744		0.743	
29 to 30	0.748		0.734	
30 to 31	0.744		0.739	
31 to 32	0.739		0.743	

3.0 Results Recorded in the Examination of Selected Vertical and Horizontal Welds

An ultrasonic examination was performed to detect stress corrosion cracks, wall thinning and pitting in the HAZ of a selected number of welds. Since stress corrosion cracks could lie perpendicular or parallel to the weld line, two separate examinations were performed. The first examination used a pair of 45-degree opposing transducers to detect and characterize cracks that might lie perpendicular to the weld line. In the second examination a straight beam (0-degree) transducer was used to detect wall thinning and corrosion, and a 60-degree transducer was used to detect and characterize cracks that might lie parallel to the weld line. The HAZ was defined as that area that lies on the inner 3/4 T (thickness) of the plate and extending 1.0 in. from the edge of the weld bead. The following lists the welds that were examined. Because of interference between the transducer housing and the weld bead, a blind zone existed from the edge of the weld bead to 1/2 in. into the base metal.

- Vertical weld in Plate #3—10 ft of the HAZ of this plate was examined with the 0-degree, 45-degree and 60-degree transducers. No crack-like indications, wall thinning or pitting was detected in any of the examinations.
- Vertical weld in Plate #4—9 ft of the HAZ of this plate was examined with the 0-degree, 45-degree and 60-degree transducers. No crack-like indications, wall thinning or pitting was detected in any of the examinations.
- Horizontal weld between Plates #2 and #3—24 ft of the horizontal weld between Plates #2 and #3 were examined with the 0-degree, 45-degree and 60-degree transducers. No crack-like indications, wall thinning or pitting was detected in any of these examinations.

Comment #1: The horizontal weld between Plates #3 and #4 could not be examined ultrasonically because of surface roughness, weld spatter, and other conditions on the surface of the plate in the HAZ that prevented the transducers from maintaining ultrasonic contact with the plate.

Comment #2: The knuckle weld could not be examined ultrasonically because of the concrete spatter on the surface of the tank in the weld area that caused the transducer to lift off the surface and prevented consistent ultrasonic coupling of the acoustic energy.

4.0 Concluding Comments

The two 15-in. wide ultrasonic examinations were made on the full height of the primary tank wall of Tank 241-AY-102 to detect wall thinning, pitting and cracks. These examinations in the vertical tank wall were intended to sample the condition of the tank and to provide information that could be used to

establish the tank's integrity. The results of the examinations in the selected areas showed very little or no corrosion in the four plates that go to make up the shell of the primary tank. Further, no crack-like indications were detected in the wall of the primary tank.

The HAZ of the vertical welds in Plates #3 and #4 and the horizontal weld between Plates #2 and #3 were examined to detect stress-corrosion cracks, pitting, and wall thinning. The ultrasonic examination did not detect wall thinning in excess of 4% of the nominal wall thickness in the HAZ and found no crack-like indications from cracks that might lie in either parallel or perpendicular to the weld line. No abnormal indications were found in the heat-affected zone of the welds examined.

Based on the results of the ultrasonic examinations in the areas examined, Tank 241-AY-102 has no apparent wall thinning greater than the nominal wall thickness that might be expected from manufacturing variations and has no detectable cracks in the wall of the primary tank.

ATTACHMENT 2

241-AY-102 Double-Shell Tank Ultrasonic Examination Data Reports With Data Sheets

COGEMA-99-1017

June 30, 1999

COGEMA-99-1017

Mr. Chris E. Jensen
Lockheed Martin Hanford Corporation
Post Office Box 1500, MSIN R1-56
Richland, Washington 99352-1505

Dear Mr. Jensen:

AY-102 DOUBLE SHELL TANK ULTRASONIC EXAMINATION DATA REPORTS

Ultrasonic examination of double shell tank (DST) AY-102 was completed on June 4, 1999. The primary tank data showed no reportable indications. Primary tank wall areas ultrasonically inspected were two vertical wall scans approximately 15 inches wide by 30 feet long, and 19 feet of the vertical weld and 25 feet of horizontal welds.

The project specification required an ultrasonic inspection of the horizontal weld between the bottom transition plate and the knuckle. However due to concrete material adhered to the inspection surface examination of the weld was not possible. With LMHC concurrence the horizontal weld between plates 1 and 2 was substituted for the weld between the bottom transition plate and the knuckle.

COGEMA Engineering is pleased to provide the enclosed AY-102 DST Ultrasonic Examination Calibration Sheets and Ultrasonic Data Reports. This completes our nondestructive examination of DST AY-102. The original ultrasonic report was transferred to Mr. Jerry Posakony at PNNL for final evaluation.

If you have any questions, please feel free to contact me at (509) 376-5403.

Sincerely,


W. H. Nelson
COGEMA NDE Ultrasonic Level III

cjl

Enclosure

P.O. Box 840
Richland, Washington 99352-0840
Phone (509) 372-3572 • Fax (509) 372-3169

2/99 AUTOMATED ULTRASONIC THICKNESS CALIBRATION SHEET							CALIBRATION REPORT# N/A		
LOCATION <i>Hawford</i>		SYSTEM <i>DST TANK 4Y102</i>		CALIBRATION BLOCK <i>SDI PT-1 / STEP BLK.</i>					
PROCEDURE <i>SDI 2.1 Rev. 3</i>				THICKNESS <i>0.75" / 0.1-1.00</i>		MATERIAL <i>CS / CS</i>			
UT SYSTEM <i>PSP-3</i>		SERIAL # <i>305</i>		REFERENCE BLOCK <i>IIW</i>					
SOFTWARE VERSION <i>P-scan / T-scan</i>		REV. <i>6.05</i>		THICKNESS <i>4" SP / 1" T</i>		MATERIAL <i>CS</i>			
LINEARITY DUE DATE <i>6/15/99</i>				REFERENCE BLOCK TEMP <i>AMBIENT</i> OF		PYRO SN. <i>N/A</i>			
SCANNER TYPE <i>AWS-5D</i>		SERIAL # <i>105</i>		COUPLANT <i>WATER</i>		BATCH # <i>N/A</i>			
SCANNER CABLE <i>AWS-5D</i>				CABLE LENGTH <i>400'</i>		CABLE # <i>N/A</i>			
SIGNAL CABLE <i>RG 59</i>				CABLE LENGTH <i>400'</i>		CABLE # <i>N/A</i>			
CHANNEL	TRANSDUCER MAKE	MODEL	FREQ.	SIZE	SERIAL #	GATE EVAL METHOD	ANGLE	WEDGE TYPE	IMAGE
1	<i>KrautKramer</i>	<i>MSEB 5E</i>	<i>5</i>	<i>2(8x2mm)</i>	<i>1642</i>	<i>EDGE CONT</i>	<i>0°</i>	<i>STND</i>	<i>1</i>
2	<i>KrautKramer</i>	<i>MSEB 5E</i>	<i>5</i>	<i>2(8x2mm)</i>	<i>1642</i>	<i>PRK CONT</i>	<i>0°</i>	<i>STND</i>	<i>2</i>
3	<i>KrautKramer</i>	<i>MSEB 5E</i>	<i>5</i>	<i>2(8x2mm)</i>	<i>1637</i>	<i>EDGE CONT</i>	<i>0°</i>	<i>STND</i>	<i>3</i>
4	<i>KrautKramer</i>	<i>MSEB 5E</i>	<i>5</i>	<i>2(8x2mm)</i>	<i>1637</i>	<i>PRK CONT</i>	<i>0°</i>	<i>STND</i>	<i>4</i>
INITIAL CALIBRATION			CALIBRATION CHECKS						
DATE	<i>5/2/99</i>	<i>5/11/99</i>	<i>5/11/99</i>						
TIME	<i>1430</i>	<i>0959</i>	<i>2055</i>						
REFLECTOR	<i>BACKWALL</i>	<i>BACKWALL</i>	<i>BACKWALL</i>						
CH. 1	THK. 1	<i>0.30</i>	<i>0.301</i>	<i>0.305</i>	<i>0.305</i>				
	THK. 2	<i>1.00</i>	<i>1.000</i>	<i>1.000</i>	<i>1.000</i>				
CH. 2	THK. 1	<i>0.315</i>	<i>0.301</i>	<i>0.502</i>	<i>0.502</i>				
	THK. 2	<i>1.00</i>	<i>1.001</i>	<i>1.000</i>	<i>1.000</i>				
CH. 3	THK. 1	<i>0.3</i>	<i>0.301</i>	<i>0.296</i>	<i>0.280</i>				
	THK. 2	<i>1.00</i>	<i>1.000</i>	<i>0.995</i>	<i>0.987</i>				
CH. 4	THK. 1	<i>0.3105</i>	<i>0.296</i>	<i>0.493</i>	<i>0.480</i>				
	THK. 2	<i>1.00</i>	<i>0.996</i>	<i>0.991</i>	<i>0.982</i>				
FILE #	<i>A42CL201</i>	<i>A42CL202</i>	<i>A42CL203</i>						
DISK #	<i>A42PW14</i>	<i>A42PW14</i>	<i>A42PW18</i>						
EXAMINER	<i>QJZ</i>	<i>QJZ</i>	<i>QJZ</i>						
REMARKS									
Examiner <i>James B. Elders</i>		Examiner <i>N/A</i>		Reviewer <i>W. J. Nelson</i>			Page <i>1 of 30</i>		
Level <i>III</i> Date <i>5/11/99</i>		Level <i> </i> Date <i> </i>		Level <i>III</i> Date <i>6-4-99</i>					
<i>COGEMA</i>									

AUTOMATED ULTRASONIC THICKNESS CALIBRATION SHEET							CALIBRATION REPORT#			
2/99							N/A			
LOCATION <i>HARFORD</i>		SYSTEM <i>DST TANK AY102</i>			CALIBRATION BLOCK <i>STEP BLK</i>					
PROCEDURE <i>SDI 2.1 Rev. 3</i>					THICKNESS <i>0.1 - 1.00</i>		MATERIAL <i>CS</i>			
UT SYSTEM <i>PSG-3</i>		SERIAL # <i>305</i>			REFERENCE BLOCK <i>JIW</i>					
SOFTWARE VERSION <i>D-Scan/7-Scan</i>		REV. <i>6.05</i>			THICKNESS <i>1"</i>		MATERIAL <i>CS</i>			
LINEARITY DUE DATE <i>6/15/99</i>					REFERENCE BLOCK TEMP <i>AMBIENT</i> °F		PYRO SN. <i>N/A</i>			
SCANNER TYPE <i>AWS-5D</i>		SERIAL # <i>105</i>			COUPLANT <i>WATER</i>		BATCH # <i>N/A</i>			
SCANNER CABLE <i>AWS-5D</i>					CABLE LENGTH <i>400'</i>		CABLE # <i>N/A</i>			
SIGNAL CABLE <i>RG 59</i>					CABLE LENGTH <i>400'</i>		CABLE # <i>N/A</i>			
CHANNEL	TRANSDUCER MAKE	MODEL	FREQ.	SIZE	SERIAL #	GATE EVAL METHOD	ANGLE	WEDGE TYPE	IMAGE	
1	<i>KrautKramer</i>	<i>MSEB 5E</i>	<i>5</i>	<i>2(8x2mm)</i>	<i>1642</i>	<i>EDGE 10NT</i>	<i>0°</i>	<i>STND</i>	<i>1</i>	
2	<i>KrautKramer</i>	<i>MSEB 5E</i>	<i>5</i>	<i>2(8x2mm)</i>	<i>1642</i>	<i>PKE 10NT</i>	<i>0°</i>	<i>STND</i>	<i>2</i>	
3			<i>2</i>							
4				<i>A</i>						
INITIAL CALIBRATION			CALIBRATION CHECKS							
DATE	<i>5/2/99</i>	<i>5/3/99</i>	<i>5/8/99</i>	<i>5/14/99</i>	<i>5/14/99</i>					
TIME	<i>1612</i>	<i>1010</i>	<i>2130</i>	<i>0914</i>	<i>2151*</i>					
REFLECTOR	<i>STEP BLK</i>	<i>STEP BLK</i>	<i>STEP BLK</i>	<i>STEP BLK</i>	<i>STEP BLK</i>					
CH. 1	THK.1 <i>0.3</i>	<i>0.305</i>	<i>0.305</i>	<i>0.301</i>	<i>0.305</i>	<i>0.289</i>				
	THK.2 <i>1.0</i>	<i>1.004</i>	<i>1.009</i>	<i>1.009</i>	<i>1.004</i>	<i>0.991</i>				
CH. 2	THK.1 <i>0.3</i>	<i>0.305</i>	<i>0.305</i>	<i>0.301</i>	<i>0.305</i>	<i>0.287</i>				
	THK.2 <i>1.0</i>	<i>1.004</i>	<i>0.995</i>	<i>0.995</i>	<i>1.009</i>	<i>0.991</i>				
CH. 3	THK.1									
	THK.2	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>				
CH. 4	THK.1	<i>A</i>	<i>A</i>	<i>A</i>	<i>A</i>	<i>A</i>				
	THK.2									
FILE #	<i>A42-C101</i>	<i>A42-C102</i>	<i>A42-C103</i>	<i>A42-C104</i>	<i>A42-C105</i>					
DISK #	<i>A42-PW1</i>	<i>A42-PW1</i>	<i>A42-PW3</i>	<i>A42-PW4</i>	<i>A42-PW6</i>					
EXAMINER	<i>gbb</i>	<i>gbb</i>	<i>gbb</i>	<i>gbb</i>	<i>gbb</i>					
REMARKS										
<i>* Unable to meet 12hr. due to radiological issues. Cal. OK. gbb</i>										
Examiner <i>James B. Elder</i>		Examiner <i>N/A</i>			Reviewer <i>W.H. Nelson</i>			Page		
Level <i>III</i> Date <i>5/14/99</i>		Level <i>N/A</i> Date <i>N/A</i>			Level <i>III</i> Date <i>6.4.99</i>			2 of 30		
<i>COGEMA</i>										

AUTOMATED ULTRASONIC P-SCAN CALIBRATION SHEET							CALIBRATION REPORT#						
LOCATION <i>Handford</i>							SYSTEM <i>DST TRUCK A402</i>			CALIBRATION BLOCK <i>SDI PT-1</i>			
PROCEDURE <i>SDI 2.1 Res.3</i>							THICKNESS <i>0.75</i>		MATERIAL <i>CS</i>				
UT SYSTEM <i>PSP-3</i>			SERIAL # <i>305</i>				REFERENCE BLOCK <i>ITW 4"</i>						
SOFTWARE VERSION <i>P-Scan/T-Scan</i>			REV. <i>6.05</i>				THICKNESS <i>4" SP</i>		MATERIAL <i>CS</i>				
LINEARITY DUE DATE <i>6/15/99</i>							REFERENCE BLOCK TEMP <i>AMBIENT</i> °F			PYRO SN. <i>N/A</i>			
SCANNER TYPE <i>AWS-5D</i>			SERIAL # <i>105</i>				COUPLANT <i>WATER</i>			BATCH # <i>N/A</i>			
SCANNER CABLE <i>AWS-D</i>							CABLE LENGTH <i>400'</i>		CABLE # <i>N/A</i>				
SIGNAL CABLE <i>RG 59</i>							CABLE LENGTH <i>400'</i>		CABLE # <i>N/A</i>				
CHANNEL	TRANSDUCER MAKE	MODEL	FREQ.	SIZE	SERIAL #	GATE EVAL METHOD	ANGLE NOM. FACT.	WEDGE TYPE	IMAGE				
1	Krautkramer	MWB 45 YE	4	8x9mm	2423	ICODE 20	45/44	STND	<i>1/2</i>				
2	Krautkramer	MWB 45 YE	4	8x9mm	2412	ICODE 20	45/44	STND	<i>3/4</i>				
3													
4					<i>A</i>								
INITIAL CALIBRATION					CALIBRATION CHECKS								
DATE	<i>5/5/99</i>	<i>5/5/99</i>	<i>5/6/99</i>	<i>5/6/99</i>									
TIME	<i>1736</i>	<i>7241</i>	<i>1007</i>	<i>2045</i>									
REFLECTOR / ORIENTATION	<i>0.05" ID notch</i>	<i>0.05" ID notch</i>	<i>0.05" ID notch</i>	<i>0.05" ID notch</i>									
CH. 1	AMPLITUDE	<i>75dB (+1dB)</i>	<i>+0dB</i>	<i>75 +0dB</i>	<i>+1dB</i>								
	LOCATION	<i>ID</i>	<i>ID</i>	<i>ID</i>	<i>ID</i>								
CH. 2	AMPLITUDE	<i>72dB (+1dB)</i>	<i>+2dB</i>	<i>74 +0dB</i>	<i>+1dB</i>								
	LOCATION	<i>ID</i>	<i>ID</i>	<i>ID</i>	<i>ID</i>								
CH. 3	AMPLITUDE	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>								
	LOCATION	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>	<i>N/A</i>								
CH. 4	AMPLITUDE	<i>A</i>	<i>A</i>	<i>A</i>	<i>A</i>								
	LOCATION	<i>A</i>	<i>A</i>	<i>A</i>	<i>A</i>								
FILE #	<i>A42CL4A1</i>	<i>A42CL4A2</i>	<i>A42CL4A3</i>	<i>A42CL4A4</i>									
DISK #	<i>A42PW7</i>	<i>A42PW10</i>	<i>A42PW11</i>	<i>A42PW13</i>									
EXAMINER	<i>CRZ</i>	<i>CRZ</i>	<i>CRZ</i>	<i>CRZ</i>									
REMARKS	<i>N/A</i>												
Examiner	<i>[Signature]</i>			Examiner	<i>N/A</i>			Reviewer	<i>[Signature]</i>				
Level III	Date <i>5/6/99</i>			Level	Date			Level <i>III</i>	Date <i>6.4.99</i>				
									<i>COGLIMA</i>				
									Page <i>3</i> of <i>30</i>				

AUTOMATED ULTRASONIC P-SCAN CALIBRATION SHEET							CALIBRATION REPORT#			
LOCATION HANFORD		SYSTEM DST		CALIBRATION BLOCK SDI PT-1						
PROCEDURE SDI 2.1 REV. 3				THICKNESS 0.75"		MATERIAL CS				
UT SYSTEM PSP-3		SERIAL # 305		REFERENCE BLOCK ITW						
SOFTWARE VERSION P-SCAN/T-SCAN			REV. 6.05		THICKNESS 1" 4" SP		MATERIAL CS			
LINEARITY DUE DATE 6-15-99				REFERENCE BLOCK TEMP AMBIENT °F			PYRO SN. N/A			
SCANNER TYPE AWS-5D		SERIAL # 105		COUPLANT WATER			BATCH # N/A			
SCANNER CABLE AWS-5D				CABLE LENGTH 400'		CABLE # N/A				
SIGNAL CABLE RG-59				CABLE LENGTH 400'		CABLE # N/A				
CHANNEL	TRANSDUCER MAKE	MODEL	FREQ.	SIZE	SERIAL #	GATE EVAL METHOD	ANGLE NOM./ACT.	WEDGE TYPE	IMAGE	
1	KBA	MWB45-04	4 Mhz	8 x 9mm	30042	/	45°/44°	INT.	1	
2	KBA	MWB45-04	4 Mhz	8 x 9mm	2415	N/A	45°/44°	INT.	2	
3	KBA	MWB45-04	4 Mhz	8 x 9mm	2423	/A	45°/44°	INT.	3	
4	KBA	MWB45-04	4 Mhz	8 x 9mm	2412	/	45°/46°	INT.	4	
INITIAL CALIBRATION			CALIBRATION CHECKS							
DATE		5-15-99	5-15-99							
TIME		09:53	14:13							
REFLECTOR / ORIENTATION		.050" ID NOTCH	.050" ID NOTCH							
CH. 1	AMPLITUDE	81 dB	81 dB							
	LOCATION	ID	ID							
CH. 2	AMPLITUDE	80 dB	79 dB							
	LOCATION	ID	ID							
CH. 3	AMPLITUDE	78 dB	80							
	LOCATION	ID	ID							
CH. 4	AMPLITUDE	81 dB	80 dB							
	LOCATION	ID	ID							
FILE #		AY2CL4C1	AY2CL4C2							
DISK #		P45C-1	P45C-4							
EXAMINER		R. SWAIN	R. SWAIN							
REMARKS										
N/A										
Examiner Ronald V. Swain		Examiner N/A		Reviewer W. J. Nelson			Page 4 of 30			
Level II Date 5-15-99		Level A Date 5-15-99		Level III Date 6-4-99						
COGEMA										

2/99 AUTOMATED ULTRASONIC P-SCAN CALIBRATION SHEET							CALIBRATION REPORT# N/A		
LOCATION HANFORD		SYSTEM DST		CALIBRATION BLOCK SDI PT-1					
PROCEDURE SDI 2.1		REV. 3		THICKNESS 0.75"		MATERIAL CS			
UT SYSTEM PSP-3		SERIAL # 305		REFERENCE BLOCK TW					
SOFTWARE VERSION P-SCAN / T-SCAN		REV. 6.05		THICKNESS 1" 4" S.P.		MATERIAL CS			
LINEARITY DUE DATE 6-15-99		REFERENCE BLOCK TEMP AMBIENT °F		PYRO SN N/A		BATCH # N/A			
SCANNER TYPE AWS-5D		SERIAL # 105		COUPLANT WATER		BATCH # N/A			
SCANNER CABLE AWS-5D		CABLE LENGTH 400'		CABLE # N/A		BATCH # N/A			
SIGNAL CABLE RG-59		CABLE LENGTH 400'		CABLE # N/A		BATCH # N/A			
CHANNEL	TRANSDUCER MAKE	MODEL	FREQ.	SIZE	SERIAL #	GATE EVAL METHOD	ANGLE NOM./ACT.	WEDGE TYPE	IMAGE
1	KBA	MWB60-4E	4 MHz	8x9mm	1855	N	10°/59°	INT.	1 & 2
2	KBA	MWB60-4E	4 MHz	8x9mm	1854	A	60°/59°	INT.	3 & 4
3				N					
4				A					
INITIAL CALIBRATION			CALIBRATION CHECKS						
DATE	5-14-99	5-14-99							
TIME	0930	17:16							
REFLECTOR / ORIENTATION	0.050" ID NOTCH	0.050" ID NOTCH							
CH. 1	AMPLITUDE	64 dB	64 dB						
	LOCATION	ID	ID						
CH. 2	AMPLITUDE	66 dB	66 dB						
	LOCATION	ID	ID						
CH. 3	AMPLITUDE								
	LOCATION	N							
CH. 4	AMPLITUDE		A						
	LOCATION								
FILE #	AY2CLLAI	AY2CLLAZ							
DISK #	PL0A-1	PL0A-5							
EXAMINER	R. SWAIN	R. SWAIN							
REMARKS									
N/A									
Examiner <i>Ronald V. Swain</i> Level II Date 5-14-99			Examiner <i>N</i> Level <i>A</i> Date <i>A</i>			Reviewer <i>W. Deban</i> Level <i>II</i> Date 6-4-99 COGEMA		Page 5 of 30	

2/99 AUTOMATED ULTRASONIC THICKNESS DATA REPORT							REPORT# <i>N/A</i>	
							REF. CAL. # <i>N/A</i>	
LOCATION <i>HANFORD</i>		SYSTEM <i>DST TANK AY102</i>		EXAM START <i>1045</i>	EXAM END <i>1130</i>	JOB # <i>N/A</i>		
COMPONENT ID <i>PRIMARY WALL TOP TRANSITION PLATE 0°</i>				EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED		NOM. THICKNESS <i>0.375"</i>		
CONFIGURATION TO <i>TOP TRANSITION PLATE SCAN 1,0°</i>				CALIBRATED RANGE <i>0.3-1.0</i>		TEMP AMBIENT °F		
CIRCUMFERENCE/TOTAL LENGTH EXAMINED <i>36.6"</i>		SCAN LENGTH/PART <i>12"</i>		REF. LEVEL CORRECTION (TRANS. CORR) <i>0</i> DB				
PROCEDURE <i>SDI 2.1</i>			REV <i>3</i>	MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER		CONDITION <i>Fair</i>		
FILE NAME/ITEM# <i>A42PWST10</i>		DATA DISK#		TRANSDUCER <input checked="" type="checkbox"/> DUAL <input type="checkbox"/> SGL <input checked="" type="checkbox"/> ODEG <input type="checkbox"/> ANGLE				
X ₀ REF. POINT (Lo) <i>1" below Haunch weld toe</i>		Y ₀ REF. POINT (Wo) <i>~ E of 24" Riser</i>		SCAN WIDTH <i>15"</i>				
PART #/ INDICATION	L START	L STOP	W START	W STOP	AVE. THK.	MIN. THK, R. LIG.	AREA REPORTABLE	COMMENTS
<i>1</i>					<i>.418</i>	<i>.398</i>	<i>NO</i>	
<i>2</i>		<i>N</i>			<i>.416</i>	<i>.398</i>	<i>NO</i>	<i>N</i>
<i>3</i>			<i>A</i>		<i>.412</i>	<i>.395</i>	<i>NO</i>	<i>A</i>
<i>4</i>					<i>.413</i>	<i>.398</i>	<i>NO</i>	<i>A</i>
<i>N</i>								
<i>A</i>								
SUMMARY								
MERGED RESULTS								
REMARKS								
Examiner <i>James B. Ede</i> Level <u>III</u> Date <u>5/11/99</u>			Analyst <i>James B. Ede</i> Level <u>III</u> Date <u>5/13/99</u>			Reviewer <i>W.D. Nelson</i> Level <u>IV</u> Date <u>6-4-99</u> COGEMA		Page <i>6</i> of <i>30</i>

AUTOMATED ULTRASONIC THICKNESS DATA REPORT							REPORT#	
							N/A	
							REF. CAL. #	
							N/A	
LOCATION HANFORD		SYSTEM DST AY102		EXAM START 1150	EXAM END 1411	JOB # N/A		
COMPONENT ID AY102 PRIMARY WALL PLATE 1 SCAM 1 0°				EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED		NOM. THICKNESS 1/2"		
CONFIGURATION TOP TRANS. PLATE TO PLATE 1				CALIBRATED RANGE 0.3 - 1.0 "		TEMP AMBIENT °F		
CIRCUMFERENCE/TOTAL LENGTH EXAMINED 114 1/2"		SCAN LENGTH/PART 12"		REF. LEVEL CORRECTION (TRANS. CORR) +3 DB				
PROCEDURE SDI 2.1			REV 3	MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER		CONDITION fair		
FILE NAME/ITEM# A42R0110		DATA DISK#		TRANSDUCER <input checked="" type="checkbox"/> DUAL <input type="checkbox"/> SGL <input checked="" type="checkbox"/> ODEG <input type="checkbox"/> ANGLE				
X ₀ REF. POINT (L ₀) -1" from toe of well		Y ₀ REF. POINT (W ₀) -7" cw of Riser E (24")		SCAN WIDTH 15"				
PART #/ INDICATION	L START	L STOP	W START	W STOP	AVE. THK.	MIN. THK. R. LIG.	AREA REPORTABLE	COMMENTS
1					.535	.495	NO	
2					.533	.500	NO	
3					.531	.510	NO	
4					.533	.510	NO	
5					.538	.503	NO	
6					.538	.503	NO	
7					.536	.508	NO	
8					.537	.518	NO	
9					.535	.514	NO	
10					.532	.514	NO	
N/A								
SUMMARY MERGED RESULTS								
REMARKS								
N/A								
Examiner <u>James B. Eber</u> Level III Date <u>5/3/99</u>			Analyst <u>James B. Eber</u> Level III Date <u>5/12/99</u>			Reviewer <u>W. J. Nelson</u> Level III Date <u>6-4-99</u> COGEMA		Page <u>7</u> of <u>30</u>

AUTOMATED ULTRASONIC THICKNESS DATA REPORT							REPORT#	
2/99							N/A	
LOCATION <u>Hanford</u>							REF. CAL. #	
SYSTEM <u>DST TANK AY102</u>			EXAM START <u>1445</u>		EXAM END <u>1700</u>		JOB # <u>N/A</u>	
COMPONENT ID <u>PRIMARY WALL, PLATE 2, SCAM 1 0°</u>				EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED			NOM. THICKNESS <u>1/2"</u>	
CONFIGURATION TO <u>PLATE 2</u>				CALIBRATED RANGE <u>0.3-1.0</u>			TEMP AMBIENT °F	
CIRCUMFERENCE/TOTAL LENGTH EXAMINED <u>115"</u>			SCAN LENGTH/PART <u>12</u>		REF. LEVEL CORRECTION (TRANS. CORR) <u>3</u> DB			
PROCEDURE <u>SDI 2.1</u>			REV <u>3</u>		MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER			CONDITION <u>fair</u>
FILE NAME/ITEM# <u>A42PW210</u>			DATA DISK#			TRANSDUCER <input checked="" type="checkbox"/> DUAL <input type="checkbox"/> SGL <input checked="" type="checkbox"/> ODEG <input type="checkbox"/> ANGLE		
X ₀ REF. POINT (L ₀) <u>1" from toe of weld</u>			Y ₀ REF. POINT (W ₀) <u>~7" cw from 24" riser E</u>			SCAN WIDTH <u>15</u>		
PART # / INDICATION	L START	L STOP	W START	W STOP	AVE. THK.	MIN. THK. R. LIG.	AREA REPORTABLE	COMMENTS
1					.535	.500	NO	N/A
2					.526	.518	NO	
3					.535	.510	NO	
4					.537	.508	NO	
5					.537	.508	NO	
6					.534	.508	NO	
7					.533	.503	NO	
8					.534	.498	NO	
9					.536	.495	NO	
10					.540	.510	NO	
SUMMARY								
MERGED RESULTS								
REMARKS								
N/A								
Examiner <u>James B. Ellen</u>			Analyst <u>James B. Ellen</u>			Reviewer <u>W.A. Nelson</u>		Page
Level <u>III</u> Date <u>5/3/99</u>			Level <u>III</u> Date <u>5/12/99</u>			Level <u>III</u> Date <u>6-4-99</u>		8 of 30
COGEMA								

AUTOMATED ULTRASONIC THICKNESS DATA REPORT							REPORT#		
2/99							N/A		
LOCATION <u>Hanford</u>							REF. CAL. #		
SYSTEM <u>DST TASK AY102</u>			EXAM START <u>1210</u>		EXAM END <u>1510</u>		JOB # <u>N/A</u>		
COMPONENT ID <u>PRIMARY WALL PLATE 1, SCAN 2</u>			EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED			NOM. THICKNESS <u>1/2"</u>			
CONFIGURATION <u>TO PLATE 1 0°</u>			CALIBRATED RANGE <u>0.3-1.0"</u>			TEMP AMBIENT OF			
CIRCUMFERENCE/TOTAL LENGTH EXAMINED <u>113.8"</u>			SCAN LENGTH/PART <u>12</u>		REF. LEVEL CORRECTION (TRANS. CORR) <u>0</u> DB				
PROCEDURE <u>SDI 2.1</u>			REV <u>3</u>		MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER		CONDITION <u>Fair</u>		
FILE NAME/ITEM# <u>AY2PW120</u>			DATA DISK#		TRANSDUCER <input checked="" type="checkbox"/> DUAL <input type="checkbox"/> SGL <input checked="" type="checkbox"/> ODEG <input type="checkbox"/> ANGLE		SCAN WIDTH <u>15"</u>		
X ₀ REF. POINT (L ₀) <u>1" below weld</u>			Y ₀ REF. POINT (W ₀) <u>~12" ccw from 24" riser &</u>						
PART #/ INDICATION	L START	L STOP	W START	W STOP	AVE. THK.	MIN. THK, R. LIG.	AREA REPORTABLE	COMMENTS	
1					.509	.493	NO		
2					.507	.493	NO		
3					.508	.485	NO		
4					.509	.498	NO		
5					.511	.498	NO		
6					.512	.498	NO		
7					.513	.493	NO		
8					.509	.490	NO		
9					.507	.485	NO		
10					.510	.493	NO		
SUMMARY MERGED RESULTS									
REMARKS									
Examiner <u>James B. Elden</u>			Analyst <u>James B. Elden</u>			Reviewer <u>W. H. Nelson</u>		Page	
Level <u>III</u> Date <u>5/4/99</u>			Level <u>III</u> Date <u>5/12/99</u>			Level <u>III</u> Date <u>6-4-99</u>		11 of 30	
COGEMA									

AUTOMATED ULTRASONIC THICKNESS DATA REPORT						REPORT#		REF. CAL. #		
2/99						N/A		N/A		
LOCATION HARFORD 200E		SYSTEM DST TANK AY102		EXAM START 1600		EXAM END 1729		JOB # N/A		
COMPONENT ID AY102 PRIMARY WALL PLATE 2 SCAN 2 0°				EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED			NOM. THICKNESS 0.5"			
CONFIGURATION TO PLATE 2				CALIBRATED RANGE 0.3" - 1.00"			TEMP AMBIENT °F			
CIRCUMFERENCE/TOTAL LENGTH EXAMINED 115		SCAN LENGTH/PART 12"		REF. LEVEL CORRECTION (TRANS. CORR)			0 DB			
PROCEDURE SDI 2.1			REV 3		MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER			CONDITION fair		
FILE NAME/ITEM# AY2 PW220		DATA DISK#			TRANSDUCER <input checked="" type="checkbox"/> DUAL <input type="checkbox"/> SGL <input checked="" type="checkbox"/> ODEG <input type="checkbox"/> ANGLE					
X ₀ REF. POINT (L ₀) ~ 1" from toe of weld		Y ₀ REF. POINT (W ₀) ~ 12" from hizer & (23" aw from weld)			SCAN WIDTH 15"					
PART #/ INDICATION	L START	L STOP	W START	W STOP	AVE. THK.	MIN. THK. R. LIG.	AREA REPORTABLE	COMMENTS		
1					.500	0.490	NO	N/A		
2					.500	.485	NO			
3					.505	.490	NO			
4					.510	.498	NO			
5					.513	.490	NO			
6					.508	.490	NO			
7					.505	.490	NO			
8					.508	.490	NO			
9					.513	.493	NO			
10					.510	.498	NO			
SUMMARY										
MERGED RESULTS										
REMARKS										
N/A										
Examiner <i>James B. Miller</i>		Analyst <i>James B. Miller</i>			Reviewer <i>W.H. Nelson</i>			Page		
Level III Date 5/4/99		Level III Date 5/11/99			Level III Date 6-4-99			12 of 30		
COGEMA										

AUTOMATED ULTRASONIC THICKNESS DATA REPORT							REPORT#	
							N/A	
							REF. CAL. #	
							N/A	
LOCATION		SYSTEM		EXAM START		EXAM END	JOB #	
Hanford		1ST TANK AY102		1900		2100	N/A	
COMPONENT ID				EXAMINATION SURFACE			NOM. THICKNESS	
PRIMARY WALL PLATE 3 SCAN 2 0°				<input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED			0.75"	
CONFIGURATION				CALIBRATED RANGE			TEMP AMBIENT OF	
TO PLATE 3				0.3-1.0"				
CIRCUMFERENCE/TOTAL LENGTH EXAMINED			SCAN LENGTH/PART		REF. LEVEL CORRECTION (TRANS. CORR)			
94.8			12"		0 DB			
PROCEDURE				REV		MATERIAL TYPE		CONDITION
SDI 2.1				3		<input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER		Fair
FILE NAME/ITEM#			DATA DISK#			TRANSDUCER		
AY2PW320						<input checked="" type="checkbox"/> DUAL <input type="checkbox"/> SGL <input checked="" type="checkbox"/> ODEG <input type="checkbox"/> ANGLE		
X ₀ REF. POINT (L ₀)			Y ₀ REF. POINT (W ₀)			SCAN WIDTH		
1" from weld toe			12" circ of 24" riser E			15"		
PART #/ INDICATION	L START	L STOP	W START	W STOP	AVE. THK.	MIN. THK. R. LIG.	AREA REPORTABLE	COMMENTS
1					.748	.739	NO	
2					.748	.739	NO	
3					.752	.743	NO	
4					.756	.743	NO	
5					.756	.743	NO	
6					.761	.734	NO	
7					.761	.739	NO	
8					.769	.743	NO	
SUMMARY								
MERGED RESULTS								
REMARKS								
N/A - Laminations detected throughout plate								
Examiner			Analyst			Reviewer		Page
James B. Eller			James B. Eller			LWA Nelson		13 of 30
Level III Date 5/4/99			Level III Date 5/12/99			Level III Date 6-4-99		
COGEMA								

2/99

ULTRASONIC P-SCAN DATA REPORT

REPORT #
N/A

LOCATION HANFORD	SYSTEM DST TANK AY102	EXAM START 1210	EXAM END 1330	JOB # N/A
COMPONENT ID PRIMARY WALL TOP TRANS. PLATE SCAN 2, 45°		EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED		NOM. THICKNESS 3/8"
CONFIGURATION TO TOP TRANS. PLATE SCAN 2-45°		CALIBRATED RANGE 0-2.56"		TEMP AMBIENT °F
CIRCUMFERENCE/TOTAL LENGTH EXAMINED 36"		SCAN LENGTH/PART 12"		REF. LEVEL CORRECTION (TRANS. CORR) 0 DB
PROCEDURE SDI 2.1		REV 3		MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER
FILE NAME/ITEM# AY2 PWT24		DATA DISK#		CONDITION FAIR
X ₀ REF. POINT (L ₀) 1" FROM HANGAR WELD		Y ₀ REF. POINT (W ₀) 15" CCW OF 24" RISE &		TRANSDUCER <input type="checkbox"/> DUAL <input checked="" type="checkbox"/> SGL <input type="checkbox"/> ODEG <input checked="" type="checkbox"/> ANGLE 45
		SCAN WIDTH 15"		
SIZING METHOD		ANGLE	REFERENCE CAL. SHEET	SET-UP
1 45 DEGREE SHEAR		45		
2 60 DEGREE SHEAR				
3 AATT				
4 DUAL 0 DEGREE				

INDICATION INFORMATION

IND	METHOD	WELD SIDE	DEPTH R. LIG.	MAX AMP	L1	LENGTH	L2	W1	WIDTH	W2	INDICATION TYPE
No Cracklike Indications											

REMARKS

Examiner <u>James B. Eder</u> Level <u>III</u> Date <u>5/6/99</u>	Analyst <u>James B. Eder</u> Level <u>III</u> Date <u>5/13/99</u>	Reviewer <u>W.H. Nelson</u> Level <u>III</u> Date <u>6-4-99</u> COGEMA	Page 14 of 30
---	---	--	--------------------------------

2/99							ULTRASONIC P-SCAN DATA REPORT					REPORT # N/A	
LOCATION HANFORD			SYSTEM DST TANK AY102			EXAM START 1330		EXAM END 1630		JOB # N/A			
COMPONENT ID PRIMARY WALL PLATE 1 SCAN 2, 45°			CONFIGURATION TO PLATE 1, SCAN 2			EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED			NOM. THICKNESS 0.5"				
CIRCUMFERENCE/TOTAL LENGTH EXAMINED 115"			SCAN LENGTH/PART 12"			CALIBRATED RANGE 0-70 2.56"			TEMP AMBIENT OF				
PROCEDURE SDI 2.1			REV 3			MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER			CONDITION FAIR				
FILE NAME/ITEM# AY2PW124			DATA DISK#			TRANSDUCER <input type="checkbox"/> DUAL <input checked="" type="checkbox"/> SGL <input type="checkbox"/> ODEG <input checked="" type="checkbox"/> ANGLE 45			SCAN WIDTH 15"				
X ₀ REF. POINT (L ₀) 1" from toe of weld			Y ₀ REF. POINT (W ₀) ~12" CCW of 24" Riser &										
SIZING METHOD		ANGLE		REFERENCE CAL. SHEET		SET-UP							
1 45 DEGREE SHEAR		45											
2 60 DEGREE SHEAR													
3 AATT													
4 DUAL 0 DEGREE													
INDICATION INFORMATION													
IND	METHOD	WELD SIDE	DEPTH R. LIG.	MAX AMP	L1	LENGTH	L2	W1	WIDTH	W2	INDICATION TYPE		
	No Cracklike Indications												
REMARKS N/A													
Examiner James Siller Level III Date 5/6/99			Analyst James Siller Level III Date 5/13/99			Reviewer W.H. Nelson Level III Date 6-4-99 COGEMD			Page 15 of 30				

2/99 ULTRASONIC P-SCAN DATA REPORT							REPORT # N/A				
LOCATION HANFORD		SYSTEM DST TANK A4102		EXAM START 1630	EXAM END 1840	JOB # N/A					
COMPONENT ID PRIMARY WALL PLATE 2, SCAN 2 45°				EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED		NOM. THICKNESS 0.5"					
CONFIGURATION TO PLATE 2, SCAN 2				CALIBRATED RANGE 0 TO 2.56"		TEMP AMBIENT °F					
CIRCUMFERENCE/TOTAL LENGTH EXAMINED 115.2"		SCAN LENGTH/PART 12		REF. LEVEL CORRECTION (TRANS. CORR) 0 DB							
PROCEDURE SDI 2.1			REV 3		MATERIAL TYPE <input type="checkbox"/> SS <input type="checkbox"/> CS OTHER _____			CONDITION			
FILE NAME/ITEM# A42 PW224		DATA DISK#			TRANSDUCER <input type="checkbox"/> DUAL <input type="checkbox"/> SGL <input type="checkbox"/> 0DEG <input type="checkbox"/> ANGLE _____			SCAN WIDTH			
X ₀ REF. POINT (L ₀) 1" from weld		Y ₀ REF. POINT (W ₀) ~12" CCW of 24" riser &									
SIZING METHOD		ANGLE		REFERENCE CAL. SHEET			SET-UP				
1 45 DEGREE SHEAR		45									
2 60 DEGREE SHEAR											
3 AATT											
4 DUAL 0 DEGREE											
INDICATION INFORMATION											
IND	METHOD	WELD SIDE	DEPTH R. LIG.	MAX AMP	L1	LENGTH	L2	W1	WIDTH	W2	INDICATION TYPE
No Cracklike Indications											
REMARKS N/A											
Examiner <i>James B. Egan</i> Level III Date 5/6/99				Analyst <i>James B. Egan</i> Level III Date 5/13/99				Reviewer <i>W. A. Nelson</i> Level II Date 6-4-99 COGEMA			Page 14 of 30

2/99							ULTRASONIC P-SCAN DATA REPORT				REPORT # N/A				
LOCATION HARFORD		SYSTEM DST TANK AY10Z		EXAM START 18YS		EXAM END 2021		JOB # N/A							
COMPONENT ID PRIMARY WALL PLATE 3, SCAN 2, 45°				EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED			NOM. THICKNESS 0.75								
CONFIGURATION PLATE TO 3, SCAN 2				CALIBRATED RANGE 0-2.56"			TEMP AMBIENT °F								
CIRCUMFERENCE/TOTAL LENGTH EXAMINED 96"		SCAN LENGTH/PART 12		REF. LEVEL CORRECTION (TRANS. CORR) 0 DB											
PROCEDURE SDI 2.1			REV 3		MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER				CONDITION fair						
FILE NAME/ITEM# AY2PW324		DATA DISK#			TRANSDUCER <input type="checkbox"/> DUAL <input checked="" type="checkbox"/> SGL <input type="checkbox"/> ODEG <input checked="" type="checkbox"/> ANGLE 45				SCAN WIDTH 15"						
X _o REF. POINT (Lo) 1 1/2" from to		Y _o REF. POINT (Wo) ~ 12" ccw of riser &													
SIZING METHOD		ANGLE		REFERENCE CAL. SHEET			SET-UP								
1 45 DEGREE SHEAR		45													
2 60 DEGREE SHEAR															
3 AATT															
4 DUAL 0 DEGREE															
INDICATION INFORMATION															
IND	METHOD	WELD SIDE	DEPTH R. LIG.	MAX AMP	L1	LENGTH	L2	W1	WIDTH	W2	INDICATION TYPE				
	No Cracklike Indications.														
REMARKS N/A															
Examiner <i>James B. Ellen</i> Level III Date 5/6/99				Analyst <i>James B. Ellen</i> Level III Date 5/13/99				Reviewer <i>W.A. Nelson</i> Level III Date 6-4-99 COGEMA				Page 17 of 30			

2/99							ULTRASONIC P-SCAN DATA REPORT					REPORT # N/A			
LOCATION HANFORD			SYSTEM DST TANK A4102		EXAM START 1410	EXAM END 1430	JOB # N/A								
COMPONENT ID PRIMARY WALL, TOP TRANS. PLATE, SCAN 1, 45°					EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED			NOM. THICKNESS 3/8"							
CONFIGURATION TO TOP TRANSITION PLATE SCAN 1,					CALIBRATED RANGE 0-2.56"			TEMP AMBIENT OF							
CIRCUMFERENCE/TOTAL LENGTH EXAMINED 36"			SCAN LENGTH/PART 12		REF. LEVEL CORRECTION (TRANS. CORR) 0 DB										
PROCEDURE SDI 2.1				REV 3		MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER			CONDITION fair						
FILE NAME/ITEM# A42 PWT 14			DATA DISK#			TRANSDUCER <input type="checkbox"/> DUAL <input checked="" type="checkbox"/> SGL <input type="checkbox"/> 0DEG <input checked="" type="checkbox"/> ANGLE 45			SCAN WIDTH						
X ₀ REF. POINT (L ₀) 1" from HANDED WELD			Y ₀ REF. POINT (W ₀) 2" & 24" Riser												
SIZING METHOD		ANGLE		REFERENCE CAL. SHEET			SET-UP								
1 45 DEGREE SHEAR		45													
2 60 DEGREE SHEAR															
3 AATT															
4 DUAL 0 DEGREE															
INDICATION INFORMATION															
IND	METHOD	WELD SIDE	DEPTH R. LIG.	MAX AMP	L1	LENGTH	L2	W1	WIDTH	W2	INDICATION TYPE				
No Crack like Indications															
REMARKS N/A															
Examiner Level III Date 5/5/99				Analyst Level III Date 7/13/99				Reviewer Level II Date 6-4-99 COGEMA				Page 18 of 30			

2/99 ULTRASONIC P-SCAN DATA REPORT							REPORT # N/A				
LOCATION <u>HANFORD</u>		SYSTEM <u>DST TANK AY102</u>		EXAM START <u>1815</u>	EXAM END <u>2015</u>	JOB # <u>N/A</u>					
COMPONENT ID <u>PRIMARY WALL PLATE 2 SCAN 1, 45°</u>				EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED		NOM. THICKNESS <u>0.5"</u>					
CONFIGURATION <u>TO PLATE 2</u>				CALIBRATED RANGE <u>0-2.56" SP</u>		TEMP <u>AMBIENT</u> OF					
CIRCUMFERENCE/TOTAL LENGTH EXAMINED <u>18.2"</u>		SCAN LENGTH/PART <u>12"</u>		REF. LEVEL CORRECTION (TRANS. CORR) <u>0</u> DB							
PROCEDURE <u>SDI 2.1</u>			REV <u>3</u>		MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER _____			CONDITION <u>fail</u>			
FILE NAME/ITEM# <u>AY2PW214</u>		DATA DISK#			TRANSDUCER <input type="checkbox"/> DUAL <input checked="" type="checkbox"/> SGL <input type="checkbox"/> ODEG <input checked="" type="checkbox"/> ANGLE <u>45</u>						
X _o REF. POINT (Lo) <u>1" from weld toe</u>		Y _o REF. POINT (Wo) <u>7" CW of 24" Riser &</u>			SCAN WIDTH <u>15"</u>						
SIZING METHOD		ANGLE		REFERENCE CAL. SHEET			SET-UP				
1 45 DEGREE SHEAR		<u>45°</u>									
2 60 DEGREE SHEAR											
3 AATT											
4 DUAL 0 DEGREE											
INDICATION INFORMATION											
IND	METHOD	WELD SIDE	DEPTH R. LIG.	MAX AMP	L1	LENGTH	L2	W1	WIDTH	W2	INDICATION TYPE
<u>No Crack like Indications.</u>											
REMARKS <u>N/A</u>											
Examiner <u>James B. Elder</u> Level III Date <u>5/5/99</u>				Analyst <u>James B. Elder</u> Level III Date <u>5/13/99</u>				Reviewer <u>W.H. Nelson</u> Level III Date <u>6-4-99</u> <u>COGEMA</u>			Page <u>20</u> of <u>30</u>

2/99						AUTOMATED ULTRASONIC THICKNESS DATA REPORT			REPORT# N/A	
						REF. CAL. # N/A				
LOCATION HANFORD		SYSTEM DST TANK A4102		EXAM START 1800		EXAM END 1900		JOB # N/A		
COMPONENT ID PRIMARY WALL VERT WELD 3 0°				EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED			NOM. THICKNESS 0.75"			
CONFIGURATION PLATE 3 TO PLATE 3				CALIBRATED RANGE 0.3" - 1.00"			TEMP Ambient °F			
CIRCUMFERENCE/TOTAL LENGTH EXAMINED 104.5"		SCAN LENGTH/PART 12"		REF. LEVEL CORRECTION (TRANS. CORR)			0 DB			
PROCEDURE SDI 2.1			REV 3		MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER			CONDITION Fair		
FILE NAME/ITEM# A42 PVW3 0			DATA DISK#		TRANSDUCER <input checked="" type="checkbox"/> DUAL <input type="checkbox"/> SGL <input checked="" type="checkbox"/> CODEG <input type="checkbox"/> ANGLE					
X ₀ REF. POINT (Lo) -1" down from Plate 2-3 weld			Y ₀ REF. POINT (Wo) Weld 2		SCAN WIDTH 6"					
PART #/ INDICATION	L START	L STOP	W START	W STOP	AVE. THK.	MIN. THK. R. LIG.	AREA REPORTABLE	COMMENTS		
1					0.767	0.730	NO	N/A		
2					0.767	0.745	NO			
3					0.774	0.756	NO			
4					0.774	0.756	NO			
5					0.778	0.745	NO			
6					0.774	0.748	NO			
7					0.774	0.722	NO			
8					0.778	0.741	NO			
9					0.778	0.752	NO			
SUMMARY										
MERGED RESULTS										
REMARKS										
Examiner <u>James B. Eller</u> Level III Date <u>5/11/99</u>			Analyst <u>James B. Eller</u> Level III Date <u>5/12/99</u>			Reviewer <u>W. Nelson</u> Level III Date <u>6-4-99</u> COGEMA			Page 22 of 30	

ULTRASONIC P-SCAN DATA REPORT						REPORT # N/A					
2/99		LOCATION HANFORD		SYSTEM DST-TANK AY102		EXAM START 1530		EXAM END 1616		JOB # N/A	
COMPONENT ID PRIMARY WALL VERT WELD 3, 60°				EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED				NOM. THICKNESS 0.75"			
CONFIGURATION PLATE 3 TO PLATE 3.				CALIBRATED RANGE 0-3.57"				TEMP °F			
CIRCUMFERENCE/TOTAL LENGTH EXAMINED 102"			SCAN LENGTH/PART 12"			REF. LEVEL CORRECTION (TRANS. CORR) 0 DB					
PROCEDURE SDI 2.1			REV 3			MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER			CONDITION		
FILE NAME/ITEM# A12VW36A			DATA DISK#			TRANSDUCER <input type="checkbox"/> DUAL <input checked="" type="checkbox"/> SGL <input type="checkbox"/> 0DEG <input checked="" type="checkbox"/> ANGLE 60			SCAN WIDTH 5"		
X ₀ REF. POINT (L ₀)			Y ₀ REF. POINT (W ₀) E of weld								
SIZING METHOD		ANGLE		REFERENCE CAL. SHEET				SET-UP			
1 45 DEGREE SHEAR				N A							
2 60 DEGREE SHEAR		60°									
3 AATT											
4 DUAL 0 DEGREE											
INDICATION INFORMATION											
IND	METHOD	WELD SIDE	DEPTH R. LIG.	MAX AMP	L1	LENGTH	L2	W1	WIDTH	W2	INDICATION TYPE
	No Cracklike Indications										
REMARKS											
Intermittent noise from surface roughness and/or probe(s) rocking up at toe of weld. Also weld geometry indications AK											
Examiner Ronald V. Swain Level <u>II</u> Date <u>6-4-99</u>			Analyst James B. Ellis Level <u>III</u> Date <u>5/23/99</u>			Reviewer W.D. Nelson Level <u>III</u> Date <u>6-4-99</u> COGEMA			Page 23 of 30		

5/14/99

2/99						ULTRASONIC P-SCAN DATA REPORT					REPORT #
LOCATION: HANFORD		SYSTEM: DST TANK 4Y102		EXAM START: 1300	EXAM END: 1330	JOB #: N/A					
COMPONENT ID: PRIMARY WALL Vert. Weld 3 45°		EXAMINATION SURFACE: <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED			NOM. THICKNESS: 0.75"						
CONFIGURATION: PLATE 3 TO PLATE 3		CALIBRATED RANGE: 0-2.56"			TEMP: AMBIENT °F						
CIRCUMFERENCE/TOTAL LENGTH EXAMINED: 102"		SCAN LENGTH/PART: 12"		REF. LEVEL CORRECTION (TRANS. CORR): 0 DB							
PROCEDURE: SDI 2.1		REV: 3		MATERIAL TYPE: <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER			CONDITION: Fair				
FILE NAME/ITEM#: 4Y2VW34C		DATA DISK#			TRANSDUCER: <input type="checkbox"/> DUAL <input checked="" type="checkbox"/> SGL <input type="checkbox"/> 0DEG <input checked="" type="checkbox"/> ANGLE 45						
X ₀ REF. POINT (L ₀)		Y ₀ REF. POINT (W ₀): 9 of weld			SCAN WIDTH: 5"						
SIZING METHOD		ANGLE		REFERENCE CAL. SHEET			SET-UP				
1 45 DEGREE SHEAR		45									
2 60 DEGREE SHEAR											
3 AATT											
4 DUAL 0 DEGREE											
INDICATION INFORMATION											
IND	METHOD	WELD SIDE	DEPTH R. LIG.	MAX AMP	L1	LENGTH	L2	W1	WIDTH	W2	INDICATION TYPE
	No Cracklike Indications.										
REMARKS											
Examiner: Ronald V. Swain Level <u>II</u> Date <u>6-4-99</u>			Analyst: James B. Elder Level <u>III</u> Date <u>5/23/99</u>			Reviewer: W.H. Nelson Level <u>IV</u> Date <u>6-4-99</u>			Page: 24 of 30		

5/13/99

<p>2/99</p> <h2 style="text-align: center;">AUTOMATED ULTRASONIC THICKNESS DATA REPORT</h2>						<p>REPORT# <u>N/A</u></p>			
						<p>REF. CAL. # <u>N/A</u></p>			
<p>LOCATION <u>HANFORD</u></p>		<p>SYSTEM <u>DST TANK AY102</u></p>		<p>EXAM START <u>1900</u></p>		<p>EXAM END <u>2010</u></p>	<p>JOB # <u>N/A</u></p>		
<p>COMPONENT ID <u>PRIMARY WALL, VERT WELD 2 0°</u></p>				<p>EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED</p>		<p>NOM. THICKNESS <u>0.5"</u></p>			
<p>CONFIGURATION <u>PLATE 2 TO PLATE 2</u></p>				<p>CALIBRATED RANGE <u>0.3-1.0"</u></p>		<p>TEMP <u> </u> °F</p>			
<p>CIRCUMFERENCE/TOTAL LENGTH EXAMINED <u>114.7"</u></p>		<p>SCAN LENGTH/PART <u>12"</u></p>		<p>REF. LEVEL CORRECTION (TRANS. CORR) <u>0</u> DB</p>					
<p>PROCEDURE <u>SDI 2.1</u></p>			<p>REV <u>3</u></p>	<p>MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER <u> </u></p>		<p>CONDITION <u>Fair</u></p>			
<p>FILE NAME/ITEM# <u>Ay2PVW20</u></p>		<p>DATA DISK# <u> </u></p>		<p>TRANSDUCER <input checked="" type="checkbox"/> DUAL <input type="checkbox"/> SGL <input checked="" type="checkbox"/> ODEG <input type="checkbox"/> ANGLE <u> </u></p>		<p>SCAN WIDTH <u>6"</u></p>			
<p>X₀ REF. POINT (L₀) <u>1" below PLATE 1-2 weld</u></p>		<p>Y₀ REF. POINT (W₀) <u>WELD E</u></p>							
PART # / INDICATION	L START	L STOP	W START	W STOP	AVE. THK.	MIN. THK. R. LIG.	AREA REPORTABLE	COMMENTS	
1					0.520	0.493	NO	<div style="font-size: 4em; opacity: 0.5;">N/A</div>	
2					0.515	0.485	NO		
3					0.510	0.485	NO		
4					0.508	0.485	NO		
5					0.515	0.485	NO		
6					0.515	0.488	NO		
7					0.515	0.490	NO		
8					0.515	0.493	NO		
9					0.518	0.465	NO		
10					0.523	0.493	NO		
<p>SUMMARY MERGED RESULTS</p>									
<p>REMARKS</p> <hr/> <hr/> <hr/>									
<p>Examiner <u>James B. Elle</u> Level <u>III</u> Date <u>5/11/99</u></p>			<p>Analyst <u>James B. Elle</u> Level <u>III</u> Date <u>5/12/99</u></p>			<p>Reviewer <u>W. H. Nelson</u> Level <u>II</u> Date <u>6-4-99</u> COGEMA</p>		<p>Page <u>25</u> of <u>30</u></p>	

2/99 ULTRASONIC P-SCAN DATA REPORT							REPORT # N/A				
LOCATION HANFORD		SYSTEM DST TANK A4102		EXAM START 1420	EXAM END 1515	JOB # N/A					
COMPONENT ID PRIMARY WALL VERT WELD 2, 60°				EXAMINATION SURFACE <input checked="" type="checkbox"/> LOD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED			NOM. THICKNESS 0.5"				
CONFIGURATION PLATE 2 TO PLATE 2				CALIBRATED RANGE 0-3.51"			TEMP AMBIENT OF				
CIRCUMFERENCE/TOTAL LENGTH EXAMINED 114"		SCAN LENGTH/PART 12"		REF. LEVEL CORRECTION (TRANS. CORR) 0 DB							
PROCEDURE SDI 2.1			REV 3	MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER			CONDITION Fair				
FILE NAME/ITEM# A42VW26A		DATA DISK#		TRANSDUCER <input type="checkbox"/> DUAL <input checked="" type="checkbox"/> SGL <input type="checkbox"/> 0DEG <input checked="" type="checkbox"/> ANGLE 60			SCAN WIDTH				
X ₀ REF. POINT (L ₀)		Y ₀ REF. POINT (W ₀) E of weld.									
SIZING METHOD		ANGLE		REFERENCE CAL. SHEET			SET-UP				
1 45 DEGREE SHEAR											
2 60 DEGREE SHEAR		60									
3 AATT											
4 DUAL 0 DEGREE											
INDICATION INFORMATION											
IND	METHOD	WELD SIDE	DEPTH R. LIG.	MAX AMP	L1	LENGTH	L2	W1	WIDTH	W2	INDICATION TYPE
No Cracklike Indications.											
REMARKS											
Intermittent noise from rough surface and/or probe(s) rocking up at toe of weld. Also had weld geometry indications.											
Examiner Donald V. Swain Level II Date 5/14/99			Analyst James B. Elder Level III Date 5/23/99			Reviewer W.H. Nelson Level III Date 6-4-99 COGEMA			Page 24 of 30		

2/99							ULTRASONIC P-SCAN DATA REPORT					REPORT #	
LOCATION HADFORD			SYSTEM DST TANK A4102			EXAM START 1200		EXAM END 1245		JOB # N/A			
COMPONENT ID PRIMARY WALL VERT WELD 2. 45°					EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED			NOM. THICKNESS 0.5					
CONFIGURATION PLATE 2 TO PLATE 2.					CALIBRATED RANGE 0-2.5			TEMP AMBIENT °F					
CIRCUMFERENCE/TOTAL LENGTH EXAMINED 113.28			SCAN LENGTH/PART 12"		REF. LEVEL CORRECTION (TRANS. CORR) 0 DB								
PROCEDURE SDI 2.1			REV 3		MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER			CONDITION Fair					
FILE NAME/ITEM# A42VW24C			DATA DISK#			TRANSDUCER <input type="checkbox"/> DUAL <input checked="" type="checkbox"/> SGL <input type="checkbox"/> 0DEG <input checked="" type="checkbox"/> ANGLE 45°			SCAN WIDTH 5"				
X _o REF. POINT (L _o)			Y _o REF. POINT (W _o) 8" of weld										
SIZING METHOD		ANGLE		REFERENCE CAL. SHEET			SET-UP						
1 45 DEGREE SHEAR		45											
2 60 DEGREE SHEAR													
3 AATT													
4 DUAL 0 DEGREE													
INDICATION INFORMATION													
IND	METHOD	WELD SIDE	DEPTH R. LIG.	MAX AMP	L1	LENGTH	L2	W1	WIDTH	W2	INDICATION TYPE		
No Cracklike Indications													
REMARKS													
Examiner Ronald V. Jwan Level <u>II</u> Date <u>6-4-99</u>			Analyst James B. Baker Level <u>III</u> Date <u>5/23/99</u>			Reviewer W. J. Nelson Level <u>III</u> Date <u>6-4-99</u> COG5MIA			Page 27 of 30				

AUTOMATED ULTRASONIC THICKNESS DATA REPORT							REPORT# <u>N/A</u>		
							REF. CAL. # <u>N/A</u>		
LOCATION <u>Hampford</u>	SYSTEM <u>DST TANK AY102</u>		EXAM START <u>1410</u>	EXAM END <u>1630</u>	JOB # <u>N/A</u>				
COMPONENT ID. <u>PRIMARY WALL PLATE ABOVE WELD 3, 0°</u>			EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED			NOM. THICKNESS <u>0.5"</u>			
CONFIGURATION <u>PLATE 1 TO PLATE 2 HORIZ WELD 3.</u>			CALIBRATED RANGE <u>0.3-1.0"</u>			TEMP <u>AMBIENT °F</u>			
CIRCUMFERENCE/TOTAL LENGTH EXAMINED <u>293" (24'4")</u>		SCAN LENGTH/PART		REF. LEVEL CORRECTION (TRANS. CORR.) <u>0</u> DB					
PROCEDURE <u>SDI 2.1</u>			REV <u>3</u>		MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER		CONDITION <u>Fair</u>		
FILE NAME/ITEM# <u>A42PHW30</u>		DATA DISK#		TRANSDUCER <input checked="" type="checkbox"/> DUAL <input type="checkbox"/> SGL <input checked="" type="checkbox"/> ODEG <input type="checkbox"/> ANGLE					
X ₀ REF. POINT (Lo) <u>33" CW from Plate 1 Vert. (112 1/2')</u>		Y ₀ REF. POINT (Wo) <u>Weld 3</u>		SCAN WIDTH <u>6"</u>					
PART #/ INDICATION	L START	L STOP	W START	W STOP	AVE. THK.	MIN. THK. R. LIG.	AREA REPORTABLE	COMMENTS	
<u>A42PHW30 .1</u>					<u>.508</u>	<u>.493</u>	<u>NO</u>		
<u>" .2</u>					<u>.508</u>	<u>.490</u>	<u>NO</u>		
<u>" .3</u>					<u>.508</u>	<u>.490</u>	<u>NO</u>		
<u>" .4</u>					<u>.520</u>	<u>.498</u>	<u>NO</u>		
<u>" .5</u>					<u>.520</u>	<u>.498</u>	<u>NO</u>		
<u>" .6</u>					<u>.518</u>	<u>.498</u>	<u>NO</u>		
<u>" .7</u>					<u>.525</u>	<u>.500</u>	<u>NO</u>		
<u>" .8</u>					<u>.525</u>	<u>.500</u>	<u>NO</u>		
<u>" .9</u>					<u>.515</u>	<u>.485</u>	<u>NO</u>		
<u>" .10</u>					<u>.515</u>	<u>.498</u>	<u>NO</u>		
<u>" .11</u>					<u>.523</u>	<u>.498</u>	<u>NO</u>		
<u>" .12</u>					<u>.523</u>	<u>.500</u>	<u>NO</u>		
<u>" .13</u>					<u>.515</u>	<u>.493</u>	<u>NO</u>		
<u>" .14</u>					<u>.523</u>	<u>.500</u>	<u>NO</u>		
<u>" .15</u>					<u>.525</u>	<u>.508</u>	<u>NO</u>		
<u>" .16</u>					<u>.520</u>	<u>.508</u>	<u>NO</u>		
<u>" .17</u>					<u>.518</u>	<u>.498</u>	<u>NO</u>		
<u>" .18</u>					<u>.520</u>	<u>.500</u>	<u>NO</u>		
<u>" .19</u>					<u>.523</u>	<u>.505</u>	<u>NO</u>		
<u>" .20</u>					<u>.523</u>	<u>.500</u>	<u>NO</u>		
<u>A42PHW30 .21</u>					<u>.523</u>	<u>.505</u>	<u>NO</u>		
SUMMARY					<u>* .22</u>	<u>.515</u>	<u>.498</u>	<u>NO</u>	
MERGED RESULTS					<u>* .23</u>	<u>.515</u>	<u>.500</u>	<u>NO</u>	
					<u>* .24</u>	<u>.518</u>	<u>.500</u>	<u>NO</u>	
					<u>* .25</u>	<u>.520</u>	<u>.505</u>	<u>NO</u>	
REMARKS									
<p><u>* Scan to 293" (24+feet) to include weld repairs in examination area.</u></p> <p><u>Repairs at 258-266" and 281-291"</u></p> <p><u>Plate 1 vert. weld at 34" (~112 1/2'), Plate 2 Vert. weld at 270" (132' mark)</u></p>									
Examiner <u>James B. Ellis</u> Level <u>III</u> Date <u>5/11/99</u>			Analyst <u>James B. Ellis</u> Level <u>III</u> Date <u>5/12/99</u>			Reviewer <u>W.H. Nelson</u> Level <u>IV</u> Date <u>6-4-99</u> <u>COGEMA</u>		Page <u>28</u> of <u>30</u>	

2/99 ULTRASONIC P-SCAN DATA REPORT							REPORT # N/A				
LOCATION HANFORD		SYSTEM DST TANK AY102		EXAM START 1015	EXAM END 1301	JOB # N/A					
COMPONENT ID PRIMARY WALL HORIZ. WELD 3, 60° AX.				EXAMINATION SURFACE <input checked="" type="checkbox"/> OD <input type="checkbox"/> ID <input type="checkbox"/> PAINTED			NOM. THICKNESS 0.5"				
CONFIGURATION PLATE 1 TO PLATE 2				CALIBRATED RANGE 0-2.58"			TEMP AMBIENT °F				
CIRCUMFERENCE/TOTAL LENGTH EXAMINED 288"			SCAN LENGTH/PART 12"		REF. LEVEL CORRECTION (TRANS. CORR) 0 DB						
PROCEDURE SDI 2.1			REV 3		MATERIAL TYPE <input type="checkbox"/> SS <input checked="" type="checkbox"/> CS OTHER			CONDITION fair			
FILE NAME/ITEM# AY2HW36A		DATA DISK#			TRANSDUCER <input type="checkbox"/> DUAL <input checked="" type="checkbox"/> SGL <input type="checkbox"/> 0DEG <input checked="" type="checkbox"/> ANGLE 60°			SCAN WIDTH 5"			
X ₀ REF. POINT (L ₀)		Y ₀ REF. POINT (W ₀) 1/2 of weld									
SIZING METHOD		ANGLE		REFERENCE CAL. SHEET			SET-UP				
1 45 DEGREE SHEAR											
2 60 DEGREE SHEAR		60°									
3 AATT											
4 DUAL 0 DEGREE											
INDICATION INFORMATION											
IND	METHOD	WELD SIDE	DEPTH R. LIG.	MAX AMP	L1	LENGTH	L2	W1	WIDTH	W2	INDICATION TYPE
No Cracklike Indications											
REMARKS Intermittent noise from surface roughness and/or probe(s) rocking up at toe of weld. Also weld geometry indications. JZ.											
Examiner Ronald V. Swan Level <u>II</u> Date <u>5/14/99</u>			Analyst James B. Eller Level <u>III</u> Date <u>5/23/99</u>			Reviewer W. J. Nelson Level <u>II</u> Date <u>6-2-99</u> COGEMA			Page 29 of 30		

