

DØ SOLENOID UPGRADE PROJECT

**Solenoid insulating vacuum vessel;
Relief path capacity calculation**

D-ZERO ENGINEERING NOTE # 3823.111- EN-345

**May 26, 1993
Rev. August 2, 1993**

Russ Rucinski & David Bell

This engineering note documents the calculations done to determine the relief capacity of the solenoid vacuum pumping line. The calculations were done by David Bell, a co-op student from the University of Wisconsin. The calculations are attached. The conclusion is that the vacuum pumping line has a venting capacity of 129 g/s warm helium or 298 g/s warm nitrogen. Both of these capacities are much larger than the expected operating mass flow rates of the liquid helium (5 to 15 g/s) or liquid nitrogen (2 or 3 g/s) circuits. The calculations assume the solenoid vacuum vessel is at 3 psig and the relief plate is set at 1.5 psig.

Additional calculations were done to prove that the venting capacity of the vacuum pumping line exceeded flowrates due to a failure mode. These calculations are attached. Since the system is not finalized, (pipe sizes not determined, components sized...) the calculations were done by first picking reasonable line sizes based on known allowed pressure drops in the system and then doing a maximum delivery rate calculation if a line was completely severed in the vacuum space of the solenoid/control dewar. The numbers from these calculations say that failure mode flow rates are 80 g/s liquid helium or 80 g/s liquid nitrogen. Both these values are less than the capacity of the relief line.

In the five months since the (12/92 Dave Bell) calculations were done, some changes occurred to the relief path. The most notable is that the radiation shield is now considered to be 6.625" O.D. instead of 6.00" used in the venting calculation. This change would tend to lower the capacity numbers. Another change was that for about half the venting path the chimney vacuum shell size was increased to 10" pipe. This change tends to increase the capacity numbers which were done assuming 8" pipe. These changes taken together probably offset each other or make the capacity numbers better. In either case, since the margin of safety is large, the calculations have not been redone.

Russ Rucinski
RD/DØ Mech. 8/2/93


IT IS DESIRED TO DETERMINE THE RELIEF CAPACITY OF THE VACUUM PUMPING LINE.

REQUIREMENTS - RELIEF OPENS AT 1.5 PSIG. THE SOLENOID SHOULD BE RUN AT NO HIGHER THAN 3 PSIG → PRESSURE DROP IN PIPE SHOULD BE NO MORE THAN 1.5 PSIG -


THE PROBLEM - DETERMINE MAX FLOW RATE THROUGH VACUUM JACKET

ASSUME: $T = 300 K$

- ② 5" BULKHEAD CONVERGES TO 3x7" OSGROUND
- ③ OSGROUND 3" x 7" SECTION FROM A TO B
- ④ CIRCULAR SECTION BULKHEAD BETWEEN 6" & 8.5" PIPES
- ⑤ B IS ASSUMED TO BE A REGULAR ELBOW & C
- ⑥ VENT IS AT OR NEAR D
- ⑦ PIPE $\epsilon = 0.00015 ft$
- ⑧ ASSUME LAMINAR FLOW



AB = 105 in
BC = 109 in
CD = 264 in



THE length of the 5" BULKHEAD TO 3x7" OSGROUND ADAPTER IS NOT YET KNOWN. ASSUME IT TO BE AN INLET CONDITION TO THE PIPE WITH $K=1$

PROPERTIES


17.646 psia = 122.010 kPa
 16.646 psia = 11.646 kPa

He ~ 1.120 MPa
 300K $\rho = 0.1925 \text{ kg/m}^3$, $V_{\text{sound}} = 1020 \text{ m/s}$, $\nu_{\text{He}} = 19.92 \text{ m}^2/\text{s}$

He ~ .11 MPa (MIDWAY BETWEEN .10 & .12)
 $\rho = .1775 \text{ kg/m}^3$, $\nu_{\text{He}} = 19.92 \text{ m}^2/\text{s}$

N₂ ~ 1.2 atm
 300K $\rho = 731.995 \text{ kg/m}^3$, $V_{\text{sound}} = 353.2 \text{ m/s}$, $\nu_{\text{N}_2} = 179.57 \text{ m}^2/\text{s}$, $\text{PRANDTL NUMBER} = .729$
 $\rho = 0.001366 \frac{\text{kg}}{\text{cm}^3} \left(\frac{1000 \text{ kg}}{1000 \text{ kg}} \right) \left(\frac{100 \text{ cm}^3}{1000 \text{ cm}^3} \right) \left(\frac{1 \text{ m}}{100 \text{ cm}} \right)^3$
 ~ 1.1 atm $\rho = 798.5 \text{ kg/m}^3$

OBROUND SECTION, IF CONSIDERED TO BE 2 PARALLEL PIPES



AREA $\approx \frac{1}{2} \pi r^2 = 2.70594 \text{ in}^2$


$P = \frac{1}{2}(2\pi r) + \frac{1}{2}(\pi \frac{1}{2}) + \frac{1}{8} = 6.2837$

$D_h = \frac{4(2.70594)}{6.2837} \approx 1.72 \text{ in}$

$D_h = 4[\pi(1/8)^2] +$

$\frac{e}{D} = \frac{0.00015}{(1.72/2)} = 0.00105$

CIRCULAR SECTION



$D_h = 2(a-b) = 2(4.25 - 3) = 2.5 \text{ in}$
 annulus

$\frac{e}{D} = \frac{0.00015}{(2.5/2)} = 0.00072$

$A = \frac{\pi}{4}(8.5^2 - 6^2) = 28.47 \text{ in}^2$

VENT CAP LOCATED AT OR NEAR SECTION D

ASSUME THAT INLET TO OBROUND AND ADAPTER BETWEEN OBROUND AND ANNULUS ARE EQUIVALENT TO ENTRANCE CONDITIONS WITH MAX RESISTANCE COEFFICIENT OF 1

USE CRANE FLOW EQNS 2-1 to 2-4, OR WHITE, FLUID MECHANICS 1986
 combine into form McGraw-Hill 2nd ed 6.111

$$\Delta h_{total} = \frac{V_{AB}^2}{2g} \left(f \frac{L_{AB}}{D} \right) + \frac{V_{BC}^2}{2g} \left(f \frac{L_{BC}}{D} \right) + \frac{V_{CD}^2}{2g} \left(f \frac{L_{CD}}{D} \right) + \frac{V_{BC}^2}{2g} (K_B) + \frac{V_{CD}^2}{2g} (K_C)$$

$$+ \frac{V_{CD}^2}{2g} K_D + \frac{V_{AB}^2}{2g} K_1 + \frac{V_{CD}^2}{2g} (K_{out})$$

I wrote the equation in this form to distinguish each term
 (the first 3 are head loss through segments AB, BC, & CD, respectively.)

K_B is for the adapter between the 3"x7" obround and the annulus. Assume it is a constant value restriction = 1 with negligible length

K_C is ASSUMED TO BE A REGULAR ELBOW 54° 90° R=29"
 $\frac{L}{D} = \frac{29}{2.5} = 11.6$ from chart TOTAL resistance in bend is taken as an additional length of pipe from the chart on P A-27 in CRANE FLUID FLOW
 $K_C = f \frac{L_{equiv}}{D}$ and $L_{equiv} @ \frac{L}{D} = 11.6 = 320$

K_D is a mitre bend of about 33° $\frac{L}{D} \approx 9.5$ from CRANE FLUID FLOW P A-27

K_1 is the inlet condition to the obround MAX VALUE = 1

K_{out} is OUTLET AT D, MAX VALUE = 0.5

THE ACCEPTABLE $\Delta P = 1.5 \text{ psig} = 216 \text{ lb}_f/\text{ft}^2$

$\Delta P = \rho g h \Rightarrow h = \frac{216 \text{ lb}_f/\text{ft}^2}{\rho g}$

for He $\left(\frac{1.925 \frac{\text{kg}}{\text{m}^3} (1.9403 \times 10^{-3} \frac{\text{ft}^3}{\text{s}^2})}{\frac{\text{ft}}{\text{s}^2}} \right) 32.174 \frac{\text{ft}}{\text{s}^2} = \frac{17993 \text{ ft}}{\frac{158}{\text{ft}^2}} = 114 \text{ ft}$

for N_2 $h = \frac{216 \frac{\text{lb}_f}{\text{ft}^2}}{\left(\frac{1.366 \frac{\text{kg}}{\text{m}^3} (1.9403 \times 10^{-3} \frac{\text{ft}^3}{\text{s}^2})}{\frac{\text{ft}}{\text{s}^2}} \right) 32.174 \frac{\text{ft}}{\text{s}^2}} = \frac{2532.96 \text{ ft}}{\frac{158}{\text{ft}^2}} = 16 \text{ ft}$

If we take a value of 16 g/s flow rate into $= 16 \times 10^{-3} \frac{\text{kg}}{\text{s}}$
 $= \frac{16 \times 10^{-3} \frac{\text{kg}}{\text{s}} (16.9 \times 10^{-2} \frac{\text{ft}^3}{\text{s}^2})}{\frac{\text{ft}}{\text{s}^2}} = 1.096 \times 10^{-3} \frac{\text{ft}^3}{\text{s}}$

$$m = \rho VA$$

where A is approximate area

Helium

$$V_{ave} \text{ OBROUND} = \frac{m}{\rho A} = \frac{6.096 \times 10^{-3} \frac{lb}{ft}}{(1.925 \frac{lb}{ft^3}) \left(\frac{1.9403 \times 10^{-3} \frac{ft^2}{ft^2} \right) (2) \left(\frac{2.70594 \times 10^{-2} \frac{ft}{ft} \right) \left(\frac{14 \frac{ft}}{12 \frac{in}}{ft}} \right)^2}$$

$$V_{ave} = 78.10 \frac{ft}{s}$$

$$V_{ave} \text{ Annulus} = \frac{m}{\rho A} = 14.85 \frac{ft}{s}$$

NITROGEN $V_{ave} \text{ obround} = 11.01 \frac{ft}{s}$

$$V_{ave} \text{ annulus} = 2.09 \frac{ft}{s}$$

$$v = \frac{L}{\rho}$$

$$v \text{ N}_2 @ 1.1 \text{ atm} = \frac{179.55 \frac{ml}{cm^3}}{.00125 \frac{g}{cc}} = 0.14338 \frac{cm^2}{s} \cdot \left(\frac{1 \text{ in}}{2.54 \text{ cm}} \right)^2$$

$$v \text{ He @ 1.2 \text{ atm} = \frac{19.72 \times 10^{-6} \frac{kg}{(m^3 \cdot s)}}{.1925 \frac{kg}{m^3}} = 1.0348 \times 10^{-4} = 1.1139 \times 10^{-3}$$

$$Re_{He} \text{ obround} = \frac{(78.10 \frac{ft}{s}) \left(\frac{1.72}{12} \right) \frac{ft}{ft}}{1.1139 \times 10^{-3} \frac{ft^2}{s}} = 118050$$

$$\text{annulus} = \frac{[(14.85 \frac{ft}{s}) \left(\frac{2.5}{12} \right) \frac{ft}{ft}]}{1.1139 \times 10^{-3} \frac{ft^2}{s}} = 27776$$

$$Re_{N_2} \text{ obround} = \frac{(11.01 \frac{ft}{s}) \left(\frac{1.72}{12} \right) \frac{ft}{ft}}{1.5433 \times 10^{-4} \frac{ft^2}{s}} = 10225$$

$$Re_{N_2} \text{ Annulus} = \frac{(2.09 \frac{ft}{s}) \left(\frac{2.5}{12} \right) \frac{ft}{ft}}{1.5433 \times 10^{-4} \frac{ft^2}{s}} = 2825$$

I WILL USE $f=0.02$ TO DETERMINE AN APPROXIMATE
 MAX ACCEPTABLE MASS FLOW RATE

$$V = \frac{\dot{m}}{\rho A}$$

He

$$17993 \text{ ft} = \frac{\left[\frac{\dot{m}}{(0.1425)(1.9403 \times 10^{-3})(2)(2.70594) \left(\frac{1}{12}\right)^2} \right]^2 \left(1 + 0.02 \left(\frac{105}{1.72} \right) \right)}{2(32.174 \frac{\text{ft}}{\text{s}^2})}$$

$$+ \frac{\left[\frac{\dot{m}}{(0.1425)(1.9403 \times 10^{-3})(28.47) \left(\frac{1}{12}\right)^2} \right]^2 \left(43 + \frac{0.02(109)}{2.5} + \frac{0.02(264)}{2.5} \right)}{2(32.174)}$$

$$(17993 \text{ ft})(2)(32.174 \frac{\text{ft}}{\text{s}^2}) = \frac{\dot{m}^2 (1.127 \times 10^9)}{\text{ft}^2} + \frac{\dot{m}^2 (3.6053 \times 10^9)}{\text{ft}^2}$$

$$\dot{m}^2 = 7.7824 \times 10^{-9} \frac{\text{ft}^2}{\text{s}^2} \rightarrow \dot{m} = 0.008813 \frac{\text{ft}}{\text{s}} \cdot \frac{1 \text{ kg}}{\text{s}} \cdot \frac{6.4582 \times 10^{-2} \frac{\text{kg}}{\text{ft}^3}}{\text{ft}^3}$$

$$\frac{0.1247 \text{ kg}}{\text{s}}$$

$$= 128.79 \frac{\text{g}}{\text{s}}$$

N₂

$$2532.96 \text{ ft} = \frac{\frac{\dot{m}^2}{(1.366)^2(1.9403 \times 10^{-3})(2)(2.70594) \left(\frac{1}{12}\right)^2} \left[1 + 0.02 \left(\frac{105}{1.72} \right) \right] \frac{\text{ft}^2}{\text{s}^2}}{2(32.174) \frac{\text{ft}}{\text{s}^2}}$$

$$+ \frac{\frac{\dot{m}^2}{(1.366)^2(1.9403 \times 10^{-3})(28.47) \left(\frac{1}{12}\right)^2} \left[43 + \frac{0.02(109)}{2.5} + \frac{0.02(264)}{2.5} \right] \frac{\text{ft}^2}{\text{s}^2}}{2(32.174) \frac{\text{ft}}{\text{s}^2}}$$

$$2532.96(2)(32.174) \frac{\text{ft}^2}{\text{s}^2} = \left(\dot{m}^2 (2.25433 \times 10^8) + 1.67442 \times 10^8 \dot{m}^2 \right) \frac{\text{ft}^2}{\text{s}^2}$$

$$\dot{m}^2 = 4.165 \times 10^{-4} \rightarrow \dot{m} = 0.0204 \frac{\text{ft}}{\text{s}} \left(\frac{1 \text{ kg}}{\text{s}} \cdot \frac{6.4582 \times 10^{-2} \frac{\text{kg}}{\text{ft}^3}}{\text{ft}^3} \right)$$

$$= 0.2978 \frac{\text{kg}}{\text{s}} = 297.8 \frac{\text{g}}{\text{s}}$$

THESE VALUES ARE CONSIDERABLY HIGHER
 THAN THE EXPECTED SOLENOID FLOW RATES OF
 16 g/s LHe ~ 39 g/s LN₂

7

$$\Delta h_{total} = \frac{V_{AB}^2}{2g} \left(f_{L_{AB}} \frac{L_{AB}}{D_{AB}} \right) + \frac{V_{BC}^2}{2g} \left(f_{L_{BC}} \frac{L_{BC}}{D_{BC}} \right) + \frac{V_{CD}^2}{2g} \left(f_{L_{CD}} \frac{L_{CD}}{D_{CD}} \right) + \frac{V_{BC}^2}{2g} (1) + \frac{V_{CD}^2}{2g} \left(f_{CD} \frac{32.0}{D} \right)$$

$$+ \frac{V_{CO}^2}{2g} \left(f_{CO} (9.5) \right) + \frac{V_{AB}^2}{2g} (1) + \frac{V_{CO}^2}{2g} (0.5)$$

for N_2 $V_{AB} = V_{N_2}$ in demand = 11.01 ft/s
 $V_{BC} = V_{CO} = V_{N_2}$ in annulus = 2.09
 $f_{L_{AB}} = .033$
 $f_{L_{BC}} = 0.023$ } MOODY CHART
 $\propto 64/Re$

$$\Delta h_{N_2} = \frac{(11.01 \text{ ft/s})^2}{2(32.174 \frac{\text{ft}}{\text{s}^2})} \left(.033 \frac{105 \frac{\text{ft}}{12}}{1.72 \frac{\text{ft}}{12}} \right) + \frac{(2.09 \frac{\text{ft}}{\text{s}})^2}{2(32.174 \frac{\text{ft}}{\text{s}^2})} \left(.023 \frac{109}{2.5} \right) + \frac{(2.09 \frac{\text{ft}}{\text{s}})^2}{2(32.174 \frac{\text{ft}}{\text{s}^2})} \left(.033 \frac{264}{2.5} \right)$$

$$+ \frac{11.01^2}{32.174} (1.5 + 32 \cdot 9.5) + \frac{11.01^2}{2(32.174)} (1) = 5.68 + 3.15 = 8.8 \text{ ft}$$

for H_2 $V_{AB} = V_{H_2}$ in demand = 78.10 ft/s
 $V_{BC} = V_{CO} = V_{H_2}$ in annulus = 14.85 ft/s
 $f_{L_{AB}} = .033$
 $f_{L_{BC}} = .045$ } MOODY
 transition?

$$\Delta h_{H_2} = \frac{78.1^2}{2(32.174)} \left(1 + (.033) \frac{105}{1.72} \right) \frac{14.85^2}{2(32.174)} \left(43 + \frac{109}{2.5} + \frac{(.045)(264)}{2.5} \right)$$

$$= 285.8 + 170.4 = 456 \text{ ft}$$

THESE ARE WELL BELOW THE P. 3 HEAD VALUES

WHAT ABOUT A 5 FOLD INCREASE IN FLOW (DP INCREASE IN PROPORTION TO V^2)

$$80 \text{ g/s} = 5.48 \times 10^{-3} \frac{\text{lb}_m}{\text{s}}$$

H_2 Demand 390.05 ft/s
 Annulus 74.23 ft/s

H_2 $h = 5395.3 + 3976.9 = 9372.2$

N_2 Demand 55.03 ft/s
 Annulus 10.46 ft/s

N_2 $h = 101.65 + 78.04 = 180.1$

H_2 $Re_{demand} = 50890 \rightarrow f = 0.021$

$Re_{annulus} = 9252 \rightarrow f = .023$

N_2 $Re_{demand} = 74286 \rightarrow f = .019$

$Re_{annulus} = 14120 \rightarrow f = .021$

STILL LESS THAN MAX ACCEPTABLE HEAD VALUE.

IT CAN BE SEEN THAT THE FRICTION FACTORS ARE CONVERGING TO AN UPPER BOUND OF ABOUT 0.02. 6

I WILL USE $f=0.02$ TO DETERMINE AN APPROXIMATE
 MAX ACCEPTABLE MASS FLOW RATE

$$V = \frac{\dot{m}}{\rho A}$$

He

$$17993 \text{ ft} = \left[\frac{\dot{m}}{(0.1925)(1.9403 \times 10^{-3})(2)(2.70594) \left(\frac{\text{ft}}{\text{s}}\right)^2} \right]^2 \left(1 + 0.02 \frac{(105)}{1.72} \right)$$

$$+ \left[\frac{\dot{m}}{(0.1925)(1.9403 \times 10^{-3})(28.47) \left(\frac{\text{ft}}{\text{s}}\right)^2} \right]^2 \left(43 + \frac{0.02(109)}{2.5} + \frac{0.02(264)}{2.5} \right)$$

$$(17993 \text{ ft})(2)(32.174 \frac{\text{ft}}{\text{s}^2}) = \frac{\dot{m}^2}{\text{ft}^2} (1.2127 \times 10^{10}) + \frac{\dot{m}^2}{\text{ft}^2} (3.6053 \times 10^9)$$

$$\dot{m}^2 = 7.7824 \times 10^{-4} \frac{\text{ft}^2}{\text{s}^2} \rightarrow \dot{m} = 0.008813 \frac{\text{ft} \cdot \text{s}}{\text{ft}^2} \cdot \frac{1 \text{ kg}}{\text{s}} = 6.4582 \times 10^{-2} \frac{\text{kg}}{\text{s}}$$

$$= \frac{0.1247 \text{ kg}}{\text{s}}$$

$$= \frac{128.79}{\text{s}}$$

N₂

$$2532.96 \text{ ft} = \frac{\dot{m}^2}{(1.366)^2(1.9403 \times 10^{-3})(2)(2.70594) \left(\frac{\text{ft}}{\text{s}}\right)^2} \left[1 + 0.02 \frac{(105)}{1.72} \right] \frac{\text{ft}^2}{\text{ft}^2 \cdot \text{s}^2}$$

$$+ \frac{\dot{m}^2}{(1.366)^2(1.9403 \times 10^{-3})(28.47) \left(\frac{\text{ft}}{\text{s}}\right)^2} \left[43 + 0.02 \frac{(109)}{2.5} + 0.02 \frac{(264)}{2.5} \right] \frac{\text{ft}^2}{\text{ft}^2 \cdot \text{s}^2}$$

$$2532.96(2)(32.174) \frac{\text{ft}^2}{\text{s}^2} = \frac{\dot{m}^2}{\text{ft}^2} (2.23433 \times 10^9) + \frac{\dot{m}^2}{\text{ft}^2} (1.67462 \times 10^8)$$

$$\dot{m}^2 = 4.165 \times 10^{-4} \rightarrow \dot{m} = 0.0204 \frac{\text{ft} \cdot \text{s}}{\text{ft}^2} \left(\frac{1 \text{ kg}}{\text{s}} \right) = 6.4522 \times 10^{-2} \frac{\text{kg}}{\text{s}}$$

$$= \frac{0.2978 \text{ kg}}{\text{s}} = \frac{297.8 \text{ g}}{\text{s}}$$

THESE VALUES ARE CONSIDERABLY HIGHER THAN THE EXPECTED SOLENOID FLOW RATES OF
 16 g/s LN₂ = 3 g/s LN₂

7



SUBJECT
DØ SOLENOID - VACUUM VESSEL RELIEF
CAPACITY REQUIREMENT


NAME
RUSS RUCINSKI
DATE
7/27/93
REVISION DATE

IT HAS BEEN CALCULATED THAT THE CHIMNEY VACUUM JACKET HAS 130 G/S HELIUM OR 300 G/S NITROGEN VENTING CAPACITY FOR 3 PSIG AT THE SOLENOID & 1.5 PSIG LIFT PLATE.

I WILL TRY TO PROVE THAT THIS CAPACITY IS GREATER THAN THAT POSSIBLE BY A "FAILURE" MODE. [NOTE OPERATIONAL FLOW RATES ARE EXPECTED TO BE 15 G/S He MAX. AND 3 G/S N₂.]

- TRY MOST CONSERVATIVE (& EASIEST) ASSUMPTIONS.

LHe MAX. DELIVERY RATE: STORAGE DEWAR AT 1.8 ATM



HARD W'S ARE NOT AVAILABLE SINCE THE LINE FROM THE STORAGE DEWAR TO CONTROL DEWAR IS NOT SIZED YET.

→ ESTIMATE CRITEREA FOR LINE SIZING.

$$\left. \begin{array}{l} 1) P_1 = 1.8 \text{ ATM} = 11.8 \text{ psig} \\ P_2 = 1.7 \text{ ATM} = 10.3 \text{ psig} \end{array} \right\} \text{ AT } 15 \text{ G/S } \text{ MAX. EXPECTED OPERATIONAL FLOW}$$

LENGTH OF PIPE ≈ 200 FT FOR COLL. HALL DETECTOR POSITION (LONGEST)

$$\Delta P = 3.36 \times 10^{-6} \frac{f L W^2}{\rho d^5} \quad \text{KNOWING } W, L, f, \Delta P \text{ AND } d \ \& \ Re$$

$$W = 15 \text{ G/S} \quad \mu = 2.864 \mu \text{Pa-s} \quad \rho = 106.7 \text{ KG/M}^3$$

$$Re = \frac{dW}{\mu}$$

(8)



SUBJECT

DØ SOLENOID - VACUUM VESSEL RELIEF
CAPACITY REQUIREMENT

NAME

RUSS RUCINSKI

DATE

7/28/93

REVISION DATE

← OFF MOODY.

d	Re	f	ΔP_{100}
.75	350,052	.014	.042 psi
.62"	423,451	.0135	.105 psi
.37"	709,566	.012	1.24 psi
.495	530,382	.013	0.312 psi ←

BASED ON THESE CALCULATIONS I WOULD ESTIMATE THAT WE WILL PROBABLY USE 5/8" O.D. X .065" WALL STAINLESS TUBING FOR THE X-FER LINE FROM THE DEWAR TO CONTROL DEWAR. ΔP TO COLLISION HALL AT MAX. FLOW RATE \approx 0.62 psi.

FOR ASS'Y HALL $\Delta P \approx$ 0.312 psi. SINCE WE ARE IN TURBULENT FLOW REGIME, $\Delta P \propto W^2$

$$\Delta P_1 = 0.312 \text{ psi} \quad W_1 = 15 \text{ g/s}$$

$$\Delta P_2 = 8.8 \text{ psi} \quad W_2 = ? \quad \leftarrow \Delta P = 11.8 \text{ psig} - 3 \text{ psig}$$

LEAK/RUPTURE IN
SOLENOID / CONTROL
DEWAR

$$\frac{\Delta P_1}{W_1^2} = \frac{\Delta P_2}{W_2^2} \Rightarrow W_2^2 = \frac{\Delta P_2}{\Delta P_1} W_1^2$$

$$W_2 = \sqrt{\frac{\Delta P_2}{\Delta P_1} W_1^2} = \sqrt{\frac{8.8}{.312} (15 \text{ g/s})^2} = \underline{79.7 \text{ g/s}}$$

FOR UPSET CONDITIONS, WORST CASE, MAXIMUM LHR FLOW ALLOWED THRU SUPPLY LINE TO CONTROL DEWAR OR SOLENOID IS 80 g/s. THIS IS LESS THAN 130 g/s CAPACITY OF RELIEF PATH.



SUBJECT
Dφ SOLENOID - VACUUM VESSEL RELIEF
CAPACITY REQUIREMENT.

NAME
RUSS RUCINSKI
DATE
7/28/93
REVISION DATE

LN₂ MAX. DELIVERY RATE:

THE LN₂ CIRCUIT WILL RUN IN THE SAME VACUUM JACKET AS THE LHe PIPES FROM THE LHe STORAGE DEWAR TO THE CONTROL DEWAR. THE EXPECTED OPERATIONAL MASS FLOW RATE IS ABOUT 2-3 g/s.

L = 100 ft ASS'Y HALL POSITION
200 ft COLL. HALL POSITION

AT THE INLET TO THE CONTROL DEWAR THE OPERATIONAL PRESSURE OF THE LN₂ CIRCUIT WILL BE ABOUT 10 PSIG.

THE TUBING IN THE TRANSFER LINE WOULD BE NO LARGER THAN 1/2" O.D. x .065" WALL TUBE WHICH WOULD GIVE AN OPERATIONAL PRESSURE DROP OF:

$$d = 0.37 \text{ IN}, \rho = 771 \text{ kg/m}^3, \mu = 120 \mu\text{Pa}\cdot\text{s} \left. \begin{array}{l} \text{SAT. LN}_2 \\ 228 \text{ kPa} \end{array} \right\}$$

$$Re = 338.6 \Rightarrow \text{TRANSITION} \frac{64}{Re} = 0.19 < f < 0.04$$

$\Delta P_{100} < 0.02 \text{ psi}$ WHICH IS NEGLIGIBLE.

{ IN REAL CASE SOME 2φ WOULD BE FLOWING }
TENDING TO INCREASE ΔP.

USING SAME REASONING AS WITH LHe

$$W_2 = \sqrt{\frac{\Delta P_2}{\Delta P_1}} W_1 \quad \text{WHERE: SUBSCRIPT-2 REFERS TO SEVERED LINE CASE}$$

$$W_2 = \sqrt{\frac{(10 \text{ psig} - 3 \text{ psig})}{(10.02 - 10 \text{ psig})}} (3 \text{ g/s})^2 = 56 \text{ g/s} \quad \begin{array}{l} * \text{TK 5MS} \\ 80 \text{ g/s} \end{array}$$

THIS IS LESS THAN 300 g/s CAPACITY OF (10) RELIEF PATH.

= 17



SUBJECT

DØ SOLENOID - VACUUM VESSEL RELIEF
CAPACITY REQUIREMENT.

NAME

RUSS RUCINSKI

DATE

7/28/93

REVISION DATE

NOTE TO CALCULATIONS:

THESE CALCULATIONS ARE ONLY MEANT FOR THE PURPOSE OF BOUNDING THE WORST CASE SCENARIO. ASSUMPTIONS WERE MADE ABOUT THE TRANSFER LINE SIZES. VALUES USED FOR THE OPERATIONAL PRESSURES AND FLOWRATES, ARE PRETTY WELL KNOWN AT THIS TIME. IT IS NOT REALISTIC TO ASSUME THAT A COMPLETE RUPTURE INTO THE SOLENOID VACUUM JACKET WILL OCCUR.

THE REAL VALUE OF THESE CALCULATIONS IS THAT I FEEL IT PROVES THE VALIDITY OF THE STATEMENT,

"THE RELIEF VENTING PATH CAPACITY IS MUCH GREATER THAN POSSIBLE FAILURE MODE FLOWRATES".

THIS IS STATED IN MY CHAPTER 5 OF THE SOLENOID DESIGN REPORT.

<u>St. Input</u>	<u>Name</u>	<u>Output</u>	<u>Unit</u>	<u>Comment</u>
				D0 Solenoid LN2 line
				Russ Rucinski RD/DØ 7/28/93
				** FLUID FLOW IN PIPES **
				Pressure drop equation from Crane
				Technical paper 410
100	L		ft	length of pipe
.37	d		in	pipe inside diameter
.04	f			friction factor of pipe
	Re	3386.996		Reynolds number of pipe flow
795	rho		kg/m ³	fluid mass density
	dP	.02212023	lb/in ²	pressure drop across pipe of length L
	Area	.10752101	in ²	cross-sectional area of pipe
3	mdot		g/s	mass flow rate
.00012	mu		Pa-s	fluid viscosity
	W	23.80968	lb/hr	

<u>St. Input</u>	<u>Name</u>	<u>Output</u>	<u>Unit</u>	<u>Comment</u>
				D0 Solenoid LN2, max flow
				with delta P of 7 psi
				Russ Rucinski RD/DØ 7/28/93
				** FLUID FLOW IN PIPES **
				Pressure drop equation from Crane
				Technical paper 410

100	L		ft	length of pipe
.37	d		in	pipe inside diameter
.019	f			friction factor of pipe
	Re	90319.894		Reynolds number of pipe flow
795	rho		kg/m ³	fluid mass density
	dP	7.4717217	lb/in ²	pressure drop across pipe of length L
	Area	.10752101	in ²	cross-sectional area of pipe
80	mdot		g/s	mass flow rate
.00012	mu		Pa-s	fluid viscosity
	W	634.9248	lb/hr	

<u>St. Input</u>	<u>Name</u>	<u>Output</u>	<u>Unit</u>	<u>Comment</u>
				D0 Solenoid LHe line
				Russ Rucinski RD/DØ 7/28/93
				** FLUID FLOW IN PIPES **
				Pressure drop equation from Crane
				Technical paper 410

100	L		ft	length of pipe
.495	d		in	pipe inside diameter
.013	f			friction factor of pipe
	Re	530382.82		Reynolds number of pipe flow
106.7	rho		kg/m ³	fluid mass density
	dP	.3124628	lb/in ²	pressure drop across pipe of length L
	Area	.19244218	in ²	cross-sectional area of pipe
15	mdot		g/s	mass flow rate
2.864E-6	mu		Pa-s	fluid viscosity
	W	119.0484	lb/hr	