ANL-6253
Reactors - General
(TID-4500, 15th Ed.)
AEC Research and
Development Report

ARGONNE NATIONAL LABORATORY
9700 South Cass Avenue
Argonne, Illinois

REACTOR DEVELOPMENT PROGRAM
PROGRESS REPORT

October 1960

N. Hilberry, Laboratory Director

<u>Division</u>	<u>Director</u>
Chemical Engineering	S. Lawroski
Idaho	M. Novick
Metallurgy	F. G. Foote
Reactor Engineering	B. I. Spinrad
Remote Control	R. C. Goertz

Report coordinated by R. M. Adams

Issued November 15, 1960

Operated by The University of Chicago
under

Contract W-31-109-eng-38

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Previous reports issued in this series:

August, 1960 ANL-6215

September, 1960 ANL-6234

TABLE OF CONTENTS

	<u>Page</u>
I. Water Cooled Reactors (040101)	1
A. General Research and Development	1
1. Heat Transfer and Fluid Flow Studies	1
2. Boiling Slurry Reactor Experiment (SLURREX)	2
3. Reactor Decontamination	2
B. EBWR	3
1. 100 Mw Modifications	3
2. Supporting Research and Development	4
3. EBWR, Core II	5
C. BORAX V	6
1. Construction	6
2. Procurement	6
3. Design	7
4. Development and Fabrication	7
II. Sodium Cooled Reactors (040103)	9
A. General Research and Development	9
1. ZPR-III	9
2. ZPR-VI and IX	10
3. Juggernaut	11
4. Fuel Fabrication Facility	12
5. Irradiation Studies - Fast Reactor Fuels	13
B. EBR-I	13
1. Mark III Operation	13
2. Mark IV Development	14
C. EBR-II	15
1. Construction	15
2. Installation of Equipment	16
3. Engineering	16
4. Procurement	17
5. Component Development - Reactor	17
6. Component Development - Steam Generators	20
7. Component Development - Fuel Reprocessing Facilities	21
8. EBR-II Fuel Fabrication and Development	21
9. Process Development	24

	<u>Page</u>
III. Studies and Evaluations (040116)	27
IV. Reactor Safety (040117)	28
A. Thermal Reactor Safety Studies	28
1. Fuel-Coolant Chemical Reactions	28
2. Kinetics of Oxidation and Ignition of Reactor Materials	29
B. Fast Reactor Safety Studies	29
1. TREAT - Experimental	29
2. Out-of-Pile Meltdown Studies	32
3. Theoretical Studies of Meltdown	33
4. Thermal Measurements of U-Fs	34
5. TREAT - Reactor Development	34
V. Nuclear Technology and General Support (040400)	36
A. Applied Nuclear and Reactor Physics	36
1. Experimental	36
2. Theoretical	40
B. Reactor Fuels and Materials Development	41
1. Ceramic Fuels	41
2. Properties of Metals and Alloys	42
3. Corrosion Studies	44
4. Irradiation Studies	45
5. Nondestructive Testing Techniques	46
6. Liquid Metal Slurry Studies	47
C. Reactor Components Development	47
1. Development of Shielded Facilities	47
2. Development of Viewing Systems	48
3. Instrumentation and Control	48
4. Heat Engineering Studies	49
D. Separations Development	49
1. Fluidization and Fluoride Volatility Separations Processes	49
2. Chemical-Metallurgical Process Studies	51
E. Advanced Reactor Development	53
1. Argonne High Flux Reactor (AHFR)	53
2. Basic Radiation Effects Reactor	55
3. Packed Bed Fuel Elements	55
4. Lunar Power Plant	57
5. Direct Conversion Studies	57
VI. Publications	58

I. WATER COOLED REACTORS (040101)

A. General Research and Development

1. Heat Transfer and Fluid Flow Studies

a. Steam-Water Separation Studies - Studies are being continued on the problem of steam carryunder in the downcomer of a natural circulation boiling reactor. Exploratory studies are made with air-water mixtures at atmospheric pressure to establish parameters for high pressure steam-water tests at 135 atm (2000 psi). These air-water studies disclosed a marked sensitivity of the volumetric void fraction to velocity in downflow. As the downcomer velocity of the two-phase mixture approaches the buoyancy velocity of the gas bubbles, the void fraction increases sharply.

In addition, a strong temperature effect on degree of carryunder was noted. Preliminary analysis suggests that this effect must be a function of the fluid viscosity since no other fluid properties were changing with temperature. A preliminary empirical correlation taking into account the various effects noted thus far has been developed. It appears to have promise and will be tested over wider ranges of the variables.

b. Hydrodynamic Instability - Reactors and hydrodynamic test loops have demonstrated unstable behavior under certain operating conditions. There have been two distinct mechanisms postulated as the cause of these oscillations: (1) a feedback loop-power-voids-reactivity-power relationship which makes a reactor unstable; and (2) a mechanism which causes a test loop heated at constant power to become unstable and in a similar manner affects a reactor. Possibly both of these mechanisms contribute to unstable reactor behavior but undeniably the second mechanism operates in a test loop. Three separate but complementary studies concerned with instability are in progress:

(1) An autocorrelation noise analysis is being applied to the inlet and outlet flow and void traces from the Armadilla test loop. The amplitude of these variables under different operating conditions will be obtained. A recent series of traces is now being analyzed.

(2) Measurements are being planned of the power-to-void transfer function for an electrically heated test section in an out-of-pile test loop. A 1.27 m long rectangular test section is to be inserted in the small scale 135 atm (2000 psi) loop. The effect of sinusoidal power variations on steam bubble density inside the test tube at different heights will be measured as a function of oscillation frequency.

The test section has been fitted with thermocouples, and is now being installed in the test loop. Thermocouples for measuring the water temperature at the inlet and outlet of the test section have been calibrated and a traversing system for the steam void detector is being built.

A typical condition for the oscillation test will be: pressure 41 atm (600 psi), water flow velocity 1.5 m/sec, and heating power 50 kw. Under these conditions subcooled boiling will always take place all the way down to the inlet. Because of this, the incremental heat transfer coefficient has

been found theoretically to change relatively little along the test element. A transfer function representation of the heat transfer from test element wall to coolant has been completed. It has been found that under the conditions cited, about half the heat leaves the wall in the form of steam bubbles. The rest is transferred to the water, and there will be a certain time delay until this part of the heat shows up as voids. This effect is now being studied theoretically, in order to determine whether this time delay is long enough to warrant inclusion in the theoretical model.

(3) Finally, in a program using the Armadilla loop (41 atm) the influence of pressure, test section geometry, riser geometry, water level, and inlet temperature on the power at the inception of oscillations, oscillation period, and oscillation amplitude is being studied. A 1.08 cm diameter test section and riser has been built. The old 1.58 cm test section and riser and the lower portion of the loop are being altered to facilitate interchanging of test sections and risers.

2. Boiling Slurry Reactor Experiment (SLURREX)

It is the Laboratory's understanding that the SLURREX proposal will not be supported by the Commission. Accordingly, a terminal report summarizing the work done to date is being prepared.

3. Reactor Decontamination

The reactor decontamination program has two main objectives: (a) to determine the seriousness of fuel ruptures in boiling water reactors as measured by the quantities of radioactive materials which deposit in the steam system, and (b) to determine what methods of decontamination can be used to remove these deposited activities. The first study is being made with a stainless steel loop that simulates the action of a boiling water reactor into which mixed fission products can be introduced. Quantities and types of fission products deposited are monitored by several methods. A second study is being made in the laboratory to find suitable means of removing deposited activity.

In the laboratory, it was reported that the presence of oxygen during the contamination portion of an experiment reduced the effectiveness of decontamination by the alkaline permanganate-citrate procedure. This effect was greater when 30-day-cooled uranium was used for the experiment than it was with 60-day-cooled uranium. Corrosion studies of various turbine materials in typical decontamination reagents were continued. Pitting of chromium-molybdenum steels in citrate solutions adjusted to pH = 10 was found to be appreciably reduced when hexamethylene tetramine was added as an inhibitor; 2-mercapto-benzo-thiazole was also effective, although several deep pits were still observed.

In loop runs deposition of zirconium-95 and ruthenium-103 on the metal sample strip in the disengaging section decreased substantially with elevation. Cerium-141 deposition was lower on strips exposed in the liquid than would be expected from its concentration in the circulating liquid. The total gamma activity in steam samples permitted only limited observa-

tions regarding isotopic content. Disengaging factors* calculated were 2×10^3 for total gamma counts and 9×10^4 for zirconium-95. Disengaging factors for other fission products fell in between these two values. Gamma spectra of loop water and residual undissolved uranium oxide indicated that iodine-131 was preferentially leached into the water.

B. EBWR

1. 100 Mw Modifications

a. Construction and Equipment - Hydrostatic tests on the primary reboilers revealed the presence of numerous leaks in the tube end seal welds. Some repairs to No. 1 reboiler were made but additional leaks were uncovered upon further testing. Negotiations are in progress to establish procedures for repair and reinstallation of the equipment. Although this work may require appreciable time, the operations planned for EBWR during 1960 do not include use of the reboiler system.

A review of the electrical system drawings has been performed with the architect-engineer field representative. As-built drawings for the new plant are now complete and up-to-date.

b. Chemical Control System - Delivery delays of neutron sources and electronic equipment necessary for the soluble poison monitoring devices have set back completion of the reactor purification and chemical control system. All pipe-fitting is completed and electrical service installation is nearing completion.

Phantom drawings of the purification system valving for various operational modes have been completed for inclusion in the Operating Manual and for display at the valving station of the purification system.

c. EBWR Instrumented Assemblies - More two-phase pressure drop data across the turbine flowmeters on the EBWR instrumented assemblies have been obtained. It is now evident, contrary to last month's tentative report, that the two-phase pressure drop corresponds to the values originally predicted.

Clips that locate the in-core flux monitors between fuel plates of these instrumented assemblies had to be redesigned. This redesign has caused a minor delay in the final fabrication of the second instrumented assembly.

Instrumentation for the EBWR fuel element test section has been installed and is ready for a series of tests. Burnout detection is provided by a d-c burnout detector and by a temperature burnout detector. The first instrument responds to a resistive unbalance in the test section due to a temperature excursion; the second instrument will shut off power when the temperature near the heated exit exceeds a predetermined level. The

*Disengaging factor is the ratio of the activity in the liquid phase to that in the vapor phase. This factor is often called a decontamination factor in the literature but is not so called herein to avoid confusion with the "decontamination factors" which are the ratios of activities on solid surfaces before and after various chemical treatments.

temperature profile along the test section will be scanned by a mercury-jet switch. The feasibility of thermocouple scanning was checked by monitoring three thermocouples on a heated nichrome strip. The thermocouple outputs were readable with one-millivolt resolution.

d. Void Simulators - Four void simulator units are being fabricated for use in EBWR critical experiments. Each unit contains five hollow rectangular tubes connected to a header. The rectangular tubes are located between the fuel plates of thin EBWR Core-I fuel elements. Simulation of voids will be accomplished by removal of the water in these tubes using air pressure.

e. Containment Shell Leak Rate Test - A leak rate test of the EBWR containment shell was conducted during the period October 11, 1960, through October 13, 1960. The leak rate curve appears to be within the allowable shell leakage rate limitation of 1000 cu. ft. of air at STP per 24 hr. However, because of unusual spread in the points obtained, a fitted curve will be calculated on the IBM-704 to determine the leak rate.

f. Operator Training - Work is in progress on a display and training board of the EBWR main steam and feedwater piping. Piping is represented by colored tapes which closely duplicate the color coding used in the plant. All valves will be shown in their proper locations and numbered with both the old and the new system.

Lectures on nuclear instrumentation have been presented to reactor operating personnel.

2. Supporting Research and Development

a. Examination of Original Control Rods - A facility has been constructed and operated in the EBWR fuel storage pit for sawing the old control rods into short lengths for handling and analysis. The original EBWR No. 4 boron-steel and No. 9 hafnium control rods were each cut into thirty 15 cm lengths. In addition, the hafnium to Zircaloy-2 transition region was removed from the No. 1 hafnium control rod for comparison with the similar portion of the No. 9 control rod which had been found to be parted when removed from the reactor.

The 15 cm length removed from the No. 4 boron-steel control rod which had highest radioactivity contained the boron-steel-Zircaloy-2 transition (2.6 r/hr under 30 cm of water). Highest activity on the No. 9 hafnium rod occurred at the middle of the Zircaloy-2 portion (1.0 r/hr under 30 cm of water).

The control rod end tips and the extension shaft ends showed high activation. Since these are located completely out of the neutron flux zone, it is surmised that the activity of the extension shaft ends is associated with crud deposits. The grapple end (top of the poison section) of the hafnium rod was remarkably free of activity (25 mr/hr in air).

b. Irradiation Damage - The availability of SA-212B steel removed from the EBWR pressure vessel affords an opportunity to study the long-term (approximately 10,000 hr) influence of biaxial stress and temperature,

and the effects of fabrication on the impact properties of this steel. The results from this research are expected to establish the validity of the assumptions of reactor safety associated with requirements for fine-grained, high impact strength (at low temperatures) steels currently required for nuclear reactor pressure vessels. A reference block of SA-212B steel in the form of 4 in. plate from part of the lower EBWR head is available for the comparison study. The reference plate is part of the same heat of steel used in fabrication of the EBWR shell.

A cutting diagram was prepared for the sectioning of a "standard" heat of SA-212B steel into multi-notch impact specimens. This is a carefully documented heat of steel made available by the U. S. Steel Corporation to the workers in the field. These impact specimens are to be irradiated in a vertical tube irradiation assembly placed within the reflector region of the EBWR. The irradiation facility (described in the July, 1960, Progress Report) incorporates a method for shielding some of the samples with boron.

A metal thermometer for determining maximum specimen temperatures during irradiation has undergone some preliminary tests. The indication is based on the melting temperatures of various lead-tin alloys. However, the preliminary tests showed that surface tension prevented the small globule (1.5 mm diameter) of molten metal from parting after the melting temperature was reached. Modified versions of the device are being constructed in an effort to overcome this difficulty.

3. EBWR Core-II

a. Hydrodynamic Calculations - A considerable improvement in velocity distribution in a spike core can be achieved by using a different diameter of rods in the spiked region instead of a uniform rod diameter. Table I shows the results of the calculations.

Table I

	No. Rods	Rod Diameter (cm)	Power (mw)	Average Inlet Velocity (m/sec)	Average Exit Void Fraction
Central Region	36	1.194	18	1.79	0.356
Spike Region	32	1.041	47	1.86	0.628
Outer Region	79	1.194	35	1.86	0.249

The velocities calculated are satisfactory with respect to instability and burnout although the exit void in the spike region is high. This permits more flow area in the spike region.

b. Development of EBWR Core II Cladding - Adequate corrosion resistance and mechanical strength at elevated temperatures are important requirements of an aluminum alloy to make it acceptable for fuel cladding in a power reactor.

Under subcontract to the Laboratory Armour Research Foundation is investigating the development of aluminum alloys having adequate properties

as above for application to EBWR Core II cladding.

The method employed is powder extrusion of mixtures containing additives, possibly nonmetallic. High temperature strength is obtained through the presence of a dispersed insoluble phase. Materials in rod specimen form have now been produced which have close to the desired properties. It remains to optimize these properties and to produce tubing from these compositions.

During the month, powder has been produced in an atomizing apparatus, but the yield was low. Furthermore, analytical techniques were not good enough to evaluate silicon pickup, a most important feature. Low silicon A288 powder has been obtained from ALCOA and extrusion die design and procurement has started.

General studies of variables affecting strength and corrosion resistance of the extruded product continue. Present emphasis is on composition and concentration of the dispersant.

C. BORAX V

1. Construction

The reactor vessel was unloaded at the site on October 12. Insulation of the vessel and mounting of the thermocouples has begun. Most of the piping in the equipment pit has been placed, and the major portion of the piping in the east trench running from the equipment pit to the access shaft has been installed. The boron dump tank and the batch emergency storage tank have been positioned and piping to them is installed.

The two control air compressors have been positioned and the main air piping has been installed. The air filter and dryer in the turbine building are connected.

Conduit and junction boxes for equipment pit and access shaft lighting is in place. Conduit in the east building wall from the motor control center and to the access shaft is in place.

The exterior trench between reactor and turbine building has been partially covered and back-filled.

Heating and ventilating duct for the reactor building is in, and the heating unit has been placed in operation by connecting to the temporary electrical supply.

The construction contract was 83.0% complete as of October 31, 1960, versus the 97% scheduled.

2. Procurement

The scheduled delivery of boiling fuel rods calls for delivery of 100 empty rods, 12 natural rods and 100 enriched rods by the end of October. The 100 empty rods have been delivered and it appears that the schedule will be met on the remainder. The rods are scheduled to be shipped in

weekly partial shipments of from 400 to 600 rods, with shipment to be completed by December 19.

A contract for fabrication of superheat fuel plates was signed on October 3, with Atomics International. The scheduled delivery calls for shipment of sample plates in 12 weeks and delivery of final superheat plates 13 weeks after approval of the samples. Allowing two weeks for testing, delivery should be complete by April 17.

Fabrication of the boiling fuel assemblies at Central Shops has begun. Materials procurement for the three core structures has started.

An order has been placed for area radiation monitors. Most of the accessory equipment for reactor instrumentation and control is on hand and installation and wiring of this equipment is proceeding. Seven of the process instrumentation and control items remain to be received.

3. Design

Drawings for fabrication of the three core support structures, control rods, hold-down boxes, and chimneys have been forwarded to Central Shops for fabrication.

The preliminary design of all fuel handling tools has been completed. A boiling fuel assembly grapppler has been fabricated and tested under water. The solenoid and latch work satisfactorily. A tank for underwater testing of all handling equipment has been designed and bids have been requested. Visibility and handling methods will be checked out in this tank.

The preliminary design of the air ejector exhaust modification is complete. This modification will include the addition of an auxiliary condenser and de-mister to remove moisture, a fan to add dilution air and place the filters under negative pressure, means for reducing the hydrogen concentration, and a charcoal filter for collection of fission product iodine.

A study is in progress to determine the effects on heat transfer which would result from changing the superheat fuel plate spacers from disks to wires.

Hazard evaluation studies are continuing. The studies have been concentrated on the effects of metal-water reaction on radioactivity release and the effects of high rates of reactivity addition possible in the cold water accident. Analysis is also being done on the possibility of superheater meltdown.

4. Development and Fabrication

a. Superheat Fuel - The contract for fabrication of stainless steel-uranium oxide dispersion type superheat fuel plates for BORAX V was awarded to Atomics International Division of North American Aviation. These plates are to be evaluated by the Laboratory for adherence to specifications.

The nondestructive testing group has completed assembly of equipment to be used for measuring the amount and distribution of U-235, cladding thickness, bond integrity, and radioactive surface contamination on each plate. No test has yet been developed for detecting surface halide ion contamination. Special equipment for all other nondestructive tests is almost complete.

The equipment ordered for preparation of metallographic specimens has been received and is being installed. When the microscopes to be used for examination of specimens containing enriched uranium are received, equipment will be ready for all specified destructive tests. The Chemistry Division is making preparations for analyzing the required number of plate samples.

The method of assembly of fuel plates is still under development. Efforts have been concentrated on achievement of a weld between the plates and spacers which will not penetrate beyond the surface cladding and will produce a strong metallurgical bond. The plates with spacers welded on one face will then be stacked and furnace brazed in a vacuum. Three experimental assemblies have been made, and one has been sectioned for examination of the plate to spacer bond and the side strip to plate bond.

b. Control Rod Drives - The old drives from EBWR are being reworked for use on BORAX V. Final testing prior to shipping the drives to Idaho has been started. All components, except a gear safety cover and water deflector, have been received. The water deflector is used to direct the flow during cleanout of dashpot and seal housings. Neither item will hold up delivery to Idaho. Shipment of drives is still expected before December 1.

c. Miscellaneous - Three modifications of the air water flow test loop were made. To reduce vibration of the test section, bracing and expansion joints on either side of the pump were installed. A viewing port was added in the pump suction line to see if bubbles were being carried in the water line. A small control valve was added in parallel with the large, air-flow control valve to provide more satisfactory control at low flow rates. These modifications were completed and testing has begun on the Potter meters at low flow rates.

Sample boiling fuel thermocouples were received from the Aero Research Corporation and were sent to Hoskins Company for calibration. These are tungsten-tungsten, 26% rhenium with tantalum sheath and magnesium oxide insulation for measuring central fuel temperatures to 4800°F.

Leak testing of the condenser has been completed.

II. SODIUM COOLED REACTORS (040103)

A. General Research and Development

1. ZPR-III

a. Operations - Critical studies of the first of a series of oxide cores were initiated during the last month. Uranium oxide fuel was not available, therefore, aluminum oxide pieces, and uranium pieces were interspersed to achieve the desired atomic ratio of 2:1 for oxygen:uranium.

The core investigated was of an estimated 370 liter size with a calculated critical mass of 350 kg of U-235. It was 28 inches long and approximately 32 inches in diameter, blanketed with 12 inches of 83 v/o depleted uranium. The core is composed of an assembly of 2 in. x 2 in. x 14 in. drawers with 16 columns of material in each drawer. The columns are distributed as follows: three columns of uranium, six columns of aluminum oxide, four columns of 45% aluminum, and three columns of stainless steel. This arrangement preserves an atom ratio of oxygen to uranium of 1.90 to 1, and corresponds to 26 v/o UO_2 of density 10.9. The amount of aluminum present is equivalent to 48 v/o of sodium in the core if 48 v/o sodium is considered to be simulated by 24 v/o of aluminum metal. The stainless steel in the core mockup, including the drawers and matrix channels, amounts to 24.7 v/o. Further descriptive data may be found in the September Progress Report, ANL 6234. (On page 10 of the September progress report, paragraph 4, line 5, 26.9 v/o stainless steel should be changed to read 24.7 v/o stainless steel).

Contrary to the estimates, the original core was subcritical using all of the available pieces of aluminum oxide. This loading contained approximately 400 kg of U-235. A plot of subcritical multiplication indicated that the core would go critical with the mass of U-235 in excess of 475 kg. Since there was not available sufficient aluminum oxide to continue building up this same composition, criticality was approached from this point by increasing the enrichment in distributed drawers. The loadings of 56 drawers were changed to increase the average core enrichment from 31% to 33.21%. This loading went critical at 422.91 kg of U-235.

The control rods were calibrated using both period and subcritical multiplication measurements and the worth of core material at the edge of the core was determined. The corrected clean critical mass was then calculated as 420.7 kg of U-235.

Measurements of the average neutron lifetime were made by the Rossi-alpha method. The Rossi-alpha was tentatively determined to be $3.48 \times 10^4 \text{ sec}^{-1}$, which (with β estimated at 7.3×10^{-3}) gives an average neutron lifetime of 21×10^{-8} seconds.

Axial danger coefficient traverses were made with the following samples: 22.93 g of fully enriched uranium, 64.387 g of natural uranium, 24.09 g of plutonium, and 3.25 g of boron-10.

To obtain information on the neutron spectrum, gold and sodium

resonance detectors and U-238 and U-235 fission foils were activated and analyzed. The U-238 foils were also analyzed for neptunium to determine neutron capture. Of particular interest for this core were the gold (30,000 barns, 4.9 ev) and sodium (360 barns, 2.9 kev) resonance peaks as an attempt to determine some characteristics of the soft end of the neutron spectrum.

Axial counter traverses were made with U-234, U-235, U-238 and plutonium fission counters and a $B^{10}F_3$ proportional counter. The fission distributions were plotted and the fission ratios determined for Pu:U-235, U-234:U-235 and U-238:U-235. Because of interest in low energy regions of the neutron spectrum a miniature $B^{10}F_3$ counter was purchased and adapted for use with the fission counter traverse mechanism.

b. Analysis - Multigroup calculations of a ZPR-III uranium oxide assembly resulted in a critical mass estimate about 40% smaller than observed experimentally. For an aluminum-U-235 assembly previously studied the calculated critical mass is 12% too small. If the latter discrepancy is attributed to incorrectly evaluated group transport cross sections for aluminum and iron in the region of the scattering resonances due to the effects of flux depression at the resonances, the appropriate group transport cross sections of aluminum and iron should be reduced. A 12% average reduction in the transport cross sections in the energy range 9 kev to 1.35 Mev was specified. For the case of the oxide assembly, which contains large volume fractions of iron and aluminum, 0.24 and 0.25, respectively, these reductions in transport cross sections reduce the calculated critical mass error to 10-15%. This remaining discrepancy suggests that the group cross sections of oxygen may also require re-evaluation.

2. ZPR-VI and ZPR-IX

a. Construction and Procurement - Preparations for the ZPR-VI and ZPR-IX systems have been carried as a single effort in order to achieve a measure of economy in the procurement of components in common between these two systems. Consequently, preparations for the two systems are very much intertwined. Recently, however, a review has been undertaken to determine the advisability of deferring ZPR-IX. This delay has unavoidably slowed the pace of procurement of components for ZPR-VI. As an example, detailed drawings of the bed and table assembly have been received from the supplier but their approval has been postponed, pending a decision on whether one or two units are to be obtained. Construction on the neutron source drives and storage units is in a similar status and the awarding of the contract for the control console and nuclear instrumentation has also been delayed.

The design and drawings have been completed for the ZPR-VI loading platform, the fuel drawer transport system and the television monitoring system. It is anticipated that a decision regarding ZPR-IX will have been reached by the time that specifications for these items have been prepared for solicitation of bids.

A machine to coat the uranium fuel and blanket material is being fabricated and is sufficiently well along that an initial trial run is being

planned for late November. The machine is designed to dip-coat, bake, and dry a maximum of 65 small pieces of uranium per minute in a continuous operation. KEL-F, a trifluorochloroethylene polymer, has been tested as a substitute for the higher cost tetrafluorethylene material used in coating the ZPR-III uranium and appears satisfactory for the ZPR-VI coating operation. The preliminary testing of the fuel coating apparatus will provide an opportunity for additional testing of the KEL-F coating.

All of the No. 4 cell doors and frames have been installed in Building D-315. The concrete floor and bottom half of the cell walls was poured October 19. Three doors for cell No. 5 have been filled with high density concrete. In addition, the roof forms for the cell are being erected. Approximately 50% of the total brick work is complete in cell No. 6 and work continues on ducting, conduits, and service piping. Over-all construction of the building is approximately 50% complete.

b. Control Rod Drive Development - Two types of control rod drives are to be used for these reactors: (1) an expulsion type, whereby a fuel drawer will be ejected from the core, and (2) an insertion type, which will insert a boron-filled shim rod into the core.

Initial testing of the expulsion type drive yielded very poor scram times for the first 15 cm of travel. Inspection of the test rig revealed significant galling and scratching of the contact areas between the fuel drawer and tube. The two surfaces have since been polished smooth and the fuel drawer bottom has been chrome plated. A second cause of unnecessary drag was the misalignment of the drive during installation; the entire test rig has since been realigned.

The insertion drive has been redesigned to accomodate certain restrictions made necessary by the narrow guide spaces in which the drive rod must operate. The method of mounting has been changed from flush to recess, thereby decreasing the rear overhang to 120 cm. Construction of the drive is proceeding, although it has been delayed somewhat to accommodate the above design changes.

3. Juggernaut

The Juggernaut is a water-cooled and graphite-moderated reactor of the ARGONAUT type. It is to operate at power levels up to 250 kw and provide a versatile facility for nuclear research and component development.

a. Construction - The piping work for the reactor is progressing and installation at the site should take place next month.

One hundred sixty-five fuel plates have been delivered.

The console is being wired, detailed wiring diagrams are in preparation, and the console will be moved to Building D-335.

All the transistors in the power supplies of the count-rate meter and the pulse amplifiers have been replaced by zener diodes for better voltage stability and improved reliability.

b. Development - Additional investigation of the buildup of Wigner energy has resulted in design changes in the control rods. If uncontrolled Wigner energy release should occur in the graphite reflector, temperatures above the melting point of cadmium might occur. For this reason the control material for the shim-safety rods is being changed from cadmium to 2 wt-% natural boron in steel.

Relative worth tests of boron-steel and thermally black cadmium have been carried out by rod drop techniques in the ARGONAUT thermal column, 18 cm from the face of the reactor. These tests indicated that 0.300-cm thick boron-steel (2 wt-% boron) is worth the same as 0.102-cm cadmium, and that 0.208-cm boron-steel (2 wt-% boron) is worth 7% less. Boron steel plates 0.275-cm thick will be used for control elements in the Juggernaut.

Revision of the Juggernaut Hazards Summary Report has been completed. The hazards evaluation section has been expanded in scope and detail. In addition more emphasis has been placed on the planned experimental usage of the reactor. The first draft of the operating manual has been prepared and a report of the physics analysis work has been written.

4. Fuel Fabrication Facility

a. Installation and Operational Testing - Continuous operation of the helium purification system for the hood lines has become routine. There is no new evidence that the system moisture can be reduced much below 100 ppm and a weekly regeneration of the moisture tower is necessary to hold this level. The oxygen level has been maintained below 500 ppm recently and lower values may be possible, except over week ends when a gradual increase occurs. The carbon towers will adsorb oxygen for approximately 12 hours at low temperature before reaching saturation. Hood Line PF-9 was added to the helium system during the month. Eight out of twelve helium hoods are now "on stream" representing a recirculation volume of 8,500 cu. ft.

b. Development of Methods for Melting and Casting UC-PuC - Mockup tests are continuing on the graphite resistance coil furnace in PF-14 using a welding transformer as a temporary power source. Temperatures of 1500°C have been reached and maintained for extended periods using a graphite coil of 2.875 in. ID. The 5.75 in. ID coil has produced temperatures of 2100°C, and higher temperatures are anticipated. Early results indicate that arcing may occur at temperatures in excess of 1800°C and modifications appear necessary for routine operation at this temperature level. The water-cooled copper contact plates have been installed and appear to work satisfactorily at all temperature levels investigated. Shell temperatures are not excessive.

A change in design of the graphite coil is under investigation. Fabrication has started on other internal furnace parts and permanent electrical connectors.

c. Methods of Calorimetric Assay for Plutonium Content - The purpose of this program is to investigate methods of nondestructive

calorimetric determination of total plutonium content in jacketed specimens by heat measurement.

Drawings of the necessary components to assay ZPR-III fuel plates calorimetrically have been completed and approved.

5. Irradiation Studies - Fast Reactor Fuels

a. Irradiation of Refractory Alloy Clad Uranium-Fissium Alloy - Irradiations made on uranium-20 w/o plutonium-10 w/o fissium alloy, the reference fuel for EBR-II Core-II, have shown that the fuel swells severely at temperatures 300°C below the anticipated EBR-II fuel operating temperatures. The most promising approach to the swelling problem appears to be to restrain physically the swelling of the fuel alloy by the jacket or cladding which is placed over each fuel pin. Refractory metal alloys are being actively investigated for the cladding because of their superior high temperature mechanical properties and their acceptable compatibility with the fuel alloy.

The initial irradiation studies in this program are being made with 0.144 in. diameter specimens of 20% enriched uranium-fissium alloy as a stand-in for uranium-plutonium-fissium alloy. This is being done because the first irradiations are intended primarily to measure the temperature distributions in specimens with 20 w/o fissile atom content, and assembly of the highly instrumented specimens and capsules would be delayed if glovebox operations were required.

At the present time two instrumented capsules, CP-13 and CP-14, are under irradiation in CP-5. Each capsule contains three specimens (2 in. long) of enriched uranium-5 w/o fissium alloy inserted in three-inch lengths of niobium, yttrium and vanadium tubing. The diameter and wall thickness of the tubing is identical to that used in EBR-II. The center temperatures of the three specimens are instrumented as well as temperatures adjacent to the specimen along its length. The maximum measured center temperature is 730°C. The maximum jacket temperatures are near 550°C, the jacket temperature expected in EBR-II. The rate of burnup is estimated to be 0.25% total atom burnup per month.

B. EBR-I

1. Mark III Operation

With stripped rib subassemblies (Hexes C and D) in the configuration that was in effect at the end of the stability studies last May, additional power coefficient determinations were completed under a variety of conditions (i.e. 1/2 power, high inlet temperature, series flow, full flow, 2/3 flow, 1/3 flow).

Additional rod drop experiments were made at full power, (1200 kw), full series flow, high inlet temperature.

Training of reactor operators is continuing on EBR-I. Intermittent, rather than steady operation is being used to provide the maximum individual experience.

2. Mark IV Development

Acceptable metal yield in the centrifugal casting operation has been increased from 36% to 60% in the last four melts. Further studies of yield will be made by varying charge weight and pouring temperature. Analytical results to date show no deleterious effect on composition due to remelting of the Pu-1 w/o Al alloy.

Three melts, using aluminum, were made in the PF-9 injection casting furnace prior to placing the hood line "on stream". All aspects of the casting operation performed satisfactorily.

Yttrium oxide has proved very satisfactory for coating MgO crucibles and stopper rods. Coating of graphite has been more difficult owing to the lack of adherence of Y_2O_3 . The use of $MgO \cdot ZrO_2$ as a base coating will be evaluated.

The upsetting dies have been received and tests will begin shortly on aluminum and/or lead prior to in-hood upsetting of fuel pins. Deep-hole drilling investigations are continuing.

The new welding machine, "pop welder" was completed during the month and tests are in progress. Numerous heliarc girth welds have been made on the Zircaloy-2 hardware components. An automatic control circuit is being designed and constructed for the girth welding unit. Samples incorporating both types of welds have been prepared for evaluation.

The bonding furnace pin holder basket was completed and tested during the month. Operational tests on the NaK filling chamber will begin as soon as the remaining 25% fabrication work has been completed.

Equipment and techniques for density measurements are being evaluated. A bromobenzene immersion medium has been tested for effects upon neoprene and Cr-39 plastic window material. No serious deleterious effects were noted. Evaluation of ultrasonic cleaning techniques are being initiated. Ultrasonic testing of finished fuel pins for internal defects is also being evaluated. Properties of Pu-Al alloys are reported in the section "Reactor Fuels and Materials Development."

Six experimental fuel element tubes have been fabricated. The lower fuel rod tip has been redesigned to give better welding geometry. Welding cycles, both for welding the rib wires and the end plugs, have been established. Shop tooling developed for fabricating four specimen rod assemblies is adaptable to these fuel rods and is being used, saving considerable tool cost. All the above tubes were helium leak tested with a mass spectrometer and found to be leak tight.

Initial production of fuel pins is scheduled for November 1 pending evaluation of the criticality safety procedures and release of material for Core IV fabrication.

The initial delivery of 200 feet of EBR-I Mark IV jacket tubing is now expected early in November. Methods are being developed for the fabrication of fuel jacket tubing from the 0.375 in. OD tubing stock now

on hand.

The development phases of the rod-tip girth weld and the rib-wire weld are complete.

C. EBR-II

1. Construction

The following tabulation presents the status of construction contracts as of October 21, 1960:

<u>Building</u>	<u>% Completion</u>	<u>Estimated Construction Completion Date</u>
Power Plant (Package 2)	100 *	*
Reactor Plant (Package 2)	100 *	*
Sodium Boiler Plant (Package 3)	54 **	**
Fuel Cycle Facility (Package 3)	57	May, 1961

* The Power Plant and the Reactor Plant were accepted from the construction contractor during October on an Interim Facility Transfer. Specific corrections and remaining items of work are to be completed by the construction contractor on a "punch list" basis. These consist primarily of the usual final clean-up and miscellaneous items.

** Construction delayed; revised schedule not established.

The following buildings have been completed and accepted: Lab and Service Building, Guard House, Fuel Storage and Pump House, Electrical Substation, Cooling Tower, Fire House, Pump House No. 1, Sanitary System and Warehouse.

a. Sodium Boiler Plant - The construction of the Sodium Boiler Plant is now 54% complete. Delays have been due largely to difficulties experienced by the piping subcontractor in the procurement fabrication, and installation of piping (see Progress Report, September, 1960, ANL-6234); and difficulties experienced by the Laboratory in the fabrication of the steam evaporators and the superheaters.

b. Fuel Cycle Facility - Construction of the Fuel Cycle Facility is 57% complete. The gas-tight steel liner for the argon cell has been completed and the contractor is in the process of pouring the roof of the argon cell. Work is also proceeding on the concrete block partitions, and roof of the high bay area.

c. Electrical - The contractor is pulling wires and cables in the underground duct runs to the Power Plant. Work is progressing on grounding conduits, bus duct, lighting fixtures, public address power telephones, controls, alarm systems, and incidental electrical work. The electrical work is estimated to be 31% complete.

2. Installation of Equipment - Package 4

a. Reactor Plant - Progress in the installation of equipment by the Package 4 contractor has improved during October, but was still somewhat hampered by the presence of the construction contractor up to October 21. In the Reactor Plant, Package 4 progress on the reactor and primary system was hindered by the construction contractor working on the heating and ventilating systems.

In both the Reactor Plant and the Power Plant, considerable work remains for the construction contractor in the form of small jobs such as insulation, painting, and other work of a similar nature. These jobs are covered by the punch lists referred to and while none of them are large in themselves, in aggregate they are sizable and as such are a delaying factor in the installation of the equipment.

The installation of equipment in the Lab and Service Building is complete. The installation of the machine tools in the Power Plant was essentially completed during October. In the Reactor Plant the area preparation is about complete; the primary shield plugs are well along the shield cooling throttling devices are nearing completion; the work on the well casing and shroud surrounding the heat exchanger is about complete; the large rotating plug and the small rotating plug are more than half done. Substantial progress has also been made on the primary tank cleanup, and on the auxiliary pump plugs and bus parts. A start has been made on the reactor vessel and grid supports and on mounting the control rod drives.

b. Power Plant - The 13.8 kv potential transformer units which were damaged by a power surge have been rebuilt by the manufacturer and the switchgear has been re-energized. During the rebuilding, the primary leads for the potential transformers on the line side of the 13.8-kv bus were reconnected, thus providing proper zone protection. The operational relays and the over-voltage control circuit for the 400-kw and the 100-kw diesel generators have been checked.

3. Engineering

The Architect-Engineer (H. K. Ferguson Company) has completed the construction design, the final instrumentation and control schematics, and the plant system maintenance and operating manuals. Their work was completed on October 1, and is now being transmitted to the Laboratory on an orderly schedule. Four hundred and thirty-six drawings covering the Reactor Plant, Fuel Cycle Facility, and the Lab and Service Building have been received. The balance of the tracings for the Power Plant and the Sodium Boiler Plant and Yard are scheduled for shipment before November 1.

The final review of all panel board and electrical wiring diagrams and drawings is progressing satisfactorily. Because the instrumentation and control systems are interconnected, complete systems are reviewed and checked before being issued to the installation contractor (Package 4). Sufficient drawings have been issued to date to enable the work to proceed without hindrance. This procedure will result in issuing large numbers of drawings covering complete systems in the near future.

4. Procurement

The procurement of equipment by the Laboratory is proceeding satisfactorily and delivery now involves essentially only equipment to be installed by the Package 4 contractor. The majority of these items are to be installed in the Primary System. Delivery of this equipment is proceeding in an orderly fashion with arrival well in advance of need.

5. Component Development - Reactor

a. Reactor Vessel Cover Lifting Mechanism - In EBR-II the reactor vessel is completely submerged within the large volume of bulk sodium contained in the primary tank. The vessel is mounted on the bottom structure of the tank, so that the distance from the top of the vessel to the free surface of the bulk sodium is approximately 12 ft. A removable cover is provided on the reactor vessel which forms the upper boundary of the reactor coolant outlet plenum and encloses the neutron shielding. This cover is approximately 8 ft in diameter and weighs 13 tons. It is penetrated vertically by a number of drive shafts including those for the twelve control rod drives and the gripper and holddown mechanism.

During reactor operation, the cover is clamped to the reactor vessel by means of three "cover locking" mechanisms. When fuel or blanket subassemblies are to be transferred into or out of the vessel, it is necessary first to remove the cover from the vessel to a position in which it will permit ready access to the interior of the reactor and not interfere with the motions of the various fuel transfer devices. This is accomplished by lifting the cover vertically upward until the top of the cover is a few inches below the free surface of the sodium. All the drive shafts extending through the cover slide within their respective penetrations

The vessel cover lifting mechanism suspends the cover from the small rotating plug mounted in the primary tank support structure, and raises or lowers the cover by means of two 4-inch diameter circular columns which extend through the rotating plug and engage a pair of jackscrews driven by a single motor. Consequently, the cover bears a fixed angular orientation in respect to the small rotating plug; when the plug is rotated, the cover rotates with it.

Because the cover lifting mechanism is relatively massive and would be very difficult to modify in the field, it has been thought advisable to test thoroughly this mechanism before shipping it to the construction site. The entire mechanism has been assembled at the Watertown Arsenal and initial testing accomplished. During this testing a dead load equivalent to the weight of the cover was attached to the lifting shafts. All electrical circuitry and electrical components were checked out and determined to be operating correctly. Mechanical operation was also satisfactory except that some chattering (vibration) occurred. The source of this chattering was determined to be binding on one of the two lifting screws. In the first effort to overcome this, the entire mechanism was releveled, realigned, and readjusted, but a small amount of chattering still remained. The defective lifting screw and nut are now being lapped in a second effort to overcome the trouble, after which testing will be continued. This mechanism is not scheduled for installation for some time and it does not appear that any delay

in this installation will be incurred.

b. Control Rod Drive Lifting Platform - The process of transferring subassemblies into or out of the reactor vessel requires rotation of the large and small rotating plugs. As noted above, rotation of these plugs produces rotation of the reactor vessel cover. Each of the 12 control rod drives extends through the cover, traverses the coolant outlet plenum, and affixes to the control rod handling head by means of a latching mechanism. Because of this arrangement, these drive shafts also rotate when the cover rotates. Before the vessel cover may be rotated, it is necessary not only to unlatch the control rod drive shafts from the rod handling heads, but to raise the drive shafts sufficiently to clear the tops of the rod handling heads and those of the other subassemblies (all of which are at the same elevation) during rotation. For this purpose, the 12 control rod drive mechanisms are mounted on a lifting platform which is located on the top surface of the small rotating plug.

Testing of the control rod drive lifting platform has recently been completed at the Laboratory. The complete unit was assembled, with all internal wiring, limit switches and interlocks included. Testing was conducted with a load of 11,200 lb; design load is approximately 10,200 lb. Both mechanical and electrical operation of the unit was completely satisfactory. This mechanism is now being disassembled for shipment to the construction site.

c. Reactor Vessel Cover Lock Mechanism - During reactor operation the reactor vessel cover is held clamped to the top flange of the reactor vessel by means of three equally spaced "cover locks." These locks are actuated remotely to permit unclamping of the cover (preparatory to the lifting of the cover) during the fuel transfer process. The locking mechanisms extend from the bottom of the cover up through the bulk sodium and biological shield to the top of the primary tank support structure. The drive units are electrical, with manual override, and are located at the top ends of the mechanisms.

Two of the three units have been assembled and tested at the Laboratory. Operation was accomplished both manually and electrically without difficulty. These two units are now being readied for shipment to Idaho. The test of the third unit is nearing completion and this unit should be ready for shipment in November.

d. Gripper and Holddown Mechanism - The function of the gripper and holddown mechanism is to insert and extract subassemblies from the reactor vessel. This mechanism performs its operations remotely, with vertical movement only. It incorporates several design features which lend added reliability to the fuel transfer process, such as "sensing" devices, "force-limiting" devices, and holddown of adjacent fuel subassemblies to prevent their simultaneous removal.

The mechanism is necessarily complex and requires extremely careful alignment and adjustment of many interconnected assemblies. It is essential, both for assuring proper operation and for minimizing field installation time, that the entire unit be assembled and tested prior to shipment.

The unit is being assembled on a 50 foot high structure which supports the entire mechanism and permits access to the critical parts at several different elevations. At present, all of the gripper lower components, which will be submerged in sodium during operation, have been assembled and installed on the test structure. Fabrication of all components is complete; however, a few of the holddown parts have not yet received final inspection. It is anticipated that completion of assembly and testing will be accomplished in about four weeks, well in advance of the time scheduled for installation.

e. Primary Sodium Sampler and Cavity Shield - The primary sodium sampler is employed to extract sodium remotely from the primary coolant stream for the purpose of making sodium oxide determinations and for physical removal of small specimens to enable analyses of gross impurities in the sodium. The primary sodium sampler cavity shield forms a protective housing around the sampler assembly to prevent accidental damage and provide gamma shielding for operating personnel.

For making oxide determinations, the sampler utilizes the vacuum distillation analytical technique developed at the Laboratory. A representative sodium sample is introduced remotely into a metal foil lined sample cup and the sodium is separated from its non-volatile impurities by vacuum distillation. After a sufficient distillation time, the sampler is filled with inert gas and the metal foil is withdrawn. The residue on the foil is then analyzed by standard chemical or radiological methods. The only radioactive material removed to the exterior of the cavity shield during the process is that present on the foil.

This sampler is a precision analytical device. Because of its complex nature and the many physical restrictions in its location within the Reactor Plant, both the sampler and the cavity shield are being mocked up under conditions identical (physically) to those expected in the actual installation so that any interferences and deficiencies can be detected and remedied. This mockup is also intended to establish in detail the various operation parameters (such as vacuum levels and temperature requirements) of the sampling equipment. In addition to testing, the mockup is being used to determine the best method of disassembly of the equipment for shipping and field installation purposes.

The complete sampler assembly has now been mocked up. Several interferences between the lead shield and the moving parts of the assembly were detected and have been corrected. These interferences were due primarily to imperfections in castings and to fabrication difficulties with the shroud surrounding the main shield assembly. Operation of the equipment under anticipated EBR-II conditions will start within one week. No difficulty is expected in meeting the scheduled delivery date.

f. Festoon Cable Test - The test of the festoon cable for the small rotating plug was completed after 2300 cycles. No mechanical or electrical failure occurred, and based upon these highly satisfactory results, the apparatus has been dismantled and those parts which can be utilized on the reactor will be shipped to Idaho for installation.

g. Shield Design - In order to improve the response of certain nuclear instruments, the cans which make up a section of the primary neutron shield for EBR-II are to be filled with sodium instead of graphite as previously designed. The maximum heat generation rate in the vessel steel with graphite in the shield cans was calculated to be 0.024 watts/cm^3 . The heating rate is about one-half this magnitude when sodium replaces the graphite. The circulating coolant should handle this difference without any harmful stresses being developed.

h. EBR-II Automatic Flux Control - An automatic flux control system is being designed for EBR-II which will control reactor power to $\pm 1\%$ from 10% to 100% of full power. An on-off control system will be used in order to utilize the control motors and power contactors provided for manual operation.

The improved model of the simplified control circuit and operational amplifier mentioned in the September Progress Report (ANL-6234) has been tested for a period of ten days. The results obtained were quite satisfactory. The noise has been reduced to 18 mv rms (or 30 mv peak to peak). As to the drift, in the first six days, the drift was 10 volts, and in the rest of the four days, the drift leveled off at that value with a maximum of ± 0.5 -volt variations.

The mechanical part of the unit has been designed in a separate chassis, and the final model is now under fabrication.

i. Control Rod Reactivity Generator - A sinusoidal reactivity generator and wave analyzer are being designed to measure the transfer function of EBR-II. The reactivity generator will utilize a specially designed rotary mechanism which will fit into a control rod location.

The nulling circuit of the transfer function measurement unit has been re-examined; a new circuit which can eliminate the second harmonic in the old model was developed. The theoretical computation has been proved successful and an experimental model has been fabricated for verification. Examination of the phase shift indicating system has resulted in the use of a mechanical device that will present the phase shift in digital form.

Final checking and corrections on drive components internal to the core are 95% completed. Preliminary layout of drive arrangement is approximately 50% completed.

6. Component Development - Steam Generators

Two different techniques to prepare the superheater tube ends for welding have been developed. One method involves the removal of the nickel-phosphorus bonding layer by a cyanide base solution. The other procedure is upset forging the tube ends at room temperature. The chemical method is the least preferable of the two because it is incapable of adding wall thickness to the inner tubes which are already at or below the minimum in wall thickness. For this reason only enough tubes to provide for one unit have been so prepared, and this unit is in assembly. Sufficient tubing for two more units has been upset forged and the units

which employ these tubes are being assembled.

Time consumed in the development of the end preparation methods has made it impossible to deliver the first superheater on schedule, and will probably have some effect on the delivery date of the last (fourth) superheater. It is felt that completion of the last unit cannot be predicted with reasonable accuracy until the first unit is near completion, whereupon the schedule will be revised if necessary.

7. Component Development - Fuel Reprocessing Facilities

Design and testing of equipment for the Fuel Cycle Facility is being continued. Work on the installation packet for the melt refining furnace off-gas auxiliaries has started. Detail drawings of the window shutters are being made. The design of the large air locks is being modified.

Eight operating manipulators are being manufactured by General Mills. The Pivot Tower and Power Inlet for the manipulators has been shipped to Idaho. Performance tests have been completed on the manipulator removal hoist (blister) in the mockup area. The hoist has been removed from that area and is being readied for shipment to Idaho.

An MI cable sample sealed with General Cable's Type "H" sealant has been irradiated to a dose of 7.6×10^8 rad; its insulation resistance remained at greater than 200 megohms.

Preliminary design is proceeding on many of the devices required to dismantle the fuel subassemblies in the air cell of the Fuel Cycle Facility. Layout design studies have been made of methods of removing the fuel elements from the support grid. One method employs a wedge to force the elements off one row at a time. Other design studies are being carried out on a unit for cutting the lower shank, clamps to hold the fuel elements after the hex tube is removed, and a device for holding the blanket rod assembly and for shearing the center rod retainer. A hex tube grapple has been built and tested successfully with an applied load of 2800 lbs.

The design of refabrication equipment for EBR-II is now approximately 35% complete. The design of subcell equipment supporting the injection casting process is essentially complete. This equipment includes vacuum piping, pump shrouds, bases, pressurizing and coolant circulating units. Preliminary work on the wiring diagrams for the control and sequencing of activities associated with injection casting is in the layout stage.

A testing program is under way in the gamma irradiation facility in Building 310 for the investigation of transient radiation effects at various total doses upon a quartz crystal piezoelectric transducer and a strain gauge type pressure transducer. At the present time the test devices have been exposed to a total dose exceeding 10^8 roentgen.

8. EBR-II Fuel Fabrication and Development

a. Fuel Element Production - One thousand EBR-II fuel elements were loaded and bonded during the month. In addition 850 reclaimed fuel pins from

earlier rejects were reloaded to reduce the backlog of reclaimed elements to zero. Of these elements, 1275 were accepted to bring the total up to 5675 or 60.6% of the number required.

b. Blanket Fabrication - Production of EBR-II inner and outer blanket rods was resumed on October 18, 1960. Production had been terminated on September 26, 1960 pending the resizing of stainless steel jacket tubing which had been fabricated outside specified tolerances. A new batch of tubing has now been received.

A total of 10,487 inner and outer blanket rods have been loaded, bonded, inspected and accepted. This represents 95.8% of the number required for the first reactor loading. Several thousand extra rods were included with the first order.

Completed fuel rods are loaded into fuel elements of nineteen rods each. To date twenty-two inner blanket elements have been assembled. Also twenty-seven upper and twenty-seven lower elements have been completed.

Uranium from 526 damaged or otherwise unacceptable inner and outer blanket rods has been reclaimed. An additional 183 rods, which were assembled for the purpose of bond development, have been disassembled and the uranium salvaged. The latter group of rods contained reject uranium which was not intended for reactor use. This reclaiming phase has been suspended pending completion of the bond operation.

c. Stainless Steel Hardware Fabrication - The procurement of vendor-produced stainless steel parts for EBR-II Core I is continuing. The number of orders completed is now 71%. The degree of completion of the remaining items has been lowered to an average of 25% because of the addition of new orders for boron carbide control rod parts.

16,733 of a required 21,000 fuel tube components have been produced and delivered to assembly operations. Enough tubes and tips are on hand to produce a total of approximately 22,500 rods.

Production has been resumed on inner-outer blanket tube components and 1,665 have been delivered to the canning line. This brings the number produced to 13,749 of a required 16,000.

d. Bond Inspection - Five EBR-II fuel elements were tested with the four channel pulsed eddy current equipment, radiographed and submitted to destructive testing to check the accuracy of measuring sodium level with the eddy current equipment as well as radiography.

Table II shows the average sodium levels as determined by each method.

Table II. Sodium Levels in EBR-II Fuel Pins

<u>Pin Identification Number</u>	<u>Radiography</u>	<u>Eddy Current</u>	<u>Destructive Test</u>
14A-5	0.648"	0.660"	0.660"
14A-42	0.705	0.720	0.714
14A-48	0.759	0.746	0.750
14A-49	0.721	0.745	0.740
14A-50	0.715	0.730	0.730

e. Fuel Irradiation - Two EBR-II fuel pins (samples Nos. 19 and 20) are being irradiated in CP-5. CP-5 power was raised to 4.7 Mw from the 2.0 level during the month. The temperature of sample No. 19 rose satisfactorily to 1067°F. The sample had accumulated a burnup in the vicinity of 1.75% up to that time. Calculations predict that the burnup will reach 2% early in November. At this time, the specimen will be removed for examination. Specimen No. 20 which was under irradiation in the "in element" thimble, quite inexplicably demonstrated erratic thermal behavior when the power was raised. Excessively high temperatures were reached which implied disastrous consequences to the integrity of the element. Consequently, this specimen was removed from the reactor for examination.

f. Fast Reactor Fuel Jacket Development - The desired higher operating temperatures for future fast reactors require a fuel jacket material which will be compatible with both sodium coolant and fuel, have good fabricability and weldability and high strength and low creep at elevated temperatures. Some niobium and vanadium base alloys rank high in possession of the above desirable properties. Niobium base alloys are being developed for the Laboratory by Battelle Memorial Institute, and vanadium base alloys have been developed by Armour Research Foundation for fabrication development work at the Laboratory. Commercial suppliers have been contacted to supply tubing of the above high strength alloys.

The V-10 w/o Ti-3 w/o Nb alloy tube mentioned in the August Progress Report (ANL-6215) was further cold drawn and sized to finish dimensions, (0.176 in. OD x 0.009 in. wall). The 3 in. long tube was leak checked with a mass spectrometer helium leak detector and no defects were found. This tube is currently being machined to length along with end plugs of the same composition. When completed, the material will be submitted for assembly of an irradiation test specimen.

The V-10 w/o Ti-3 w/o Ta alloy tube was also cold drawn and sized to finish dimensions. However, the tube ruptured while it was being removed from the mandrel.

An Inconel heat treating fixture to be used for annealing refractory alloys in vacuo is being constructed and is estimated to be 95% completed. Existing fixtures were not adequate since some temperatures achieved will be in excess of 1300°C.

Four niobium base alloys, in the form of bar stock to be used for extrusion and tube fabrication, were received from BMI. The bars are of the following composition (nominal): (a) Nb-2 w/o Cr; (b) Nb-3 w/o Zr; (c) Nb-5 3 w/o V; (d) Nb-2 w/o Zr-1 w/o Cr.

9. Process Development

a. Melt Refining Process Technology - The first melt refining experiment using highly irradiated (0.6 - total atom percent burnup) uranium - five percent fissium alloy has been completed. A charge of 388 g of 40-day cooled EBR-II-type fuel pins was heated under argon in a lime-stabilized zirconia crucible for three hours at 1400°C. The molten metal was top-poured into a graphite-coated copper mold. The pouring yield was 72.4 percent. This yield was considered adequate for the first run of the series and for the small size of the melt. Analyses of charge, ingot, and oxidized skull fractions in general confirm results previously obtained on melt refining synthetic, irradiated, and radio-actively spiked uranium-fissium alloys. Removals from the melt of greater than 99 percent were effected for rare earths and yttrium, barium and strontium, and iodine. Ninety-five percent of the tellurium and 9 percent of the zirconium were also removed, the latter removal being attributed to the presence of carbon in the starting material. Only 2.0 percent of the starting barium and strontium and 0.19 percent of the iodine could be accounted for in the ingot and skull fractions; the remainder presumably being volatilized and/or retained by the crucible during melt refining. Analyses for molybdenum whose behavior is assumed representative of fissium elements other than zirconium, indicate that the melt-refined metal was 3.4 percent richer in fissium elements than the charge.

A second fission gas release experiment was made using a 0.6 - total atom percent burnup uranium - five percent fissium fuel pin. The evolution of krypton-85 and changes in pin geometry were followed while heating at a rate that simulated the rate contemplated for plant-scale melt refining practice. Initial swelling occurred at about 700°C and continued until a maximum diametral increase of about 47 percent was observed at 1000°C. At 1020°C, the pin began to lose its cylindrical shape and the central portion, which was unsupported, started to sag. Longitudinal increase appeared to occur with the swelling, and it was estimated that the length had increased at least 25 percent at the time the diameter had increased 45 percent. Evolution of krypton-85 began at about 700°C and continued to about 1050°C. Since evolution of xenon and krypton occurred during the same temperature interval in the previous experiment (September Progress Report, ANL-6234) conducted at about one-half the heating rate, it appears likely that the release of noble gas during melt refining may be controlled by the heating rate between 700°C and 1050°C.

Studies on the nitridation of unirradiated uranium and uranium - five percent fissium pins, both uncoated and coated with sodium, are continuing. At about 500°C in a 96 percent argon - 4 percent nitrogen static atmosphere, nitridation occurred much more rapidly than in previous experiments at about 300°C. The presence of a sodium coating significantly increased the rate of nitrogen pickup. Measures to prevent pinshell formation during storage of irradiated, self-heating EBR-II fuel in the argon-

nitrogen processing cell atmosphere may be necessary to avoid poor melt refining yields.

b. Processing of Melt Refining Skulls - Current processes for recovering and decontaminating uranium present in melt refining skulls begin with reduction of the oxidized skulls by liquid metal solutions. Reductions with magnesium at 800°C of oxidized skulls containing uranium and cerium oxides have produced uranium and cerium metals, both with 90 percent yields, in about six hours. The oxide particle sizes used in these experiments were less than 170 mesh and greater than 325 mesh. Similar experiments with coarser oxide particles, some of which are formed in typical skull oxidations, indicate a much slower reduction rate.

In a demonstration run at 800°C with a 10 percent magnesium-zinc alloy, quantitative reduction of fissium oxide was obtained within four hours. Separation of precipitated uranium-zinc by procedures based on settling of the precipitate (pouring or pressure siphoning) has proven much more difficult than previously encountered with more dilute magnesium-zinc solutions. As compared with 5 percent magnesium solutions, the 10 percent magnesium solution may be more viscous and/or the precipitate produced in it may be more finely divided. In the 10 percent magnesium solution, the solubility of uranium in the supernatant liquid at the lowest feasible separation temperature is also higher than desirable. Therefore, a dilution of the magnesium concentration, either before or after oxide reduction, is indicated. A second demonstration run has been started in which a 5 percent magnesium-zinc solution was used for reduction.

The use of molten salt fluxes together with liquid metal reductants is being studied in connection with the skull recovery program. The flux serves a dual purpose: (1) to increase the rate of skull oxide reduction; and (2) to provide a vehicle for removal of solid magnesium oxide produced by magnesium or magnesium-containing reductants. Fluxes investigated to date include a variety of mixtures of alkali and alkaline earth halides. Complete reduction of U_3O_8 to metal has been achieved in one to two hours at about 750°C with several fluxes in contact with zinc - five percent magnesium. A rough correspondence between reduction rate and flux solubility for U_3O_8 appears to exist.

c. Engineering Development for Liquid Metal Processes - It has been found that ruthenium is virtually quantitatively removed from skull oxide by leaching with molten zinc. It is expected that other noble metals would behave in a similar fashion.

Construction of equipment for large-scale (1 kilogram of uranium) retorting of uranium concentrates is nearly completed.

A program to develop the necessary engineering equipment and techniques to handle any volatile oxides formed during the skull oxidation has been started.

d. Blanket Processing - The stability of a solution of plutonium in magnesium held at 800°C in a tantalum crucible and the stability of a solution of plutonium in a 3 percent magnesium-zinc solution held at 750°C

in a graphite crucible were studied in runs of two weeks' duration. In the run with plutonium-magnesium solution held in a tantalum crucible, an appreciable loss of plutonium from solution occurred in the first few hours of the test after which the concentration remained essentially constant for the duration of the run. Since in previous short-term runs similar plutonium solutions had been stable, a reaction with impurities in the initial stage of the present run is suggested. The impurities are as yet unidentified. The plutonium-zinc solution held in a graphite crucible was stable over the two-week duration of the experiment.

e. Materials Evaluation Studies- Corrosion tests of various materials tested in tantalum capsules in a rocking furnace at 850°C indicate that molybdenum has less resistance to attack by zinc at this temperature than tantalum, and that tantalum - 7.5 percent tungsten is superior to tantalum. The effect of impurities in tantalum on its susceptibility to attack by zinc is being investigated. Pyrolytic graphite shows promise of resisting attack by zinc at 850°C although some graphite flaked off during the test presumably because of abrasion and erosion caused by the rocking action.

Equipment is being assembled for experiments designed to evaluate the stability of uranium in various molten alloys and container material systems. Tantalum frits to replace graphite frits in sampling tubes have been successfully fabricated. It is expected that they will be obtainable from commercial suppliers.

A vacuum-tight mechanical connector adaptable to remote connection of pipe lines entering pressure vessels remained gas tight after six cycles at temperatures up to 875°C .

Exploratory studies are being made which have for their objective the development of engineering materials for the construction of components of pyrometallurgical fuel reprocessing equipment for service in direct contact with molten metal systems. The tantalum diboride-nickel system was chosen for the initial investigation. It was found that two complex borides, NiTaB_2 and Ni_5TaB_2 , were formed. A Ni_5TaB_2 - nickel eutectic was also formed. Preliminary studies indicate that iron and cobalt may form similar complex borides with tantalum diboride.

III. EVALUATIONS (040116)

A considerable effort is devoted to carrying out studies and evaluations at the request of the Commission. During the month, five evaluations were completed and two were initiated as shown below:

Completed:

- a. Evaluation of Direct Cycle Diphenyl Reactor Proposal.
- b. Evaluation of a proposal for the development of a fuel failure detector system.
- c. Review of the updated SGR 10 year program report.
- d. Review of ATR experimental facilities for use in irradiating fast reactor fuels.
- e. Review of updated fast reactor 10 year program report.

Initiated During the Month:

- a. Review of three volumes of Nuclear Power Plant Cost Evaluation Handbook.
- b. Survey of steam-cooled reactor systems for use in central station power applications.

IV. REACTOR SAFETY (040117)

A. Thermal Reactor Safety Studies

1. Fuel-Coolant Chemical Reactions

Knowledge of the nature and extent of chemical reactions with nuclear reactor core metals that may occur in pressurized water or steam is essential to safe operation of reactors. The principal laboratory procedure uses a condenser discharge to provide almost instantaneous heating and melting of metal wire in water or steam. The energy input to the wire indicates reaction temperature; the transient pressure measures reaction rate; light emission indicates time-temperature behavior; hydrogen generated gives extent of reaction; and particle size of the residue indicates the surface area exposed to reaction. A second method consists of heating the metal inductively and then subjecting it to a steam pulse to induce a metal-steam reaction.

Studies of the kinetics of metal-water reactions under reactor incident conditions are being made in the TREAT reactor.

The series of runs with 60 mil zirconium wires in the high-pressure condenser discharge apparatus is continuing. Previous results indicated that more extensive reaction occurred as the saturated vapor pressure of the water was increased. The apparatus was modified to study the effect of inert gas pressure. Preliminary results indicate that inert gas does not increase the extent of reaction.

In studies of the aluminum-water reaction by the pressure-pulse method, apparatus changes were made to avoid the problem of outgassing the platinum resistance heater. A larger metal sample was used with induction heating. Preliminary runs indicate that satisfactory reproducibility has been achieved and that there is no interference from desorbed gases.

The ninth series of six metal-water transient irradiation experiments in TREAT was made on uranium wires. In these experiments the rate of energy input was progressively changed. The wires were 93 percent enriched uranium with diameters of 34 and 64 mils. Observation of the uranium after the reactor bursts indicated that, with an average energy of 44 megawatt-seconds (216 calories per gram uranium), a reactor period of 515 milliseconds did not melt the uranium. Reactor periods of 304 milliseconds or less resulted in melting of the wires. The uranium attained temperatures of about 1500°C with extensive formation of particles. One run with a bundle of three uranium wires, to simulate a fuel element cluster, resulted in 12.9 percent reaction. Fusing together of the three wires with the production of some fine particles occurred. The data from the in-pile, uranium-water experiments in which the reactor period and burst energy were systematically varied will be used in the computer correlation work which is now in progress. A plot of the amount of uranium-water reaction versus the reactor period indicated that the extent of reaction decreases as the period increases.

An investigation into a possible thermite reaction between UO_2 or U_3O_8 and aluminum is being undertaken. Differential thermal analysis equipment for this study is under construction.

2. Kinetics of Oxidation and Ignition of Reactor Materials

Studies are being made of the oxidation and ignition kinetics of the metals uranium, zirconium, plutonium and thorium in order to provide information leading to an understanding of the reactions. This knowledge should make it possible to minimize the hazards associated with handling these nuclear reactor materials. Isothermal oxidation on microscope stage, shielded ignition, burning curves, rate of propagation of burning foil and burning temperatures are the techniques being used. In the continuing study of ignition and burning of uranium, zirconium, and plutonium more emphasis is being placed on the burning process. Burning propagation rate studies provide a useful tool to observe the effects of many variables. Addition of halogenated hydrocarbons to air in which uranium or zirconium specimens are burning has been observed to lower markedly the burning propagation velocity. This effect is being investigated.

Preliminary studies of the burning propagation velocities of uranium and zirconium in heated surroundings show that heating to 150°C has no effect on the velocity.

Previous studies of ignition of uranium cubes in oxygen have demonstrated that additions of copper increase the ignition temperature. Additional experiments at low and intermediate concentrations of this additive have further characterized this effect. It is felt that a reduced oxidation rate in the gamma phase is a contributing factor in this ignition temperature rise.

In the continuing work on uranium powder ignition, BET area determination of subsieve (-325 mesh) irregular powder gave a specific area value (9900 sq. cm/g) comparable to that estimated from ignition temperature measurements.

Preliminary results with subsieve irregular uranium monocarbide powder show ignition temperatures (145° to 175°C) comparable to those for subsieve irregular uranium metal powder.

Ignition temperatures of uranium powder calculated on the basis of Frank-Kamenetskii theory using interpolated critical heights and effective thermal conductivities show good agreement with experimental values obtained with spherical uranium powders.

The burning propagation of two atom percent aluminum-plutonium alloy foils in air is essentially unaffected by 5 and 10 percent helium, 3 percent moisture and 5 percent carbon dioxide, but is prevented by 3 percent dibromomethane or 12 percent chlorobromomethane.

B. Fast Reactor Safety Studies

1. TREAT - Experimental

In-pile meltdown experiments in the TREAT reactor are being performed in order to survey types of fast reactor fuel element failure and meltdown product distribution, as well as to determine the mechanisms operative in meltdown product movement phenomena.

a. EBR-II, Mark I - Dry Samples - Previous experiments on un-cooled EBR-II prototype fuel elements had shown that samples which reached maximum cladding temperatures in excess of approximately 1015°C suffered extensive failure. Cladding was observed to have failed relatively uniformly along lengths of 2-5 cm, with essentially all the fuel alloy expelled vigorously from the cladding under the influence of the vapor pressure of bond sodium, to form annuli of "frozen" stainless steel fuel alloy on the walls of the meltdown crucibles. As the total sample energy input approached a figure about 75% greater than that necessary to produce sample failure, it was discovered that there was a noticeable, if qualitative, trend for the fuel alloy to dissolve greater amounts of steel cladding, and to be expelled relatively uniformly along the element, rather than to travel several centimeters inside the cladding and leave through one or two isolated failure regions.

A series of six 3% enriched EBR-II, Mark I fuel samples (Series XII) were given clipped transient power bursts initiated with $k_{ex}(0) = 1.5\%$, corresponding to an initial period of about 110 milliseconds. The first four have been examined: three were given transients of about 170 Mws (approximately twice the energy input necessary to produce sample failure) and the fourth 224 Mws (approximately 160% greater than that necessary for failure). The remaining two unexamined elements were given transients of 260 Mws and 300 Mws, respectively. Observations made thus far on this series have been consistent with those on the previous high energy input samples, showing the "lateral" dissolution and expulsion of fuel and little evidence for travel of molten fuel alloy inside the cladding prior to ejection. In each case the fuel element was almost completely disintegrated with only end pieces of the cladding remaining.

Four niobium-clad, unenriched EBR-II type pins have been made for the next series of TREAT experiments (Series XIII). This series is designed to investigate the modes of failure of such pins under energy inputs greater than those previously found to cause failure. The first two pins in this series have been subjected to transient power bursts of 550 and 620 Mw-sec. but they have not yet been examined.

Preparations are also under way for the assembly of the first four stagnant sodium capsules. Four 3% enriched EBR-II elements have been prepared for insertion into these capsules.

b. Fermi I - Dry Samples - The four Fermi I samples subjected to "flattened" TREAT power transients of 2-4 sec. duration during the previous report period (see Progress Report, September, 1960, ANL-6234) were examined. These four experiments had been run to test the hypothesis that the cladding cracks were due to stresses arising from the short power duration transients employed previously. No failures were observed, although two were given energy inputs (about 38 Mws) found previously to correspond to the threshold of failure for 0.2 sec. duration power pulses, and the remaining two were given energy inputs (about 45 Mws) found previously to produce extensive failure for 0.2 sec. duration pulses. The maximum temperatures observed were between 1070°C and 1270°C . The cladding cracks of the type found on earlier samples subjected to short pulses, and which triggered failure, were absent, and thermocouples were not lost during transients when the fuel alloy expanded upon melting, as was the case previously. However, inspection of the cladding with a

magnifying glass showed some evidence for stresses in the cladding. Samples of these four elements have been taken for metallographic analysis of fuel alloy-cladding interdiffusion and mechanical damage to cladding.

It is noted that the lower heating rates in the "flat-power" tests should have resulted in peak uranium temperatures about 25°C less than with bursts having the same total energy input.

c. Oxide Fuel Meltdown Experimentation - Meltdown experiments on uranium oxide fuel samples are being planned as the first step in extension of the Fast Reactor Safety program to non-metallic fuels. Literature surveys have been completed of the manufacturing techniques involved in the production of ceramics having the nominal formula of UO_2 , the physical properties of such ceramics, effects of the various manufacturing processes on physical properties, and results of irradiation experiments on uranium oxide samples. Some preliminary calculations have been performed to assist in defining the range of experimental variables that would be explored in TREAT.

Two uranium enrichments (3% and 10%) have been tentatively selected for the TREAT oxide samples. For the 3% enrichment samples it is estimated that a TREAT energy release of about 580 Mw-sec. will be required to carry a typical 0.51 cm dia., stainless steel clad UO_2 sample under adiabatic conditions from room temperature to the melting point of the ceramic, and supply the oxide heat of fusion. For the 10% enrichment samples it is estimated that a TREAT energy release of about 185 Mw-sec. will be required to melt such a sample adiabatically. Two enrichments were selected in order to facilitate experimentation in both the temperature region below the oxide melting point, and the region around and above the melting point, as well as to permit the use of a wide range of initial reactor periods and "flattened" power bursts.

A preliminary list of goals, prepared to provide orientation of the oxide program, includes the following:

- (1) Definition of processes occurring prior to cladding failure which produce oxide movement inside the cladding.
- (2) Determination of mechanisms of cladding failure operative at temperatures below the melting point of the oxide.
- (3) Determination of failure mechanisms operative near, or at, the oxide melting point.
- (4) Investigation of failure in the temperature range above the oxide melting point.
- (5) Investigation of the influence on the first four points of sample density, sample geometry, rates of temperature rise, etc.
- (6) Investigation of the effects of sample pre-irradiation.

The presence of sodium coolant will alter the temperature distributions through the sample, as well as affect the movement of oxide upon

failure of the cladding. Hence, the experimental program will cover this aspect as well.

UO₂ has been selected as the material for initial study, rather than mixed oxides of uranium and plutonium, in order to achieve a great simplification in post-mortem studies, and to facilitate sample preparation and testing. As information is accumulated on the phenomena associated with uranium oxide fuel behavior, and the roles played by such properties as thermal conductivity, melting point, sintering temperatures, vapor pressure, etc., mixed oxide experiments may be desirable for the understanding of such systems.

2. Out-of-Pile Meltdown Studies

a. Furnace Tests - Out-of-pile furnace explorations in the range from 1000°C down to 750°C were continued. At 1000°C for a very short interval at temperature (~ 5 sec) very little damage was apparent upon the fuel. The only visible evidence was the formation of two very tiny spots of eutectic. However, when the time was raised to 25 sec at 1000°C or 95 sec above 800°C, large quantities of alloy were formed over the fuel surface and the can was penetrated by large openings.

Significantly, the penetrations observed at the lower temperatures (less than 940°C) were no larger than pinholes, despite extensive formation of alloy on the uranium contiguous to the cladding surface. This implies that attack actually begins upon the uranium and large quantities of alloy are formed before breakthrough of the cladding occurs. In one sample which was not penetrated a considerable erosion of the uranium was seen. Twenty-two of these tests have been completed and attention is now being focussed upon the 750°C temperature level.

One item of importance should be noted. This is the absence, in these tests, of warping of the fuel element by uncoiling of the helical wire. In the furnace tests the wire heats at the same rate as the fuel element, and hence does not distort the element in any way. This has an important effect upon the failure pattern since enforced contact between fuel and cladding can hasten the melting process.

b. NMI Experiments on Uranium Cladding Interactions - Nuclear Metals, Incorporated, under subcontract to the Laboratory, has been performing a series of experiments designed to explore the mechanisms and rate constants for interactions between uranium and cladding materials of interest for fast reactors. However, as of October 31, 1960, this subcontract has been cancelled. The following presents a brief resume of the results obtained to date.

Because of the difference in types of interaction and experimental techniques, these studies were divided into two parts which were under attack simultaneously:

(1) Studies were made of the interdiffusion between iron and uranium at temperatures between the threshold for formation of a liquid eutectic (725°C) and the melting point of uranium (1129°C), as a function of type of assembly, time, temperature, and pressure. Results were

carried to a maximum temperature of 850°C and a maximum pressure of about 2.6 atm for a temperature increase from 750°C to 850°C.

(2) Studies were started of the liquid-solid interaction between liquid uranium and a range of cladding metals. An experimental isothermal technique was devised which appears to be free from errors due to liquid uranium convection and irregular sample attack. Zirconium was selected to be studied first because of general interest in this couple and because other data, as well as preliminary tests by NMI, had indicated that the rate-determining step for this couple is the diffusion of zirconium through the molten uranium, and that results could be described by the equation

$$\Delta L = 2K \sqrt{D(T) t} \quad .$$

where ΔL is the recession of the uranium-zirconium interface; K is a constant depending on materials, geometry, and temperature; T ; D is the diffusion coefficient which is a function of temperature; and t is time. Tentative values of 3.6×10^{-5} cm²/sec and 5.6×10^{-5} cm²/sec were calculated for D at 1250°C and 1350°C, respectively, using NMI data for the solubility of zirconium in molten uranium.

c. NMI Development of Thermite Heaters for Out-of-Pile Model Meltdown - NMI has also been working on development of a technique for heating meltdown samples internally using the thermite-like reaction between uranium and molybdenic oxide. Work on this project is also being terminated and NMI will close out its efforts by supplying the Laboratory with six prototype tantalum-clad "thermite heaters." The heaters were designed to serve as the central section of a model EBR-II fuel element and be surrounded by a hollow cylindrical uranium pin, bonded with sodium to steel cladding. Firing tests of such heaters have been conducted at NMI. Essentially instantaneous radial ignition along the length of the thermite column has been obtained. Trouble has been encountered from emission of reaction products from holes in the tantalum tubes. Motion pictures taken of the test firings showed that these holes appeared at localized hot spots before the tubes reached maximum temperature.

3. Theoretical Studies of Meltdown

a. Diffusion-Controlled Melting - Theoretical studies of phenomena associated with meltdown are being undertaken in order to provide a framework for correlating experimental results and for predicting fuel element meltdown behavior. The diffusion-controlled dissolution of zirconium in molten uranium at constant temperature has been investigated in a paper issued as an ANL report. Based on the work in that report and the NMI experimental results on the dissolution of zirconium in molten uranium, a model has been set up and studied mathematically for the case of diffusion-controlled dissolution of zirconium fuel element cladding by molten uranium in an isothermal system the temperature of which is a function of time. Although zirconium-uranium was the couple considered, the techniques developed both for the earlier report and the more recent work are applicable

* G. Golden, "Kinetics of Dissolution of Zirconium in Molten Uranium," ANL-6167

to other pairs of metals for which diffusion in the molten member of the couple is the rate-determining mechanism.

Three types of relationships between time and temperature have been considered: (a) temperature increases linearly with time, (b) temperature increases exponentially with time, and (c) temperature increases parabolically with time. For these cases, it has been found possible to describe the recession of the zirconium-uranium interface, L , by an equation of the form

$$\Delta L = \left(2 \frac{\pi}{\pi} \right)^{1/2} \left[b + \frac{2a\tau}{3} \right]$$

Here τ is a time-like variable defined by the equation

$$d\tau = \frac{D(T)}{dT/dt} dT,$$

and a and b are constants whose values depend on the materials being studied and the functional form of dT/dt , the time rate of temperature change.

4. Thermal Measurements of U-Fs

A subcontract has been negotiated with Denver Research Institute to furnish data on specific heat, the heats of transformation and the heat of fusion of uranium-fissium alloys, including unalloyed uranium. This information will be of use in the meltdown series of tests in TREAT. Incidental benefits will result in the completion of gaps in scientific information in this area, and consequently, specifications to DRI have been for somewhat greater precision than those required for the TREAT work.

The enthalpy of 3, 5, and 8 w/o fissium-uranium alloys is being determined as part of a study of properties of the first fuel alloy for EBR-II. First calorimeter drops to determine specific heats, heats of fusion, and approximate heats of transformation have been made on specimens prepared by the Laboratory. Pure uranium is being run in this series both as a zero percent fissium specimen as well as to check discrepancies in the literature.

5. TREAT - Reactor Development

Transients without samples were run with reactivity additions of 2.6 and 2.8 percent to obtain data on reactor characteristics for transients approaching the design value of 1000 Mw-sec. The energy release for the 2.8 percent transient was 980 Mw-sec, resulting in a maximum reactor temperature of 366°C. This compares to a design value of 400°C maximum fuel temperature for an energy release of 1000 Mw-sec. Based on these data, it is estimated that an energy release of 1100 Mw-sec could be obtained without exceeding the design maximum hot spot temperature of 400°C assuming a starting temperature of 30°C.

An attempt has been made to measure the gamma flux in the reactor core by means of both ionization gamma chamber and liquid dosimeters.

A multiple-plate ionization chamber was calibrated in terms of ampere-hours per roentgen in the Gamma Facility of MTR. Dosimeters of Fe and Ce type were also calibrated there. From the ionization chamber the gamma flux at the core center was determined as 1.4×10^3 r/Mw-sec of reactor integrated power. However, the liquid dosimeters gave values two and four times larger for the Fe and Ce types, respectively, neither agreeing with each other or with the gamma chamber.

Subsequent tests indicate that none of the detectors is significantly sensitive to the dose rate or neutron flux. Further work will be undertaken to reconcile these differences.

The first two samples of a six-sample test series on GE-ANPD fuel elements were tested and the samples returned to ANPD for examination.

V. NUCLEAR TECHNOLOGY AND GENERAL SUPPORT

A. Applied Nuclear and Reactor Physics

1. Experimental

a. Fission Physics

(1) The Determination of $\bar{\nu}$ for U^{238} and Th^{232} Relative to $\bar{\nu}_{U^{235}}$ (Thermal) - This work was initiated as a result of the direct need for better values of relative neutron yields in fission for reactor design. Previous measurements by this group resulted in a value $\bar{\nu}$ (Th^{232}) in agreement with French studies but not in agreement with recent work in the USSR. It is hoped that new experiments will resolve this discrepancy. In addition to the studies of $\bar{\nu}$ (U^{238} and Th^{232}) the equipment can be applied to measurement of $d\bar{\nu}/dE$ (U^{235}).

The method employed determines the number of prompt fission neutrons emitted by slowing them down in a homogeneous material and then capturing them in a BF_3 counter matrix. The large array of BF_3 counters and the requisite collimators are under construction. The fissile source is contained within a rather complex fission counter. The necessary electronic instrumentation is in operation.

(2) Fast Neutron Fission Cross Sections - The measurement of fast neutron fission cross sections requires a precise knowledge of the incident neutron flux and amount of fissionable material under study. In our work the former requirement is usually met with a standard U^{235} fission counter. A typical result is given in Figure 1 where the relative ratio of the Am^{243} fission cross section to the fission cross section of U^{235} is plotted as a function of incident neutron energy. The problem of determining accurately the mass of the unknown fissile sample can be very difficult. In the cases of Am^{243} and Pu^{241} the highly active sample was deposited on thin foils. The initially deposited mass is not known and the foils cannot be destroyed. The only suitable method of fissile assay appears to be precision alpha counting. For this purpose a low geometry alpha counter utilizing a solid state detector was constructed. This unit is capable of determining precisely the amounts of Am^{243} and Pu^{241} on the foils in question. Such measurements have been made and are now being analyzed.

b. Fast Neutron Cross Sections

(1) Scattering - A careful measurement was made of the angular distribution of neutrons elastically scattered from natural tungsten. In addition, the angular distribution of neutrons inelastically scattered to the first level at 120 kev was determined. The incident neutron energies were 550, 750, 1000, and 1300 kev. Multiple scattering corrections are now being applied to the measured distributions. These measurements are of particular interest because of the possible application of tungsten in small, very high temperature nuclear power sources.

(2) Capture - Work preliminary to a precise measurement of the activation cross section of iodine was performed. The fast activation

Fig. 1

cross section of iodine is similar to that of gold in that it is a standard for other measurements and a convenient activation detector in its own right. Like gold, there are large discrepancies between the various measured iodine capture cross sections. Work on a careful measurement of this cross section is now in progress.

c. Instrumentation

(1) Transistorized Time Analyzer - The development of a transistorized time analyzer possessing a 0.1 microsecond channel width is progressing well. The logical design has been completed and the individual circuit blocks are under test. The final unit will be used in the macroscopic pulsed neutron work. The time resolution is approximately an order of magnitude shorter than that obtainable with the vacuum tube unit now in use.

(2) New Van de Graaff Accelerating Tube - The performance of the new accelerating tube installed about two months ago continues to be excellent and the machine stability is very good. During the month analyzed proton beams of 140-200 microamps were obtained at the target. Currents of this size are indeed excellent.

d. General Reactor Physics Experiments

(1) Thermal Reactor Spectra - Following significant preliminary effort on detectors, renovation of the mechanical chopper, performance testing of the time-of-flight equipment, and modification of the ZPR-IV', a first attempt to measure a thermal neutron spectrum has been made. The beam hole of ZPR-IV' was filled with graphite to produce a well-thermalized spectrum incident upon the chopper collimator. The detector consisted of four BF₃ counters, 2.54 cm in diameter, with axes perpendicular to the neutron beam. Measurements were made with various combinations of a beam shutter opened and closed and the chopper rotating and stationary. Approximately 2000 neutrons were detected for each combination and it was apparent that a small number of beam neutrons was present in spite of the very high background. However, no evidence of spectral structure could be seen above the statistical scattering of the points. The number of neutrons detected per chopper burst ranged from about 1/30 to 1/7, depending on channel width and ZPR-IV' power level. These tests showed that the signal-to-noise ratio has now been reduced by approximately a factor of 100, but still is of the order of 0.01. Thus, it is evident that additional effort is required to locate a more sensitive detector and to reduce further the recording of background neutrons from the poorly shielded source reactor.

The evaluation of various neutron detectors for possible use with the chopper continued but at an accelerated pace this month. Several B¹⁰ and Li⁶ containing scintillating materials (mostly glass samples) were tested for potential use in the experiments under conditions judged similar to those which would exist in actual operation. Test conditions include both high gamma background and high fast neutron background. The most promising appears to be a combination of Li⁶F and ZnS (Ag) in lucite. Apparatus and materials were assembled to manufacture several test crystals made of these materials.

One step made previously to reduce the neutron background level

was the lining of the last 150 cm of flight path with natural uranium bricks. Tests showed this to decrease the background during time-of-flight measurements by almost a factor of two. Another factor of 100 is desirable, however. Additional shielding of the reactor, the flight path and the detector will be needed. To this end, approximately 75 shielding blocks have been added as shielding. The D_2O thermal column was removed from the leakage face of the reactor and was replaced by 4 in. of wood plus 4 in. of lead plus 18 in. of concrete.

Although meaningful results will be obtained only when the chopper and associated equipment is moved to the well-shielded Juggernaut reactor, these preliminary measurements will serve to demonstrate the minimum signal-to-noise ratio which can be achieved on that system. This will provide a basis for a decision on whether the expense involved in fabricating a tank to contain D_2O for use at Juggernaut is warranted.

(2) Measurement of ν - One of the crucial steps in the absolute determination of $\bar{\nu}$ for thermal fission, as described in previous reports, is the coincidence calibration of fission chamber efficiency, with the aid of a fast neutron detector having a high degree of gamma rejection. Even Hornyak buttons, which have the best intrinsic gamma rejection of all fast neutron detectors, are inadequate for this particular effort. Investigation of the phototube-detector system has revealed some means of improving gamma discrimination with attendant improvement in Hornyak button efficiency. This scheme, based on the differences in apparent decay times due to the various types of interactions, requires pulses of the shortest possible rise time and several volts amplitude. Thus, photomultiplier tubes and associated circuitry are very important. In this connection, seven different phototube types (RCS-6342-A, 6655A, 5819, 6903, 6810A, CBS CL-1002, and LEAP 56AVP) were tested by photographing the tube response to fast-rising Cherenkov pulses. In addition, the decay of various scintillators was observed.

About four weeks in December have been reserved at the CP-5 thermal column for some preliminary measurements. To obtain maximum benefit, it will be necessary for the manganese bath sphere and associated equipment to be ready by then. The objective for this run will be to obtain a $\pm 10\%$ value for ν of U^{235} . This error will be reduced as the fast circuitry and beta-gamma coincidence equipment become available.

Some work was done on a Cherenkov counter using Mn^{56} betas. It was decided, as a result, to purchase special low-noise quartz phototubes. The tubes ordered have 13 stages and have a room temperature dark current of no more than 200 electrons/sec at zero bias, in contrast to unselected tubes with a normal emission rate of 20,000 electrons/sec.

(3) Resonance Integral Measurements - A program of resonance integral determinations for fission products is being planned which will employ the Argonne Thermal Source Reactor (ZPR-IV'). The central sample position, pneumatic insertion device and auto-rod system developed during the past year to make ZPR-IV' useful for the precise determination of reactivity effects will be utilized.

Resonance absorption may increase the poisoning effect of fission products in thermal reactors by as much as a factor of two under certain conditions. Such effects are very significant particularly for reactors

designed to have a long core life and those in which there is appreciable hardening of the thermal spectrum as a consequence of under-moderation. Many of the resonance integrals for the potentially influential fission products have not been measured, although estimates have been made from resonance parameters. The calculated and the few measured values vary by as much as a factor of two.

In preparation for these proposed measurements, the void space in the reactor which had been used as the auto-rod detector location was loaded with fuel to produce a completely symmetric core. This was done to provide better geometry for the reactivity coefficient measurements. The loading change was followed by the usual control rod and fuel element worth measurements. For a preliminary experiment, the reactivity effect of samples of several stainless steels which might be used as the cladding material for the BORAX V boiling region fuel elements was determined.

e. High Conversion Critical Experiment - Core modifications required for the replacement of the AHFR critical by the Hi-C system in ZPR-VII are under way. The 3 wt-% enriched UO_2 fuel is all on hand and all of the required hardware, except the finger-type control rods, is available for installation. The source container, extension shaft, guide tube, core grid and lucite reflector are being revised to permit use of a plutonium-beryllium (long-lived) source rather than the previously used polonium-beryllium sources which require frequent replacement because of the much greater decay rate. The modification is necessary to accommodate the larger dimensions of the plutonium-beryllium source.

The hazards summary report for ZPR-VII (ANL-5715) is being revised to include experimentation with BORAX V oxide fuel and superheater elements, which will extend the scope of the critical experiments. The cores appear relatively safe because of their low moderator content and large resonance absorption, both of which contribute to their sizable negative temperature coefficients. The temperature coefficient of H_2O moderator increases with temperature until boiling takes place, thus increasing the moderator-density contribution to the temperature-reactivity coefficient throughout the range of critical experimentation.

2. Theoretical

a. Mathematical Numerical Methods Analyses - A supplement to the basic floating point interpretive subroutine for the LGP-30 computer has been prepared to allow manipulation of the integers used in the index registers as floating point numbers without leaving the interpretive mode. This also simplifies truncation and rounding of floating point numbers for programming purposes which do not involve the index registers. The modification will be submitted to the LGP-30 Users Group.

An Algol algorithm was coded for computing the exponential integral of a complex argument. The resulting program was tested against available tables, and was found to give results to the full accuracy of the tables. A certification describing this check has been submitted to Communications of the Association for Computing Machinery.

An inconsistency has been discovered in one section of the new artificial language Algol-60. A modification of the language to overcome

this difficulty has been devised, and submitted for consideration by the committee charged with maintaining the language.

b. Reactor Physics Constants Center - The effort to publish a revised edition of the report of the Center, Reactor Physics Constants (ANL-5800), has been initiated. This means that in this and several months to follow the reactor physics staff will be called upon to devote a large fraction of its time to this project at the expense of other physics programs.

B. Reactor Fuels and Materials Development

1. Ceramic Fuels

a. Refractories for Reactor Use - The preparation of sinterable $\text{La}_2\text{O}_3\text{-UO}_2$ powders for fabrication of high density bodies was continued. X-ray patterns were taken for twelve $\text{La}_2\text{O}_3\text{-UO}_2$ compositions which were calcined in air for two hours at 1650°C . Particle reduction of these compositions to obtain sinterable powders is in progress.

b. Fabrication Studies of UC-PuC - The use of UC-PuC as a reactor fuel requires the development of a procedure for producing UC which is economical and capable of being scaled-up for large production rates. Direct reaction of UO_2 and C satisfies these conditions best of the production techniques presently in use. This part of the work has as its objective the production of good quality UC by the direct reaction of UO_2 and C.

Two different lots of UO_2 were each mixed with two different carbons. These batches were compressed into 3/8 in. cylindrical pellets. The pellets were reacted at 1650°C both in argon and vacuum. In each case X-ray diffraction examination revealed the presence of UC_2 , UC, and UO_2 . Petrographic examination of the mixed powder showed the carbon to be present as agglomerates or chunks which were large with respect to the size of the UO_2 particles. Examination of the reacted pellets by metallography showed the pellets to be made up of a carbide matrix with islands of unreacted UO_2 and carbon.

The results of these firings indicate that the kinetics of the reaction between UO_2 and C require large surface contact area between the reactants if complete reaction is to be achieved at moderate temperatures in a reasonably short time. The problem in achieving the contact is to obtain small particle size, high surface area carbon and UO_2 which breaks down easily to discrete particles during mixing. This perhaps can be facilitated somewhat by the use of an electrolyte.

When large surface contact between the reactants is achieved, it will be necessary to effect a fast heat up and short reaction time. This will require modification of present equipment. This work is now in progress.

In September an average density of 11.5 gm/cc was reported for a solid solution of 80 w/o UC-20 w/o PuC. In a continuation of this phase a group of pellets was fired to 1750°C in vacuum. The average geometric density of these pieces was 11.9 gm/cc which is 86.9% of theoretical.

In the preparation of good purity UC by reaction of UO_2 and carbon

it is necessary to introduce a slight excess of carbon. This same procedure was followed in the preparation of PuC. Chemical analysis indicates a carbon content of 5.8 w/o (theoretical 4.78) and X-ray examination indicates an approximately equal mixture of PuC and Pu₂C₃. Preparation of a series of mixtures has been started in an effort to obtain a more nearly stoichiometric PuC.

c. Uranium-Thorium Sulfide - Investigation of the suitability of the sulfides as fuel and fertile materials continues.

The US sintering study has been extended to firing in atmospheres. The US No. 15 low temperature mixture was homogenized (1) to 1800°C for 1 hour in argon, and (2) to 1800°C for 1 hour in vacuum. The products were almost identical in physical appearance, weight loss (0.7% vs 0.2%) and lattice parameter (5.4874 vs 5.4878 Å). It is planned to fire pellets from each homogenization to 1800°C for 1 hour in H₂, argon and vacuum. The H₂ firing has been run, resulting in the migration of the material in the center of the pellets to the surface, forming a hollow shell. This was not anticipated since a preliminary firing to 750°C in H₂ had produced only a slight surface reaction on raw and sintered pellets.

A 3 to 4 v/o solution of H₂SO₄ in water is the best etchant found thus far for US polished sections. Immersion for 8 minutes in a 3% (or 3 minutes in a 4%) solution produces a rapid gaseous reaction which must be stopped within a few seconds for best results. Measurements on polished sections showed that the average grain size of US No. 14 increased from 45 to 80 microns when the firing temperature was raised from 1800°C to 2000°C. It was also observed that a small amount of secondary phase, insoluble in dilute acid, exists mainly as occlusions at 1700°C, migrates to the grain boundaries at 1800°C, and by 2000°C is found mainly on the crystal planes in a Widmanstätten type structure.

2. Properties of Metals and Alloys

a. Properties of U-Fs Alloys - A first drop of the uranium-5 w/o fissium alloy has been made in the prototype isothermal calorimeter under development in Building 212 (Fuels Technology Center) and the data are being analyzed. The gloveboxed calorimeter which will be used to determine the enthalpy of plutonium-containing fuel materials will be developed from this prototype calorimeter.

b. Phase Study of U-Pu-Fs Alloys - Attempts to optimize the properties of U-Pu-Fs alloys by control of fabrication methods, by alterations in composition, and by thermal treatments have been difficult to interpret because of the complex structure of these materials. As part of a program to improve the understanding of these alloys, metallographic and X-ray studies of the phases in U-20 w/o Pu-Fs alloys (0 to 15 w/o Fs) have been made on specimens homogenized at 625°C, 700°C and 775°C. The data are now being evaluated.

c. Properties of Pu-1 w/o Al Alloy - An engineering evaluation is being made of some of the physical and mechanical properties of the Pu-1 w/o Al alloy, because of the current interest in this alloy system as a possible fuel for the Mark IV loading of EBR-I and for service in a ZPR-type assembly.

Density values for as-cast pins measuring 0.25 in. diameter by 1.5 in. long ranged from 16.09 g/cc for the 0.23 w/o Al alloy to 15.13 g/cc for the 1.16 w/o alloy. The Rockwell B hardness values for the same alloy compositions fell within the range 88 to 96.

A tentative linear expansion coefficient of 10.5 microinch/in-°C has been observed for the Pu-0.68 w/o Al alloy for the temperature range 100°C to 350°C. A break in the dilation curve occurring above 350°C indicates a transformation which is probably related to the metastable as-cast structure. Metallographic inspection tends to verify this.

Four hot deformation tests were run on the Pu-1 w/o Al reference alloy under a series of static loads simulating reactor operations. Temperatures of initial slumping and slumping rates at various temperatures up to 600°C are being investigated. In general, the as-cast slug begins to slump at a lower temperature on the initial run than it does on a rerun. Likewise, the slumping rate is rapid during the first 2 to 3 hours and tapers off appreciably during the next 20 hours.

d. Properties of PuC - The purpose and scope of this study of the properties of PuC as a potential high temperature plutonium-containing fast reactor fuel were given in detail in the August, 1960 Progress Report (ANL-6215).

Metallographic studies on arc cast plutonium-carbon alloys containing 45 a/o C, 47.5 a/o C, and 50 a/o C have been completed. Several specimens of the above composition have shown a phase transformation on quenching from 700°C which seems to be inconsistent with the accepted phase diagram of the plutonium-carbon system. Work is in progress on the evaluation of this transformation by thermal expansion, metallography and X-ray diffraction.

e. Development of Niobium Base Alloys - Niobium base alloys are the first alternate materials to stainless steel for fast reactor fuel cladding. The maximum interface temperature for EBR-II, Core I is calculated to be about 580°C (see "Hazard Summary Report, EBR-II," ANL-5719, p. 81) including factors of uncertainty. This is well below the U-Fe eutectic temperature of 725°C of potential meltdown, especially when the deterrent action of the sodium bond is present. However, the use of Pu in the second core, (and succeeding cores) of EBR-II, the need for high strength claddings to limit fuel swelling, and the eventual desirability of lifting temperature limitations for future designs makes stainless steel unsuitable for this application in spite of its low cost.

Accordingly, alloys of niobium with chromium, zirconium or vanadium are of interest in the order named. Under subcontract to the Laboratory, Battelle Memorial Institute has been engaged in making these alloys and measuring certain properties.

To date, elevated temperature tensile tests have shown the following comparisons for fully annealed specimens:

Table III. Ultimate Tensile Strength

<u>Alloy</u>	<u>650°C</u>	<u>800°C</u>	<u>1000°C</u>
Nb-2.37 Cr	64,800	65,400	46,500
Nb-3.34 Zr	46,200	45,300	45,400
Nb-5.21 V	68,200	66,500	47,700
304 SS	42,000	23,000	8,000

Yield and creep strengths follow a similar pattern.

The current status of the work on this subcontract is one of finishing the property measurements and making thin-walled tubing of these materials to prove out in the TREAT reactor. As hot strength is a required characteristic of these alloys, fabrication of tubing is expected to be attended by problems. Extrusion would be more difficult than rolling, but the latter process would need to be supplemented by seam welding or pressure bonding in order to make tubes.

f. Liquid-phase Sintering Techniques for Molybdenum Alloys - Molybdenum is among the alternate materials for use as a fuel element cladding material for EBR-II cores later than No. I. This element presents a good combination of strength and thermal conductivity in the unalloyed state, but is difficult and expensive to fabricate.

Under subcontract to the Laboratory, the Armour Research Foundation has been studying the application of the liquid-phase sintering process to molybdenum alloys. The essential result has been greatly increased ductility and improved weldability. The structure of the material consists of a dispersion of single crystal molybdenum in a very thin matrix of another alloy. Ductility is promoted because dislocations will not pile up at grain boundaries in the dispersed phase, but are transferred to the thin matrix which is readily deformed.

Several different matrix materials have been tried for this purpose, among which are such combinations as W-Ni-Fe, Pt-Ni-Cu, Cu-Pd and Ni-Cr-Fe. Most resulted in a desirable amount of ductility. However, when the additional conditions of high temperature strength and compatibility with plutonium are applied, all the desirable properties have not as yet been found in the same material.

3. Corrosion Studies

a. Corrosion Resistant Aluminum Alloys - As part of a program to increase the mechanical properties of corrosion resistant aluminum alloys, a series of alloys has been prepared. Tensile tests have been performed at 315°C. Corrosion tests are now in progress.

Table IV. Tensile Strengths of Various Aluminum (A288) Alloys

<u>Alloy Number</u>	<u>Additive, w/o</u>	<u>Ultimate Tensile Strength at 315°C</u>
334	0.1 Cu, 0.1 Cr, 0.1 Nb, 0.1 V, 0.1 Zr	8100 psi
335	0.1 Cu, 0.1 Cr, 0.1 Nb, 0.1 V, 0.1 Mo, 0.1 Zr, 0.1 Y	7400
336	0.5 Cu	4210
337	0.5 Zr	6900
338	0.5 Cr	7800
339	0.5 V	7200
Standard: X8001 Alloy		3300

The new ternary alloys containing titanium and iron continue to show promise. The alloy containing 1.5 w/o Ti plus 0.5 w/o Fe has shown good corrosion resistance to date after 40 days exposure to static distilled water at 360°C. Corrosion tests have indicated that in alloys containing 1 w/o Zr, the minimum acceptable iron content is about 1 w/o. Additional iron seems to be beneficial in regard to retention of corrosion resistance after hot and cold rolling.

4. Irradiation Studies

a. Development of Controlled High Temperature Irradiation Capsules - Reactor fuel development programs usually require irradiation experiments to determine the actual in-reactor performance of promising fuel materials. For initial irradiation experiments, in which large numbers of fuel compositions, heat treatments, methods of fabrication, etc., are to be evaluated, the use of capsules has been found to be an economical and effective approach. A typical capsule may be somewhat over an inch in diameter, from three to twenty-four inches long, and contain several fuel specimens immersed in NaK or sodium. The capsule is placed directly in the process coolant of a test reactor so that heat fluxes can be accommodated which are comparable to those of the test reactor fuel elements. Capsules of this type were originally developed at the Laboratory several years ago. Many hundreds of such capsules have since been used by numerous sites engaged in fuel development programs.

In recent years the phenomenon of high temperature swelling in irradiated metallic fuels has become a problem of major technical importance. In order to determine adequately the critical swelling temperature for each metallic fuel, irradiation experiments must be performed in which the temperatures of fuel specimens are accurately known during irradiation. Thus, most groups engaged in high temperature fuel development have modified the simple capsule described above so that thermocouples are located in or adjacent to the fuel specimens. In addition, a means of temperature

control is usually employed.

A continuing effort has been devoted to the development of instrumented capsules for use in the Laboratory's CP-5 reactor. Six of the fuel thimbles in the reactor were modified to bypass heavy water into the thimbles so that adequate cooling would be available for experimental fuel irradiations. The instrumented capsules which have been developed for these thimbles are 1.5 in. in diameter and approximately one foot long. Each capsule contains up to six fuel specimens with a thermocouple adjacent to, or inserted in the center of, each specimen. Temperature control is provided by up to 2000 watts of auxiliary electrical heat in each capsule. The capsules are constructed with a double wall of Zircaloy-2. They are attached to special shield plugs in such manner that the capsules can be withdrawn from the reactor and replaced with new experiments within a period of a few minutes.

At the present time five instrumented capsules are in the CP-5 reactor. All are operating successfully. The capsules have been in the reactor for periods ranging up to eight months. Measured central fuel temperatures range up to 770°C . Temperature control during reactor operation is within 2°C of the desired temperature.

5. Nondestructive Testing Techniques

a. Ultrasonic Techniques - A series of tests are being run to determine the feasibility of testing welds in thin (20-100 mils) plates by the use of Lamb waves. Initially, the effect of the weld on the propagation of the Lamb wave was investigated. The Lamb wave modes were studied for changes in velocity, amplitude, attenuation, and pulse shape when the mode was travelling through the weld. The measurements were then compared with those made over an unwelded portion of the plate. With some modes there was a considerable decrease in amplitude over the weld; however, these changes were neither consistent nor reproducible. These factors will be further studied over a portion of the plate in which there are built-in defects.

The work on measuring the ultrasonic velocity and attenuation of engineering materials at high temperatures is continuing. While attempting to analyze the echo signals received from cylindrical specimens it was discovered that some of the apparent echoes were distortions introduced in the electrical leads and circuits.

Work is continuing on quantitative measurements to compare various couplants. Experiments are now being carried out to compare Nonaq and Eastman 910 adhesive.

b. Neutron Techniques - The photographic detection of neutron images is presently being investigated, with at least one long range objective being to apply neutron radiography as a useful inspection method for nondestructive testing. Because neutrons have little influence on normal photographic emulsions, it is necessary to use intermediate materials next to the film. These materials emit photographically detectable radiation when bombarded with neutrons.

Neutron radiography is potentially useful because the relative neutron absorption by various materials is different from that of gamma radiation. Since gamma radiation is almost always associated with the neutron beam, it is desirable to employ a detection system having a low response to gamma radiation, in order that the desired neutron image not be masked by the gamma image.

One method of completely eliminating the effects of gamma radiation is to use a radioactive foil transfer imaging technique. In this method the film itself is not exposed to the neutron-gamma radiation field. Only a foil of material which becomes radioactive is exposed to this radiation. The radioactive, image-carrying foil is then transferred to a sheet of film to produce a visible neutron image.

Several materials have been investigated for use with this imaging method. In the neutron flux used for these tests ($10^5 \text{ n/cm}^2\text{-sec}$), rhodium and silver do not appear to be useful for this technique. The large portion of the activity associated with these materials which is contributed by very short activity isotopes (< 1 minute) means that a large part of the photographic effect produced by these materials occurs during the neutron exposure and very shortly thereafter. Transfer techniques with these materials are therefore very inefficient and are generally not useful at all except in a substantially higher neutron flux. Indium and gold do appear to be useful in this neutron flux but require exposures in the order of hours.

6. Liquid Metal Slurries

The loop studies of $\text{UO}_2\text{-NaK}$ slurries described in the September Progress Report (p. 55, ANL-6234) are being continued on a limited basis. Three kilograms of 6-8 micron UO_2 , prepared at Los Alamos, were received and will be used to study high-density slurry behavior. The loop to be used will be erected and operated in Building 206, but irradiation studies are being postponed.

The engineering studies loop at MSA was operated to determine pressure drops and pump performance at slurry concentrations higher than the 2.5 to 5 vol % of previous runs. It now appears that the maximum concentration that can reasonably be handled with confidence in a large system cannot exceed 8 vol %. At or above this concentration the slurry tends to form plugs in horizontal or low velocity sections. Increasing temperature has some beneficial effect but is still not sufficient to offset the plugging problem. The studies now have been concluded on 2.5, 5, and 7% slurries in the temperature range 148°C to 426°C . No further research can be planned at the present time.

C. Reactor Components Development

1. Development of Shielded Facilities

An experimental model of a small disposable isolation room for personnel and equipment entry into a contaminated cave has been constructed out of plastic. This room is held in position by a metal framework on the outside of the enclosure. The room can be attached to a cave door opening by a zipper or a by a gasket arrangement. Plastic doors on either

side of the room are attached with zippers. Several rooms can be connected together in a row to effect several steps of decontamination.

Plastic suits have been used on occasion to protect operating personnel when entering a contaminated cave. However, these suits pose the problem of decontaminating the outside surface sufficiently well that the wearer can remove it conveniently. This problem has been partially solved by attaching the suit to the end of a long tunnel attached to the wall of such a plastic room as described above. This gives, in effect, a "man-shaped" glove. While this represents an improvement over the free suit, problems arise in entering the suit and contracting the tunnel when the wearer is ready to exit. An experimental model of such a suit has been built. An improvement over earlier models has been achieved by devising a "tunnel retractor" and an arrangement of the suit and tunnel which provides easy entrance and exit from the suit.

2. Development of Viewing Systems

a. Basic Glass Studies - An investigation has been continuing on the mechanisms of energy storage in gamma irradiated glasses. This is part of the program to develop improved shielding and optical glasses suitable for use in high level research and process facilities for long periods of time. An irradiation-induced charge displacement has been observed when an irradiated glass sample is subsequently heated at a constant rate and with a large thermal gradient across the sample. The charge displacement occurs without any externally applied electric potential. In the initial studies with a Cabal type glass the rate of charge displacement reaches a maximum at around 280°C . The total charge displaced is directly proportional to the thermal gradient across the 0.125 in. thick sample in the range tested of 500°C to 1000°C/in. Reversing the direction of irradiation of the sample does not alter the polarity of the charge displacement. This is an effect which would be expected if the phenomenon were due to a space charge buildup from Compton electron recoil.

The induced charge displacement has been observed to increase by a factor of about eight after an exposure of 8×10^5 r when 0.1 weight percent of CeO_2 was added to a Cabal glass. This is of interest because of the importance of understanding the role of cerium in suppressing the radiation induced coloration in the visible light region.

3. Instrumentation and Control

a. Analog-to-Digital Techniques for Auto and Cross-Correlation of Reactor Dynamics Data - Cross-correlation techniques can be utilized to improve experimental measurements of reactor transfer functions and stability predictions with poor signal-to-noise conditions.

Special equipment has been ordered which converts analog information into digital form and stores the data on magnetic tape in IBM-704 computer format. The sample and hold circuit was tested and found to be very non-linear. After repair by the manufacturer the repaired unit was reinstalled. An attempt to test the unit uncovered a wiring error in the original system design. The error was corrected and test data were recorded with six simultaneous inputs fed directly into Beckman amplifiers.

The IBM-704 computer program for sinusoidal cross-correlation has been completed. A test tape was prepared with a sinusoidal signal, attenuated and phase shifted signal, noise signal, and combined noise-attenuated-phase shifted signal. An analog computer with a noise source was used to simulate these various signals.

4. Heat Engineering Studies

a. Boiling Liquid Metal Studies - A small scale test loop is being designed for studies of boiling liquid metals. Initial tests will be with sodium and will be aimed at measuring vapor volume fractions and two-phase frictional losses in a flowing system.

The construction of the framework for the flowing system has commenced, and miscellaneous loop parts are also being fabricated. The measurement of vapor volume fractions by using an electromagnetic flow-meter to measure the local liquid velocity is being investigated. This method would have the advantage of extreme simplicity and fast response time, and would enable study of the transient behavior of the system.

Since liquid velocity does not affect the heat transfer rate in boiling, it is not necessary to have a flowing system to measure boiling heat transfer, and therefore some experiments can be conducted in pool boiling. Two simple tests are planned which will measure heat transfer from a horizontal cylinder and from a flat plate. The experiments have been designed and are being constructed, and the initial testing of the apparatus should start in December.

D. Separations Development

1. Fluidization and Fluoride Volatility Separations Processes

Volatility separations are being considered for reprocessing power reactor fuels. Emphasis is now on the development of the Direct Fluorination Volatility Process applicable to the processing of oxide fuels. The fuel for the Dresden reactor (UO_2 clad in zirconium) is a typical example.

Studies are being made on a 50 to 100 gram scale of the fluorination, transportation, separation and decomposition of plutonium hexafluoride.

The direct fluorination of high-density, sintered UO_2 pellets in an inert bed of fluidized solids is being investigated to study problems of heat removal, reaction rate, fluorine utilization efficiency, and general behavior of the system. Methods of decladding of Zircaloy-clad fuel are being investigated. Two of the approaches being used are direct hydrofluorination and combinations of hydrofluorination-hydrochlorination reactions. Fluidized beds of inert solids are being used as heat-transfer media.

Processes for recovering uranium from other enriched uranium fuel alloys using similar techniques and direct fluorination are also being studied. These include reaction of HCl-HF and $\text{Cl}_2\text{-HF}$ mixtures with zirconium fuels. Reactions of stainless steel with various gaseous reagents are being studied in fluidized beds with application to decladding of stainless steel-clad and processing of stainless steel-matrix fuels.

The fluid-bed conversion of uranium hexafluoride into uranium dioxide is being studied. The process involves either a single-step pyrohydrolysis and reduction using steam and hydrogen simultaneously, or a two-step process using alternatively steam or hydrogen, followed by the other reactant.

a. Direct Fluorination of Uranium Dioxide Fuel - Heat transfer tests on uranium dioxide pellet fuels were continued in a mockup system simulating that encountered in uranium dioxide fluorinations, that is, with fluidized medium in the voids of a heated, non-fluidized pellet bed. For a range of heights of the fluid bed both above and below that of the pellet bed, the mean coefficient of heat transfer from the pellet surfaces to the fluidized medium was found to vary continuously with superficial gas velocity from 20 Btu/(hr)(sq ft)(°F) at the onset of fluidization to about 80 on the fluidization plateau. Without the fluidized medium the heat transfer coefficient was about 10.

b. HCl-HF and Cl₂-HF Studies on Uranium-Zirconium Alloys-Two Reaction Zone Fluid-Bed Scheme - Additional studies in the six-inch diameter fluid-bed reactor, using the two-reaction zone scheme for processing low uranium-zirconium alloy fuels, show both hydrogen chloride and chlorine to be suitable as primary (lower zone) gas reactants. Reaction rates with chlorine at temperatures near 400°C have ranged from 300 to 400 g/hour of metal, while the maximum rate to date for hydrogen chloride has been about 300 g/hour. The fuel charges consisted of alloy plate sections weighing up to about 3 kg. The volatile zirconium tetrachloride and uranium chlorides are readily converted to the solid tetrafluorides by hydrogen fluoride admitted in the upper zone. The two zones are separated by a conical baffle. Granular calcium fluoride and an abrasive-grain aluminum oxide have both been used as the inert starting bed heat transfer medium in which the metal fuel charges are submerged.

c. Fluid-Bed Fluorination Studies - Fluid-bed fluorination experiments are being conducted on the reaction products of the two-zone hydrochlorination-hydrofluorination system to achieve separation of uranium. The most promising results to date were achieved at 500°C. Repeated four-hour fluorinations continued to show additional removal (up to 96 percent after 12 hours) using material containing an initial uranium content of 0.15 percent. Additional experiments at 550°C and 600°C indicated the initial rate of uranium removal was increased with increasing temperature. However, on continued fluorination a leveling-off effect (four-hour and eight-hour results essentially identical) was noted at 550°C. This would indicate sintering might be occurring; however, a complex mechanism must be in progress since increased uranium removal, from 90 to 93 percent, was achieved by a short additional period (1 hr) at 600°C.

d. Processing of Stainless Steel-Clad or Matrix Fuel Elements - Reaction of stainless steel with chlorine, considered as a decladding step for stainless steel clad nuclear fuels, has been compared with other reactants in tube furnace experiments preparatory to fluid-bed work. The results are shown in the following table:

<u>Reactant Composition</u>	<u>Temp. °C</u>	<u>Penetration Rate (mils/hr)</u>
50-50 mole % Cl ₂ , N ₂	570	5
	600	9.7
28 Cl ₂ , 41HF, 31N ₂ (mol %)	565	1.7
100% fluorine	550	0.7

Nickel, considered as a material of construction, corroded at about 20 mils/month at 600°C in chlorine. This indicates that lower temperatures may be necessary for actual process conditions.

e. Conversion of UF₆ to UO₂ - Values of 94.4 and 96.8 percent of the theoretical density were obtained in tests on uranium dioxide pellets prepared from powder produced in the fluid-bed simultaneous reaction scheme (steam-hydrogen) and the fluid-bed two-step process (steam followed by hydrogen). The better results were obtained for the material prepared by the two-step process. The powder was ground to minus 325 mesh in both cases.

f. Plutonium Fluoride Studies - Two experiments have been made in each of which approximately fifty grams of plutonium dioxide have been reacted with fluorine to produce plutonium hexafluoride with approximately one hundred percent yields. Five transport experiments have been made with plutonium hexafluoride using fluorine as a carrier gas. The plutonium hexafluoride in amounts ranging from 14 to 27 grams was transported through a furnace at 550°C to 600°C. It was then passed through a thermal gradient zone and was condensed. Recoveries of 99.1 ± 0.8 percent were obtained.

Data have been collected on fast neutron dosages from plutonium fluorides as they are used in our facilities. A typical dose is 83 n/(sec) (sq cm) at 2 in. from a 50-g sample of plutonium hexafluoride in a can (permissible dose 20 n/(sec)(sq cm) equivalent to 100 mr/40 hr week).

2. Chemical-Metallurgical Process Studies

Investigations of liquid metal solvent systems are being directed toward providing new pyrometallurgical methods for reprocessing nuclear reactor fuels. Related physicochemical data on liquid metal systems and thermochemical data on materials of interest to high-temperature chemistry are being obtained.

a. Liquid Metal Solvent Studies - The solubility of dysprosium and manganese in liquid cadmium have been determined and may be represented by the empirical equations

$$\text{Dysprosium (325°C-550°C): } \log (\text{atom percent Dy}) = 3.335 - 2450 T^{-1}$$

$$\text{Manganese (325°C-650°C): } \log (\text{atom percent Mn}) = 3.263 - 3054 T^{-1} + 0.4476 \times 10^6 T^{-2}$$

The temperature coefficient of solubility $[d(\log x) / d(1/T)]$ for the first transition period metals, titanium, manganese, iron, cobalt, and

nickel in liquid cadmium has been found to be a smooth function of a size factor (solvent atomic radius/solute atomic radius).

The solubilities of the first transition metals in cadmium at 500°C show a periodic variation with atomic number similar to the periodicity observed for the second transition series of metals.

The coprecipitation behavior of fission product elements is an important factor in determining separations that may be achieved by recrystallization from metallic solutions. The coprecipitation coefficients, λ , defined by the expression $\log \left[\frac{\text{tracer in solution}}{\text{total tracer}} \right] = \lambda \log \left[\frac{\text{carrier in solution}}{\text{total carrier}} \right]$, of a number of elements when carried by the cerium-cadmium intermetallic compound CeCd_{11} from liquid cadmium are being measured. Results that have been obtained to date are the following: sodium, 0; lithium, 0; potassium, 0; lanthanum, 1.49; strontium, 0.10; and zirconium, 0.04.

The coprecipitation coefficient of cerium when carried by the uranium-zinc intermetallic compound (epsilon phase, $\text{UZn}_{11.5-x}$) from a 10 weight percent magnesium-zinc solution was found to be 0.67. This does not differ significantly from the value of 0.66 obtained in pure zinc.

The influence of lead on the distribution of uranium between the two immiscible liquid metals zinc and bismuth has been determined. Upon adding lead to the system, the distribution coefficient (weight percent uranium in zinc-rich phase/weight percent uranium in bismuth-rich phase) was found to increase from 0.14 (zero percent lead) to 1.1 (39 weight percent lead in bismuth phase).

Vapor pressure measurements on the cerium-zinc system show the existence of intermetallic phases whose compositions correspond to the formulae CeZn_{11} , $\text{CeZn}_{8.5}$, CeZn_5 , CeZn_2 and CeZn . Analysis of the effusion data suggests that the CeZn_5 phase may exhibit a wide composition range.

Both vapor pressure measurements and thermal analysis studies have shown the existence of two intermetallic phases in the uranium-zinc system. The delta phase (composition $\text{UZn}_{8.5}$), which is probably a line compound, is formed by peritectic reaction at 844°C from the epsilon phase. This latter phase has been shown by both vapor pressure measurement and X-ray diffraction studies to have a range in composition. Attempts are being made to establish this range.

Measurements have been made of the free energy of formation of the epsilon phase using a galvanic cell method. The results are not significantly different from previous measurements ($\Delta F^\circ = -72,855 + 79.207 T - 2.218 \times 10^{-2} T^2$ for the temperature range from 550°C to 650°C).

Measurements of the magnetic susceptibility, χ , of the cerium-cadmium intermetallic compound showed that the Curie-Weiss equation, $\left[\chi = \frac{C}{T - \Delta} \right]$ is followed with $\Delta = -2^\circ$ and $C = 0.81$. The effective

Bohr magneton number for cerium in this compound is 2.55 which is in good agreement with the theoretical value of 2.56 for a Ce^{+3} ion in a $2F_{5/2}$ state.

A preliminary value for the heat of combustion of boron in fluorine has been determined to be $\Delta E_C^0/M = -24,946 \text{ cal/g}$ for the reaction

A preliminary value (without standard state corrections) of the heat of combustion in oxygen of tungsten and sulfur in the stoichiometric proportions of tungsten disulfide, WS_2 , has been determined to be $\Delta E_C = -2229.67 \pm 0.89 \text{ cal/g}$ for the reaction

Exploratory non-calorimetric combustion experiments have been carried out with titanium, hafnium, thorium, uranium and boron nitride in fluorine as well as uranium mononitride and zirconium dihydride in oxygen. Satisfactory combustion techniques have been developed for calorimetric combustions of titanium and hafnium in fluorine but additional work is necessary for the remaining materials.

E. Advanced Reactor Development

1. Argonne High Flux Reactor (AHFR)

Owing to the difficult budget situation, the research and development work specific to AHFR has been stopped and a terminal report is being written.

The design for the AHFR critical experiment will be modified to make the facility a general purpose research tool for high performance water systems. Studies of the hydraulic problems associated with parallel plate fuel assemblies will continue in the AHFR forced circulation loop in an effort to increase the power density limits of this type of element. The results will be useful to a variety of heterogeneous reactor concepts.

a. AHFR Critical - The disassembly of the AHFR reference design critical assembly provided an opportunity to obtain experimental information on the worth of the beryllium radial reflector. Upon completion of the temperature coefficient experiment described in the September Progress Report (ANL-6234) the worth of the reflector was measured by removing it in steps of approximately 10 cm in height and establishing criticality after each change. In order to regain reactivity for continuation of this stepwise removal, it was necessary to remove the stainless steel poison strip. It is estimated that the replacement of the 90% beryllium-10% lucite reflector by light water causes a loss of approximately 12% reactivity.

The final measurement in this AHFR critical assembly program was the determination of the critical water height, for reference purposes, of an unpoisoned 6 x 6 array of fuel elements. The core structure, fuel elements, and beryllium parts have been stored.

b. Hydraulic Test Loop - A theoretically adiabatic, forced circulation test loop has been constructed to facilitate investigation of the

hydraulic problems encountered in the fuel element designs proposed for the Argonne High Flux Reactor. The loop is designed to operate at a pressure of 10 atm and a water circulation rate of 1900 liters/min. With the exception of the test section and holder, the loop is constructed of stainless steel; flow studies are carried out in a horizontal plane.

The loop debugging has been completed, although vibration absorbers for the pumps have not yet been received. The orifice has been calibrated and is considered accurate and reproducible within 2% of the standard. The standard (a calibrated venturi) was considered accurate within $\pm 0.5\%$. Operation at a given pressure is now possible within 0.2 atm; however, a stable operating temperature has never yet been achieved during any set of runs. Tests are still being conducted to determine the eventual stable operating temperature of the loop and the time required to obtain this temperature.

Modifications to the test section holder have been completed and specific tests of the fuel element mockup will begin soon. These tests will include measurements of the coolant flow distribution through the fuel element channels, the total frictional pressure drop across the element, and the pressure drops across the inlet and outlet flow transition sections. Total coolant flow rates will be varied from 400 to 1800 liters/min at pressure parameters of 5 to 8.5 atm gauge.

Flow distribution measurements will be made with a multiple head pitot tube, enabling the impact pressure in four different channels to be read simultaneously. The pitot tube tips will be located at the coolant channel centerlines, and will project 3 mm into the channel from the outlet end of the mockup. It will be possible to traverse laterally across the mockup outlet with the pitot tubes so that a complete map of the flow distribution can be obtained.

Owing to the location of the static pressure tap, which will serve as the reference point for all four readings, accurate reduction of the impact pressures to absolute velocity within the fuel element is not contemplated. However, since the impact pressure is proportional to the square of velocity, a map of the percentage of total flow rate passing through each channel will be obtained.

Since the design for AHFR requires the operation of a reactor core near the limit of its capabilities, the problem of stresses and vibrations in parallel plate fuel elements with high coolant flow rates must be examined.

The dynamic behavior of parallel fuel plates, periodically supported in the longitudinal direction, was studied, including the effects of fluid acceleration on the loading on the plates. Although the work is not as yet completed, it appears that the presence of the fluid leads to travelling waves in the plate superimposed on the natural vibration modes.

c. Heat Flux and Heat Transfer Tests - Atmospheric pressure pool-boiling burnout tests, conducted to determine permissible levels of decay heat flux in the AHFR core, have been completed. The system consisted of two vertical, resistance-heated plates 6.02 cm (2.375 in.) wide and 44.5 cm (17.5 in.) high in parallel orientation, separated by a water channel

equal to the plate thickness and with half-thickness water channels on the outside plate surfaces. The heated plate perimeters and the water channels thus defined were open to the water pool in which the assembly was immersed to a depth of approximately 25 cm (10 in.) above the top of the heated plates. Plate thicknesses (and central water channel dimension) investigated were 0.089 cm (0.035 in.), 0.127 cm (0.050 in.), and 0.152 cm (0.060 in.) Burnout was determined by visual observation of the beginning of incandescence in the heated plates.

The burnout heat flux was evaluated on the basis of total plate surface area although the electrical current density caused a highly non-uniform flux distribution; the resultant burnout heat flux values are therefore unrealistically low. A better evaluation can be made after experimental determination of the electrical resistance profiles of the heated plates. The use of equal plate and flow channel thicknesses precluded the determination of the effect of flow channel spacing, since the burnout heat fluxes, as evaluated, were directly proportional to the plate thickness (and also the channel spacing) and therefore occurred at identical electrical current density. The limited scope of the tests and lack of time made independent checking of the flow channel dimension impractical.

The test results are therefore more valuable qualitatively than quantitatively. All burnouts were preceded by flow failure, as expected, and in most cases steam bursts were observed being ejected downward from the channel entrance, as well as from the channel sides.

An investigation was also made of the effect of partially and completely restraining the flow from the open sides of the channel. When a restraining barrier was installed to form a one-half channel along the end plates (normal spacing in the AHFR core), no lowering of the burnout heat flux occurred. Completely closing the channel sides resulted in a burnout heat flux approximately 40% lower than in the case of open or partially open channel sides. This is regarded as further confirming evidence that the critical heat flux (burnout) is the result of a hydrodynamic crisis.

2. Basic Radiation Effects Reactor

Conceptual design of the BRER (see Progress Report, September, 1960, ANL-6234, p. 67) was completed. A final report is now being reviewed prior to publication.

As a possible interim method for irradiation of a small number of samples of interest for solid state investigations, the use of a cylindrical converter with an inner boral lining is being explored. Such an assembly would be placed within the D₂O reflector of CP-5 in an effort to obtain a high fast-to-thermal spectrum within the converter.

3. Packed Bed Fuel Elements

a. Empirical Correlation for Pressure Drop - A rather detailed analysis of much of the data from packed bed pressure drop tests was completed. The data can be correlated within $\pm 30\%$ by the relation

$$\frac{\Delta P}{q} \frac{D_p}{L} = \frac{3850}{Re} \quad \text{for } 2 < Re < 9$$

where

Re = Reynolds number

ΔP = pressure loss

q = superficial velocity head

D_p = mean particle size

L = bed length

This equation yields pressure losses approximately 40% higher than would be obtained from the Katz correlation* for dense packings of 40% voids, but only 75% of those given by Leva ** for beds of sharp sands of this porosity. Four of the five packings (including the bed of UO_2 spheres) deviated only $\pm 20\%$ from the new correlation. Gravimetric porosity measurements varied from about 32 to 41% voids which would lead one to expect pressure drop variations on the order of 250%. A possible explanation is that the granule beds effectively packed to a more uniform density than indicated by the measurements. There was no consistent agreement or correlation between the gravimetric porosity results and the volumetric determinations made with the packing in a graduated glass. While these results prevented the inclusion of porosity or sphericity effects in the correlation, it appears that the packing of the granules is reproducible within reasonable limits and the equation is adequate for practical purposes.

Some preliminary calculations for a 2-kw experimental bed of UO_2 -CaO-ZrO₂ particles with 10 wt-% UO_2 were completed. Dimensions of the bed depend on physics considerations and allowable forces on the bed support. Assuming superheated steam discharging from the bed at 815°C, the over-all pressure loss from a 175-cm³ bed, 5 cm long, would be 0.1 atm; for a 20-cm bed the loss is 1.0 atm. Rough sizing calculations of a de-superheater-condenser for the experimental system indicate that this component would require only a small volume.

b. Heat Transfer and Fluid Flow - A mathematical model with two independent variables (time, and the distance along the axis) was postulated to study the transient heat transfer in a heat-generating packed bed. The model introduces a number of simplifications in that it assumes plug flow and neglects the variation of temperature with the radial position. Based on the conclusions drawn in an earlier study, the interparticle heat transfer by conduction has also been neglected. Even so, the model is quite useful in studying analytically the performance of packed beds. However, the equations which describe even this simplified model are too complicated to be solved analytically.

* "Unit Operations," G. G. Brown, ed. Wiley & Sons, Inc. (1950).

** M. Leva, et al, "National Bureau of Standards Bulletin 504. "

A numerical scheme, known as a method of characteristics, for solving the system of hyperbolic partial differential equations in their full generality was found to be satisfactory. The method of characteristics is an approximate one, yet is straightforward, systematic, and appears capable of producing numerical results of great accuracy.

4. Lunar Power Plant

The conceptual design for a mercury-cycle, compact reactor as a stationary power source on the moon is essentially complete. In an effort to reduce weight, titanium has been proposed as a material for the heat sink radiator (22% savings over stainless steel). Since little is known about corrosion rates of titanium in mercury, static autoclave tests (370°C, 6.8 atm) were made to explore this problem. The results for liquid phase mercury corrosion after seven days exposure show a 0.12 to 0.28 mg/cm²/day rate for titanium; a Type 304 stainless steel control sample gave essentially zero corrosion.

5. Direct Conversion Studies

A new method was used to carbonize the tantalum disc to be used in a new cesium plasma cell. The tantalum to be carbonized was exposed to the reducing flame of a candle and a thick layer of carbon black was deposited on it. The tantalum was heated in vacuum by electron bombardment to about 1400°C to 1500°C. It appears that this method is preferable to carbonization in methane. Deposition of UC-ZrC solution on the TaC base had to be repeated two times to obtain a good continuous layer. The deposition was checked with an alpha counter and is estimated at about 1 mg/cm² thickness.

Because experimental electrode emissivities are poorly known and vary with time, an auxiliary electric heater is being built to measure the power loss by heat radiation from the cathode to the anode in parallel plate geometry. The heater, in good thermal contact, is substituted for the radiation source and the heater power required to produce the same cooling oil temperature change is determined.

VI. PUBLICATIONSPapers

THE INTERNAL FEEDBACK FOR EBR-I, MARK III
J. C. Carter, D. W. Sparks and J. H. Tessier
Nuc. Sci. & Eng. 8, 326-339 (1960)

OXIDATION STUDIES OF URANIA-THORIA SOLID SOLUTIONS
E. D. Lynch, J. H. Handwerk and C. L. Hoenig
J. Am. Cer. Soc. 43 (10) 520-524

SOME PHYSICAL PROPERTIES OF THORIA REINFORCED BY METAL
FIBERS
Y. Baskin, Y. Harada and J. H. Handwerk
J. Am. Cer. Soc. 43 (9) 489-492

FABRICATION OF U_3O_8 - ALUMINUM DISPERSION FUEL ELEMENTS
BY EXTRUSION
R. A. Noland, D. E. Walker and L. C. Hymes
Book: Materials in Nuclear Applications
ASTM Spec. Tech. Pubn. No. 276, 336-344

THE ENGINEERING ASPECTS OF THE WATER VAPOR PERMEABILITY
OF GLOVE MATERIALS
J. E. Ayer, R. M. Mayfield and D. R. Schmitt
Nuc. Sci. & Eng. 8 (3) 274-276

INTRODUCTION TO CHAPTER, "SYMPOSIUM ON CERAMICS IN
NUCLEAR ENERGY"
J. H. Handwerk
Book: Materials in Nuclear Applications
ASTM Spec. Tech. Pubn. No. 276, p. 291

ANL Reports

- ANL-6117 THE FLUORINATION OF URANIUM FROM DRIED SOLIDS
AND ITS APPLICATION TO THE FLUORIDE VOLATILITY
PROCESS
J. Fischer and C. E. Johnson
- ANL-6167 KINETICS OF DISSOLUTION OF ZIRCONIUM IN MOLTEN
URANIUM
G. Golden
- ANL-6178 COST STUDY OF A 100-Mwe DIRECT-CYCLE BOILING
WATER REACTOR PLANT
C. F. Bullinger and J. M. Harrer
- ANL-6183 CHEMICAL ENGINEERING DIVISION SUMMARY REPORT
APRIL, MAY AND JUNE, 1960
S. Lawroski, R. C. Vogel and V. H. Munnecke
- ANL-6189 OPERATIONAL TESTS OF EBWR VAPOR RECOVERY SYSTEM
R. J. Gariboldi and D. R. Jacobson
- ANL-6205 TRANSFER FUNCTION MEASUREMENT AND REACTOR
STABILITY ANALYSIS
Edited by D. Okrent and J. A. DeShong, Jr.
Proceedings of Conference held at Argonne National
Laboratory, Argonne, Illinois, May 2-3, 1960
- ANL-6216 REMOVAL OF EBWR FUEL ELEMENT SCALE BY SLURRY
HONING
Ira Charak