

271  
IN-1321  
8/5

1488

IN-1321  
JUNE 1970

**MASTER**

RELAP3 -- A COMPUTER PROGRAM  
FOR REACTOR BLOWDOWN ANALYSIS



**IDAHO NUCLEAR CORPORATION**  
NATIONAL REACTOR TESTING STATION  
IDAHO FALLS, IDAHO

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

**U. S. ATOMIC ENERGY COMMISSION**

## DISCLAIMER

**This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.**

## **DISCLAIMER**

**Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.**

Printed in the United States of America  
Available from  
Clearinghouse for Federal Scientific and Technical Information  
National Bureau of Standards, U. S. Department of Commerce  
Springfield, Virginia 22151  
Price: Printed Copy \$3.00; Microfiche \$0.65

#### LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of any information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission, or employee of such contractor, to the extent that such employee or contractor of the Commission, or employee of such contractor prepares, disseminates, or provides access to, any information pursuant to his employment or contract with the Commission, or his employment with such contractor.

**LEGAL NOTICE**

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Atomic Energy Commission, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

IN-1321  
Issued: June 1970  
Reactor Technology  
TID-4500

**RELAP3 -- A COMPUTER PROGRAM  
FOR REACTOR BLOWDOWN ANALYSIS**

BY

W. H. Rettig  
G. A. Jayne  
K. V. Moore  
C. E. Slater  
M. L. Uptmor

**IDAHO NUCLEAR CORPORATION**

A Jointly Owned Subsidiary of

AEROJET GENERAL CORPORATION  
ALLIED CHEMICAL CORPORATION  
PHILLIPS PETROLEUM COMPANY



U. S. Atomic Energy Commission Scientific and Technical Report  
Issued Under Contract AT(10-1)-1230  
Idaho Operations Office

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

A handwritten signature in black ink, appearing to be "Rettig", is located at the bottom right corner of the page.

## ABSTRACT

RELAP3 is a computer program, written in FORTRAN IV, that describes the behavior of water-cooled nuclear reactors during postulated accidents such as loss-of-coolant, pump failure, or power transients. The behavior of the primary cooling system and the reactor is emphasized. The program calculates flows, mass inventories, energy inventories, pressures, temperatures, and qualities along with variables associated with reactor power, reactor heat transfer, or control systems. The program is sufficiently versatile to describe simple hydraulic systems as well as complex reactor systems.

The user must define the geometric description of the system to be analyzed as well as an appropriate set of initial conditions. RELAP3 then solves an integral form of the fluid conservation and state equations applied to each user-defined control volume. Currently, the number of these control volumes is limited to 20 and the number of junctions (flow paths) between volumes to 50. By simply increasing the array sizes these limits could be raised until the capacity of the particular computer is reached.

RELAP3 source decks are available in single (BCD) and double precision (EBCDIC) versions. Use of special timing and input-output routines (available for the IBM 7044 and the IBM 360 systems) is desirable, but not necessary. Sample problems have been run on a wide variety of computers: IBM 7044, Univac 1108, CDC 6600, and IBM 360/75. The most recent changes have only been tested on the IBM 360/75 computer.

## CONTENTS

|                                       |    |
|---------------------------------------|----|
| ABSTRACT .....                        | ii |
| I. INTRODUCTION .....                 | 1  |
| II. RELAP3 FEATURES .....             | 3  |
| 1. GEOMETRIC DETAIL .....             | 3  |
| 2. GRAVITY HEAD .....                 | 3  |
| 3. CONTROL OPTIONS .....              | 4  |
| 4. STEAM SEPARATION .....             | 4  |
| 5. PUMP CHARACTERISTICS .....         | 4  |
| 6. FRICTION COEFFICIENTS .....        | 4  |
| 7. PROGRAM ORGANIZATION .....         | 4  |
| 8. RESTART CAPABILITY .....           | 5  |
| 9. PLOTTING AND EDITING OPTIONS ..... | 5  |
| III. EQUATIONS SOLVED .....           | 6  |
| 1. MASS AND ENERGY BALANCES .....     | 6  |
| 2. THERMODYNAMIC PRESSURE .....       | 7  |
| 3. MOMENTUM BALANCE .....             | 9  |
| 4. CHOKED FLOW .....                  | 11 |
| 5. ENERGY REMOVAL .....               | 11 |
| 6. ENERGY ADDITION .....              | 12 |
| 6.1 Conduction Model .....            | 13 |
| 6.2 Heat Transfer Correlations .....  | 16 |
| 7. CRITICAL HEAT FLUX .....           | 18 |
| 8. POWER GENERATION .....             | 20 |
| 9. REACTIVITY .....                   | 21 |
| 10. TWO-PHASE SEPARATION MODEL .....  | 22 |
| 11. JUNCTION QUALITIES .....          | 25 |

|   |    |
|---|----|
| 12. FILL SYSTEMS . . . . .  | 25 |
| 13. SYSTEM BALANCES . . . . .   | 25 |
| 14. CHECK VALVES . . . . .  | 27 |
| IV. REFERENCES . . . . .  | 29 |
| APPENDIX A -- APPROXIMATIONS TO THE CONSERVATION<br>EQUATIONS . . . . . | 31 |
| APPENDIX B -- CHOICE OF TIME STEP SIZE . . . . .                        | 37 |
| APPENDIX C -- INPUT DEFINITIONS . . . . .                               | 41 |
| APPENDIX D -- PROGRAM STRUCTURE . . . . .                               | 57 |
| APPENDIX E -- SUBROUTINE DESCRIPTIONS . . . . .                         | 61 |
| APPENDIX F -- RELAP3 FLOW CHARTS . . . . .                              | 71 |
| APPENDIX G -- SAMPLE PROBLEMS . . . . .                                 | 85 |

#### FIGURES

|  |    |
|--|----|
| 1. Control volume . . . . .                    | 7  |
| 2. Low pressure table structure . . . . .      | 8  |
| 3. Flow volume . . . . .                       | 9  |
| 4. Fuel rod heat conduction model . . . . .    | 15 |
| 5. Check valve characteristic curves . . . . . | 28 |

#### FLOW CHARTS

|                              |    |
|------------------------------|----|
| 1. Program flow . . . . .    | 73 |
| 2. Tape editing . . . . .    | 74 |
| 3. Restarting link . . . . . | 75 |
| 4. Input link . . . . .      | 76 |
| 5. Transient link . . . . .  | 77 |
| 6. Volume data . . . . .     | 78 |



|                                       |    |
|---------------------------------------|----|
| 7. Junction data . . . . .            | 79 |
| 8. Reactor data . . . . .             | 80 |
| 9. Mass and energy balances . . . . . | 81 |
| 10. Momentum balance . . . . .        | 82 |
| 11. Reactor kinetics . . . . .        | 83 |

# RELAP3 -- A COMPUTER PROGRAM FOR REACTOR BLOWDOWN ANALYSIS

## I. INTRODUCTION

In support of the Loss-of-Fluid Test (LOFT) safety analysis effort, the RELAP series of computer programs[1] has been developed to describe hydrodynamic conditions inside a reactor primary system. The new version, RELAP3, can be used for many pressurized-water-reactor safety studies such as large reactivity excursions, coolant losses, or pump failures. RELAP3 retains most of the calculational methods used in previous versions but provides greater freedom in describing the system geometry. Unlike predecessors RELAP3 is built of dozens of specialized subroutines, each of which performs a limited portion of the calculation. Thus, extending or improving the models has been made easier.

RELAP3 represents the reactor system as a set of arbitrarily connected fluid volumes that describe the plenums, piping, reactor core, and heat exchangers. Any volume may be chosen independently as a core region or heat exchanger. Fluid compressibility in all volumes (including core regions) is considered in predicting the course of the transient. Each connection between volumes may be specified as a normal junction, a leak junction, or a fill water source. A normal junction may also include a pump and a valve. The transient is calculated time-step by time-step; the volume masses, energies, and bubble contents are advanced, and new junction conditions are obtained, and flows recomputed. Reactor conditions may be used to provide reactivity feedback.

Predecessors of RELAP3 were specifically designed to describe a reactor primary system of three volumes (a lower plenum, an upper plenum, and a pressurizer), a core, and an external loop. Full flow was required as an initial condition. These requirements prohibited analysis of simplified experiments such as single vessel blowdowns. At the other extreme, the three volume description could not provide enough detail to adequately describe a complete reactor primary system. RELAP3 does not contain these restrictions, thus analysis of both simplified and complex systems is allowed.

The RELAP3 program is being released, not as a final product, but as a current method for investigating the transients expected in pressurized water reactor accidents. Modifications currently planned to improve and extend the area of usefulness of the calculations will be included in the next version of the RELAP computer program. Future program modifications will be issued as compatible modules to the current code, and documentation of these modifications will be as addenda to this report.

The body of this computer program description is divided into two parts. The first contains descriptions of features included in RELAP3, with emphasis on those features which are different from those contained in previous versions. The second part contains the most important of the equations RELAP3 uses to describe a reactor primary system.

Several appendices are included to aid in the use or modification of RELAP3. The first three are to be used in determining junction constants, time step sizes,

and other input quantities. Following these are three appendices (program structure charts, subroutine descriptions, and flow charts) of interest to a programmer who wishes to understand or modify the program. The final appendix contains two sample problems with solutions: a single vessel blowdown and a reactor primary system blowdown.

## II. RELAP3 FEATURES

RELAP3 may be viewed either as an extension of the previous version (RELAP2) or as a completely new computer program. The physical models vary little from those used in the previous version, but the logic used to attack the problem has required almost all of the older programming to be scrapped. RELAP3 was designed so that changes could be made in the physical models without a major programming task, whereas previous versions were too interlocked in structure for such changes to be made easily.

To gain generality in RELAP3, no constraints were included on the nature of a specific volume or junction. For instance, any volume may be selected to represent any core region or heat exchanger. Likewise, any junction may represent a leak out of the system with no restrictions as to which or how many junctions must be so used. Thus, multiple breaks may be treated directly by specifying several leak junctions in the input.

### 1. GEOMETRIC DETAIL

In RELAP3 the terms volumes and junctions have the following meanings: volumes specify a region of fluid within a given set of fixed boundaries; and junctions are the common flow areas of connected volumes. Calculated results are limited in geometric detail by the size of each volume.

RELAP3 is general in the geometrical description allowed. RELAP2 required that exactly three volumes be used, with a fixed set of pipes connecting these volumes. RELAP3 allows a maximum of 20 volumes connected by a maximum of 50 junctions, with no restrictions as to the order of these connections. The number of volumes and junctions, 20 and 50, is arbitrary and can be increased to far greater limits on any large computer such as the IBM 360/75. Changes required consist almost entirely of increasing the array sizes given in the COMMON statements. These changes can be performed automatically by an auxiliary FORTRAN IV routine which is available separately. The smaller limits were chosen to ensure that RELAP3 would fit into an IBM 7044 size computer with only a simple overlay structure being required.

### 2. GRAVITY HEAD

In RELAP3 junctions connect volumes directly and thus contain no elevation changes. To account for gravity terms, the pressure calculated within a volume from thermodynamic relationships is assumed to occur at the center of gravity. Positive or negative gravity heads may then be found by integration of the fluid density from the center of gravity to the level of the junction connected to the volume.

### 3. CONTROL OPTIONS

Control parameters have been generalized in RELAP3. For instance, reactor scram may be initiated by the first condition detected among high power level, short period, fuel temperature, high pressure in any volume, low pressure in any volume, and so on. Opening the leaks (staggered leak openings might be accomplished through the individual opening-time curves), tripping the pumps, starting the fill systems, controlling up to five valves separately, or ending the problem also may be put under the control of many different conditions.

### 4. STEAM SEPARATION

One of several sets of coefficients (input) for the steam separation calculation may be chosen for each volume. Part of the required volume data is a bubble set index which determines, for each volume, the set of coefficients to be used. The zeroth set (a uniform liquid-steam mixture) is built-in; others must be supplied as input.

### 5. PUMP CHARACTERISTICS

Although only one pump coastdown curve is allowed, several different pump characteristic curves may be supplied. Each of these curves may be used as many times as desired so that no limit exists on the number of pumps in the system. Allowing only one coastdown curve may sometimes be a limitation because staggered loss-of-flow accidents cannot be handled in any convenient way. Should solutions for staggered loss-of-flow accidents be required, modifications to correct this problem are not expected to be difficult to make.

### 6. FRICTION COEFFICIENTS

An option which eliminates some input is the implicit calculation of friction coefficients. When the friction coefficient is left out of the data for a junction, RELAP3 will calculate a value which establishes steady state flow. This calculation, which is based on initial pressures including gravitational heads, often yields a negative friction coefficient that would cause numeric instabilities. If a negative friction coefficient is found after the input is processed, the RELAP3 run will be aborted to avoid lost computer time. Initial pressures must be readjusted by the user.

### 7. PROGRAM ORGANIZATION

Extraneous input requirements have been almost eliminated. For instance, a problem containing no core regions will require no reactor or heat transfer data. As a result, a typical single vessel blowdown (one volume, one leak junction) requires about 15 cards out of the several hundred currently possible.

Input simplification also has led to dropping options which were not used in RELAP2. RELAP3 includes no xenon transient capabilities, no provisions for a decrease of net positive suction head (Henry's Law), no analytic equations for rod worth, and no analytic expressions for the Doppler reactivity.

The input link of RELAP3 is broken into subroutines, each written to handle a different kind of input information. The construction into subroutines facilitates programming changes. For example, a change to the pump description would be limited to modifying the pump input and initialization and the pump head calculation with little worry about missing required changes hidden elsewhere in the program. Once the input and initialization programming has been used it is deleted as the transient link is pulled into the computer memory. Thus a programmer is guaranteed that only variables contained in common lists are transferred.

In RELAP3 all initialization is performed in the input link and the initial values are placed in the labeled common areas, simplifying the transient portion of the calculation considerably. Previously, initial conditions were set up within the same subroutine which performed the transient calculation. Changes were difficult because no indication existed as to which variables were recalculated each time step, and which were calculated only in the initial conditions. In addition, this technique added length to the already long transient routine making it even harder with which to work.

## 8. RESTART CAPABILITY

The major cause of failure of a RELAP3 calculation appears to be the time step size being too large. In addition, the probability of a computer failure during a very long run becomes significant. The restarting capability included in RELAP3 can salvage virtually all of the computer time spent prior to a failure, allowing the problem to be continued with a new time stepping sequence. The choice of edited variables and the edit frequency may also be modified in the continuation. Thus, a close look may be taken at a selected portion of a RELAP3 run without starting over again.

## 9. PLOTTING AND EDITING OPTIONS

The data tape used for storing the information required for restarting is also used for storing the editable variables at designated intervals. RELAP3 can process one of these tapes to obtain additional edits as required. The plotting program is adapted only to the NRTS computing system, but is available as a separate package for those who want to convert it.

### III. EQUATIONS SOLVED

RELAP3 obtains a time-dependent thermal and hydraulic solution by integrating a set of differential equations subject to certain algebraic relationships. These equations and relationships are presented in the following sections.

A mass and energy balance is obtained from junction conditions, heat output of reactor regions, and heat removed by heat exchanger regions. By using the equation-of-state for water (in the form of tables) a pressure and a quality are obtained for each volume. If a linear density model for steam separation within a volume is assumed, fluid conditions can be determined for each junction. A one-dimensional momentum balance (flow calculation) is then obtained for each junction. The fluid conditions within a volume, the flow through a volume, and the reactor power level are then used to establish the reactor heat flux and the fuel element temperatures. By the use of reactivity feedback from reactor conditions, the space-independent reactor kinetics equations are then advanced to determine a new reactor power level. A new cycle is then begun with a new mass and energy balance.

#### 1. MASS AND ENERGY BALANCES

As demonstrated in Appendix A, the mass and energy stored in each volume are calculated from the basic conservation equations by assuming constant flow and fluid properties during any given time step. The conservation equations are in the form of ordinary time-dependent differential equations describing the behavior within a fixed control volume, illustrated in Figure 1. The mass and energy equations are

$$\frac{dM_i}{dt} = \sum_{j=1}^N W_{ij} \quad (1)$$

and

$$\frac{dU_i}{dt} = \sum_{j=1}^N W_{ij} h_{ij} + Q_i \quad (2)$$

where

$M_i$  = total mass in volume  $i$

$W_{ij}$  = flow rate into volume  $i$  through junction  $j$

$U_i$  = energy in volume  $i$


$h_{ij}$  = enthalpy of flowing fluid

$Q_i$  = heat input to volume  $i$ .

Kinetic and frictional energies are neglected in Equation (2).

For an energy balance in each volume, the correct enthalpy must be determined for all incoming and exiting flows. In RELAP3, the exit state of the fluid through a junction is defined by the state of the fluid in contact with the

junction point. If the mixture level of liquid and entrained steam bubbles is below a junction, the flow is assumed to be steam. Conversely, if the mixture level is above the junction, the flow is determined by the bubble gradient equations described in Section III-10.



INC-A-14175

FIG. 1 CONTROL VOLUME.

## 2. THERMODYNAMIC PRESSURE

Pressure,  $P_i$ , in each volume is determined implicitly by requiring the mass of fluid,  $M_i$ , with internal energy,  $U_i$ , to fill control volume  $V_i$ . The enthalpy,  $h_i$ , of volume  $i$  is calculated by the equation

$$h_i = \frac{U_i}{M_i} + P_i \frac{V_i}{M_i} \quad (3)$$

Through use of this enthalpy, along with an estimated pressure, the specific volume of the fluid is calculated from the available physical property tables. An iterative process of matching the specific volume from the steam tables with known specific volume  $V_i/M_i$  is used to determine the volume pressure. The property tables for water cover the range of  $0.1 \leq P \leq 3206$  psi, and  $32 \leq T \leq 5600^\circ\text{F}$ .

The values in the thermodynamic property tables were calculated from the 1967 ASME Steam Formulae[2]. For each pressure,  $P_j$ , the tables of water density,  $\rho$ , and steam specific volume,  $v$ , are arranged as follows:

$$\text{liquid} \left\{ \begin{array}{lll} h_{j,1} & \rho_{j,1} & T_{j,1} \\ h_{j,2} & \rho_{j,2} & T_{j,2} \\ \cdot & & \\ \cdot & & \\ \cdot & & \\ \cdot & & \\ h_{j,13} & \rho_{j,13} & T_{j,13} \end{array} \right.$$



steam

|   |            |            |            |
|---|------------|------------|------------|
|   | $h_{j,1s}$ | $v_{j,1s}$ | $T_{j,1s}$ |
| { | .          |            |            |
|   | .          |            |            |
|   | .          |            |            |
|   | .          |            |            |
|   | $h_{j,5s}$ | $v_{j,5s}$ | $T_{j,5s}$ |

where

$$T_{j,1} = 32^{\circ}\text{F}$$

$$T_{j,13} = T_{j,1s} = T_{\text{sat}}(P_j)$$

$$T_{j,4s} = 1600^{\circ}\text{F}$$

$$T_{j,5s} = 5600^{\circ}\text{F}$$

and  $P_j = 0.1, 0.3, 1.0, 5.0, 14.7, 50., 100., 200., 400., 600., \dots$   
 $3000., 3206.2 \text{ psi}$

In the low-pressure (<50 psi) liquid range of the tables, entries are arranged along equal temperature lines for all pressures, as shown in Figure 2.





FIG. 2 LOW PRESSURE TABLE STRUCTURE.

For pressures > 100 psi, the liquid entries for a given pressure are at equally spaced temperature intervals from 32°F to  $T_{sat}$ . The entries for a given pressure in the steam region are equally spaced between  $T_{sat}$  and 1600°F with a final point at 5600°F.

In the liquid region, at high pressure (> 2200 psi) and within a few degrees of saturation temperature, the tables have proven inadequate. RELAP3 results should be carefully examined by the user for possible errors arising from this cause.

### 3. MOMENTUM BALANCE

The control volume used for the flow calculation is shifted to a mid-position between the two adjacent mass-energy control volumes, as shown in Figure 3. This shifting of the two types of control volumes has the advantage of minimizing the extrapolation of boundary conditions. The mass-energy calculations require a junction flow as a boundary condition, which, with the shifted flow volume, is approximately the average flow as given by Equation (4). Likewise, the flow volume requires as a boundary condition, the pressure which is available as the average thermodynamic pressure from mass-energy-volume, adjusted for gravity effects.



INC-A-14172

FIG. 3 FLOW VOLUME.

Junction flows are calculated from the one-dimensional momentum equation which in English units is:

$$\frac{1}{144g_c} \left( \frac{l}{A} \right) \frac{dW_j}{dt} = P_i - P_{i+1} + \Delta P_p + \int_{V_j} \frac{\rho dz}{144} - \frac{K_j W_j |W_j|}{\rho_j} \quad (4)$$

where

$g_c$  = gravitational conversion constant

$\frac{\ell}{A}$  = junction inertia

$W_j$  = average flow from volume  $i$  to volume  $i+1$

$P_i - P_{i+1}$  = thermodynamic pressure differential across the fluid contained in the flow volume

$\Delta P_p$  = pump head

$\int_{V_j} \rho dz$  = gravitational head across fluid column

$K_j$  = net friction coefficient including normal friction losses (Appendix A).

$\rho_i$  = fluid density in volume  $i$ .

The fluid contained within the flow volume has an associated inertia which depends on the actual shape of the volume.

The junction inertia for a homogeneous volume is

$$\left(\frac{\ell}{A}\right)_j = \int_{V_j} \frac{d\ell}{A} \quad (5)$$

where

$\ell$  = the length of the flow path

$A$  = cross-sectional area for the flow.

In the simple example shown in Figure 3,

$$\left(\frac{\ell}{A}\right)_j = \frac{1}{2} \left(\frac{\ell_i + \ell_{i+1}}{A_i}\right). \quad (6)$$

The normal friction coefficients should initially balance with the input pressure distributions for flowing systems. If initial flow exists between two volumes, RELAP3 can calculate the appropriate friction coefficient as

$$K_j = \frac{[(P_i + \Delta P_{grav,i}) - (P_{i+1} + \Delta P_{grav,i+1}) + \Delta P_{pump,j}] \rho_j}{W_j |W_j|} \quad (7)$$

For junctions with no initial flow, the user must supply a value for  $K_j$ .

Elevation heads, which are included in Equation (4), are calculated by integrating the density distribution as defined by the steam separation model.

#### 4. CHOKED FLOW

At the user's option, any junction except a fill junction can be limited by choking.

The limiting mass flow is defined by Moody's two-phase choked flow model[3],

$$W_{\text{choke}} = A_{\text{choke}} f_n(P_o, h_o) \quad (8)$$

where

$W_{\text{choke}}$  = maximum junction flow

$A_{\text{choke}}$  = minimum area in junction

$f_n$  = mass flux as a function of stagnation pressure,  $P_o$ , and enthalpy,  $h_o$ .

The stagnation conditions are assumed to be the thermodynamic conditions within the volume feeding the junction and at the junction height.

The flow through a junction is chosen as the smaller of the inertial flow or the choked flow.

Moody's model also gives the throat pressure,  $P_{th}$ , as a function of  $P_o$  and  $h_o$ . In RELAP3, the sink pressure must be less than the throat pressure for choking to occur in a leak junction.

#### 5. ENERGY REMOVAL

Energy removal by a heat exchanger is calculated from an input table or by the following flow-dependent equation:

$$Q_i = -Q_{HE} = -\frac{W}{W_o} H_{HE} (T_{\text{Pri}} - T_{\text{Sec}}) \quad (9)$$

where

$Q_i$  = rate of heat addition to volume i

$Q_{HE}$  = heat removal rate of the heat exchanger

- $W$  = flow of the primary coolant through volume  $i$   
 $W_0$  = initial coolant flow through volume  $i$   
 $H_{HE}$  = effective heat transfer coefficient during steady state full power operation  
 $T_{Pri}$  = temperature of primary coolant in the heat exchanger  
 $T_{Sec}$  = temperature of secondary coolant in the heat exchanger.

The term representing the heat transfer coefficient ( $H_{HE}$ ) is determined internally in the code from initial steady state conditions:

$$H_{HE} = - \frac{Q_i}{(T_{Pri} - T_{Sec})} \quad (10)$$

Since heat exchangers are independent of each other, the choice of a flow dependent model for one does not eliminate the possibility of using an input table for another.

## 6. ENERGY ADDITION

Energy addition to the fluid occurs in the core volumes [a]. The rate of heat addition is calculated using a multinode pin conduction subroutine and a subroutine for predicting the heat transfer coefficients for the various modes of heat transfer.

An iterative process calls alternately the subroutine to calculate the heat transfer coefficient and the conduction subroutine to calculate the temperatures. The latter subroutine requires the heat transfer coefficient, the bulk fluid temperature, the surface flux (from previous time step), the time step size, and the heat generation rates as input. Convergence of the heat transfer coefficient terminates the iteration; that is, if after two successive iterations the change in the heat transfer coefficient is less than a specified tolerance, the calculation is terminated.

Flows, pressures, and densities of the coolant fluid are assumed constant during a single time step. The flow through a given core volume is obtained by averaging the flow through the inlet and outlet junctions.

Heat generation in the fuel pins is determined by reactor kinetics routines or by table look up of power versus time.

---

[a] The steam generator volumes can also be used as an energy source through the use of a negative heat removal curve.

The overall energy balance for the pin is

$$V \bar{\rho} \bar{C} \frac{d\bar{T}}{dt} = Q + S_N k_N \frac{dT_N}{dR} \quad (11)$$

where

$V$  = fuel pin volume

$\bar{\rho}$  = density

$\bar{C}$  = specific heat

$\frac{d}{dt}$  = derivative with respect to time

$\bar{T}$  = average pin temperature

$Q$  = heat generation rate in fuel pin

$S_N$  = pin surface area

$k_N$  = thermal conductivity at surface of pin

$\frac{d}{dR}$  = derivative with respect to radius

$T_N$  = surface temperature.

Equation (11) assumes a uniform heat flux and an average temperature defined by

$$\bar{T} = \frac{\int_V C_p T dV}{\int_V C_p dV} \approx \frac{\sum_{n=1}^N (\rho V)_n C_n T_n}{\sum_{n=1}^N (\rho V)_n C_n} \quad (12)$$

where

$N$  = total number of annuli used in pin

and

$n$  = fuel pin annulus number.

### 6.1 Conduction Model

The pin conduction model solves the one-dimensional heat conduction equation for a cylindrical geometry. The pin conduction model and the method of solution are patterned after the model and method used in the HEAT1 code [4]. Currently, the model can accommodate up to 31 radial nodes, six different concentric regions, and six different materials. Core volumes can be stacked vertically to achieve axial definition.

For annulus  $n$  shown in the diagram, the conduction equation is

$$V_n \bar{\rho}_n \bar{C}_n \frac{d\bar{T}_n}{dt} = Q_n + S_n k_n \frac{dT_n}{dR} - S_{n-1} k_{n-1} \frac{dT_{n-1}}{dR} \quad (13)$$

where

$S$  = annulus surface area.

Equation (13) is approximated numerically by

$$V_n \bar{\rho}_n \bar{C}_n \frac{(T'_n - T_n)}{\Delta t} = Q'_n + \frac{S_n}{2\Delta R_n} \left[ \bar{k}_{n,n+1} (T_{n+1} - T_n) + \bar{k}'_{n,n+1} (T'_{n+1} - T'_n) \right] - \frac{S_{n-1}}{2\Delta R_{n-1}} \left[ \bar{k}_{n-1,n} (T_n - T_{n-1}) + \bar{k}'_{n-1,n} (T'_n - T'_{n-1}) \right] \quad (14)$$

where

$$\bar{k}_{n,n+1} = \frac{k_n + k_{n+1}}{2} \quad (15)$$

and superscript prime (') designates the current iteration.

The boundary conditions are

$$\left. \frac{dT'}{dR} \right|_{R=0} = 0 \quad (16)$$

and

$$\frac{dT'_N}{dR} = \frac{h(T'_N - T'_W)}{-k'_N} \quad (17)$$

where

$h$  = heat transfer coefficient.

$N$  simultaneous equations of the form

$$a_n T'_{n-1} + b_n T'_n + g_n T'_{n+1} = d_n$$

are obtained by writing Equation (14) for each of the  $N$  regions

where

$a$ ,  $b$ ,  $g$ , and  $d$  are constants for a given iteration.

The  $N$  equations form a matrix equation which is solved by the method described in Reference 4 for the temperatures at each node.

In order to solve the conduction equations, the pin is divided into annular regions as shown in Figure 4.




FIG. 4 FUEL ROD HEAT CONDUCTION MODEL.



## 6.2 Heat Transfer Correlations

Correlations for predicting heat transfer coefficients for seven different modes of heat transfer are provided. The correlations and conditions for which they are used are as follows:

Mode 1 -- Subcooled Forced Convection:  $X < 0.0$ ,  $T_s < T_{NB}$   
Seider Tate correlation [5]

$$h = \frac{0.023k_f(T_w)}{D} \left[ \frac{DG}{\mu_f(T_w)} \right]^{0.8} \left[ \text{Pr}(T_w) \right]^{1/3} \left[ \frac{\mu_f(T_w)}{\mu_f(T_s)} \right]^{0.14} \quad (18)$$

where

$h$  = heat transfer coefficient, Btu/ft<sup>2</sup>-hr-°F

$X$  = mass fraction of steam (quality)

$T_{NB}$  = minimum surface temperature for nucleate boiling as defined by Equation (19), °F

$k_f(T_w)$  = saturated liquid thermal conductivity evaluated at  $T_w$ , Btu/ft-hr-°F

$T_w$  = temperature of coolant, °F

$D$  = hydraulic diameter of flow channel, ft

$G$  = mass flux of coolant, lb/ft<sup>2</sup>-hr

$\mu_f(T_w)$  = saturated liquid viscosity evaluated at  $T_w$ , lb/ft-hr

$\text{Pr}(T_w)$  = Prandtl number for coolant

$\mu_f(T_s)$  = saturated liquid viscosity evaluated at  $T_s$ , lb/ft-hr

$T_s$  = fuel pin surface temperature, °F

subscript  $f$  indicates saturated liquid property

subscript  $g$  indicates vapor property.

Mode 2 -- Subcooled Nucleate Boiling:  $X < 0.0$ ,  $T_s = T_{NB}$   
Thom correlation [6]

$$T_{NB} = T_{sat} + 0.072 e^{-P/1260} \phi_S^{0.5} \quad (19)$$

$$h = \frac{\phi_S}{T_{NB} - T_w} \quad (20)$$

where

$T_{sat}$  = saturation temperature, °F

$P$  = pressure, psi

$\phi_S$  = surface flux, Btu/hr-ft<sup>2</sup>.

Mode 3 -- Nucleate Boiling:  $0 < X < 0.1$

The heat transfer coefficient is calculated by interpolating with respect to quality between Equations (20) and (21).

Mode 4 -- Forced Convection Boiling:  $0.1 < X < 0.6$   
Schrock and Grossman correlation with Wright constants [7]

$$h = 6700 \left[ \frac{\phi_S}{GH_{fg}} + 0.00035 \left\{ \left( \frac{X}{1-X} \right)^{0.9} \left( \frac{\rho_f}{\rho_g} \right)^{0.5} \left( \frac{\mu_g}{\mu_f} \right)^{0.1} \right\}^{0.66} \right] \left[ \left( \frac{0.023k_f}{D} \right) \left( \frac{DG(1-X)}{\mu_f} \right)^{0.8} \left( Pr \right)^{0.4} \right] \quad (21)$$

The physical properties are evaluated at saturation conditions where

$H_{fg}$  = heat of vaporization, Btu/lb

$\rho$  = density, lb/ft<sup>3</sup>

$k$  = thermal conductivity, Btu/hr-ft-°F.

Mode 5 -- Forced Convection Boiling:  $0.6 < X \leq 1.0$

The heat transfer coefficient is calculated by interpolating with respect to quality between Equations (21) and (22).

Mode 6 -- Single Phase Steam:  $X \geq 1.0$   
Dittus-Boelter correlation [8]

$$h = 0.023 \frac{k_g}{D} \left( \frac{DG}{\mu_g} \right)^{0.8} \left( Pr_g \right)^{0.4} \quad (22)$$

Physical properties are evaluated at  $\frac{T_W + T_S}{2}$ .

Mode 7 -- Stable Film Boiling:  $\phi_S$  has exceeded the critical heat flux.  
Dougall-Rohsenow correlation [9]

$$h = 0.023 \frac{k_g}{D} \left[ \left( \frac{DG}{\mu_g} \right) \left( \frac{\rho_g}{\rho_f} (1-X) + X \right) \right]^{0.8} \left[ Pr_g \right]^{0.4} \quad (23)$$

The physical properties are evaluated at saturation conditions. If  $X \leq 0.0$ , the term  $\left[ \frac{\rho_g}{\rho_f} (1-X) + X \right]$  is set equal to 1.0, which reduces Equation (23) to Equation (22).

## 7. CRITICAL HEAT FLUX

The choice of a correlation for predicting the critical heat flux depends upon the pressure and mass flux. If the surface flux exceeds the predicted critical heat flux, stable film boiling is assumed to occur. The critical heat flux correlations and the conditions under which they are used are as follows:

Range 1 --  $P < 725$  psi: Modified Barnett correlation[a]

$$\frac{\phi_{CHF}}{10^6} = \frac{B + E (H_f - H_{in})}{F + L} \quad (24)$$

where

$$B = [73.71 D_{HE}^{0.0523} G'^{0.663} (1.0 - 0.315e^{-11.34D_{HY}G'}) 888.6] [H_{fg}]^{-1} \quad (25)$$

$$E = 0.104 D_{HE}^{1.445} G'^{0.691} \quad (26)$$

and

$$F = 45.55 D_{HY}^{0.0817} G'^{0.587} \quad (27)$$

$P$  = pressure, psi

$\phi_{CHF}$  = critical heat flux, Btu/hr-ft<sup>2</sup>

$H_f$  = saturated liquid enthalpy, Btu/lb

$H_{in}$  = inlet enthalpy, Btu/lb

$L$  = channel length, in.

$D_{HE}$  = heated equivalent diameter, in.

$G'$  = mass flux, 10<sup>6</sup> lb/hr-ft<sup>2</sup>

$D_{HY}$  =  $[D_r(D_r + D_{HE})]^{1/2} - D_r$ , in. ( $D_r$  = pin diameter)

$H_{fg}$  = heat of vaporization, Btu/lb

Range 2 --  $725$  psi  $< P < 1000$  psi

The critical heat flux is calculated by linear interpolation with respect to pressure between Equations (24) and (28).

Range 3 --  $1000$  psi  $< P < 1500$  psi: Barnett correlation[10]

$$\frac{\phi_{CHF}}{10^6} = \frac{J + M (H_f - H_{in})}{R + L} \quad (28)$$

---

[a] New constants were derived for the Barnett[10] correlation for low pressure rod bundle data by Idaho Nuclear Corporation.

where

$$J = 67.45 D_{HE}^{0.68} (G')^{0.192} \cdot [1.0 - 0.744 \exp(-6.512 D_{HY} \cdot G')] \quad (29)$$

$$M = 0.2587 D_{HE}^{1.261} (G')^{0.817} \quad (30)$$

$$R = 185.0 D_{HY}^{1.415} (G')^{0.212} \quad (31)$$

Range 4 -- 1500 psi < P < 1800 psi

The critical heat flux is calculated by linear interpolation with respect to pressure between Equations (28) and (32).

Range 5 -- P ≥ 1800 psi, G > 0.5 x 10<sup>6</sup> lb/hr-ft<sup>2</sup>  
B&W-2 correlation[11]

$$\phi_{CHF} = \frac{S[3.702 \times 10^7 W^Z - 0.15208 G H_{fg} X]}{12.71 Y^N} \quad (32)$$

where

$$S = [1.15509 - 0.40703 D_{HY}] \quad (33)$$

$$W = (5.9137 \times 10^{-7} G) \quad (34)$$

$$Z = [0.8304 + 6.8479 \times 10^{-4} (P - 2000)] \quad (35)$$

$$Y = (3.0545 \times 10^{-6} G) \quad (36)$$

and

$$N = [0.71186 + 0.00020729 (P - 2000)] \quad (37)$$

where

G = mass flux, lb/hr-ft<sup>2</sup>

X = quality.

Range 6 -- P ≥ 1800 psi: G ≤ 0.5 x 10<sup>6</sup> lb/hr-ft<sup>2</sup>

The critical heat flux is calculated by using the average value between Equations (28) and (32).

The inlet enthalpy used in the critical heat flux correlations is dependent on the flow direction and is determined in the following manner.

| <u>Flow at Normal Inlet</u> | <u>Flow at Normal Outlet</u> | <u>H<sub>in</sub></u> |
|-----------------------------|------------------------------|-----------------------|
| > 0                         | ≥ 0                          | H at normal inlet     |
| ≤ 0                         | ≤ 0                          | H at normal outlet    |
| All other cases             |                              | H of core volume      |

## 8. POWER GENERATION

Power generation is determined by either a reactor kinetics calculation or by a tabular input of power versus time. The reactor kinetics equations are solved by a method similar to that used in the IREKIN program [12]. The standard reactor kinetics equations are

$$\frac{dn}{dt} = \frac{\beta}{\Lambda} [(\rho/\beta) - 1] n + \sum_{i=1}^6 \lambda_i C_i + S \quad (38)$$

$$\frac{dC_i}{dt} + \lambda_i C_i = \frac{\beta_i}{\Lambda} n, \quad i=1, 2 \dots 6 \quad (39)$$

$$\beta = \sum_{i=1}^6 \beta_i \quad (40)$$

where

$n$  = reactor fission power

$\beta$  = effective delayed neutron fraction

$\Lambda$  = neutron generation time

$\rho$  = reactivity

$\lambda_i$  = decay constant of delayed neutron group  $i$

$C_i$  = concentration of delayed neutron group  $i$

$S$  = neutron source

$\beta_i$  = effective fraction for delayed neutron group  $i$ .

Also included as an option in the reactor kinetics subroutine are 11 groups of radioactive gamma heat sources:

$$\frac{d\gamma_j}{dt} + \lambda_j \gamma_j = E_j n, \quad j=1, 2, \dots 11 \quad (41)$$

where

$\gamma_j$  = concentration of delayed gamma group  $j$

$\lambda_j$  = decay constant of delayed gamma group  $j$

$E_j$  = yield fraction of delayed gamma group  $j$ .

The total power is a sum of the direct fission power and the instantaneous gamma heating. All power is assumed to be generated in the fuel elements, direct gamma heating of the coolant not being considered. The inclusion of the gamma terms gives a more realistic shutdown transient. The total power, P, is

$$P = n E_f + \sum_{j=1}^{11} \lambda_j \gamma_j \quad (42)$$

where

$E_f$  = fraction of power produced in steady state by fission

If the gamma heating option is not used, then  $E_f = 1$ ; otherwise,  $E_f = 0.93$  and  $\sum E_j = 0.07$ .

## 9. REACTIVITY

As input to the reactor kinetics calculations, reactivity is developed explicitly as a known function of time and implicitly through core feedback mechanisms. The explicit input reactivity is calculated from a table of  $\rho/\beta$  versus time, and feedback reactivity is determined from coolant density, coolant temperature, and fuel temperature for each reactor volume.

The void reactivity is calculated by density changes in the coolant:

$$(\rho/\beta)_v = \sum_i 100\alpha_{vi} \left( 1 - \frac{\rho_i}{\rho_{i0}} \right) \quad (43)$$

where

$(\rho/\beta)_v$  = void reactivity

$\alpha_{vi}$  = void reactivity coefficient of core region i

$\rho_i$  = coolant density in core region i

$\rho_{i0}$  = initial coolant density in core region i.

Likewise, the temperature-dependent reactivities are

$$(\rho/\beta)_{WT} = \sum_i \alpha_{WT_i} \Delta T_{bc_i} \quad (44)$$

$$(\rho/\beta)_{FT} = \sum_i \alpha_{FT_i} \Delta T_{f_i} \quad (45)$$

$$(\rho/\beta)_{DOP} = \sum_i \beta_{DOP_i} f(\alpha_{DOP}, \Delta T_{f_i}) \quad (46)$$

where

$(\rho/\beta)_{WT}$  = coolant temperature reactivity

$\alpha_{WT_i}$  = coolant temperature reactivity coefficient of core region i

$\Delta T_{hc_i}$  = change in bulk coolant temperature in core region i

$(\rho/\beta)_{FT}$  = fuel element temperature reactivity

$\alpha_{FT_i}$  = fuel element temperature reactivity coefficient of core region i

$\Delta T_{f_i}$  = change in fuel element temperature in core region i

$(\rho/\beta)_{DOP}$  = Doppler reactivity

$\beta_{DOP_i}$  = weighting factor of core region i for Doppler reactivity

$f(\alpha_{DOP}, \Delta T_{f_i})$  = Doppler function, input tables.

A total reactivity is obtained by summing the contributions from control rods, water void, water temperature, fuel temperature, and Doppler effects. This total reactivity is adjusted by an additive constant which yields the desired time step zero reactivity.

## 10. TWO-PHASE SEPARATION MODEL

The two-phase separation model used in RELAP3 is a semiempirical fit to a number of experimental, high pressure blowdowns [13].

The quantities necessary to describe the separation of steam bubbles into a gas dome are the partial density of the bubbles and the local bubble velocity at the steam-dome mixture interface. Physically, during a continuous decompression of a large stagnant volume, the density of bubbles is expected to be least near the bottom of the volume. This distribution is reasonable because the static pressure will be highest near the bottom and because the bubbles tend to accumulate as they rise through the mixture. The first order

approximation is one in which the density of bubbles increases linearly as a function of height within the two-phase mixture. A limitation of this model is the inability to describe bubble distributions when physical conditions, such as oscillating pressure or an oscillating flow, would be expected to lead to a complicated situation.

The assumed bubble distribution is

$$\rho_{gb} = m \frac{z}{Z_m} + b \quad (47)$$

where

$\rho_{gb}$  = partial steam density within the mixture

$m, b$  = time-dependent slope and intercept

$z$  = height above the bottom of the volume

$Z_m$  = time-dependent height of mixture interface.

The slope and intercept of the assumed bubble distributions are evaluated by applying conservation of mass. Integrating the partial bubble density over the volume of the mixture gives the instantaneous mass of steam within the mixture. For an average void fraction less than 0.5, that is

$$0 \leq \frac{M_{gb}}{\rho_g V_m} \leq \frac{1}{2} \quad (48)$$

where

$M_{gb}$  = mass of steam entrained in the mixture

$\rho_g$  = density of saturated steam

$V_m$  = volume of the mixture,

the slope and intercept are

$$m = 2C_o \frac{M_{gb}}{V_m} \quad (49)$$

$$b = (1-C_o) \frac{M_{gb}}{V_m} \quad (50)$$

For average void fractions between 0.5 and 1,

$$\frac{1}{2} \leq \frac{M_{gb}}{\rho_g V_m} \leq 1, \quad (51)$$



the slope and intercept are

$$m = 2C_o \left( \rho_g - \frac{M_{gb}}{V_m} \right) \quad (52)$$

$$b = (1+C_o) \frac{M_{gb}}{V_m} - C_o \rho_g \quad (53)$$

To generalize this model, an arbitrary constant,  $C_o$ , is included. This constant (which must be limited to values between zero and one) determines the maximum bubble gradient at any instant. If the constant is chosen as zero, the mixture is homogeneous; if chosen as one, the bubble gradient is always maximum within the permissible physical constraints. Values outside this range may give negative values for the partial bubble density and so are not allowed. Within RELAP3, each volume can have an individual  $C_o$  chosen by the user. Small volumes with high mass flux such as core channels or pipe sections are best described by a homogeneous model where  $C_o = 0$ . In plenums and tanks where the homogeneous model is not desirable, a value of  $C_o = 0.8$  is recommended. This value was determined as a best choice for a one-volume description of experimental vessel blowdowns [14].

The velocity of steam bubbles relative to the mixture interface is another input quantity which can be different for each volume. In the preceding referenced model test, a value of three feet per second was used. If the velocity is zero, no separation occurs although a bubble density gradient may still exist.

By using Equation (47), the local fluid quality is determined for each junction at its connection to a volume. The partial steam density at the surface of the mixture (needed to calculate the rate at which bubbles cross the interface) is also obtained from Equation (47).

To determine the mass and quality of the mixture, a balance for the entrained steam must be performed. Steam can be added to a volume either through a junction or by flashing of liquid within the mixture.

The differential equation describing the bubble mass balance within a given volume is

$$\frac{dM_{gb}}{dt} = \frac{dM_s}{dt} - \sum \psi_i X_i W_i - A v_{bub} \rho_{gb} \Big|_{Z_m} \quad (54)$$

where

$M_{gb}$  = mass of steam (gas bubbles) entrained in the mixture

$M_s$  = total mass of steam within the volume

$\psi_i$  = fraction of steam flowing at the junction and originating within the steam dome

$X_i$  = quality of junction flow

- $W_i$  = flow into or out of the volume at junction i  
 $A$  = cross-sectional area of the volume  
 $v_{\text{bub}}$  = bubble velocity at mixture surface  
 $\rho_{\text{gb}}|_{Z_m}$  = gas bubble density at the mixture surface.

## 11. JUNCTION QUALITIES

Since junctions at control volume boundaries are treated as points rather than distributed areas (so far as fluid properties within the volume are concerned), qualities at these points can oscillate between zero and one. Also, when junctions are near the top or the bottom of a volume, more gas or liquid can be extracted than really exists within the volume. If during a blowdown, the mixture level falls to a junction, then during one time step the flow will be two phase and then change to pure steam the following time step. Under these conditions the flow can be large enough to extract more steam than is physically present. To eliminate these difficulties, the flow during any single time step is assumed to be composed of a combination of steam and mixture when the mixture level is adjacent to the junction location. This modification smooths the time step variation of junction quality and virtually eliminates the time step size instability associated with oscillating mixture levels.

## 12. FILL SYSTEMS

Water may be injected into any volume by means of fill junctions. The junction flows are obtained by interpolating tabular input of flow versus either time or pressure. Several fill junctions may connect to the same volume if desired. Initiation of flow through fill junctions may be controlled by many different trip signals. No cut-off is allowed except implicitly through the flow versus time table.

## 13. SYSTEM BALANCES

An overall mass balance is performed:

$$M_B = \sum_i M_i + \int \sum_j W_j dt - \int \sum_k W_k dt \quad (55)$$

where

$M_B$  = mass balance

$M_i$  = mass in volume i

$W_j$  = flow in leak junction j

$W_k$  = flow in fill junction k.

Energy within the system described by RELAP3 can be stored, injected, or removed by several mechanisms. In general, the total energy at any time within the reactor system is

$$E_T = E_f + \sum E_i \quad (56)$$

where

$E_T$  = total energy stored

$E_f$  = energy stored within fuel elements

$E_i$  = internal energy of water in volume i.

The energy stored within the fuel elements is

$$E_f = \sum_m \left[ \sum_n (\rho V)_n C_n T_n \right]_m \quad (57)$$

where

m = core region number

n = node number

$\rho$  = density

V = node volume

C = specific heat capacity

T = temperature.

Energy can be extracted from the system through leaks or heat exchangers, respectively, as

$$E_l = \int_0^t \sum_j W_j h_j dt \quad (58)$$

and

$$E_{HE} = \int_0^t \sum_m Q_{HE_m} dt \quad (59)$$

where

$E_{\ell}$  = energy lost through leakage

$W_j$  = flow through leak j

$h_j$  = enthalpy of fluid flowing through leak j

$E_{HE}$  = heat removed by heat exchangers

$Q_{HE_m}$  = rate of heat loss through heat exchanger n.

Energy can be added to the system by the reactor power and the fill water injection, respectively, as

$$E_{RP} = \int_0^t \sum_m Q_{RP_m} dt \quad (60)$$

and

$$E_F = \int_0^t \sum_k W_k h_k dt \quad (61)$$

where

$E_{RP}$  = heat added through nuclear fission

$Q_{RP_m}$  = rate of heat addition in core region m

$E_f$  = heat added through fill water injection

$W_k$  = flow through fill junction k

$h_k$  = enthalpy of fluid flowing through fill k.

Applying the conservation of energy principle to the system gives

$$E_{\text{initial}} = E_{\text{stored}} + E_{\text{extracted}} - E_{\text{injected}} \quad (62)$$

or

$$\text{Energy Balance} = \sum E_i + E_f + E_{\ell} + E_{HE} - E_{RP} - E_F \quad (63)$$

This energy balance is computed and available in the minor edit list. The first time step edit gives the initial energy inventory because the time integral terms are zero.

#### 14. CHECK VALVES

Check valves may be placed, at the users option, in any RELAP3 junction. Three pressure loss coefficients,  $C_i$ , and the back pressure to close

the valve,  $P_{cv}$ , are user supplied input constants. The user also has a choice of valve type; Type 1 without a hysteresis loop in the characteristic flow versus pressure curve and Type 2 with the hysteresis loop. The characteristic curves for these two types are shown in Figure 5.

Both types of check valves are controlled by flow dependent pressure losses of the form  $C_1 W |W| / \rho$ .

Three regions of operation are defined for each valve:

- (1)  $C_1$  is used for positive flow with the valve open
- (2)  $C_2$  is used for negative flow with the valve open
- (3)  $C_3$  is used for negative flow with the valve almost closed.

For all positive flow, the valve remains open and sustains a pressure loss proportional to  $C_1$ . For negative flow, the valve remains open if the pressure loss, which is proportional to  $C_2$ , is less than the back pressure required to close the valve.

After the valve closes, the pressure loss is proportional to  $C_3$  for small leakage flows. The hysteresis difference between Type 1 and Type 2 check valves is apparent in Figure 5. Type 1 check valves open in exactly the reverse procedure of the closing sequence. A Type 1 valve opens when negative flow has decreased to a value such that the pressure loss for the open phase is less than the loss required to keep the valve closed. A Type 2 valve reopens only when the pressure loss developed in the closed position is less than the required back pressure.




FIG. 5 CHECK VALVE CHARACTERISTIC CURVES.

#### IV. REFERENCES

1. K. V. Moore and W. H. Rettig, RELAP2 -- A Digital Program for Reactor Blowdown and Power Excursion Analysis, IDO-17263 (March 1968).
2. C. A. Meyer et al, 1967 ASME Steam Tables -- Thermodynamic and Transport Properties of Steam, New York: The American Society of Mechanical Engineers, 1967.
3. F. J. Moody, "Maximum Flow Rate of a Single Component, Two-Phase Mixture", J. Heat Trans. - Trans. ASME, 87 n 1 (February 1965) pp 134-142.
4. R. J. Wagner, HEAT 1 -- A One-Dimensional Time Dependent or Steady State Head Conduction Code for the IBM-650, IDO-16867 (April 1963).
5. E. N. Sieder and G. E. Tate, "Heat Transfer and Pressure Drop of Liquids in Tubes", Indus. and Eng. Chem., 28 n 12 (December 1936) pp 1429-1435.
6. J. R. S. Thom et al, "Boiling in Sub-Cooled Water During Flow Up Heated Tubes or Annuli", Proc. Instn. Mech. Engrs., Vol. 180, pt 3c (1965-66) pp 226-246.
7. V. E. Schrock and L. M. Grossman, Forced Convection Boiling Studies, Final Report on Forced Convection Vaporization Project, TID-14632 (1959).
8. F. W. Dittus and L. M. K. Boelter, "Heat Transfer in Automobile Radiators of the Tubular Type", Univ. Calif. -- Publ. in Eng., 2 n 13 (1930) pp 443-461.
9. R. S. Dougall and W. M. Rohsenow, Film Boiling on the Inside of Vertical Tubes with Upward Flow of the Fluid at Low Qualities, MIT-TR-9079-26 (1963).
10. P. G. Barnett, A Correlation of Burnout Data for Uniformly Heated Annuli and its Use for Predicting Burnout in Uniformly Heated Rod Bundles, AEEW-R-463, (1966).
11. J. S. Gellerstedt et al, "Correlation of Critical Heat Flux in a Bundle Cooled by Pressurized Water", Two-Phase Flow and Heat Transfer in Rod Bundles, Presented at the Winter Annual Meeting of ASME, Los Angeles, California (November 18, 1969) pp 63-71.
12. R. J. Wagner, IREKIN -- Program for the Numerical Solution of the Reactor Kinetics Equations, IDO-17114 (January 1966).
13. H. D. Curet, "Experimental Blowdown Phenomena Applicable to Pressurized-Water Reactor Systems", ANS Trans., 9 n 2 (1966) pp 560-561.
14. K. V. Moore and R. P. Rose, "Application of a Lumped Parameter Bubble-Rise Model to Coolant Blowdown Analysis", ANS Trans., 9 n 2 (1966) pp 559-560.

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

**APPENDIX A**

**APPROXIMATIONS TO THE CONSERVATION EQUATIONS**



THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

## APPENDIX A

### APPROXIMATIONS TO THE CONSERVATION EQUATIONS

The following brief description of the fluid equations used in RELAP3 is based upon the fundamental mass, energy, and momentum conservation equations [a].

These equations are

(a) Mass conservation

$$\frac{\partial \rho}{\partial t} = - \vec{\nabla} \cdot (\rho \vec{v}) \quad (\text{A-1})$$

where

$\rho$  = fluid density

and

$\vec{v}$  = local fluid velocity.

(b) Energy conservation

$$\frac{\partial (\rho e)}{\partial t} = - \vec{\nabla} \cdot (\rho e \vec{v}) - \vec{\nabla} \cdot \vec{q} - \vec{\nabla} \cdot (p \vec{v}) - \vec{\nabla} \cdot (\vec{\tau} \cdot \vec{v}) \quad (\text{A-2})$$

where

$$e = u + \frac{v^2}{2} + \phi$$

$e$  = total specific energy

$q$  = heat flux

$p$  = pressure

$\tau$  = viscous stress tensor

$u$  = thermodynamic internal energy

$\phi$  = potential energy function.

(c) Momentum conservation

$$\frac{\partial \rho \vec{v}}{\partial t} = - \vec{\nabla} \cdot (\rho \vec{v} \vec{v}) - \vec{\nabla} p - \vec{\nabla} \cdot \vec{\tau} + \rho \vec{g} \quad (\text{A-3})$$

where

$g$  = gravitational acceleration constant.

General assumptions include

(a) Stationary control volumes

---

[a] Several excellent references are available on thermal hydraulics; one being by R. B. Bird, W.E. Stewart, and E.N. Lightfoot, Transport Phenomena, John Wiley and Sons, Inc., New York, 1960.

- (b) Axisymmetric, one-dimensional flow
- (c) Negligible body forces (except gravity).

Integrating the mass equation over a fixed volume and applying the "Gauss Divergence Theorem" gives

$$\frac{d}{dt} \int_V \rho dv = - \int_{\delta} \rho \vec{v} \cdot d\vec{\delta} \quad (\text{A-4})$$

$$\frac{dM_i}{dt} = \sum W_{ij} \quad (\text{A-5})$$

where

$M_i$  = total mass in volume  $i$

and

$W_{ij}$  = mass flow rate into volume  $i$  through junction  $j$  (surface area  $j$ ).

For the energy equation, frictional, kinetic, and potential energy effects are assumed negligible.

Then using

$$\frac{\partial \rho u}{\partial t} = - \vec{\nabla} \cdot (\rho h \vec{v} - \vec{q}) \quad (\text{A-6})$$

where

$h$  = enthalpy

and integrating over volume  $v_i$  gives

$$\frac{dU_i}{dt} = \sum W_{ij} h_{ij} + Q_i \quad (\text{A-7})$$

where

$U_i$  = thermodynamic energy in volume  $v_i$

$h_{ij}$  = enthalpy content of fluid moving through junction  $j$

$Q_i$  = rate of energy transferred through surface  $\delta_i$ .

Restricting the momentum equation to one-dimensional flow and integrating over  $v_i$  gives

$$\frac{d}{dt} \int_{v_i} \rho \vec{v} dv = - \int_{\delta_i} \vec{\nabla} (\rho \vec{v} \cdot d\vec{\delta}) - \int_{\delta_i} \vec{\tau} \cdot d\vec{\delta} - \int_{\delta_i} p d\vec{\delta} + \int \rho \vec{g} dv \quad (\text{A-8})$$

For the friction term, the pressure losses are assumed proportional to  $v^2$ . If the volume  $v_1$  is a simple tube with no area changes, then in English units

$$\frac{1}{144g_c} \frac{l_i}{A_i} \frac{d\bar{W}_i}{dt} = - \frac{k \bar{W}_i |\bar{W}_i|}{\rho_i} + P_{ij} - P_{ik} + (\Delta\rho_j)(\Delta z_j) \quad (A-9)$$

where

$g_c$  = gravitational conversion constant

$l_i$  = length of pipe

$A_i$  = pipe cross-sectional area

$W_i$  = average flow

$k_i$  = RELAP3 friction coefficient

$P_{ij}$  = inlet pressure

$P_{ik}$  = outlet pressure

$\Delta\rho_j$  = density change across junction j

$\Delta z_j$  = elevation change between centers of mass across junction j.

For a straight section of pipe, the friction term  $k$  is directly related to the Fanning friction factor for a single pipe:

$$k = \frac{fA_w}{2(144g_c)A} \quad (\text{single pipe}) \quad (A-10)$$

where

$f$  = Fanning friction factor

$A_w$  = wetted wall area

$A$  = cross-sectional area for flow.

For a single flow path with several area changes, the ratio of control volume length to flow area is

$$\frac{l}{A} = \sum_{i=1}^N \frac{l_i}{A_i} \quad (A-11)$$

and momentum flux terms are included as a part of the friction term  $k$ . This last simplification is correct only when the flow is unidirectional during the transient. In complex loop systems, the best way to define  $k$  is from a steady state condition in which

$$k_i = \frac{[P_{ik} - P_{ij} - (\Delta\rho_j)(\Delta z_j)]\rho_i}{W_i^2} \quad (A-12)$$

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

**APPENDIX B**

**CHOICE OF TIME STEP SIZE**

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

## APPENDIX B

### CHOICE OF TIME STEP SIZE

The numerical advancement technique used in RELAP3 is a forward finite difference approximation with each conservation equation advanced independently for a small time step  $\Delta t$ . Since the same time step is used for all volumes and junctions, the overall stability of the solution is controlled by the most sensitive portion of the system.

For an isolated volume and junction the Helmholtz frequency  $f$  is

$$f = \frac{\omega}{2\pi} = \frac{a}{2\pi} \sqrt{\frac{A}{V\ell}} \quad (\text{B-1})$$

where

$\omega$  = angular velocity

$a$  = velocity of sound

$V$  = volume of fluid

$\ell/A$  = path "inertia"

The time step size must be smaller than the natural oscillation period, preferably by at least a factor of 5 to 10. When the time step size approaches the natural period, numeric instabilities can result. Thus, an appropriate time step is

$$\Delta t = \frac{2\pi}{na} \sqrt{V\ell/A} \quad (\text{B-2})$$

where

$$n = 5 \text{ to } 10.$$

These values of  $\Delta t$  are only approximate and could be slightly larger in some cases. These relations show that the small volumes and inertias control the choice of time steps. If a single vessel with a total volume  $V_T$ , length  $\ell_T$ , and cross section  $A$  (where  $V_T = \ell_T A$ ) is divided into  $m$  equal subvolumes, the time step size becomes

$$\Delta t \approx \left(\frac{2\pi}{na}\right) \frac{\ell_T}{m} \quad (\text{B-3})$$

The computer time required goes up as the square of the number of volumes in this example of equal subvolumes because the number of time steps and the number of volumes increase.

Other types of numeric instability due to mass and energy flow are possible, but normally the frequencies associated with these instabilities are lower than the Helmholtz frequencies. Under certain conditions of extremely high flow, small mass content, or small energy content within a volume, the fluid within a large time step can be completely replaced. Time steps for mass and energy should be chosen such that

$$\Delta t_m < \frac{M}{\sum |W|} \quad (\text{B-4})$$



$$\Delta t_u < \frac{U}{\sum |Wh|}$$

where

W = flow

M = mass in volume

h = enthalpy

U = total internal energy of volume.

Nonlinearities, especially the rapid change in density that can occur at junctions, present instability problems. Since previous values of density are used to advance the equations, the possibility exists of exhausting a volume of all material near the end of a blowdown transient. The reverse problem of over-filling a volume and drastically increasing the pressure is also possible.

Currently the only method of verifying solution accuracy is to rerun the problem with smaller time steps. Numerical variations in solutions with different time steps will exist, but are generally negligible. Results of a RELAP3 calculation are dependent upon the computer word length. Single precision on the IBM 360 is not recommended except for problems involving very few time advancements (~ 1000). The EBCDIC punched source deck for the IBM 360 uses double precision (64 bit words) to avoid excessive roundoff.

Different computers and different time step sizes also affect the solution when control parameters are reached asymptotically. For example, blowdown problems are normally terminated at a chosen pressure, but since final pressures are usually approached asymptotically, the computer time and the number of total time advancements may show significant variation. From an engineering viewpoint these variations are considered negligible.

**APPENDIX C**

**INPUT DEFINITIONS**

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

## APPENDIX C

### INPUT DEFINITIONS

#### CONTROL CARDS FOR THE NRTS SYSTEM

(1) // JOB

This card contains accounting information.

(2) //XQT EXEC RELAP3, options

The options are given in any order by using keywords. No blanks are allowed except after a comma on a card to be continued or after all wanted options have been selected. The keywords used and the choices to be made are

XTIME = the CPU time in minutes (10 seconds, if omitted).

PAGES = the approximate number of full pages to be printed (20, if omitted).

TPOUT = \_\_\_\_\_ The data set name should include the user's initials  
(data set  
name  
out)

plus a maximum of five alphanumeric characters but no blanks. Big OS will tell which tape is saved. If TPOUT is omitted, the default is NULLFILE. In this case, calls to the tape writing routines internal to RELAP3 will be satisfied, but no output tape will be created.

TPIN = \_\_\_\_\_ This data setname must be one used on a previous  
(data set  
name  
in)

TPOUT option. If TPIN is omitted, the default is NULLFILE. If TPIN is included, turning in an appropriate LIBRARY VOLUME NEEDED card will help avoid excessive wait time.

SER = T9XXXX, where XXXX is the serial number of the tape corresponding to TPIN.

(3) //X.SYSIN DD \*

This card may be omitted without causing difficulties

(4) (following all data)/\*

This card is one of the pink terminator cards.

## RELAP3 INPUT DEFINITIONS

(1) Title (one card)

FORMAT: 18A4,2A4

At least one nonblank character must appear somewhere in columns 1-72.

(2) Problem Dimensions (one card)

FORMAT: 15I3,E10.6,17X,2A4

|     |       |   |   |
|-----|-------|---|---|
| N1  | LDMP  | = | Tape control (only one tape may be generated during a job)<br>( 0 = no tape used)<br>(-1 = store restart information on FORTRAN Unit 4)<br>(-2 = store restart and plot information on FORTRAN Unit 4)<br>(-3 = edit the tape on FORTRAN Unit 3)<br>( N = restart at page number N using the tape on FORTRAN Unit 3)<br>(-3 ≤ LDMP ≤ 999) |
| N2  | NEDI  | = | Number of minor edit variables desired<br>(0 ≤ NEDI ≤ 9)  |
| N3  | NTC   | = | Time step card count<br>(1 ≤ NTC ≤ 20)  |
| N4  | NTR   | = | Number of trip control cards<br>(1 ≤ NTR ≤ 20)  |
| N5  | NVOL  | = | Number of control volumes<br>(1 ≤ NVOL ≤ 20)  |
| N6  | NBUB  | = | Number of bubble parameter sets. A set may be used in several volumes<br>(0 ≤ NBUB ≤ 5)   |
| N7  | NJUN  | = | Number of junctions or flow paths<br>(1 ≤ NJUN ≤ 50)  |
| N8  | NPMPC | = | Pump curve count. A curve may be used for several junctions<br>(0 ≤ NPMPC ≤ 5)  |
| N9  | NCKV  | = | Number of check valve types. A parameter set may be used for several junctions<br>(0 ≤ NCKV ≤ 5)  |
| N10 | NLK   | = | Number of normalized-area vs time curves. May be used many times<br>(0 ≤ NLK ≤ 5)   |
| N11 | NFLL  | = | Number of fill system curves. May be used many times<br>(0 ≤ NFLL ≤ 5)  |
| N12 | NOCOR | = | Number of core regions<br>(0 ≤ NOCOR ≤ 20)  |

N13 NMTL = Number of sets of rod geometry  
 (1 ≤ NMTL ≤ 20) if NOCOR ≥ 1,  
 (0 ≤ NMTL ≤ 20) if NOCOR = 0,

N14 NHTX = Number of heat exchanger data sets  
 (0 ≤ NHTX ≤ 20)

N15 NKC = Number of thermal property tables  
 (NKC ≤ 6)

X1 POWER = Reactor thermal power in megawatts  
 (0. ≤ POWER)

(3) Edit Variable Cards (one card if NEDI > 0)

FORMAT: 9(1X,A2,1X,I2),18X,2A4

|   |    |   |    |   |    |    |    |       |      |         |    |
|---|----|---|----|---|----|----|----|-------|------|---------|----|
| 1 | 2  | 4 | 5  | 7 | 8  | 10 | 11 | 12    | 6I-4 | 6I+1    | 73 |
|   | XI |   | NI |   | X2 |    | N2 | ----- | NI   | -BLANK- | ID |

(I=NEDI, number of minor edit variables desired)

XI = Minor edit variable symbol

NI = Region number of variable desired

Symbols of available minor edit variables

| <u>Symbol</u> | <u>Variable</u> (with reference to volume)                            |
|---------------|---|
| AP            | Average pressure  |
| TM            | Total mass  |
| TE            | Total energy  |
| AT            | Average temperature   |
| AR            | Average density   |
| AH            | Average enthalpy  |
| AX            | Average quality   |
| BM            | Bubble mass   |
| ML            | Mixture level   |
| VF            | Specific volume of fluid  |
| VG            | Specific volume of gas  |
| HF            | Specific enthalpy of fluid  |
| HG            | Specific enthalpy of gas  |
| TS            | Saturation temperature  |
| PS            | Saturation pressure   |
| WM            | Liquid mass<br>(for these variables, NI is volume number 1 ≤ NI ≤ 20) |

| <u>Symbol</u> | <u>Variable</u> (with reference to volumes which are core volumes only)  |
|---------------|--|
| WQ            | Power into coolant   |
| DF            | DNB heat flux  |
| SF            | Surface heat flux  |
| HC            | Surface heat transfer coefficient  |
| FT            | Fuel element temperature   |
| <u>Symbol</u> | <u>Variable</u> (with reference to volumes which are core volumes only)  |
| CT            | Center-line temperature  |
| ST            | Surface temperature  |
| FQ            | Power generated in fuel<br>(for these variables, NI is volume number $1 \leq NI \leq 20$ )                     |
| <u>Symbol</u> | <u>Variable</u> (with reference to junctions)  |
| JW            | Junction flow  |
| JH            | Junction enthalpy  |
| JX            | Junction quality   |
| LF            | Leak force   |
| TD            | Total pressure differential  |
| FD            | Pressure differential due to friction  |
| ED            | Pressure differential due to elevation   |
| PD            | Pressure differential due to pump  |
| AD            | Pressure differential due to acceleration<br>(for these variables, NI is junction number $1 \leq NI \leq 50$ ) |
| <u>Symbol</u> | <u>Variable</u> (with reference to the system)   |
| NQ            | Normalized power   |
| AE            | Total energy added during transient  |
| FE            | Energy stored in fuel  |
| LE            | Total energy leaked  |
| HE            | Energy removed by heat exchanger   |
| EB            | Energy balance term  |
| LM            | Total mass leaked  |
| MB            | Mass balance   |
| TR            | Total reactivity   |
| RV            | Reactivity due to coolant voids  |
| RW            | Reactivity due to temperature changes in coolant   |
| RF            | Reactivity due to temperature changes in fuel  |

RC      Reactivity due to control rod changes  
 RD      Reactivity due to Doppler effect  
 PO      Power  
 HL      Total heat removed  
 RP      Reactor period  
 (these variables are system variables, NI = 0)

ALL THE FOLLOWING CARDS USE THIS FORMAT:      4I3,6E10,6,2A4

|    |    |    |    |    |       |    |    |
|----|----|----|----|----|-------|----|----|
| 1  | 4  | 7  | 10 | 13 | 23    | 63 | 73 |
| N1 | N2 | N3 | N4 | X1 | ..... | X6 | ID |

In all cases ID is any legitimate BCD field (EBCDIC for an IBM 360). If fewer than four integers are required, the remaining integer fields are left blank. If more cards are required to fill the tables, a similar format is used:

|   |   |   |    |    |       |     |    |
|---|---|---|----|----|-------|-----|----|
| 1 | 4 | 7 | 10 | 13 | 23    | 63  | 73 |
|   |   |   |    | X7 | ..... | X12 | ID |

etc

(4) Time Step Cards      (NTC Cards)

N1      Number of time steps per minor edit  
 (0 is interpreted as 1)  
 N2      Number of minor edits per major edit  
 (0 is interpreted as 50)  
 N3      Number of major edits per restart tape edit  
 (0 is interpreted as 20)  
 N4      Number of time steps per plot tape edit  
 (0 is interpreted as N1)  
 X1      DELTM = Time step size (sec)  
 (0 < DELTM)  
 X2      TLAST = End of current time step data (sec)  
 (TLAST<sub>i-1</sub> < TLAST<sub>i</sub>)

(5) Trip Controls      (NTR Cards)

N1      IDTR      =      Action to be taken  
 (1 ≤ IDTR ≤ 10)  
           1 = End of problem)  
           2 = Open leaks  
           3 = Reactor scram and heat exchanger cutoff  
           4 = Trip pumps  
           5 = Start fills  
           6-10 = Open (or close) valves



|    |       |   |   |                    |
|----|-------|---|---|--------------------|
| N2 | IDSIG | = | Signal being compared<br>( $1 \leq   \text{IDSIG}   \leq 9$ )   |                    |
|    |       |   | 1 = Elapsed time  | + = HIGH, - = HIGH |
|    |       |   | 2 = Normalized reactor<br>power   | + = HIGH, - = LOW  |
|    |       |   | 3 = Reactor period  | + = LOW, - = LOW   |
|    |       |   | 4 = Pressure (Vol. N3)  | + = HIGH, - = LOW  |
|    |       |   | 5 = Mixture level (Vol. N3)   | + = HIGH, - = LOW  |
|    |       |   | 6 = Liquid Level (Vol. N3)  | + = HIGH, - = LOW  |
|    |       |   | 7 = Water temperature<br>(Vol. N3)  | + = HIGH, - = LOW  |
|    |       |   | 8 = Metal temperature<br>(Core N3)  | + = HIGH, - = LOW  |
|    |       |   | 9 = Flow (JUNC N3)  | + = HIGH, - = LOW  |
| N3 | IX1   | = | Volume, or Junction Index   |                    |
| N4 | IX2   | = | Optional volume index<br>If $\text{IX2} > 0$ a high $\Delta P$ or $\Delta T$ test is used<br>(for $\text{IDSIG} = 4, -4, 7, -7$ ) |                    |
| X1 | SETPT | = | Signal setpoint   |                    |
| X2 | DELAY | = | Delay time for initiation of action after reaching setpoint.  |                    |

NOTE: On first trip card,  $\text{N1} = \text{N2} = 1$ .

(6) Volume Data

(NVOL cards)

|    |          |   |  |
|----|----------|---|--|
| N1 | IBUB     | = | Bubble data index<br>( $0 \leq \text{IBUB} \leq \text{NBUB}$ )   |
| N2 | IQIN     | = | Heat generation index<br>( $-\text{NHTX} \leq \text{IQIN} \leq \text{NOCOR}$ )   |
|    | IQIN < 0 | = | Heat exchanger region (same index may be repeated if it refers to a time dependent heat exchanger only)  |
|    | IQIN > 0 | = | Core region (same index may not be repeated)   |
| X1 | P        | = | Pressure (psi)<br>( $0.1 \leq P \leq 3206.2$ )   |
| X2 | TEMP     | = | Temperature (or quality of mixture)<br>(°F or dimensionless)<br>( $0. \leq \text{TEMP} \leq 1. \text{ or } 32. \leq \text{TEMP} \leq 5600.$ )  |
| X3 | V        | = | Volume ( $\text{ft}^3$ )<br>( $0. < V$ )   |
| X4 | ZVOL     | = | Volume height, bottom to top (ft)<br>( $0. < \text{ZVOL}$ )  |
| X5 | ZM       | = | Mixture level (from bottom) (ft)<br>( $0. \leq \text{ZM} \leq \text{ZVOL}$ )<br>Liquid phase: $\text{ZM} = 0.$ is interpreted as<br>$\text{ZM} = \text{ZVOL}$<br>Liquid phase: $0. < \text{ZM} < \text{ZVOL}$ implies<br>an air head over the liquid |
| X6 | ELEV     | = | Elevation at the bottom of the volume (ft)   |

(7) Bubble Data (NBUB cards)

X1 ALPH = Bubble gradient parameter  
(0. ≤ ALPH)  
X2 VBUB = Bubble velocity (ft/sec)  
(0. ≤ VBUB)

NOTE: Set number 0  
(ALPHA = 0., VBUB = 0.) is built-in.

(8) Junction Data (NJUN cards)

N1 IW1 = Volume index at junction inlet  
(0 ≤ IW1 ≤ NVOL)  
N2 IW2 = Volume index at junction exit  
(0 ≤ IW2 ≤ NVOL)  
N3 IPUMP = (a) (IW1 > 0, IW2 > 0) Pump Index (0 ≤ IPUMP ≤ NPMPC)  
(b) (IW1 > 0, IW2 ≤ 0) Leak Index (1 ≤ IPUMP ≤ NLK)  
(c) (IW1 ≤ 0, IW2 > 0) Fill Index (1 ≤ IPUMP ≤ NFLL)  
(d) (IW1 ≤ 0, IW2 ≤ 0) 0 (NULL JUNCTION)  
N4 IVALVE = Valve index  
(0 ≤ |IVALVE| ≤ NCKV or 6 ≤ |IVALVE| ≤ 10)  
(a) IVALVE = 0, No valve  
(b) 1 ≤ IVALVE ≤ NCKV, Type 1 check valve  
(c) -NCKV ≤ IVALVE ≤ -1, Type 2 check valve  
(d) 6 ≤ IVALVE ≤ 10, Initially open valve which closes under trip control (IDTRP = IVALVE)  
(e) -10 ≤ IVALVE ≤ -6, Initially closed valve which opens trip control (IDTRP = IVALVE)  
X1 WP = Flow (lb/sec)  
X2 AJUN = Minimum flow area for choked flow calculation (ft<sup>2</sup>)  
(0. ≤ AJUN)  
(a) IW1 > 0, IW2 > 0  
0. implies no restriction  
(b) IW1 > 0, IW2 ≤ 0  
0. is interpreted as 1.  
(c) IW1 ≤ 0, IW2 > 0  
0. is interpreted as 1.  
(d) IW1 ≤ 0, IW2 ≤ 0  
AJUN is ignored  
X3 ZJUN = Junction elevation (ft)  
(a) IW1 > 0, IW2 > 0  
ZJUN must lie between bottom and top of both inlet and exit volumes  
(b) IW1 > 0, IW2 ≤ 0  
ZJUN must lie between bottom and top of inlet volume

(c)  $IW1 \leq 0, IW2 > 0$   
 ZJUN must lie between bottom and top of  
 exit volume

(d)  $IW1 \leq 0, IW2 \leq 0$   
 ZJUN is ignored

X4 INERTA = Junction effective  $L/A$  ( $ft^{-1}$ )  
 ( $0. \leq INERTA$ )  
 (a)  $IW1 > 0, IW2 > 0$   
 INERTA  $> 0$   
 (b)  $IW1 \leq 0$  or  $IW2 \leq 0$   
 INERTA  $\geq 0$

X5 KJUN = Friction coefficient ( $lb_f \cdot sec^2 / lb_m \cdot ft^3 \cdot in.^2$ )  
 ( $0. \leq KJUN$ )  
 (a)  $IW1 > 0, IW2 > 0$   
 KJUN = 0. implies value computed from  
 pressure drop data. Must give positive  
 answer.  
 (b)  $IW1 \leq 0$   
 KJUN ignored beyond this point  
 (c)  $IW2 \leq 0$ . If  $KJUN \leq 0$ , then KJUN is  
 calculated internally from the orifice  
 equation, which is

$$KJUN = \frac{1}{144g_c (2A^2)},$$

where A is the effective leak area,  
 including a contraction coefficient.

(9) Pump Coastdown (one curve if NPMPC  $> 0$ )

N1 NPUCD = Number of data points  
 ( $2 \leq NPUCD \leq 20$ )  
 X1 CAVCON = Cavitation constant  
 X2 Ignored  
 X3 TIME<sub>1</sub> (sec)  
 X4 MULTIPLIER<sub>1</sub>  
 X5 TIME<sub>2</sub>  
 X6 MULTIPLIER<sub>2</sub>  
 X7 TIME<sub>3</sub>  
 X8 MULTIPLIER<sub>3</sub>  
 etc

where TIME<sub>1</sub>  $<$  TIME<sub>2</sub>  $<$  TIME<sub>3</sub>  $<$  ...

(10) Pump Head (NPMPC curves)

|    |       |   |  |
|----|-------|---|--|
| N1 | NPUMP | = | Number of data points<br>( $2 \leq \text{NPUMP} \leq 20$ )   |
| N2 | IX    | = | Flow variable type<br>IX $\leq 0$ flow in pounds per second<br>IX $> 0$ flow in gallons per minute |
| N3 | IY    | = | Head variable type<br>IY $\leq 0$ head in pounds per square inch<br>IY $> 0$ head in feet          |

|    |                   |   |   |
|----|-------------------|---|---|
| X1 | SPUMP             | = | Net positive suction head (ft)  |
| X2 | FPUMP             | = | Shutdown friction coefficient ( $\text{lb}_f\text{-sec}^2/\text{lb}_m\text{-ft}^3\text{-in.}^2$ ) |
| X3 | FLOW <sub>1</sub> |   | lb/sec or gal/min   |
| X4 | HEAD <sub>1</sub> |   | lb/in. <sup>2</sup> or ft   |
| X5 | FLOW <sub>2</sub> |   |   |
| X6 | HEAD <sub>2</sub> |   |   |
|    | etc               |   |   |
|    |                   |   | where FLOW <sub>1</sub> < FLOW <sub>2</sub> < . . .   |

(11) Check Valves (NCKV cards)

|    |     |   |   |
|----|-----|---|---|
| X1 | PCV | = | Back pressure for closure ( $\text{lb}/\text{in.}^2$ )  |
| X2 | CV1 | = | Forward flow friction coefficient ( $\text{lb}_f\text{-sec}^2/\text{lb}_m\text{-ft}^3\text{-in.}^2$ )               |
| X3 | CV2 | = | Reverse flow friction coefficient, valve open ( $\text{lb}_f\text{-sec}^2/\text{lb}_m\text{-ft}^3\text{-in.}^2$ )   |
| X4 | CV3 | = | Reverse flow friction coefficient, valve closed ( $\text{lb}_f\text{-sec}^2/\text{lb}_m\text{-ft}^3\text{-in.}^2$ ) |

(12) Leak Sets (NLK curves)

|    |                   |   |  |
|----|-------------------|---|--|
| N1 | NAREA             | = | Number of data points<br>(2 < NAREA < 20)  |
| N2 | ICHOKE            | = | Leak type<br>ICHOKE ≤ 0, no liquid phase choking<br>ICHOKE > 0, liquid phase choking allowed |
| X1 | SINK              | = | Sink pressure ( $\text{lb}/\text{in.}^2$ )   |
| X2 | CONCO             | = | Contraction coefficient  |
| X3 | TIME <sub>1</sub> |   | (sec)  |
| X4 | AREA <sub>1</sub> |   | (ft <sup>2</sup> , dimensionless if AJUN > 0)  |
| X5 | TIME <sub>2</sub> |   |  |
| X6 | AREA <sub>2</sub> |   |  |
|    | etc               |   |  |

where TIME<sub>1</sub> < TIME<sub>2</sub> < . . .

(13) Fill Sets (NFLL curves)

|    |       |   |   |
|----|-------|---|---|
| N1 | NFILL | = | Number of data points<br>(2 < NFILL < 20)   |
| N2 | IX    |   | Independent variable<br>IX = 0, time<br>IX > 0, pressure ( $P_{\text{vol}} + P_{\text{grav}}$ )<br>IX < 0, differential pressure ( $P_{\text{vol}} + P_{\text{grav}} - P_{\text{fill}}$ ) |

N3 IY = Flow type  
     IY ≤ 0, flow in pounds per second per square foot  
     IY > 0, flow in gallons per minute per square foot  
  
 X1 FILPRS = pressure in fill reservoir  
 X2 FILTEM = Temperature (or quality) in fill reservoir (°F)  
 X3 TIME<sub>1</sub> or PRESSURE<sub>2</sub> (sec or lb/in.<sup>2</sup>)  
 X4 FLOW<sub>1</sub> (lb/sec or gal/min)  
 X5 TIME<sub>2</sub> or PRESSURE<sub>2</sub>  
 X6 FLOW<sub>2</sub>  
     etc  
     where TIME<sub>1</sub> < TIME<sub>2</sub> < . . .  
     or PRESSURE<sub>1</sub> < PRESSURE<sub>2</sub> . . . .

(14) Kinetics Constants (One card if NOCOR > 0)

N1 NODEL = Number of delayed groups  
     NODEL ≤ 0, explicit time-power curve  
     NODEL = 7, one prompt neutron group plus six groups of delayed neutrons  
     NODEL = 18, one prompt neutron group plus six groups of delayed neutrons plus eleven delayed gamma emitters  
  
 X1 BOVL = β/L = Effective delayed neutron fraction over mean lifetime (sec<sup>-1</sup>)  
 X2 RHOIN = Initial reactivity (\$)

(15) Scram Curve (One curve if NOCOR > 0)

N1 NSCR = Number of data points  
     (2 ≤ NSCR ≤ 20)  
  
 X1 TIME<sub>1</sub> (sec)  
 X2 REACTIVITY<sub>1</sub> or NORMALIZED POWER (\$ or dimensionless)  
 X3 TIME<sub>2</sub>  
 X4 REACTIVITY<sub>2</sub> or NORMALIZED POWER  
     etc  
     where TIME<sub>1</sub> < TIME<sub>2</sub> < . . .

(16) Doppler Curve (One curve if NOCOR > 0 and NODEL > 0)

N1 NDOP = Number of data points  
     (2 ≤ NDOP ≤ 20)  
  
 X1 TEMPERATURE<sub>1</sub> (°F)  
 X2 REACTIVITY<sub>1</sub> (\$)

X3 TEMPERATURE<sub>2</sub>

X4 REACTIVITY<sub>2</sub>

etc

where TEMPERATURE<sub>1</sub> < TEMPERATURE<sub>2</sub> < . . .

(17) Reactivity Coefficients (NOCOR cards if NODEL > 0)

X1 ALPHVW = Water void coefficient (\$/%void)

X2 ALPHTW = Water temperature coefficient (\$/°F)

X3 ALPHTM = Metal temperature coefficient (\$/°F)

X4 DOPWT = Doppler weighting fraction

(18) Channel Data (NOCOR cards)

N1 IMTL = Rod geometry index (1 ≤ IMTL ≤ NMTL)

N2 NODT<sub>1</sub>

N3 NODT<sub>2</sub>

N4 NODT<sub>3</sub>

} = Node numbers at which temperatures are to be printed

X1 QFRAC = Fraction of total power generated in core volume

X2 ARHT = Total heat transfer area in core volume (ft<sup>2</sup>)

X3 CHNL = Channel length (ft)

X4 HDIAM = Hydraulic diameter (ft)

X5 HEDIAM = Heated equivalent diameter (ft)

(19) Rod Geometry Constants (NMTL sets)

First card in a set:

N1 NR = Number of regions in rod and number of cards in this set (1 ≤ NR ≤ 6)

N2 IKCW = Thermal property table index for region (1 ≤ IKCW ≤ NKC)

N3 NDRW = Number of space steps in region

X1 DRW = Region space step size (ft)

X2 RHOIW = Region material density (lb/ft<sup>3</sup>)

X3 POFRW = Power fraction for region

Successive cards in the set:

N1 NR = blank or 0

All other fields are the same as in the first card of the set.

For each set, ΣNDRW < 31.

(20) Thermal Property Tables (NKC sets)

One set:

N1 NKP = Number of points in thermal conductivity table  
( $2 \leq \text{NKP} \leq 20$ )

X1 TPK<sub>1</sub> = Temperature<sub>1</sub> (°F)

X2 TPK<sub>2</sub> = Thermal Conductivity<sub>1</sub> (Btu/ft-hr-°F)

X3 TPK<sub>3</sub> = Temperature<sub>2</sub>

X4 TPK<sub>4</sub> = Thermal Conductivity<sub>2</sub>

etc, until NKP points are read,

where Temperature<sub>1</sub> < Temperature<sub>2</sub> < . . .

N1 NCP = Number of points in heat capacity table ( $2 \leq \text{NCP} \leq 20$ )

X1 TPC<sub>1</sub> = Temperature<sub>1</sub> (°F)

X2 TPC<sub>2</sub> = Heat capacity<sub>1</sub> (Btu/lb-°F)

X3 TPC<sub>3</sub> = Temperature<sub>2</sub>

X4 TPC<sub>4</sub> = Heat capacity<sub>2</sub>

etc, until NCP points are read,

where Temperature<sub>1</sub> < Temperature<sub>2</sub> < . . .

(21) Heat Exchanger Data (NHTX sets)

N1 IHTX = Number of data points, 0 meaning flow and temperature dependent.

(IHTX = 0 or  $2 \leq \text{IHTX} \leq 20$ )

(A) IHTX = 0

X1 = Fraction of power removed by heat exchanger

X2 TSEC = Secondary side temperature (°F)

X3 HTXCO = Heat exchanger coefficient (Btu/hr-°F). (Not used if heat exchanger starts with a nonzero flow)

(B) IHTX > 0

X1 TIME<sub>1</sub> (sec)

X2 NORMALIZED POWER<sub>1</sub>

X3 TIME<sub>2</sub>

X4 NORMALIZED POWER<sub>2</sub>

etc

where TIME<sub>1</sub> < TIME<sub>2</sub> < . . .

(22) End Card (1 card, optional)

Columns 1 through 72 blank

Omit this card if another problem follows.



## INPUT FOR RESTARTING

An old restart data tape to be used must be mounted on FORTRAN Unit 3 and a blank tape must be mounted on Unit 4. The normal RELAP3 program is used with the following input definitions.

(1) Title (one card)

FORMAT: 18A4,2A4

The first 12 characters of the new title must be identical to the title of the problem which is to be restarted.

(2) Problem Dimensions (one card)

FORMAT: 15I3,E10.6,17X,2A4

N1 LDMP = N, the page number of the old problem where restart is to begin  
( $1 \leq \text{LDMP} \leq 999$ )

N2 NEDI = Number of minor edit variables  
( $0 \leq \text{NEDI} \leq 9$ )

N3 NTC = Time step card count  
( $1 \leq \text{NTC} \leq 20$ )

N4 NTR = Number of trip control cards  
( $0 \leq \text{NTR} \leq 20$ )  
NTR = 0 will cause the trip control values on the restart tape to be used, assuming chronological consistency.

Columns 13 through 72 are blank.

(3) Edit Variable Cards (one card if NEDI > 0)

The same rules apply as for the original problem. The quantities being edited on the new run need not have any relation to those of the original run.

(4) Time Step Cards (NTC cards)

The same rules apply as for the original problem. The time step sequence on the new run need not have any relation to that of the old run. No cards referring to problem times previous to the point of restart will be used, but they may be inputted.

(5) End Card (one card)

FORMAT: 20A4

Columns 1 through 72 are blank.

This card is omitted if another problem follows. A following problem must not use or generate a tape.

## INPUT FOR TAPE EDITING

An old plot tape must be mounted on FORTRAN Unit 3. The normal RELAP3 program is used with the following input definitions.

(1) Title (one card)

FORMAT: 18A4,2A4

The first 12 characters of the new title must be identical to the title of the problem which is to be edited.

(2) Problem Dimensions (one card)

FORMAT: 15I3,E10.6,17X,2A4

|    |      |   |  |
|----|------|---|--|
| N1 | LDMP | = | -3   |
| N2 | NEDI | = | Number of minor edit variables<br>( $0 \leq \text{NEDI} \leq 9$ )    |
| N3 | NTC  | = | Edit frequency control card count<br>( $1 \leq \text{NTC} \leq 20$ ) |

These are the only control integers required for a tape edit. The others will not be checked because the information will be retrieved from tape.

(3) Edit Variable Cards (one card if NEDI > 0)

The same rules apply as for the original problem. The quantities being edited need not have any relation to those of the original run.

(4) Edit Frequency Control Cards (NTC cards)

FORMAT: 2I3,6X,2E10.6,40X,2A4

|    |   |
|----|---|
| N1 | Number of plot records per minor edit<br>(0 is interpreted as 1)                                |
| N2 | Number of minor edits per major edit<br>(0 is interpreted as 50)                                |
| X1 | DELTM = Time step size (sec)<br>( $0 < \text{DELTM}$ )  |
| X2 | TLAST = End of current edit frequency control data<br>( $\text{TLAST}_{i-1} < \text{TLAST}_i$ ) |

(5) End Card (one card)

FORMAT: 20A4

Columns 1 through 72 are blank.

This card is omitted if another problem follows. A following problem cannot use a different input tape.

**APPENDIX D**


**PROGRAM STRUCTURE**

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

APPENDIX D

PROGRAM STRUCTURE

RELAY3 OVERLAY STRUCTURE





**APPENDIX E**

**SUBROUTINE DESCRIPTIONS**

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK



## APPENDIX E

### SUBROUTINE DESCRIPTIONS

#### BAL

Performs the mass and energy balance for all volumes and then obtains new pressures.

Each junction is examined and then mass and energy contents of the inlet and outlet volumes are advanced. Each volume is tested for direct heat addition or removal, the corresponding energy transfer routines are called, subroutine STATE is entered to obtain a new average pressure, and mixture conditions are then calculated.

#### BUBB

Calculates both the enthalpy and a bubble indicator at the junction height within a volume.

#### BUFIO

Is an NRTS package to allow tape handling in an overlapped mode and with non-FORTRAN records. A FORTRAN routine is available.

#### CCC

Calculates some exponential relationships needed by the reactor kinetics routine (RKEN).

#### CHEK

Positions a plot tape to the first record for the tape edit routine.

#### CHKV

Either generates a friction coefficient for a check valve or controls an on-off valve using TRIP.

#### CHNALF

Replaces the IBM supplied CHAIN routine for the IBM 7044 so that chaining will function as the manual describes.

#### CHNL

Calls the core heat transfer routine (TROD), and calculates the energy in the fuel for a core volume.

#### CINITL

Performs the steady state initialization for all core volumes.

For each core volume water properties are found. With this information and the steady state heat fluxes, HTRZ and TEMZ are called to obtain the initial surface heat transfer coefficient and the initial radial temperature distribution.

### DATA

Is a block data subroutine containing thermodynamic properties at saturation and the steam tables.

### DATB

Is a block data subroutine containing the leak tables.

### DATC

Is a block data subroutine containing physical properties at saturation, RELAP3 array limits, and miscellaneous numerical constants.

### EDCOM

Reads from the plot tape the integers which are needed for the tape edit routine.

### EDDAT

Reads a plot record from tape for the tape edit routine.

### EDEDIT

Formats and prints output in the tape edit routine.

### EDINED

Reads an edit control card for the tape edit routine.

### EDIT

Will, as required by the time step cards, list a few variables frequently, a complete edit less frequently, and call PLTAPE to save data.

### FAIL

Sets a flag to indicate the calculation has failed.

### FILL

Provides the junction flow and enthalpy for a fill system type of junction.

### FLOSRRH

Performs the junction flow calculation.

Inlet pressure, output pressure, junction water properties, pump head, and check valve friction factor are obtained. Inertial and choked flow routines (FLOW and LEAK) are called and a choice made between these two flows. For a fill system a special routine (FILL) is invoked.

### FLOW

Performs the inertial flow iteration for a junction.

### HEADC

Calculates all junction gravity heads by assuming that the volume pressure obtained from thermodynamic relationships occurs at the center of gravity.

### HTRC

Calculates critical heat flux, heat transfer mode, and heat transfer coefficient at the fuel pin surface.

### HTXQ

Calculates the energy removed by a heat exchanger, allowing a choice between a flow-temperature dependence or an input curve of removal rate versus time.

### INBUBL

Processes bubble data cards.

### INCKV

Processes check valve data cards.

### INCNL

Processes channel heat transfer cards.

### INCORE

Calls, in succession, the reactor kinetics input (IREKIN), the core heat transfer input (INCNL and INRØD), steady state core heat transfer initialization (CINITL), and reactor kinetics initialization (KINITL).

### INEDIT

Processes a card describing the variables to be monitored most often.

### INFILL

Processes data describing the fill systems.

### INHTXQ

Processes data describing the heat exchangers.

### INJUN

Processes junction description cards and sets up initial conditions for all junctions.

After the junction description cards are read, pump and check valve input routines (INPUMP and INCKV) are called. Junction water properties, pump heads, and check valve friction coefficients are then obtained. Finally, junction friction coefficients required to produce steady state are calculated and checked. A negative friction coefficient will cause an error indication.

INMAIN

Calls in succession all of the input data processing and initial conditions routines.

INLEAK

Processes data describing the leaks.

INPUMP

Processes pump coastdown data and pump characteristics.

INREAC

Processes a set of Doppler data and then reactivity coefficient cards.

INRKEN

Processes the reactor kinetics data and then calls the scram and reactivity data processing routines (INSCRAM and INREAC).

INROD

Processes data describing the fuel rods; reads thermal property tables for the rod materials.

INSCRM

Processes the reactor scram curve.

INTABL

Is called by all input processing routines which require tabular data running beyond a single card.

INTRIP

Processes the trip parameter cards.

INTSTP

Processes the time step control cards.

INVOL

Processes volume description cards and sets up initial conditions for all volumes.

After the volume description cards are read, water properties are obtained. Then masses and energy contents are computed, and finally liquid and mixture levels are set up.

KINITL

Initializes the common areas associated with the reactor kinetics routine and calculates the beginning-of-problem reactivity feedback to be used as a base for perturbations.

### LEAK

Performs the choked flow calculations by a double interpolation of the leak tables contained in a block data subroutine (DATB).

### MAIN

Processes the title card and the integer data and controls the calling of the input, restart, transient, tape editing, and termination segments of the program.

### PLTAPE

Saves all data for possible restarting. May also save editable variables for later re-edit or plot.

### POLATE

Is a linear interpolation routine used by many other routines.

### POSIT

Positions a restart tape to the correct page.

### PRESS

Is the steam table interpolation routine.

Given a pressure and a pressure index, the saturation properties are obtained by a linear interpolation. If an enthalpy and an enthalpy index are also given, a double interpolation for specific volume and temperature are performed and the indices updated.

### PRINTR

Controls the flow of tape editing routines.

### PULLIN

Restores all of the labeled common blocks to their old values.

### PUMP

Obtains a pump pressure head from the flow-head table, the coastdown curve, and the cavitation equation.

### REAC

Adds the sum of the reactivity feedback terms to the reactivity obtained from the scram curve (SCRM).

### REEDIT

Reads a new edit control card.

### RETSTP

Reads a new set of time step control cards.

### RKEN

Supplies the normalized reactor power level.

In the case of a power-time type of problem, the normalized power is obtained directly from the scram curve (SCRM).

For a kinetics type of run, the reactivity summing routine (REAC) is called and then a Runge-Kutta advancement is performed according to the reactor kinetics equations.

### RNDO

Is a routine called to avoid round-off error in Runge-Kutta advancement of the reactor kinetics equations (RKEN).

### RESTRT

Controls the flow of the restart procedure.

Routines which are called include an edit control input (REEDIT), a time step input (RETSTP), a tape positioning routine (POSIT), and the restoring routine (PULLIN).

### SCRM

Obtains the current value of reactivity (or normalized power) from the scram table.

### STATE

Calculates pressure and enthalpy, when given specific volume and internal energy, by using the steam tables directly to get to the proper interval and then iterating through PRESS.

### SUBPG

Ejects a sheet of output and puts problem title, elapsed computer time, and page number at the top of the next page.

### TEMH

Calculates enthalpy and specific volume when given pressure and temperature (or quality) by using the steam tables directly to get to the proper interval and then iterating through PRESS.

### TEMP

Calculates transient fuel pin temperatures at radial nodes, given heat generation rate, surface heat transfer coefficient, bulk coolant temperatures, and old time step value of surface heat flux.

### TEMZ

Calculates initial fuel pin temperatures at radial nodes, given heat generation rate, surface heat transfer coefficient, bulk coolant temperature, and steady state surface heat flux.

### TIME

Obtains the elapsed computer time in seconds.

### TKANDC

Interpolates, from the tables of thermal conductivity and heat capacity, values for the nodal pin temperatures. TKANDC is called by both TEMZ and TEMP.

### TRAN

Controls the flow of the transient calculations.

Routines which are called by TRANS include the time step size and edit control (TSTP), the volume mass and energy balance (BAL), the flow calculation (FLOSRRH), the reactor power calculation (RKEN), and the editing package (EDIT). Errors during one of these routines are detected after the return and will cause termination of the problem.

### TRIP

Generates signals to end the problem, to open the leak junctions, to initiate a reactor scram, to shut down the pump, to start the fill systems, or to open or close a valve.

### TROD

Is the core heat transfer routine. TROD calls HTRC and TEMP in an iterative procedure, until a convergence on the pin surface heat transfer coefficient is obtained.

### TSPIN

Processes the edit frequency control cards for the tape edit routine.

### TSPRNT

Determines the edit requirements during the tape edit routine.

### TSTP

Obtains the new time step size and sets the edit control parameters.

### VAPOR1

Sets up the coefficients needed for the height dependent bubble density calculation (BUBB).

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK




**APPENDIX F**  
**RELAP3 FLOW CHARTS**

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

APPENDIX F


RELAP3 FLOW CHARTS



INC-A-15862


CHART 1, PROGRAM FLOW.

PRINTR




INC-A-15863

CHART 2. TAPE EDITING.




INC-A-14452.

CHART 3. RESTARTING LINK.



INC-A-14453


CHART 4. INPUT LINK.



INC-A-14454

CHART 5. TRANSIENT LINK.


INVOL



INC - A-14455


CHART 6. VOLUME DATA.





INC-A-14456

CHART 7. JUNCTION DATA.



INC-A-14457

CHART 8. REACTOR DATA.

BAL






CHART 9. MASS AND ENERGY BALANCES.

FLOSRRH



INC-A-14459

CHART 10. MOMENTUM BALANCE.



INC-A-14460

CHART 11. REACTOR KINETICS.

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK

**APPENDIX G**

**SAMPLE PROBLEMS**

THIS PAGE  
WAS INTENTIONALLY  
LEFT BLANK



## APPENDIX G

### SAMPLE PROBLEMS

The test cases which follow show the input, output, and restart formats and provide results for comparison. The results were obtained from a double precision version and run on an IBM 360/75. Other computers using a longer word length produce the essential features of these results from a single precision version. These cases have been run on the CDC 6600, Univac 1108, and the IBM 7044 as well as the IBM 360/75. However, the RELAP3 version used on all but the IBM 360/75 was one which did not contain the current core geometry and heat transfer.

The test cases are designed to check the major features of RELAP3. The first case is a one-volume unheated blowdown, and the second case is a three-volume reactor blowdown with reactivity feedback. The last test case is a sample restart of the three-volume problem.

Execution time and to a lesser degree the numerical results depend upon the particular computer used. Observed timings are as follows:

| <u>Computer</u> | <u>Compiler</u> | <u>Compile Time<sup>[a]</sup><br/>(min)</u> | <u>Execute Time<sup>[a]</sup><br/>(min)</u> |
|-----------------|-----------------|---|---|
| IBM 360/75      | H/2             | 2.0   | 4.6   |
| IBM 7044        | IBSYS           | 27.   | 25.   |
| CDC 6600        | RUN             | 1.4   | 3.0   |
| Univac 1108     | FORTTRAN V      | 1.2   | 4.5   |

---

[a] The running times can vary depending on the time of day, installed hardware, and costing algorithm.

SAMPLE PROBLEM 1 -- ONE VOLUME UNHEATED BLOWDOWN  
AND THREE-VOLUME TEST PROBLEM WITH REACTOR KINETICS

```

//GAJ3A#15 JOB (R,M37001,10,X00760,0685),G.A.JAYNE,CLASS=A,PRTY=8
//XQT EXEC RELAP3,XTIME=10,PAGES=80,TPOUT='L.GAJR3001'
//X.SYSIN DD *
RELAP3 STANDARD ONE VOLUME CASE 5/70 30.TOP,1VOL,2342.5P,520F TITLE 10
0 5 4 3 1 1 1 0 0 1 0 0 0 0 0 0 0.0 INTL 20
AP 1 TM 1 ML 1 JW 1 JX 1 EDIT 30
10 0.0005 0.2 TIME 40
50 0.0010 1.0 TIME 41
20 0.0025 2.0 TIME 42
20 0.0050 10000.0 TIME 43
1 1 25.0 0.0 ENDT 50
1 -4 1 14.8 0.0 ENDP 51
2 1 0.001 0.0 STRT 52
1 0 2342.5 520.0 8.45 10.333 0.0 0.0VOL 60
0.8 3.0 BUB 70
1 0 1 0.0 0.026167 9.5 0.0 0.0 IFAK 80
3 1 12.5 0.6 0.0 0.0 0.001 1.0LAREA120
10000.0 1.0 LAREA121
THREE VOLUME TEST PROBLEM WITH REACTOR KINETICS ETC. MAY, 1970 TITL 10
-2 9 5 6 3 1 4 1 1 1 0 1 1 1 2 50.0 CONT 20
AP 3 JW 2 JW 3 AX 3 FT 3 ST 3 HC 3 DF 3 SF 3 EDIT 30
50 50 1 50 0.0002 0.5 TIME 40
10 50 3 10 0.0010 2.0 TIME 41
2 50 4 2 0.0050 4.0 TIME 42
4 50 3 2 0.0050 10.0 TIME 43
4 50 5 2 0.0050 25.0 TIME 44
1 1 21.0 0.0 ENDT 50
1 -4 1 50.0 0.0 ENDP 51
2 1 0.01 0.0 LEAK 52
3 -4 1 2000.0 0.2 SCRМ 53
3 1 0.01 1.0 SCRМ 54
4 -4 1 1000.0 0.1 PMPT 55
1 0 2400.00 550.0 350.0 11.0 0.0 4.5VOL1 60
1 -1 2408.81 521.5 250.0 8.0 0.0 0.0VOL2 61
0 +1 2405.61 550.0 15.0 3.0 0.0 2.0VOL3 62
0.0 3.0 BUB 70
1 0 1 0.0 1.5 10.5 0.0 0.0 JUN1 80
2 3 0 1390.0 5.0 2.0 0.3 0.0 JUN2 81
3 1 0 1390.0 5.0 5.0 0.3 0.0 JUN3 82
1 2 1 1390.0 5.0 7.0 60.0 0.0 JUN4 83
3 0.0002 0.0 1.0 1.0 0.0PCD 90
100.0 0.0 PCD 91
3 1 1 100.0 0.0001 -8.0E+6 400.0 10.0E+6 200.0PHEAD100
20.0E+6 -300.0E+6 PHEAD101
0.4 0.00003 0.01 100.0 0.05 0.00400PL 160
3 0 50.0 0.6 0.0 0.0 1.0LAREA120
100.0 1.0 LAREA121
18 300.0 0.0 KIN 140
3 0.0 0.0 0.5 -20.0 100.0 -20.0SCRМ 150
3 0.0 0.0 500.0 0.0 4500.0 0.00400PL 160
-0.3 -0.0001 0.000001 1.0 REAC 170

```

|    |   |   |   |        |          |        |          |        |           |        |
|----|---|---|---|--------|----------|--------|----------|--------|-----------|--------|
| 1  | 2 | 4 | 7 | 1.0    | 1068.0   | 3.0    | 0.05     | 0.05   | CHNL      | 180    |
| 2  | 1 | 3 |   | 0.005  | 1000.0   | 1.0    |          |        | ROD1      | 190    |
|    | 2 | 5 |   | 0.0005 | 600.0    | 0.0    |          |        | ROD2      | 191    |
| 20 |   |   |   | 100.0  | 5.00256  | 300.0  | 3.99600  | 500.0  | 3.32820K  | 11 200 |
|    |   |   |   | 700.0  | 2.85408  | 900.0  | 2.50128  | 1100.0 | 2.22948K  | 12 200 |
|    |   |   |   | 1300.0 | 2.01528  | 1500.0 | 1.84356  | 1700.0 | 1.70460K  | 13 200 |
|    |   |   |   | 1900.0 | 1.55160  | 2100.0 | 1.46520  | 2300.0 | 1.38600K  | 14 200 |
|    |   |   |   | 2500.0 | 1.33560  | 3000.0 | 1.27080  | 3500.0 | 1.23840K  | 15 200 |
|    |   |   |   | 3700.0 | 1.23840  | 4000.0 | 1.26000  | 4300.0 | 1.31400K  | 16 200 |
|    |   |   |   | 4700.0 | 1.40400  | 5100.0 | 1.50480  |        | K         | 17 200 |
| 20 |   |   |   | 100.0  | 0.05779  | 300.0  | 0.06540  | 500.0  | 0.06914C  | 11 201 |
|    |   |   |   | 700.0  | 0.07143  | 900.0  | 0.07306  | 1100.0 | 0.07435C  | 12 201 |
|    |   |   |   | 1300.0 | 0.07543  | 1500.0 | 0.07639  | 1700.0 | 0.07728C  | 13 201 |
|    |   |   |   | 2500.0 | 0.0797   | 2700.0 | 0.0810   | 3000.0 | 0.0850 C  | 14 201 |
|    |   |   |   | 3200.0 | 0.0897   | 3500.0 | 0.0990   | 3800.0 | 0.1116 C  | 15 201 |
|    |   |   |   | 4100.0 | 0.1265   | 4400.0 | 0.1403   | 4600.0 | 0.1474 C  | 16 201 |
|    |   |   |   | 4800.0 | 0.1530   | 5100.0 | 0.1562   |        | C         | 17 201 |
| 15 |   |   |   | 100.0  | 7.90920  | 300.0  | 8.22240  | 500.0  | 8.67600K  | 21 202 |
|    |   |   |   | 700.0  | 9.27000  | 900.0  | 10.00080 | 1100.0 | 10.87200K | 22 202 |
|    |   |   |   | 1300.0 | 11.88720 | 1500.0 | 13.03560 | 1700.0 | 14.328 K  | 23 202 |
|    |   |   |   | 1800.0 | 14.652   | 2000.0 | 16.02    | 2200.0 | 17.892 K  | 24 202 |
|    |   |   |   | 2500.0 | 21.132   | 2900.0 | 26.28    | 3300.0 | 32.22 K   | 25 202 |
| 11 |   |   |   | 100.0  | 0.06708  | 300.0  | 0.07318  | 500.0  | 0.07693C  | 21 203 |
|    |   |   |   | 700.0  | 0.07981  | 900.0  | 0.08228  | 1100.0 | 0.08455C  | 22 203 |
|    |   |   |   | 1300.0 | 0.08669  | 1500.0 | 0.08876  | 1700.0 | 0.09078C  | 23 203 |
|    |   |   |   | 1800.0 | 0.0870   | 3300.0 | 0.0870   |        | C         | 24 203 |
| 0  |   |   |   | 1.0    | 400.0    |        |          |        | HTEX      | 210    |
|    |   |   |   |        |          |        |          |        | END       | 220    |

/\*

//GAJ5C#15 JOB (R,M37001,10,X00760,0685),G.A.JAYNE,CLASS=C,PRTY=8  
 //XQT EXEC RELAP3,XTIME=5,TPIN='L.GAJR3001'  
 //X.SYSIN DD \*

THREE VOLUME TEST PROBLEM RESTARTED FROM TAPE  
 37 8 2  
 JW 2 JW 3 AX 3 FT 3 ST 3 HC 3 DF 3 SF 3  
 4 50 3 10 0.005 10.0  
 4 50 4 10 0.005 20.0

TITL 10  
 CONT 20  
 EDIT 30  
 TIME 40  
 TIME 41  
 END 220

RELAP3 STANDARD ONE VOLUME CASE 5/70 30.TOP,1VOL,2342.5P,520F

TIME = 0.0 PAGE 1

RELAP3 STANDARD ONE VOLUME CASE 5/70 30.TOP,1VOL,2342.5P,520F

TITLE 10

MISCELLANEOUS PROBLEM CONTROL DATA.

| TAPE DUMP | NUM EDIT | NUM TIME | NUM TRIP | NUM VOL | NUM BUBL | NUM JUNC | NUM PUMP | NUM CURV | NUM VALV | NUM CHK | NUM LEAK | NUM FILL | NUM CORE | NUM ROD | NUM HEAT | NUM ROC | NUM POWER   | INITIAL |
|-----------|----------|----------|----------|---------|----------|----------|----------|----------|----------|---------|----------|----------|----------|---------|----------|---------|-------------|---------|
| 0=NO      | VAR      | SETS     | SGNL     |         | SETS     |          | CURV     |          |          |         |          |          | REG      | GEOM    | EXCH     | MAT     | (MEGAWATTS) |         |

0 5 4 3 1 1 1 0 0 1 0 0 0 0 0 0 0 0.0

INTL 20

EDIT IDENTIFICATION NUMBERS

|    | 1 | 2  | 3 | 4  | 5 | 6  | 7 | 8  | 9 |   |   |   |   |
|----|---|----|---|----|---|----|---|----|---|---|---|---|---|
| AP | 1 | TM | 1 | ML | 1 | JW | 1 | JX | 1 | 0 | 0 | 0 | 0 |

EDIT 30

DATA FOR 4 TIME STEP SETS.

| SET NUM | T S PER | BRF PER | LRG PER | LRG RST | T S PER | TIME STEP SIZE | END OF INTERVAL |
|---------|---------|---------|---------|---------|---------|----------------|-----------------|
| 1       | 10      | 0       | 0       | 0       | 0       | 0.500000D-03   | 0.200000D 00    |
| 2       | 50      | 0       | 0       | 0       | 0       | 0.100000D-02   | 0.100000D 01    |
| 3       | 20      | 0       | 0       | 0       | 0       | 0.250000D-02   | 0.200000D 01    |
| 4       | 20      | 0       | 0       | 0       | 0       | 0.500000D-02   | 0.100000D 05    |

TIME 40  
TIME 41  
TIME 42  
TIME 43

06

REL AP3 STANDARD ONE VOLUME CASE 5/70 30.TOP,1VOL,2342.5P,520F

TIME = 0.13 PAGE 2

GENERALIZED TRIP PARAMETERS FOR 3 SIGNALS.

| TRIP NO. | TRIP ID | SIG ID | INDX 1 | INDX 2 | ACTION | TRIP SIGNAL  | SET POINT    | DELAY TIME |         |
|----------|---------|--------|--------|--------|--------|--------------|--------------|------------|---------|
| 1        | 1       | 1      | 0      | 0      | END    | ELAPSED TIME | 0.250000D 02 | 0.0        | ENDT 50 |
| 2        | 1       | -4     | 1      | 0      | END    | LOW PRESSURE | 0.148000D 02 | 0.0        | ENDP 51 |
| 3        | 2       | 1      | 0      | 0      | LEAK   | ELAPSED TIME | 0.100000D-02 | 0.0        | STRT 52 |

16

REL AP3 STANDARD ONE VOLUME CASE 5/70 30.TOP,1VOL,2342.5P,520F

TIME = 0.15 PAGE 3

INPUT DATA FOR 1 VOLUMES.

| VOL NUM | BUBL INDX | HEAT INDX | PRESSURE (PSI) | TEMPERATURE (OR QUALITY) | VOLUME (FT**3) | HEIGHT (FT)  | MIXTURE LEVEL (FT) | ELEVATION (FT) |        |
|---------|-----------|-----------|----------------|--------------------------|----------------|--------------|--------------------|----------------|--------|
| 1       | 1         | 0         | 0.234250D 04   | 0.520000D 03             | 0.845000D 01   | 0.103330D 02 | 0.0                | 0.0            | VOL 60 |

INPUT FOR 1 SETS OF BUBBLE CONSTANTS

| SET NO. | SLOPE PARAMETER | BUBBLE VELOCITY |                 |
|---------|-----------------|-----------------|-----------------|
| 0       | 0.              | 0.              | (BUILT-IN DATA) |
| 1       | 0.800000D 00    | 0.300000D 01    | BUB 70          |

DESCRIPTIONS OF 1 JUNCTIONS.

| FROM VOL | TO VOL | PUMP CHCK LEAK VALV FILL INDX | INITIAL FLOW (LBS/SEC) | MINIMUM FLOW AREA (FT**2) | JUNCTION HEIGHT (FT) | JUNCTION INERTIA (1/FT) | FRICTION COEFFICIENT (DP=F*V*W**2) |         |
|----------|--------|-------------------------------|------------------------|---------------------------|----------------------|-------------------------|------------------------------------|---------|
| 1        | 0      | 1 0                           | 0.0                    | 0.2616700-01              | 0.9500000 01         | 0.0                     | 0.0                                | LEAK 80 |

92

PARAMETERS FOR 1 LEAKS.

| LEAK NO. | DATA PTS. | LEAK TYPE | SINK PRESSURE                | CONTRACTION COEFFICIENT      | TIME | AREA | TIME         | AREA         |                      |
|----------|-----------|-----------|------------------------------|------------------------------|------|------|--------------|--------------|----------------------|
| 1        | 3         | 1         | 0.1250000 02<br>0.1000000 05 | 0.6000000 00<br>0.1000000 01 | 0.0  | 0.0  | 0.1000000-02 | 0.1000000 01 | LAREA120<br>LAREA121 |

RELAP3 STANDARD ONE VOLUME CASE 5/70 30.TOP,1VOL,2342.5P,520F

TIME = 0.27 PAGE 6

TIME STEP NUM 0. TIME = 0.0 SEC.

| TOTAL SYSTEM QUANTITIES | NORM POWR          | POWR (MW)      | HEAT REM (BTU/HR)  | ENGY LEAK (BTU)    | MASS LEAK (LB) | ENGY BAL. (BTU)          | MASS BAL. (LB)   | TOT. REAC (\$)                | REAC T SEC.           |                     |
|-------------------------|--------------------|----------------|--------------------|--------------------|----------------|--------------------------|------------------|-------------------------------|-----------------------|---------------------|
|                         | 0.0                | 0.0            | 0.0                | 0.0                | 0.0            | 2.06568D 05              | 4.11154D 02      | 0.0                           | 0.0                   |                     |
| VOLUME NUMBER           | AVG. PRES PSIA     | TOT. MASS (LB) | AVG. ENTH (BTU/LB) | AVG. DENS (LB/FT3) | AVG. TEMP (F)  | AVG. QUAL                | BUBB MASS (LB)   | MIXT LEVL (FT)                | LIQ. MASS (LB)        |                     |
| 1                       | 2.34250D 03        | 4.11154D 02    | 5.11320D 02        | 4.86572D 01        | 5.20000D 02    | 0.0                      | 0.0              | 1.03330D 01                   | 4.11154D 02           |                     |
| JUNCTION NUMBER         | CONNECTING VOLUMES | CHOKE          | JCT. FLOW (LB/SEC) | JCT. ENTH (BTU/LB) | JCT. QUAL      | P R E S S U R E TOT. PSI | S U R E ELEV PSI | D I F F E R E N T F R I C PSI | E R E N T A C C L PSI | I A L S P U M P PSI |
| 1                       | 1 TO 0             | NO             | 0.0                | 5.11320D 02        | 0.0            | 0.0                      | 0.0              | 0.0                           | 0.0                   | 0.0                 |

| TIME    | AVG PRESS   | TOTAL MASS  | MIXT LEVEL  | FLOW        | LB/         | QUALITY |
|---------|-------------|-------------|-------------|-------------|-------------|---------|
| SEC     | VOL 1 PSIA  | VOL 1 LB    | VOL 1 FT    | JUN 1 SEC   | JUN 1       |         |
| 0.00500 | 1.958400 03 | 4.101020 02 | 1.033300 01 | 3.475180 02 | 0.0         |         |
| 0.01000 | 1.474650 03 | 4.085980 02 | 1.033300 01 | 2.578750 02 | 0.0         |         |
| 0.01500 | 1.098380 03 | 4.074980 02 | 1.033300 01 | 1.801320 02 | 0.0         |         |
| 0.02000 | 8.187660 02 | 4.067320 02 | 1.033300 01 | 1.169180 02 | 0.0         |         |
| 0.02500 | 7.763250 02 | 4.061780 02 | 1.033300 01 | 1.097660 02 | 6.364540-05 |         |
| 0.03000 | 7.761360 02 | 4.056300 02 | 1.033290 01 | 1.097230 02 | 1.486850-04 |         |
| 0.03500 | 7.759450 02 | 4.050810 02 | 1.033280 01 | 1.096810 02 | 2.338160-04 |         |
| 0.04000 | 7.757550 02 | 4.045330 02 | 1.033270 01 | 1.096390 02 | 3.190380-04 |         |
| 0.04500 | 7.755630 02 | 4.039850 02 | 1.033260 01 | 1.095960 02 | 4.043540-04 |         |
| 0.05000 | 7.753710 02 | 4.034370 02 | 1.033240 01 | 1.095540 02 | 4.897640-04 |         |
| 0.05500 | 7.751790 02 | 4.028890 02 | 1.033210 01 | 1.095110 02 | 5.752690-04 |         |
| 0.06000 | 7.749860 02 | 4.023420 02 | 1.033180 01 | 1.094690 02 | 6.608720-04 |         |
| 0.06500 | 7.747920 02 | 4.017940 02 | 1.033150 01 | 1.094260 02 | 7.465730-04 |         |
| 0.07000 | 7.745980 02 | 4.012470 02 | 1.033120 01 | 1.093840 02 | 8.323730-04 |         |
| 0.07500 | 7.744030 02 | 4.007010 02 | 1.033080 01 | 1.093410 02 | 9.182740-04 |         |
| 0.08000 | 7.742080 02 | 4.001540 02 | 1.033030 01 | 1.092980 02 | 1.004280-03 |         |
| 0.08500 | 7.740130 02 | 3.996080 02 | 1.032990 01 | 1.092560 02 | 1.090380-03 |         |
| 0.09000 | 7.738160 02 | 3.990610 02 | 1.032940 01 | 1.092130 02 | 1.176600-03 |         |
| 0.09500 | 7.736190 02 | 3.985150 02 | 1.032880 01 | 1.091700 02 | 1.262910-03 |         |
| 0.10000 | 7.734220 02 | 3.979700 02 | 1.032820 01 | 1.091270 02 | 1.349340-03 |         |
| 0.10500 | 7.732240 02 | 3.974240 02 | 1.032760 01 | 1.090850 02 | 1.435870-03 |         |
| 0.11000 | 7.730250 02 | 3.968790 02 | 1.032700 01 | 1.090420 02 | 1.522520-03 |         |
| 0.11500 | 7.728260 02 | 3.963340 02 | 1.032630 01 | 1.089990 02 | 1.609270-03 |         |
| 0.12000 | 7.726270 02 | 3.957890 02 | 1.032550 01 | 1.089560 02 | 1.696140-03 |         |
| 0.12500 | 7.724260 02 | 3.952440 02 | 1.032480 01 | 1.089130 02 | 1.783120-03 |         |
| 0.13000 | 7.722260 02 | 3.947000 02 | 1.032400 01 | 1.088700 02 | 1.870220-03 |         |
| 0.13500 | 7.720240 02 | 3.941550 02 | 1.032310 01 | 1.088270 02 | 1.957440-03 |         |
| 0.14000 | 7.718220 02 | 3.936110 02 | 1.032230 01 | 1.087840 02 | 2.044770-03 |         |
| 0.14500 | 7.716200 02 | 3.930680 02 | 1.032130 01 | 1.087410 02 | 2.132220-03 |         |
| 0.15000 | 7.714170 02 | 3.925240 02 | 1.032040 01 | 1.086970 02 | 2.219800-03 |         |
| 0.15500 | 7.712130 02 | 3.919810 02 | 1.031940 01 | 1.086540 02 | 2.307490-03 |         |
| 0.16000 | 7.710090 02 | 3.914370 02 | 1.031840 01 | 1.086110 02 | 2.395310-03 |         |
| 0.16500 | 7.708040 02 | 3.908940 02 | 1.031730 01 | 1.085680 02 | 2.483260-03 |         |
| 0.17000 | 7.705990 02 | 3.903520 02 | 1.031620 01 | 1.085240 02 | 2.571330-03 |         |
| 0.17500 | 7.703930 02 | 3.898090 02 | 1.031510 01 | 1.084810 02 | 2.659530-03 |         |
| 0.18000 | 7.701870 02 | 3.892670 02 | 1.031390 01 | 1.084370 02 | 2.747860-03 |         |
| 0.18500 | 7.699790 02 | 3.887250 02 | 1.031270 01 | 1.083940 02 | 2.836320-03 |         |
| 0.19000 | 7.697720 02 | 3.881830 02 | 1.031150 01 | 1.083500 02 | 2.924920-03 |         |
| 0.19500 | 7.695640 02 | 3.876410 02 | 1.031020 01 | 1.083070 02 | 3.013650-03 |         |
| 0.20000 | 7.693550 02 | 3.871000 02 | 1.030890 01 | 1.082630 02 | 3.102510-03 |         |



RELAP3 STANDARD ONE VOLUME CASE 5/70 30.TOP,1VOL,2342.5P,520F

TIME = 3.74 PAGE 8

TIME STEP NUM 400. TIME = 0.200000D 00 SEC.

| TOTAL SYSTEM QUANTITIES | NORM POWR          | POWR (MW)      | HEAT REM (BTU/HR)  | ENGY LEAK (BTU)    | MASS LEAK (LB) | ENGY BAL. (BTU)          | MASS BAL. (LB)   | TOT. REAC (\$)                     | REAC T SEC.        |                  |
|-------------------------|--------------------|----------------|--------------------|--------------------|----------------|--------------------------|------------------|------------------------------------|--------------------|------------------|
|                         | 0.0                | 0.0            | 0.0                | 1.21770D 04        | 2.40539D 01    | 2.06568D 05              | 4.11154D 02      | 0.0                                | 0.0                |                  |
| VOLUME NUMBER           | AVG. PRES PSIA     | TOT. MASS (LB) | AVG. ENTH (BTU/LB) | AVG. DENS (LB/FT3) | AVG. TEMP (F)  | AVG. QUAL                | BURB MASS (LB)   | MIXT LEVL (FT)                     | LIQ. MASS (LB)     |                  |
| 1                       | 7.69355D 02        | 3.87100D 02    | 5.05281D 02        | 4.58106D 01        | 5.13304D 02    | 1.88178D-03              | 6.95223D-01      | 1.03089D 01                        | 3.86371D 02        |                  |
| JUNCTION NUMBER         | CONNECTING VOLUMES | CHOKE          | JCT. FLOW (LB/SEC) | JCT. ENTH (BTU/LB) | JCT. QUAL      | P R E S S U R E TOT. PSI | S U R E ELEV PSI | D I F F E R E N T I A L S FRIC PSI | E R E N T ACCL PSI | I A L S PUMP PSI |
| 1                       | 1 TO 0             | YES            | 1.08263D 02        | 5.06137D 02        | 3.10251D-03    | 7.56855D 02              | 0.0              | 0.0                                | 0.0                | 0.0              |

| TIME     | AVG PRESS   | TOTAL MASS  | MIXT LEVEL  | FLOW        | LB/         | QUALITY |
|----------|-------------|-------------|-------------|-------------|-------------|---------|
| SEC      | VOL 1 PSIA  | VOL 1 LB    | VOL 1 FT    | JUN 1       | SEC         | JUN 1   |
| 12.10000 | 2.38347D 01 | 2.46446D 01 | 9.48415C 00 | 3.12368D 00 | 1.28431D-01 |         |
| 12.20000 | 2.32445D 01 | 2.43418D 01 | 9.48418C 00 | 2.92197D 00 | 1.29496D-01 |         |
| 12.30000 | 2.26836D 01 | 2.40594D 01 | 9.48421D 00 | 2.71551D 00 | 1.30976D-01 |         |
| 12.40000 | 2.21528D 01 | 2.37978D 01 | 9.48424D 00 | 2.50370D 00 | 1.33003D-01 |         |
| 12.50000 | 2.16529D 01 | 2.35578D 01 | 9.48427D 00 | 2.28397D 00 | 1.35807D-01 |         |
| 12.60000 | 2.11853D 01 | 2.33404D 01 | 9.48431D 00 | 2.04831D 00 | 1.39893D-01 |         |
| 12.70000 | 2.07535D 01 | 2.31484D 01 | 9.48437D 00 | 1.76243D 00 | 1.47023D-01 |         |
| 12.80000 | 2.03704D 01 | 2.29919D 01 | 9.48445D 00 | 1.42324D 00 | 1.61060D-01 |         |
| 12.90000 | 2.00152D 01 | 2.28549D 01 | 9.48447D 00 | 1.31065D 00 | 1.65883D-01 |         |
| 13.00000 | 1.96769D 01 | 2.27291D 01 | 9.48449D 00 | 1.20036D 00 | 1.71651D-01 |         |
| 13.10000 | 1.93553D 01 | 2.26143D 01 | 9.48451D 00 | 1.09156D 00 | 1.78672D-01 |         |
| 13.20000 | 1.90498D 01 | 2.25103D 01 | 9.48454D 00 | 9.82866D-01 | 1.87472D-01 |         |
| 13.30000 | 1.87606D 01 | 2.24172D 01 | 9.48456D 00 | 8.71314D-01 | 1.99093D-01 |         |
| 13.40000 | 1.84882D 01 | 2.23358D 01 | 9.48459D 00 | 7.48179D-01 | 2.16396D-01 |         |
| 13.50000 | 1.82362D 01 | 2.22689D 01 | 9.48464D 00 | 5.46859D-01 | 2.63091D-01 |         |
| 13.60000 | 1.79726D 01 | 2.21907D 01 | 9.48423D 00 | 2.09558D 00 | 1.24147D-01 |         |
| 13.70000 | 1.75571D 01 | 2.19863D 01 | 9.48425D 00 | 1.98664D 00 | 1.24861D-01 |         |
| 13.80000 | 1.71582D 01 | 2.17928D 01 | 9.48426D 00 | 1.87773D 00 | 1.25935D-01 |         |
| 13.90000 | 1.67756D 01 | 2.16102D 01 | 9.48428D 00 | 1.77028D 00 | 1.27248D-01 |         |
| 14.00000 | 1.64091D 01 | 2.14382D 01 | 9.48430D 00 | 1.66418D 00 | 1.28846D-01 |         |
| 14.10000 | 1.60584D 01 | 2.12768D 01 | 9.48432D 00 | 1.55930D 00 | 1.30781D-01 |         |
| 14.20000 | 1.57232D 01 | 2.11258D 01 | 9.48434D 00 | 1.45549D 00 | 1.33124D-01 |         |
| 14.30000 | 1.54033D 01 | 2.09851D 01 | 9.48436D 00 | 1.35260D 00 | 1.35967D-01 |         |
| 14.40000 | 1.50983D 01 | 2.08547D 01 | 9.48438D 00 | 1.25047D 00 | 1.39429D-01 |         |
| 14.50000 | 1.48081D 01 | 2.07345D 01 | 9.48441D 00 | 1.14892D 00 | 1.43676D-01 |         |
| 14.50500 | 1.47940D 01 | 2.07287D 01 | 9.48441D 00 | 1.14385D 00 | 1.43913D-01 |         |

TIME STEP NUM 4101. TIME = 0.1450500 02 SEC.

| TOTAL SYSTEM QUANTITIES | NORM POWR          | POWR (MW)      | HEAT REM (BTU/HR)  | ENGY LEAK (BTU)    | MASS LEAK (LB) | ENGY BAL. (BTU)          | MASS BAL. (LB)   | TOT. REAC (\$)                     | REAC T SEC.    |             |
|-------------------------|--------------------|----------------|--------------------|--------------------|----------------|--------------------------|------------------|------------------------------------|----------------|-------------|
|                         | 0.0                | 0.0            | 0.0                | 2.02557D 05        | 3.90425D 02    | 2.06568D 05              | 4.11154D 02      | 0.0                                | 0.0            |             |
| VOLUME NUMBER           | AVG. PRES PSIA     | TOT. MASS (LB) | AVG. ENTH (BTU/LB) | AVG. DENS (LB/FT3) | AVG. TEMP (F)  | AVG. QUAL                | BUBB MASS (LB)   | MIXT LEVL (FT)                     | LIQ. MASS (LB) |             |
| 1                       | 1.47940D 01        | 2.07287D 01    | 1.94612D 02        | 2.45311D 00        | 2.12198D 02    | 1.46838D-02              | 2.78327D-01      | 9.48441D 00                        | 2.04244D 01    |             |
| JUNCTION NUMBER         | CONNECTING VOLUMES | CHOKE          | JCT. FLOW (LB/SEC) | JCT. ENTH (BTU/LB) | JCT. QUAL      | P R E S S U R E TOT. PSI | S U R E ELEV PSI | D I F F E R E N T I A L S FRIC PSI | A C C L PSI    | P U M P PSI |
| 1                       | 1 TD               | 0 NO           | 1.14385D 00        | 3.19885D 02        | 1.43913D-01    | 2.29400D 00              | 0.0              | 2.21544D 00                        | 0.0            | 0.0         |

97

END TRIP SIGNAL.

THREE VOLUME TEST PROBLEM WITH REACTOR KINETICS ETC. MAY, 1970

TIME = 0.0 PAGE 1

THREE VOLUME TEST PROBLEM WITH REACTOR KINETICS ETC. MAY, 1970

TITL 10

MISCELLANEOUS PROBLEM CONTROL DATA.

| TAPE | NUM  | NUM  | NUM  | NUM | NUM  | NUM  | NUM  | NUM  | NUM  | NUM  | NUM  | NUM  | NUM  | NUM | NUM  | NUM | NUM  | NUM | INITIAL      |
|------|------|------|------|-----|------|------|------|------|------|------|------|------|------|-----|------|-----|------|-----|--------------|
| DUMP | EDIT | TIME | TRIP | VOL | BUBL | JUNC | PUMP | CHK  | LEAK | FILL | CORE | ROD  | HEAT | ROD | HEAT | ROD | HEAT | ROD | POWER        |
| 0=NO | VAR  | SETS | SGNL |     | SETS |      | CURV | VALV | CUR/ | CURV | REG  | GEOM | EXCH | MAT |      |     |      |     | (MEGAWATTS)  |
| -2   | 9    | 5    | 6    | 3   | 1    | 4    | 1    | 1    | 1    | 0    | 1    | 1    | 1    | 2   |      |     |      |     | 0.500000D 02 |

CONT 20

EDIT IDENTIFICATION NUMBERS

|      |      |      |      |      |      |      |      |      |
|------|------|------|------|------|------|------|------|------|
| 1    | 2    | 3    | 4    | 5    | 6    | 7    | 8    | 9    |
| AP 3 | JW 2 | JW 3 | AX 3 | FT 3 | ST 3 | HC 3 | DF 3 | SF 3 |

EDIT 30

DATA FOR 5 TIME STEP SETS.

| SET | T S | BRF | LRG | T S | TIME         | END          |
|-----|-----|-----|-----|-----|--------------|--------------|
| NUM | PER | PER | PER | PER | STEP         | OF           |
|     | BRF | LRG | RST | PLT | SIZE         | INTERVAL     |
| 1   | 50  | 50  | 1   | 50  | 0.200000D-03 | 0.500000D 00 |
| 2   | 10  | 50  | 3   | 10  | 0.100000D-02 | 0.200000D 01 |
| 3   | 2   | 50  | 4   | 2   | 0.500000D-02 | 0.400000D 01 |
| 4   | 4   | 50  | 3   | 2   | 0.500000D-02 | 0.100000D 02 |
| 5   | 4   | 50  | 5   | 2   | 0.500000D-02 | 0.250000D 02 |

TIME 40

TIME 41

TIME 42

TIME 43

TIME 44

GENERALIZED TRIP PARAMETERS FOR 6 SIGNALS.

| TRIP NO. | TRIP ID | SIG ID | INDX 1 | INDX 2 | ACTION | TRIP SIGNAL  | SET POINT    | DELAY TIME   |         |
|----------|---------|--------|--------|--------|--------|--------------|--------------|--------------|---------|
| 1        | 1       | 1      | 0      | 0      | END    | ELAPSED TIME | 0.210000D 02 | 0.0          | ENDT 50 |
| 2        | 1       | -4     | 1      | 0      | END    | LOW PRESSURE | 0.500000D 02 | 0.0          | ENDP 51 |
| 3        | 2       | 1      | 0      | 0      | LEAK   | ELAPSED TIME | 0.100000D-01 | 0.0          | LEAK 52 |
| 4        | 3       | -4     | 1      | 0      | SCRAM  | LOW PRESSURE | 0.200000D 04 | 0.200000D 00 | SCRM 53 |
| 5        | 3       | 1      | 0      | 0      | SCRAM  | ELAPSED TIME | 0.100000D-01 | 0.100000D 01 | SCRM 54 |
| 6        | 4       | -4     | 1      | 0      | PUMP   | LOW PRESSURE | 0.100000D 04 | 0.100000D 00 | PMPT 55 |

INPUT DATA FOR 3 VOLUMES.

| VOL<br>NUM | BUBL<br>INDX | HEAT<br>INDX | PRESSURE<br>(PSI) | TEMPERATURE<br>(OR QUALITY) | VOLUME<br>(FT**3) | HEIGHT<br>(FT) | MIXTURE<br>LEVEL (FT) | ELEVATION<br>(FT) |      |    |
|------------|--------------|--------------|-------------------|-----------------------------|-------------------|----------------|-----------------------|-------------------|------|----|
| 1          | 1            | 0            | 0.240000D 04      | 0.550000D 03                | 0.350000D 03      | 0.110000D 02   | 0.0                   | 0.450000D 01      | VOL1 | 60 |
| 2          | 1            | -1           | 0.240881D 04      | 0.521500D 03                | 0.250000D 03      | 0.800000D 01   | 0.0                   | 0.0               | VOL2 | 61 |
| 3          | 0            | 1            | 0.240561D 04      | 0.550000D 03                | 0.150000D 02      | 0.300000D 01   | 0.0                   | 0.200000D 01      | VOL3 | 62 |

INPUT FOR 1 SETS OF BUBBLE CONSTANTS.

| SET<br>NO. | SLOPE<br>PARAMETER | BUBBLE<br>VELOCITY |                 |        |
|------------|--------------------|--------------------|-----------------|--------|
| 0          | 0.                 | 0.                 | (BUILT-IN DATA) |        |
| 1          | 0.800000D 00       | 0.300000D 01       |                 | BUB 70 |

DESCRIPTIONS OF 4 JUNCTIONS.

| FROM VOL | TO VOL | PUMP LEAK VALV | CHK FILL INDX | INITIAL FLOW (LBS/SEC) | MINIMUM FLOW AREA (FT**2) | JUNCTION HEIGHT (FT) | JUNCTION INERTIA (1/FT) | FRICTION COEFFICIENT (OP=F*V*W**2) |      |    |
|----------|--------|----------------|---------------|------------------------|---------------------------|----------------------|-------------------------|------------------------------------|------|----|
| 1        | 0      | 1              | 0             | 0.0                    | 0.150000D 01              | 0.105000D 02         | 0.0                     | 0.0                                | JUN1 | 80 |
| 2        | 3      | 0              | 0             | 0.139000D 04           | 0.500000D 01              | 0.200000D 01         | 0.300000D 00            | 0.0                                | JUN2 | 81 |
| 3        | 1      | 0              | 0             | 0.139000D 04           | 0.500000D 01              | 0.500000D 01         | 0.300000D 00            | 0.0                                | JUN3 | 82 |
| 1        | 2      | 1              | 0             | 0.139000D 04           | 0.500000D 01              | 0.700000D 01         | 0.600000D 02            | 0.0                                | JUN4 | 83 |

PARAMETERS FOR 1 PUMP TYPES.

| DATA PTS. | CAVITATION CONSTANT          | TIME AFTER TRIP | PUMP MULTIPLIER | TIME AFTER TRIP              | PUMP MULTIPLIER               |                         |                  |                         |                  |          |          |
|-----------|------------------------------|-----------------|-----------------|------------------------------|-------------------------------|-------------------------|------------------|-------------------------|------------------|----------|----------|
| 3         | 0.200000D-03<br>0.100000D 03 | 0.0             | 0.100000D 01    | 0.100000D 01                 | 0.0                           | PCD                     | 90               |                         |                  |          |          |
|           |                              |                 |                 |                              |                               | PCD                     | 91               |                         |                  |          |          |
| PUMP NO.  | DAT PTS                      | IND VAR         | DEP VAR         | NET POSITIVE SUCTION HEAD    | FRICTION COEFFICIENT          | LBS/SEC (0) GAL/MIN (1) | PSI (0) FEET (1) | LBS/SEC (0) GAL/MIN (1) | PSI (0) FEET (1) |          |          |
| 1         | 3                            | 1               | 1               | 0.100000D 03<br>0.200000D 08 | 0.100000D-03<br>-0.300000D 09 | -0.800000D 07           | 0.400000D 03     | 0.100000D 08            | 0.200000D 03     | PHEAD100 | PHEAD101 |

PARAMETERS FOR 1 CHECKVALVES.

| VALVE NO. | BACK PRESSURE FOR CLOSURE | FORWARD FRIC. COEFF. | OPEN REVERSE FRIC. COEFF. | CLOSED REVERSE FRIC. COEFF. |          |
|-----------|---------------------------|----------------------|---------------------------|-----------------------------|----------|
| 1         | 0.400000D 00              | 0.300000D-04         | 0.100000D-01              | 0.100000D 03                | CHKV 110 |

102

PARAMETERS FOR 1 LEAKS.

| LEAK NO. | DAT PTS | LEAK TYPE | SINK PRESSURE                | CONTRACTION COEFFICIENT      | TIME | AREA | TIME         | AREA         |          |          |
|----------|---------|-----------|------------------------------|------------------------------|------|------|--------------|--------------|----------|----------|
| 1        | 3       | 0         | 0.500000D 02<br>0.100000D 03 | 0.600000D 00<br>0.100000D 01 | 0.0  | 0.0  | 0.500000D-01 | 0.100000D 01 | LAREA120 | LAREA121 |



REACTOR KINETICS PARAMETERS.

| NO.<br>GRPS | BETA OVER<br>LIFETIME | INITIAL<br>REACTIVITY |         |
|-------------|-----------------------|-----------------------|---------|
| 18          | 0.300000D 03          | 0.0                   | KIN 140 |

SCRAM CURVE.

| DATA<br>PTS. | TIME | REACTIVITY | TIME         | REACTIVITY    | TIME         | REACTIVITY    |          |
|--------------|------|------------|--------------|---------------|--------------|---------------|----------|
| 3            | 0.0  | 0.0        | 0.500000D 00 | -0.200000D 02 | 0.100000D 03 | -0.200000D 02 | SCRM 150 |

DOPPLER REACTIVITY CURVE.

| DATA<br>PTS. | METAL<br>TEMPERATURE | REACTIVITY<br>(DOLLARS) | METAL<br>TEMPERATURE | REACTIVITY<br>(DOLLARS) | METAL<br>TEMPERATURE | REACTIVITY<br>(DOLLARS) |          |
|--------------|----------------------|-------------------------|----------------------|-------------------------|----------------------|-------------------------|----------|
| 3            | 0.0                  | 0.0                     | 0.500000D 03         | 0.0                     | 0.450000D 04         | 0.400000D-02            | DOPL 160 |

| CORE<br>REG.<br>NO. | WATER VOID<br>COEFFICIENT<br>(\$/PER CENT) | WATER TEMP.<br>COEFFICIENT<br>(\$/DEG F) | METAL TEMP.<br>COEFFICIENT<br>(\$/DEG F) | DOPPLER<br>WEIGHTING<br>FACTOR |          |
|---------------------|--|--|--|--------------------------------|----------|
| 1                   | -0.300000D 00                              | -0.100000D-03                            | 0.100000D-05                             | 0.100000D 01                   | REAC 170 |

103

HEAT TRANSFER DATA FOR 1 CORE REGIONS.

| CORE REG | ROD GEOM | PRINT AT | T NODES    | POWER FRACTION | HEAT TRANS. AREA | CHAN LENGTH | HYD DIAM     | HTD EQ DIAM  |          |
|----------|----------|----------|------------|----------------|------------------|-------------|--------------|--------------|----------|
| 1        | 1        | 2        | 4 7        | 0.100000 01    | 0.1068000 04     | 0.300000 01 | 0.5000000-01 | 0.5000000-01 | CHNL 180 |
| ROD GEOM | REGION   | K,C      | SET SPACES | SIZE           | DENSITY          | POWER FRAC  |              |              |          |
| 1        | 1        | 1        | 3          | 0.500000-02    | 0.100000 04      | 0.100000 01 |              |              |          |
| 1        | 2        | 2        | 5          | 0.500000-03    | 0.600000 03      | 0.0         |              |              |          |

K AND C TABLES, SET NUMBER 1

|    |             |              |             |              |              |              |          |
|----|-------------|--------------|-------------|--------------|--------------|--------------|----------|
| 20 | 0.100000 03 | 0.5002560 01 | 0.300000 03 | 0.3996000 01 | 0.5000000 03 | 0.3328200 01 | K 11 200 |
|    | 0.700000 03 | 0.2854080 01 | 0.900000 03 | 0.2501280 01 | 0.1100000 04 | 0.2229480 01 | K 12 200 |
|    | 0.130000 04 | 0.2015280 01 | 0.150000 04 | 0.1843560 01 | 0.1700000 04 | 0.1704600 01 | K 13 200 |
|    | 0.190000 04 | 0.1551600 01 | 0.210000 04 | 0.1465200 01 | 0.2300000 04 | 0.1386000 01 | K 14 200 |
|    | 0.250000 04 | 0.1335600 01 | 0.300000 04 | 0.1270800 01 | 0.3500000 04 | 0.1238400 01 | K 15 200 |
|    | 0.370000 04 | 0.1238400 01 | 0.400000 04 | 0.1260000 01 | 0.4300000 04 | 0.1314000 01 | K 16 200 |
|    | 0.470000 04 | 0.1404000 01 | 0.510000 04 | 0.1504800 01 |              |              | K 17 200 |
| 20 | 0.100000 03 | 0.5779000-01 | 0.300000 03 | 0.6540000-01 | 0.5000000 03 | 0.6914000-01 | C 11 201 |
|    | 0.700000 03 | 0.7143000-01 | 0.900000 03 | 0.7306000-01 | 0.1100000 04 | 0.7435000-01 | C 12 201 |
|    | 0.130000 04 | 0.7543000-01 | 0.150000 04 | 0.7639000-01 | 0.1700000 04 | 0.7728000-01 | C 13 201 |
|    | 0.250000 04 | 0.7970000-01 | 0.270000 04 | 0.8100000-01 | 0.3000000 04 | 0.8500000-01 | C 14 201 |
|    | 0.320000 04 | 0.8970000-01 | 0.350000 04 | 0.9900000-01 | 0.3800000 04 | 0.1116000 00 | C 15 201 |
|    | 0.410000 04 | 0.1265000 03 | 0.440000 04 | 0.1403000 00 | 0.4600000 04 | 0.1474000 00 | C 16 201 |
|    | 0.480000 04 | 0.1530000 03 | 0.510000 04 | 0.1562000 00 |              |              | C 17 201 |

K AND C TABLES, SET NUMBER 2

|    |             |              |             |              |              |              |          |
|----|-------------|--------------|-------------|--------------|--------------|--------------|----------|
| 15 | 0.100000 03 | 0.7909200 01 | 0.300000 03 | 0.8222400 01 | 0.5000000 03 | 0.8676000 01 | K 21 202 |
|    | 0.700000 03 | 0.9270000 01 | 0.900000 03 | 0.1000080 02 | 0.1100000 04 | 0.1087200 02 | K 22 202 |
|    | 0.130000 04 | 0.1188720 02 | 0.150000 04 | 0.1303560 02 | 0.1700000 04 | 0.1432800 02 | K 23 202 |
|    | 0.180000 04 | 0.1465200 02 | 0.200000 04 | 0.1602000 02 | 0.2200000 04 | 0.1789200 02 | K 24 202 |
|    | 0.250000 04 | 0.2113200 02 | 0.290000 04 | 0.2628000 02 | 0.3300000 04 | 0.3222000 02 | K 25 202 |
| 11 | 0.100000 03 | 0.6708000-01 | 0.300000 03 | 0.7318000-01 | 0.5000000 03 | 0.7693000-01 | C 21 203 |
|    | 0.700000 03 | 0.7981000-01 | 0.900000 03 | 0.8228000-01 | 0.1100000 04 | 0.8455000-01 | C 22 203 |
|    | 0.130000 04 | 0.8669000-01 | 0.150000 04 | 0.8876000-01 | 0.1700000 04 | 0.9078000-01 | C 23 203 |
|    | 0.180000 04 | 0.8700000-01 | 0.330000 04 | 0.8700000-01 |              |              | C 24 203 |

DATA SETS FOR 1 HEAT EXCHANGERS.

| HTXG | VOL | IN | OUT | POWER     | FRAC | SEC       | TEMP | HTXQ | COEFF |
|------|-----|----|-----|-----------|------|-----------|------|------|-------|
| 1    | 2   | 4  | 2   | 0.100000D | 01   | 0.400000D | 03   | 0.0  |       |

HTEX 210

TIME STEP NUM 0. TIME = 0.0 SEC.

| TOTAL SYSTEM QUANTITIES | NORM POWR          | POWR (MW)              | HEAT REM (BTU/HR)     | ENGY LEAK (BTU)        | MASS LEAK (LB) | ENGY BAL. (BTU)          | MASS BAL. (LB)     | TOT. REAC (\$)                     | REAC T SEC.    |             |
|-------------------------|--------------------|------------------------|-----------------------|------------------------|----------------|--------------------------|--------------------|------------------------------------|----------------|-------------|
|                         | 1.00000D 00        | 5.00000D 01            | 1.70650D 08           | 0.0                    | 0.0            | 1.58648D 07              | 2.92802D 04        | 0.0                                | 0.0            |             |
| VOLUME NUMBER           | AVG. PRES PSIA     | TOT. MASS (LB)         | AVG. ENTH (BTU/LB)    | AVG. DENS (LB/FT3)     | AVG. TEMP (F)  | AVG. QUAL                | BUBB MASS (LB)     | MIXT LEVL (FT)                     | LIQ. MASS (LB) |             |
| 1                       | 2.40000D 03        | 1.64239D 04            | 5.47259D 02           | 4.69256D 01            | 5.50000D 02    | 0.0                      | 0.0                | 1.10000D 01                        | 1.64239D 04    |             |
| 2                       | 2.40881D 03        | 1.21523D 04            | 5.13059D 02           | 4.86092D 01            | 5.21500D 02    | 0.0                      | 0.0                | 8.00000D 00                        | 1.21523D 04    |             |
| 3                       | 2.40561D 03        | 7.03923D 02            | 5.47260D 02           | 4.69282D 01            | 5.50000D 02    | 0.0                      | 0.0                | 3.00000D 00                        | 7.03923D 02    |             |
| VOLUME NUMBER           | HEAT TRANS. MODE   | SURF FLUX (BTU/HR/FT2) | DNB FLUX (BTU/HR/FT2) | H.T. COEF (BTU/H/F2/F) | SURF TEMP (F)  | FUEL TEMP (F)            | CENT TEMP (F)      | POWR H2O (BTU/HR)                  | FUEL POWR (MW) |             |
| 2                       |                    |                        |                       |                        |                |                          |                    | -1.70650D 08                       |                |             |
| 3                       | 1                  | 1.59785D 05            | 1.60811D 06           | 2.78836D 03            | 6.07304D 02    | 8.57031D 02              | 1.21619D 03        | 1.70650D 08                        | 5.00000D 01    |             |
| VOLUME NUMBER           | NODE               | TEMP                   | NODE                  | TEMP                   | NODE           | TEMP                     |                    |                                    |                |             |
| 3                       | 2                  | 1.14373D 03            | 4                     | 6.54849D 02            | 7              | 6.25540D 02              |                    |                                    |                |             |
| JUNCTION NUMBER         | CONNECTING VOLUMES | CHOKE                  | JCT. FLOW (LB/SEC)    | JCT. ENTH (BTU/LB)     | JCT. QUAL      | P R E S S U R E TOT. PSI | S S U R E ELEV PSI | D I F F E R E N T I A L S FRIC PSI | A C C L PSI    | P U M P PSI |
| 1                       | 1 TO               | 0 NO                   | 0.0                   | 5.47259D 02            | 0.0            | 0.0                      | 0.0                | 0.0                                | 0.0            | 0.0         |
| 2                       | 2 TO               | 3 NO                   | 1.39000D 03           | 5.13059D 02            | 0.0            | 3.20000D 00              | -1.86292D -01      | 3.38629D 00                        | 6.66134D -16   | 0.0         |
| 3                       | 3 TO               | 1 NO                   | 1.39000D 03           | 5.47260D 02            | 0.0            | 5.61000D 00              | 2.11820D 00        | 3.49180D 00                        | 6.66134D -16   | 0.0         |
| 4                       | 1 TO               | 2 NO                   | 1.39000D 03           | 5.47259D 02            | 0.0            | -8.81000D 00             | -1.99031D 00       | 9.45191D 01                        | 4.26326D -14   | 1.01339D 02 |

105

TIME STEP = 0, TIME = 0.0 , PAGE = 11

RESTART DATA BEING DUMPED.



TIME STEP NUM 2500. TIME = 0.500000D 00 SEC.

| TOTAL SYSTEM QUANTITIES | NORM POWR          | POWR (MW)              | HEAT REM (BTU/HR)     | ENGY LEAK (BTU)        | MASS LEAK (LB) | ENGY EAL. (BTU)          | MASS BAL. (LB)   | TOT. REAC (\$)             | REAC T SEC.        |             |
|-------------------------|--------------------|------------------------|-----------------------|------------------------|----------------|--------------------------|------------------|----------------------------|--------------------|-------------|
|                         | 1.40516D-01        | 7.02729D 00            | 1.05567D 08           | 1.80607D 06            | 3.33328D 03    | 1.58651D 07              | 2.92802D 04      | -1.06540D 01               | -4.50638D-01       |             |
| VOLUME NUMBER           | AVG. PRES PSIA     | TOT. MASS (LB)         | AVG. ENTH (BTJ/LB)    | AVG. DENS (LB/FT3)     | AVG. TEMP (F)  | AVG. QUAL                | BUBB MASS (LB)   | MIXT LEVL (FT)             | LIQ. MASS (LB)     |             |
| 1                       | 9.46548D 02        | 1.32170D 04            | 5.41241D 02           | 3.77630D 01            | 5.37532D 02    | 1.12582D-02              | 1.33279D 02      | 1.07691D 01                | 1.30682D 04        |             |
| 2                       | 9.48882D 02        | 1.20254D 04            | 5.07302D 02           | 4.81016D 01            | 5.15971D 02    | 0.0                      | 0.0              | 8.00000D 00                | 1.20254D 04        |             |
| 3                       | 1.01115D 03        | 7.04460D 02            | 5.30032D 02           | 4.69640D 01            | 5.34412D 02    | 0.0                      | 0.0              | 3.00000D 00                | 7.04460D 02        |             |
| VOLUME NUMBER           | HEAT TRANS. MODE   | SURF FLUX (BTU/HR/FT2) | DNB FLUX (BTU/HR/FT2) | H.T. COEF (BTU/H/F2/F) | SURF TEMP (F)  | FUEL TEMP (F)            | CENT TEMP (F)    | POWR H2O (BTU/HR)          | FUEL POWR (MW)     |             |
| 2                       |                    |                        |                       |                        |                |                          |                  | -1.05567D 08               |                    |             |
| 3                       | 7                  | 9.52429D 04            | 6.29255D 05           | 7.58227D 02            | 6.60047D 02    | 8.58335D 02              | 1.19486D 03      | 1.01719D 08                | 7.02729D 00        |             |
| VOLUME NUMBER           | NODE               | TEMP                   | NODE                  | TEMP                   | NODE           | TEMP                     |                  |                            |                    |             |
| 3                       | 2                  | 1.12245D 03            | 4                     | 6.77952D 02            | 7              | 6.65965D 02              |                  |                            |                    |             |
| JUNCTION NUMBER         | CONNECTING VOLUMES | CHOKE                  | JCT. FLOW (LB/SEC)    | JCT. ENTH (BTJ/LB)     | JCT. QUAL      | P R E S S U R E TOT. PSI | S U R E ELEV PSI | D I F F E R E N T FRIC PSI | T I A L S ACCL PSI | P U M P PSI |
| 1                       | 1 TO 0             | YES                    | 6.68164D 03           | 5.41227D 02            | 1.12326D-02    | 8.96548D 02              | 0.0              | 0.0                        | 0.0                | 0.0         |
| 2                       | 2 TO 3             | NO                     | 6.59437D 02           | 5.07302D 02            | 0.0            | -6.22682D 01             | -1.78870D-01     | 7.69969D-01                | -6.28593D 01       | 0.0         |
| 3                       | 3 TO 1             | NO                     | 1.22922D 03           | 5.30032D 02            | 0.0            | 6.46025D 01              | 1.81672D 00      | 2.72943D 00                | 6.00564D 01        | 0.0         |
| 4                       | 1 TO 2             | NO                     | 9.48029D 02           | 5.37294D 02            | 5.28367D-03    | -2.33431D 00             | -1.72867D 00     | 4.95626D 01                | -9.26254D 00       | 4.09057D 01 |

108

THREE VOLUME TEST PROBLEM WITH REACTOR KINETICS ETC. MAY, 1970

TIME = 143.37 PAGE 14

TIME STEP = 2500, TIME = 0.500000D 00, PAGE = 14  
RESTART DATA BEING DUMPED.





TIME STEP NUM 4000. TIME = 0.200000D 01 SEC.

| TOTAL SYSTEM QUANTITIES | NORM POWR   | POWR (MW)   | HEAT REM (BTU/HR) | ENGY LEAK (BTU) | MASS LEAK (LB) | ENGY BAL. (BTU) | MASS BAL. (LB) | TOT. REAC (\$) | REAC T SEC.  |
|-------------------------|-------------|-------------|-------------------|-----------------|----------------|-----------------|----------------|----------------|--------------|
|                         | 8.02307D-02 | 4.01200D 00 | 1.47839D 08       | 6.53007D 06     | 1.20479D 04    | 1.58649D 07     | 2.92802D 04    | -2.92743D 01   | -3.12043D 00 |

| VOLUME NUMBER | AVG. PRES PSIA | TOT. MASS (LB) | AVG. ENTH (BTU/LB) | AVG. DENS (LB/FT3) | AVG. TEMP (F) | AVG. QUAL.  | BUBB MASS (LB) | MIXT LEVL (FT) | LIQ. MASS (LB) |
|---------------|----------------|----------------|--------------------|--------------------|---------------|-------------|----------------|----------------|----------------|
| 1             | 6.89313D 02    | 6.23682D 03    | 5.28174D 02        | 1.78195D 01        | 5.00495D 02   | 5.53358D-02 | 1.51058D 02    | 6.94439D 00    | 5.89170D 03    |
| 2             | 7.51446D 02    | 1.05093D 04    | 5.04250D 02        | 4.20373D 01        | 5.10438D 02   | 5.28870D-03 | 4.84508D 01    | 7.86141D 00    | 1.04537D 04    |
| 3             | 7.27052D 02    | 4.86104D 02    | 5.07867D 02        | 3.24069D 01        | 5.06535D 02   | 1.68756D-02 | 8.20331D 00    | 3.00000D 00    | 4.77900D 02    |

| VOLUME NUMBER | HEAT TRANS. MODE | SURF FLUX (BTU/HR/FT2) | DNB FLUX (BTU/HR/FT2) | H.T. COEF (BTU/H/F2/F) | SURF TEMP (F) | FUEL TEMP (F) | CENT TEMP (F) | POWR H2O (BTU/HR) | FUEL POWR (MW) |
|---------------|------------------|------------------------|-----------------------|------------------------|---------------|---------------|---------------|-------------------|----------------|
| 2             |                  |                        |                       |                        |               |               |               |                   |                |
| 3             | 7                | 4.34472D 04            | 1.56937D 06           | 1.85656D 02            | 7.40570D 02   | 8.51294D 02   | 1.07345D 03   | -1.47839D 08      | 4.01200D 00    |

| VOLUME NUMBER | NODE | TEMP        | NODE | TEMP        | NODE | TEMP        |
|---------------|------|-------------|------|-------------|------|-------------|
| 3             | 2    | 1.01489D 03 | 4    | 7.53443D 02 | 7    | 7.45428D 02 |

| JUNCTION NUMBER | CONNECTING VOLUMES | CHOKE | JCT. FLOW (LB/SEC) | JCT. ENTH (BTU/LB) | JCT. QUAL   | P R E S S U R E TOT. PSI | S U R E ELEV PSI | D I F F E R E N T F R I C PSI | E R E N T A C C L PSI | I A L S P U M P PSI |
|-----------------|--------------------|-------|--------------------|--------------------|-------------|--------------------------|------------------|-------------------------------|-----------------------|---------------------|
| 1               | 1 TO 0             | YES   | 4.89993D 03        | 5.40929D 02        | 7.31058D-02 | 6.39313D 02              | 0.0              | 0.0                           | 0.0                   | 0.0                 |
| 2               | 2 TO 3             | NO    | 3.45534D 03        | 5.02422D 02        | 2.65637D-03 | 2.43938D 01              | -2.10376D-01     | 2.45432D 01                   | 6.09811D-02           | 0.0                 |
| 3               | 3 TO 1             | NO    | 3.55960D 03        | 5.07807D 02        | 1.68667D-02 | 3.77393D 01              | 9.47638D-01      | 3.67246D 01                   | 6.70540D-02           | 0.0                 |
| 4               | 1 TO 2             | NO    | -8.06107D 02       | 5.06271D 02        | 8.13682D-03 | -6.21332D 01             | -1.00818D 00     | -4.78808D 01                  | -1.32442D 01          | 0.0                 |

111

TIME STEP NUM 5000. TIME = 0.7000000 01 SEC.

| TOTAL SYSTEM QUANTITIES | NORM POWR          | POWR (MW)              | HEAT REM (BTU/HR)     | ENGY LEAK (BTU)        | MASS LEAK (LB) | ENGY BAL. (BTU)          | MASS BAL. (LB)   | TOT. REAC (\$)             | REAC T SEC.        |             |
|-------------------------|--------------------|------------------------|-----------------------|------------------------|----------------|--------------------------|------------------|----------------------------|--------------------|-------------|
|                         | 5.93840D-02        | 2.96962D 00            | -6.29579D 06          | 1.39252D 07            | 2.57705D 04    | 1.58611D 07              | 2.92802D 04      | -4.73328D 01               | -8.61183D 00       |             |
| VOLUME NUMBER           | AVG. PRES PSIA     | TOT. MASS (LB)         | AVG. ENTH (BTU/LB)    | AVG. DENS (LB/FT3)     | AVG. TEMP (F)  | AVG. QUAL                | BUBB MASS (LB)   | MIXT LEVL (FT)             | LIQ. MASS (LB)     |             |
| 1                       | 1.65605D 02        | 2.58980D 03            | 3.72762D 02           | 7.39944D 00            | 3.63238D 02    | 4.29195D-02              | 5.29043D 01      | 5.97686D 00                | 2.47865D 03        |             |
| 2                       | 1.72732D 02        | 8.57871D 02            | 4.29278D 02           | 3.43148D 00            | 3.67085D 02    | 1.04412D-01              | 6.85809D 01      | 6.23008D 00                | 7.68298D 02        |             |
| 3                       | 1.69981D 02        | 6.20118D 01            | 4.10503D 02           | 4.13412D 00            | 3.65600D 02    | 8.41705D-02              | 5.21956D 00      | 3.00000D 00                | 5.67922D 01        |             |
| VOLUME NUMBER           | HEAT TRANS. MODE   | SURF FLUX (BTU/HR/FT2) | DNB FLUX (BTU/HR/FT2) | H.T. COEF (BTU/H/F2/F) | SURF TEMP (F)  | FUEL TEMP (F)            | CENT TEMP (F)    | POWR H2O (BTU/HR)          | FUEL POWR (MW)     |             |
| 2                       |                    |                        |                       |                        |                |                          |                  | 6.29579D 06                |                    |             |
| 3                       | 7                  | 1.84228D 04            | 5.00380D 05           | 4.70921D 01            | 7.56974D 02    | 7.97990D 02              | 8.68935D 02      | 1.96755D 07                | 2.96962D 00        |             |
| VOLUME NUMBER           |                    | NODE                   | TEMP                  | NODE                   | TEMP           | NODE                     | TEMP             |                            |                    |             |
| 3                       |                    | 2                      | 8.52648D 02           | 4                      | 7.62546D 02    | 7                        | 7.59107D 02      |                            |                    |             |
| JUNCTION NUMBER         | CONNECTING VOLUMES | CHOKE                  | JCT. FLOW (LB/SEC)    | JCT. EMTH (BTU/LE)     | JCT. QUAL      | P R E S S U R E TOT. PSI | S U R E ELEV PSI | D I F F E R E N T FRIC PSI | T I A L S ACCL PSI | P U M P PSI |
| 1                       | 1 TO 0             | YES                    | 1.31109D 03           | 4.67792D 02            | 1.53652D-01    | 1.15605D 02              | 0.0              | 0.0                        | 0.0                | 0.0         |
| 2                       | 2 TO 3             | NO                     | 4.13244D 02           | 3.94321D 02            | 6.34908D-02    | 2.75122D 00              | 2.60016D-02      | 2.73474D 00                | -9.52092D-03       | 0.0         |
| 3                       | 3 TO 1             | NO                     | 4.41579D 02           | 4.10503D 02            | 8.41102D-02    | 4.37617D 00              | 2.84183D-01      | 4.10207D 00                | -1.00868D-02       | 0.0         |
| 4                       | 1 TO 2             | NO                     | -3.33836D 01          | 1.19529D 03            | 1.00000D 00    | -7.12739D 00             | -5.62538D-02     | -7.18745D 00               | 1.26310D-01        | 0.0         |

112

TIME STEP = 5000, TIME = 0.7000000 01, PAGE = 37  
RESTART DATA BEING DUMPED.



TIME STEP NUM 5825. TIME = 0.1112500 02 SEC.

| TOTAL SYSTEM QUANTITIES | NORM POWR          | POWR (MW)              | HEAT REM (BTU/HR)     | ENGY LEAK (BTU)        | MASS LEAK (LB) | ENGY BAL. (BTU)          | MASS BAL. (LB)      | TOT. REAC (\$)                | REAC T SEC.           |                     |
|-------------------------|--------------------|------------------------|-----------------------|------------------------|----------------|--------------------------|---------------------|-------------------------------|-----------------------|---------------------|
|                         | 5.432300-02        | 2.716230 00            | -9.701120 05          | 1.490740 07            | 2.800340 04    | 1.586060 07              | 2.928020 04         | -4.925920 01                  | 1.569430 01           |                     |
| VOLUME NUMBER           | AVG. PRES PSIA     | TOT. MASS (LB)         | AVG. ENTH (BTU/LB)    | AVG. DENS (LB/FT3)     | AVG. TEMP (F)  | AVG. QUAL                | BUBB MASS (LB)      | MIXT LEVL (FT)                | LIQ. MASS (LB)        |                     |
| 1                       | 4.999270 01        | 8.848490 02            | 2.913230 02           | 2.528140 00            | 2.810010 02    | 4.451390-02              | 2.010840 01         | 5.840390 00                   | 8.454610 02           |                     |
| 2                       | 4.956000 01        | 3.744760 02            | 3.194940 02           | 1.497910 00            | 2.801550 02    | 7.588730-02              | 0.0                 | 1.912060-01                   | 3.460580 02           |                     |
| 3                       | 4.977080 01        | 1.746060 01            | 3.409140 02           | 1.164040 00            | 2.805670 02    | 9.863530-02              | 1.722230 00         | 3.000000 00                   | 1.573830 01           |                     |
| VOLUME NUMBER           | HEAT TRANS. MODE   | SURF FLUX (BTU/HR/FT2) | DNB FLUX (BTU/HR/FT2) | H.T. COEF (BTU/H/F2/F) | SURF TEMP (F)  | FUEL TEMP (F)            | CENT TEMP (F)       | POWR H2O (BTU/HR)             | FUEL POWR (MW)        |                     |
| 2                       |                    |                        |                       |                        |                |                          |                     | 9.701120 05                   |                       |                     |
| 3                       | 7                  | 8.640030 03            | 2.254360 05           | 1.743950 01            | 7.759510 02    | 7.934580 02              | 8.220690 02         | 9.227560 06                   | 2.716230 00           |                     |
| VOLUME NUMBER           | NODE               | TEMP                   | NODE                  | TEMP                   | NODE           | TEMP                     |                     |                               |                       |                     |
| 3                       | 2                  | 8.157870 02            | 4                     | 7.788600 02            | 7              | 7.770380 02              |                     |                               |                       |                     |
| JUNCTION NUMBER         | CONNECTING VOLUMES | CHOKE                  | JCT. FLOW (LB/SEC)    | JCT. ENTH (BTU/LB)     | JCT. QUAL      | P R E S S U R E TOT. PSI | S U R F E L E V PSI | D I F F E R E N T F R I C PSI | E R E N T A C C L PSI | I A L S P U M P PSI |
| 1                       | 1 TO 0             | NO                     | 0.0                   | 1.174090 03            | 1.000000 00    | -7.302390-03             | 0.0                 | 0.0                           | 0.0                   | 0.0                 |
| 2                       | 2 TO 3             | NO                     | -5.386570 01          | 3.409140 02            | 1.028450-01    | -2.107880-01             | 1.342000-02         | -2.131860-01                  | -1.102230-02          | 0.0                 |
| 3                       | 3 TO 1             | NO                     | -1.884160 02          | 2.624970 02            | 1.333140-02    | -2.218820-01             | 9.389000-02         | -3.972790-01                  | 8.150750-02           | 0.0                 |
| 4                       | 1 TO 2             | NO                     | 3.691630 01           | 2.693060 02            | 2.067810-02    | 4.326700-01              | 2.124500-03         | 6.458490-01                   | -2.153040-01          | 0.0                 |

115

TIME STEP = 5825, TIME = 0.1112500 02, PAGE = 49

RESTART DATA BEING DUMPED.

TRAILER LABEL BEING WRITTEN.

END TRIP SIGNAL.

THREE VOLUME TEST PROBLEM WITH REACTOR KINETICS ETC. MAY, 1970

TIME = 382.30 PAGE 51

END 220

END-OF-DATA (BLANK CARD) ENCOUNTERED.

117

THREE VOLUME TEST PROBLEM RESTARTED FROM TAPE

TIME = 0.0 PAGE 1

THREE VOLUME TEST PROBLEM RESTARTED FROM TAPE

TITL 10

MISCELLANEOUS PROBLEM CONTROL DATA.

TAPE NUM NUM  
DUMP EDIT TIME  
0=NO VAR SETS

37 8 2

CONT 20

OLD RELAP3 PROBLEM WAS TITLED

THREE VOLUME TEST PROBLEM WITH REACTOR KINETICS ETC. MAY, 1970

DUMP AT PAGE NUMBER 37 HAS BEEN FOUND.

SUCCESSFUL RESTART, ENTERING TRANSIENT ROUTINE.

EDIT IDENTIFICATION NUMBERS

|      |      |      |      |      |      |      |      |   |
|------|------|------|------|------|------|------|------|---|
| 1    | 2    | 3    | 4    | 5    | 6    | 7    | 8    | 9 |
| JW 2 | JW 3 | AX 3 | FT 3 | ST 3 | HC 3 | DF 3 | SF 3 | 0 |

EDIT 30

DATA FOR 2 TIME STEP SETS.

| SET<br>NUM | T S<br>PER<br>BRF | BRF<br>PER<br>LRG | LRG<br>PER<br>RST | T S<br>PER<br>PLT | TIME<br>STEP<br>SIZE | END<br>OF<br>INTERVAL |
|------------|-------------------|-------------------|-------------------|-------------------|----------------------|-----------------------|
| 1          | 4                 | 50                | 3                 | 10                | 0.500000D-02         | 0.100000D 02          |
| 2          | 4                 | 50                | 4                 | 10                | 0.500000D-02         | 0.200000D 02          |

TIME 40

TIME 41



THREE VOLUME TEST PROBLEM RESTARTED FROM TAPE

TIME = 1.21 PAGE 36

TIME STEP NUM 5000. TIME = 0.7000000 01 SEC.

| TOTAL SYSTEM QUANTITIES | NORM POWR          | POWR (MW)              | HEAT REM (BTU/HR)     | ENGY LEAK (BTU)        | MASS LEAK (LB) | ENGY BAL. (BTU)          | MASS BAL. (LB)   | TOT. REAC (\$)             | REAC T SEC.         |                 |
|-------------------------|--------------------|------------------------|-----------------------|------------------------|----------------|--------------------------|------------------|----------------------------|---------------------|-----------------|
|                         | 5.938400-02        | 2.96962D 00            | -6.29579D 06          | 1.39252D 07            | 2.57705D 04    | 1.58611D 07              | 2.92802D 04      | -4.73328D 01               | -8.61183D 00        |                 |
| VOLUME NUMBER           | AVG. PRES PSIA     | TOT. MASS (LB)         | AVG. ENTH (BTU/LB)    | AVG. DENS (LB/FT3)     | AVG. TEMP (F)  | AVG. QUAL.               | BUBB MASS (LB)   | MIXT LEVL (FT)             | LIQ. MASS (LB)      |                 |
| 1                       | 1.65605D 02        | 2.58980D 03            | 3.72762D 02           | 7.39944D 00            | 3.63238D 02    | 4.29195D-02              | 5.29043D 01      | 5.97686D 00                | 2.47865D 03         |                 |
| 2                       | 1.72732D 02        | 8.57871D 02            | 4.29278D 02           | 3.43148D 00            | 3.67085D 02    | 1.04412D-01              | 6.85809D 01      | 6.23008D 00                | 7.68298D 02         |                 |
| 3                       | 1.69981D 02        | 6.20118D 01            | 4.10503D 02           | 4.13412D 00            | 3.65600D 02    | 8.41705D-02              | 5.21956D 00      | 3.00000D 00                | 5.67922D 01         |                 |
| VOLUME NUMBER           | HEAT TRANS. MODE   | SURF FLUX (BTU/HR/FT2) | DNB FLUX (BTU/HR/FT2) | H.T. COEF (BTU/H/F2/F) | SURF TEMP (F)  | FUEL TEMP (F)            | CENT TEMP (F)    | POWR H2O (BTU/HR)          | FUEL POWR (MW)      |                 |
| 2                       |                    |                        |                       |                        |                |                          |                  | 6.29579D 06                |                     |                 |
| 3                       | 7                  | 1.84228D 04            | 5.00380D 05           | 4.70921D 01            | 7.56974D 02    | 7.97990D 02              | 8.68935D 02      | 1.96755D 07                | 2.96962D 00         |                 |
| VOLUME NUMBER           |                    | NODE                   | TEMP                  | NODE                   | TEMP           | NODE                     | TEMP             |                            |                     |                 |
| 3                       |                    | 2                      | 8.52648D 02           | 4                      | 7.62546D 02    | 7                        | 7.59107D 02      |                            |                     |                 |
| JUNCTION NUMBER         | CONNECTING VOLUMES | CHOKE                  | JCT. FLCW (LB/SEC)    | JCT. ENTH (BTU/LB)     | JCT. QUAL      | P R E S S U R E TOT. PSI | S U R E ELEV PSI | D I F F E R E N T FRIC PSI | T I A L S ACCL. PSI | P U M P P S I . |
| 1                       | 1 TO 0             | YES                    | 1.31109D 03           | 4.67793D 02            | 1.53652D-01    | 1.15605D 02              | 0.0              | 0.0                        | 0.0                 | 0.0             |
| 2                       | 2 TO 3             | NO                     | 4.13244D 02           | 3.94321D 02            | 6.34908D-02    | 2.75122D 00              | 2.60016D-02      | 2.73474D 00                | -9.52092D-03        | 0.0             |
| 3                       | 3 TO 1             | NO                     | 4.41579D 02           | 4.10503D 02            | 8.41102D-02    | 4.37617D 00              | 2.84183D-01      | 4.10207D 00                | -1.00868D-02        | 0.0             |
| 4                       | 1 TO 2             | NO                     | -3.33836D 01          | 1.19529D 03            | 1.00000D 00    | -7.12739D 00             | -6.62538D-02     | -7.18745D 00               | 1.26310D-01         | 0.0             |

619

THREE VOLUME TEST PROBLEM RESTARTED FROM TAPE

TIME = 1.26 PAGE 37

120

TIME STEP = 5000, TIME = 0.700000D 01, PAGE = 37  
RESTART DATA BEING DUMPED.



THREE VOLUME TEST PROBLEM RESTARTED FROM TAPE

TIME = 57.14 PAGE 48

TIME STEP NUM 5825. TIME = 0.1112500 02 SEC.

| TOTAL SYSTEM QUANTITIES | NORM POWR          | POWR (MW)              | HEAT REM (BTU/HR)     | ENGY LEAK (BTU)        | MASS LEAK (LB) | ENGY BAL. (BTU)          | MASS BAL. (LB)   | TOT. REAC (\$)                | REAC T SEC.    |                     |
|-------------------------|--------------------|------------------------|-----------------------|------------------------|----------------|--------------------------|------------------|-------------------------------|----------------|---------------------|
|                         | 5.432300-02        | 2.716230 00            | -9.701120 05          | 1.490740 07            | 2.800340 04    | 1.586050 07              | 2.928020 04      | -4.925920 01                  | 1.569430 01    |                     |
| VOLUME NUMBER           | AVG. PRES PSIA     | TOT. MASS (LB)         | AVG. ENTH (BTU/LB)    | AVG. DENS (LB/FT3)     | AVG. TEMP (F)  | AVG. QUAL                | BUBB MASS (LB)   | MIXT LEVL (FT)                | LIQ. MASS (LB) |                     |
| 1                       | 4.999270 01        | 8.848490 02            | 2.913230 02           | 2.528140 00            | 2.810010 02    | 4.451390-02              | 2.010840 01      | 5.840390 00                   | 8.454610 02    |                     |
| 2                       | 4.956000 01        | 3.744760 02            | 3.194940 02           | 1.497910 00            | 2.801550 02    | 7.58E730-02              | 0.0              | 1.912060-01                   | 3.460580 02    |                     |
| 3                       | 4.977080 01        | 1.746060 01            | 3.409140 02           | 1.164040 00            | 2.805670 02    | 9.862530-02              | 1.722230 00      | 3.000000 00                   | 1.573830 01    |                     |
| VOLUME NUMBER           | HEAT TRANS. MODE   | SURF FLUX (BTU/HR/FT2) | DNB FLUX (BTU/HR/FT2) | H.T. COEF (BTU/H/F2/F) | SURF TEMP (F)  | FUEL TEMP (F)            | CENT TEMP (F)    | POWR H2O (BTU/HR)             | FUEL POWR (MW) |                     |
| 2                       |                    |                        |                       |                        |                |                          |                  | 9.701120 05                   |                |                     |
| 3                       | 7                  | 8.640030 03            | 2.254360 05           | 1.743950 01            | 7.759510 02    | 7.9345E0 02              | 8.220690 02      | 9.227560 06                   | 2.716230 00    |                     |
| VOLUME NUMBER           | NODE               | TEMP                   | NODE                  | TEMP                   | NODE           | TEMP                     |                  |                               |                |                     |
| 3                       | 2                  | 8.157870 02            | 4                     | 7.788600 02            | 7              | 7.770380 02              |                  |                               |                |                     |
| JUNCTION NUMBER         | CONNECTING VOLUMES | CHOKE                  | JCT. FLOW (LB/SEC)    | JCT. ENTH (BTU/LB)     | JCT. QUAL      | P R E S S U R E TOT. PSI | S U R E ELEV PSI | D I F F E R E N T F R I C PSI | A C C L PSI    | I A L S P U M P PSI |
| 1                       | 1 TO 0             | NO                     | 0.0                   | 1.174090 03            | 1.000000 00    | -7.302390-03             | 0.0              | 0.0                           | 0.0            | 0.0                 |
| 2                       | 2 TO 3             | NO                     | -5.386570 01          | 3.409140 02            | 1.028450-01    | -2.107880-01             | 1.342000-02      | -2.131860-01                  | -1.102230-02   | 0.0                 |
| 3                       | 3 TO 1             | NO                     | -1.884160 02          | 2.624970 02            | 1.333140-02    | -2.218820-01             | 5.389000-02      | -3.972790-01                  | 8.150750-02    | 0.0                 |
| 4                       | 1 TO 2             | NO                     | 3.691630 01           | 2.693060 02            | 2.067810-02    | 4.326700-01              | 2.124500-03      | 6.458490-01                   | -2.153040-01   | 0.0                 |

THREE VOLUME TEST PROBLEM RESTARTED FROM TAPE

TIME = 57.21 PAGE 49

TIME STEP = 5825, TIME = 0.1112500 02, PAGE = 49

RESTART DATA BEING DUMPED.

TRAILER LABEL BEING WRITTEN.

122

THREE VOLUME TEST PROBLEM RESTARTED FROM TAPE

TIME = 57.21 PAGE 50

END TRIP SIGNAL.

THREE VOLUME TEST PROBLEM RESTARTED FROM TAPE

TIME = 57.21 PAGE 51

END 220

END-OF-DATA (BLANK CARD) ENCOUNTERED.

128