**The National Carbon Capture Center
at the Power Systems Development Facility**

Topical Report

Budget Period Four

January 1, 2012 – December 31, 2012

DOE Cooperative Agreement
DE-NT0000749

The National Carbon Capture Center
at the Power Systems Development Facility

Topical Report
Budget Period Four
January 1, 2012 – December 31, 2012

Prepared by:

Southern Company Services, Inc.
Power Systems Development Facility
P.O. Box 1069, Wilsonville, AL 35186
Phone: 205-670-5840

Fax: 205-670-5843

E-mail: nccc@southernco.com

<http://www.NationalCarbonCaptureCenter.com>

Disclaimer

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, nor Southern Company Services, Inc., nor any of its employees, nor any of its subcontractors, nor any of its sponsors or co-funders, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report is available to the public from the National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, VA 22161. Phone orders are accepted at (703) 487-4650.

Abstract

The Power Systems Development Facility (PSDF) is a state-of-the-art test center sponsored by the U.S. Department of Energy and dedicated to the advancement of clean coal technology. In addition to the development of high efficiency coal gasification processes, the PSDF features the National Carbon Capture Center (NCCC) to promote new technologies for CO₂ capture from coal-derived syngas and flue gas.

The NCCC includes multiple, adaptable test skids that allow technology development of CO₂ capture concepts using coal-derived syngas and flue gas in industrial settings. Because of the ability to operate under a wide range of flow rates and process conditions, research at the NCCC can effectively evaluate technologies at various levels of maturity and accelerate their development path to commercialization.

During the calendar year 2012 portion of the Budget Period Four reporting period, efforts at the NCCC focused on testing of pre- and post-combustion CO₂ capture processes and gasification support technologies. Preparations for future testing were on-going as well, and involved facility upgrades and collaboration with numerous technology developers.

In the area of pre-combustion, testing was conducted on a new water-gas shift catalyst, a CO₂ solvent, and gas separation membranes from four different technology developers, including two membrane systems incorporating major scale-ups. Post-combustion tests involved advanced solvents from three major developers, a gas separation membrane, and two different enzyme technologies. An advanced sensor for gasification operation was evaluated, operation with biomass co-feeding with coal under oxygen-blown conditions was achieved, and progress continued on refining several gasification support technologies.

Acknowledgement

The authors wish to acknowledge the contributions and support provided by DOE project manager Morgan “Mike” Mosser. We would also like to thank our co-funding partners: the Electric Power Research Institute, American Electric Power, Luminant, NRG Energy, Arch Coal, Peabody Energy, and Rio Tinto. The material in this report is based upon work supported by the DOE under award DE-NT0000749. However, any opinions, findings, conclusions, or recommendations expressed herein are those of the authors and do not necessarily reflect the views of the DOE.

Table of Contents

Disclaimer	iii
Abstract	iv
Acknowledgement	v
List of Figures	ix
List of Tables	xii
List of Abbreviations and Acronyms	xiii
1.0 EXECUTIVE SUMMARY	1
1.1 Pre-Combustion CO ₂ Capture Testing	2
1.2 Post-Combustion CO ₂ Capture Testing	3
1.3 Gasification Technology Testing	4
1.4 Milestones for 2012	4
2.0 PRE-COMBUSTION CO ₂ CAPTURE	6
2.1 Syngas Conditioning Unit Modifications	6
2.1.1 SCU Upgrades	7
2.1.2 SCU Expansion and Syngas Cleaning System	7
2.2 Water-Gas Shift Catalyst	8
2.3 Worcester Polytechnic Institute Membranes	10
2.4 Membrane Technology & Research Membranes	13
2.4.1 MTR 500-lb/hr CO ₂ Membrane System	14
2.4.2 MTR 50 lb/hr CO ₂ Membrane and Hydrogen Stamp Membrane	15
2.5 Media & Process Technology Membrane	16
2.6 Eltron Membrane	19
2.7 Membrane Material Coupon Testing	21
2.8 TDA Research Sorbent	23
2.9 University of Alabama Solvent	23
2.10 Ohio State University Syngas Chemical Looping	25
3.0 POST-COMBUSTION CO ₂ CAPTURE	26
3.1 PC4 Modifications	26

Table of Contents (Cont'd)

3.1.1	Balance of Plant Upgrades.....	26
3.1.2	Slipstream Solvent Test Unit.....	27
3.2	MEA Baseline Test Campaign.....	28
3.2.1	PSTU Description.....	28
3.2.2	MEA Carryover	29
3.2.3	Amine and Degradation Product Carryover	32
3.2.4	Breakdown Products Detected in Solvent	34
3.2.5	Metal Accumulation in Solvent.....	34
3.2.6	Anion Accumulation in Solvent.....	37
3.2.7	Solvent Metals Removal	38
3.2.8	Oxygen Content of CO ₂ from Regenerator	41
3.2.9	Additional MEA Testing	41
3.3	Hitachi Solvent.....	41
3.4	BASF / Linde Solvent and Process	45
3.5	Cansolv Technologies Solvent.....	46
3.5.1	Optimization of Energy vs. L/G Ratio.....	48
3.5.2	Variation of Packing Height	49
3.5.3	Amine Concentration Experiments.....	50
3.5.4	Liquid Analysis.....	50
3.5.5	Gas Sampling.....	53
3.5.6	Preliminary Conclusions.....	54
3.5.7	Future Testing with Natural Gas-Simulated Flue Gas.....	54
3.6	Chiyoda Solvent.....	55
3.7	MTR 1-ton/day CO ₂ Capture Membrane Skid	56
3.8	MTR 20-ton/day CO ₂ Capture Membrane Skid	61
3.9	Codexis Enzymes	62
3.10	Akermin Enzymes	63
3.11	Engineering Studies	64
4.0	GASIFICATION	66

Table of Contents (Cont'd)

4.1	Gasification Operation.....	66
4.2	Oxygen-Blown Biomass Co-Feeding.....	68
4.2.1	Test Objectives and Results	68
4.2.2	Oxygen Supply System.....	73
4.3	Hot Gas Filtration	74
4.4	Sensor Development	74
4.4.1	Sapphire Thermowell.....	75
4.4.2	Densflow Coal Flow Meter.....	76
4.4.3	Coal Feeder Level Probes.....	77
4.5	Gasification Process Modifications	77
4.5.1	Gasifier Standpipe Replacement	77
4.5.2	PCD Tubesheet Repair	79
4.5.3	Primary Gas Cooler	80
4.5.4	Pressure Letdown Device Design Modifications	80
4.6	Stanford University Tunable Diode Laser	80
4.6.1	Stanford’s Development Work	81
4.6.2	Test Objectives and Sensor Installation.....	83
4.6.3	TDL Sensor Design for H ₂ O and Temperature Measurements.....	84
4.6.4	TDL Sensor Testing and Results	84
4.6.5	Summary and Conclusions.....	88
4.7	Engineering Studies	89
5.0	CONCLUSIONS AND LESSONS LEARNED	90
5.1	Pre-Combustion.....	90
5.2	Post-Combustion	91
5.3	Gasification.....	95

List of Figures

Figure 1. NCCC/PSDF Facilities.	2
Figure 2. Syngas Conditioning Unit.	6
Figure 3. SCU Expansion Area Housing Syngas Cleaning System.....	8
Figure 4. SCU Reactor Vessels Used for WGS Catalyst Evaluation.	9
Figure 5. Water-Gas Shift Catalyst Test Results for Runs R07 through R09.	10
Figure 6. WPI Hydrogen Membranes.....	11
Figure 7. WPI Membrane Oven and Skid.	11
Figure 8. WPI Membrane Permeance for Run R09.....	12
Figure 9. XPS Analysis of WPI Membrane Surface.....	13
Figure 10. MTR CO ₂ and Hydrogen Membrane Test Units.	13
Figure 11. MTR 500 lb/hr Membrane System Skids in Fabrication.	14
Figure 12. Installed MTR 500 lb/hr CO ₂ Membrane System.....	14
Figure 13. Test Results of MTR 50 lb/hr CO ₂ Membrane and Hydrogen Stamp Membrane in R09.	15
Figure 14. Hydrogen Content of Permeate and Reject Streams for MPT Membrane during R08.	18
Figure 15. Conceptual Multi-Tube CMS Bundle with Surface Area Greater Than 110 ft ²	19
Figure 16. Schematic of Eltron Hydrogen Membrane Tube.	20
Figure 17. Eltron Membrane Tubes.	20
Figure 18. Eltron Membrane Hydrogen Flux during R09 Testing.	21
Figure 19. SEM Image of the Surface of an FCC-Structured Palladium-Based Coupon Exposed during R08.....	22
Figure 20. SEM Image of the Surface of a Baseline Coupon of a Super-Permeable Material Exposed during R08.	23
Figure 21. CO ₂ Capacity as a Function of CO ₂ Partial Pressure for University of Alabama Solvent.	24
Figure 22. H ₂ S Absorption for University of Alabama Solvent.....	24
Figure 23. PC4 Facilities.	26
Figure 24. Slipstream Solvent Test Unit.....	27
Figure 25. PSTU Schematic.....	29
Figure 26. Color Change of Solvent During 2012 MEA Baseline Test Campaign.	34
Figure 27. CO ₂ Capture Efficiency over the Duration of Hitachi Solvent Testing.	43

List of Figures (Cont'd)

Figure 28. Variation of CO ₂ Capture Efficiency with Hitachi Solvent Flow Rate.....	43
Figure 29. Variation of Regeneration Energy with Hitachi Solvent Flow Rate.	44
Figure 30. Variation of CO ₂ Capture Efficiency of Hitachi Solvent with Reboiler Steam Flow Rate.....	44
Figure 31. Model View of BASF/Linde Pilot Unit.	46
Figure 32. Solvent, Flue Gas, and Steam Flow Rates during Cansolv Solvent Testing.....	48
Figure 33. Optimization of Cansolv DC-201 Solvent at Various Absorber Packing Heights.	48
Figure 34. Variation of Steam Flow and Lean and Rich loadings with Absorber Packing Sections.....	49
Figure 35. Variation of CO ₂ Capture Rate, Amine Concentration, and Stripping Factor.	50
Figure 36. Increase of Anionic Species in Lean Solvent over Time.	51
Figure 37. Chromatograph of Lean Cansolv Solvent Samples Taken at t=0 and t=900 Hours. ...	52
Figure 38. Change in Cations and Metals Concentrations in Lean Cansolv Solvent over Time...	53
Figure 39. Modifications to PSTU Requested by Chiyoda.....	55
Figure 40. MTR 1-ton/day CO ₂ Membrane Components.	56
Figure 41. Schematic of MTR Flue Gas Membrane Skid.	57
Figure 42. Schematic Showing MTR Membrane Skid Gas Flows.	57
Figure 43. Deposits in Compressor Outlet and the Filtrand from the Solution made by Deposits.	59
Figure 44. Inspection of MTR Membrane.	60
Figure 45. Inspection of Membrane Sheets and Feed Spacer of MTR Module.....	61
Figure 46. Codexis Enzyme Test Unit Installed at the PC4.....	62
Figure 47. Results of Codexis Enzyme Testing.	63
Figure 48. Akermis Enzyme Pilot Plant Installed at the PC4.	64
Figure 49. NCCC Gasification Process.	66
Figure 50. Gasifier Temperature Control during Non-Steady-State Operation.	67
Figure 51. Raw Biomass for R08 Co-Feeding.	69
Figure 52. Torrified Biomass for R08 Co-Feeding.	69
Figure 53. Particle Size Distribution Curves for R08 Gasifier Feedstocks.	70
Figure 54. Biomass Feed Rate as a Function of Feeder Speed of Original Rotary Coal Feeder...	71
Figure 55. Carbon Conversion during PRB Coal and Biomass Co-Feed Operation.....	72

List of Figures (Cont'd)

Figure 56. Mass and Energy Balances for R08 Biomass Co-Feed Operation.	72
Figure 57. Fine and Coarse Ash Particle Size Distribution Curves for R08 Operation.	73
Figure 58. Temperature Readings for Sapphire and HR-160 Thermowells.	75
Figure 59. Comparison of Coal Feed Rates Indicated by Weigh Cells and Densflow Meter.	76
Figure 60. Gasifier Standpipe Refractory before and after Standpipe Replacement.....	78
Figure 61. Standpipe Demolition in Progress.	79
Figure 62. PCD Tubesheet Fracture and Repair.....	79
Figure 63. Conceptual Use of TDL Sensor for Control of an IGCC Plant.	81
Figure 64. Location of TDL Sensor in NCCC Transport Gasification Process.....	83
Figure 65. TDL Sensor Assembly Installed in Gasification Process.	84
Figure 66. In-Situ Measurements of Flue Gas Moisture during Gasifier Start-Up.....	85
Figure 67. Thermocouple Measurements Compared with TDL Temperature and Syngas H ₂ O Measurements.....	86
Figure 68. Continuous TDL H ₂ O Measurements Compared with H ₂ O Sampling Data.....	86
Figure 69. Fluctuations in TDL H ₂ O Measurements and Gasifier Thermocouple Measurements.....	87
Figure 70. Fluctuations in TDL H ₂ O Measurements and PDAC Feeder Pressure.....	87
Figure 71. TDL H ₂ O Measurement and GC CO ₂ Measurements during Upset Condition.	88

List of Tables

Table 1. Major Project Milestones for the 2012 Portion of Budget Period Four.	5
Table 2. Design Parameters for WGS Catalyst Reactor Vessels.....	9
Table 3. Results from Testing of Baffle Arrangement in MPT Full-Scale Membrane Bundle.....	17
Table 4. Composition Data for Egress Streams from MPT Membrane during R09.	18
Table 5. Parametric Tests Results for Solvent Carryover from Absorber Wash Tower.....	31
Table 6. Amine and Degradation Product Carryover during MEA Testing.	32
Table 7. Effect of Scrubber Liquid in Impingers on Vapor Emissions.	33
Table 8. Major Degradation Products in Lean MEA.....	34
Table 9. RCRA-Listed Metals in Solvent from 2012 MEA Test Campaign.	35
Table 10. Non-RCRA-Listed Metals in Solvent from 2012 MEA Test Campaign.	37
Table 11. Anions in Solvent from 2012 MEA Test Campaign.....	38
Table 12. Selenium Species in MEA Solvent with and without pH Adjustment.	39
Table 13. Efficiency of Metals Removal from MEA Solvent with Texas A&M ZVI Process.....	40
Table 14. Operating Parameters for Hitachi Solvent Testing.	42
Table 15. L/G Ratio and Heat of Regeneration of 30 wt% MEA and Hitachi Solvent.....	45
Table 16. CO ₂ Capture Efficiency of Hitachi Solvent with Varying Number of Absorber Beds in Service.....	45
Table 17. Cansolv Solvent Test Schedule.....	47
Table 18. Main Contaminants Found in Gas Streams during Three Sampling Surveys.....	54
Table 19. Steady State Carbon Conversions for R08 and R09.	67
Table 20. Coal and Biomass Properties.....	70
Table 21. Coal and Biomass Co-Feed Operating Parameters.	71

List of Abbreviations and Acronyms

ARPA-E	Advanced Research Projects Agency-Energy
CCAT	Connecticut Center for Advanced Technologies
CFAD	Continuous Fine Ash Depressurization
CFM	Cross-Flow Membrane
CMR	Catalytic Membrane Reactor
CMS	Carbon Molecular Sieve
CSM	Countercurrent-Swept Membrane
DC	Direct Current
DCS	Distributed Control System
DOE	Department of Energy
EERC	Energy and Environmental Research Center
EPA	Environmental Protections Agency
EPRI	Electric Power Research Institute
FCC	Face-Centered Cubic
FGD	Flue Gas Desulfurization
G	Gas (Flue Gas)
GC	Gas Chromatograph
H ₂ S	Hydrogen Sulfide
HTM	Hydrogen Transport Membrane
ICP-MS	Inductively Coupled Plasma Mass Spectrometry
IGCC	Integrated Gasification Combined Cycle
L	Liquid (Solvent)
L/G	Liquid (Solvent) to Gas (Flue Gas) Ratio
LDL	Lower Detection Limit
MCC	Motor Control Center
MDEA	Methyldiethanolamine
MEA	Monoethanolamine
MM5	Modified Method 5
MPT	Media & Process Technology
MTR	Membrane Technology & Research
NCCC	National Carbon Capture Center
NDIR	Non-Dispersive Infrared
NETL	National Energy Technology Laboratory
OD	Outer Diameter
OSU	Ohio State University
PC	Pulverized Coal
PC4	Post-Combustion Carbon Capture Center
PCC	Post-Combustion CO ₂ Capture
PCD	Particulate Control Device
PDAC	Pressure Decoupled Advanced Coal
PLC	Programmable Logic Controller
PRB	Powder River Basin
PSDF	Power Systems Development Facility
PSTU	Pilot Solvent Test Unit

List of Abbreviations and Acronyms (Cont'd)

RCRA	Resource Conservation and Recovery Act
RP-UHPLC-ICP- TQMS	Reverse Phase, Ultra-High Pressure Liquid Chromatography, Inductively Coupled Plasma, Triple Quadrupole Mass Spectrometry
S	Steam (Reboiler Steam)
S/L	Steam (Reboiler Steam) to Liquid (Solvent) Ratio
SCL	Syngas Chemical Looping
SCR	Selective Catalytic Reduction
SCU	Syngas Conditioning Unit
SSTU	Slipstream Solvent Test Unit
TCLP	Toxicity Characteristic Leaching Procedure
TDL	Tunable Diode Laser
UA	University of Alabama
WGS	Water-Gas Shift
WMS	Wavelength-Modulation Spectroscopy
WPI	Worcester Polytechnic Institute
XPS	X-Ray Photoelectron Spectroscopy
ZVI	Zero Valent Iron

1.0 EXECUTIVE SUMMARY

The Power Systems Development Facility (PSDF) is a key national asset for ensuring continued cost-effective, environmentally acceptable energy production from coal. Sponsored by the U.S. Department of Energy's (DOE's) National Energy Technology Laboratory (NETL), the PSDF is an engineering scale test center located in Wilsonville, Alabama. The PSDF staff has effectively developed advanced power systems to meet the national need for cleaner, more efficient power production from coal. In the 18 years of PSDF operation, numerous technologies have been tested under challenging process conditions without any lost-time accidents.

Building on its previous success, PSDF now houses the National Carbon Capture Center (NCCC), established in 2009. The NCCC provides test facilities and wide-ranging support to researchers developing lower-cost CO₂ capture technologies that will enable coal-based power generation to remain a key contributor to the energy mix. The facilities accommodate a range of equipment sizes and operating conditions and provide commercially representative settings that allow results to be scaled confidently to commercial application, a crucial element in shortening development times.

Project Partnership with DOE

The DOE conceived the PSDF as the premier advanced coal power generation research and development facility of the world, to “serve as the proving ground for many new advanced power systems.” Since operations began in 1996, the PSDF has been a center for national efforts to develop clean, high efficiency coal-based power generation technologies. Two significant achievements—in addition to many secondary goals that were met—were the development of hot gas filtration to improve energy efficiency and the development of a gasifier suitable for use with low-rank coals, which comprise over half of the total coal reserves in the U.S. and the world. These two technologies have progressed to commercialization with an integrated gasification combined cycle (IGCC) power plant under construction in Kemper County, Mississippi.

Project Mission and Approach

Offering a world-class neutral test facility and a highly specialized staff, the National Carbon Capture Center accelerates the commercialization of advanced technologies to enable coal-based power plants to achieve near-zero emissions. Work at the NCCC supports the next stages of coal-fired power technologies and the continued operation of conventional coal-fired power plants under CO₂ emission constraints.

In undertaking its mission, the NCCC is involved in a range of activities in the areas of pre- and post- combustion CO₂ capture and gasification to develop the most promising technologies for future commercial deployment. The test facilities, shown in Figure 1, include the original PSDF site, which houses the gasification and pre-combustion CO₂ capture processes, and the Post-Combustion Carbon Capture Center (PC4), located at the adjacent Alabama Power E.C. Gaston power plant.

Figure 1. NCCC/PSDF Facilities.

1.1 Pre-Combustion CO₂ Capture Testing

For the area of pre-combustion CO₂ capture, highlights of testing in 2012 are listed below.

- Testing of water-gas shift (WGS) was conducted with a technology developer's catalyst during the two gasification runs of 2012 for parametric studies and long-term evaluation. Result showed up to 70 percent CO conversion with no steam addition.
- Worcester Polytechnic Institute (WPI) completed testing of palladium-based hydrogen membranes, demonstrating product purity as high as 99.9 percent. The group continued to optimize the composition and thicknesses of the membrane and membrane coating.

WPI secured funding for a five-fold scale up of the technology based on the data collected at the NCCC.

- Membrane Technology & Research (MTR) continued testing of polymeric CO₂ and hydrogen membranes, and successfully commissioned a 10:1 scale up of its CO₂ membrane. The scaled-up membrane system operated as designed and demonstrated liquid CO₂ production.
- Media & Process Technology (MPT) completed further testing of its Carbon Molecular Sieve (CMS) hydrogen membrane, which was increased to a full-scale size. Testing verified the effectiveness of a baffle design incorporated to improve gas distribution throughout the tube bundle, and it produced hydrogen purity up to 95 percent.
- Eltron Research & Development achieved stable operation with its dense-metal, high-temperature hydrogen separation membrane during its first testing at the NCCC in late 2012. Hydrogen purity in the permeate stream was greater than 99.87 percent during the entire testing period, which indicated excellent membrane integrity without leakage.
- Syngas exposure testing of sample coupons from NETL has proved instrumental in guiding the selection of suitable membrane compositions by identifying different corrosion tendencies.
- Operation with a CO₂ capture solvent from the University of Alabama was conducted to advance the university's development of its physical solvent. Test results showed that the CO₂ absorption of the solvent was within the range of those of previously tested solvents.

1.2 Post-Combustion CO₂ Capture Testing

Technology development at the PC4 included:

- The Pilot Solvent Test Unit (PSTU) at the PC4 was operated with monoethanolamine (MEA), for a second solvent baseline test campaign. Researchers confirmed the higher-than-expected solvent carryover and are pursuing ways to reduce it. The testing included quantification of the solvent metal contaminants and evaluation of methods for their removal.
- Testing of advanced amine solvents in the PSTU was completed with solvents from Hitachi and Cansolv Technologies, and testing began with Chiyoda's solvent. The data collected are being used to support development of their commercial processes.
- MTR continued long-term testing of an advanced CO₂ gas separation membrane, which has demonstrated efficient operation and is being scaled up from a 1-ton CO₂/day unit to a 20-ton CO₂/day unit. Operation of the 1-ton unit has consistently demonstrated greater than 90 percent CO₂ capture. Based on operational experience, MTR incorporated a new design for its compressor.
- Codexis exposed its CO₂ capture-enhancing enzymes and solvent to flue gas, achieving a CO₂ capture rate increase of more than 25-fold compared to solvent alone. This is the largest scale that enzyme-based carbon capture technology has been demonstrated to date.

- Akermin commenced with commissioning of its pilot plant incorporating immobilized, carbonic anhydrase enzyme in an absorber, with testing to proceed through mid-2013.

1.3 Gasification Technology Testing

Accomplishments in the area of gasification testing are listed below.

- The gasification process was operated in two different test runs with stable operation, supporting the development of technologies including automatic gasifier controls, coal feeders, advanced sensors and instrumentation, and high efficiency particulate filtration components.
- Co-feeding of biomass with coal was conducted for over 200 hours in oxygen-blown gasification mode on behalf of the Connecticut Center for Advanced Technologies (CCAT). The biomass was fed at rates ranging from 10 to 30 wt% of the total feed rate, with average steady-state carbon conversions greater than 98 percent.
- The testing of Stanford University's Tunable Diode Laser (TDL) marked a major milestone in the scale-up of this sensor. The TDL is considered to be a potential breakthrough technology for control of advanced gasification systems.

1.4 Milestones for 2012

The Budget Period Four performance period for the NCCC entails a total period of twenty-one months, from January 2012 through September 2013. This report describes the results of work at the NCCC for the calendar year 2012 portion of Budget Period Four. In partnership with the DOE, the NCCC established and met the milestones listed in Table 1 during 2012.

Table 1. Major Project Milestones for the 2012 Portion of Budget Period Four.

<i>Research Area</i>	<i>Milestone</i>	<i>Completion Date</i>	<i>Report Reference Section</i>
<i>Gasification</i>	Begin field replacement of refractory-lined piping	Jan 2012	4.5.1
<i>Post-Combustion</i>	Conduct follow-up testing on baseline MEA solvent	Mar 2012	3.2
<i>Post-Combustion</i>	Resume long-term testing of MTR membrane	Mar 2012	3.7
<i>Gasification</i>	Complete field replacement of refractory-lined piping	May 2012	4.5.1
<i>Post-Combustion</i>	Complete testing of Codexis enzyme-based process	May 2012	3.9
<i>Pre-Combustion</i>	Upgrade SCU electrical system to support projected loads	Jun 2012	2.1.1
<i>Pre-Combustion</i>	Add new control room and DCS operator workstation for SCU	Jun 2012	2.1.1
<i>Post-Combustion</i>	Complete testing of Hitachi solvent in PSTU (1,000 hours)	Jun 2012	3.3
<i>Pre-Combustion</i>	In R08, test WGS catalyst and membranes from MTR, MPT, and WPI	Jul 2012	2.0
<i>Gasification</i>	Conduct gasification test run R08 for 750 hours air-blown operation using PRB coal	Jul 2012	4.1
<i>Post-Combustion</i>	Extend testing of Hitachi solvent in PSTU	Jul 2012	3.3
<i>Gasification</i>	Extend test run R08 to conduct oxygen-blown gasification with biomass/coal co-feed for Connecticut Center for Advanced Technologies	Sep 2012	4.2
<i>Post-Combustion</i>	Continue testing MTR membrane	Sep 2012	3.7
<i>Post-Combustion</i>	Complete testing of Cansolv solvent in PSTU	Oct 2012	3.5
<i>Pre-Combustion</i>	Install a new syngas cooling and cleaning system to support a low temperature scale-up polymeric CO ₂ membrane field demonstration; install vendor-supplied module and interconnections	Nov 2012	2.1.2
<i>Gasification</i>	Conduct gasification run R09 for 1,000 hours of on-coal operation with PRB with testing of Stanford's TDL	Dec 2012	4.1, 4.6
<i>Pre-Combustion</i>	In R09, test CO ₂ solvent from University of Alabama; membranes from MTR, MPT, WPI, Eltron; WGS catalyst; and large-scale MTR membrane	Dec 2012	2.0
<i>Post-Combustion</i>	Initiate installation of SSTU	Dec 2012	3.1.2
<i>Post-Combustion</i>	Continue testing MTR membrane in bench-scale area	Dec 2012	3.7
<i>Post-Combustion</i>	Install and begin commissioning Akermin enzyme process in bench-scale area	Dec 2012	3.10
<i>Post-Combustion</i>	Begin testing Chiyoda solvent in PSTU	Dec 2012	3.6

2.0 PRE-COMBUSTION CO₂ CAPTURE

The infrastructure for pre-combustion CO₂ capture testing provides for a wide range of test conditions, and includes the Syngas Conditioning Unit (SCU). Figure 2 is a flow diagram of the SCU, which consists of small reactor vessels, arranged to allow operation in series or in parallel, and accommodates a range of flow rates, temperatures, and pressures. During 2012, several upgrades to the SCU were incorporated, and various tests with gas separation membranes, a CO₂ capture solvent, and a WGS catalyst commenced. Several technology developers also tested metallic hydrogen membrane coupons of advanced materials for syngas exposure in the SCU vessels. Preparations were also underway to support future testing, including Ohio State University's (OSU's) Syngas Chemical Looping (SCL) project.

Figure 2. Syngas Conditioning Unit.

2.1 Syngas Conditioning Unit Modifications

The increasing number and size of pre-combustion test skids required upgrades to the SCU infrastructure. The NCCC installed new, larger buildings for a Motor Control Center (MCC) and a control room and constructed an expansion area containing a high-capacity syngas cleaning system.

2.1.1 SCU Upgrades

Electrical Upgrades

To meet the projected increased testing demand, additional electrical supply was required, much of which was routed through an MCC contained in a new electrical building. The building was vendor-supplied according to NCCC specifications, and NCCC staff designed and poured the foundations and laid the underground conduit carrying the power supply cables. The MCC incoming line sections were installed, checked, and energized in June with available equipment.

The MCC equipment was designed to be delivered in two phases.

- The first phase was to support the SCU expansion with the 1,000 lb/hr syngas cleaning system and to support testing of MTR's new scaled-up CO₂ separation membrane system to process 500 lb/hr of syngas. This phase was completed by August 2012 with all motor control centers installed and fully functional.
- The second phase of MCC equipment will be ordered once the design load requirements of the 800-lb/hr OSU SCL project are established.

Control Room Upgrades

The original SCU control room did not provide adequate space for NCCC plant operators and technology developer personnel. This control room was located beneath the sheltered area of the SCU, occupying space that could be used for process equipment. Hence, a more commodious room was installed outside of the sheltered area, opening up space for the SCU expansion. Distributed Control System (DCS) workstations were provided to allow SCU operators to control the equipment directly rather than requesting changes through the main control room. Fiber optic cables were supplied, connecting the new SCU control room to the main DCS and the plant historian. The work was completed and ready for operation in June.

Other Upgrades

At the end of 2012, process and mechanical design work were underway to install a new fixed-bed reactor vessel in the SCU to provide additional capacity for testing of sorbents and catalysts. This project is scheduled for completion in early 2013 to be used initially with a high-temperature mercury sorbent from Johnson Matthey. Another project was underway to increase the syngas flow rates available for testing of WGS and carbonyl sulfide hydrolysis catalysts. Process design was near completion by the end of 2012, and detailed design will be finalized in 2013.

2.1.2 SCU Expansion and Syngas Cleaning System

In 2012, the NCCC staff designed and installed the SCU expansion area comprising a process structure and the new syngas cleaning system. The system was initially utilized in December for testing of MTR's 500 lb/hr CO₂ separation membrane during run R09. Figure 3 provides views of the expansion area and the syngas cleaning system.

Figure 3. SCU Expansion Area Housing Syngas Cleaning System.

Syngas Cleaning System Process Description

The syngas passing to the SCU contains hydrogen sulfide (H_2S), which is removed by a high-temperature absorbent. For the MTR membrane, the syngas must be cooled to ambient temperature, which is below the condensation point of most hydrocarbons present. To remove the hydrocarbons and thus prevent fouling of downstream equipment, the hot syngas is bubbled through a stirred quench tank of chilled water at 50°F , which removes the majority of the hydrocarbons. The syngas leaving the tank passes into a packed column scrubber with a counter-current flow of chilled water to remove entrained hydrocarbons. The syngas leaving the scrubber is heated from around 50°F to 100°F , which lowers the relative humidity and avoids condensation of water and residual hydrocarbons in the membrane equipment. The ancillary equipment includes heat exchangers utilizing chilled water preceded by a pair of liquid filters to remove the condensed hydrocarbons. When the pressure drop across a filter exceeds the set point, a clean filter is brought into service and the one leaving service is steam cleaned. The steam/ hydrocarbon mixture passes to the atmospheric syngas combustor during the cleaning stage. In addition to removing hydrocarbons, the chilled water also condenses out water vapor, which accumulates in the stirred tank. The level in the quench tank is maintained automatically, and the excess water is drained to a second tank that discharges at a controlled rate to the atmospheric syngas combustor.

2.2 Water-Gas Shift Catalyst

Water gas shift catalyst evaluation is completed in one of three pressure vessels shown in Figure 4. The vessels and the lines delivering the syngas are heavily trace heated and insulated to maintain the required operating temperatures. Some of the key design parameters for the vessels are presented in Table 2.

Figure 4. SCU Reactor Vessels Used for WGS Catalyst Evaluation.

Table 2. Design Parameters for WGS Catalyst Reactor Vessels.

<i>Design Parameter</i>	<i>Value</i>
Vessel Material of Construction	310 Stainless Steel
Design Pressure, psia	365
Design Temperature, °F	1,000
Height of Parallel Section, inches	48
Internal Diameter, inches	5.2

The syngas at the inlet of the hot gas filtration system (Particulate Control Device, or PCD) of the gasification process is analyzed using two on-line gas chromatographs (GCs) and a Non-Dispersive Infrared (NDIR) CO/CO₂ meter, and this information is used as the inlet syngas composition to the WGS vessel. The syngas composition leaving the WGS vessel is provided by GC analyzers. Syngas moisture content is determined by condensation measurement, as this has proved to be more accurate than using continuous analyzers. The vessel is equipped with an inlet flow meter and control valve to control flow rate. A similar arrangement is provided for steam should steam addition be needed to promote the shift reaction. The meters are configured so that they can be checked with a known flow of nitrogen prior to start-up and at intervals during the run.

An undisclosed water gas shift catalyst supplier began testing a catalyst under development in 2011 using coal-derived syngas. Parametric testing was completed during R07 at the end of 2011, using 50 lb/hr of raw syngas at 480°F and 200 psia for 850 hours. Steam was added to extend the range of steam-to-CO ratios.

After completion of testing, the catalyst was removed and returned to the manufacturer for post-run analysis. The analysis was considered favorable, and the supplier requested that the catalyst be tested for a more extended time at constant conditions. For ease of operation, it was agreed that steam would not be added and that the reaction would proceed with the intrinsic syngas moisture content. A fresh batch of catalyst was installed prior to R08. Following 292 hours of operation in R08, the catalyst was blanketed with nitrogen and kept ready for retesting in R09. A further 746 hours of testing was achieved in R09, bringing the exposure time for this batch of catalyst to 1,038 hours.

Test data collected over the three runs are presented in Figure 5. The range of data for R07 is wider because of the steam added during testing. For one pass of syngas, over 80 percent CO conversion was achieved with a steam-to-CO ratio of 2. For the intrinsic steam-to-CO ratio of around 0.9, CO conversion was as much as 70 percent. Further testing of this catalyst is planned for 2013.

Figure 6. WPI Hydrogen Membranes.

Figure 7 shows the installed membrane test skid, including an oven, membrane module housing the membrane tube, sulfur guard bed, and ballast vessel. The membrane module was designed to process 10 lb/hr of syngas with hydrogen augmentation from gas cylinders to achieve hydrogen concentrations of 35 to 40 vol%.

Figure 7. WPI Membrane Oven and Skid.

WPI's testing at the NCCC began in 2011. WPI tested a total of five membranes with various palladium-alloy compositions for a combined 1,337 hours during R06 and R07. Testing continued in 2012 with two new palladium membranes alloyed with two other elements. One of the membranes employed a proprietary coating. A combined 575 hours during the R08 and R09 test runs were completed with these ternary-alloyed membranes. Both tests showed stable performance during the entire testing duration and further demonstrated the robustness of WPI's membranes in a coal-derived syngas environment.

During R08, WPI tested the uncoated ternary alloy membrane, which consistently produced greater than 99.8 percent purity hydrogen with stable performance over a total of 411 hours. A

parametric test was performed to better understand the hydrogen permeance at hydrogen inlet concentrations varying from 10 to 50 percent. The results showed that hydrogen purity increased with increasing hydrogen concentration in the feed. Hydrogen product purity of 99.9 percent was achieved with 40 percent hydrogen in the feed. After the test, the membrane surface was very clean compared to those tested previously.

For R09, WPI prepared a ternary alloy membrane similar to that tested in R08, but with a slight variation in thickness of the alloy layers. This membrane was also coated with the proprietary material. Though the coating was designed to resist sulfur poisoning, testing during R09 was primarily to determine the hydrogen permeance without any sulfur present for comparison to that from the membrane without the coating. A membrane coupon was also installed inside the membrane module for exposure to the same conditions as the tested membrane. The coupon is currently being analyzed for surface contamination to optimize the material composition and determine appropriate gas pre-treatment requirements.

High product purity and stability of the membrane was demonstrated during the 164 hours of testing. The proprietary coating did not appear to impact hydrogen permeance. Figure 8 plots hydrogen permeance during the R09 test run and shows its stable performance. However, the hydrogen permeance was lower than that measured in the WPI laboratory.

Figure 8. WPI Membrane Permeance for Run R09.

This permeance reduction has also been observed in the previous test runs. Surface contaminant analysis by X-Ray Photoelectron Spectroscopy (XPS) from a previously tested membrane showed high concentrations of carbon on the surface layer as shown in Figure 9. Elemental carbon concentration at the membrane surface was about 46 percent and gradually decreased as the depth increased. However, even at 1,000 nm depth, the carbon concentration remained at 1 percent. WPI theorized that the presence of unsaturated hydrocarbons in the syngas may have resulted in the carbon deposition on the palladium layer, leading to the loss of active sites for

hydrogen permeation. Additional testing and analysis is planned to provide insight of the root causes for the permeance reduction.

Figure 9. XPS Analysis of WPI Membrane Surface.

2.4 Membrane Technology & Research Membranes

In 2009, MTR, a world leader in the development and production of membrane-based separation systems, began testing two types of polymeric membranes at the NCCC: a CO₂-selective Polaris™ membrane and a hydrogen-selective Proteus™ membrane. Successful operation has led to scale-ups of both membrane types. In 2011, MTR scaled up the hydrogen membrane from a 1-lb/hr stamp cell to a 10-lb/hr module. In 2012, MTR scaled up the 50-lb/hr CO₂ membrane module to an integrated system designed for 500 lb/hr syngas. Figure 10 shows the 50-lb/hr CO₂ membrane skid and 10-lb/hr hydrogen membrane module.

Figure 10. MTR CO₂ and Hydrogen Membrane Test Units.

2.4.1 MTR 500-lb/hr CO₂ Membrane System

The MTR integrated 500-lb/hr CO₂ membrane system consists of membrane, compressor, and refrigeration skids, which are shown in Figure 11. Figure 12 shows the membrane system's three skids installed in the newly expanded SCU. The membrane skid includes two stages of membrane modules for CO₂ separation. It also houses a sulfur polishing reactor and two desiccant dryers for sulfur and moisture removal upstream of the compressor and refrigeration skids, heaters, and control panels. The first-stage permeate stream from the membrane skid is pressurized to about 420 psig in the compressor skid, and then the compressed gas stream is liquefied in the refrigeration skid which removes the CO₂. Uncondensed gas is fed to the second-stage membrane for further CO₂ separation. The second-stage membrane permeate stream is combined with the first-stage permeate stream, and the combined stream is treated in the sulfur polishing reactor. Reject streams from both first- and second-stage membrane modules, as well as the liquid CO₂ stream, are sent to the atmospheric syngas combustor.

Figure 11. MTR 500 lb/hr Membrane System Skids in Fabrication.

Figure 12. Installed MTR 500 lb/hr CO₂ Membrane System.

During R09, treated syngas was fed to the MTR system for the first time. The NCCC provided gas composition measurements from four GCs for continuous data from feed, permeate, and reject streams of the two membranes, as well as measurements from an NDIR instrument to measure CO₂ concentration in the liquid CO₂ stream.

The R09 testing accomplished two major milestones. First, the complete system operated successfully as designed on syngas. Second, the process yielded liquid CO₂ with up to 92 percent purity. MTR plans to continue testing of the 500 lb/hr system in 2013. Prior to further testing, several modifications will be incorporated to improve system performance, including a new membrane design, improved CO₂ liquid level control, and reprogramming of the Programmable Logic Controller (PLC).

2.4.2 MTR 50 lb/hr CO₂ Membrane and Hydrogen Stamp Membrane

MTR also continued testing the smaller CO₂ membrane module and the hydrogen membrane stamp cell during R08 and R09 and completed a combined 500 hours of operation. Testing of the scaled-up hydrogen membrane was suspended due to issues with leaks. While these issues were being resolved, MTR continued materials evaluation with the stamp cell. Results are shown in Figure 13 for the most recent testing of the CO₂ and hydrogen membranes completed in R09.

Figure 13. Test Results of MTR 50 lb/hr CO₂ Membrane and Hydrogen Stamp Membrane in R09.

The CO₂ membrane was tested in two configurations—as a single membrane module and with two modules connected in series. R09 testing demonstrated CO₂ enrichment from about 15 vol% in the feed to 50 vol% in the permeate stream. The hydrogen membrane stamp cell enriched the hydrogen from a feed concentration of 14 vol% to 80 vol% in the permeate. Both CO₂ and hydrogen membranes performed stably, achieving separation performances equal to or slightly above what had been achieved historically. Testing was cut short in R09 due to leaks—first, with a pressure regulator and later with membranes.

2.5 Media & Process Technology Membrane

Media & Process Technology, a technology innovator specializing in the development of high-performance, low-cost ceramic membranes, first tested its hydrogen-selective CMS membrane at the site in 2008. MPT began evaluation of the CMS technology with single tubes, progressing to a pilot bundle containing 14 tubes before developing a full-scale 86-tube bundle with a total surface area of 8.2 ft² processing up to 50 lb/hr of syngas. The bundle consists of 86 alumina tubes contained within a 5-inch diameter pressure vessel and is designed for operating temperatures as high as 570°F and transmembrane pressure drops of over 300 psi.

MPT's first test with the full-scale CMS was in 2011 during run R07. Performance with raw syngas at 480°F and 215 psia was lower than anticipated based on previous tests with single tubes and the pilot module.

- Hydrogen permeance for the syngas was on average 0.8 m³/m²/hr/bar, about half the value expected for pure hydrogen.
- The hydrogen concentration in the permeate was also lower than expected. With around 7 vol% hydrogen in the syngas, the permeate contained about 35 vol% hydrogen compared to 55 vol% in previous tests. With around 40 vol% hydrogen in the syngas, the permeate contained 80 vol % hydrogen compared to 95 vol% or more in previous tests.

In January 2012 at MPT's Pittsburgh laboratory, MPT investigated performance of the full-scale membrane bundle tested during R07. The lab testing indicated considerable discrepancy between the permeance for pure helium and for gas mixtures of He/N₂ or He/Ar. As this discrepancy was not observed for the single-tube and the pilot-scale module testing, the reduced performance was attributed to poor radial distribution of the syngas within the bundle. To improve distribution, baffles similar to those used in shell-and-tube heat exchangers were installed longitudinally to force the syngas to flow across the bundle diameter and so access the interior tubes.

MPT tested a number of baffle arrangements using a 60:40 He/Ar mixture and identified one that raised permeance to about 1.4 m³/m²/hr/bar, almost 90 percent of the pure helium value. To extend the range of operating pressure and gas flow rates and confirm the improved performance of the bundle prior to testing with syngas in R08, off-line tests on MPT's test skid at the NCCC were completed. To accommodate the tests, some equipment modifications were required, including additional relief valves and new flow meters for helium and nitrogen supply. All design and installation work was carried out by NCCC personnel who also supported execution of the test program. In addition, several system modifications were completed to facilitate long-term testing. These included the addition of steam lines for on-line cleaning of cooling coils, a larger pre-filter for the reject stream, and a larger vortex cooler for the process cabinet to avoid overheating of instrumentation.

Off-line testing was carried out in April 2012 using a 70:30 He/N₂ mixture and achieved permeance values of 1.45 to 1.51 m³/m²/hr/bar, 95 to 99 percent of the value for pure helium. (The helium simulates the hydrogen in the syngas more safely than using bottled hydrogen and the nitrogen represents the balance of gases in syngas.) Table 3 provides the results from MPT's

lab testing and off-line testing at the NCCC. These results confirmed that the baffle arrangement identified by MPT improved gas distribution within the membrane bundle, enabling it to achieve results similar to those of single tubes. Hence, this baffle arrangement was included in a new membrane module for testing in R08.

Table 3. Results from Testing of Baffle Arrangement in MPT Full-Scale Membrane Bundle.

<i>Feed Rate, SLPM</i>	<i>Temperature, °F</i>	<i>Reject Pressure, psia</i>	<i>Permeate Pressure, psia</i>	<i>Helium Permeance, m³/m²/hr/bar</i>	<i>Percent of Pure Helium Permeance</i>
MPT Laboratory Testing with 60:40 He/Ar Binary Gas Mixture					(1)
76	387	65	15	1.41	89
50	387	63	15	1.39	88
NCCC Off-Line Testing with 70:30 He/N ₂ Binary Gas Mixture					(2)
69	383	56	18	1.48	97
97	383	56	18	1.49	98
180	383	109	24	1.51	99
226	383	125	20	1.45	95
266	383	155	24	1.45	96

Pure helium permeance is independent of pressure and gas flow rate. Values were determined to be ⁽¹⁾ 1.57 m³/m²/hr/bar at 428°F and ⁽²⁾ 1.52 m³/m²/hr/bar at 383°F.

R08 testing began in June with raw syngas feed containing about 8 vol% hydrogen and flow rates varying from 150 to 250 standard liters/min. The operating temperature was maintained at about 480°F, higher than the 450°F used in previous tests, and was selected to avoid the deposition of hydrocarbons previously seen in the membrane. (Post-run inspection showed no evidence of hydrocarbon deposits.) The transmembrane pressure drop was about 200 psi with the permeate-side pressure in the range of 18 to 20 psia. Hydrogen permeance was estimated to be 1.2 m³/m²/hr/bar, 85 to 90 percent of the value for pure hydrogen. Product hydrogen was 50 to 55 percent pure, exceeding the 30-percent purity obtained in R07. This further validated the effectiveness of the baffles in distributing syngas flow through the tube bundle.

The membrane bundle was tested again near the end of R08 for over 100 hours during a period of oxygen-blown gasifier operation when biomass was co-fed with the coal. Figure 14 plots the hydrogen content (dry basis) of the permeate and reject streams during this period. Once the syngas hydrogen composition stabilized at 22 vol% (after around 20 hours), the permeate stabilized at 80 vol% hydrogen and the reject stream at 10 vol% for most of the test period. At the end of the run, the hydrogen in the feed was enriched to 32 vol%, which increased the permeate hydrogen content to about 92 vol%.

Figure 14. Hydrogen Content of Permeate and Reject Streams for MPT Membrane during R08.

The CMS membrane bundle operated for almost 400 hours during R09, including a 300-hour period of continuous operation under NCCC supervision, processing 50 lb/hr of raw flue gas at 190 psia and 500°F. Table 4 provides gas composition data on a dry basis for the two egress streams. For short-duration tests, the syngas hydrogen content was increased to 40 vol% (simulating the syngas produced by a commercial oxygen-blown gasifier), resulting in hydrogen permeate purity of about 95 percent (dry basis). This degree of product enrichment is greater than that achieved for the single tube and pilot-bundle membranes and indicates the improvements made in the quality of the deposited CMS layer.

Table 4. Composition Data for Egress Streams from MPT Membrane during R09.

<i>Syngas Constituent</i>	<i>Permeate Concentration</i>	<i>Reject Concentration</i>
Hydrogen, vol%	95	35
CO ₂ , vol%	1.3	6
CO, vol%	< 0.3	6
H ₂ S, ppmv	Below LDL	25
Nitrogen (balance), vol%	3.4	53

High permeate moisture levels limited the accuracy of hydrogen permeance determinations, but helium and nitrogen pure-component permeance measurements were made periodically to give an indication of membrane performance stability. The permeance for helium was about 1.1 m³/m²/hr/bar and that for nitrogen was about 0.01 m³/m²/hr/bar; these values were stable throughout the 300-hour continuous test period and correspond to values obtained from off-line characterization tests for the membrane bundle.

Future Test Plans

Based on 2012 performance results, two modifications to MPT's test skid were proposed for 2013. First, improved means to determine the permeate moisture content are to be investigated, which will allow more rigorous data analysis to be performed. Second, measures to reduce false alarms by a hydrogen sensor in MPT's purged membrane cabinet are to be incorporated. As discussed below, MPT is also planning on enhancing the CMS with WGS functionality.

MPT's concept for CMS membrane technology is that it be incorporated with the water gas shift reaction stage producing a catalytic membrane reactor (CMR) that allows the separation of the hydrogen simultaneously with its formation. This increases the driving forces in subsequent WGS/membrane stages, allowing a closer approach to equilibrium. MPT has investigated the CMR concept at the bench scale feeding a synthetic syngas mixture containing H_2S to a single CMS membrane tube surrounded by sour WGS catalyst. WGS catalyst will be added to the full-scale membrane bundle to collect CMR performance data at the NCCC during 2013.

To accommodate the high syngas flow rate from a commercial gasifier, the surface area per CMR module must be increased significantly to reduce the number of modules required and the complexity of interconnecting pipe work. MPT has conceived a multiple bundle module shown in Figure 15 that contains 14 of the full-scale CMS bundles (higher numbers are possible) between which the WGS catalyst would be packed. Such an arrangement offers more than 110 ft^2 of flow area. The total syngas flow would be around 700 lb/hr and could be tested at the NCCC within the SCU provided that the increased hydrogen demand can be met economically.

Figure 15. Conceptual Multi-Tube CMS Bundle with Surface Area Greater Than 110 ft^2 .

2.6 Eltron Membrane

Under DOE sponsorship, Eltron Research & Development, a technology group specializing in chemical and engineering technologies, is developing a high-temperature hydrogen transport membrane (HTM) for pre-combustion capture of CO_2 . The Eltron HTM technology uses a multi-layer metal alloy tube to separate hydrogen from coal-derived syngas (see Figure 16), providing high purity hydrogen and capture of high pressure CO_2 suitable for utilization or

sequestration. Eltron's membranes can withstand high differential pressures of up to 1,000 psi, allowing for successful integration with advanced, high-pressure coal gasification processes.

Figure 16. Schematic of Eltron Hydrogen Membrane Tube.

At the direction of DOE, NCCC began discussions with Eltron in early October about testing the HTM at NCCC in run R09. To accommodate the testing within the tight schedule, WPI's existing membrane testing oven was used. A new module and flange connections for the permeate and retentate gas streams were fabricated on-site according to standards of the American Society of Mechanical Engineers. The two membrane tubes tested were of 0.5-inch outer diameter (OD), with one tube 8 inches long and the other, 6 inches long. The 8-inch long tube was installed for permeation testing, and the 6-inch long tube was installed for exposure-only testing. Figure 17 shows these two membrane tubes.

Figure 17. Eltron Membrane Tubes.

The assembled module was installed inside WPI's oven. A new thermocouple was installed to directly measure syngas temperature from the retentate stream in addition to an oven temperature indicator. The oven-heating program was modified to accommodate Eltron's proprietary start-up process, and testing began on December 1.

The membranes were tested at about 640°F for a total of 204 hours, including 183 hours of syngas operation with hydrogen enrichment and 21 hours with bottled hydrogen/nitrogen gases. The system operated with 10 lb/hr shifted and sweetened syngas (less than 1 ppmv sulfur). With hydrogen enrichment, the hydrogen concentration of the syngas reached about 38 to 40 vol% (dry basis). During the testing period, the membrane consistently demonstrated a hydrogen flux of about 20 scfh/ft², as shown in Figure 18. The step increase in flux at around 50 hours was the result of replacing a rotameter with a higher resolution one. Hydrogen purity in the permeate stream was greater than 99.87 percent during the entire testing period, which indicated excellent membrane integrity without leakage.

Figure 18. Eltron Membrane Hydrogen Flux during R09 Testing.

Eltron plans to conduct post-operation analysis of the two membranes, including laboratory permeation measurements at conditions similar to those of NCCC testing and surface impurities analysis using various techniques available in-house such as X-ray diffraction, X-ray fluorescence, and scanning electron microscope/microprobe. For higher sensitivity analysis to detect low levels of impurities, samples from each of these tubes will be sent to an independent lab with instrumentation and expertise appropriate for surface analysis such as Auger electron spectroscopy or X-ray photoelectron spectroscopy. Depth profiling will be conducted as well.

2.7 Membrane Material Coupon Testing

Because of their high permeability and selectivity, dense metal membranes are a promising technology for the separation of hydrogen from coal-derived syngas. However, syngas impurities can corrode and poison metal-based separation membranes, degrading their performance and causing mechanical failure. Sulfur compounds, particularly hydrogen sulfide, are probably the most detrimental. The effects of other minor contaminants, such as arsenic and selenium compounds, are not investigated in laboratory studies. Testing with syngas containing the full suite of coal-derived contaminants is therefore an essential step the development of metal-based hydrogen separation membranes.

NETL is currently utilizing a variety of experimental and computational techniques to evaluate and develop potential sulfur-tolerant membrane alloys for application in severe gasification operating environments. Performance of these materials is typically tested under “clean” laboratory conditions using pure hydrogen and hydrogen containing 1,000 ppmv H₂S. To evaluate their corrosion resistance, sample coupons of selected materials were installed in the head (dust-free side) of the hot gas filter on the Transport Gasifier train for long-term exposure during runs R05, R06, R07, and R08. At this location, the syngas contains about 250 ppmv H₂S at around 750°F, and over 25 different coupons, primarily palladium-based, have been tested.

The NCCC results demonstrate that the palladium alloys with B2 crystalline structure tend to be more corrosion resistant than the alloys with face-centered cubic (FCC) crystalline structures, which is in agreement with laboratory studies. In the B2 alloys, corrosion products formed a very thin surface coating with high levels of arsenic and selenium in addition to sulfur. The membrane alloys are effective in scavenging the impurities, especially arsenic and selenium, from the syngas and indicate that minor gas stream impurities are much more important than previously thought. Figure 19 shows a scanning electron microscope (SEM) image of the surface of an FCC-structured palladium ternary alloy coupon exposed in R08. The surface is thickly covered with corrosion products consisting of palladium arsenides and sulfides, showing that this specific composition is not acceptable for use with syngas.

Figure 19. SEM Image of the Surface of an FCC-Structured Palladium-Based Coupon Exposed during R08.

NETL is also investigating protective coatings for hydrogen membrane alloys. The so-called super permeable metals and alloys (tantalum, niobium, vanadium, etc.) are promising for separation applications due to their permeability and lower cost, but they are very susceptible to corrosive degradation. Several uncoated coupons of these materials were also exposed during R08 to provide a performance baseline for coating research. Figure 20 presents an SEM image of the surface of one on these coupons. For this material, the surface was also thickly covered with a layer of corrosion products consisting only of oxides. No sulfur was detected. Results

such as these can only be achieved using coal-derived syngas and are extremely important in guiding future hydrogen separation alloy development efforts.

Figure 20. SEM Image of the Surface of a Baseline Coupon of a Super-Permeable Material Exposed during R08.

2.8 TDA Research Sorbent

Technology developer TDA Research is advancing a new pre-combustion CO₂ capture technology that uses a proprietary carbon-based sorbent modified with surface functional groups to physically adsorb CO₂ from shifted syngas. TDA Research tested the sorbent during R07 in November 2011, utilizing about 5 lb/hr sweet, shifted syngas. Preparations were ongoing in 2012 for further testing of TDA's sorbents during R10 in 2013.

For R10 testing TDA will incorporate a WGS reactor in the test skid to control the degree of the shift reaction. The CO₂ sorbent materials to be tested will also incorporate a WGS catalyst for simultaneous WGS and CO₂ capture. As CO₂ is continuously removed from syngas during CO₂ adsorption, the WGS reaction within the sorbent reactor will approach equilibrium more closely. The NCCC will deliver a new, heat-traced raw syngas stream to the TDA skid and provide deionized water for steam generation for the WGS reaction. NCCC staff will also assist in gas analysis to supplement TDA's own gas analysis.

2.9 University of Alabama Solvent

The Bara Research group of the University of Alabama (UA) has been researching the use of alkylimidazoles, a group of low volatility and low viscosity liquids, as physical solvents for economical CO₂ separation from processes like IGCC. UA provided an alkylimidazole solvent for testing in the SCU stirred batch reactor during R09 using bottled gases and syngas. Results indicated that the solvent performed as expected in regard to the solvent's capacity for CO₂. All tests were performed at 70°F. CO₂ capture was evaluated using bottled gases with 35 and 40

vol% CO₂ at 150 and 300 psig. CO₂ capacity of the UA solvent as a function of partial pressure is compared with other physical solvents in Figure 21.

Figure 21. CO₂ Capacity as a Function of CO₂ Partial Pressure for University of Alabama Solvent.

Absorption of H₂S from the syngas is indicated by Figure 22. This graph shows the reactor outlet concentration of H₂S in the syngas and indicates that with fresh solvent essentially all of the H₂S was collected for over an hour.

Figure 22. H₂S Absorption for University of Alabama Solvent.

The solvent was saturated with CO₂ after about 20 minutes, but this did not affect the H₂S capacity. Also shown in Figure 22 are data from subsequent H₂S absorption tests after

regeneration by various techniques. Flash regeneration released all of the CO₂ from the sample but was not very effective at removing H₂S from the solvent (restoring less than 10 percent of the original capacity). Flash regeneration followed by thermally soaking the solvent at 212°F while purging with nitrogen did not appear to remove any additional H₂S. This behavior seems to indicate that it acts as a physical solvent for CO₂ but reacts chemically with H₂S irreversibly. This interaction will be studied more closely in future testing. For the next test campaign, planned for 2013, a blend of the base and a new solvent will be evaluated for improvements. Also, water may be introduced to the solvent to observe the effect on the H₂S interaction.

2.10 Ohio State University Syngas Chemical Looping

One of the major upcoming projects at the NCCC is the installation and testing of the SCL process developed at OSU. This process aims to convert syngas into separated hydrogen and CO₂ streams using a countercurrent moving-bed reducer/oxidizer reactor system. The project is funded by DOE's Advanced Research Projects Agency-Energy (ARPA-E), which is providing OSU \$5 million for this project. SCL has been successfully demonstrated at bench and sub-pilot scales. OSU is working with a team of engineering and consulting firms to address all the industrial concerns and ready the technology for demonstration.

In this project, a 250-kW pilot scale SCL plant will be constructed adjacent to the NCCC gasification structure and will utilize up to 900 lb/hr of raw syngas at elevated temperature. In early 2012, demolition of unused equipment was completed to make room for the SCL unit, which is approximately 26 by 28 feet and 70 feet tall. Construction for the project is scheduled to begin in April 2013 with initial start-up planned for late 2013 and testing planned into the spring of 2014.

NCCC supported the OSU team by participating in an initial Design Hazard Review and assisting with developmental engineering work. NCCC developed conceptual designs for connecting the SCL system to the Transport Gasifier process and other balance of plant equipment. OSU and NCCC cooperatively developed plans for construction and operation of the system. OSU received the Phase 3 funding release from ARPA-E in December 2012, which releases the project for detailed engineering, purchasing of long-lead capital equipment, and construction.

3.0 POST-COMBUSTION CO₂ CAPTURE

The PC4 was constructed to advance flue gas CO₂ capture technologies at a range of operating conditions and technology development stages. A major area of the PC4 is the PSTU, which is designed to test absorption and regeneration of CO₂ solvents at flue gas rates up to 5,000 lb/hr (equivalent to 0.5 MWe). The PC4 also features test bays for larger units (up to 1.0 MWe) and for bench-scale units (up to 0.1 MWe each). See Figure 23. The site also includes an independent control room, electrical infrastructure, and a balance of plant area containing utilities and chemical storage/handling facilities.

Figure 23. PC4 Facilities.

3.1 PC4 Modifications

Work progressed on several modifications at the PC4 to increase the center's flexibility and enhance data collection and operation. A Slipstream Solvent Test Unit (SSTU) is being added to the site to provide bench-scale testing of solvents.

3.1.1 Balance of Plant Upgrades

To accommodate testing of the two 1-MW-equivalent projects, MTR's CO₂ separation membrane and BASF/Linde's pilot solvent unit, as well as other future projects, several upgrades are being implemented. Design and procurement activities began for these upgrades, which will

be installed at the NCCC during 2013 for the start of testing of the MTR and BASF/Linde units in early 2014. The modifications include:

- A forced draft fan delivering 20,000 lb/hr with a higher delivery head will replace the current fan with a delivery rate of 12,000 lb/hr. The higher flow will allow simultaneous operation of the two 1-MW skids with excess flue gas for testing in the bench-scale area.
- The random packing in the pre-scrubber will be replaced with structured packing to maintain high SO₂ collection efficiency at the higher flue gas flow rate.
- To meet the higher cooling duty requirements, a second cooling tower cell will be added along with larger water circulation pumps.
- Electrical infrastructure additions included the design of a new 2,500 KVA transformer and switchgear. A factory acceptance test for new switchgear took place in early December, after which the unit was shipped to the site.

3.1.2 Slipstream Solvent Test Unit

The NCCC purchased and began installation of the SSTU, which is shown in Figure 24, to increase the flexibility of the PC4 by allowing testing of solvents (such as those in early stages of development) available only in amounts smaller than the 4,000 gallons required for the PSTU. The SSTU comprises a pre-scrubber, condenser, absorber, regenerator, and associated equipment along with analytical instrumentation. During the year, the process flow scheme was developed, the foundation for the SSTU was installed adjacent to the PSTU, and design work was underway to determine needed modifications to the unit and to prepare utility tie-ins. Sulzer, a technology development firm with expertise in mass transfer equipment, is being contracted to collaborate with the NCCC on this project.

Figure 24. Slipstream Solvent Test Unit.

3.2 MEA Baseline Test Campaign

The 1,140-hour MEA Baseline Test Campaign completed in May 2011 identified some issues that required further investigation.

- MEA carryover from the wash tower was in excess of 100 ppmv, compared to the vapor equilibrium value of 3 ppmv. These high values exceed limits for volatile organic compounds and result in excessive solvent make up rates.
- Degradation products in the regenerated CO₂ stream were not sampled.
- The laboratories used to measure degradation in the CO₂-depleted flue gas streams declined to measure degradation products in the solvent. They were concerned that the time required for cleaning of the instruments after analysis would result in sample backlogs.
- End-of-run analysis of the used solvent revealed selenium and chromium contents, each in excess of 1 ppmw, which makes the solvent a hazardous waste if sent to disposal.

An MEA follow-up test campaign was completed in 2012 to investigate these observations further. The 30-wt % MEA solution was loaded on March 7, and flue gas was introduced later that day. Most of the solvent had been used in the 2011 Baseline Test Campaign, but make-up was required to achieve the operating inventory. The first test started on March 8, and the campaign was completed on March 25, achieving just over 400 test hours.

This section provides a description of the PSTU and the sampling and analytical procedures used to measure the MEA carryover and degradation products present in the CO₂-depleted flue gas stream leaving the absorber and the CO₂ leaving the regenerator. The data collected are discussed along with measures being pursued to resolve the issues identified.

3.2.1 PSTU Description

The PSTU was designed to achieve 90 percent CO₂ capture using 30 wt% aqueous MEA. This is the reference solvent to determine baseline performance against which other solvents tested can be compared. These solvents may include hindered amines, amino acid salts, and ionic liquids. To accommodate the range of solvent properties, the PSTU design is very flexible operationally. A schematic of the PSTU is presented in Figure 25.

Figure 25. PSTU Schematic.

Up to 35,000 lb/hr of flue gas is extracted from downstream of the Plant E.C. Gaston Unit 5 flue gas desulfurization (FGD) system and is utilized for PC4 testing activities. Of this amount, 5,000 lb/hr of flue gas flows to the PSTU. There are five major columns, or subsystems, which include:

- The pre-scrubber which removes the small amount of SO₂ remaining in the flue gas
- A cooler/condenser unit that cools the flue gas to appropriate reaction temperatures and removes flue gas moisture
- An absorber to promote efficient gas-liquid contacting to remove CO₂ from the flue gas
- A washing tower that cools the CO₂-depleted flue gas, removing trace amounts of entrained solvent
- A regenerator that provides heat to release the CO₂ from the solvent

Further description of the PSTU subsystems has been published previously (see NCCC/PSDF Budget Period Two Topical Report, which can be found at the web address www.NationalCarbonCaptureCenter.com).

3.2.2 MEA Carryover

Based on information gleaned from discussions with industry experts, the MEA carryover is thought to occur because of the presence of SO₃ aerosol in the flue gas. The aerosol acts as a

nucleation site for the formation of droplets into which the MEA diffuses. Many of the droplets are too small to be collected efficiently in the wash tower and thus escape with the CO₂-depleted flue gas. It was theorized that MEA carryover could be reduced by controlling absorber temperature (higher or lower) to increase droplet size and make them more easily removable. A parametric test program was defined, the major variables of which were:

- Operation with two and three beds, with and without intercooling
- Adjusting of the wash water MEA concentration

Coincidentally, for a portion of the test period, a higher sulfur coal was burned, allowing the effect of higher SO₃ to be investigated also.

- Test 1 was a repeat of the major operating conditions in the 2011 MEA testing, using three beds without intercooling. The MEA concentration in the wash water was the intrinsic value determined by the operating conditions.
- Test 2 was similar to Test 1 but with both intercoolers in service to provide the maximum degree of cooling. The MEA concentration in the wash water was adjusted to the same value as for Test 1 to eliminate this as a variable. Solvent carryover increased 3.5 times, presumably as a consequence of lowering the absorber solvent temperature.
- Test 3 employed only two beds with one intercooling stage, and again the MEA concentration in the wash water was adjusted to the value achieved in Test 1. Solvent carryover was reduced, possibly because the unused upper bed was collecting droplets.
- Test 4 was similar to Test 3 but with the wash water flushed several times to achieve the lowest possible MEA concentration, which is considered responsible for the reduced solvent carryover.
- Test 5 was similar to Test 3 but without intercooling and with the MEA concentration in the wash water achieving its intrinsic value. The solvent carryover was the lowest of all the tests, presumably because the higher solvent temperatures resulted in the formation of larger droplets coupled with the droplet interception capability of the inactive upper bed.
- Test 6 was similar to Test 3 but allowing the wash water to achieve its intrinsic MEA concentration, which accounts for the increased solvent carryover.
- Tests 7, 8, and 9 were similar to Test 5, but conducted with flue gas from a higher sulfur coal, resulting in higher SO₃ in the flue gas entering the absorber. On average, this resulted in 80-percent higher solvent carryover, roughly proportional to the increase in SO₃ level. The three results indicated a high level of data reproducibility.

The results are presented in Table 5.

Table 5. Parametric Tests Results for Solvent Carryover from Absorber Wash Tower.

<i>Test</i>	<i>Beds</i>	<i>Number of Intercoolers</i>	<i>Maximum Temperature, °F</i>	<i>MEA in Wash Water, wt.%</i>	<i>Total MEA Carryover, lb/hr</i>
Alabama Bituminous Coal (Flue Gas with 1.8 ppmv SO ₃)					
1	3	0	174	1.05 ⁽¹⁾	2.1
2	3	2	160	0.98 ⁽²⁾	7.3
3	2	1	162	1.06 ⁽²⁾	4.9
4	2	1	163	0.22 ⁽³⁾	3.8
5	2	0	174	0.92 ⁽¹⁾	1.1
6	2	1	163	5.58 ⁽¹⁾	5.9
Higher Sulfur Illinois Coal (Flue Gas with 3.2 ppmv SO ₃)					
7	2	0	176	1.16 ⁽¹⁾	1.8
8	2	0	174	1.02 ⁽¹⁾	2.1
9	2	0	174	1.08 ⁽¹⁾	1.7
⁽¹⁾ Intrinsic Values ⁽²⁾ Adjusted to ~1% ⁽³⁾ Reduced Using Fresh Water					

These data indicate that MEA carryover:

- Increased with SO₃ level—In the moist environment of the absorber, the SO₃ aerosol forms a nucleus for droplet formation, the liquid composition being determined by local water-MEA concentrations. Stack measurements performed by others indicate that 4 ppm of H₂S in flue gas corresponds to about 10⁶ particles/cm³, the majority being 0.1 microns or smaller, so there are abundant sites for droplet formation.
- Decreased with increasing solvent temperature—It is hypothesized that the higher the temperature, the larger the droplets formed and so the easier they are removed in the wash tower.
- Decreased with the upper absorber bed inactive—It is hypothesized that the liquid present on the surface of the structured packing in the upper bed intercepts some of the smaller droplets that would have otherwise passed through the wash tower.
- Decreased with wash water MEA content—The lower the MEA content of the wash water, the lower the equilibrium MEA vapor content of the gas stream.

Based on these results, NCCC staff communicated with suppliers of gas-liquid contactor equipment to determine how wash tower performance might be improved. One designer recommended that the structured packing be replaced with a bubble tray design, recirculating water between tray levels and feeding clean water to the upper tray. The supporting modeling work did not predict the increased solvent carryover, reducing confidence in the success of the proposed modification.

Currently the NCCC is working with Sulzer, the original equipment supplier, to test an innovation that is expected to reduce greatly carryover without increasing water usage. The

current proposal is to install Sulzer's devices in the head of the absorber and the wash tower and test their effectiveness separately and in combination in reducing solvent carryover.

As reported in the NCCC's Budget Period Three Topical Report, during tests completed at the PC4, Aker Clean Carbon used an anti-mist technology on the wash tower of its Mobile Test Unit that was able to eliminate solvent carryover. This proved effective for Aker's CCamine solvent as well as for MEA, showing that reduced solvent carryover can be achieved. The basis of the technology is proprietary.

3.2.3 Amine and Degradation Product Carryover

To determine the composition of the vapor and liquid leaving the wash tower and the regenerator condenser, the NCCC uses a modified version of the Environmental Protection Agency (EPA) Modified Method 5 (MM5) extractive sampling train. See Budget Period Three Topical Report for further description of the sampling method and the analytical methods used.

The results of the analyses are presented in Table 6. The majority of the species collected were in the liquid phase. For example, the total MEA present is 135 ppmv and only 4 ppmv was present in the vapor (both concentrations are expressed as being present in the gas phase). However, this is the vapor content at 40°F (leaving the ice bath of the MM5 sampling apparatus), not the flue gas temperature (125°F). Passage through the bath results in the condensation of an unknown amount of vapor; hence, by convention, results are expressed as vapor.

Table 6. Amine and Degradation Product Carryover during MEA Testing.

<i>Analyte</i>	<i>Outlet Concentration, ppmv⁽¹⁾</i>	
	<i>Wash Tower</i>	<i>Regenerator</i>
MEA	135	0.061
Formaldehyde	0.32	2.09
Acetaldehyde	0.69	2.04
Ammonia	140	3.5
Ethyl amine	0.036	ND
Acetone	0.18	0.033
Acetonitrile	0.039	0.023
Acetic acid	0.021	0.020
Propionic acid	0.23	0.26
N-Nitrosodimethylamine ⁽²⁾	0.000225	0.0000058
N-Nitrosodiethanolamine ⁽²⁾	0.00106	ND
⁽¹⁾ Expressed as ppmv in the gas phase		
⁽²⁾ Present only in vapor samples		
ND = Not Detected		

The conclusions from this area of testing were:

- Almost all the MEA carryover from the capture plant occurs downstream of the wash tower. As discussed previously, this is because of the SO_3 present in the flue gas. There is essentially no SO_3 present in the regenerator, and MEA carryover is almost negligible.
- Over 97 percent of the ammonia produced is carried over from the wash tower, possibly indicating that oxidation degradation is more pronounced than thermal degradation. Adding an oxidation inhibitor will reduce solvent degradation and so lower ammonia release.
- As ammonia is a degradation by-product, it is likely that the other degradation products are also promoted by oxidation. The majority of the formaldehyde and acetaldehyde are carried over from the regenerator, most likely due to their lower volatility compared to ammonia.
- Only two nitrosamines were detected. These were nitrosodimethylamine, which was below 1 ppb, and nitrosodiethanolamine, at about 1 ppb. Neither compound was detected in the liquid samples.

In the 2011 MEA Baseline Test Campaign, an additional impinger was added to the sampling train to allow the CO_2 -depleted flue gas to bubble through 0.02-N sulfuric acid (H_2SO_4). It was anticipated that this would react with the MEA and lower the carryover. The MEA was indeed reduced, but so too were other species that do not react readily with sulfuric acid (e.g., acetaldehyde). Hence, it was possible that removal was as a result of bubbling the gas through a liquid not necessarily sulfuric acid.

The tests were repeated in March 2012 using water and sulfuric acid as the reagent. As only one sample train is available, three separate runs had to be completed: a baseline test with the additional impinger dry, followed on subsequent days by runs with sulfuric acid and with water. The results are presented in Table 7. The mode of testing may account for some of the variability, but both liquids appear equally able to remove the species listed. On the basis of these results, passing the CO_2 -depleted stream through an acid-wash stage would not be effective. Moreover, the solvent would be lost to the process, so if used would increase solvent makeup costs.

Table 7. Effect of Scrubber Liquid in Impingers on Vapor Emissions.

<i>Sampled Compound</i>	<i>Wash Tower Outlet, ppmv</i>			<i>Scrubbing Efficiency, %</i>	
	<i>No Liquid</i>	<i>H₂SO₄</i>	<i>Water</i>	<i>H₂SO₄</i>	<i>Water</i>
MEA	4.40	3.02	2.13	31.44	51.52
Formaldehyde	0.035	0.0020	0.0031	94.34	91.19
Acetaldehyde	0.628	0.492	0.734	21.53	-16.97
Ammonia	53.7	4.75	1.74	91.14	96.75
Ethyl amine	0.0356	0.0325	0.0255	8.47	28.18
N-Nitrosodimethylamine	0.000225	0.0000371	0.0000172	83.51	92.36

3.2.4 Breakdown Products Detected in Solvent

The major degradation products present in the lean solvent are presented in Table 8. The values in the rich solvent were similar. The concentration of five individual constituents generally increased with time. The amount of the compounds would be reduced by use of an oxidation inhibitor. As the constituents originated from breakdown of MEA, the constituents will vary with the solvent used. Activated carbon filters are in place to remove degradation products, and their efficacy will be assessed in subsequent runs.

Table 8. Major Degradation Products in Lean MEA.

<i>Constituent</i>	<i>Concentration, ppmw</i>		
	<i>3/9/2012</i>	<i>3/15/2012</i>	<i>3/22/2012</i>
Formaldehyde	1.91	4.69	6.48
Acetaldehyde	0.21	0.29	0.37
Acrolein	0.15	0.30	0.39
Total	2.27	5.28	7.24

Figure 26 shows how the color of the solvent varied during the run, moving from pale yellow to a rich reddish brown. Similar color changes have been observed with other solvents. The cause of the color change has not been established, but may be degradation products or the accumulation of metals.

Figure 26. Color Change of Solvent During 2012 MEA Baseline Test Campaign.

3.2.5 Metal Accumulation in Solvent

According to the EPA, a waste is considered hazardous if it exhibits at least one of four characteristics: ignitability, corrosivity, reactivity, and toxicity. Solvent disposal was deemed to only be influence by toxicity criteria, so only this characteristic is discussed.

Over time, water percolates through solids in a landfill and dissolves contaminants that may pose health risks if that water enters the food chain. The Toxicity Characteristic Leaching Procedure

(TCLP) simulates this leaching process and determines which of the contaminants identified by the EPA are present and in what concentration. Forty chemicals are currently listed, including heavy metals, pesticides, solvents, and some other organics. In the case of a liquid with less than 0.5-wt% solids, the liquid is considered to be the TCLP leachate.

If regulated limits of any one of the 40 chemicals are exceeded, then the waste is considered hazardous under the Resource Conservation and Recovery Act (RCRA) and must be disposed meeting strictly enforced requirements, all at increased cost to the waste producer. If sent to disposal, the landfill must include a barrier to contain groundwater with a facility to treat any run off. Before entering the landfill, some hazardous wastes may require treatment such as stabilization and/or solidification. In some instances, to reduce the volume of waste, incineration with stringent flue gas cleanup may be used.

If more than 2,200 lb of hazardous waste is produced per calendar month, then the producer is determined to be a Large Quantity Generator, and this carries additional onerous requirements, such as reporting and accounting requirements, further adding to the cost of waste disposal. The most economical way to proceed is likely to be identifying how to avoid producing the hazardous waste, if at all possible.

At the end of the 2011 MEA Baseline Test Campaign, consideration was given to disposing of the used solvent. In accordance with RCRA requirements, solvent analysis was completed for the eight metals listed in Table 9 and included the 40 regulated chemicals. These were all determined by inductively coupled plasma mass spectrometry (ICP-MS) except for mercury, which was determined by cold-vapor atomic fluorescence spectroscopy. While the RCRA limits provided in the table are in units of ppbw, the RCRA limit is actually defined in units of mg/L (1,000 ppbw is approximately equal to 1 mg/L).

Table 9. RCRA-Listed Metals in Solvent from 2012 MEA Test Campaign.

<i>Metals</i>	<i>Inlet Gas, ppbw</i>	<i>Liquid Concentrations, ppbw</i>			<i>RCRA Limit, ppbw</i>	<i>Probable Source of Buildup</i>
		<i>Fresh MEA</i>	<i>Makeup Water</i>	<i>Final MEA Solution</i>		
Arsenic	1.13	< 12	0.462	219	5,000	Flue Gas
Barium	3.40	< 12	54.3	265	100,000	Flue Gas
Cadmium	< 0.14	< 12	< 0.225	< 10	1,000	
Chromium	0.315	< 12	0.927	45,090	5,000	Corrosion
Lead	0.271	< 12	2.34	< 10	5,000	
Mercury	0.009	> 0.50	> 0.50	> 0.50	200	
Selenium	9.74	44.1	< 0.225	1,950	1,000	Flue Gas
Silver	< 7.00	< 12	< 0.225	< 500	5,000	

The initial solvent for the 400-hour 2012 campaign was 50 percent fresh MEA and 50 percent from the 1,140-hour 2011 campaign, so the metals concentration is roughly equivalent to a 1,000 hour run (1140/2 + 400). Even in this short time, two metals exceeded the RCRA limit.

- Chromium was measured at 45,090 ppbw, well in excess of the 5,000 ppbw limit. The majority of the chromium originates from corrosion of the 316L stainless steel, which is composed of about 18 percent chromium. The 316L was selected for the vessel material due to its corrosion resistance, although these results indicate that a corrosion inhibitor is needed as well. The chromium would be significantly reduced by fabricating the plant from carbon steel, which is standard industrial practice.
- Selenium was measured at 1,950 ppbw, almost twice the 1,000 ppbw limit. The selenium originates mainly from the flue gas. Speciation testing using Reverse Phase, Ultra-High Pressure Liquid Chromatography, Inductively Coupled Plasma, Triple Quadrupole Mass Spectrometry (RP-UHPLC-ICP-TQMS) showed that 50 percent of the selenium was selenide, 25 percent selenite, and 25 percent elemental selenium. Selenate, the most toxic form of selenium, was below the detection limit.
- The presence of amine interfered with the RP-UHPLC-ICP-TQMS procedure when used to determine the chromium species present, but the procedure successfully determined the species of arsenic present. For arsenic, 17 percent was present as arsenite and 83 percent as arsenate. Although both are toxic, the former is the most toxic.
- The other metals present above the lower detection limits (LDLs), arsenic (219 ppbw) and barium (265 ppbw) both originate mainly from the flue gas. The variability seen in LDL values is normal, and varies between chemicals and the medium in which they are present.
- The flue gas content of RCRA metals is very low, but the high level of gas-liquid contact and the chemical environment in the absorber appears effective at removing much of it.
- The fresh MEA contained about 44 ppbw of RCRA metals (mainly selenium) but the used MEA contained 47,250 ppbw (mainly chromium).
- The solvent process includes a reclaimer to thermally separate the solvent from heat stable salts. It is likely that the metals in Table 9 will remain with the residue, and although this will reduce the quantity of waste, the concentration will be approximately 10 times higher.

The ICP-MS analysis revealed the presence of a range of other metals not included in the RCRA limit. Table 10 presents these additional metals that originate either from corrosion of the materials of construction or from the flue gas. Discussion on some of the metals follows.

Table 10. Non-RCRA-Listed Metals in Solvent from 2012 MEA Test Campaign.

<i>Metal</i>	<i>Inlet Gas Concentration, ppbw</i>	<i>Liquid Concentrations, ppbw</i>			<i>Probable Source of Buildup</i>
		<i>Fresh MEA</i>	<i>Makeup Water</i>	<i>Rich MEA Solution</i>	
Aluminum	281	< 120	272	4,060	Flue Gas
Calcium	684	< 1200	15,720	23,100	Flue Gas/FGD
Cobalt ⁽¹⁾	< 0.07	< 12	0.431	1,020	Corrosion
Iron	17.6	191	18,410	137,200	Corrosion
Magnesium	21.4	< 240	4,660	15,340	Flue Gas/FGD
Manganese	74.3	< 60	83.2	5,620	Flue Gas/Corrosion
Molybdenum ⁽¹⁾	< 0.28	< 12	0.886	5,270	Flue Gas
Nickel ⁽¹⁾	0.205	24.8	2.42	28,770	Corrosion
Potassium	38.8	< 1200	1,520	6,480	Flue Gas
Sodium	49.7	< 1200	5,110	399,100	Flue Gas/Pre-scrubber
Strontium	3.20	< 12	46.2	84.7	Flue Gas
Tungsten	< 0.70	< 12	< 0.225	1,590	Flue Gas
Vanadium	< 0.28	< 12	3.14	165	Flue Gas
Uranium	< 0.14	< 12	< 0.225	12.3	Flue Gas
Zinc	2.95	< 120	27.4	940	Flue Gas

⁽¹⁾ Regulated in California

- Cobalt was above 1,000 ppbw and is considered to be a corrosion product. The cobalt present in the solvent may have originated from metal workings from fabrication, as cobalt is used to harden and thus increase wear resistance of metal components.
- Iron (137,200 ppbw), manganese (5,620 ppbw), and nickel (28,770 ppbw) (with chromium) were present in the same proportions as are those metals in 316L stainless steel, the material used in fabricating the PSTU vessels. Iron and manganese are also present in the flue gas.
- Calcium (15,720 ppbw) and magnesium originate from the flue gas, probably material picked up from the FGD as fine particulate.
- Sodium (399,100 ppbw) originates from the flue gas, and is almost certainly material picked up from the pre-scrubber. Ways of reducing this carryover will be investigated.
- The fresh MEA contained about 920 ppbw of other metals (mainly aluminum), but the used MEA contained 628,750 ppbw (mainly sodium and iron).

3.2.6 Anion Accumulation in Solvent

The anions in the MEA and presented in Table 11 were measured using ion chromatography. Note that the concentrations were measured in ppmw, not ppbw as for the cations. The major inorganic anion detected was sulfate, the majority of which likely arises from salts of sodium

(pre-scrubber), calcium and magnesium (wet FGD), and potassium and aluminum (coal ash), all cations being detected in used MEA (see Table 10). Some sulfate may also arise from the transmission of SO₂ from the caustic scrubber, but this is thought to be a minor source. The chloride, nitrate, and nitrite originate from the flue gas, and the oxalate and formate are solvent degradation products.

Table 11. Anions in Solvent from 2012 MEA Test Campaign.

<i>Anion</i>	<i>Rich MEA Concentration, ppmw</i>	<i>Probable Source of Buildup</i>
Sulfate	1,010	Flue Gas
Chloride	21.2	Flue Gas
Nitrate	19.3	Flue Gas
Nitrite	2.3	Flue Gas
Oxalate	393	Solvent Degradation
Formate	1,820	Solvent Degradation

3.2.7 Solvent Metals Removal

While contaminants in the solvent must be limited to prevent operational issues such as foaming, deposition, and sludge formation, one of the greatest concerns is reducing the selenium level, as it infringes the RCRA limit. Because chromium originates from corrosion, it is assumed that its concentration can be managed by appropriate selection of materials of construction. Hence, the initial studies concentrated on the removal of selenium with the effect on the other materials present.

Metals Removal Using Established Water Treatment Methods

NCCC staff has consulted with water treatment experts to determine how selenium might be most economically removed. Based on studies of selenium chemistry for water treatment, three different waste water chemical treatment procedures were identified.

- Treatment with copper chloride solution without pH adjustment
- Treatment with ferric chloride solution with pH adjustment using sulfuric acid
- Treatment with zero-valent iron (ZVI) powder with and without pH adjustment

All three treatment techniques have been reported to remove selenium successfully from a variety of wastewater streams, but there is no experience of their use to treat MEA solutions. The tests were carried out using a bench-scale jar tester, consisting of several stirred beakers that allowed a range of conditions to be tested simultaneously and so accelerate progress of parametric testing.

No precipitation of solids was observed with either copper or ferric chloride, even when a flocculant was added, indicating that there was no removal of selenium or any other metals. It is

assumed that the MEA interfered with the precipitating reaction, possibly by chelating the metal cations. As MEA is a buffer, a large amount of acid was needed to adjust the pH, and consequently much of the MEA was consumed. From this observation, it was concluded that for a removal process to be successful, it should not require acidification.

For the ZVI tests with acidification for pH adjustment into the range 5 to 6, approximately 75 percent of the selenium in the MEA solution was removed, lowering the concentration from approximately 900 ppbw to 200 ppbw. No other metals were removed. Speciation tests revealed the following characteristics of the removal process:

- Selenide constituted 54 percent of the selenium and the ZVI removed 95 percent of it, reducing the concentration from 490 ppbw to 20 ppbw.
- Selenite constituted 44 percent of the selenium, and the ZVI removed 75 percent of it, reducing the concentration from 400 ppbw to 100 ppbw.
- The selenate constituted around 1 percent of the selenium, and the ZVI reduced the amount to below the lower detection limit.
- The elemental selenium was not detected initially, but increased to around 80 ppbw, possibly the acid promoting a conversion from one of the other species.

The selenium species in the used solvent were determined twice, first without treatment (at a pH of 10.3) and then with acidification to reach a pH of 5 to 6. The results are presented in Table 12. The biggest change was the increase in selenite and corresponding reduction in elemental selenium occurring as a result of acidification. Variation of species with oxygen-reduction potential and pH has been observed by researchers investigating water treatment processes. These are the first known results for aqueous amine solutions.

Table 12. Selenium Species in MEA Solvent with and without pH Adjustment.

<i>Selenium Species</i>	<i>Percentage of Selenium Species</i>	
	<i>Without pH Treatment</i>	<i>With pH Treatment</i>
Selenide	50	54
Selenite	25	45
Elemental	25	Below LDL
Selenate	Below LDL	1

Metals Removal Using ZVI Method at Texas A&M University

MEA samples were sent to Texas A&M University to be treated using their proprietary process based on ZVI without acidification. A bench-scale jar tester was used with the pH of the MEA at its intrinsic value of 10.3. Table 13 lists the removal efficiency after six hours of ZVI treatment for the RCRA metals that were measurable in the solvent as well as several non-listed metals. The difference in separation performance compared to the NCCC test results may arise from not using sulfuric acid for pH adjustment. Some of the non-listed metals (calcium, iron, and potassium) increased in concentration, presumably because they are present in the ZVI oxide mixture.

Table 13. Efficiency of Metals Removal from MEA Solvent with Texas A&M ZVI Process.

<i>Metal</i>	<i>Removal Efficiency, %</i>
RCRA Listed Metals	
Arsenic	96
Barium	98
Selenium	80
Chromium	31
Non-Listed Metals	
Aluminum	15
Cobalt	80
Magnesium	39
Manganese	86
Molybdenum	16
Nickel	66
Sodium	5
Strontium	74
Tungsten	63
Vanadium	83
Uranium	67
Zinc	64

Metals Removal Using Sorbents

One supplier recommended three sorbents developed for water treatment, which were evaluated in the bench-scale jar tester without acidification. The sorbents are 650 micron silica matrix materials (marketed as Self Assembled Monolayers on Mesoporous Supports) licensed from Battelle. The three sorbents tested were:

- ESL-63 for removal of lead, zinc, cobalt, iron, and nickel
- FESL-63 for removal of selenium, chromium, and arsenic
- THSL-63 for removal of mercury, cadmium, lead, selenium, cobalt, iron and magnesium

None of the sorbents, individually or in combination, removed any of the metals. Again, the MEA is believed to interfere with the separation mechanism, and there are no plans to test other sorbents.

Other Methods of Metal Removal

Methods used by the petrochemical industry for removing contaminants from MEA include ion exchange and electrodialysis. Samples of used MEA will be tested to determine if these two techniques remove metals as well as degradation products.

3.2.8 Oxygen Content of CO₂ from Regenerator

The CO₂ specification for pipeline transportation is that it contains less than 100 ppmv of oxygen to inhibit corrosion of carbon steel. The oxygen can be transferred into the regenerator either dissolved in the solvent or as flue gas entrained with the solvent pumped from the absorber sump. It was decided to measure this important parameter. A gas chromatograph was investigated initially but the argon peak of the carrier gas obscured the oxygen peak. Instead, a GE O2X1 fuel-cell oxygen detector probe was selected for the measurement program. Attempts to make continuous measurements were confounded by small leaks resulting in high oxygen contents. Therefore, a batch mode of sampling and analysis was used.

- First, all the air was displaced from the bomb using a nitrogen purge for an extended period. The bomb was then valved off to prevent oxygen re-entering.
- The bomb was attached to a tapping on the regenerator outlet and CO₂ at 1.7 bar (25 psia) was purged through for an extended period. The bomb was then valved off, enclosing the CO₂ sample at elevated pressure.
- The bomb was attached to the inlet of the GE O2X1 analyzer and the gas passed through for about one minute until the pressure had decayed.
- Six samples were taken, and the average oxygen content was about 10 ppmv.

The conclusion is that the oxygen content of the CO₂ is comfortably below the 100 ppmv limit.

3.2.9 Additional MEA Testing

A third MEA run would be beneficial in confirming the effectiveness of measures to reduce solvent carryover and to maintain solvent metals content at low levels. The current plan is to use the SSTU to screen proposed measures and then confirm their long-term effectiveness in the PSTU.

3.3 Hitachi Solvent

Since the early 1990's, through extensive research, development, and demonstration, Hitachi has developed and continually improved CO₂ capture process designs and technologies for full-scale power plant applications. Hitachi's latest advanced amine solvent, H3-1, reportedly has a high CO₂ capture capacity, low regeneration energy, high resistance to degradation, low amine losses, and low corrosivity. Hitachi conducted testing in the PSTU to demonstrate the solvent for use at coal-burning facilities in the U.S.

Testing of Hitachi's H3-1 solvent began in the PSTU in April and concluded in mid July, with a total of over 1,300 hours of testing. The test campaign included parametric testing followed by continuous long-term testing at an optimum condition. The parametric tests were conducted over a range of operating conditions including a varying number of absorber beds in service and with and without intercoolers in service. The operating condition ranges are listed in Table 14.

Table 14. Operating Parameters for Hitachi Solvent Testing.

<i>Operating Parameter</i>	<i>Range</i>
Absorber Flue Gas Flow Rate (G), lb/hr	4,000 to 6,000
Solvent Flow Rate (L), lb/hr	7,000 to 17,000
Reboiler Steam Flow Rate (S), lb/hr	700 to 1,100
Absorber Inlet Flue Gas Temperature, °F	96 to 122
Absorber Inlet Solvent Temperature, °F	96 to 114
Wash Tower Exit Temperature, °F	107 to 123
Regenerator Pressure, psig	3 to 22
Inlet Flue Gas CO ₂ Content, vol%	11 to 13
Number of Absorber Beds	1, 2, and 3
Intercoolers	On and Off

The test objectives include the verification of operational performance, establishment of absorber flooding conditions, and determination of the effects of the following:

- L/G and S/L ratios on CO₂ capture performance
- The number of beds and intercooling on CO₂ capture performance
- Flue gas and solvent temperature on CO₂ capture performance
- Operating pressure on solvent regeneration
- Wash tower exit temperature on solvent carryover

During testing, an automatic titrator determined the CO₂ loading and amine content of the solvent entering and leaving the absorber. Periodic checks were completed by manual titration of the samples. Both titration devices were calibrated with an analytical standard provided by Hitachi. During testing, NCCC staff performed mass balance checks to ensure the reliability of data yielded from plant instrumentation. A variety of gas and liquid samples were taken by NCCC staff during the test period. The PC4 gas sampling system was used to determine solvent carryover from the wash tower. Gas sampling methods suggested by Hitachi were used to collect samples from the wash tower and regenerator to determine the carryover of amine and nitrosamines.

Hitachi is working with NCCC staff on data analysis and preparation of the final report. Preliminary information presently available has been released as a series of figures, which are presented and discussed briefly.

Figure 27 plots the variation in capture efficiency over the test campaign. The range of variables covered is given in Table 14. On average, CO₂ capture efficiency of over 90 percent was achieved over the test period.

Figure 27. CO₂ Capture Efficiency over the Duration of Hitachi Solvent Testing.

The variation of CO₂ capture efficiency with solvent flow rate for a constant reboiler steam flow is presented in Figure 28. For these conditions, capture efficiency reaches a maximum at a particular solvent flow rate. At the lower flow rates before the maximum, as less solvent is available, solvent leaving the absorber is richer, and this limits the amount of CO₂ that can be captured. At the higher solvent flow rates after the maximum, more of the heat supplied is used to provide sensible heat. As the heat supplied is constant, less is available for regeneration and less CO₂ is released, increasing the loading of the lean solvent. This in turn results in the solvent leaving the absorber becoming richer and again limiting the amount of CO₂ that can be captured. The operating conditions for these tests are as follows:

- Inlet flue gas CO₂ content: 11.5 to 11.9 percent
- Flue gas flow rate: 5,000 lb/hr
- Number of packed beds in service: 3 without intercooling
- Regenerator operating pressure: 14 psig

Figure 28. Variation of CO₂ Capture Efficiency with Hitachi Solvent Flow Rate.

The variation of regeneration energy with solvent flow rate for a constant reboiler steam flow is presented in Figure 29. For these conditions, regeneration energy reaches a minimum at the same solvent flow rate producing the maximum in Figure 28. This occurs because regeneration energy is inversely proportional to the amount of CO₂ captured. The operating conditions for these tests were the same as those listed above.

Figure 29. Variation of Regeneration Energy with Hitachi Solvent Flow Rate.

The variation of CO₂ capture efficiency with reboiler steam flow and flue gas CO₂ content is presented in Figure 30. The operating conditions were the same for both data sets. Data showed that efficiency fell for steam flow rates below the optimum value. At the lower steam flows, the lean solvent returning to the absorber is richer in CO₂, and this limits the amount of CO₂ that can be captured. Efficiency also fell with increasing flue gas CO₂ content. Presumably, the rich solvent leaving the absorber is saturated with CO₂ in both cases, and so a lower percentage is removed for the flue gas with the higher CO₂ content.

Figure 30. Variation of CO₂ Capture Efficiency of Hitachi Solvent with Reboiler Steam Flow Rate.

The data collected and given in Table 15 showed that compared to 30 wt% MEA, Hitachi's H3-1 operated with a 37 percent lower L/G ratio, achieving a 33 percent lower heat of regeneration. Operation with the H3-1 solvent requires lower regeneration energy because less liquid has to be heated in the reboiler in combination with a lower heat of reaction with CO₂. The operating conditions for these tests were:

- Inlet flue gas CO₂ content: 12.5 to 13.0 percent
- CO₂ capture efficiency: 92 to 94 percent
- Flue gas flow rate: 5,000 lb/hr
- Number of packed beds in service: 3 without intercooling

Table 15. L/G Ratio and Heat of Regeneration of 30 wt% MEA and Hitachi Solvent.

<i>Solvent</i>	<i>L/G Ratio</i>	<i>Heat of Regeneration, Btu/lb</i>
30 wt% MEA	3.2	1,550
H3-1	2.2	1,030

With three beds in service, using the intercoolers was shown to raise the CO₂ capture efficiency from 89 to 94 percent. By lowering average solvent temperature in the absorber enabling operation in the optimal range of 100 to 140°F, the intercoolers enhance CO₂ capture efficiency. For these values, the inlet flue gas CO₂ content ranged from 11.7 to 12.0 percent, and the flue gas flow rate was 5000 lb/hr.

The CO₂ capture efficiency increased with the number of absorber beds in service, as demonstrated by the data provided in Table 16. With more beds, the surface area available for gas-liquid contacting is increased and the gas residence time in the reaction zone is increased. Both factors help raise CO₂ capture efficiency. For these values, the inlet flue gas CO₂ content ranged from 11.7 to 12.3 percent, and the flue gas flow rate was 5000 lb/hr.

Table 16. CO₂ Capture Efficiency of Hitachi Solvent with Varying Number of Absorber Beds in Service.

<i>Number of Beds in Service</i>	<i>CO₂ Capture Efficiency, %</i>
1	76.5
2	87.7
3	91.7

3.4 BASF / Linde Solvent and Process

BASF and Linde are designing and planning the construction and operation of a pilot-scale test facility to be installed and tested at the PC4. Figure 31 provides a model view of the 1-MW CO₂ capture pilot plant. The plant, which will incorporate BASF/Linde's enhanced CO₂ capture process and an advanced amine solvent from BASF, is designed to process up to 30 tons/day of

CO₂. The group plans to optimize the process through parametric testing and to accumulate critical data for commercial scale-up through long-term testing.

Figure 31. Model View of BASF/Linde Pilot Unit.

Progress during the year for the BASF/Linde project included:

- Establishing a design basis
- Developing a project schedule
- Preparing engineering drawings and a 3-D model
- Completing a design hazard review
- Initiating procurement of major balance of plant equipment
- Preparing the test site

Installation of the pilot plant is scheduled to begin in the fourth quarter of 2013. Testing is planned to begin in 2014 and to continue into 2015.

3.5 Cansolv Technologies Solvent

As part of its research and development of CO₂ capture processes, Cansolv Technologies conducted extensive testing of its DC-201 solvent in the PSTU in the third quarter of 2012. Testing involved parametric studies, equipment configurations, and solvent additives.

The piloting campaign duration was three months, from July 24 to October 28, 2012. A total of 1,725 hours of testing was achieved, which represents 80 percent of stable operation over the period. The test plan was interrupted on three occasions due to E.C. Gaston power plant shut-down or maintenance on the selective catalytic reduction (SCR) unit and scrubber: from August 15 to August 19; from September 7 to September 17; and on September 27.

Typically, two data points were collected per day, comprising of critical pilot unit parameters, such as temperatures, flows, and pressures, as well as liquid and gas sample analyses. Data collection was initiated after conditions had been stable for at least three hours. Liquid samples consisted of pre-scrubber sump, lean amine, rich amine, reflux, and water-wash recirculation fluids. Mass balance closures between the absorber and the stripper were very good (within 2 percent). The test protocol was discussed and refined by Cansolv Technologies and NCCC staff prior to the test. The test was divided into the sub-tests indicated by Table 17.

Table 17. Cansolv Solvent Test Schedule.

The technical objectives defined for the test included evaluation of the following:

- Approach to equilibrium at various temperatures and L/G ratios (including 1, 2, or 3 absorber beds in service with 0, 1, or 2 intercoolers operating)
- Regeneration energy at various L/G ratios and regeneration temperatures and pressures
- CO₂ capture percentage at various solvent concentrations
- Amine or degradation product concentrations upstream and downstream of the water-wash section as well as in the CO₂ product
- Solvent stability under the oxidative environment, including the effect of SO₂ and NO₂ concentration in the gas
- Corrosion rates
- The effect on CO₂ capture performance at different concentrations of an additive

Figure 32 plots the solvent, flue gas, and steam flow rates during the test period. The gas flow through the absorber was kept constant at 5,000 lb/hr. The liquid flow rate was varied from 11,000 to 6,800 lb/hr and the steam flow rate from 750 to 1,000 lb/hr, depending on test conditions.

Figure 32. Solvent, Flue Gas, and Steam Flow Rates during Cansolv Solvent Testing.

3.5.1 Optimization of Energy vs. L/G Ratio

This part of the test investigated the loading capacity of the solvent in the absorber and its influence on reboiler steam usage. These tests were performed at the same gas flow rate that was used for the evaluation of MEA on the PSTU unit. The amine and steam flows were varied to achieve 90 percent CO₂ capture. Figure 33 gives the results of this first set of experiments. The DC-201 solvent required 40 percent less energy than MEA to achieve the same capture rate using three packing sections in the absorber. The solvent also required 50 percent less circulation (L/G being 4 kg/Nm³ for MEA and 2 kg/Nm³ for DC-201).

Figure 33. Optimization of Cansolv DC-201 Solvent at Various Absorber Packing Heights.

3.5.2 Variation of Packing Height

This part of the campaign focused on the effect of absorber packing height on the performance of the capture system. The PSTU is equipped with three packing sections in the absorber, each 20 feet tall. An intercooler is located between each packing section. The solvent is withdrawn from the column at the bottom of one packing section, cooled in a heat exchanger, and returned to the column at the top of the packing section below. Lowering the solvent temperature into the optimal range increases the CO₂ solvent loading.

Three absorber configurations were tested:

- 3 packing sections, 2 intercoolers
- 2 packing sections, 1 intercooler
- 1 packing section, 0 intercooler

The amine and steam flows were varied to achieve 90 percent CO₂ capture. Results of this set of experiments are shown in Figure 34. The operating conditions (liquid to gas ratio and steam usage per ton of CO₂ captured) were not significantly affected while switching from three to two packing sections. The L/G did not vary, and the stripping factor increased from 2.2 GJ/ton CO₂ to 2.3 GJ/ton CO₂. Under these conditions, the solvent is not kinetically limiting and can reach adequate rich loading.

Figure 34. Variation of Steam Flow and Lean and Rich loadings with Absorber Packing Sections.

A clearer response can be seen when switching from two to one packing sections. In this case, to maintain 90 percent CO₂ capture, the amine flow had to be increased (L/G going from 2.0 to

2.5 kg/Nm³), as well as the steam flow. (Stripping factor increased from 2.3 GJ/ton CO₂ to 2.8 GJ/ton CO₂.) With only one packing section, the solvent appears to be kinetically limiting, and the lower rich loading achieved results in a lower lean loading and a higher steam flow rate.

3.5.3 Amine Concentration Experiments

During these experiments, the amine concentration in the solvent was varied from 40 to 60 wt% to study the effect on CO₂ capture efficiency and on steam usage (or stripping factor, expressed in GJ/ton CO₂ captured). When the amine concentration in the solvent falls below a given value, the CO₂ capture efficiency decreases due to loss of active amine sites in the solvent. This is shown in Figure 35 where reducing amine concentration from 53 to 40 wt%, reduced CO₂ capture efficiency from about 90 to 84 percent. Similarly, if the amine concentration is increased too much, some limitation in CO₂ mass transfer from the gas to the liquid phases may occur due to the increased viscosity of the solvent. A counter-measure to this loss in performance is to increase reboiler steam flow to lower the lean CO₂ solvent loading and provide extra CO₂ capacity in the absorber. These results are also shown in Figure 35. These tests indicate the following:

- Operational flexibility from 40 to 60 wt% solvent concentration
- Optimum operation with respect to energy consumption between 45 to 55 wt% solvent concentration

Figure 35. Variation of CO₂ Capture Rate, Amine Concentration, and Stripping Factor.

3.5.4 Liquid Analysis

Samples from the amine loop, as well as from the pre-scrubber were taken and analyzed for anions, cations, and metals. This activity was handled jointly by NCCC and Cansolv

Technologies. Figure 36 presents the change of anion concentrations over time in the lean solvent, as analyzed at Cansolv's laboratory in Montreal. Sulfate build-up in the solvent is related to the accumulation of sulfate salts (for example, sodium from the caustic scrubber) although there was also some SO₂ slippage from the pre-scrubber. An average of 1.5 ppmv of SO₂ has been measured in the gas entering the absorber, although this is close to the lower detection limit of the ultraviolet SO₂ analyzer used. In a similar way, the nitrate build-up is related to NO₂ entering the absorber (average measured at 2 ppmv in the gas). No drop in performance was noticed as a result of this contamination.

Figure 36. Increase of Anionic Species in Lean Solvent over Time.

Three main types of reaction are involved in the degradation of amine-based solvents:

- Oxidation of amine or hydroxyl functionalities, leading primarily to low molecular weight organic acids and ammonia
- Formation of heavier molecular weight species by coupling of two amine molecules (The product is still an amine and may have suitable CO₂ absorption properties.)
- Irreversible reaction with SO₂ leading to sulfonated neutral species
- Irreversible reaction with CO₂, leading to the formation of non-alkaline compounds such as oxazolidone, imidazolidone, etc.

The increase in concentrations of formate and acetate gives a primary indication of the degradation rate of the solvent. After three months of testing, the total amount of organic acids was 500 ppmw in solution, which indicates a very low degradation rate of the DC-201 solvent under these conditions. It should be noted that some bleed-and-feed occurred during the test, mainly due to mechanical losses through automated sampling lines.

Analysis of lean amine samples was also carried out by means of liquid chromatography coupled with mass spectroscopy. This technique allows for the detection of high molecular weight non-ionic degradation products. Although analysis of the samples has not yet been finalized, Figure 37 gives a preliminary indication of the degree of stability of the DC-201 solvent. Comparison between lean amine samples taken at the start of testing and after 900 hours reveals a minor peak at a retention time of 11.5 minutes on the chromatograph. It is considered that this degradation peak represents only a minor portion of the total amine content, but further analysis is required to quantify the degradation products present.

Figure 37. Chromatograph of Lean Cansolv Solvent Samples Taken at t=0 and t=900 Hours.

Analysis for metals was performed by Southern Research Institute at its Birmingham laboratory. Results are summarized below.

- Metals originating from the flue gas
 - Selenium (2 ppmw in pre-scrubber loop after 1 month of testing)
 - Arsenic (0.4 ppmw)
 - Manganese (2 ppmw)
- Alkyl metals found in the pre-scrubber and the amine loops originating in the caustic and water used in the pre-scrubber
 - Sodium (1.9 wt% in the pre-scrubber and 79 ppmw in the solvent)
 - Calcium (9 ppmw in the pre-scrubber and 3.5 ppmw in the solvent)
- Other metals found relating to the metallurgy of the system
 - Iron (8 ppmw in the pre-scrubber and 1.1 ppmw in the solvent)
 - Nickel (0.22 ppmw in the pre-scrubber and 0.08 ppmw in the solvent)
 - Chromium (0.57 ppmw in the pre-scrubber and 0.07 ppmw in the solvent)

These metals concentrations were much lower than for MEA, and were a good indication of the DC-201 solvent's lower corrosivity. For example, iron was measured at 137 ppmw in MEA (see Table 10), an order of magnitude higher than for DC-201.

Figure 38 plots the concentrations over time of other metals and cations detected in the lean solvent. Aside from the sodium and sulfur levels, no metals were found at sufficient levels to have any impact on the solvent CO₂ capture performance.

Figure 38. Change in Cations and Metals Concentrations in Lean Cansolv Solvent over Time.

3.5.5 Gas Sampling

Three emissions surveys were completed, with NCCC sampling at three locations: the CO₂-depleted flue gas streams upstream of the absorber wash tower (outlet of absorber) and downstream of the absorber wash tower, and the CO₂ product gas from the regenerator. Results are presented in Table 18. While analyses for nearly 50 different species were performed, only those with concentrations above the lower detection limit are reported.

Acetaldehyde, which typically comes from coal combustion gas, was detected at ppmv levels in the three streams. Formaldehyde, ammonia, and dimethylamine emissions result from the degradation of the solvent. The emissions level leaving the water-wash and in the product CO₂ (were found to be low, in the ppmv to the sub-ppmv range. Nitrosamines were also detected, but at the ppbv level. It should be noted that additional analyses related to amine emissions are still pending and will be presented when they become available.

Table 18. Main Contaminants Found in Gas Streams during Three Sampling Surveys.

<i>Outlet Sample Location</i>	<i>Abs</i>	<i>Wash</i>	<i>Regen</i>	<i>Abs</i>	<i>Wash</i>	<i>Regen</i>	<i>Abs</i>	<i>Wash</i>	<i>Regen</i>
Run Date	8/16/2012			9/25/2012			10/9/2012		
Concentration in flue gas, ppmv									
Acetaldehyde	5.51	9.83	5.33	5.22	5.26	4.94	5.7	5.51	5.47
Acrolein	0.12	0.0146	0.124	0.069	0.03	0.115	--	--	0.047
Formaldehyde	0.066	0.097	0.042	0.035	0.014	0.016	0.13	0.056	0.025
Ammonia	0.732	--	--	--	--	--	0.907	0.668	--
THC as Hexane	--	0.479	0.941	--	--	--	--	--	0.408
Dimethylamine	0.738	0.951	--	0.283	0.432	0.119	1.395	1.024	--
Concentration in flue gas, ppbv									
N-Nitrosodiethanolamine	--	0.078	0.206	0.041	0.014	--	--	--	--
N-Nitrosodimethylamine	52.1	26.7	--	0.718	0.339	0.112	4.081	1.234	0.205

3.5.6 Preliminary Conclusions

During the 1,725-hour test campaign, the Cansolv DC-201 solvent demonstrated:

- The targeted 90 percent CO₂ capture rate
- 50 percent reduction in solvent flow compared to MEA
- 35 percent reduction in energy consumption compared to MEA
- Minimal effect of solvent concentration on performances
- Minimal degradation under oxidative environment, including effect of SO₂ and NO₂
- Low emissions upstream and downstream of water-wash section
- Low corrosion rates

Additional data processing and sample analysis are pending in order to complete a final report.

3.5.7 Future Testing with Natural Gas-Simulated Flue Gas

Cansolv has identified value in testing at lower flue gas CO₂ concentrations that are representative of those from natural gas combined cycle plants. This can be achieved by introducing air into the flue gas upstream of the blower. The proposed scheme was reviewed with Cansolv personnel and a cost estimate for the work prepared. The lower CO₂ flow requires that the solvent flow also be reduced, and this could result in either flooding or insufficient wetting of the packing. The NCCC contracted the technology firm Sulzer for consultation to assess any effects upon absorber operation and recommend any necessary design or operational changes. The simulated natural gas run is planned to begin in the third quarter of 2013.

3.6 Chiyoda Solvent

Based on its experience as a worldwide engineering, procurement, and construction contractor, the Chiyoda Corporation is focusing on suitable commercial plant designs for low carbon emissions. As part of this effort, Chiyoda has been developing an advanced amine solvent in conjunction with an optimized CO₂ capture process. After equipment modifications to the PSTU requested by Chiyoda were completed, testing of the T-3 solvent began in December 2012. Chiyoda plans to continue testing into mid-2013, completing parametric testing and long-term operation. The design modifications to the PSTU requested by Chiyoda, illustrated in Figure 39, were as follows:

- Adding piping to recirculate cold-rich solvent back to different levels in the absorber. As the absorption rate for the T-3 solvent is slower than for MEA, in once-through operation the solvent leaving absorber is not fully loaded. Recycling solvent increases rich solvent CO₂ loading, reducing solvent flow to the regenerator for a given capture rate and lowering the heat of regeneration. The recycled flow might also help to flatten the vertical temperature profile in the absorber, which would also improve performance.
- Installing new piping to the regenerator to allow the hot-rich solvent to be introduced at the top of the lower level of packing instead of at the top of the column. This modification was initiated to address the concern about excess solvent carryover from the regenerator. The top bed will be flushed by the condensate return, and this will help suppress solvent carryover.

Figure 39. Modifications to PSTU Requested by Chiyoda.

The initial operation in December was truncated due to foaming in the wash tower, which resulted in a high pressure drop across the packing and the loss of solvent with the CO₂-depleted

flue gas. There was no evidence that foaming had occurred in the absorber or regenerator. Testing was planned to resume in January following a Gaston Unit 5 outage. Meanwhile laboratory tests to understand and prevent foaming will be carried out.

3.7 MTR 1-ton/day CO₂ Capture Membrane Skid

In addition to pre-combustion applications, MTR's polymeric Polaris™ membrane is being tested for separating CO₂ from coal-derived flue gas. In October 2008, in response to a solicitation, the DOE awarded \$3.4 million to MTR to build a 50-kW equivalent post-combustion capture unit and conduct a six-month field test at Arizona Public Service's Cholla coal-fired power plant near Phoenix, Arizona. Testing ran from April to July 2010, and based on the operating experience and the data collected, an improved unit was designed for testing at the NCCC.

The membrane test skid, shown in Figure 40, includes two membrane module designs required for commercial units, cross-flow membrane (CFM) and countercurrent-swept membrane (CSM) modules. The skid processes 250,000 scf/day of flue gas drawn from downstream of the pre-scrubber, and is designed to capture one ton/day of CO₂ with a capture efficiency of 90 percent.

Figure 40. MTR 1-ton/day CO₂ Membrane Components.

Figure 41 is a schematic of the skid. The incoming flue gas is cooled by chilled water, and the condensate is removed in the separator upstream of the flue gas compressor (oil-free screw design). The flue gas leaves the compressor at around 300°F and 45 psia before being cooled to around 100°F by chilled water. The condensate is removed in a separator, which also includes a coalescing filter, before the flue gas passes to the two first-stage membrane vessels. Each vessel contains two CFM membranes connected in series, individual membranes being 8-inches OD by 39-inches long. Two second-stage membrane vessels each contain a single CSM membrane, also 8-inches OD by 39-inches long. The chilling circuits are not expected to be included in commercial designs and are used on the test skid to vary inlet flue gas conditions as part of parametric testing.

Figure 41. Schematic of MTR Flue Gas Membrane Skid.

A vacuum pump on the permeate side of the first-stage membrane increases the pressure driving force to increase the amount of CO₂ removed to as high as 70 percent. The second-stage membrane extracts additional CO₂ from the residual flue gas by using sweep air on the permeate side to increase the concentration driving force. The additional removal is sufficient to increase the CO₂ capture efficient to 90 percent or higher.

The arrangement of the membranes is shown schematically in Figure 42. The flue gas leaving the separator (A) is split before entering two CFM vessels in parallel. The two CO₂-depleted flue gas streams, still at pressure, are recombined (C) then split again before entering two CSM vessels in parallel. Sweep air (D) enters each CSM vessel and the CO₂-rich air (E) leaves at the opposite end. The CO₂-rich permeate streams (B) leaving the CFM vessels are the product stream and the CO₂-lean flue gas streams (F) leaving the CSM vessels are the reject stream. All flows are eventually re-combined and passed to the return header.

Figure 42. Schematic Showing MTR Membrane Skid Gas Flows.

Commissioning of the skid was completed in December 2011 prior to shutdown for the holiday period. It operated for two days in mid-January before Unit 5 was placed in marginal reserve until early March. During restart of the membrane, the carbon-steel compressor rotor was unable to turn and was found to have rusted and seized on the casing. The corrosion almost certainly occurred because of the humid conditions within the compressor and could possibly have been avoided if it had been purged with dry gas during the extended outage.

A replacement rotor was ordered and installed. The supplier does not provide a stainless rotor for this size of compressor, so the replacement was carbon steel. A compressor bypass line was added to allow testing to continue in case of future compressor issues. A service technician also came to site and made several repairs and adjustments to improve chiller performance to further reduce flue gas humidity at the compressor inlet.

The system was restarted in April. Although operational, the chiller still had difficulty in achieving the membrane inlet flue gas design temperature of 50°F. The heat exchanger was sized for the inlet flue gas temperature at Cholla, 90°F; however, the corresponding temperature at the NCCC is typically between 120 and 150°F, depending on the PSTU blower load. To reduce cooling duty, the compressor bypass line was used to recirculate half of the 1,000 lb/hr cooled flue gas back to the compressor inlet so that only 500 lb/hr of hot flue gas was drawn from the header. Previously, the excess flow was vented.

Flue gas recirculation reduced the inlet temperature to the membrane by about 5°F. To further reduce temperature, MTR decided to use process cooling water to cool the flue gas downstream of the compressor, allowing all the chilled water to be supplied to the cooler upstream of the compressor. In September, some chiller components failed, and as the chiller is not included in the commercial design, it was removed from service. After this, all cooling was achieved by process cooling water.

In May 2012, the two-stage membrane skid was operating steadily, reducing the CO₂ from about 12 vol% in the flue gas to about 5 vol% in the CO₂-depleted discharge stream. This corresponds to around 60 percent CO₂ capture. In early June, two new CSM modules were installed with higher CO₂ permeance membrane material and configured for improved flue gas flow distribution. These improvements lowered the CO₂ content in the CO₂-depleted stream to around 3 vol%, corresponding to CO₂ capture of approximately 87 percent.

The system was shut down at the end of July to perform routine maintenances on all rotating equipment (i.e., vacuum pump, sweep air compressor, and flue gas compressor). The flue gas compressor would not turn upon attempted restart, and as in March, the rotor had rusted and seized on the casing. After evaluating various options, instead of replacing the rotor, MTR decided to install a liquid-ring compressor, which is designed to handle harsh gas conditions and is available in stainless steel.

Further inspection of the compressor showed that, in addition to corrosion, significant dark/yellowish materials were deposited in the compressor discharge line and to a much lesser degree in the inlet. The deposits were mainly water soluble, and the insoluble material was filtered from the solution. Figure 43 provides photographs of these deposit materials.

Figure 43. Deposits in Compressor Outlet and the Filtrand from the Solution made by Deposits.

The three materials (deposit, solution, and filtrand) were each analyzed, and findings are given below.

- Energy-dispersive X-ray spectroscopic (EDX) analysis showed the deposits to consist primarily of oxygen, carbon, and sulfur with lesser amounts of iron, silicon, sodium, magnesium, and aluminum.
- EDX analysis showed the filtrand to consist primarily of oxygen, iron, and sulfur with lesser amounts of carbon, silicon, sodium, magnesium, calcium, phosphorous, and aluminum. As it is insoluble, the iron is assumed to be present as a ferric compound.
- Analysis of the solution by ion chromatography showed that ammonium and sulfate ions were present. Inductively coupled plasma mass spectrometry analysis showed the predominant metal to be iron. As it is soluble, the iron is assumed to be present as a ferrous compound.

Based on these analyses, the deposit was determined to consist of:

- Around 18 wt% ammonium sulfate and/or bisulfate—This determination was made assuming double sulfates of ammonium with iron (alums) are not formed.
- Around 53 wt% iron sulfate, an approximate 50:50 mix of ferrous and ferritic salts—The iron salts are considered to be formed as a corrosion product from the reaction of the ammonium salts (which are acidic) with the iron present in the compressor exit pipe work.
- Of the remaining 29 wt%, approximately half is carbon and the other half consists of elements found in fly ash (e.g., silicon, sodium, and magnesium).

The deposits are similar to those formed in the baskets of air heaters, but the question arises as to how the ammonia penetrated Unit 5's wet FGD and the PSTU's caustic pre-scrubber. It is hypothesized that some of the SO_3 aerosol formed in the boiler and across the SCR unit (where ammonia is injected to promote NO_x reduction) is present as an ammonium compound, not as a

free radical. Measurements by others suggest the aerosol is below 0.1 microns and extremely difficult to remove from the gas stream.

A second question is why the aerosol dropped out after the compressor. Up to this point, the gas has been saturated and all surfaces wetted. Compression raises the gas temperature and lowers the saturation level. The higher temperature also increases the stickiness of ammonium sulfate/bisulfate, which then sticks to the dry surface present after the compressor.

Whether the deposits formed over a period of time, or as a consequence of an upset in the power plant is not known. Inspections of the compressor outlet in March did not reveal anything obvious, but this was after only a limited number of operating hours.

Particulate material was also found in the coalescing filter downstream of the compressor. EDX analysis indicated the presence of sulfur, iron, silicon, magnesium, phosphorous, selenium, and chlorine. This material may have been carried over from the deposits in the compressor outlet and if not removed would have passed to the membranes. If correct, this material would be eliminated if the compressor outlet deposit did not form. In the liquid ring compressor, cooling water comes into direct contact with the flue gas, which will prevent dry surfaces being created onto which the deposit can form. Moreover, any deposit that might form would rapidly dissolve in the water.

During the August outage, two CFM modules (one from each vessel) were removed for inspection by MTR. These that had been in operation since the beginning of testing in December 2011 and had been exposed to flue gas for almost 1,500 hours with some additional hours on air when flue gas was not available. No particulate was found on either end of the membranes (see Figure 44) or within the membrane envelopes (see Figure 45). Membrane performance did not degrade with time or with pressure drops increase, suggesting that the pretreatment system worked effectively and prevented fouling of the membranes by flue gas contaminants.

Figure 44. Inspection of MTR Membrane.

Figure 45. Inspection of Membrane Sheets and Feed Spacer of MTR Module.

The membrane was put back in operation in September with just two first-stage CFM membranes and with the flue gas compressor bypassed. The driving force for CO₂ permeation was from the PSTU blower on the feed side (sufficient to overcome the pressure drop across the entire membrane system) and the vacuum pump on the permeate side of the CFM module. This mode of operation provided useful operational experience, as a flue gas blower may be used on commercial systems. Near the end of September, the chiller failed, and the switch to process cooling water was made.

The liquid-ring compressor was delivered on October 29, set in the location occupied by the previous compressor, and the flue gas piping modified accordingly. Two cooling water lines were also installed to the new compressor, and a new cooling water line was installed to provide cooling duty previously provided by the chiller. A full set of six new membrane modules were also installed, two modules in series in each CFM vessel, and a single membrane module in each CSM vessel. Local flow gauges on the permeate and reject streams were replaced with transmitters to facilitate continuous collection of flow rate data, and program logic was written to start, stop, and operate the new compressor.

The system was successfully restarted on December 14 and ran for about 100 hours before being shut down on December 18 due to an outage on Unit 5. The CO₂ content of the flue gas feed was reduced from about 12 percent to around 1 percent in the residual stream leaving the skid, corresponding to CO₂ capture greater than 90 percent. This is an improvement over the previous capture efficiency of 87 percent and indicates the continuing improvements being made in membrane performance.

3.8 MTR 20-ton/day CO₂ Capture Membrane Skid

MTR is currently working to install a 20-ton/day CO₂ membrane test skid based on the 1-ton/day CO₂ system test results. During 2012, NCCC engineers participated in several design reviews at NETL, reviewed the system process, design, and layout, and began design on the preliminary routing of the new flue gas line.

Lessons learned from the operation of 1-ton/day unit provided valuable inputs to the 20-ton/day system design changes. Some of the critical skid modifications included equipment rearrangement to fit the skid to the footprint available at PC4, addition of a Venturi scrubber

upstream of the compressor, replacement of a screw compressor with a liquid ring compressor, and provision of additional instrumentation for better monitoring and control. The skid delivery is currently scheduled for the first quarter of 2014.

3.9 Codexis Enzymes

In May 2010, Codexis received \$4.7 million from ARPA-E to investigate the use of carbonic anhydrase enzymes to accelerate the rate of CO₂ capture for solvents that have desirably low heats of reaction such as methyldiethanolamine (MDEA), ammonia, and potassium carbonate. The enzyme is mixed with the solvent and so must be resistant to decomposition at regeneration temperatures. Thus, a major objective of this ARPA-E funded research was to demonstrate the stability of the enzyme under operating conditions.

Previous testing on the enzyme technology was conducted with synthetic flue gas in bench-scale stirred cell reactors and a wetted wall column and in a pilot-scale with the Codexis Test Unit (shown in Figure 46). The tests at the PC4 were the first using coal-derived flue gas to determine the stability of the enzyme in the presence of trace contaminants.

Figure 46. Codexis Enzyme Test Unit Installed at the PC4.

The Codexis Test Unit consists of absorber columns and a desorber tank. Both absorber columns are over 20 feet tall with a 4-inch internal diameter. The absorber contains loose packing while the desorber is an open vessel without packing. The flue gas flow is 850 standard ft³/hr, the solvent flow rate is 260 lb/hr, and the CO₂ removal rate is 14 lb/hr.

NCCC staff completed the design and construction necessary to accommodate the Codexis Test Unit for initial exposure of the solvent and enzymes to flue gas. Commissioning and testing were completed in a two-week period at the end of May using MDEA. Figure 47 provides trends of the operation over a six-day period with CO₂ capture averaging around 65 percent at a rate of capture over 25 times greater than for MDEA alone with 0.2 g/L of enzyme loading. No

apparent effect of trace metals or elevated process temperatures on enzyme performance was seen.

Figure 47. Results of Codexis Enzyme Testing.

Although Codexis has plans to test their carbon capture technology in a larger system (e.g., the PSTU) using the enzyme-accelerated MDEA solution, they have yet to receive the funding to do any additional work.

3.10 Akermin Enzymes

Akermin is developing a carbonic anhydrase enzyme to accelerate the capture of CO₂ by potassium carbonate, a widely available low-cost commodity chemical. Unlike most amine solvents, potassium carbonate is non-volatile, does not degrade in the presence of oxygen, SO₂ and other impurities, and has low corrosivity. These properties lower the cost of wash towers and solvent clean up equipment, and eliminate the need for corrosion inhibitors. Although the heat of reaction is half that of MEA, the potassium carbonate reaction with CO₂ (below) is much slower, hence the need for the enzyme to improve the kinetics.

The enzyme is embedded in a thin polymer film on the surface of the absorber packing and is referred to as being immobilized. This avoids transferring the enzyme into the high-temperature stripper column where it can potentially thermally decompose.

Akermin completed laboratory testing at its St. Louis site and constructed a pilot plant to process 88 lb/hr of flue gas. The NCCC performed design and installation of flue gas supply/return and utilities. In addition, heat tracing modifications were made within the Akermin skid, and Ethernet connections to operator stations in the control room were installed. Figure 48 provides a photograph of the pilot plant installed at the PC4. Checkout and commissioning of the pilot plant was completed in December 2012. Testing is planned to proceed to mid-2013.

Figure 48. Akermin Enzyme Pilot Plant Installed at the PC4.

3.11 Engineering Studies

The NCCC's Engineering and Economic Evaluations group began work on a post-combustion CO₂ capture (PCC) baseline study. In collaboration with NETL and the Electric Power Research Institute (EPRI), a study basis and scope was developed and finalized. NETL provided a process simulation model of a pulverized coal (PC) unit using AspenPlus software, and this model served as the starting point for the modeling work completed by the study. The model was expanded to include post-combustion flue gas cleanup processes and CO₂ compression. Validation of the model against data from MEA solvent tests at the PC4 and against Southern Company steam cycle data resulted in significant expansion and modification of the model.

As an example of optimization efforts during this study, fourteen heat and material balances were computed to determine the optimum lean solvent loading and regenerator pressure for MEA. Heat integration was optimized starting with methods suggested by EPRI in a 2011 study on a pulverized coal unit with post-combustion cleanup. The condensation of sulfuric acid on the heat exchanger surfaces was investigated to determine the appropriate heat exchanger material of construction. An investigation was conducted on the impact of MEA concentration, operating temperature, and CO₂ loading on corrosion, oxidation degradation, and polymerization. The engineering firm WorleyParsons was contracted to provide a capital cost estimate for the amine system of plant. The PCC study was nearly completed in 2012, and four cases will be reported in early 2013.

An economic evaluation was completed comparing PRB coal and an Illinois bituminous coal in a PC+PCC plant based on different flue gas cleanup technology to provide equivalent amine slip. It was determined that bituminous coal gives a lower cost of electricity. An investigation was also conducted of the thermodynamic feasibility of pressurized coal drying for very high moisture coals.

Over the course of 2012, the NCCC migrated its process simulation software from AspenTech to ChemCAD software from ChemStations. Work was begun to establish a design basis for a NCCC system study of using membranes for post-combustion CO₂ capture and to establish a relationship between DOE and ChemStations that will allow DOE's membrane unit operations model to be integrated into CHEMCAD software.

4.0 GASIFICATION

The NCCC gasification process, represented in Figure 49, features several key components of an IGCC plant. These include high pressure solids feed systems; a Transport Gasifier; syngas coolers; a hot gas filter vessel, the PCD; and continuous ash depressurization systems for ash cooling and removal. During the year, the gasification process operated over two test runs, R08 and R09, for a total of more than 1,250 hours. Progress continued on the development of the pressure decoupled advanced coal (PDAC) feeder, gasifier control automation, sensors, and instrumentation. Run R08 included a 219-hour test period of co-feeding biomass with coal in oxygen-blown gasification conducted on behalf of CCAT, and R09 featured testing of Stanford University's TDL sensor. At the conclusion of R09, the gasification process had operated for over 18,000 total hours with over 2,000 hours in oxygen blown operation.

Figure 49. NCCC Gasification Process.

4.1 Gasification Operation

Gasifier operation was stable during runs R08 and R09, with steady-state carbon conversions comparable to previous test runs, as demonstrated by Table 19. The historical PRB coal carbon conversion represents average values from PRB test runs since the 2006 gasifier modifications were completed.

Table 19. Steady State Carbon Conversions for R08 and R09.

	<i>Maximum</i>	<i>Minimum</i>	<i>Average</i>
Historical PRB Coal Carbon Conversion, %	99.6	95.3	98.4
R08 PRB Coal Carbon Conversion, %	98.9	97.9	98.4
R09 PRB Coal Carbon Conversion, %	98.7	97.8	98.1

Gasifier temperature control enhancements utilizing upper and lower mixing zone air flow adjustments were ongoing during R08 and R09. Beginning in R06, a more aggressive algorithm was created that accounted for sudden increases and decreases in gasifier temperature resulting from non-steady-state operation, such as changing coal feed rate. Using a rate-of-change analysis for gasifier temperature, the controller can scale its response by varying the total air flow rate set point more aggressively. After steady-state operation has been reached again, the slower tuned controllers take control again. Figure 50 illustrates the improvement in gasifier exit temperature control achieved by these efforts. Gasifier temperature variation has been decreased from 5°F achieved during initial control implementation to less than 2°F during R08 and R09.

Figure 50. Gasifier Temperature Control during Non-Steady-State Operation.

During the R08 gasifier start-up, finer sand than that typically used as bed material was employed to assess any improvement the finer material might yield in overall temperature distribution through the gasifier. Initial results showed a decrease in temperature differential, although the data may have been skewed slightly due to the extended heat-up ramp rate required to cure refractory in the newly installed standpipe. The test may be repeated in the future during a more typical gasifier start-up to gain additional insight.

Testing of previous PDAC feeder control logic improvements also continued during R08 and R09. The coal feed rate trim controller successfully maintained a consistent coal feed rate as evidenced by the SWR Engineering flow meter and conveying line differential pressure. This controller was especially important during R08 since the feeder functioned as the sole coal feeder

during the biomass co-feed testing. This run also marked the first time the PDAC feeder had been utilized during oxygen-blown gasifier operation. The gasifier pressure feedback controller installed previously permitted automatic adjustments to feeder pressure and nitrogen flow as gasifier pressure was reduced for oxygen-blown operation. The adjustments made by the controller permitted the pressure differential between the feeder and the gasifier to be maintained at a constant level, helping keep the coal feed rate steady.

The annual stack testing for environmental permit compliance was also completed during R08 operation. The official report confirmed that the facility is well under the permitted limits for all measured species.

4.2 Oxygen-Blown Biomass Co-Feeding

During the final portion of the R08 run, 219 hours of oxygen-blown gasification testing were conducted with biomass co-feed on behalf of CCAT. CCAT received funding through the Department of Defense as part of its initiative to develop alternative liquid fuels for U.S. military applications through the utilization of gasification techniques and sustainable fuel sources such as biomass. Previous gasification testing had been conducted by CCAT at the Energy and Environmental Research Center (EERC) at the University of North Dakota utilizing biomass co-feed with coal in the EERC Transport Gasifier. Testing at the NCCC provided an opportunity to validate data collected from testing at the EERC at a larger scale.

The NCCC test plan included co-feeding of two forms of biomass, raw pellets and torrefied pellets, with PRB sub-bituminous coal during oxygen-blown gasifier operation. This biomass co-feed testing extended the operational experience the NCCC obtained previously during the R03 and R04 gasification runs when raw pellets were co-fed with PRB and lignite coal respectively during air-blown gasifier operation.

4.2.1 Test Objectives and Results

The NCCC test plan included co-feed testing of both raw and torrefied southern pine biomass pellets with PRB sub-bituminous coal at concentrations ranging from 10 to 30 wt% of the total feed to the gasifier. Each biomass co-feed test condition was maintained for approximately 24 hours to allow for all required sampling and analysis to be conducted. The objectives for testing were developed jointly by CCAT and NCCC as follows:

- Collect test results and compare with those obtained from the EERC test to determine if operating at a larger scale results in better conversion, higher efficiency, and a syngas quality more suitable for producing liquid fuels
- Achieve the desired coal-biomass mixtures with separate feeding of coal and biomass
- Demonstrate gasification of the coal–biomass mixtures under the test conditions
- Determine carbon conversion and the amount of carbon in the gasifier solids for each test condition
- Demonstrate successful gasifier circulation without forming deposition or agglomeration

- Determine the extent of tars production with the coal/biomass mixtures in the gasifier
- Evaluate hot gas filtration performance at each test condition
- Monitor gasifier operating parameters including solids circulation rate, syngas recirculation rate, and coal/biomass blend

One of the NCCC mill systems was dedicated during the run to processing biomass. The raw biomass pellets, shown in Figure 51, had been previously used as feedstock during the R03 and R04 runs. This was the first gasification operation with torrifified biomass pellets, which are shown in Figure 52. The torrifified pellets had mill operational characteristics similar to PRB coal due to the breakdown of the wood fiber structure by the torrifification process.

Figure 51. Raw Biomass for R08 Co-Feeding.

Figure 52. Torrifified Biomass for R08 Co-Feeding.

The average particle size distributions for the three feedstocks are shown in Figure 53, with the torrifified biomass more closely following the normal distribution for PRB coal. For the run, a total of 1,600 tons of PRB coal and 41 tons each of torrifified and raw biomass were processed. Table 20 lists the as-received and as-fed properties of the coal and biomass.

Figure 53. Particle Size Distribution Curves for R08 Gasifier Feedstocks.

Table 20. Coal and Biomass Properties.

<i>Property</i>	<i>PRB Coal</i>	<i>Torrified Biomass</i>	<i>Raw Biomass</i>
As-Received Carbon, wt %	52.1	57.5	48.5
As-Received Hydrogen, wt %	3.5	5.3	5.7
As-Received Nitrogen, wt %	0.9	0.3	0.02
As-Received Sulfur, wt %	0.2	0.01	0.06
As-Received Ash, wt %	6.6	1.8	1.2
As-Received Oxygen, wt % (by difference)	12.1	30.9	38.4
As-Received Volatiles, wt %	42.3	65.3	72.2
As-Received Fixed Carbon, wt %	26.4	28.8	20.3
As-Received Heating Value, Btu/lb	8,960	9,670	8,070
As-Received Moisture Concentration, wt%	25	4.2	6.3
As-Fed Moisture Concentration, wt%	18	7.8	8.0
As-Fed Mass Median Diameter, micron	280	536	990
As-Fed Oversize (>1,180 micron) Content, wt%	5	14.9	40.8
As-Fed Fine (<45 micron) Content, wt%	14	7.1	1.0

The increase in moisture concentration of both forms of biomass after milling operations was unexpected. Two potential causes were longer than planned exposure to ambient moisture before material processing began and lower mill system exhaust gas flow (i.e. higher recycle gas flow) leading to higher relative moisture levels inside the mill system.

After establishing steady gasification operation with PRB feed utilizing the PDAC feeder, torrified biomass was fed followed by the raw biomass. The actual co-feed percentages for the torrified biomass were 17, 20, and 29 wt%. Due to the turndown limits of the rotary feeder and

the bulk density of the torrified material, the lowest percentage co-feed was higher than the planned 10 wt%. The actual co-feed percentages for the raw biomass were 12, 20, and 28 wt%. The lower bulk density (larger volume) of the raw biomass allowed for a closer approach to the planned lower co-feed test condition. Biomass feed rate as a function of feeder speed is given in Figure 54. Feeder performance was stable during testing.

Figure 54. Biomass Feed Rate as a Function of Feeder Speed of Original Rotary Coal Feeder.

Gasifier operating conditions remained stable during all tests and yielded high carbon conversions during both coal-only and biomass co-feed operation as shown in Table 21. Syngas lower heating values (LHVs), also given in Table 21, remained stable during the biomass co-feed periods, and there was no appreciable tar generation during the testing.

Table 21. Coal and Biomass Co-Feed Operating Parameters.

	<i>PRB Coal Only</i>	<i>Torrified Biomass Co-Feed</i>			<i>Raw Biomass Co-Feed</i>		
		<i>17 wt%</i>	<i>20 wt%</i>	<i>29 wt%</i>	<i>12 wt%</i>	<i>20 wt%</i>	<i>28 wt%</i>
Gasifier Exit Temp., °F	1,707	1,699	1,698	1,699	1,701	1,708	1,692
Coal Feed Rate, lb/hr	3,607	3,302	3,259	3,201	3,552	3,386	2,784
Biomass Feed Rate, lb/hr	0	652	795	1,288	472	835	1,100
Total Feed Rate, lb/hr	3,607	3,954	4,054	4,489	4,024	4,221	3,884
Oxygen/Fuel Ratio, lb/lb	0.80	0.78	0.76	0.72	0.75	0.71	0.74
Steam/Fuel Ratio, lb/lb	1.20	1.15	1.11	1.02	1.12	1.06	1.18
Carbon Conversion	98.3	98.2	98.4	98.2	98.5	98.0	98.2
Syngas LHV, Btu/scf	97.7	86.7	97.6	110.8	96.7	98.0	95.2

The carbon conversions achieved during co-feed operation also compared well with previous biomass co-feed operation with PRB coal as shown in Figure 55.

Figure 55. Carbon Conversion during PRB Coal and Biomass Co-Feed Operation.

Comprehensive mass and energy balances were conducted for each test condition with acceptable closures achieved in both cases, as illustrated in Figure 56.

Figure 56. Mass and Energy Balances for R08 Biomass Co-Feed Operation.

No evidence of agglomeration was observed in the circulating solids, and the continuous coarse ash discharge system functioned well during all test conditions. PCD performance remained stable with a consistent pressure drop and low particulate loading in the outlet gas (less than 0.1 ppmw). The continuous fine ash discharge system also performed well during all test conditions.

The observed range of ash particle size distributions for both ash discharge systems during testing is shown in Figure 57.

Figure 57. Fine and Coarse Ash Particle Size Distribution Curves for R08 Operation.

In summary, performance of the gasification system during the oxygen-blown biomass co-feed testing was stable with no operational problems. All data analysis, system operating parameters, and sample data has been shared with the CCAT team. Collaboration with CCAT personnel will continue to generate a final test report during 2013.

4.2.2 Oxygen Supply System

In support of biomass co-feed with oxygen feed for CCAT in R08, significant design effort was spent on the re-commissioning and modification of the oxygen supply system. The work included installation of a new oxygen flow meter. Cleanliness, system operating pressure, and materials of construction are all directly related to the characteristic elements that are managed to minimize ignition risks in an oxygen line. Challenges associated with the design included:

- To accelerate the schedule, the need to use a higher velocity flow meter made from stainless steel instead of a more burn resistant material like Hastelloy or Monel
- The need to minimize high velocity start-up transients identified in the design hazard review
- The need to identify an operating pressure that was high enough to satisfy process needs and low enough to minimize ignition mechanism risks
- Cleaning of the existing oxygen header required to remove particle contamination in the oxygen supply piping

An oxygen design engineer was engaged to assist the NCCC design group. The consultant evaluated the probability and potential consequence of ignition, assisted with inspection of the oxygen system, and made recommendations on cleaning of the system. After the final report from the consultant was received, the new flow meter design was validated, and the equipment was installed. A scope was developed for cleaning the oxygen header, a contractor selected to perform the work, and the oxygen header was cleaned prior to R08. Design work was also completed to incorporate interlocks to address the high velocity start-up transients that had been identified as a risk factor.

Some additional design and field work continued during R08 to address start-up transients upon introduction of oxygen, primarily implementation of a method to pre-pressurize the oxygen line to reduce start-up velocity.

4.3 Hot Gas Filtration

PCD research efforts continued during the year focusing on the long-term evaluation of material performance of several types of filter elements and failsafe devices. The failsafes installed include Pall Dynalloy devices constructed of forward (supporting screen on the inner surface of the failsafe) and reverse structures (supporting screen on the outer surface), and PSDF-designed devices constructed of HR-160 material. The filter elements installed consist of sintered fiber elements—some elements manufactured by Porvair and HR-160 elements from Pall—and sintered powder filter elements—iron aluminide elements from Pall and elements with a high-alloy material from Mott.

The PCD operated with a high collection efficiency and stable pressure drop during R08 and R09 with particulate outlet loading typically less than 0.1 ppmw. However, operations were interrupted during the R08 run due a weld failure in the PCD tubesheet discussed in Section 4.5.2. Due to the compressed timeframe of the required repair, the PCD plenums were fitted using spare filter elements from the on-site inventory. There was insufficient time available to clean off the filter cake and inspect the elements to ensure that they did not contain a leak source. The spare filter elements consisted of both new and used iron aluminide and HR160 elements from Pall and used sintered-fiber elements with an inert coating from Porvair.

After completion of the R09 test, the filter elements installed in the PCD prior to the tubesheet failure, which have the most hours of run time, were re-installed to continue long-term material evaluation. The elements with the greatest exposure time, which are iron aluminide elements, had accumulated over 16,200 hours of syngas and fine ash particulate exposure prior to the tubesheet failure during R08. Most of the failsafes were cleaned and re-installed during the repair including both Pall Dynalloy devices and PSDF-designed devices. A new set of failsafes will be installed following the planned repair and/or replacement of the PCD tubesheet and plenum components.

4.4 Sensor Development

The in-house development of advanced sensors continued with a sapphire thermowell for gasifier service, a coal flow measurement device, and coal feeder level probes.

4.4.1 Sapphire Thermowell

An agreement was reached with Emerson to continue testing of the Rosemount thermocouple technology employing a sapphire thermowell in the riser section of the Transport Gasifier. Previous testing of this technology conducted during R04 through R06 showed good responsiveness to gasifier temperature changes, but the temperature indication continued to drift relative to the reference thermocouple, housed in a HR-160 thermowell, as shown in Figure 58. The sapphire thermowell and assembly was in service for over 2,700 hours.

Figure 58. Temperature Readings for Sapphire and HR-160 Thermowells.

Inspection of the thermocouple following the R06 run showed corrosive attack and micro-cracking of the thermocouple, indicating that the thermocouple had been exposed to syngas. The thermowell likely had a crack or weak point prior to the beginning of gasifier operation, which led to the syngas exposure and slow decay in thermocouple reading.

As a result of these findings, Emerson personnel fabricated a new thermowell assembly to re-install in the same location prior to run R08 and were on-site to assist during the initial inspection and installation of the assembly. The thermowell assembly was identical the assembly tested previously with the exception that a new smart Hart transmitter was added to provide early detection of a sensor failure. Unfortunately, the transmitter/thermocouple failed shortly after R08 began, and a post-run inspection showed that the assembly had broken.

Testing of the sapphire thermowell technology was suspended following the second assembly failure at the beginning of R08. NCCC staff has been collaborating with Rosemount to understand better the mode of the two failures and reach a decision regarding future testing. One potential path forward may include testing different sapphire thermowell assembly designs in other gasifier locations. More detailed test plans will be developed after technology collaboration agreements are finalized.

4.4.2 Densflow Coal Flow Meter

Testing of the DensFlow coal flow meter from SWR Engineering continued during R08 and R09. The device is a non-intrusive technique of measuring solids flow using a patented alternating electromagnetic field. The solids flowing through the device absorb this field energy, and a measurement of density of the material is inferred. Conveying velocity is simultaneously calculated by the same sensors. The combination of the two measurements with the cross sectional area of the device yields a mass flow rate of material through the feeder discharge line.

While the measurement provided by the meter has shown good response to instantaneous changes in coal feed rate when compared to existing conveying line differential pressure readings, the absolute reading has not matched up well with the loss in weight calculation provided by the PDAC feeder surge bin weigh cell device. Although the original design intent was to measure dense flow solid streams at pressure, SWR Engineering has maintained that the device is capable of measuring the more dilute phase flow regime of the PDAC feeder discharge to the gasifier.

Following operation during R07, the decision was made to recalibrate the instrument following the manufacturer's guidelines and to perform off-line feeder testing at higher coal feed rates than had previously been achieved during on-line operation prior to R08. The rationale for the off-line testing was that at higher coal feed rates, the solids flow in the feeder discharge line should be less dilute and more closely approach dense-phase flow conditions. However, the data collected during the off-line test period revealed that the discrepancy in coal feed rates between the weigh cell calculation and flow meter still existed at the higher rates. This result was further substantiated with flow rate data collected during R08 and R09 as illustrated in Figure 59.

Figure 59. Comparison of Coal Feed Rates Indicated by Weigh Cells and Densflow Meter.

Collaboration with SWR Engineering personnel regarding the outcome of the data generated will be needed to determine what changes are necessary to address the difference for future testing.

4.4.3 Coal Feeder Level Probes

Long-term evaluation of two coal feeder solids level probes continued during both R08 and R09. The Dynatrol vibration level probes installed in the PCAD feeder dispense vessel and lock vessel prior to the R02 run have continued to provide very reliable indication of solids level in both vessels for lignite and sub-bituminous coals. Further optimization of the lock vessel fill cycle has been made possible by the performance of these devices. The level probes have operated for almost 6,000 hours.

Evaluation of the Drexelbrook point sensitive level probe also continued during both test runs. The probe was vertically installed in the top of the PDAC feeder dispense vessel prior to the R04 test run to permit higher level control of the coal inventory in the vessel. Since installation, the probe has continually provided steady solids level control, mitigating the impact of solids level variation on coal feed rate. Over 4,700 hours of operation have been achieved to date.

4.5 Gasification Process Modifications

Several modifications were made to the gasification process during the year to address equipment related issues. These changes included replacement of the gasifier standpipe and repairs to the PCD tubesheet and primary gas cooler. Additionally, work began on design of a new pressure letdown device for the Continuous Fine Ash Depressurization (CFAD) system to decrease construction costs of the system.

4.5.1 Gasifier Standpipe Replacement

A 2012 project deliverable for DOE was the replacement of the gasifier standpipe. During routine inspections of the gasifier in 2009, refractory damage was identified in the standpipe arising from the loss of hot-face refractory. Two places of concern were the intersection of the solids separation unit and standpipe, and the intersection of the J-leg and standpipe. The refractory in the standpipe and J-leg was the refractory originally installed in the gasifier, and had been in service for 15 years and almost 22,000 hours of operation, experiencing more thermal cycles than would a commercial unit. Figure 60 shows boroscope inspection photographs of the standpipe refractory. As seen in the figure, the refractory was in excellent condition following initial operation in runs R08 and R09.

Figure 60. Gasifier Standpipe Refractory before and after Standpipe Replacement.

The work scope of the project included the following items in addition to the physical replacement of the standpipe itself:

- Removal and re-installation of 10 tons of structural steel and grating, 50 small bore piping runs, and nearly 100 tubing runs
- Disconnection and re-termination of over 190 instrumentation loops and 170 power-related loops
- Installation of 49 new area gas detectors (to upgrade to current models supported by the supplier which is necessary to maintain the emergency response infrastructure) and checkout of over 140 associated instrumentation loops
- Separation and re-surfacing of the riser/mixing zone body flange to address a leak found during R07

Demolition of small bore piping and dismantling of related instrumentation and the original standpipe was completed during the first quarter of 2012 (see Figure 61). Installation of the first two of the four new standpipe sections was also completed in the first quarter. However, a fit-up problem was identified with the first piece of refractory-lined pipe. NCCC design and construction groups, KBR engineering, and a contracted laser alignment company developed an appropriate field modification, but the installation of the first standpipe piece took longer than initially projected.

Figure 61. Standpipe Demolition in Progress.

The standpipe replacement was completed in May with installation of the remaining two sections of the new standpipe and small-bore piping, instrumentation, and tubing. Checkout and calibration of all instrumentation and wiring started in May and was completed in early June. Functional testing of all associated system control logic was completed prior to R08 start-up.

4.5.2 PCD Tubesheet Repair

Inspections of the PCD tubesheet were performed in August during the second R08 outage following the detection of high solids loading in the outlet syngas, and a significant crack was found in the tubesheet outer-ring to outer-cone weld, as shown in Figure 62. This is a structural weld that supports the weight of the tubesheet and plenum assemblies. Working with the original designer (Siemens Westinghouse), it was determined that the weld could be repaired. NCCC construction and maintenance personnel made the repairs and reinstalled the PCD tubesheet at the end of August.

Figure 62. PCD Tubesheet Fracture and Repair.

Options are being considered for major repairs and/or replacements of the PCD tubesheet and plenum components due to the tubesheet outer-ring to outer-cone weld damage that was identified and repaired during R08. NCCC engineers are evaluating options and will submit proposals to management for review in early 2013.

4.5.3 Primary Gas Cooler

During the R09 start-up, a leak was identified in the primary gas cooler, which is located between the gasifier and the PCD. Hydrostatic pressure testing identified one leaking tube, the ends of which were plugged to prevent further leaking. While the primary gas cooler operated satisfactorily during R09, it will be replaced due to the likelihood of future tube leaks. Plans call for the replacement cooler to be delivered and installed in 2013.

4.5.4 Pressure Letdown Device Design Modifications

The current CFAD system pressure letdown device (PLD) design has been utilized at NCCC for a number of years. A project was initiated to investigate and test proposed modifications to the PLD, which should significantly decrease fabrication cost and time without affecting performance. Mechanical design drawings were completed in December. Fabrication and installation will commence in early 2013 with plans to test the new concept in R10. Following the R10 run, the same proposed PLD design will be installed on the PDAC feeder and tested offline prior to R11.

4.6 Stanford University Tunable Diode Laser

During R09, Stanford University's Hanson research group tested tunable diode laser (TDL) sensor technology in the syngas downstream of the PCD. Preliminary findings validated the TDL technology's ability for real-time in-situ monitoring of H₂O, CO₂, and gas temperature in a gasification process.

Prior to the campaign, Stanford collaborated with NCCC to design an apparatus capable of supporting the measurement device on the particulate free syngas stream exiting the PCD. In conjunction, both teams developed a robust plan to assess the durability and accuracy of the sensor across a wide range of operating conditions. Throughout the testing, readings from the unit were consistent, with no significant measurement drift observed.

In addition to the validation of the sensor's measurement methodologies, a technical assessment was performed by NCCC to ascertain the performance of the sapphire window assemblies employed to provide a pressure boundary between the process gas and the laser emitter/receiver. During the two-month campaign, a number of events occurred which required the use of the safety systems designed to respond to gasifier upsets. In each case, the system responded as expected, allowing rapid return to normal and safe operation with no observed window fouling or laser path obstruction.

4.6.1 Stanford's Development Work

Sensor History

The Hanson research group at Stanford University has a long and successful history of research to develop laser absorption sensors for combustion and propulsion applications. Recently, one of the goals of this research has been to demonstrate the applicability of these measurement techniques for coal gasification systems. Laser absorption sensors have good potential to provide in-situ monitoring of syngas from coal gasification, providing control signals for the gasification process as well as real-time monitors for the energy content and composition of the product syngas.

There are three important challenges to the development of laser absorption sensors for gasifier applications:

- Modern gasification processes utilize high pressures, and absorption sensing at such conditions is complicated by collisional broadening and the resulting blending of absorption transitions.
- Absorption measurements rely on the transmission of a laser beam, and gasifier product streams can be heavily laden with particulate, which can scatter light and strongly attenuate the transmitted laser intensity.
- Optical absorption sensing requires optical access for line-of-sight laser transmission measurements in the explosive and toxic syngas; thus, the optical access must provide security for safe operation if a window fails or if the sensor requires maintenance during the long operation cycle of a commercial gasification plant.

Stanford's vision for laser-sensor control IGCC utilization of clean coal is illustrated in Figure 63. Here gas temperature is monitored in the gasifier (location 1 in the figure), the syngas concentration marker (e.g., CO or H₂O) is tracked at the gasifier exit (location 2), and syngas quality (e.g., Wobbe index) is monitored before (location 3) and after (location 4) the particulate cleanup of the syngas.

Figure 63. Conceptual Use of TDL Sensor for Control of an IGCC Plant.

Sensor 1 provides a control signal to optimize the gasifier (e.g., temperature), sensor 2 monitors exit syngas for gasifier control (e.g., the fuel/oxidizer), sensors 3 and 4 monitor syngas quality (e.g., energy content) to control the gas turbine fuel/air ratio. The use of optical fibers enables simultaneous measurements at multiple locations and remote installation of the lasers, detectors, and control electronics.

Stanford's research to develop TDL absorption sensors for gasifier applications for temperature and H₂O content has been sponsored by EPRI. Related research to extend these sensors to syngas composition measurements of CO, CO₂, CH₄, and NH₃ has been sponsored by NETL. This research has included optimization of sensor design for gasifier conditions, laboratory validation of sensor performance analyzing synthetic syngas, and field measurements in two pilot-scale facilities at the Institute for Clean and Secure Energy at the University of Utah. In 2009, the first proof-of-concept TDL absorption measurements were performed in syngas flows above the fluidized bed of a pilot-scale black-liquor gasifier, and time-resolved temperature was measured successfully even with significant (10^4) attenuation of the transmitted laser beam by particulate scattering. Between 2010 and 2012, the sensor was extended to monitor four species (H₂O, CO₂, CO, and CH₄) and temperature in a pilot-scale, down-fired, oxygen-blown coal gasifier. The results showed that in-situ TDL measurements provided real-time monitoring of wet syngas without the time delays of wall-imbedded thermocouples and GC measurements of sampled and dried syngas.

Basis of Operation

Although the Stanford TDL sensor was applied successfully in university research gasifiers, all previous tests were limited to relatively short run times (<12 hours), and the sensors could be adjusted by operators during the run. Testing at NCCC offered the first opportunity for measurements in an engineering-scale system, with the safety and access limitations expected for industrial-scale gasifiers over a duration of several weeks. The demonstration of the Stanford TDL sensor at the NCCC during the R09 test run focused on five areas:

- Design, fabrication, and operation of the TDL sensor while meeting the requirements for safe operation on the syngas process piping
- Evaluating in-situ syngas TDL measurements with only remote access
- Correlation of in-situ syngas TDL measurements with NCCC diagnostic equipment
- Comparison of increased time resolution against current sampling-based GC and H₂O measurements
- Reliability of the optical windows to provide safe, stable, long-term operation

The results, summarized here and presented in more detail below, from the TDL sensor during the R09 test campaign were positive for all of these areas of focus. With significant assistance from NCCC staff, optical access was engineered, constructed, and installed in the syngas product line 99 feet downstream of the PCD. A Stanford sensor for H₂O and gas temperature was designed for optimal performance at the conditions expected for the measurement location (620 to 800°F, 220 to 290 psig, 6 to 10 vol% H₂O, 8-inch path length). A prototype device was constructed and tested at Stanford and shipped to NCCC.

Measurements were conducted during R09 from the beginning (hour 0) until end (hour 630) of the campaign. During the entire test period, the laser transmission was stable and the window performance and optical alignment did not degrade with time or ambient temperature or during gasifier warm-up. There were no leaks or failures in the TDL sensor package. Measurements of H₂O and temperature were made with a time resolution of a few seconds. Sensor performance was evaluated with wide variety of laser scan and modulation parameters. From hours 62 through 97, temperature measurements were suspended and bonus proof-of-concept measurements of CO₂ were conducted. Raw sensor data from the entire campaign was recorded for subsequent optimization of the data analysis procedures. Measurements of moisture content were in good agreement with sampling data although with significantly faster time resolution; temperature measurements also agreed with thermocouple data. Even though successful measurements of moisture and temperature were acquired over the entire campaign (no temperature readings for hours 62 through 97), lessons were learned about optical alignment, optical engineering, and optical transmission that suggest improvements for further refinement of sensor performance.

4.6.2 Test Objectives and Sensor Installation

Laser absorption is a line-of-sight measurement and requires optical access across the measurement volume. This was a challenge at NCCC where engineering design of optical access in the syngas process piping had not been previously performed. The experience and expertise of the NCCC team was crucial in selecting a measurement location and guiding the engineering and construction of safe installation of optical access for the TDL sensor. A location was selected 99 feet downstream from the exit of the PCD, with the sensor lasers and electronics remotely located in an existing instrumentation shelter, as illustrated in Figure 64.

Figure 64. Location of TDL Sensor in NCCC Transport Gasification Process.

To enable safe maintenance of the TDL sensor, if needed during the gasifier run, shut-off valves were installed on either side of the process pipe as depicted in Figure 65. These redundant valves would allow the transmitter or receiver enclosures to be opened to examine the windows

providing optical access. A pair of flange-mounted sapphire windows was installed on either side of the rig, and measurement of temperature and pressure between the windows provided a safety alarm to signal valve closure in the event of window failure.

Figure 65. TDL Sensor Assembly Installed in Gasification Process.

The transmitter and receiver packages for the TDL lasers were enclosed in purged metal enclosures, and the optics were remotely adjusted to optimize sensor alignment using low-voltage direct current (DC) motors. Laser light was produced in the instrumentation shelter and coupled to the transmitter via optical fiber, and the transmitted light was collected and delivered via optical fiber to a detector located nearby (about 6 feet away) in a purged enclosure. The light was detected on a low-voltage DC detector and the DC signal returned to the instrument shelter for processing. The entire sensor flange stack from transmitter to receiver was mounted on a rail suspended from the syngas process pipe to maintain clear line-of-sight for the laser sensor and to minimize deviations from temperature variations.

4.6.3 TDL Sensor Design for H₂O and Temperature Measurements

A modulation strategy, wavelength-modulation spectroscopy (WMS), developed at Stanford for measurements of gas temperature and concentration in harsh environments was selected for the TDL sensor to provide sensitive and accurate detection of absorption over a wide dynamic range of optical transmission. The degree of non-absorption losses from phenomena such as beam steering were unknown for this application, and the installation of the optical access produced a long (15 feet) line-of-sight sensor path, producing a long moment arm for angular beam misalignment from transmitter/detector vibration or beam steering in the syngas. Stanford's WMS strategy has proven to be highly robust to such effects.

4.6.4 TDL Sensor Testing and Results

Testing During Start-up

The TDL-measured moisture level in the syngas, with a 2-second time resolution as shown in Figure 66 from hour 0 to hour 50. During the first few hours, the sensor successfully tracked ignition of the propane burner used for initial warm-up of the gasifier by the appearance of water vapor combustion product. The stability of the H₂O signal during this period mirrored the stability of the propane burner. Hence, the TDL signal has good potential for rapid feedback to the operator on the stability of the heater. During hour 7, the warm-up period of the gasifier began with a stable propane flame. The moisture content of the syngas steadily increased at the

sampling location downstream of the PCD during warm-up; this variation was expected as the fuel/air ratio of the propane burner was being increased as seen in Figure 66.

Figure 66. In-Situ Measurements of Flue Gas Moisture during Gasifier Start-Up.

The fuel was transitioned to coal (in combustion mode) at approximately hour 40, and the coal feed rate was pulsed to control the warm-up rate of the gasifier. This transient cycling of the coal fuel is captured in the right panel by the H_2O content variation (with 2-second time resolution) in the flue gases (note that this is not yet syngas as the gasifier is in combustion mode). During this period, propane was terminated at hour 44, and the coal feeding transitioned into gasification mode. This process continued to hour 52 when coal feeding was terminated. This shutdown is also reflected in the TDL measurement of water vapor.

Capturing Transients in Operation

Figure 67 presents the syngas moisture level and temperature measurements from the TDL sensor from hours 105.5 to 112; these data are compared to thermocouple data at the PCD outlet and at a location 24 feet downstream of the PCD outlet. The differences between these readings are consistent with the temperature gradient with distance. All three temperatures were stable as a function of time. However, the TDL-measured H_2O content fluctuated with an approximately 10 minute cycle, which correlated with the gasifier temperature also shown in Figure 67. The transients captured in the gasifier temperature were also reflected in the syngas moisture content. Two conclusions drawn from these observations are:

- The syngas H_2O level indicates the transient behavior in the gasifier, demonstrating the feasibility of a gasifier control sensor for the located downstream of the PCD.
- The stable syngas temperature measured by the TDL sensor reflects the large thermal mass of the gasifier and all its piping between gasifier and TDL sensor locations; however, the moisture level measurement is unaffected by this thermal mass, and the high velocity of the syngas flow avoids diffusive mixing.

Figure 67. Thermocouple Measurements Compared with TDL Temperature and Syngas H₂O Measurements

Continuous Monitoring

The TDL sensor collected continuous records of H₂O from hour 140 until hour 575, except for three short periods when the sensor valves were closed as a precaution when gasifier upsets occurred. During the entire period, transmission of the TDL sensor was stable, the windows did not exhibit any indications of fouling, and there were no noticeable effects of variations in temperature. Figure 68 plots the syngas H₂O measurements from the sensor and from condensate samples. These two H₂O measurements methods have similar mean values over the 435-hour record with larger variations in the condensate sampling.

Figure 68. Continuous TDL H₂O Measurements Compared with H₂O Sampling Data.

The H₂O mole fraction data of Figure 68 varies with time by approximately ± 0.002 , which might suggest that the TDL sensor has a ± 3 percent statistical uncertainty. However, when the H₂O data are examined on a more expanded time scale, the measured H₂O content has a distinct

oscillation suggesting that the sensor is capturing a real variation of H_2O mole fraction. These oscillations in H_2O are strongly correlated with the gasifier temperature, as shown in Figure 69. (Note that the gasifier temperature fluctuations are less than 0.5 percent of the gasifier temperature.) NCCC engineers were able to correlate the variations in the H_2O mole fraction with other data sets: PDAC feeder dispense vessel and discharge line pressure, and PCD back-pulse nitrogen receiver tank pressure. These correlations led NCCC staff to infer that the fluctuations in syngas moisture resulted from variations in coal feed rate.

Figure 69. Fluctuations in TDL H_2O Measurements and Gasifier Thermocouple Measurements.

Figure 70 demonstrates the nearly perfect correlation of the TDL-measured H_2O mole fraction with the PDAC dispense vessel pressure. As this pressure increases, so does the coal feed rate assuming constant gasifier pressure.

Figure 70. Fluctuations in TDL H_2O Measurements and PDAC Feeder Pressure.

Changes in the TDL-measured H_2O mole fraction mirrored changes in the GC measured CO_2 , and an example is given in Figure 71 for an event that occurred at approximately hour 420. Note the changes in CO_2 are mirrored in the changes in syngas H_2O . However, the improved time resolution of the TDL sensor provides H_2O mole fraction that captures the variation in the gasifier conditions, and the TDL sensor data is approximately 30 minutes ahead of the GC, illustrating the long time delays from gas sampling, drying, and GC measurement time.

Figure 71. TDL H_2O Measurement and GC CO_2 Measurements during Upset Condition.

4.6.5 Summary and Conclusions

The first optical access in the NCCC fluidized-bed Transport Gasifier was designed, installed downstream of the PCD, and used for measurement in campaign R09 in November and December 2012. The optical system was stable over the entire campaign, with no obvious window fouling or loss of alignment due to gasifier or ambient temperature. This optical system was used for monitoring both water vapor content and temperature, the latter based on the ratio of absorption by two water vapor transitions.

One of the water vapor absorption transitions provided temperature-insensitive monitoring of water vapor mole fraction. The H_2O mole fraction was recorded continuously from hour 0 to hour 630, with unattended operation from hour 140 to hour 575. The water mole fraction measurements were in good agreement with liquid water sampling data collected by NCCC. The precision of the H_2O mole fraction measurements appeared to be on the order of one part in a thousand. Variations measured by the TDL sensor in the H_2O mole fraction of the product syngas were on the order of ± 2 parts in 80, correlating well with temperature fluctuations in the gasifier of ± 2 K and with pressure variations in the coal feed system.

There were numerous lessons learned. For example, the fraction of transmitted light was less than expected, suggesting that improvements to the optical collection to suppress beam steering could improve sensor performance. Successful unattended operation of the TDL sensor suggests the utility of improving the sensor software for remote (e.g., internet) access to the sensor to assess sensor health and optical alignment. Stanford's first use of remote adjustment of optical alignment was successful, suggesting that remote alignment and sensor operation could be quite

feasible for very long-term measurement campaign operation. Stanford's calibration-free, WMS strategy ensured accurate interpretation of absorption signals even at low light transmission (<0.01 percent). This strategy also suppressed signal variation with changes in the optical transmission. The addition of automatic gain control in the signal processing has the potential for operation over even larger dynamic ranges. The rapid (seconds) time-resolution of the TDL sensor allowed it to capture changes in the syngas composition that were not evident in the GC monitor. The TDL sensor also responded to gasifier changes nearly 30 minutes before the GC instrument. The rapid time-resolution suggests that the TDL sensor has promise as a control sensor for the gasifier, even when the TDL sensor is located downstream of the PCD.

In addition to improving sensor performance with changes in the optical collection and software for long-term remote operations, extension of the sensor to add new species such as CO, CO₂, and CH₄ could significantly extend the utility of laser-absorption sensing for this industry. The success of this TDL sensor campaign at the NCCC shows that laser absorption sensing is not only possible in engineering-scale gasifiers, but could be an important new diagnostic tool with the potential for new control strategies in future gasifier utilization and development.

4.7 Engineering Studies

Two draft NETL reports on air-blown Transport Gasification systems were reviewed, and comments and questions were sent to NETL. As a benchmark, the capital costs of an NETL oxygen-blown case were also compared with the published costs for the Duke Edwardsport IGCC plant. Feedback was provided to NETL on the relative accuracy of the estimates.

5.0 CONCLUSIONS AND LESSONS LEARNED

5.1 Pre-Combustion

SCU Upgrades

Major upgrades to the SCU were incorporated to meet the expected requirements for future testing. A new control room and MCC building were installed. A new 1,000 lb/hr syngas cleaning system was installed and operated successfully for the first time during R09.

Water-Gas Shift Catalyst

A catalyst vendor has tested a WGS catalyst during the last three gasification runs, performing parametric tests and long-term evaluation. Test results showed that for one pass of syngas, over 80 percent CO conversion was achieved with a steam-to-CO ratio of 2. For the intrinsic steam-to-CO ratio of around 0.9, CO conversion was almost 70 percent.

WPI Hydrogen Membranes

WPI continued to optimize the composition of its palladium-based membranes and demonstrated production of 99.9 percent pure hydrogen. WPI continues to investigate the cause of hydrogen flux decrease seen from test results, which appears to be related to carbon deposition on the membrane surface.

MTR CO₂ and Hydrogen Membranes

MTR successfully demonstrated a 10:1 scale-up of its CO₂ membrane with a 500 lb/hr integrated system featuring membrane, compressor, and refrigeration skids. The system operated as designed, and produced liquid CO₂ with up to 92 percent purity. The initial testing showed the need for several modifications related to membrane design, CO₂ liquid level control, and PLC logic. These modifications will be incorporated prior to further operation.

MTR also continued testing of its 50 lb/hr CO₂ membrane in two configurations—as a single membrane module and with two modules connected in series. R09 testing demonstrated CO₂ enrichment from about 15 vol% in the feed to 50 vol% in the permeate stream. The hydrogen membrane stamp cell enriched the hydrogen from a feed concentration of 14 vol% to nearly 80 vol% in the permeate in R09. Both CO₂ and hydrogen membranes performed stably during the operation, achieving separation performances equal to or slightly above what had been demonstrated previously.

MPT Hydrogen Membrane

Since recently scaling up its CMS membrane to a full-scale 86-tube bundle, MPT successfully incorporated a baffle design into its system to improve gas distribution through the bundle and increase hydrogen separation. The baffle design was developed in the MPT lab and further tested in off-line operation at the NCCC. Test results verified the efficacy of the baffle and demonstrated stable operation with hydrogen production of about 95 percent purity.

Eltron Hydrogen Membrane

The first testing of Eltron's hydrogen transport membrane at the NCCC was achieved on an expedited schedule. The membrane demonstrated stable hydrogen flux and produced 99.87 percent pure hydrogen.

Membrane Material Coupon Testing

To evaluate their corrosion resistance, NETL has provided 25 sample coupons of selected hydrogen membrane materials (primarily palladium-based) to be installed in the head (dust-free side) of the hot gas filter. At this location, the syngas typically contains about 250 ppmv H₂S at around 750°F. The NCCC results demonstrate that the palladium alloys with B2 crystalline structure tend to be more corrosion resistant than the alloys with face-centered cubic crystalline structures. Using coal-derived syngas provides a wider range of contaminants that the materials must prove resistant to, and so is extremely important in guiding future hydrogen separation membrane alloy development.

University of Alabama CO₂ Solvent

UA's alkyimidazole solvent was tested in the SCU stirred batch reactor during R09 using bottled gases and syngas. Results indicated that the solvent performed as expected in regard to the solvent's capacity for CO₂ and was within the range of solvents previously tested at the NCCC. Testing also showed that absorption of H₂S was essentially complete within an hour of operation.

Flash regeneration released all of the CO₂ from the sample but was not effective at removing H₂S from the solvent (restoring less than 10 percent of the original capacity). Flash regeneration followed by thermally soaking the solvent at 212°F while purging with nitrogen did not appear to restore any additional H₂S capacity. This behavior seems to indicate that it acts as a physical solvent for CO₂ but has some chemical solvent properties with H₂S. This interaction will be studied more closely in future testing.

Ohio State University Syngas Chemical Looping

In this project, a 250 kW pilot scale SCL plant will be constructed adjacent to the NCCC gasification structure and will utilize up to 900 lb/hr of syngas. In 2012, demolition of unused equipment was completed to make room for the SCL unit. NCCC supported the OSU team by participating in an initial design hazard review and assisting with developmental engineering work. NCCC developed conceptual designs for connecting the SCL system to the Transport Gasifier process and balance of plant equipment. OSU and NCCC cooperatively developed plans for construction and operation of the system. Construction for the project is scheduled to begin in April 2013 with initial start-up planned for late 2013 and testing planned into the spring of 2014.

5.2 Post-Combustion

PC4 Upgrades

To meet the requirements of future testing at the PC4, work was in progress to increase the capacity of the flue gas supply, PSTU pre-scrubber SO₂ removal, process cooling water, and

electrical infrastructure. The NCCC purchased and began installation of the SSTU for increased flexibility in solvent testing.

MEA Baseline Test Campaign

A 400-hour MEA Baseline Test Campaign was conducted as a follow-up to the 1,140-hour campaign conducted in 2011. The 2012 campaign was performed to further investigate solvent carryover, degradation products, and metal concentrations in the solvent.

Evaluation of solvent carryover indicated that the carryover increased with SO₃ level, decreased with increasing solvent temperature, with the upper absorber bed inactive, and with wash water MEA content. Almost all the MEA carryover from the capture plant occurred downstream of the wash tower. NCCC staff is currently working to incorporate a design by Sulzer to reduce carryover.

Regarding degradation products, the test campaign showed that over 97 percent of the ammonia emitted from the process is carried over from the wash tower. As ammonia is a degradation by-product, it is likely that the other degradation products are also promoted by oxidation. The majority of the formaldehyde and acetaldehyde is carried over from the regenerator. Only two nitrosamines were detected: nitrosodimethylamine, which was below 1 ppb, and nitrosodiethanolamine, at about 1 ppb. Neither compound was detected in the liquid samples. Based on sampling using an impinger with acid, passing the CO₂-depleted stream through an acid-wash stage would not be effective in removing degradation products. Adding an oxidation inhibitor will reduce solvent degradation and so lower ammonia release. Activated carbon filters are in place to remove degradation products, and their efficacy will be assessed in subsequent runs.

Solvent analysis showed that chromium was measured at 45,090 ppbw, well in excess of the 5,000 ppbw RCRA limit. The majority of the chromium originates from corrosion of the 316L stainless steel vessel material. The chromium would be significantly reduced by fabricating the plant from carbon steel, which is standard industrial practice. Selenium was measured at 1,950 ppbw, almost twice the 1,000 ppbw limit. The selenium originates mainly from the flue gas. The other RCRA metals present above the lower detection limits are arsenic (219 ppbw) and barium (265 ppbw), both originating mainly from the flue gas.

Methods investigated for metals removal from the solvent included waste water chemical treatment procedures, silica sorbents, and a ZVI method at Texas A&M University. Of these, the ZVI method at Texas A&M was the most effective. Other means of solvent removal being investigated include ion exchange and electrodialysis. In addition, the SSTU will be utilized to screen proposed measures to reduce solvent carryover and to maintain solvent metals content at low levels before confirming their long-term effectiveness in the PSTU.

Measurements from the PSTU outlet CO₂-rich stream showed that the oxygen content of the stream is comfortably below the 100 ppmv limit required for pipeline transport.

Hitachi Solvent

Testing of Hitachi's H3-1 solvent in the PSTU comprised over 1,300 hours. On average, CO₂ capture efficiency of over 90 percent was achieved over the test period.

The variation of CO₂ capture efficiency with solvent flow rate for a constant reboiler steam flow showed that capture efficiency reached a maximum at a particular solvent flow rate. Likewise, the variation of regeneration energy with solvent flow rate for a constant reboiler steam flow showed that regeneration energy reached a minimum at the same solvent flow rate producing the maximum CO₂ capture.

The variation of CO₂ capture efficiency with reboiler steam flow and flue gas CO₂ content indicated that efficiency fell for steam flow rates below the optimum value. At the lower steam flows, the lean solvent returning to the absorber is richer in CO₂, and this limits the amount of CO₂ that can be captured. This testing also demonstrated decreased efficiency with increasing flue gas CO₂ content.

Compared to 30 wt% MEA, Hitachi's H3-1 operated with a 37 percent lower L/G ratio, achieving a 33 percent lower heat of regeneration. Operation with the H3-1 solvent required lower regeneration energy because of the smaller amount of liquid needing heating in the reboiler in combination with a lower heat of reaction with CO₂. With three beds in service, using the intercoolers was shown to raise the CO₂ capture efficiency from 89 to 94 percent. By lowering average solvent temperature in the absorber enabling operation in the optimal range of 100 to 140°F, the intercoolers enhance CO₂ capture efficiency. The CO₂ capture efficiency increased with the number of absorber beds in service, as the beds provide surface area for gas-liquid contacting and increase the gas residence time in the reaction zone.

Cansolv Technologies Solvent

Testing of the Cansolv DC-201 solvent was completed after 1,725 hours of operation in the PSTU. Data showed that the Cansolv solvent required 40 percent less energy than MEA to achieve the same capture rate using three packing sections in the absorber. The solvent also required 50 percent less circulation (L/G of 2 kg/Nm³ for DC-201 and 4 kg/Nm³ for MEA).

The operating conditions (liquid-to-gas ratio and steam usage per ton of CO₂ captured) were not significantly affected while switching from three to two packing sections. The L/G did not vary, and the stripping factor increased from 2.2 GJ/ton CO₂ to 2.3 GJ/ton CO₂. When switching from two to one packing section in the absorber, the solvent flow rate requirement increased (L/G going from 2.0 to 2.5 kg/Nm³), as did that for reboiler steam flow rate. (Stripping factor increased from 2.3 GJ/ton CO₂ to 2.8 GJ/ton CO₂.)

Testing demonstrated operational flexibility from 40 to 60 wt% solvent concentration and optimum operation with respect to energy consumption from 45 to 55 wt% solvent concentration. Results of solvent degradation sampling indicated very low degradation rate of the DC-201 solvent. Solvent sampling for metals showed that the solvent was contaminated with metals, although the metals concentrations did not impact solvent capture. The build-up of sulfates originating from SO₂ and nitrates from NO₂ also did not affect solvent performance.

Solvent degradation products, including formaldehyde, ammonia, and dimethylamine were found to be low, in the ppmv to the sub-ppmv range. Nitrosamines were also detected, but at the ppbv level. Further analyses related to solvent emissions are ongoing.

Chiyoda Solvent

The NCCC completed design modification to the PSTU that Chiyoda requested for better representing their expected commercial operation. Chiyoda began testing its T-3 solvent in the PSTU in December 2012 and plans to continue operation into mid-2013 to complete parametric testing and achieve long-term operation.

MTR 1-ton/day Flue Gas Membrane

After initial operation in late 2011, the MTR 1 ton/day membrane operated intermittently during 2012. Due to corrosion and buildup of deposits in the compressor outlet, the screw compressor was replaced with a liquid-ring compressor. In the liquid ring compressor, cooling water comes into direct contact with the flue gas, which will prevent dry surfaces being created onto which the deposit can form. Moreover, any deposit that does form will rapidly dissolve in the water.

During an outage in August, two CFM modules (one from each vessel) were removed for inspection by MTR. These had been in operation since the beginning of testing in December 2011 and had been exposed to flue gas for almost 1,500 hours with some additional hours on air when flue gas was not available. No particulate was found on either end of the membranes or within the membrane envelopes. Membrane performance did not degrade with time or with pressure drops increase, suggesting that the pretreatment system worked effectively and prevented fouling of the membranes by flue gas contaminants.

During 100 hours of operation in December, the CO₂ content of the flue gas feed was reduced from about 12 percent to around 1 percent in the residual stream leaving the skid, corresponding to CO₂ capture greater than 90 percent. This is an improvement over the previous capture efficiency of 87 percent and indicates the continuing improvements being made in membrane performance.

MTR 20-ton/day Membrane System

Lessons learned from the operation of 1-ton/day unit provided valuable inputs to the 20-ton/day system design changes. Some of the critical skid modifications included equipment rearrangement to fit the skid to the footprint available at PC4, addition of a Venturi scrubber upstream of the compressor, replacement of a screw compressor with a liquid ring compressor, and provision of additional instrumentation for better monitoring and control.

Codexis Enzymes

Codexis performed testing at the PC4 on carbonic anhydrase enzymes to accelerate the rate of CO₂ capture for solvents with low heats of reaction such as MDEA. The tests at the PC4 were the first using coal-derived flue gas to determine the stability of the enzyme under industrial operating conditions in the presence of trace contaminants. The two-week commissioning and testing period demonstrated CO₂ capture averaging around 65 percent at a rate of capture over 25 times greater than for MDEA alone with 0.2 g/L of enzyme loading. No apparent effect of trace metals or elevated process temperatures on enzyme performance was seen.

Akermin Enzymes

In December 2012, Akermin completed checkout and commissioning of its pilot plant for evaluation of a carbonic anhydrase enzyme to accelerate the capture of CO₂ by potassium carbonate. For this design, the enzyme is contained on the surfaces of the absorber packing. Testing is planned to proceed to mid-2013.

Engineering Studies

The NCCC's Engineering and Economic Evaluations group began work on a post-combustion CO₂ capture (PCC) baseline study in collaboration with the NETL and EPRI.

5.3 Gasification

Gasification Operation

The gasification process operated over two test runs, R08 and R09, for a total of more than 1,250 hours. Progress continued on the development of the pressure decoupled advanced coal (PDAC) feeder, gasifier control automation, sensors, and instrumentation. Steady-state carbon conversions were comparable to previous test runs. At the conclusion of R09, the gasification process had operated for over 18,000 total hours with over 2,000 hours in oxygen blown operation.

Gasifier temperature control enhancements utilizing upper and lower mixing zone air flow adjustments were ongoing during R08 and R09. Gasifier temperature variation has been decreased from 5°F achieved during initial control implementation to less than 2°F during R08 and R09.

Testing of previous PDAC feeder control logic improvements also continued. The gasifier pressure feedback controller permitted automatic adjustments to feeder pressure and nitrogen flow as gasifier pressure was reduced for oxygen-blown operation. The adjustments made by the controller permitted the pressure differential between the feeder and the gasifier to be maintained at a constant level, helping keep the coal feed rate steady.

Oxygen-Blown Biomass Co-Feeding

During the final portion of the R08 run, 219 hours of oxygen-blown gasification testing were conducted with biomass co-feed on behalf of CCAT. The testing included co-feeding of two forms of biomass, raw pellets and torrefied pellets, with PRB sub-bituminous coal during oxygen-blown gasifier operation. The actual co-feed percentages for the torrefied biomass were 17, 20, and 29 wt%. The actual co-feed percentages for the raw biomass were 12, 20, and 28 wt%.

Gasifier operating conditions remained stable during all tests and yielded high carbon conversions during both coal-only and biomass co-feed operation. Syngas heating values remained stable during the biomass co-feed periods, and there was no appreciable tar generation during the testing.

PCD Operation

PCD research efforts continued during the year focusing on the long-term evaluation of material performance of several types of filter elements and failsafe devices. The elements with the greatest exposure time, which are iron aluminide elements, have accumulated over 16,200 hours of syngas operation.

Sensor Development

Testing of an Emerson sapphire thermowell for gasifier service continued. Following removal of a previously tested thermowell that showed corrosion, a new thermowell assembly was re-installed in the same location prior to run R08 with an added transmitter for detection of sensor failure. Unfortunately, the transmitter/thermocouple failed shortly after R08 began, and a post-run inspection showed that the assembly had broken. NCCC staff continues to collaborate with Emerson for future test plans.

Testing of the DensFlow coal flow meter from SWR Engineering during R08 and R09 continued to show discrepancy between the flow meter and the weigh-cell calculated coal flow rates. NCCC staff are pursuing ways to improve the flow meter accuracy. The Dynatrol vibration level probes and a point sensitive level probe from Drexelbrook installed in the PCAD feeder vessels continued to provide reliable measurements.

Gasification Process Modifications

A major process modification was the replacement of the gasifier standpipe made because of refractory damage. Two places of concern were the intersection of the solids separation unit and standpipe, and the intersection of the J-leg and standpipe. The refractory in the standpipe and J-leg was the refractory originally installed in the gasifier, and had been in service for 15 years. The refractory was in excellent condition following initial operation in runs R08 and R09.

The PCD tubesheet required repair of a significant fracture, and plans began in evaluating options for further repairs or replacement of PCD vessel components. The primary gas cooler also required repairs due to a leaking tube, and the cooler is planned to be replaced in 2013. Modifications to the fine ash removal system were underway to incorporate an improved pressure letdown device.

TDL Sensor

Stanford University's Hanson research group tested the TDL sensor throughout R09, for more than 600 hours of operation. Testing at NCCC offered the first opportunity for measurements in an engineering-scale system, with the safety and access limitations expected for industrial-scale gasifiers. The sensor provided continuous, time-resolved measurements of moisture concentration and temperature. In addition, Stanford personnel also tested a proof-of-concept CO₂ measurement during start-up.

Initial testing focused on testing the sensor during system heat-up and transition to steady state gasification conditions. The TDL was then setup for long-term monitoring and provided continuous unattended monitoring of H₂O and temperature for over 400 hours. TDL measurements of moisture content were in good agreement with gas analyzer readings and

temperature indications near the location of the sensor although with significantly faster time resolution

During the test period, the laser transmission was stable and window performance and optical alignment did not degrade with time, ambient temperature, or gasifier warm-up. There were no leaks or failures in the TDL sensor package.

Some of the lessons learned from this successful demonstration of the TDL follow.

- The fraction of transmitted light was less than expected, indicating that improvements to the optical collection to suppress beam steering could improve sensor performance.
- Successful unattended operation of the TDL sensor suggests the utility of enhancing the sensor software for remote access to the sensor to assess sensor health and optical alignment.
- Stanford's first use of remote adjustment of optical alignment was successful, suggesting that remote alignment and sensor operation is feasible for long-term measurement campaign operation.
- Stanford's calibration-free WMS strategy ensured accurate interpretation of absorption signals even at low light transmission (less than 0.01 percent). This strategy also suppressed signal variation with changes in the optical transmission. The addition of automatic gain control in the signal processing has the potential for operation over even larger dynamic ranges.
- The rapid time-resolution of the TDL sensor allowed it to capture changes in the syngas composition that were not evident in the GC monitor. The TDL sensor also responded to gasifier changes nearly 30 minutes before the GC data. The rapid time-resolution suggests that the TDL sensor has promise for gasifier control, even when located downstream of the PCD.

In addition to improving sensor performance with changes in the optical collection and software for long-term remote operations, extension of the sensor to add new species such as CO, CO₂, and CH₄ could significantly extend the utility of laser-absorption sensing. The success of this TDL sensor campaign at the NCCC shows that it could be an important diagnostic tool with the potential for integration with control strategies for gasifiers.

Engineering Studies

In the area of gasification, NCCC staff reviewed and provided feedback on NETL reports on air-blown Transport Gasification systems as well as an oxygen-blown case comparison to published costs for the Duke Edwardsport IGCC plant.