Atoms International Division
Rockwell International

U

CLASSIFICATION LEVEL
(S, C OR U)

DOCUMENT NO.

TI-653-260-001

COVER SHEET

DOCUMENT TITLE

Comparison of Calculated and Experimental Reactivities of
SNAP Reactors

AUTHOR

D. S. Bost

NOTICE
This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Energy Research and Development Administration, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed or represents that its use would not infringe privately owned rights.

THIS IS AN INTERNAL WORKING
DOCUMENT AND MAY BE
EXPANDED, MODIFIED, OR
WITHDRAWN AT ANY TIME.

~~IT IS INTENDED FOR
INTERNAL USE ONLY.~~

CLASSIFICATION TYPE
(RD OR DI)

~~THIS REPORT MAY NOT BE PUBLISHED WITHOUT THE APPROVAL OF THE PATENT BRANCH, AEC.~~

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Atomic Energy Commission, nor any of their employees nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

U

CLASSIFICATION LEVEL
(S, C OR U)

MASTER

DO NOT REMOVE THIS SHEET **DISTRIBUTION OF THIS DOCUMENT UNLIMITED**

ef

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

Atomic International
North American Rockwell

SUPPORTING DOCUMENT

#725

NUMBER

TI-653-260-001

REV LTR/CHG NO.

SEE SUMMARY OF CHG

PROGRAM TITLE

SPF Reactor Program

DOCUMENT TYPE

Technical Information

DOCUMENT TITLE

Comparison of Calculated and Experimental
Reactivities of SNAP Reactors

KEY WORDS

Reactivity Calculations,
SNAP Reactors

ORIGINAL ISSUE DATE 8/4/71

GO NO.

6531

S/A NO.

20310

PAGE 1 OF

48

TOTAL PAGES

REL. DATE 8-10-71/13

PREPARED BY/DATE

D. S. Bost

228

DEPT

731

MAIL ADDR

LB41

SECURITY CLASSIFICATION

(CHECK ONE BOX ONLY)

UNCL ☒

CONF. ☐

SECRET ☐

AEC ☐

DOD ☐

DEFENSE ☐

(CHECK ONE BOX ONLY)

RESTRICTED ☐

DATA ☐

DEFENSE ☐

INFO. ☐

APPROVALS

DATE

H. Rood

8/7/71

AUTHORIZED
CLASSIFIER

H. Rood

DATE
8/7/71

DISTRIBUTION

* NAME	MAIL ADDR
H. Alter	NA03
J. Brurings	LB22
J. G. Asquith	LB02
E. J. Donovan	LB25
J. D. Gylfe	LB01
R. B. Harty	LB27
O. R. Hillig	TO09
R. L. Koontz	NA03
R. T. Lancet	LB41
L. M. Maki	LB03
A. B. Martin	LB04
D. G. Mason	LB02
W. J. Roberts	LB36
H. Rood	LB22
D. S. Bost	LB41
R. A. Johnson	LB02
J. H. VanOsdol	LB20
R. O. Williams	LB13
R. F. Wilson	LB01
Reactor Analysis Unit (9)	LB22
Program Office File	LB02

ABSTRACT

The reactivities of S8ER, the S8ER core in SCA-4B, S8DR, and SCA-4A were calculated using current methods and cross section data for comparison with experiment. A variety of core loadings and reflector shim configurations were used, making a total of twelve calculations. These may be grouped into six near critical and six significantly supercritical configurations. The mean error and standard deviation was $-0.11 \pm 1.53\%$ for all calculations, $+0.51 \pm 1.05\%$ for the near criticals, and $-0.73 \pm 1.76\%$ for the supercritical.

RESERVED FOR NR PROPRIETARY/LEGAL NOTICES

* TITLE PAGE ONLY

I. Introduction

The reactivities of four reactors were calculated using current methods and cross section data for comparison with experiment. This type of analysis is required periodically to evaluate the effects of refinements in methods and revisions in cross section data. In particular, the recent library revision made this effort desirable at this time.

The four reactors which were analyzed were S8ER, the water immersed S8ER core in SCA-4B, S8DR, and SCA-4A. A variety of core loadings and reflector shim configurations were used to make a total of twelve reactivity calculations. These may be grouped into six near critical configurations and six significantly supercritical configurations. The magnitude of the experimental uncertainty is least for the near critical configurations, probably because they are independent of errors in the control drum calibration curves. It is therefore felt that these six provide the most reliable test of the calculational method.

II. Summary of Results

The comparison between calculated and experimental reactivities is given in Table I. An effective delayed neutron fraction (β_{eff}) of .0075 was used for the SNAP 8 cores to convert calculated $\Delta K/K$ to dollars. For SCA-4A, a β_{eff} of .0080 was used. References from which the experimental reactivities were obtained are included in Table I.

There are two values of excess reactivity quoted for the full loaded, fully shinned S8ER. These differ by \$1.55. One measurement was taken in the water and the other was taken in the vacuum vessel. The actual difference in reactivity between the two was approximately 32¢ from the position of the drums at criticality. The remaining discrepancy may be attributed to the use of drum calibrations to determine excess reactivity because the drum calibrations in the two locations were quite different. A similar problem existed for the fully loaded, fully shinned S8ER with variations in excess reactivity as high as \$1.76 being quoted. The value of \$10.99 in Table I is the accepted value. The fact that the calculations underpredict the reactivity of these two reactors may be in part due to these differences in drum calibrations.

There are various ways of grouping the data to arrive at an average error between calculated and experimental reactivity. Using all the data with an average of the two values for the fully loaded S8DR, a mean error and standard deviation of $-0.11 \pm 1.53\%$ is obtained. Removing the water flooded and reflected SCA-4B data gives $-0.54 \pm 1.28\%$, which would be more applicable to beryllium reflected reactors. Grouping the six data points for the near critical configurations, the mean and standard deviation is $0.51 \pm 1.05\%$. Without the SCA-4B data this changes to $0.17 \pm .74\%$. Grouping the six supercritical configurations, the mean and standard deviation is $-0.73 \pm 1.76\%$ with the SCA-4B data and $-1.25 \pm 1.36\%$ without.

III. Conclusions and Recommendations

It may be concluded from these results that the previously used β_1 normalization for beryllium reflected reactors is no longer applicable with the new cross section library. For near critical loadings or reflector configurations, the calculations indicate that no normalization is required. For supercritical reactivities, a normalization of $\sim \beta_1$ may still be required. It is not clear whether this is due to the inability of the calculations to determine reflector worth or to the use of drum calibrations to determine excess reactivity.

It is recommended that an investigation of reflector worth be continued. Emphasis should be placed on the SCA-4A experiments because they depend less on drum calibrations. In addition, an attempt should be made to calculate either S8ER or S8DR critical drum position in two-dimensional geometry.

It is also recommended that poison worth (preferably boron splines) rather than drum calibrations be used in the future to determine excess reactivity.

IV. Method Used

The calculations were made using the APC code in the leakage iteration (DB^2) mode. Leakage terms from the core were spread to the non-core zones. Two comparisons of this method were made with R,Z DOT calculations and slightly higher reactivities were obtained with APC in both instances. For the 165 element S8DR core the difference was 26¢ and for the 211 elements S8ER core with no shims the difference was 42¢. These

comparisons were made with an old library but this fact should not alter the conclusions that the APC method is reasonably accurate. The differences between the two calculations were primarily due to geometrical differences and should be independent of the library used.

All the calculations were made using S_4 , Po transport theory with a new 28 group cross section library. The cross sections were weighted over a ZrH reactor spectrum and are based primarily on ENDF/B data. The major difference in reactivity between the new and old libraries resulted from using ENDF/B cross sections rather than KEDAK cross sections for U235. The only other significant reactivity difference came from using ENDF/B rather than AI zirconium cross sections. The revised spectrum weighting made little difference because all calculations were at room temperature; however, some differences would be expected in temperature coefficients calculated with the new library. The cross section sets which were used in the calculations are identified in Table II.

Cell weighting of cross sections was used only in the SCA-4B calculations. It was necessary in this instance because of the water and poison splines in the core. The standard method for dry or NaK filled ZrH reactors is to use no cell weighting.

The geometrical models of the reactors analyzed were generated using the SODR model in Reference 4 as a guide. The main features of this model are the use of as-built dimensions and material compositions and a reduced density reflector representations. Tabulations of measurements

made on fuel elements were used to assure that the proper amount of uranium, zirconium, hydrogen, and cladding was used in the core. The reduced density reflector representation was used in order to preserve the distance between the beryllium and the core. Reducing the beryllium density accounts for clearances between drums and stationary parts such as the core vessel and reflector cusps. The reduced density reflector model did not enter into the SCA-4B calculations because the reflector was water. It also had little influence in the SCA-4A calculations because both drums and cusps were shimmed on that machine and clearances were small. The extent to which it influences the S_{SDR} and S_{SER} calculations is unknown.

Sketches of the models used for the four reactors are shown in Figures 1-4. The twelve calculated points presented were obtained by varying fuel loadings or reflector shims.

Atom density and neutron balance tables for all four reactors are given in Tables III-X. Sufficient data are contained in these tables to reproduce all twelve calculations exactly. This should allow future evaluation of cross section data to be made with a minimum amount of effort.

Table I

Comparison of Calculated and Experimental Reactivities of SNAP Reactors

A. Near Critical Reactivities

Assembly	Calculated k_{eff}	Reactivity (\$)		Error (\$)	Reference
		Calculated	Measured		
S3DR-165 Elements Full Shims	1.0102	1.35	0.16	1.19	1
SCA-4A-37 Elements 1.25" Reflector	.9942	-0.73	-0.25	-0.48	9
S3ER-211 Elements No Shims	.9935	-0.88	-0.28	-0.60	5
S3ER-186 Elements A Shims	1.0030	0.40	0.14	0.26	5
S3ER-173 Elements A + B Shims	1.0045	0.60	0.10	0.50	5
SCA-4B-211 Elements 72 Poison Splines Water Flooded and Reflected	1.0181	2.37	0.19	2.18	10

B. Supercritical Reactivities

S3DR-169 Elements Full Shims	1.0181	2.37	1.40	0.97	2
S3DR-211 Elements Full Shims	1.1002	12.14	14.40 12.85	-2.26 -0.71	2 3
SCA-4A-37 Elements 2.25" Reflector	1.0446	5.33	6.55	-1.22	9

Table I
(continued)

Assembly	Calculated k_{eff}	Reactivity (\$)		Error (\$)	Reference
		Calculated	Measured		
SCA-4A-37 Elements 3.25" Reflector	1.0746	8.68	10.45	-1.77	9
S&ER-211 Elements Full Shims	1.0584	7.36	10.09	-2.73	6
SCA-4B-211 Elements No Poison Splines Water Flooded and Reflected	1.0615	7.72	5.87	1.85	10

TABLE II

CROSS SECTION ID NUMBERS

10	TITLE= H20	20C
20	TITLE= NAK	20C
30	TITLE= HASTN	20C
31	TITLE= 316SS	20C
32	TITLE= HASTC	20C
52	TITLE= BE	296K
53	TITLE= BE0	296K
1021	TITLE= H(ZK)	296K
9001	TITLE= 0	20C
11001	TITLE= NA	20C
13001	TITLE= AL	20C
19001	TITLE= K	20C
24001	TITLE= CR	20C
26001	TITLE= FE	20C
27001	TITLE= C0	20C
28001	TITLE= NI	20C
92821	TITLE= U238	296K
304021	TITLE= BE	296K
325001	TITLE= MN	20C
340021	TITLE= ZR(H)	296K
362911	TITLE= SM149	20C
392521	TITLE= U235	296K
442001	TITLE= M0	20C
564501	TITLE= GD155	20C

MOLECULAR CORE WTG

MACR0	CORE WTG B057 11/6/70
MACR0	CORE WTG 0110WITTE
MACR0	CORE WTG 0110WITTE
MACR0	CORE WTG B057 3/3/71
MACR0	BL CORE WTG B057 4/23/71
MACR0	BL CORE WTG B057 4/23/71
INF	AI CORE (FLANGE) 03/02/71
INF	AI CORE WTG
INF	AI CORE WTG
INF	AI CORE WTG
INF	AI CORE WTG
INF	AI CORE WTG
INF	AI CORE WTG
INF	AI CORE WTG ABS. 2/24/71
INF	AI CORE WTG
16640B	AI CORE WTG 12/28/70
INF	BL CORE (FLANGE) 04/21/71
INF	BL CORE WTG
43.8B	BL CORE (FLANGE) 03/02/71
INF	BL CORE WTG 01/29/70
1051B	B2 CORE WTG 02/22/71
INF	KD CORE WTG
INF	MC CORE WTG

DESIGNED BY:	ATOMICS INTERNATIONAL A DIVISION OF NORTH AMERICAN ROCKWELL CORPORATION	PAGE NO. 10 OF
CHECKED BY:		TI-653-250-001
DATE:	FIGURE 1. S8DR MODEL	MODEL NO.

1 3 5 7 9 11 13 15 17 19 21 23 25 27 29 31

Intervals	Radius (cm)	Intervals	Height (cm)
1 - 14	9.8089	1 - 2	0.8852
15 - 16	11.0922	3 - 6	2.6492
17 - 18	11.7348	7	3.0124
19	12.1666	8 - 9	4.9492
20 - 25	18.4887	10 - 12	8.9192
26	19.7561	13 - 30	39.8412
27	21.1557	31 - 33	43.8112
28 - 29	23.8229	34 - 35	45.7479
30 - 31	26.4902	36 - 37	46.7589
		38 - 39	47.8752
		40 - 41	48.9052

S8DR-165 ELEMENTS-FULL SHIMS - RADIAL

TABLE III

ANGULAR QUADRATURE CONSTANTS				
COSINE (MU)	WEIGHT	REFL DIRECT	WT. X COS.	
1 -4.71404E-01	0	3	0	
2 -3.33333E-01	1.66666E-01	3	-5.55553E-02	
3 3.33333E-01	1.66666E-01	2	5.55553E-02	
4 -9.42809E-01	0	8	0	
5 -8.81917E-01	1.66666E-01	8	-1.46986E-01	
6 -3.33333E-01	1.66666E-01	7	-5.55553E-02	
7 3.33333E-01	1.66666E-01	6	5.55553E-02	
8 8.81917E-01	1.66666E-01	5	1.46986E-01	

DENSITY TABLES AND

NEUTRON BALANCE TABLES

FOR S8DR

DENSITY TABLE

NUCLIDE	1	2	3	4	5	6	7
	HASTN	316SS	HASTC	BE	BEO	HZR	O
1 CORE	6.8930E-02	0.0	0.0	0.0	0.0	4.7000E-02	3.8120E-01
2 DUMMY FUEL	0.0	8.8930E-01	0.0	0.0	0.0	0.0	0.0
3 INTERFACE	0.0	3.2180E-01	0.0	0.0	4.9920E-01	0.0	0.0
4 VESSEL+GAP	0.0	5.3510E-01	0.0	0.0	0.0	0.0	0.0
5 REFLECTOR	0.0	0.0	0.0	9.5780E-01	0.0	0.0	0.0
6 A SHIM	0.0	0.0	0.0	9.0310E-01	0.0	0.0	0.0
7 B SHIM	0.0	0.0	0.0	7.9600E-01	0.0	0.0	0.0
8 C SHIM	0.0	0.0	0.0	7.1160E-01	0.0	0.0	0.0

NUCLIDE	8	9	10	11
	ZR	U238	SM149	U235
1 CORE	2.7360E-02	8.4370E-05	3.5174E-07	1.1640E-03
2 DUMMY FUEL	0.0	0.0	0.0	0.0
3 INTERFACE	0.0	0.0	0.0	0.0
4 VESSEL+GAP	0.0	0.0	0.0	0.0
5 REFLECTOR	0.0	0.0	0.0	0.0
6 A SHIM	0.0	0.0	0.0	0.0
7 B SHIM	0.0	0.0	0.0	0.0
8 C SHIM	0.0	0.0	0.0	0.0

PL-63-360-001

--- SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN* ---

*EXCEPTION - LAST LEFT LEAKAGE IS RT BNDY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE III (cont.)

	ZONE 1	ZONE 2	ZONE 3	ZONE 4	ZONE 5	ZONE 6
NO. INTERVALS	14.00000	2.00000	2.00000	1.00000	6.00000	2.00000
ZONE WIDTH	9.80890	1.28330	0.64260	0.43180	6.32209	2.66699
ZONE VOLUME	302.26660	84.26489	46.08289	32.42322	608.85840	332.16431
AVERAGE FLUX	0.05692	0.03901	0.03527	0.03394	0.02418	0.01327
RIGHT RADIUS	9.80890	11.09220	11.73480	12.16660	18.48869	21.15569
RADIAL LEAKAGE	0.32727	-0.04792	-0.01325	-0.01450	-0.04312	-0.01470
TRANS LEAKAGE	0.06008	0.01148	0.00568	0.00384	0.05141	0.01540
LEFT LEAKAGE	0.0	0.32727	0.27935	0.26610	0.25160	0.20847
LEFT L+	0.0	0.84642	0.81042	0.80241	0.80672	0.60341
LEFT L-	0.0	0.51916	0.53107	0.53631	0.55512	0.39494
NU FISSION/ABSN	1.60544	0.0	0.0	0.0	0.0	0.0
NU FISSION	0.98313	0.0	0.0	0.0	0.0	0.0
ABSORPTION	0.61238	0.03648	0.00759	0.01066	-0.00826	-0.00074
FISSION	0.40332	0.0	0.0	0.0	0.0	0.0

ATL ABSN

1 HASTN 20C	0.02705	0.0	0.0	0.0	0.0	0.0
2 316SS 20C	0.0	0.03648	0.00819	0.01066	0.0	0.0
3 HASTC 20C	0.0	0.0	0.0	0.0	0.0	0.0
4 BE 20C	0.0	0.0	0.0	0.0	-0.00026	-0.00074
5 BEO 20C	0.0	0.0	-0.00060	0.0	0.0	0.0
6 HZR 20C	0.00958	0.0	0.0	0.0	0.0	0.0
7 O 20C	0.00000	0.0	0.0	0.0	0.0	0.0
8 ZR 20C	0.01379	0.0	0.0	0.0	0.0	0.0
9 U238 20C	0.00964	0.0	0.0	0.0	0.0	0.0
10 SM149 20C	0.01421	0.0	0.0	0.0	0.0	0.0
11 U235 20C	0.53810	0.0	0.0	0.0	0.0	0.0

ATL FISSN

1 HASTN 20C	0.0	0.0	0.0	0.0	0.0	0.0
2 316SS 20C	0.0	0.0	0.0	0.0	0.0	0.0
3 HASTC 20C	0.0	0.0	0.0	0.0	0.0	0.0
4 BE 20C	0.0	0.0	0.0	0.0	0.0	0.0
5 BEO 20C	0.0	0.0	0.0	0.0	0.0	0.0
6 HZR 20C	0.0	0.0	0.0	0.0	0.0	0.0
7 O 20C	0.0	0.0	0.0	0.0	0.0	0.0
8 ZR 20C	0.0	0.0	0.0	0.0	0.0	0.0
9 U238 20C	0.00016	0.0	0.0	0.0	0.0	0.0
10 SM149 20C	0.0	0.0	0.0	0.0	0.0	0.0
11 U235 20C	0.00316	0.0	0.0	0.0	0.0	0.0

SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN* - - - -
 *EXCEPTION - LAST LEFT LEAKAGE IS RT BNDY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE III. (cont.)

	ZONE 7	ZONE 8	ZONE 9
NO. INTERVALS	2.00000	2.00000	31.00000
ZONE WIDTH	2.66721	2.66730	26.49019
ZONE VOLUME	376.88770	421.60059	2204.54761
AVERAGE FLUX	0.00904	0.00379	0.02131
RIGHT RADIUS	23.82299	26.49019	26.49019
RADIAL LEAKAGE	-0.01029	-0.00533	0.17816
TRANS LEAKAGE	0.01059	0.00558	0.16405
LEFT LEAKAGE	0.19378	0.18349	0.17816
LEFT L+	0.46265	0.32256	0.17816
LEFT L-	0.26888	0.13906	0.00000
NU FISSION/ABSN	0.0	0.0	1.49529
NU FISSION	0.0	0.0	0.98313
ABSORPTION	-0.00035	-0.00027	0.65748
FISSION	0.0	0.0	0.40332

IATL ABSN

1	HASTN	20C	0.0	0.0	0.02705
2	316SS	20C	0.0	0.0	0.05534
3	HASTC	20C	0.0	0.0	0.0
4	BE	20C	-0.00035	-0.00027	-0.00963
5	BEO	20C	0.0	0.0	-0.00060
6	HZR	20C	0.0	0.0	0.00958
7	O	20C	0.0	0.0	0.00000
8	ZR	20C	0.0	0.0	0.01379
9	U238	20C	0.0	0.0	0.00964
10	SM149	20C	0.0	0.0	0.01421
11	U235	20C	0.0	0.0	0.53810

IATL FISN

1	HASTN	20C	0.0	0.0	0.0
2	316SS	20C	0.0	0.0	0.0
3	HASTC	20C	0.0	0.0	0.0
4	BE	20C	0.0	0.0	0.0
5	BEO	20C	0.0	0.0	0.0
6	HZR	20C	0.0	0.0	0.0
7	O	20C	0.0	0.0	0.0
8	ZR	20C	0.0	0.0	0.0
9	U238	20C	0.0	0.0	0.00016
10	SM149	20C	0.0	0.0	0.0
11	U235	20C	0.0	0.0	0.40316

TI-553-260-001
Page 13

AXIAL - SBR

TABLE III (cont.)

ANGULAR QUADRATURE CONSTANTS

	COSINE (MU)	HEIGHT	REFL DIRECT	WT. X COS.
1	-1.00000E 00	0	5	0
2	-8.81917E-01	1.66666E-01	5	-1.46986E-01
3	-3.33333E-01	3.33333E-01	4	-1.11111E-01
4	3.33333E-01	3.33333E-01	3	1.11111E-01
5	8.81917E-01	1.66666E-01	2	1.46986E-01

DENSITY TABLE

NUCLIDE -->	1 HASTN	20C	2 316SS	20C	3 HASTC	20C	4 BE	20C	5 BEO	20C	6 HZR	20C	7 O	20C
MIXTURE														
1 L GRID	4.1190E-02		2.8400E-01		4.4270E-01		0.0		0.0		0.0		0.0	
2 CAPS	8.7500E-01		0.0		0.0		0.0		0.0		0.0		0.0	
3 CORE	6.8930E-02		0.0		0.0		0.0		0.0		4.7000E-02		3.8120E-0	
4 CAPS+VOID	1.8000E-01		0.0		0.0		0.0		0.0		0.0		0.0	
5 U GRID	1.1000E-01		5.7000E-01		0.0		0.0		0.0		0.0		0.0	

NUCLIDE -->	8 ZR	20C	9 U238	20C	10 SM149	20C	11 U235	20C
MIXTURE								
1 L GRID	0.0		0.0		0.0		0.0	
2 CAPS	0.0		0.0		0.0		0.0	
3 CORE	2.7360E-02		8.4370E-05		3.5174E-07		1.1640E-03	
4 CAPS+VOID	0.0		0.0		0.0		0.0	
5 U GRID	0.0		0.0		0.0		0.0	

SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN
 *EXCEPTION - LAST LEFT LEAKAGE IS RT BNDY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE III (cont.)

	ZONE 1	ZONE 2	ZONE 3	ZONE 4	ZONE 5	ZONE 6
NO. INTERVALS	6.00000	1.00000	23.00000	2.00000	4.00000	41.00000
ZONE WIDTH	2.64920	0.36320	42.73549	1.01100	2.14630	48.90520
ZONE VOLUME	2.64920	0.36320	42.73549	1.01100	2.14630	48.90520
AVERAGE FLUX	0.07469	0.12370	0.40262	0.10207	0.06834	0.36190
RIGHT RADIUS	2.64920	3.01240	45.74789	46.75890	48.90520	48.90520
RADIAL LEAKAGE	-0.00599	-0.00156	0.06009	-0.00231	-0.00362	0.04661
TRANS LEAKAGE	0.00377	0.00086	0.32754	0.00196	0.00279	0.33692
LEFT LEAKAGE	-0.02243	-0.02842	-0.02998	0.03011	0.02780	0.02418
LEFT L+	0.0	0.01624	0.01981	0.04375	0.03972	0.02418
LEFT L-	0.02243	0.04466	0.04980	0.01365	0.01192	0.0
NU FISSION/ABSN	0.0	0.0	1.60536	0.0	0.0	1.59467
NU FISSION	0.0	0.0	0.98301	0.0	0.0	0.98301
ABSORPTION	0.00222	0.00071	0.61233	0.00034	0.00083	0.61644
FISSION	0.0	0.0	0.40327	0.0	0.0	0.40327

ATL ABSN

1	HASTN	20C	0.00011	0.00071	0.02705	0.00034	0.00025	0.02845
2	316SS	20C	0.00035	0.0	0.0	0.0	0.00059	0.00094
3	HASTC	20C	0.00176	0.0	0.0	0.0	0.0	0.00176
4	BE	20C	0.0	0.0	0.0	0.0	0.0	0.0
5	BEO	20C	0.0	0.0	0.0	0.0	0.0	0.0
6	HZR	20C	0.0	0.0	0.00958	0.0	0.0	0.00958
7	O	20C	0.0	0.0	0.00000	0.0	0.0	0.00000
8	ZR	20C	0.0	0.0	0.01379	0.0	0.0	0.01379
9	U238	20C	0.0	0.0	0.00964	0.0	0.0	0.00964
10	SM149	20C	0.0	0.0	0.01421	0.0	0.0	0.01421
11	U235	20C	0.0	0.0	0.53805	0.0	0.0	0.53805

ATL FISSN

1	HASTN	20C	0.0	0.0	0.0	0.0	0.0	0.0
2	316SS	20C	0.0	0.0	0.0	0.0	0.0	0.0
3	HASTC	20C	0.0	0.0	0.0	0.0	0.0	0.0
4	BE	20C	0.0	0.0	0.0	0.0	0.0	0.0
5	BEO	20C	0.0	0.0	0.0	0.0	0.0	0.0
6	HZR	20C	0.0	0.0	0.0	0.0	0.0	0.0
7	O	20C	0.0	0.0	0.0	0.0	0.0	0.0
8	ZR	20C	0.0	0.0	0.0	0.0	0.0	0.0
9	U238	20C	0.0	0.0	0.00016	0.0	0.0	0.00016
10	SM149	20C	0.0	0.0	0.0	0.0	0.0	0.0
11	U235	20C	0.0	0.0	0.40310	0.0	0.0	0.40310

DESIGNED BY:	ATOMICS INTERNATIONAL A DIVISION OF NORTH AMERICAN ROCKWELL CORPORATION	PAGE NO. 16 OF
CHECKED BY:		TI- 653-260-001
DATE:	FIGURE 2. S8ER MODEL	MODEL NO.

Intervals	Radius (cm)	Intervals	Height (cm)
1-16	11.0418	1-2	0.7938
17-18	11.7180	3-4	1.7945
19	12.0548	5-6	3.9688
20-25	18.0727	7-29	34.3827
26-27	20.0731	30-32	37.3545
28-30	23.0869	33	37.5577
31-32	25.4340	34-35	38.4308

S8ER-211 ELEMENTS-FJLL SHIMS - RADIAL

ANGULAR QUADRATURE CONSTANTS
COSINE (MU) WEIGHT REFL DIRECT WT. X COS.

TABLE IV

DENSITY TABLES AND
NEUTRON BALANCE TABLES
FOR S8ER

DENSITY TABLE

NUCLIDE -->	1	2	3	4	5	6	7
	HASTN 20C	316SS 20C	HASTC 20C	BE 296K	BE7 296K	H(ZR) 296K	O 20C
MIXTURE							
1 CORE	6.4050E-02	0.0	0.0	0.0	0.0	4.7034E-02	3.2630E-01
2 INTERFACE	5.9400E-02	0.0	0.0	0.0	5.1500E-01	0.0	0.0
3 VESSEL+GAP	0.0	4.6860E-01	0.0	0.0	0.0	0.0	0.0
4 REFLECTOR	0.0	0.0	0.0	9.4466E-01	0.0	0.0	0.0
5	0.0	0.0	0.0	0.0	0.0	0.0	5.3800E-01
6 A SHIM	0.0	0.0	0.0	9.8736E-01	0.0	0.0	0.0
7 B SHIM	0.0	0.0	0.0	9.0983E-01	0.0	0.0	0.0
8 C SHIM	0.0	0.0	0.0	5.5890E-01	0.0	0.0	0.0

NUCLIDE -->	8	9	10	11
	ZR(H) 296K	U238 296K	SH149 20C	U235 296K
MIXTURE				
1 CORE	2.8040E-02	8.1591E-05	3.0100E-07	1.1238E-03
2 INTERFACE	0.0	0.0	0.0	0.0
3 VESSEL+GAP	0.0	0.0	0.0	0.0
4 REFLECTOR	0.0	0.0	0.0	0.0
5	0.0	0.0	0.0	0.0
6 A SHIM	0.0	0.0	0.0	0.0
7 B SHIM	0.0	0.0	0.0	0.0
8 C SHIM	0.0	0.0	0.0	0.0

TI-653-260-001
Page 17

SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN*
 *EXCEPTION - LAST LEFT LEAKAGE IS RT BNDY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE IV (cont.)

	ZONE 1	ZONE 2	ZONE 3	ZONE 4	ZONE 5	ZONE 6
NO. INTERVALS	16.00000	2.00000	1.00000	6.00000	2.00000	3.00000
ZONE WIDTH	11.04180	0.67620	0.33680	6.01789	2.00040	3.01381
ZONE VOLUME	383.02661	48.34973	25.15369	569.58301	239.72461	408.64551
AVERAGE FLUX	0.04566	0.03373	0.03239	0.02267	0.01280	0.00744
RIGHT RADIUS	11.04180	11.71800	12.05480	18.07269	20.07309	23.08690
RADIAL LEAKAGE	0.28138	-0.01020	-0.01137	-0.05323	-0.01429	-0.01438
TRANS LEAKAGE	0.08580	0.00809	0.00404	0.06407	0.01523	0.01509
LEFT LEAKAGE	0.0	0.28137	0.27117	0.25980	0.20657	0.19229
LEFT L+	0.0	0.77084	0.76790	0.76902	0.55998	0.44650
LEFT L-	0.0	0.48947	0.49673	0.50922	0.35342	0.25421
NU FISSION/ABSN	1.67554	0.0	0.0	0.0	0.0	0.0
NU FISSION	1.05839	0.0	0.0	0.0	0.0	0.0
ABSORPTION	0.63167	0.00210	0.00733	-0.01084	-0.00094	-0.00072
FISSION	0.43560	0.0	0.0	0.0	0.0	0.0

IATL ABSN

1	HASTN 20C	0.02678	0.00302	0.0	0.0	0.0	0.0
2	316SS 20C	0.0	0.0	0.00733	0.0	0.0	0.0
3	HASTC 20C	0.0	0.0	0.0	0.0	0.0	0.0
4	BE 296K	0.0	0.0	0.0	-0.01084	-0.00094	-0.00072
5	BEO 296K	0.0	-0.00092	0.0	0.0	0.0	0.0
6	H(ZR) 296K	0.01053	0.0	0.0	0.0	0.0	0.0
7	O 20C	0.00000	0.0	0.0	0.0	0.0	0.0
8	ZR(H) 296K	0.01525	0.0	0.0	0.0	0.0	0.0
9	U238 296K	0.00957	0.0	0.0	0.0	0.0	0.0
10	SM149 20C	0.01390	0.0	0.0	0.0	0.0	0.0
11	U235 296K	0.55563	0.0	0.0	0.0	0.0	0.0

IATL FISSN

1	HASTN 20C	0.0	0.0	0.0	0.0	0.0	0.0
2	316SS 20C	0.0	0.0	0.0	0.0	0.0	0.0
3	HASTC 20C	0.0	0.0	0.0	0.0	0.0	0.0
4	BE 296K	0.0	0.0	0.0	0.0	0.0	0.0
5	BEO 296K	0.0	0.0	0.0	0.0	0.0	0.0
6	H(ZR) 296K	0.0	0.0	0.0	0.0	0.0	0.0
7	O 20C	0.0	0.0	0.0	0.0	0.0	0.0
8	ZR(H) 296K	0.0	0.0	0.0	0.0	0.0	0.0
9	U238 296K	0.00016	0.0	0.0	0.0	0.0	0.0
10	SM149 20C	0.0	0.0	0.0	0.0	0.0	0.0
11	U235 296K	0.43543	0.0	0.0	0.0	0.0	0.0

SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN*

*EXCEPTION - LAST LEFT LEAKAGE IS RT BODY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE IV (cont.)

	ZONE 7	ZONE 8
NO. INTERVALS	2.00000	32.00000
ZONE WIDTH	2.34709	25.43399
ZONE VOLUME	357.77393	2032.25635
AVERAGE FLUX	0.00317	0.01973
RIGHT RADIUS	25.43399	25.43399
RADIAL LEAKAGE	-0.00537	0.17254
TRANS LEAKAGE	0.00564	0.19896
LEFT LEAKAGE	0.17791	0.17254
LEFT L+	0.26854	0.17254
LEFT L-	0.09063	0.00000
NU FISSION/ABSN	0.0	1.68444
NU FISSION	0.0	1.05839
ABSORPTION	-0.00027	0.62833
FISSION	0.0	0.43560

ATL ABSN

1	HASTN	20C	0.0	0.02980
2	316SS	20C	0.0	0.00733
3	HASTC	20C	0.0	0.0
4	BE	296K	-0.00027	-0.01277
5	BEO	296K	0.0	-0.00092
6	H(ZR)	296K	0.0	0.01053
7	O	20C	0.0	0.00000
8	ZR(H)	296K	0.0	0.01525
9	U238	296K	0.0	0.00957
10	S4149	20C	0.0	0.01390
11	U235	296K	0.0	0.55563

ATL FISSN

1	HASTN	20C	0.0	0.0
2	316SS	20C	0.0	0.0
3	HASTC	20C	0.0	0.0
4	BE	296K	0.0	0.0
5	BEO	296K	0.0	0.0
6	H(ZR)	296K	0.0	0.0
7	O	20C	0.0	0.0
8	ZR(H)	296K	0.0	0.0
9	U238	296K	0.0	0.00016
10	S4149	20C	0.0	0.0
11	U235	296K	0.0	0.43543

AXIAL - S8ER

ANGULAR QUADRATURE CONSTANTS

TABLE IV (cont.)

	COSINE (MU)	WEIGHT	REFL DIRECT	WT. X COS.
1	-1.00000E 00	0	5	0
2	-8.81917E-01	1.66666E-01	5	-1.46986E-01
3	-3.33333E-01	3.33333E-01	4	-1.11111E-01
4	3.33333E-01	3.33333E-01	3	1.11111E-01
5	8.81917E-01	1.66666E-01	2	1.46986E-01

DENSITY TABLE

NUCLIDE	1 HASTN 20C	2 316SS 20C	3 HASTC 20C	4 BE 296K	5 BEO 296K	6 H(ZR) 296K	7 O 20C
MIXTURE							
1 L GRID	5.4980E-02	0.0	8.2354E-01	0.0	0.0	0.0	0.0
2 CAPS	8.8169E-01	0.0	0.0	0.0	0.0	0.0	0.0
3 CORE	8.4050E-02	0.0	0.0	0.0	0.0	4.7084E-02	3.2630E-01
4 U GRID	5.4980E-02	8.6727E-01	0.0	0.0	0.0	0.0	0.0

NUCLIDE	8 ZR(H) 296K	9 U238 296K	10 SM149 20C	11 U235 296K
MIXTURE				
1 L GRID	0.0	0.0	0.0	0.0
2 CAPS	0.0	0.0	0.0	0.0
3 CORE	2.8040E-02	8.1591E-05	3.0100E-07	1.1238E-03
4 U GRID	0.0	0.0	0.0	0.0

SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN*

*EXCEPTION - LAST LEFT LEAKAGE IS RT BNDY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE IV (cont.)

	ZONE 1	ZONE 2	ZONE 3	ZONE 4	ZONE 5	ZONE 6
NO. INTERVALS	2.00000	2.00000	28.00000	1.00000	2.00000	35.00000
ZONE WIDTH	0.79375	1.00076	35.56000	0.20320	0.87312	38.43083
ZONE VOLUME	0.79375	1.00076	35.56000	0.20320	0.87312	38.43083
AVERAGE FLUX	0.08485	0.13860	0.49187	0.12931	0.09581	0.46335
RIGHT RADIUS	0.79375	1.79451	37.35451	37.55771	38.43083	38.43083
RADIAL LEAKAGE	-0.00197	-0.00437	0.08677	-0.00086	-0.00197	0.07760
TRANS LEAKAGE	0.00108	0.00223	0.28139	0.00042	0.00135	0.28648
LEFT LEAKAGE	-0.03698	-0.03896	-0.04332	0.04345	0.04259	0.04062
LEFT L+	0.0	0.00948	0.02368	0.05824	0.05402	0.04062
LEFT L-	0.03698	0.04843	0.06700	0.01479	0.01143	0.0
NU FISSION/ABSN	0.0	0.0	1.67553	0.0	0.0	1.86477
NU FISSION	0.0	0.0	1.05859	0.0	0.0	1.05859
ABSORPTION	0.00089	0.00213	0.63180	0.00044	0.00062	0.63588
FISSION	0.0	0.0	0.43568	0.0	0.0	0.43568

MATL ABSN

1 HASTN 20C	0.00005	0.00213	0.02678	0.00044	0.00007	0.02948
2 316SS 20C	0.0	0.0	0.0	0.0	0.00055	0.00055
3 HASTC 20C	0.00084	0.0	0.0	0.0	0.0	0.00084
4 BE 296K	0.0	0.0	0.0	0.0	0.0	0.0
5 BED 296K	0.0	0.0	0.0	0.0	0.0	0.0
6 H(ZR) 296K	0.0	0.0	0.01054	0.0	0.0	0.01054
7 O 20C	0.0	0.0	0.00000	0.0	0.0	0.00000
8 ZR(H) 296K	0.0	0.0	0.01525	0.0	0.0	0.01525
9 U238 296K	0.0	0.0	0.00957	0.0	0.0	0.00957
10 SMI49 20C	0.0	0.0	0.01391	0.0	0.0	0.01391
11 U235 296K	0.0	0.0	0.55573	0.0	0.0	0.55573

MATL FISSN

1 HASTN 20C	0.0	0.0	0.0	0.0	0.0	0.0
2 316SS 20C	0.0	0.0	0.0	0.0	0.0	0.0
3 HASTC 20C	0.0	0.0	0.0	0.0	0.0	0.0
4 BE 296K	0.0	0.0	0.0	0.0	0.0	0.0
5 BED 296K	0.0	0.0	0.0	0.0	0.0	0.0
6 H(ZR) 296K	0.0	0.0	0.0	0.0	0.0	0.0
7 O 20C	0.0	0.0	0.0	0.0	0.0	0.0
8 ZR(H) 296K	0.0	0.0	0.0	0.0	0.0	0.0
9 U238 296K	0.0	0.0	0.00016	0.0	0.0	0.00016
10 SMI49 20C	0.0	0.0	0.0	0.0	0.0	0.0
11 U235 296K	0.0	0.0	0.43551	0.0	0.0	0.43551

SER- ELEMENTS-A + D SHIMS - RADIAL

ANGULAR QUADRATURE CONSTANTS
COSINE (MU) WEIGHT REFL DIRECT WT. X COS.

TABLE V

1	-4.71404E-01	0	3	0
2	-3.33333E-01	1.66666E-01	3	-5.55553E-02
3	3.33333E-01	1.66666E-01	2	5.55553E-02
4	-9.42809E-01	0	8	0
5	-8.81917E-01	1.66666E-01	8	-1.46996E-01
6	-3.33333E-01	1.66666E-01	7	-5.55553E-02
7	3.33333E-01	1.66666E-01	6	5.55553E-02
8	8.81917E-01	1.66666E-01	5	1.46996E-01

SER WITH LUCITE DUMMIES
AND DIFFERENT SHIMS

DENSITY TABLE

NUCLIDE -->	1	2	3	4	5	6	7
	HASTN 29C	31655 29C	C 29C	BE 296K	BEH 296K	HTZR 296K	D 29C
MIXTURE							
1 CORE	6.4050E-02	0.0	0.0	0.0	0.0	4.7084E-02	3.2630E-06
2 INTERFACE	5.9400E-02	0.0	0.0	0.0	5.1500E-01	0.0	0.0
3 VESSEL+GAP	0.0	4.6860E-01	0.0	0.0	0.0	0.0	0.0
4 REFLECTOR	0.0	0.0	0.0	9.4466E-01	0.0	0.0	0.0
5 LUCITE	0.0	0.0	3.1080E-02	0.0	0.0	4.9730E-02	1.7430E-02
6 A SHIM	0.0	0.0	0.0	9.8736E-01	0.0	0.0	0.0
7 B SHIM	0.0	0.0	0.0	7.6102E-01	0.0	0.0	0.0
8 C SHIM	0.0	0.0	0.0	5.5890E-01	0.0	0.0	0.0

NUCLIDE -->	8	9	10	11
	ZR(H) 296K	U239 296K	SM149 29C	U235 296K
MIXTURE				
1 CORE	2.8040E-02	8.1591E-05	3.0100E-07	1.1238E-03
2 INTERFACE	0.0	0.0	0.0	0.0
3 VESSEL+GAP	0.0	0.0	0.0	0.0
4 REFLECTOR	0.0	0.0	0.0	0.0
5 LUCITE	0.0	0.0	0.0	0.0
6 A SHIM	0.0	0.0	0.0	0.0
7 B SHIM	0.0	0.0	0.0	0.0
8 C SHIM	0.0	0.0	0.0	0.0

Page 22
TL-53-260-001

SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN

*EXCEPTION - LAST LEFT LEAKAGE IS RT BODY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE V (cont.)

	ZONE 1	ZONE 2	ZONE 3	ZONE 4	ZONE 5	ZONE 6
NO. INTERVALS	16.00000	2.00000	2.00000	1.00000	5.00000	2.00000
ZONE WIDTH	9.99820	1.04360	0.67620	0.37680	6.01780	2.00740
ZONE VOLUME	314.04590	68.98096	48.34973	25.15369	549.58301	239.72461
AVERAGE FLUX	0.05021	0.03792	0.03463	0.03307	0.02191	0.01724
RIGHT RADIUS	9.99820	11.04180	11.71800	12.05480	18.07269	20.07339
RADIAL LEAKAGE	0.32758	-0.01781	-0.01240	-0.01772	-0.05062	-0.01074
TRANS LEAKAGE	0.07568	0.01272	0.00814	0.00405	0.06742	0.01193
LEFT LEAKAGE	0.0	0.32757	0.30977	0.29687	0.27914	0.22352
LEFT L+	0.0	0.81038	0.81373	0.80307	0.79710	0.50871
LEFT L-	0.0	0.48230	0.50401	0.50620	0.51796	0.23019
NU FISSION/ABSN	1.68657	0.0	0.0	0.0	0.0	0.0
NU FISSION	1.00447	0.0	0.0	0.0	0.0	0.0
ABSORPTION	0.59557	0.00505	0.00476	0.01363	-0.00975	-0.00101
FISSION	0.41342	0.0	0.0	0.0	0.0	0.0

MATL ABSN

1	HASTN	20C	0.02491	0.0	0.00553	0.0	0.0	0.0
2	316SS	20C	0.0	0.0	0.0	0.01358	0.0	0.0
3	C	20C	0.0	0.00003	0.0	0.0	0.0	0.0
4	BF	296K	0.0	0.0	0.0	0.0	-0.00975	-0.00101
5	BEO	296K	0.0	0.0	-0.00377	0.0	0.0	0.0
6	H(ZR)	296K	0.01006	0.00496	0.0	0.0	0.0	0.0
7	O	20C	0.00000	0.00006	0.0	0.0	0.0	0.0
8	ZR(H)	296K	0.01371	0.0	0.0	0.0	0.0	0.0
9	U238	296K	0.00850	0.0	0.0	0.0	0.0	0.0
10	S4149	20C	0.01379	0.0	0.0	0.0	0.0	0.0
11	U235	296K	0.52459	0.0	0.0	0.0	0.0	0.0

MATL FISSN

1	HASTN	20C	0.0	0.0	0.0	0.0	0.0	0.0
2	316SS	20C	0.0	0.0	0.0	0.0	0.0	0.0
3	C	20C	0.0	0.0	0.0	0.0	0.0	0.0
4	BE	296K	0.0	0.0	0.0	0.0	0.0	0.0
5	BEO	296K	0.0	0.0	0.0	0.0	0.0	0.0
6	H(ZR)	296K	0.0	0.0	0.0	0.0	0.0	0.0
7	O	20C	0.0	0.0	0.0	0.0	0.0	0.0
8	ZR(H)	296K	0.0	0.0	0.0	0.0	0.0	0.0
9	U238	296K	0.00014	0.0	0.0	0.0	0.0	0.0
10	S4149	20C	0.0	0.0	0.0	0.0	0.0	0.0
11	U235	296K	0.41327	0.0	0.0	0.0	0.0	0.0

--- SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN ---
 *EXCEPTED - LAST LEFT LEAKAGE IS RIGHT BODY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE V (cont.)

	ZONE 7	ZONE 8
NO. INTERVALS	2.00000	31.00000
ZONE WIDTH	2.34700	22.42009
ZONE VOLUME	313.31537	1579.15293
AVERAGE FLUX	0.00497	0.02364
RIGHT RADIUS	22.42009	22.42009
RADIAL LEAKAGE	-0.00692	0.21065
TRANS LEAKAGE	0.00758	0.19153
LEFT LEAKAGE	0.21758	0.21065
LEFT L+	0.36208	0.21065
LEFT L-	0.14450	0.00000
NU FISSION/ABSN	0.0	1.65302
NU FISSION	0.0	1.00447
ABSORPTION	-0.00066	0.60766
FISSION	0.0	0.41342

ATL	ABSN		
1	HASTN	20C	0.0
2	316SS	20C	0.03044
3	C	20C	0.01368
4	BE	296K	0.00003
5	BEO	296K	-0.00066
6	H(ZR)	296K	-0.01140
7	O	20C	0.00077
8	ZR(H)	296K	0.01502
9	U238	296K	0.00006
10	SM149	20C	0.01371
11	U235	296K	0.00850
			0.01379
			0.52459

ATL	FISN		
1	HASTN	20C	0.0
2	316SS	20C	0.0
3	C	20C	0.0
4	BE	296K	0.0
5	BEO	296K	0.0
6	H(ZR)	296K	0.0
7	O	20C	0.0
8	ZR(H)	296K	0.0
9	U238	296K	0.0
10	SM149	20C	0.00014
11	U235	296K	0.0
			0.41327

AXIAL - S8ER

ANGULAR QUADRATURE CONSTANTS
COSINE (MU) WEIGHT REFL. DIRECT WT. X COS.

TABLE V (cont.)

1	-1.00000E-00	0	5	0
2	-8.81917E-01	1.66666E-01	5	-1.46996E-01
3	-3.33333E-01	3.33333E-01	4	-1.11111E-01
4	3.33333E-01	3.33333E-01	3	1.11111E-01
5	8.81917E-01	1.66666E-01	2	1.46986E-01

DENSITY TABLE

NUCLIDE -->	1 MASTN 20C	2 316SS 20C	3 MASTC 20C	4 BE 296K	5 BEN 296K	6 HIZR 296K	7 O 20
MIXTURE							
1 L GRID	5.4980E-02	0.0	8.2354E-01	0.0	0.0	0.0	0.0
2 CAPS	8.8169E-01	0.0	0.0	0.0	0.0	0.0	0.0
3 CORE	5.4055E-02	0.0	0.0	0.0	0.0	4.7584E-02	3.2630E-02
4 U GRID	5.4980E-02	8.6727E-01	0.0	0.0	0.0	0.0	0.0
NUCLIDE -->	8 ZR(H) 296K	9 U238 296K	10 SM149 20C	11 U235 296K			
MIXTURE							
1 L GRID	0.0	0.0	0.0	0.0			
2 CAPS	0.0	0.0	0.0	0.0			
3 CORE	2.8040E-02	8.1591E-05	3.0100E-07	1.1238E-03			
4 U GRID	0.0	0.0	0.0	0.0			

ML-63-260-001 Page 25

EXCEPTION - LAST LEFT LEAKAGE IS RT. ASY. LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE V (cont.)

	ZONE 1	ZONE 2	ZONE 3	ZONE 4	ZONE 5	ZONE 6
NO. INTERVALS	16.00000	2.00000	2.00000	1.00000	5.00000	2.00000
ZONE WIDTH	9.99820	1.04360	0.67420	0.33680	6.01780	2.00000
ZONE VOLUME	314.04590	68.98096	49.34973	25.15369	559.58301	239.72461
AVERAGE FLUX	0.05021	0.03792	0.03453	0.03307	0.02181	0.01024
RIGHT RADIUS	9.99820	11.04180	11.71300	12.05480	18.07269	20.07304
RADIAL LEAKAGE	0.32758	-0.01781	-0.01290	-0.01772	-0.05062	-0.01074
TRANS. LEAKAGE	0.07669	0.01272	0.00314	0.00405	0.06562	0.01193
LEFT LEAKAGE	0.0	0.32757	0.30977	0.29687	0.27914	0.22352
LEFT L+	0.0	0.81038	0.81373	0.80307	0.79710	0.50871
LEFT L-	0.0	0.48280	0.50401	0.50620	0.51796	0.23019
NU FISSION/ABSN.	1.68657	0.0	0.0	0.0	0.0	0.0
NU FISSION	1.00447	0.0	0.0	0.0	0.0	0.0
ABSORPTION	0.59557	0.00505	0.00476	0.01363	-0.00975	-0.00100
FISSION	0.41342	0.0	0.0	0.0	0.0	0.0

ATL ABSN

1	HASTN 20C	0.02491	0.0	0.00553	0.0	0.0	0.0
2	316SS 20C	0.0	0.0	0.0	0.01358	0.0	0.0
3	C 20C	0.0	0.00003	0.0	0.0	0.0	0.0
4	BF 296K	0.0	0.0	0.0	0.0	-0.00975	-0.00100
5	BE 296K	0.0	0.0	-0.00077	0.0	0.0	0.0
6	H(ZR) 296K	0.01006	0.00496	0.0	0.0	0.0	0.0
7	D 20C	0.00000	0.00006	0.0	0.0	0.0	0.0
8	ZR(H) 296K	0.01371	0.0	0.0	0.0	0.0	0.0
9	U238 296K	0.00850	0.0	0.0	0.0	0.0	0.0
10	S4149 20C	0.01379	0.0	0.0	0.0	0.0	0.0
11	U235 296K	0.52459	0.0	0.0	0.0	0.0	0.0

ATL FISSN

1	HASTN 20C	0.0	0.0	0.0	0.0	0.0	0.0
2	316SS 20C	0.0	0.0	0.0	0.0	0.0	0.0
3	C 20C	0.0	0.0	0.0	0.0	0.0	0.0
4	BE 296K	0.0	0.0	0.0	0.0	0.0	0.0
5	BE 296K	0.0	0.0	0.0	0.0	0.0	0.0
6	H(ZR) 296K	0.0	0.0	0.0	0.0	0.0	0.0
7	D 20C	0.0	0.0	0.0	0.0	0.0	0.0
8	ZR(H) 296K	0.0	0.0	0.0	0.0	0.0	0.0
9	U238 296K	0.00014	0.0	0.0	0.0	0.0	0.0
10	S4149 20C	0.0	0.0	0.0	0.0	0.0	0.0
11	U235 296K	0.41327	0.0	0.0	0.0	0.0	0.0

PREPARED BY:	ATOMICS INTERNATIONAL A DIVISION OF NORTH AMERICAN ROCKWELL CORPORATION	PAGE NO. 27
CHECKED BY:		TI-653-260-001 REVISION NO.
DATE:	FIGURE 3. SCA-4A MODEL	MODEL NO.

<u>Intervals</u>	<u>Radius (cm)</u>	<u>Intervals</u>	<u>Height (cm)</u>
1 - 12	10.2210	1 - 18	15.5575
13 - 15	11.3487	19 - 21	16.1595
16 - 17	11.5442		
18 - 24	15.1168		
25 - 29	17.7256		
30 - 34	20.3342		

SCA-4A RADIAL 2.25 IN REFLECTOR

ANGULAR QUADRATURE CONSTANTS			
COSINE (MU)	WEIGHT	REFL DIRECT	WT. X COS.
1 -4.71404E-01	0	3	0
2 -3.33333E-01	1.66666E-01	3	-5.55553E-02
3 3.33333E-01	1.66666E-01	2	5.55553E-02
4 -9.42809E-01	0	8	0
5 -8.81917E-01	1.66666E-01	8	-1.46986E-01
6 -3.33333E-01	1.66666E-01	7	-5.55553E-02
7 3.33333E-01	1.66666E-01	6	5.55553E-02
8 8.81917E-01	1.66666E-01	5	1.46986E-01

TABLE VI

DENSITY TABLES AND

NEUTRON BALANCE TABLES

FOR SCA-4A

DENSITY TABLE

NUCLIDE -->	1		2		3		4		5		6		7	
	HASTN	20C	316SS	20C	H(ZR)	296K	BE	296K	O	20C	NA	20C	AL	20C
MIXTURE														
1 CORE	3.1000E-02		0.0		5.4224E-02		0.0		3.9146E-04		7.0192E-05		1.4848E-04	
2 INTERFACE	0.0		0.0		0.0		1.0642E-01		7.7670E-04		0.0		0.0	
3 VESSEL + GAP	0.0		4.1420E-01		0.0		0.0		3.1520E-05		0.0		0.0	
4 REFLECTOR	0.0		0.0		0.0		1.2140E-01		8.8600E-04		0.0		0.0	

NUCLIDE -->	8		9		10		11	
	ZR(H)	296K	U238	296K	SM149	20C	U235	296K
MIXTURE								
1 CORE	2.9472E-02		8.7863E-05		1.7890E-07		1.1882E-03	
2 INTERFACE	0.0		0.0		0.0		0.0	
3 VESSEL + GAP	0.0		0.0		0.0		0.0	
4 REFLECTOR	0.0		0.0		0.0		0.0	

- SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN* - - - -

*EXCEPTION - LAST LEFT LEAKAGE IS RT BNDY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE VI (cont.)

	ZONE 1	ZONE 2	ZONE 3	ZONE 4	ZONE 5	ZONE 6
NO. INTERVALS	12.00000	3.00000	2.00000	7.00000	5.00000	29.00000
ZONE WIDTH	10.22100	1.12770	0.19550	3.57260	2.60879	17.72559
ZONE VOLUME	329.19824	76.41650	14.06042	299.23364	269.16772	987.07568
AVERAGE FLUX	0.04712	0.03069	0.02782	0.01972	0.00821	0.02666
RIGHT RADIUS	10.22100	11.34870	11.54420	15.11680	17.72559	17.72559
RADIAL LEAKAGE	0.29976	-0.01074	-0.00546	-0.03050	-0.01188	0.24117
TRANS LEAKAGE	0.09991	0.01515	0.00253	0.03812	0.01428	0.16998
LEFT LEAKAGE	0.0	0.29976	0.28901	0.28355	0.25304	0.24117
LEFT L+	0.0	0.71276	0.67379	0.67185	0.45842	0.24117
LEFT L-	0.0	0.41300	0.38477	0.38831	0.20538	0.00000
NU FISSION/ABSN	1.74010	0.0	0.0	0.0	0.0	1.77415
NU FISSION	1.04455	0.0	0.0	0.0	0.0	1.04455
ABSORPTION	0.60028	-0.00442	0.00293	-0.00763	-0.00241	0.58875
FISSION	0.42991	0.0	0.0	0.0	0.0	0.42991

MATL ABSN

1	HASTN	20C	0.01187	0.0	0.0	0.0	0.0	0.01187
2	316SS	20C	0.0	0.0	0.00293	0.0	0.0	0.00293
3	H(ZR)	296K	0.01140	0.0	0.0	0.0	0.0	0.01140
4	BE	296K	0.0	-0.00442	0.0	-0.00753	-0.00242	-0.01447
5	O	20C	0.00001	0.00000	0.00000	0.00001	0.00000	0.00003
6	NA	20C	0.00003	0.0	0.0	0.0	0.0	0.00003
7	AL	20C	0.00003	0.0	0.0	0.0	0.0	0.00003
8	ZR(H)	296K	0.01415	0.0	0.0	0.0	0.0	0.01415
9	U238	296K	0.00903	0.0	0.0	0.0	0.0	0.00903
10	S4149	20C	0.00810	0.0	0.0	0.0	0.0	0.00810
11	U235	296K	0.54556	0.0	0.0	0.0	0.0	0.54556

MATL FISSN

1	HASTN	20C	0.0	0.0	0.0	0.0	0.0	0.0
2	316SS	20C	0.0	0.0	0.0	0.0	0.0	0.0
3	H(ZR)	296K	0.0	0.0	0.0	0.0	0.0	0.0
4	BE	296K	0.0	0.0	0.0	0.0	0.0	0.0
5	O	20C	0.0	0.0	0.0	0.0	0.0	0.0
6	NA	20C	0.0	0.0	0.0	0.0	0.0	0.0
7	AL	20C	0.0	0.0	0.0	0.0	0.0	0.0
8	ZR(H)	296K	0.0	0.0	0.0	0.0	0.0	0.0
9	U238	296K	0.00015	0.0	0.0	0.0	0.0	0.00015
10	S4149	20C	0.0	0.0	0.0	0.0	0.0	0.0
11	U235	296K	0.42976	0.0	0.0	0.0	0.0	0.42976

AXIAL - SCA-4A

ANGULAR QUADRATURE CONSTANTS

	COSINE (MJ)	WEIGHT	REFL DIRECT	WT. X COS.
1	-1.00000E 00	0	5	0
2	-8.01917E-01	1.66666E-01	5	-1.46986E-01
3	-3.33333E-01	3.33333E-01	4	-1.11111E-01
4	3.33333E-01	3.33333E-01	3	1.11111E-01
5	8.81917E-01	1.66666E-01	2	1.46986E-01

TABLE VI (cont.)

DENSITY TABLE

NUCLIDE -->	1 HASTN 20C	2 316SS 20C	3 H1Zr 296K	4 0 20C	5 NA 20C	6 AL 20C	7 ZR(H) 296
MIXTURE							
1 CORE	3.1000E-02	0.0	5.4224E-02	3.9146E-04	7.0192E-05	1.4848E-04	2.9472E-
2 GRID PLATE	3.6500E-01	4.2300E-01	0.0	0.0	0.0	0.0	0.0
NUCLIDE -->	8 U238 296K	9 SM149 20C	10 U235 296K				
MIXTURE							
1 CORE	8.7863E-05	1.7890E-07	1.1882E-03				
2 GRID PLATE	0.0	0.0	0.0				

- - - - SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN* - - - -

*EXCEPTION - LAST LEFT LEAKAGE IS RT BNDY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE VI (cont.)

	ZONE 1	ZONE 2	ZONE 3
NO. INTERVALS	18.00000	3.00000	21.00000
ZONE WIDTH	15.55750	0.60198	16.15948
ZONE VOLUME	15.55750	0.60198	16.15948
AVERAGE FLUX	0.99409	0.21027	0.96489
RIGHT RADIUS	15.55750	16.15948	16.15948
RADIAL LEAKAGE	0.09993	-0.00370	0.09623
TRANS LEAKAGE	0.29975	0.00245	0.30221
LEFT LEAKAGE	0.0	0.09993	0.09623
LEFT L+	0.35450	0.11895	0.09623
LEFT L-	0.35450	0.01902	0.0
NU FISSION/ABSN	1.74010	0.0	1.73651
NU FISSION	1.04455	0.0	1.04455
ABSORPTION	0.60028	0.00124	0.60152
FISSION	0.42991	0.0	0.42991

ATL ABSN

1	HASTN 20C	0.01187	0.00080	0.01268
2	316SS 20C	0.0	0.00044	0.00044
3	H(ZR) 296K	0.01140	0.0	0.01140
4	O 20C	0.00001	0.0	0.00001
5	NA 20C	0.00003	0.0	0.00003
6	AL 20C	0.00003	0.0	0.00003
7	ZR(H) 296K	0.01415	0.0	0.01415
8	U238 296K	0.00903	0.0	0.00903
9	54149 20C	0.00810	0.0	0.00810
10	U235 296K	0.54565	0.0	0.54565

ATL FISSN

1	HASTN 20C	0.0	0.0	0.0
2	316SS 20C	0.0	0.0	0.0
3	H(ZR) 296K	0.0	0.0	0.0
4	O 20C	0.0	0.0	0.0
5	NA 20C	0.0	0.0	0.0
6	AL 20C	0.0	0.0	0.0
7	ZR(H) 296K	0.0	0.0	0.0
8	U238 296K	0.00015	0.0	0.00015
9	54149 20C	0.0	0.0	0.0
10	U235 296K	0.42975	0.0	0.42975

PREPARED BY:	ATOMICS INTERNATIONAL A DIVISION OF NORTH AMERICAN ROCKWELL CORPORATION	PAGE NO. 32 OF
CHECKED BY:		TI-653-260-001
DATE:	FIGURE 4. SCA-48 MODEL	REVISION NO.

SEER FUEL CELL--WATER FLOODED - SCA-4B

ANGULAR QUADRATURE CONSTANTS

	COSINE (MU)	WEIGHT	REFL DIRECT	WT. X COS.
1	-4.71404E-01	0	3	0
2	-3.33333E-01	1.66666E-01	3	-5.55553E-02
3	3.33333E-01	1.66666E-01	2	5.55553E-02
4	-9.42809E-01	0	8	0
5	-8.81917E-01	1.66666E-01	8	-1.46986E-01
6	-3.33333E-01	1.65666E-01	7	-5.55553E-02
7	3.33333E-01	1.65666E-01	6	5.55553E-02
8	8.81917E-01	1.66666E-01	5	1.46986E-01

TABLE VII

DENSITY TABLE AND

NEUTRON BALANCE TABLE

FOR SCA-4B FUEL CELL

ZONE	SUBREGION	REGION
1	0	0
2	0	0
3	0	0
4	0	0

DENSITY TABLE

NJCLIDE	-->	1	2	3	4	5	6	7							
		H2O	20C	HASTN	20C	H(ZR)	296K	0	20C	ZR(H)	296K	U238	296K	SM149	20C

MIXTURE															
1 FUEL		0.0		0.0		5.9600E-02		0.0		3.5494E-02		1.0328E-04		0.0	
2 SM OXIDE		0.0		0.0		0.0		1.3233E-04		0.0		0.0		1.2210E-01	
3 WATER		3.3400E-02		0.0		0.0		0.0		0.0		0.0		0.0	

NUCLIDE	-->	8
		U235 296K

MIXTURE		
1 FUEL		1.4225E-03
2 SM OXIDE		0.0
3 WATER		0.0

11-61-660-001 Page 33

SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN

*EXCEPTION - LAST LEFT LEAKAGE IS RT BNDY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE VII (cont.)

	ZONE 1	ZONE 2	ZONE 3	ZONE 4	ZONE 5
NO. INTERVALS	14.00000	3.00000	3.00000	5.00000	25.00000
ZONE WIDTH	0.67564	0.01158	0.02642	0.04341	0.76015
ZONE VOLUME	1.43410	0.05003	0.11627	0.21488	1.81528
AVERAGE FLUX	12.92210	12.91298	12.91388	12.91959	12.92102
RIGHT RADIUS	0.67564	0.68732	0.71374	0.76015	0.76015
RADIAL LEAKAGE	0.06360	-0.02681	-0.04134	-0.00357	-0.00812
TRANS LEAKAGE	0.0	0.0	0.0	0.0	0.0
LEFT LEAKAGE	0.0	0.06362	0.03679	-0.00455	-0.00812
LEFT L+	0.0	14.18870	14.41915	14.95455	15.92886
LEFT L-	0.0	14.12507	14.38235	14.95911	15.93697
NU FISSION/ABSN	1.81238	0.0	0.0	0.0	1.58351
NU FISSION	1.59622	0.0	0.0	0.0	1.69622
ABSORPTION	0.93591	0.02672	0.04171	0.00321	1.00755
FISSION	0.69833	0.0	0.0	0.0	0.69833

MATL ABSN

1 H2O 20C	0.0	0.0	0.0	0.00321	0.00321
2 HASTN 20C	0.0	0.0	0.04171	0.0	0.04171
3 H(ZR) 296K	0.01721	0.0	0.0	0.0	0.01721
4 G 20C	0.0	0.00000	0.0	0.0	0.00000
5 ZR(H) 296K	0.02136	0.0	0.0	0.0	0.02136
6 U238 296K	0.01373	0.0	0.0	0.0	0.01373
7 SM149 20C	0.0	0.02672	0.0	0.0	0.02672
8 U235 296K	0.88360	0.0	0.0	0.0	0.88360

MATL FISSN

1 H2O 20C	0.0	0.0	0.0	0.0	0.0
2 HASTN 20C	0.0	0.0	0.0	0.0	0.0
3 H(ZR) 296K	0.0	0.0	0.0	0.0	0.0
4 G 20C	0.0	0.0	0.0	0.0	0.0
5 ZR(H) 296K	0.0	0.0	0.0	0.0	0.0
6 U238 296K	0.00021	0.0	0.0	0.0	0.00021
7 SM149 20C	0.0	0.0	0.0	0.0	0.0
8 U235 296K	0.69812	0.0	0.0	0.0	0.69812

SCA-40--SOLER-WATER FLOODED-NO POISON SPLINES - RADIAL

ANGULAR QUADRATURE CONSTANTS
COSINE (MU) WEIGHT REFL DIRECT WT. X COS.

TABLE VIII

DENSITY TABLES AND

NEUTRON BALANCE TABLES

FOR SCA-43 WITHOUT

POISON SPLINES

ONE	SUBREGION	REGION
1	0	0
2	0	0
3	0	0
4	0	0

DENSITY TABLE

NUCLIDE -->	1	2	3	4	5	6	7
	H2O	HASTN	HZR	O-PP	ZR	U238	SM149-PP
MIXTURE							
1 CORE	3.3400E-02	1.0000E 00	5.9500E-02	1.3233E-04	3.5494E-02	1.0328E-04	1.2210E-05
2 INTERFACE	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3 AL VESSEL	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4 WATER	0.0	0.0	0.0	0.0	0.0	0.0	0.0

NUCLIDE -->	8	9	10	11	12
	U235	H2O 20C	HASTN 20C	BE3 296K	AL 20C
MIXTURE					
1 CORE	1.4225E-03	0.0	0.0	0.0	0.0
2 INTERFACE	0.0	1.4215E-02	5.9400E-02	5.1500E-01	0.0
3 AL VESSEL	0.0	0.0	0.0	0.0	6.0300E-02
4 WATER	0.0	3.3400E-02	0.0	0.0	0.0

SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN -
 *EXCEPTION - LAST LEFT LEAKAGE IS RT BODY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE VIII (cont.)

	ZONE 1	ZONE 2	ZONE 3	ZONE 4	ZONE 5
NO. INTERVALS	16.00000	3.00000	1.00000	23.00000	43.00000
ZONE WIDTH	11.04100	0.67620	0.09130	23.12569	34.92499
ZONE VOLUME	303.02661	48.34973	6.00659	3394.58643	3831.96977
AVERAGE FLUX	0.03749	0.02500	0.02388	0.00508	0.00850
RIG-IT RADIUS	11.04100	11.71800	11.79930	34.92499	34.92499
RADIAL LEAKAGE	0.31198	-0.01253	-0.00115	-0.28345	0.01435
TRANS LEAKAGE	0.06343	0.09534	0.00063	0.07614	0.14554
LEFT LEAKAGE	0.0	0.31198	0.29945	0.29830	0.01495
LEFT L+	0.0	0.62716	0.61985	0.61926	0.01495
LEFT L-	0.0	0.31518	0.32040	0.31996	0.00000
NU FISSION/ABSN	1.69949	0.0	0.0	0.0	1.26470
NU FISSION	1.06144	0.0	0.0	0.0	1.06144
ABSORPTION	0.62456	0.00719	0.00051	0.20701	0.83928
FISSION	0.43697	0.0	0.0	0.0	0.43697

1ATL ABSN

1 H2O	0.00201	0.0	0.0	0.0	0.00201
2 HASTN	0.02548	0.0	0.0	0.0	0.02548
3 H2R	0.01075	0.0	0.0	0.0	0.01075
4 O-PP	0.00000	0.0	0.0	0.0	0.00000
5 ZR	0.01275	0.0	0.0	0.0	0.01275
6 U238	0.00769	0.0	0.0	0.0	0.00769
7 SM149-PP	0.01737	0.0	0.0	0.0	0.01737
8 U235	0.54851	0.0	0.0	0.0	0.54851
9 H2O 20C	0.0	0.00000	0.0	0.20701	0.20922
10 HASTN 20C	0.0	0.00000	0.0	0.0	0.00572
11 BED 296K	0.0	0.00000	0.0	0.0	-0.00074
12 AL 20C	0.0	0.0	0.00001	0.0	0.00051

1ATL FLSN

1 H2O	0.0	0.0	0.0	0.0	0.0
2 HASTN	0.0	0.0	0.0	0.0	0.0
3 H2R	0.0	0.0	0.0	0.0	0.0
4 O-PP	0.0	0.0	0.0	0.0	0.0
5 ZR	0.0	0.0	0.0	0.0	0.0
6 U238	0.00013	0.0	0.0	0.0	0.00013
7 SM149-PP	0.0	0.0	0.0	0.0	0.0
8 J235	0.43683	0.0	0.0	0.0	0.43683
9 H2O 20C	0.0	0.0	0.0	0.0	0.0
10 HASTN 20C	0.0	0.0	0.0	0.0	0.0
11 BED 296K	0.0	0.0	0.0	0.0	0.0
12 AL 20C	0.0	0.0	0.0	0.0	0.0

AXIAL - SCA-43

ANGULAR QUADRATURE CONSTANTS

	COSINE (MU)	WEIGHT	REFL DIRECT	WT. X COS.
1	-1.00000E 00	0	5	0
2	-8.31917E-01	1.65666E-01	5	-1.46986E-01
3	-3.33333E-01	3.33333E-01	4	-1.11111E-01
4	3.33333E-01	3.33333E-01	3	1.11111E-01
5	8.81917E-01	1.65655E-01	2	1.46986E-01

TABLE VIII (cont.)

ZONE	SUBREGION	REGION
1	0	0
2	0	0
3	0	0
4	0	0
5	0	0
6	0	0
7	0	0
8	0	0
9	0	0
10	0	0
11	0	0

DENSITY TABLE

NUCLIDE -->	1 H2O	2 HASTN	3 HZR	4 O-PP	5 ZR	6 U238	7 SV149-PP
MIXTURE							
1 CORE	3.3400E-02	1.0000E 00	5.7600E-02	1.3233E-04	3.5494E-02	1.0328E-04	1.2210E-05
2 END CAPS	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3 GRID PLATE	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4 AL VESSEL	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5 WATER	0.0	0.0	0.0	0.0	0.0	0.0	0.0

NUCLIDE -->	8 J235	9 H2O	10 HASTN	11 J165S	12 AL
MIXTURE					
1 CORE	1.4225E-03	0.0	0.0	0.0	0.0
2 END CAPS	0.0	3.9516E-03	8.8167E-01	0.0	0.0
3 GRID PLATE	0.0	2.5967E-03	5.4780E-02	8.6727E-01	0.0
4 AL VESSEL	0.0	0.0	0.0	0.0	6.0300E-02
5 WATER	0.0	3.3400E-02	0.0	0.0	0.0

41-653-660-001 Page 37

*EXCEPTION - LAST LEFT LEAKAGE IS RT BODY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE VIII (cont.)

	ZONE 1	ZONE 2	ZONE 3	ZONE 4	ZONE 5	ZONE 6
NO. INTERVALS	15.00000	1.00000	1.00000	2.00000	3.00000	28.00000
ZONE WIDTH	20.31999	0.63499	0.11049	0.63501	1.00076	35.56000
ZONE VOLUME	20.31999	0.63499	0.11049	0.63501	1.00076	35.56000
AVERAGE FLUX	0.03003	0.09902	0.10286	0.10877	0.13412	0.40379
RIGHT RADIUS	20.31999	20.95499	21.06548	21.70349	22.70125	58.26125
RADIAL LEAKAGE	-0.01873	-0.00150	-0.00028	-0.00327	-0.00649	0.05331
TRANS LEAKAGE	0.01326	0.00137	0.00025	0.00150	0.00292	0.31201
LEFT LEAKAGE	-0.00067	-0.01940	-0.02091	-0.02119	-0.02445	-0.03076
LEFT L+	0.0	0.01616	0.01731	0.01719	0.01874	0.02539
LEFT L-	0.00067	0.03556	0.03921	0.03837	0.04370	0.05634
NU FISSION/ABSN	0.0	0.0	0.0	0.0	0.0	1.69949
NU FISSION	0.0	0.0	0.0	0.0	0.0	1.06163
ABSORPTION	0.00545	0.00014	0.00003	0.00177	0.00358	0.62467
FISSION	0.0	0.0	0.0	0.0	0.0	0.43705

MATL ABSN

1 H2O	0.0	0.0	0.0	0.0	0.0	0.00201
2 HASTN	0.0	0.0	0.0	0.0	0.0	0.02548
3 HZR	0.0	0.0	0.0	0.0	0.0	0.01075
4 O-PP	0.0	0.0	0.0	0.0	0.0	0.00000
5 ZR	0.0	0.0	0.0	0.0	0.0	0.01275
6 J238	0.0	0.0	0.0	0.0	0.0	0.00769
7 SM149-PP	0.0	0.0	0.0	0.0	0.0	0.01738
8 U235	0.0	0.0	0.0	0.0	0.0	0.54860
9 H2O 20C	0.00545	0.0	0.00003	0.00001	0.00002	0.0
10 HASTN 20C	0.0	0.0	0.0	0.00016	0.00356	0.0
11 316SS 20C	0.0	0.0	0.0	0.00150	0.0	0.0
12 AL 20C	0.0	0.00014	0.0	0.0	0.0	0.0

MATL FISSN

1 H2O	0.0	0.0	0.0	0.0	0.0	0.0
2 HASTN	0.0	0.0	0.0	0.0	0.0	0.0
3 HZR	0.0	0.0	0.0	0.0	0.0	0.0
4 O-PP	0.0	0.0	0.0	0.0	0.0	0.0
5 ZR	0.0	0.0	0.0	0.0	0.0	0.0
6 U238	0.0	0.0	0.0	0.0	0.0	0.00013
7 SM149-PP	0.0	0.0	0.0	0.0	0.0	0.0
8 U235	0.0	0.0	0.0	0.0	0.0	0.43591
9 H2O 20C	0.0	0.0	0.0	0.0	0.0	0.0
10 HASTN 20C	0.0	0.0	0.0	0.0	0.0	0.0
11 316SS 20C	0.0	0.0	0.0	0.0	0.0	0.0

*EXCEPTION - LAST LEFT LEAKAGE IS RT BODY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE VIII (cont.)

	ZONE 7	ZONE 8	ZONE 9	ZONE 10	ZONE 11	ZONE 12
NO. INTERVALS	1.00000	2.00000	2.00000	1.00000	13.00000	70.00000
ZONE WIDTH	0.20320	0.63499	0.74930	0.63501	16.50929	76.99374
ZONE VOLUME	0.20320	0.63499	0.74930	0.63501	16.50999	76.99374
AVERAGE FLUX	0.15276	0.13876	0.12886	0.12100	0.04001	0.21040
RIGHT RADIUS	58.46445	59.09944	59.84874	60.48375	76.99374	76.99374
RADIAL LEAKAGE	-0.00170	-0.00432	-0.00249	-0.00193	-0.02056	0.00203
TRANS LEAKAGE	0.00067	0.00191	0.00210	0.00167	0.01435	0.35201
LEFT LEAKAGE	0.03235	0.03065	0.02633	0.02384	0.02191	0.00135
LEFT L+	0.05753	0.05445	0.04806	0.04551	0.04248	0.00135
LEFT L-	0.02517	0.02380	0.02173	0.02167	0.02057	0.0
NU FISSION/ABSN	0.0	0.0	0.0	0.0	0.0	1.64361
NU FISSION	0.0	0.0	0.0	0.0	0.0	1.06163
ABSORPTION	0.00103	0.00241	0.00039	0.00026	0.00618	0.64591
FISSION	0.0	0.0	0.0	0.0	0.0	0.43705
MATL ABSN						
1 H2O	0.0	0.0	0.0	0.0	0.0	0.00201
2 HASTN	0.0	0.0	0.0	0.0	0.0	0.02548
3 HZR	0.0	0.0	0.0	0.0	0.0	0.01075
4 O-PP	0.0	0.0	0.0	0.0	0.0	0.00000
5 ZR	0.0	0.0	0.0	0.0	0.0	0.01275
6 U238	0.0	0.0	0.0	0.0	0.0	0.00769
7 SM149-PP	0.0	0.0	0.0	0.0	0.0	0.01738
8 U235	0.0	0.0	0.0	0.0	0.0	0.54860
9 H2O 20C	0.00001	0.00002	0.00039	0.0	0.00618	0.01211
10 HASTN 20C	0.00102	0.00022	0.0	0.0	0.0	0.00495
11 316SS 20C	0.0	0.00217	0.0	0.0	0.0	0.00377
12 AL 20C	0.0	0.0	0.0	0.00026	0.0	0.00040
MATL FISSN						
1 H2O	0.0	0.0	0.0	0.0	0.0	0.0
2 HASTN	0.0	0.0	0.0	0.0	0.0	0.0
3 HZR	0.0	0.0	0.0	0.0	0.0	0.0
4 O-PP	0.0	0.0	0.0	0.0	0.0	0.0
5 ZR	0.0	0.0	0.0	0.0	0.0	0.0
6 U238	0.0	0.0	0.0	0.0	0.0	0.00013
7 SM149-PP	0.0	0.0	0.0	0.0	0.0	0.0
8 U235	0.0	0.0	0.0	0.0	0.0	0.43691
9 H2O 20C	0.0	0.0	0.0	0.0	0.0	0.0
10 HASTN 20C	0.0	0.0	0.0	0.0	0.0	0.0
11 316SS 20C	0.0	0.0	0.0	0.0	0.0	0.0
12 AL 20C	0.0	0.0	0.0	0.0	0.0	0.0

SCALE POISON SPLINE CELL--WATER FLOODED--SCA-4B

ANGULAR QUADATURE CONSTANTS

COSINE (MU)	HEIGHT	REFL. DIRECT	WT. X COS.
1 -4.71404E-01	0	3	0
2 -3.33333E-01	1.66666E-01	3	-5.55553E-02
3 -3.33333E-01	1.55555E-01	2	5.55553E-02
4 -9.42809E-01	0	8	0
5 -3.91917E-01	1.66666E-01	8	-1.46986E-01
6 -3.33333E-01	1.55665E-01	7	-5.55553E-02
7 3.33333E-01	1.66666E-01	6	5.55553E-02
8 9.31917E-01	1.66666E-01	5	1.46986E-01

TABLE IV

DENSITY TABLE AND

NEUTRON BALANCE TABLE

FOR SCA-4B POISON

ZONE	SUBREGION	REGION
1	0	0
2	0	0

SPLINE CELL

DENSITY TABLE

NUCLIDE	-->	1	2	3	4	5	6	7
		H2O	HASTN	HZR	O	ZR	U238	SM149
MIXTURE								
1 POISON		0.0	0.0	0.0	0.0	0.0	0.0	0.0
2 FUEL CELLS		3.2350E-02	1.0000E-00	5.9500E-02	1.1233E-04	3.5494E-02	1.0728E-04	1.2210E-05
NUCLIDE	-->	8	9	10	11			
		U235	O	20C	SM149	20C	GD	20C
MIXTURE								
1 POISON		0.0	1.3197E-02	6.2302E-04	4.2967E-03			
2 FUEL CELLS		1.4225E-03	0.0	0.0	0.0			

SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN* - - - -
 *EXCEPTION - LAST LEFT LEAKAGE IS RT BNDY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE IX (cont.)

	ZONE 1	ZONE 2	ZONE 3
NO. INTERVALS	8.00000	12.00000	20.00000
ZONE WIDTH	0.07937	1.22189	1.30127
ZONE VOLUME	0.01979	5.29987	5.31966
AVERAGE FLUX	4.15301	4.40921	4.40825
RIGHT RADIUS	0.07937	1.30127	1.30127
RADIAL LEAKAGE	-0.03585	0.03201	-0.00384
TRANS LEAKAGE	0.0	0.0	0.0
LEFT LEAKAGE	0.0	-0.03585	-0.00384
LEFT L+	0.0	0.52896	9.31752
LEFT L-	0.0	0.55482	9.32136
NU FISSION/ABSN	0.0	1.67815	1.61821
NU FISSION	0.0	1.62403	1.62403
ABSORPTION	0.03585	0.96775	1.00360
FISSION	0.0	0.66857	0.66857

1ATL ABSN

1 H2O	0.0	0.00297	0.00297
2 FASTN	0.0	0.04044	0.04044
3 H2R	0.0	0.01642	0.01642
4 O	0.0	0.00000	0.00000
5 ZR	0.0	0.02110	0.02110
6 U233	0.0	0.01366	0.01366
7 SM149	0.0	0.02492	0.02492
8 U235	0.0	0.04824	0.04824
9 O 20C	0.00000	0.0	0.00000
10 SM149 20C	0.01616	0.0	0.01616
11 O 20C	0.01958	0.0	0.01958

1ATL FISSN

1 H2O	0.0	0.0	0.0
2 FASTN	0.0	0.0	0.0
3 H2R	0.0	0.0	0.0
4 O	0.0	0.0	0.0
5 ZR	0.0	0.0	0.0
6 U233	0.0	0.00021	0.00021
7 SM149	0.0	0.0	0.0
8 U235	0.0	0.66835	0.66835
9 O 20C	0.0	0.0	0.0
10 SM149 20C	0.0	0.0	0.0
11 O 20C	0.0	0.0	0.0

SCA-43--S9ER-WATER FLOODED-72 POISON SPLINES - RADIAL

ANGULAR QUADATURE CONSTANTS
COSINE (MU) WEIGHT REFL DIRECT WT. X COS.

1	-4.71404E-01	0	3	0
2	-3.33333E-01	1.66666E-01	3	-5.55553E-02
3	3.33333E-01	1.66666E-01	2	5.55553E-02
4	-9.42809E-01	0	8	0
5	-9.91917E-01	1.66666E-01	8	-1.46986E-01
6	-3.33333E-01	1.66666E-01	7	-5.55553E-02
7	3.33333E-01	1.66666E-01	6	5.55553E-02
8	8.91917E-01	1.66666E-01	5	1.46986E-01

TABLE X

DENSITY TABLES AND

NEUTRON BALANCE TABLES

FOR SCA-43 WITH 72

ZONE	SUBREGION	REGION
1	0	0
2	0	0
3	0	0
4	0	0

POISON SPLINES

DENSITY TABLE

NUCLIDE	-->	1	2	3	4	5	6	7
		420	HASTN	HZR	O-PP	2R	U238	SM149-PP
MIXTURE								
1 CORE		3.2350E-02	1.0000E-00	5.9600E-02	1.3233E-04	3.5644E-02	1.0328E-04	1.2210E-05
2 INTERFACE		0.0	0.0	0.0	0.0	0.0	0.0	0.0
3 AL VESSEL		0.0	0.0	0.0	0.0	0.0	0.0	0.0
4 WATER		0.0	0.0	0.0	0.0	0.0	0.0	0.0
NUCLIDE	-->	8	9	10	11	12	13	14
		U235	0	SM149	GO	H2O	20C	HASTN 20C
								BE0 296K
MIXTURE								
1 CORE		1.4225E-03	1.3197E-02	5.2302E-04	4.2957E-03	0.0	0.0	0.0
2 INTERFACE		0.0	0.0	0.0	0.0	1.4215E-02	5.9400E-02	5.1500E-01
3 AL VESSEL		0.0	0.0	0.0	0.0	0.0	0.0	0.0
4 WATER		0.0	0.0	0.0	0.0	3.3400E-02	0.0	0.0
NUCLIDE	-->	15						
		AL	20C					
MIXTURE								
1 CORE		0.0						
2 INTERFACE		0.0						
3 AL VESSEL		6.0300E-02						

1-63-260-001
Page 12

SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN*

*EXCEPTION - LAST LEFT LEAKAGE IS RT BNDY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE X (cont.)

	ZONE 1	ZONE 2	ZONE 3	ZONE 4	ZONE 5
NO. INTERVALS	16.00000	3.00000	1.00000	23.00000	43.00000
ZONE WIDTH	11.04130	0.67620	0.08130	23.12569	34.92499
ZONE VOLUME	333.02561	48.34973	5.00659	3394.58643	3831.96899
AVERAGE FLUX	0.03743	0.02505	0.02392	0.00510	0.00861
RIGHT RADIUS	11.04130	11.71800	11.79930	34.92499	34.92499
RADIAL LEAKAGE	0.31336	-0.01249	-0.00115	-0.28480	0.01492
TRANS LEAKAGE	0.06373	0.00538	0.00064	0.07692	0.14668
LEFT LEAKAGE	0.0	0.31335	0.30086	0.29971	0.01492
LEFT L+	0.0	0.62854	0.62137	0.61975	0.01492
LEFT L-	0.0	0.31513	0.32050	0.32003	0.00000
NU FISSION/ABSN	1.63448	0.0	0.0	0.0	1.21477
NU FISSION	1.01804	0.0	0.0	0.0	1.01804
A45ORPTION	0.62235	0.00711	0.00051	0.20758	0.83305
FISSION	0.41908	0.0	0.0	0.0	0.41908

MATL ABSN

1 H2O	0.00137	0.0	0.0	0.0	0.00187
2 HASTY	0.02470	0.0	0.0	0.0	0.02470
3 H2R	0.01027	0.0	0.0	0.0	0.01027
4 O-PP	0.00000	0.0	0.0	0.0	0.00000
5 ZR	0.01258	0.0	0.0	0.0	0.01258
6 J238	0.00764	0.0	0.0	0.0	0.00764
7 SM149-PP	0.01631	0.0	0.0	0.0	0.01631
8 J235	0.52724	0.0	0.0	0.0	0.52724
9 O	0.00000	0.0	0.0	0.0	0.00000
10 SM149	0.00979	0.0	0.0	0.0	0.00979
11 GO	0.01245	0.0	0.0	0.0	0.01245
12 H2O 20C	0.0	0.00219	0.0	0.20758	0.20977
13 HASTY 20C	0.0	0.00566	0.0	0.0	0.00566
14 HED 295K	0.0	-0.00075	0.0	0.0	-0.00075
15 AL 20C	0.0	0.0	0.00051	0.0	0.00051

ATL

TABLE I (cont.)

1 H2D	0.0	0.0	0.0	0.0	0.0
2 HASTN	0.0	0.0	0.0	0.0	0.0
3 HZR	0.0	0.0	0.0	0.0	0.0
4 J-PP	0.0	0.0	0.0	0.0	0.0
5 ZR	0.0	0.0	0.0	0.0	0.0
6 U238	0.00013	0.0	0.0	0.0	0.00013
7 S4149-PP	0.0	0.0	0.0	0.0	0.0
8 U235	0.41894	0.0	0.0	0.0	0.41894
9 J	0.0	0.0	0.0	0.0	0.0
10 S4149	0.0	0.0	0.0	0.0	0.0
11 GO	0.0	0.0	0.0	0.0	0.0
12 H2D 20C	0.0	0.0	0.0	0.0	0.0
13 HASTN 20C	0.0	0.0	0.0	0.0	0.0
14 BEO 296K	0.0	0.0	0.0	0.0	0.0
15 AL 20C	0.0	0.0	0.0	0.0	0.0

AXIAL - SCA-4B

ANGULAR QUADRATURE CONSTANTS

	COSINE (MU)	WEIGHT	REFL DIRECT	WT. X COS.
1	-1.00000E 00	0	5	0
2	-8.81917E-01	1.65666E-01	5	-1.46986E-01
3	-3.33333E-01	3.33333E-01	4	-1.11111E-01
4	3.33333E-01	3.33333E-01	3	1.11111E-01
5	8.81917E-01	1.65666E-01	2	1.46986E-01

TABLE X (cont.)

DENSITY TABLE

NUCLIDE -->	1 H2O	2 HASTN	3 H2R	4 O-PP	5 ZR	6 U235	7 S4149-PP
MIXTURE							
1 CORE	3.2350E-02	1.0000E 00	5.9600E-02	1.3233E-04	3.5494E-02	1.3328E-04	1.2210E-05
2 END CAPS	0.0	0.0	0.0	0.0	0.0	0.0	0.0
3 GRID PLATE	0.0	0.0	0.0	0.0	0.0	0.0	0.0
4 AL VESSEL	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5 WATER	0.0	0.0	0.0	0.0	0.0	0.0	0.0

NUCLIDE -->	8 U235	9 O	10 S4149	11 GJ	12 H2O 20C	13 HASTN 20C	14 S1655 20C
MIXTURE							
1 CORE	1.4225E-03	1.3197E-02	6.2302E-04	4.2967E-03	0.0	0.0	0.0
2 END CAPS	0.0	0.0	0.0	0.0	3.9516E-03	8.8169E-01	0.0
3 GRID PLATE	0.0	0.0	0.0	0.0	2.5969E-03	5.4980E-02	3.6727E-01
4 AL VESSEL	0.0	0.0	0.0	0.0	0.0	0.0	0.0
5 WATER	0.0	0.0	0.0	0.0	3.3400E-02	0.0	0.0

NUCLIDE -->	15 AL 20C
MIXTURE	
1 CORE	0.0
2 END CAPS	0.0
3 GRID PLATE	0.0
4 AL VESSEL	6.0300E-02
5 WATER	0.0

- - - - SUMMARY BY ZONE, INCLUDING SUMMARY FOR ALL ZONES IN LAST COLUMN* - - - -
 *EXCEPTION - LAST LEFT LEAKAGE IS RT BODY LEAKAGE

THE REACTION RATES HAVE BEEN DIVIDED BY XNF

TABLE X (cont.)

	ZONE 1	ZONE 2	ZONE 3	ZONE 4	ZONE 5	ZONE 6
NO. INTERVALS	16.00000	1.00000	1.00000	2.00000	3.00000	23.00000
ZONE WIDTH	20.31999	0.63499	0.11049	0.63501	1.00076	35.56000
ZONE VOLUME	20.31999	0.63499	0.11049	0.63501	1.00076	35.56000
AVERAGE FLUX	0.03012	0.00945	0.10333	0.10729	0.13472	0.40319
RIGHT RADIIUS	20.31999	20.95499	21.06549	21.70049	22.70125	59.26125
RADIAL LEAKAGE	-0.01335	-0.00152	-0.00028	-0.00328	-0.00649	0.06353
TRANS LEAKAGE	0.01338	0.00138	0.00025	0.00152	0.00295	0.31338
LEFT LEAKAGE	-0.00060	-0.01953	-0.02105	-0.02133	-0.02461	-0.03110
LEFT L+	0.0	0.01620	0.01736	0.01724	0.01881	0.02547
LEFT L-	0.00058	0.03573	0.03841	0.03857	0.04342	0.05657
NU FISSION/ABSN	0.0	0.0	0.0	0.0	0.0	1.63449
NU FISSION	0.0	0.0	0.0	0.0	0.0	1.01323
ABSORPTION	0.00546	0.00014	0.00003	0.00177	0.00354	0.62209
FISSION	0.0	0.0	0.0	0.0	0.0	0.41918
MATL	ABSN					
1 H2O	0.0	0.0	0.0	0.0	0.0	0.00187
2 HASTN	0.0	0.0	0.0	0.0	0.0	0.02471
3 H2R	0.0	0.0	0.0	0.0	0.0	0.01029
4 O-PP	0.0	0.0	0.0	0.0	0.0	0.00000
5 ZR	0.0	0.0	0.0	0.0	0.0	0.01258
6 J238	0.0	0.0	0.0	0.0	0.0	0.00764
7 S149-PP	0.0	0.0	0.0	0.0	0.0	0.01531
8 U235	0.0	0.0	0.0	0.0	0.0	0.52735
9 J	0.0	0.0	0.0	0.0	0.0	0.00000
10 S149	0.0	0.0	0.0	0.0	0.0	0.00780
11 GO	0.0	0.0	0.0	0.0	0.0	0.01243
12 H2O 20C	0.00546	0.0	0.00003	0.00001	0.00002	0.0
13 HASTN 20C	0.0	0.0	0.0	0.00016	0.00352	0.0
14 B16SS 20C	0.0	0.0	0.0	0.00159	0.0	0.0
15 AL 20C	0.0	0.00014	0.0	0.0	0.0	0.0

TABLE

TABLE X (cont.)

1 H2O	0.0	0.0	0.0	0.0	0.0	0.0
2 HASTIN	0.0	0.0	0.0	0.0	0.0	0.0
3 H2R	0.0	0.0	0.0	0.0	0.0	0.0
4 O-PP	0.0	0.0	0.0	0.0	0.0	0.0
5 ZR	0.0	0.0	0.0	0.0	0.0	0.0
6 J233	0.0	0.0	0.0	0.0	0.0	0.0
7 S1149-PP	0.0	0.0	0.0	0.0	0.0	0.00013
8 U235	0.0	0.0	0.0	0.0	0.0	0.0
9 O	0.0	0.0	0.0	0.0	0.0	0.41233
10 S1149	0.0	0.0	0.0	0.0	0.0	0.0
11 GO	0.0	0.0	0.0	0.0	0.0	0.0
12 H2O 20C	0.0	0.0	0.0	0.0	0.0	0.0
13 HASTIN 20C	0.0	0.0	0.0	0.0	0.0	0.0
14 316SS 20C	0.0	0.0	0.0	0.0	0.0	0.0
15 AL 20C	0.0	0.0	0.0	0.0	0.0	0.0

Atomics International
North American Rockwell

NO. . TI-653-260-001
PAGE . 48

References

1. TR-568-24-001, L. D. Felten, "Fuel Loading Test (S8DR Nuclear Testing- TP-568-19-001)," September 20, 1968.
2. TR-568-24-002, L. D. Felten, "Vault Dry Critical Test (S8DR Nuclear Testing- TP-568-19-001)," November 14, 1968.
3. TR-568-24-004, L. D. Felten, "Vacuum Vessel Critical Tests (S8DR Nuclear Testing- TP-568-19-001)," May 2, 1969.
4. TI-568-13-011, C. A. Goetz, "As-Built S8DR Nuclear Calculation Model," May 9, 1968.
5. NAA-SR-9642, D. E. Crouter, Ed., "SNAP 8 Experimental Reactor Critical Experiment," September 15, 1964.
6. NAA-SR-Memo-9757, R. M. Micklich, "Approach to Critical Control Drum Configurations, Test 8ER-004," April 2, 1964.
7. NAA-SR-Memo-9755 Rev., M. D. O'Neill, "S8ER Net Critical Configuration, Test 8ER-007," April 2, 1964.
8. NAA-SR-10245, D. W. Clifford, "Interim Report on the SNAP Critical Assembly 4A (SCA-4A) Experimental Results," March 20, 1965.
9. NAA-SR-Memo-1.931, D. W. Clifford, "Experimental Results of Parametric Control Drum Study," January 19, 1965.
10. NAA-SR-9371, S. Yee, "SNAP Critical Assembly- 4B Phase III Water Immersion Experiments," December 1, 1964.