FEB 4 1964

UNCLASSIFIED

CLASSIFICATION LEVEL
(S, C, OR U)

ATOMICS INTERNATIONAL
A Division of North American Aviation, Inc.

MASTER

NAA-SR-MEMO 9232

This document contains ³⁶ pages

This is copy _____ of _____ series _____

Do not remove
this sheet

Facsimile Price \$ 3.60
Microfilm Price \$ 1.28

Available from the
Office of Technical Services
Department of Commerce
Washington 25, D. C.

CLASSIFICATION TYPE
(RD OR DI)

*NAA-SR-MEMOs are working papers and may be expanded,
modified, or withdrawn at any time,
and are intended for internal use only.*

This report may not be published without the approval of the Patent Branch, AEC.

released

LEGAL NOTICE

This report was prepared as an account of Government sponsored work. Neither the United States, nor the Commission, nor any person acting on behalf of the Commission:

A. Makes any warranty or representation, express or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this report, or that the use of any information, apparatus, method, or process disclosed in this report may not infringe privately owned rights; or

B. Assumes any liabilities with respect to the use of, or for damages resulting from the use of information, apparatus, method, or process disclosed in this report.

As used in the above, "person acting on behalf of the Commission" includes any employee or contractor of the Commission to the extent that such employee or contractor prepares, handles or distributes, or provides access to, any information pursuant to his employment or contract with the Commission.

UNCLASSIFIED

CLASSIFICATION LEVEL
(S, C, OR U)

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

ATOMICS INTERNATIONAL A Division of North American Aviation, Inc.		NAA-SR TDR NO. 9232	APPROVALS
TECHNICAL DATA RECORD		PAGE 1 OF 36	<i>G.W. Graves</i> <i>Paul D Cohn</i>
AUTHOR R. S. Daleas	DEPT & GROUP NO. 721-14	DATE 11-15-63	
TITLE Development of Salt Velocity Technique, <i>SNAP-8</i>		GO NO. 7568	S/A NO. 1330 TWR 51399
		SECURITY CLASSIFICATION	
PROGRAM SNAP 8	SUBACCOUNT TITLE SNAP 8 Hydraulics	(CHECK ONE BOX ONLY) UNCL. ☒ AEC ☒ DOD ☐ CONF. ☐ SECRET ☐	(CHECK ONE BOX ONLY) RESTRICTED DATA ☐ DEFENSE INFO. ☐
DISTRIBUTION		AUTHORIZED CLASSIFIER SIGNATURE DATE <i>Paul D Cohn</i> 11-15-63	
J.V. Addison E.B. Baumeister H.R. Brager W.C. Burke D.J. Cockeram P.D. Cohn (3) C.R. Davidson G.E. Dufoe R.J. Gimera C.A. Goetz H.H. Hanlin M.P. Heisler F.L. Henderson C.E. Johnson R.T. Lancet L.M. Maki D.G. Mason G.W. Meyers T.S. Nakae M.A. Perlow C.J. Petlak G.W. Rivenbark J.H. Roecker M.H. Slater J. Susnir J.R. Wetch J.D. Wilde Unit Members (13) 721-14 HQ 2		STATEMENT OF PROBLEM Develop the salt velocity technique for application to the SNAP 8 hydraulic core flow distribution studies.	
		ABSTRACT <p>The salt velocity technique for measuring coolant flow through a SNAP 8 tri-cusp channel was studied and developed. The parameters important in obtaining reproducible data were investigated and a test procedure which yields data of good precision was developed.</p> <p>Data were taken on a tri-cusp channel with flush circular electrodes (0.125 inch OD) as well as on a tri-cusp channel with parallel plate electrodes (0.006 inches thick, 0.250 inches long) which were situated 0.050 inches apart and which protruded 0.040 inches into the stream.</p> <p>The data are presented as the ratio of U_{exp}/U_{avg} where U_{avg} is calculated by means of a flowrator and channel geometry. It was found that in the tri-cusp channel for a range of Reynolds Numbers of 11,000 to 25,000 a radial velocity profile could not be sensed. The peripheral velocity profile over the central half of the channel appeared to be flat and relatively independent of the Reynolds Number. The data were compared with similar work of Palmer and Swanson³ in a qualitative and quantitative manner. Reasons are given for using a single calibration factor in the hydraulic model testing of S8DS core.</p> <p>While some slight modifications should be made to further improve the accuracy of the salt velocity procedure, the most important phases of the development and perfection of the procedures have been accomplished successfully.</p>	

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232
DATE 11-15-63
PAGE 2 OF 36

Introduction:

In order to ensure the optimum operation of a SNAP 8 core, it is necessary to be able to produce a coolant flow which has a radial shape somewhat like a cosine function, which corresponds to an overall minimum, maximum temperature condition. In order to be able to develop a baffle to do this, some method of measuring the velocity of a fluid through a tri-cusp channel with an extremely small cross sectional area was to be developed. For the S8ER¹ core a baffle was developed by measuring the coolant flow in the hydraulic model by means of a bucket, stop watch and balance. This method possessed two disadvantages. First, the velocity profile in a channel was only measured at the exit plane, and due to possible cross flow from one channel to another, it might not have been an accurate representation of the average flow through the channel. Second, the method required an extensive amount of testing time.

Previous to the bucket, stop watch, and balance technique, the so-called salt velocity technique² was employed in an attempt to measure coolant velocities. This consisted of the injection of a salt solution into the coolant stream for the purpose of changing the coolant's electrical conductivity. Then an oscillograph recorded the time it took the slug of salt solution to travel from upstream to downstream electrodes. In this work no attempts were made to investigate the experimental factors which would affect this technique. Instead, the hydraulic model core was simply instrumented with electrodes in certain fuel elements and measurements made. The results were poor and not reproducible. For the sake of expedience, the salt velocity method was abandoned and a baffle was developed for S8ER core by the time honored bucket, stop watch and balance technique of velocity measurement.

Interest in the salt velocity technique has again arisen for the production of a baffle for S8DS core due to the inherent disadvantages of bucket, stop watch and balance technique. The philosophy this time was to study the salt velocity technique in a mock up of a single tri-cusp channel of the S8ER core (due to the fact that the dimensions of S8DS core were not known in advance). The study had two goals. First, it was desired that the salt velocity technique could be developed to reliably measure the average velocity in a tri-cusp channel. Of second import, it was hoped that the technique would lend itself to velocity measurement over short distances so that a fuel element might be instrumented with several electrodes and in this manner detect any cross flow which might occur from one channel to another.

The first part of the report consists of a qualitative discussion of the various parameters in the system which have an important influence on the technique. The second part of the report deals with the quantitative results obtained in a tri-cusp channel which employed the best operational procedure which has so far been developed.

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 3 OF 36

Test Set-Up

The hydraulic loop used for the study was an open loop. The storage tank was a 55 gallon stainless steel drum. (See Figure A). It also acted as a surge tank since part of the fluid was always circulating in a closed loop. The fluid was pumped from the bottom of the reservoir through the system by means of a Peerless Pump with a capacity of 75 GPM. From the reservoir, the coolant flowed through a control valve, a Fischer & Porter precision bore flowrator and approximately five feet of 3/4" ID tygon tubing before entering the bottom of the upright test section. Upon exit from the test section, the fluid flowed through about ten feet of 3/4" ID tygon tubing to the top of the reservoir. Copper cooling coils were inserted into the reservoir and tap water circulated through them to maintain the reservoir at a constant temperature. Two thermometers indicated the reservoir temperature.

The test channel was built to match the geometric characteristics of a S8ER coolant channel as closely as possible. Three stainless steel rods 14.75 inches in length and 0.56 inches in diameter were mounted in lucite end plates. Circular entrance and exit channels 0.156 inches in diameter were drilled in the bottom and top end plates. The rods were mounted so that their pitch was 0.57 inches thus yielding a pitch to diameter ratio of 1.018. In order to make the channel leakproof, the 0.010 inch gap between the rods was sealed with #460 Helix potting compound. Cylindrical lucite plenums 2 inches in diameter and 6 inches in length were joined to the end plates. Lucite transition pieces which were joined to the plenums connected the tygon tubing to the test section.

Six electrodes were inserted through one of the dummy fuel elements. The first was positioned three inches from the entrance of the tri-cusp channel and the succeeding five were placed at two inch intervals. Thus, the sixth electrode was 1-3/4 inches (about 35 hydraulic diameters) from the exit of the tri-cusp channel. Epoxy plastic was used to electrically insulate and seal the electrodes in the holes bored in the dummy fuel element.

The six electrodes were wired into a 36 channel Visicorder (Figure B). Each electrode forms a leg of a Wheatstone Bridge circuit and when the salt solution passes over the electrode it causes a short between the stainless steel rod and the electrode which in turn unbalances the bridge and the event is then recorded on an oscillograph.

The circuitry of each channel is independent so that there can be no electronic coupling of the response from one electrode to that of another. Alternating current is supplied to the electrodes but the signal is rectified to a direct current signal. When the bridges are balanced

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 4 OF 36

Figure A

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-MEMO 9232

DATE 11-15-63

PAGE 5 OF 36

Figure B

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232
DATE 11-15-63
PAGE 6 OF 36

the traces on the oscillograph are straight vertical lines which are deflected when the salt solution passes over the electrodes. The time interval between each deflection can be read by means of horizontal time lines on the oscillograph paper.

Important Parameters and Procedures

This section will be a discussion of the various components of the system and the affect they have on obtaining reproducible and accurate data.

The water used in the hydraulic testing was de-ionized which has a very low electrical conductivity. The bridge circuits are designed to be nulled on this medium. It was noted that anything that might increase the conductivity of the water, such as allowing salt to accumulate in the system, greatly reduced the sensitivity of the Visicorder which in turn resulted in inconsistent data. Therefore, during a run, after the salt solution had passed through the test section, the return line was removed from the reservoir and allowed to drain long enough to discard the contaminated water and prevent its being introduced into the reservoir. Thus procedure turned out to be very important in obtaining reproducible data.

It appeared to be a good practice to store the test water in a closed vessel. This was normally done, but there was a non-testing period during which the open reservoir remained full for seven days. When testing was resumed, the bridges did not balance properly. Apparently enough carbonic acid had been produced from dissolved carbon dioxide to significantly change the conductivity of the test water. When the reservoir was drained and fresh water added, the bridges balanced properly.

The flowrator used was a very accurate instrument. It was calibrated for 100°F water by means of a stop watch, bucket and balance. The calibration curve is Figure 1. It should be noted that all the data points fall very well in a straight line. During a run the flow through the system was extremely steady and the float would move less than the width of a graduation mark. Undoubtedly, the elastic property of the tygon tubing helped to dampen out any pressure surges.

The method of injecting the salt solution into the test channels is subject to two restrictions. First, it must not introduce a pressure surge into the channel. Second, since only a small volume of fluid will flood the channel, it is very important that the salt solution be introduced with the same velocity as the bulk stream. The injection method finally selected which does this employs the pressure drop of several atmospheres between the plenum and the channel, and is in essence a bypass tube. A schematic of the injector follows.

FLOWRATOR CALIBRATION CURVE

LB/MIN OF
100°F H₂O

FIG. I

FLOWRATOR READINGS

3 4 5 6 7 8 9 10 11 12 13 14

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 8 OF 36

- ①, ② HOSE CLAMP
③ PINCH PLIERS

A tube with the same diameter as the hole in the end plate was inserted through a dummy fuel element into the tri-cusp channel 2 inches upstream of the first electrode. A glass "Y" and tygon tubing connected the insert tube to the plenum.

When the system was not steady state and the by-pass was closed the water in the glass "Y" was completely removed and replaced with salt solution. It was found to be important to completely remove any air bubbles from the glass "Y" because they would cause a deflection of the traces and hence cause confusion in interpreting the oscillograph traces.

The next step was to bring the glass "Y" up to the plenum pressure by opening hose clamp . After waiting a few seconds, the salt solution would then be injected into the channel by rapidly opening the pinch pliers. There were absolutely no signs of a pressure pulse on the flow-rator during the injection process.

NaNO_3 was the salt used throughout the tests because it has a very high solubility product and is non-corrosive. The quantity of salt solution injected did not appear to be important. The glass "Y" was always filled (about 3 cc). However, the salt concentration had a marked effect. It is desirous to get as large a difference as possible between the conductivity of the slug and that of de-ionized water in order to obtain the sharpest possible deflection in the oscillograph traces. Hence, saturated

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232
DATE 11-15-63
PAGE 9 OF 36

NaNO_3 solutions were used.

The electrodes used in the channel were made of stainless steel. After extensive use one channel was opened for inspection and no tarnish was found on them, whereas previous copper electrodes had tarnished badly. During the development period circular electrodes, 1/8" ID, positioned in the center of the rod both flush to the stream and protruding 0.010 inches into it were tested. There were not differences in the results. When the operating procedure was established, extensive testing was done on a channel with these flush electrodes and one with parallel plate electrodes (0.050 inches apart). The plates were 0.006 inches thick, 0.250 inches long and protruded 0.040 inches into the stream. The numerical results obtained on these two channels will be discussed later.

A Hewlett Packard High Frequency Generator was used as the power supply for the Visicorder. When the 60 cps live power was used, it was noted that if the time interval between two electrodes was about 8 milliseconds the electrodes appeared to be coupled, that is, the traces for the first and second, third and fourth, fifth and sixth electrodes were deflected simultaneously. A 60 cps wave form has a peak to peak time of about 16 milliseconds and apparently there was some superposition effect on the oscillograph traces. When a higher frequency signal was used, this problem was eliminated. Different frequencies in the range of 400 to 700 cps were briefly investigated and there were no apparent differences among them. A frequency of 700 cps was then arbitrarily selected for the further developmental work.

During the development period, it was learned that a new improved type of oscillograph paper with sharper and more intense traces was available. It was Kodak's Improved Linagraph Direct Print Paper, Specification 2, and will be used exclusively in the future.

Test Procedure

The following is the optimum test procedure developed to date and is the procedure used in acquiring the data to be discussed in the section on results.

The test loop was filled with about 55 gallons of de-ionized water and the pump was started. After about one hour with two immersion heaters in the reservoir, the water temperature reached 100°F. This was the water temperature at which all of the testing was done. This temperature was maintained by regulating tap water to the cooling coils in the reservoir. The desired value of water flow was set by means of the flowrator. The Visicorder signal frequency was set at 700 cps. The oscillograph paper speed was set at 160 inches/sec. and the time intervals at 1 millisecond (both maximum conditions). The glass "Y" was filled with 3 cc of saturated NaNO_3 solution as described previously. When the flow rate was

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 10 OF 36

steady, the oscillograph was started and when the paper came up to speed the salt solution was injected. The tygon return tube was then lifted from the reservoir and the contaminated water was allowed to drain off. Three runs were made at each flow rate.

Calculations and Cross-Sectional Area Measurements

The theory of hydraulic modeling and the necessary derivations for the correlation between NaK and water flow rates have been presented by Dutton² and Graves¹ and will not be repeated here. In these reports, it is developed that the ratio of mass flow in the hydraulic model to that in the prototype is:

$$\frac{W_M}{W_P} = \frac{\mu_M A_M}{\mu_P A_P} \quad (1)$$

W_M - mass flow of water in tri-cusp channel

μ_M - viscosity of water at test temperature

A_M - cross-sectional area of tri-cusp channel in hydraulic model

Since the test channel was constructed to be identical to one in S8ER core, $A_M = A_P$, it follows that

$$\frac{W_M}{W_P} = \frac{\mu_M}{\mu_P} \quad (2)$$

At the test conditions.

$$\mu_M = 1.65 \text{ lbm/hr/ft} \quad 100^\circ\text{F H}_2\text{O}$$

$$\mu_P = 0.355 \text{ lbm/hr/ft} \quad 1200^\circ\text{F NaK}$$

The average NaK flow through a single tri-cusp channel is 1.935 lbm/min. From Figure 14 in Dutton's² report, the ratio of the local to the average flow varies from 0.7 to 1.45. This then yielded the range of water flows to be investigated in the test channel.

$$\text{Average H}_2\text{O flow} - W_M = \left(\frac{1.65}{0.355}\right) (1.935) = 9 \text{ lb/min}$$

$$\text{Minimum H}_2\text{O flow} - W_M = 0.7 (9) = 6.3 \text{ lb/min.}$$

$$\text{Maximum H}_2\text{O flow} - W_M = 1.45 (9) = 13.05 \text{ lb/min.}$$

In order to evaluate the velocity indicated by the electrodes it was necessary to know the average velocity through the test channel. This required knowledge of the mass flow through the channel, the density of

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232
DATE 11-15-63
PAGE 11 OF 36

water at 100°F (61.95 lbm/ft³) and the average cross sectional area of the tri-cusp channel. The latter was measured during the construction of the channel.

After the three rods had been inserted into the end plates and the 0.010 inch gaps sealed with epoxy, the bottom of one end plate was covered with tape. A 5 cc syringe was filled with water and the needle was inserted into a plastic tubing, about 15 inches long, which had a smaller diameter than the tri-cusp channel. The tubing was inserted to the bottom of the channel and then slowly withdrawn while the water was being injected into the channel and the air was being forced out between the tubing and channel walls. The volume of water required to fill the channel and two end plates was recorded.

Area of channel with circular flush electrodes:

Total length: 15-5/8 inches
Length of 2 end plates: 15/16 inch
Volumetric measurements: 3.2, 3.2, 3.2, 3.2, 3.2 cc

volume needed to fill tri-cusp channel

$$3.2 \text{ cc} \left(0.06102 \frac{\text{in}^3}{\text{cc}} \right) - \frac{\pi}{4} (.156 \text{ in})^2 \left(\frac{15}{16} \text{ in} \right) = 0.178 \text{ in}^3$$

$$\text{Area of tri-cusp channel} = \frac{0.178 \text{ in}^3}{\left(15 \frac{5}{8} - \frac{15}{16} \right) \text{ in}} = 0.0121 \text{ in}^2$$

Area of channel with protruding plate electrodes:

Total length: 15-11/16 inches
Length of 2 end plates: 1 inch
Volumetric measurements: 3.3, 3.3, 3.3 cc

volume needed to fill tri-cusp channel

$$3.2 \text{ cc} \left(.06102 \frac{\text{in}^3}{\text{cc}} \right) - \frac{\pi}{4} (0.156 \text{ in})^2 (1 \text{ in}) = 0.182 \text{ in}^3$$

$$\text{Area of tri-cusp channel} = \frac{0.182 \text{ in}^3}{\left(15-11/16 - 1 \right) \text{ in}} = 0.0124 \text{ in}^2$$

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232
DATE 11-15-63
PAGE 12 OF 36

Results

The results are presented as a ratio of U_{exp}/U_{avg} where U_{exp} is the indicated velocity from the first to the sixth electrode (10 inches apart) and U_{avg} is based upon the flow meter readings and the measured average cross-sectional area of the channels.

$$\frac{U_{exp}}{U_{avg}}$$

Flow Rates lbm/min	Flush Circular Electrodes			Protruding Plate Electrodes		
5.85	1.085	1.097	1.085	1.115	1.1	1.1
6.4	1.1	1.1	1.085			
6.9	1.048	1.109	1.109	1.045	1.075	1.105
7.4	1.065	1.065	1.065			
7.85	1.035	1.068	1.085	1.08	1.095	1.095
8.4	1.065	1.03	1.065			
8.85	1.088	1.05	1.05	1.095	1.095	1.08
9.35	1.09	1.09	1.09			
9.85	1.1	1.055	1.1	1.063	1.063	1.063
10.35	1.135	1.11	1.135			
10.85	1.085	1.085	1.085	1.07	1.07	1.07
11.35	1.09	1.065	1.065			
11.85	1.07	1.045	1.07	1.025	1.025	1.025
12.3	1.055	1.055	1.055			
12.8	1.13	1.068	1.068	1.06	1.035	1.035

Table 1 contains the information used in computing the above ratios.

NO. NAA-SR-TDR 9232DATE 11-15-63PAGE 13 OF 36**ATOMICS INTERNATIONAL**

A Division of North American Aviation, Inc.

TABLE 1

LBM/MIN of 100°F Water	$\frac{\text{FT}^3}{\text{MIN}}$	Calculated Velocity Over 10" Interval ft/sec.		Calculated Time to Traverse 10 inches (milliseconds)	
		Circular Flush	Protruding Plate	Circular Flush	Protruding Plate
5.85	0.0944	18.72	18.25	44.4	45.7
6.4	0.1032	20.5	19.98	40.7	41.7
6.9	0.1112	22.1	21.5	37.7	38.7
7.4	0.1195	23.7	23.15	35.1	36
7.85	0.1267	25.15	24.5	33.1	34
8.4	0.1355	26.9	26.2	30.9	31.8
8.85	0.1427	28.3	27.6	29.4	30.2
9.35	0.1508	29.9	29.15	27.85	28.55
9.85	0.159	31.55	30.75	26.4	27.1
10.35	0.167	33.15	32.3	25.5	25.8
10.85	0.175	34.75	33.85	23.9	24.65
11.35	0.183	36.3	35.4	22.9	23.5
11.85	0.191	37.9	36.9	21.95	22.55
12.3	0.1985	39.4	38.4	21.1	21.7
12.8	0.2065	41.0	39.95	20.3	20.8

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 14 OF 36

For each channel, an average value of all the data points was computed as well as their standard deviation. The calculations may be found in the Appendix. The results of the analysis are: flush circular electrodes

$$\left(\frac{U_{exp}}{U_{avg}} \right)_{avg} = 1.08 \pm 0.025$$

protruding plate electrodes $\left(\frac{U_{exp}}{U_{avg}} \right)_{avg} = 1.07 \pm 0.026$

Discussion of Results

The almost identical data from the two channels leads to three quite interesting preliminary conclusions for flow of high Reynolds Numbers (11,000 to 25,000) in tri-cusp channels of this small cross sectional area. There are three parameters which might have influenced the values of U_{exp}/U_{avg} . If there was significant varying radial profile it should have been detected since one set of electrodes was flush while the other protruded well into the stream. The plate electrodes were only 0.050 inches apart while the circular electrodes covered 0.125 inches in the periphery. The peripheral profile, at least over the central 0.125 inches, thus appears quite flat as well as being independent of Reynolds Number. These points will be discussed further, later. What will be discussed immediately are the results with regards to their experimental precision and accuracy over the ten inch and two inch intervals. Only the results from the channel with flush circular electrodes will be discussed directly since the results from the two channels are so similar.

A. Results over 10 inch interval

1. Precision of experiment -

The precision of the data is good: ± 0.025 .

The system was studied for sources of random error which might contribute to a deviation of this magnitude. As noted previously, the flowrator indicated an extremely constant flow throughout a run so it could not introduce errors of this magnitude. The flowrator is sensitive to fluid viscosity which in turn is temperature dependent. However, with a 55 gallon reservoir it was quite easy to hold the bulk fluid at $100 \pm 1^\circ\text{F}$ and this deviation is not of significant importance.

The major source of error in the system appeared to be in the reading of the oscillograph traces. The one millisecond time lines are spaced about 1/8 inch apart. When the bridges are unbalanced by the salt solution, a sharp break does not occur in the traces but rather they

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 15 OF 36

tail off at an angle considerably less than 90°. Therefore, one can only approximate halfway between two time lines or to ± 0.5 milliseconds.

The maximum possible error introduced into the velocity measurement by the oscillograph traces may be calculated from the following standard error analysis:

$$V = \frac{x}{t} \quad (3)$$

V = velocity between two electrodes
x = distance between two electrodes
t = time interval between two electrodes

taking the logarithm of both sides of the equation and changing all negative signs to positive signs yields

$$\ln V = \ln x + \ln t \quad (4)$$

then differentiating (4) yields

$$\frac{\Delta V}{V} = \frac{\Delta x}{x} + \frac{\Delta t}{t} \quad (5)$$

Assuming that the leading edge of each electrode is the sensing portion* and that the measuring error between electrodes may be considered small, equation 5 reduces to $\frac{\Delta V}{V} \approx \frac{\Delta t}{t}$ (6)

Since the time of an event can be read to ± 0.5 milliseconds, the time interval between two electrodes may contain a maximum error of one millisecond. Thus, the equation for determining the maximum possible error in the velocity measurements reduces to

$$\frac{\Delta V}{V} \approx \frac{1}{t} \quad (7)$$

For the flow rates investigated, the length of time involved in transverseing the 10 inch interval varied between about 20 and 40 milliseconds. Thus, there could be maximum possible errors in the velocity measurements of

$$\frac{\Delta V}{V} \approx \frac{1}{20} = 0.05 \text{ to } \frac{\Delta V}{V} \approx \frac{1}{40} = 0.025$$

*Further experimentation will be performed to determine optimum electrode size.

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 16 OF 36

The precision of all the data (0.025) is thus seen to be well within this range of maximum possible error.

The precision of the experiments can be increased in two ways. First, decrease the maximum possible error in reading a time interval. There is a provision for inserting an external timer into the oscillograph so that time intervals of less than one millisecond might be generated. However, in addition the paper speed would have to be greatly increased over the present 160 inches/second to take advantage of a faster timer. From a discussion with a representative of Minneapolis Honeywell, it was learned that the fastest commercially available machine has a paper speed of 182 inches/second. This machine would then present no distinct advantage over the present system.

The other way to increase the precision of the experiment would be to increase the time interval between the electrodes by spacing them farther apart or by decreasing the flow rates. The tri-cusp channel tested was a mock up of a S8ER channel which has an overall length of 14.75 inches. It has been learned recently that the S8DS core will have fuel elements with a length of 17.15 inches. In the S8DS core, it should thus be possible to have the electrodes spaced further apart than in the present studies. Of far greater importance, though, is the fact that if water with a higher temperature than 100°F is used substantially lower flow rates may be employed because of the strong temperature dependence of the viscosity of water.

Referring to equation (2)

$$W_M = \frac{\mu_M}{\mu_P} W_P$$

when the 100°F test water was used the water mass flow rates were 4.65 times the NaK mass flow rates. However, 200°F water has a viscosity of 0.75 lbm/hr/ft. and if it had been used the water flow rates need only have been 2.11 times the NaK mass flow rates.

Thus, doubling the test water temperature from 100 to 200°F more than halves the required mass flow rates which in turn would decrease the maximum possible error in the system due to the time measurements by more than 50%. Thus, it would seem that in testing the S8DS hydraulic model core, the test water should be at the highest temperature that can be held in the laboratory.

2. Accuracy of experiment -

From a casual inspection of the experimental results, expressed as the ratio of U_{exp}/U_{avg} , it can be seen that there was a definite bias in the system which consistently caused a higher flow rate to be indicated by

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 17 OF 36

the salt velocity technique than was thought to be taking place. The fault could be in either the quantity U_{exp} or U_{avg} or both.

The calculated flow through the tri-cusp channel, U_{avg} , depended upon

1. flowrator calibration
2. density of 100°F water
3. cross sectional area of channel

The flowrator was calibrated at $\frac{1}{2}$ lb/minute intervals and all the data points fall exceedingly well in a straight line. The flowrator could thus not be reading consistently high by 8%. In addition, the density of water at 100°F is known very accurately. However, there is the possibility of error in the value assigned to the cross-sectional area of the channel. The area was measured by the water technique described previously. It was felt that since the air was removed the channel was completely filled and since the data were reproducible it was concluded that the average cross sectional area of the channel had been accurately measured. However, the measurements took place over the full length of the channel (14.75 inches) and only 10 inches actually were involved in the salt velocity measurements.

Undoubtedly from point to point along the channel the cross sectional area varied due to poor tolerances in the fabrication of the end plates. When the rods were placed in the end plates, a thin-walled, straight edge was inserted between the rods and discrepancies in the nominal 0.010 inch gaps were obvious. In addition when the gaps were filled with epoxy uneven seepage into the channel also caused the cross sectional area to be unequal along the length of the channel.

The magnitude of these discrepancies would be very hard to evaluate. However, the results obtained on the channel with protruding plate electrodes are essentially identical to those obtained on the channel with flush circular electrodes. It does not seem feasible that uneven flow area is to blame for the 8% discrepancy in the data since it does not seem possible that two channels could be constructed which would have identical discrepancies.

The net result is that the bias in the system most likely can be traced to the fact that only a local velocity was being sensed. It might be expected that velocity measurements in a tri-cusp channel would be a function of the position on the periphery of the channel, Reynolds Number and position in the bulk stream. As noted previously, the same results were obtained in channels with circular electrodes both flush and protruding 0.010 inches into the flow stream. It was then decided to try a different electrode geometry, that is, the closely-spaced, thin-walled, parallel plates, in the hope that any radial or

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 18 OF 36

peripheral velocity profiles would be sensed. The velocity measurements essentially had the same accuracy in all cases. The Reynolds Numbers (see Appendix for calculations) for the flow rates that were investigated varied from about 11,000 to 25,000. Extrapolating from well known circular channel theory, a flat radial profile can be expected at these Reynolds Numbers. This appears to have been borne out by the experiments.

As far as peripheral variation of flow is concerned, Palmer and Swanson³ present some interesting experimental data on the peripheral dependence of the ratio of local to average velocity of a fluid at a Reynolds Number of 20,000 in a tri-cusp channel with a pitch to diameter ratio of 1.015. Before discussing this data, a schematic of a tri-cusp channel will be presented in order to aid in understanding the following discussion.

Palmer and Swanson 3/5 paper presents the ratio of $\frac{U_{\text{local}}}{U_{\text{avg}}}$ is plotted as

a function of the angle θ from 0 to 30°. Since the circular electrodes used in the test section covered a large fraction of the rod periphery it was decided to compute a value of $\left(\frac{U_{\text{local}}}{U_{\text{avg}}}\right)_{\text{avg}}$ by graphically

integrating Palmer and Swanson's data over the periphery which the circular flush electrodes covered. It was first necessary to compute the angle θ at which the circular flush electrodes began. Then the data were plotted (Figure 2) and the graphical integration performed. The details are in the Appendix.

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 19 OF 36

The result was that at a Reynolds Number of 20,000, $\frac{U_{local}}{U_{avg}}$ averaged from $\theta = 12^\circ$ to $\theta = 30^\circ$ yielded a value of $\left(\frac{U_{local}}{U_{avg}}\right)_{avg} = 1.18$. This differs from the circular flush electrode data where $\left(\frac{U_{exp}}{U_{avg}}\right)_{avg} = 1.08$.

Palmer and Swanson also present several curves of $\frac{q_{local}}{q_{avg}}$ as a function of θ at higher Reynolds Numbers, the largest being 60,000. These curves have been plotted in Figure 3. These curves will be discussed in view of the Reynolds analogy approximation between fluid friction and heat transfer.

It is immediately evident that the curve for a Reynolds Number of 60,000 is flat from 15 to 30° and yields a value of $\frac{q_{local}}{q_{avg}} = 1.08$.

If curves at Reynolds Numbers greater than 60,000 had been generated, it would seem that they would most likely tend to converge particularly in the realm of the flat portion of the curves. A consideration of all three curves shows that the flat portion of the curves tends to extend further over the peripheral surface as the Reynolds Numbers increases and there is no reason for suspecting that this trend would reverse itself. In addition there is no reason for suspecting that this flat profile would dip below to value of $\frac{q_{local}}{q_{avg}} = 1.0$. It would thus seem that if the Reynolds Number had been increased above 60,000 the curves would have become flatter and flatter with a maximum range of the flat portion from 1.08 to 1.0.

Thus, it appears that under the Reynolds analogy approximation the tri-cusp test channel data exhibit the same trends as Palmer and Swanson's data but at vastly different Reynolds Numbers.

Palmer and Swanson's data were obtained in a tri-cusp channel with a vastly different flow area than that of the test channel employed for this study. Their channel used rods with a diameter of 6.25 inches as compared with the test channel's rod diameter of 0.56 inches. Palmer and Swanson make the point that they did not investigate channels with the same pitch to diameter ratio but different flow areas. It is quite possible that with very small channels the flow pattern would be quite different. In addition in the test channel, the closed gaps between the rods could conceivably create a pinched surface where the fluid would stagnate thus further changing the flow profile. Therefore, due to the differences in the test set ups there appears to be no reason for doubting the velocity profiles produced in this work or by Palmer and Swanson for Reynolds Numbers less than 25,000 in tri-cusp channels.

$U_{LOCAL} / U_{AVG.}$ at $Re = 20,000$

DATA TAKEN FROM PALMER AND SWANSON³

FIG. II

PERIPHERAL POSITION θ
(DEGREES)

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 22 OF 36

B. Results Over 2 inch Interval

The statements on the accuracy of the experimental data in the preceeding section will also apply to the data obtained from the intermediate electrodes. The only additional point that should be brought out is that probably an unequal flow area is responsible for the time intervals between the first and second, second and third, third and fourth electrodes being in general less than the time intervals between the fourth and fifth, fifth and sixth circular electrodes. With the plate electrodes, the time interval between the third and fourth, fifth and sixth electrodes are in general greater than the other time intervals. Some further investigation is needed to improve the point to point consistency.

As far as the precision or reproducibility of the point to point electrode data is concerned equation (7) is again applicable with the same restrictions. The time interval for the water flow to travel two inches varied between 4 and 8 milliseconds. Thus interpreting the traces could have introduced maximum errors of

$$\frac{\Delta V}{V} \approx \frac{1}{4} = 0.25 \quad \text{and} \quad \frac{\Delta V}{V} \approx \frac{1}{8} = 0.125$$

The point to point data was reproducible within these limits.

It can be seen that even if the point to point electrode data were 100% accurate (so that a 10% fluctuation in the data points could be permitted) the above maximum possible error range would be unacceptable. This analysis can then be used to determine the minimum distance two electrodes may be separated to yield the desired accuracy.

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 23 OF 36

Conclusions

In order to develop a system which will yield a velocity measurement within the desired accuracy of the actual flow velocity, the system can be improved by increasing the precision or accuracy of the experiment or both. The salt velocity technique has been developed to a point where the precision of the data is good and can be improved by following the recommendations made on the test water temperature in the preceeding section.

It appears to be established that the experimental accuracy is as good with flush electrodes as with protruding ones. This is desirous since flush electrodes will not introduce any additional pressure drop in the hydraulic model coolant channels as would protruding electrodes. It is not expected that this result will be changed even if higher temperature test water and correspondingly lower flow rates are used in the hydraulic model. This is because the Reynolds Numbers in the test channel are actually set by the hydraulic conditions in the prototype core. This can be seen from -

$$Re = \rho \frac{V_M D_H}{\mu_M}$$

(8) ρ = density

V = velocity

D_H = hydraulic diameter of model

μ = dynamic viscosity

$$W_M = \rho V_M A_M$$

(9) W_M = mass flow in model

A_M = cross sectional area of model

and equation (2) $W_M = \frac{A_M}{A_P} W_P$

From Equation (8) and (9)

$$Re = \frac{W_M}{A_M} \frac{D_H}{\mu_M} \quad (10)$$

From Equation (2) and (10)

$$Re = \frac{A_M}{A_P} W_P \frac{D_H}{A_M \mu_M} = \frac{D_H}{A_M} \frac{W_P}{\mu_M} \quad (11)$$

Thus, the Reynolds Numbers in the tri-cusp channel are functions of the channel geometry and the hydraulic conditions in the prototype core. Therefore, one can go from the test channel to the hydraulic model with the certainty that flush electrodes are the best.

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 24 OF 36

However, there might be some doubt as to the position of the electrodes on the periphery of the fuel rod. Extrapolating again from the curves of Figure 3 it is most likely that there is only a very precise point on the rod's periphery where $\frac{U_{local}}{U_{avg}} = 1.0$. It would be interesting to

experiment with thin wire electrodes and find this position in the tri-cusp channel for the flow rates of interest. However, though should also be given as to the difficulty involved in instrumenting a large portion of the hydraulic model core if the electrodes had to be positioned exactly at a certain point on the channel periphery. It would seem to make more sense to take advantage of the large flat portion of these curves and position the electrodes in the center of the channel periphery. Finally, since the data appear to be relatively insensitive to changes in Reynolds Number over the range of interest it would seem best to come up with a single factor to normalize the data to be taken in the hydraulic model core. In general, calibration factors are not the best way to solve a problem particularly if there is wide scatter in the data points. However, as pointed out previously, the precision of the system is good and most likely can be increased. Hence, there does not seem to be any major drawback to using a calibration factor in the hydraulic model tests.

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 25 OF 36

APPENDIX

I. Calculation of Standard Deviation

First $\left(\frac{U_{exp}}{U_{avg}} \right)_{avg} = \frac{\sum_{i=1}^n N_i}{n}$ was computed.

$n = 45$ for flush circular electrodes

$n = 24$ for protruding plate electrodes

$$U_{exp}/U_{avg} = N_i$$

Flush Circular Electrodes

1.085	1.097	1.085
1.1	1.1	1.085
1.048	1.109	1.109
1.065	1.065	1.065
1.035	1.068	1.085
1.065	1.03	1.065
1.088	1.05	1.05
1.09	1.09	1.09
1.1	1.055	1.1
1.135	1.11	1.135
1.085	1.085	1.085
1.09	1.065	1.065
1.07	1.045	1.07
1.055	1.055	1.055
1.13	1.068	1.068

$$\Sigma = 16.241 \quad 16.092 \quad 16.212$$

Protruding Plate Electrodes

1.115	1.1	1.1
1.045	1.075	1.105
1.08	1.095	1.095
1.095	1.095	1.08
1.063	1.063	1.063
1.07	1.07	1.07
1.025	1.025	1.025
1.06	1.035	1.035
<hr/>		
$\Sigma = 8.553$	8.558	8.573

$$\left(\frac{U_{exp}}{U_{avg}} \right)_{avg} = \frac{8.553 + 8.558 + 8.573}{24} = 1.07$$

$$\left(\frac{U_{exp}}{U_{avg}} \right)_{avg} = \frac{(16.241) + (16.092) + (16.212)}{45} = 1.08$$

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 26 OF 36

The next step is to compute the quantities

$$\beta_i = \left[\left(\frac{U_{\text{exp}}}{U_{\text{avg}}} \right)_{\text{avg}} - \frac{U_{\text{exp}}}{U_{\text{avg}}} \right]^2$$

for each data point and then finally

$$\sigma^2 = \frac{\sum_{i=1}^n \beta_i}{n-1}$$

The square root of which is the standard deviation,

$$\beta_i$$

Fluch Circular Electrodes

0.000036	0.000324	0.000036
0.000441	0.000441	0.000036
0.000961	0.000900	0.000900
0.000196	0.000196	0.000196
0.001940	0.000121	0.000036
0.000196	0.002400	0.000196
0.000081	0.000840	0.000840
0.000121	0.000121	0.000121
0.000441	0.000575	0.000441
0.003140	0.000960	0.003140
0.000036	0.000036	0.000036
0.000121	0.000196	0.000196
0.000081	0.001078	0.000081
0.000575	0.000575	0.000575
0.002600	0.000121	0.000121
$\Sigma =$		
0.010966	0.008884	0.006951

Protruding Plate Electrodes

0.002020	0.000900	0.0009
0.000625	0.000025	0.001220
0.000100	0.000625	0.000625
0.000625	0.000625	0.000100
0.000049	0.000049	0.000049
0	0	0
0.02020	0.002020	0.002020
0.000100	0.001220	0.001220
$\Sigma =$		
0.003519	0.005464	0.006134

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 27 OF 36

$$\sigma^2 = \frac{0.010966 + 0.008884 + 0.006951}{44} \quad \sigma^2 = \frac{0.003519 + 0.005464 + 0.006134}{23}$$

$$\sigma^2 = 0.000609 \quad \sigma^2 = 0.000657$$

$$\sigma = 0.0245 \quad \sigma = 0.0256$$

II. Calculation of the Fraction of the Periphery Covered by the Circular Flush Electrodes

Nominally a channel sees 1/6 of perimeter of a rod - $\frac{\pi}{6}$ (0.56) = 0.293 inches

diameter of electrode = 0.125 inches

The difference is 0.168 inches or 0.084 inches on each side of the electrode. Inspection of disassembled test sections showed that some of this area was covered by epoxy. For the purposes of this calculation this epoxy seepage will be approximated as covering one half of the free rod surface. Thus, the fraction of the rod surface that the electrode covered was

$$\frac{0.125}{0.125 + 0.084} = 0.6$$

Thus, the electrode edge was about at 12° on the rod periphery.

Graphical Integration of $\frac{U_{\text{local}}}{U_{\text{avg}}}$ From Figure II

The value of $\frac{U_{\text{local}}}{U_{\text{avg}}}$ was read at the midpoint of 1° intervals from $\theta = 12^\circ$ to $\theta = 30^\circ$. They are:

0.85	1.15	1.27	1.275
0.925	1.195	1.275	1.275
0.995	1.23	1.275	1.275
1.05	1.255	1.275	
1.105	1.265	1.275	

The sum of the values is 21.215.

$$\left(\frac{U_{\text{local}}}{U_{\text{avg}}} \right)_{\text{avg}} = \frac{\int_{12^\circ}^{30^\circ} \frac{U_{\text{local}}}{U_{\text{avg}}} d\theta}{\Delta \theta} = \frac{21.215}{18} = 1.18$$

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232DATE 11-15-63PAGE 28 OF 36Calculation of Reynolds Numbers in Tri-Cusp Channel

$$D_H = \frac{4A}{P} = 4 \frac{(0.0121)}{3(.209) + 3(.1)} = 0.0523 \text{ inches}$$

$$Re = \frac{\rho V D_H}{\mu} = \frac{w}{A} \frac{D_H}{\mu} \quad \mu = 0.0275 \text{ lbm/min/ft}$$

$$Re = \frac{(0.0523 \text{ in}) w (\text{lbm/min})}{(0.0121 \text{ in}^2) \left(0.0275 \frac{\text{lbm}}{\text{min-ft}}\right)} \left(\frac{12 \text{ in}}{\text{ft}}\right)$$

$$Re = 1900 w$$

w ranged from about 6 to 13 lbm/min.

Reynolds Number ranged from 11,400 to 25,000.

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

NO. NAA-SR-TDR 9232

DATE 11-15-63

PAGE 29 OF 36

Bibliography

1. Graves, A. W., "S8ER Hydraulic Studies," NAA-SR-TDR 7971, May 16, 1963.
2. Dutton, R. A. and Gallegos, A. N., "SNAP 8 Core Hydraulic Model Test Results," NAA-SR-TDR 6797, August 31, 1961.
3. Palmer, L. D. and Swanson, L. L., "Measurements of Heat Transfer Coefficients, Friction Factors and Velocity Profiles for Air Flowing Parallel to Closely Spaced Rods," General Atomic Division of General Dynamics Corporation, San Diego, California.

PREPARED BY
R. DALEAS

CHECKED BY

DATE
8/15/63 - 8/19/63

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

FLUSH CIRCULAR ELECTRODES

PAGE
31

OF
30

REPORT NO.
NAA-SK-TDR 9232

MODEL NO.

WATER TEMPERATURE 100°F
GLASS-Y-INJECTOR USED
CONTAMINATED H2O DUMPED
OSCILLATOR SET AT 700 C.P.S.
PAPER SPEED 160 IN./SEC.

TIME LINES - 2 MILLISECOND
BRIDGE VOLTAGE = 26 VOLTS

TIME (MILLISECONDS)
AT EACH ELECTRODE

RUN	FLOW-METER APR. READING	1	2	3	4	5	6
1	4.7	0	8	16	24	32.5	41.0
2	4.7	0	8	16	23.5	31.5	40.5
3	4.7	0	8	16	24.5	32.5	41.0
4	5.2	0	8	14	21.0	29.0	37.0
5	5.2	0	7	14	21.5	29.0	37.0
6	5.2	0	7.5	14.5	21.5	29.5	37.5
7	5.7	0	7.5	14.5	21.5	28.5	36.0
8	5.7	0	6.5	13.5	20.0	27.0	34.0
9	5.7	0	6.5	13.5	20.0	27.0	34.0
10	6.2	0	7.0	13.0	19.0	26.0	33.0
11	6.2	0	7.0	13.0	19.0	26.0	33.0
12	6.2	0	7.0	13.0	19.0	26.0	33.0
13	6.7	0	6.5	12.5	19.0	25.5	32.0
14	6.7	0	6.0	12.0	18.0	24.5	31.0
15	6.7	0	6.0	12.0	17.5	24.0	30.5
16	7.2	0	6.0	11.0	17.0	23.0	29.0
17	7.2	0	6.0	12.0	18.0	24.0	30.0
18	7.2	0	6.0	11.5	17.0	23.0	29.0
19	7.7	0	5.0	10.0	15.5	21.0	27.0
20	7.7	0	5.5	10.5	16.0	22.0	28.0
21	7.7	0	5.5	11.0	16.0	22.0	28.0
22	8.2	0	5.0	9.5	14.5	20.0	25.5
23	8.2	0	5.5	10.0	14.5	20.0	25.5
24	8.2	0	5.5	10	14.5	20.0	25.5

PREPARED BY R. DALEAS	ATOMICS INTERNATIONAL A Division of North American Aviation, Inc.	PAGE 33	OF 36
CHECKED BY		REPORT NO. NAA-SR-TDR 9232	MODEL NO.
DATE 11-15-63			

TIME INTERVAL BETWEEN Electrodes (MILLISECONDS)						
RUN	1-2	2-3	3-4	4-5	5-6	6-6
1	8.0	8.0	8.0	8.5	8.5	41.0
2	8.0	8.0	7.5	8.0	9.	40.5
3	8.0	8.0	8.5	8.0	8.5	41.0
AVG	8.0	8.0	8.0	8.17	8.67	40.83
4	8.0	6.0	7.0	8.0	8.0	37.0
5	7.0	7.0	7.5	7.5	8.0	37.0
6	7.5	7.0	7.0	8.0	8.0	37.5
AVG	7.5	6.67	7.17	7.83	8.0	37.17
7	7.5	7.0	7.0	7.0	7.5	36.0
8	6.5	7.0	6.5	7.0	7.0	34.0
9	6.5	7.0	6.5	7.0	7.0	34.0
AVG	6.83	7.0	6.67	7.0	7.17	34.67
10	7.0	6.0	6.0	7.0	6.0	33.0
11	7.0	6.0	6.0	7.0	7.0	33.0
12	7.0	6.0	6.0	7.0	7.0	33.0
AVG	7.0	6.0	6.0	7.0	7.0	33.0
13	6.5	6.0	6.5	6.5	6.5	32.0
14	6.0	6.0	6.0	6.5	6.5	31.0
15	6.0	6.0	5.5	6.5	6.5	30.5
AVG	6.17	6.0	6.0	6.5	6.5	31.17
16	6.0	5.0	6.0	6.0	6.0	29.0
17	6.0	6.0	6.0	6.0	6.0	30.0
18	6.0	5.5	5.5	6.0	6.0	29.0
AVG	6.0	5.5	5.83	6.0	6.0	29.33
19	5.0	5.0	5.5	5.5	6.0	27.0
20	5.5	5.0	5.5	6.0	6.0	28.0
21	5.5	5.5	5.0	6.0	6.0	28.0
AVG	5.33	5.17	5.33	5.83	6.0	27.67
22	5.0	4.5	5.0	5.5	5.5	25.5
23	5.5	4.5	4.5	5.5	5.5	26.5

PREPARED BY R. DALEAS	ATOMICS INTERNATIONAL A Division of North American Aviation, Inc.	PAGE 34 OF 436
CHECKED BY		REPORT NO. NAA-SR-TDR 92327
DATE 11-15-63		MODEL NO.

**TIME INTERVAL BETWEEN
ELECTRODES (MilliSeconds)**

Run	1-2	2-3	3-4	4-5	5-6	1-6			
24	5.5	4.5	4.5	5.5	5.5	25.5			
AVG	5.33	4.5	4.67	5.5	5.5	23.5			
25	4.5	4.5	5.0	5.0	5.0	24.0			
26	5.0	4.5	5.0	5.0	5.5	25.0			
27	5.0	4.5	4.5	5.0	6.0	24.0			
AVG	4.83	4.50	4.83	5.0	5.17	24.33			
28	4.5	4.0	4.5	5.0	4.5	22.5			
29	5.0	4.0	4.5	5.0	4.5	23.0			
30	4.5	4.5	4.0	4.5	5.0	22.5			
AVG	4.67	4.17	4.33	4.83	4.67	22.67			
31	5.0	4.0	4.0	4.0	5.0	22.0			
32	5.0	4.0	4.0	4.5	4.5	22.0			
33	4.0	4.0	4.0	5.0	5.0	22.0			
AVG	4.67	4.0	4.0	4.5	4.83	22.0			
34	4.0	4.0	4.0	4.5	4.5	21.0			
35	4.5	4.0	4.0	4.0	5.0	21.5			
36	4.5	3.5	4.0	4.0	5.0	21.5			
AVG	4.33	3.83	4.0	4.17	4.83	21.33			
37	4.0	4.0	4.0	4.0	4.5	20.5			
38	4.0	4.0	4.0	5.0	4.0	21.5			
39	4.0	4.0	4.0	4.0	4.5	20.5			
AVG	4.0	4.0	4.0	4.33	4.33	20.67			
40	4.0	3.5	4.0	4.0	4.5	20.0			
41	4.0	3.5	3.5	4.5	4.5	20.0			
42	4.0	4.0	4.0	4.0	4.0	20.0			
AVG	4.0	3.67	3.83	4.17	4.33	20.0			
43	3.5	3.5	3.5	3.5	4.0	18.0			
44	3.5	3.5	3.5	4.5	4.0	19.0			
45	4.0	3.0	4.0	4.0	4.0	19.0			
AVG	3.67	3.33	3.67	4.0	4.0	18.67			

PREPARED BY
R. D. ALFAS

CHECKED BY

ATOMICS INTERNATIONAL

A Division of North American Aviation, Inc.

PAGE

35 OF 236

REPORT NO.

REPORT NO. NAA-SR-TDR 9232

MODEL NO.

DATE _____

8/22/63-8/23/63 PROTRUDING PLATE ELECTRODES

WATER TEMPERATURE-100°F.

GLASS(Y) INJECTOR USED

CONTAMINATED H₂O DUMPED

OSCILLATOR SET AT 700 KPS

PAPER SPEED - 160 IN/SEC.

TIME LINES = 1 MILLISECOND

BRIDGE VOLTAGE - 26 VOLTS

Run	Flow Meter Reading	TIME AT EACH ELECTRODE IN (MILLISECONDS)					
		1	2	3	4	5	6
1	4.7	0	8.0	16.0	25.0	33.0	42.0
2	4.7	0	8.0	16.0	24.5	32.0	41.0
3	4.7	0	8.5	16.5	24.5	33.0	41.5
4	5.7	0	7.0	14.0	21.0	29.0	37.0
5	5.7	0	7.0	13.5	21.0	28.0	36.0
6	5.7	0	7.0	13.5	21.0	28.0	35.0
7	6.7	0	6.5	12.0	19.0	25.0	31.5
8	6.7	0	6.0	12.0	18.5	24.5	31.0
9	6.7	0	6.0	12.0	18.0	24.0	31.0
10	7.7	0	5.5	10.5	16.5	21.5	27.5
11	7.7	0	5.5	10.5	16.5	21.5	27.5
12	7.7	0	5.0	10.5	16.5	21.5	28.0
13	8.7	0	5.0	10.0	15.0	19.5	25.5
14	8.7	0	5.0	10.0	15.0	20.0	25.5
15	8.7	0	5.0	10.0	15.0	20.0	25.6
16	9.7	0	4.5	8.5	13.0	18.0	23.0
17	9.7	0	4.5	9.0	13.0	17.5	23.0
18	9.7	0	4.0	8.5	13.0	17.5	23.0
19	10.7	0	4.0	8.0	12.5	17.0	22.0
20	10.7	0	4.0	8.0	12.5	17.0	22.0
21	10.7	0	4.0	8.0	13.0	17.0	22.0
22	11.2	0	4.0	8.0	12.0	16.0	20.5
23	11.2	0	4.0	8.0	12.0	16.0	21.0
24	11.2	0	4.0	8.0	12.0	16.0	21.0

PREPARED BY R. DALEAS	ATOMICS INTERNATIONAL A Division of North American Aviation, Inc.	PAGE 36
CHECKED BY		REPORT NO. NAA-SR-TDR 9232
DATE 11-15-63		MODEL NO.

TIME INTERVAL BETWEEN ELECTRODES (MILLISECONDS)

Run	1-2	2-3	3-4	4-5	5-6	1-6			
1.	8.0	8.0	9.0	8.0	9.0	42.0			
2.	8.0	8.0	8.5	7.5	9.0	41.0			
3	8.5	8.0	8.0	8.5	8.5	41.5			
AVG	8.17	8.0	8.5	8.0	8.83	41.5			
4	7.0	7.0	7.0	8.0	8.0	37.0			
5	7.0	6.5	7.5	7.0	8.0	36.0			
6	7.0	6.5	7.5	7.0	7.0	35.0			
AVG	7.0	6.67	7.33	7.33	7.67	36.0			
7	6.5	5.5	7.0	6.0	7.0	31.5			
8	6.0	6.0	6.5	6.0	6.5	31.0			
9	6.0	6.0	6.0	6.0	6.5	31.0			
AVG	6.17	5.83	6.5	6.0	6.67	31.17			
10	5.5	5.0	6.0	5.0	6.0	27.5			
11	5.5	5.0	6.0	5.0	6.0	27.5			
12	5.0	5.5	6.0	5.0	7.0	28.0			
AVG	5.33	5.17	6.0	5.0	6.33	27.67			
13	5.0	5.0	5.0	4.5	6.0	25.5			
14	5.0	5.0	5.0	5.0	5.5	25.5			
15	5.0	5.0	5.0	5.0	5.5	25.5			
AVG	5.0	5.0	5.0	4.83	5.67	25.5			
16	4.5	4.0	4.5	5.0	5.0	23.0			
17	4.5	4.5	4.0	4.5	5.5	23.0			
18	4.0	4.5	4.5	4.5	5.5	23.0			
AVG	4.17	4.33	4.33	4.5	5.33	23.0			
19	4.0	4.0	4.5	4.5	5.0	22.0			
20	4.0	4.0	4.5	4.5	5.0	22.0			
21	4.0	4.0	5.0	4.0	5.0	22.0			
AVG	4.0	4.0	4.67	4.33	5.0	22.0			
22	4.0	4.0	4.0	4.0	4.5	20.5			
23	4.0	4.0	4.0	4.0	5.0	21.0			
24	4.0	4.0	4.0	4.0	5.0	21.0			
AVG	4.0	4.0	4.0	4.0	4.83	20.83			