

~~CONFIDENTIAL~~

SNPO-C

~~RESTRICTED DATA - ATOMIC ENERGY ACT 1954~~

Records

MASTER

REVISION 1
TO
RN-S-0469

To AEC-NASA Space Nuclear Propulsion Office

E-1 COMMON ANALOG MODEL (U)

NERVA Program

Contract SNP-1

July 1969

~~GROUP-1
EXCLUDED FROM AUTOMATIC DOWNGRADING
AND DECLASSIFICATION
RESTRICTED DATA
ATOMIC ENERGY ACT OF 1954~~

DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED

1187

~~CONFIDENTIAL~~

~~DISTRIBUTION OF THIS DOCUMENT IS UNLIMITED~~

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency Thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

NOTICE

This report was prepared as an account of work sponsored by the United States Government. Neither the United States nor the United States Energy Research and Development Administration, nor any of their employees, nor any of their contractors, subcontractors, or their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights.

UNCLASSIFIED

Page 1 of 2
Revision: 1
Date: 5/15/69

CONTENTS

I. MODEL SUMMARY

MASTER

Revision

Date

A. Feed system

1. Pump Inlet Line (section deleted)	-	-
2. Turbopump	1	5/15/69
3. Pump Discharge Line	1	5/15/69
4. Turbine Exhaust Line	1	5/15/69

B. Reactor and Nozzle

1. Support System Connection to Nozzle Torus	1	5/15/69
2. Nozzle Skirt/Simulator Coolant Tubes	1	5/15/69
3. Nozzle Coolant Tubes	1	5/15/69
4. Reflector Inlet Plenum	1	5/15/69
5. Reflector and Peripheral Shield	1	5/15/69
6. Dome End Plenum	1	5/15/69
7. Shield and Support Plate (section deleted-shield & support plate effects included in core section)	-	-
8. Core Inlet Plenum (section deleted-core inlet plenum effects included in dome end plenum section)	-	-
9. Core and Core Periphery	1	5/15/69
10. Thrust Chamber	1	5/15/69
11. Turbine Inlet Line	1	5/15/69
12. Support System Inlet and Bypass	1	5/15/69
13. Support System	1	5/15/69
14. Reactivity	1	5/15/69
15. Kinetics	1	5/15/69
16. Skirt Extension	1	5/15/69

Class: 4
 TR 4
 C.C.S.
 Date 3-1-83

Classification cancelled (or changed) to
 by authority of Doc
 by H.A.C. TIC, date SEP 7 - 1973

UNCLASSIFIED

DISTRIBUTION OF THIS DOCUMENT UNLIMITED


UNCLASSIFIED

Page 2 of 2
Revision: 1
Date: 5/15/69


ENCLOSURE 1

	<u>Revision</u>	<u>Date</u>
C. Controls, Actuators, and Safety Circuits		
1. Nuclear Subsystem Controls	1	5/15/69
2. Propellant Feed System Controls	1	5/15/69
3. Emergency System Controls	-	-
D. Support Facility	-	-
II. DERIVATIONS		
A. General	-	-
B. Specific	-	-
III. MODEL CHECKS		
A. Design		
1. Steady State	1	5/15/69
2. Frequency Response	1	5/15/69
3. Transient Response	-	-
B. Low Power		
1. Steady State	1	5/15/69
2. Frequency Response	1	5/15/69
3. Transient Response	-	-
IV. NOMENCLATURE	1	5/15/69

APPROVED:


D. Buden, AGC 5-15-69
Date

ACKNOWLEDGED:


R. P. Rose, WANL 7/1/69
Date

UNCLASSIFIED

UNCLASSIFIED

Page 1 of 7
Revision: 1
Date: 5/15/69

I A-2 TURBOPUMP

Pump inlet conditions at station 3, high speed turbine inlet conditions at station 285 and low speed turbine exit conditions at station 30 are common to two parallel turbopumps. One of these turbopumps is described below in equations 2 through 20. The second is described by adding a final subscript "a" to all quantities in these equations except those at the common points.

$$1. P_3 = 30 \text{ psia}, T_3 = 40^\circ\text{R}$$

$$2. W_P = W_4$$

$$3. P_4 = P_3 + N^2 f \left(\frac{W_P}{N} \right)$$

$$4. P_{45} = P_4 + N_H^2 f \left(\frac{W_P}{N_H} \right)$$

$$5. T_{45} = T_3 + .015 P_{45}$$

$$6. M_P = -1.874 \times 10^{-6} N^2 + 1.021 \times 10^{-3} W_P N - .0590 W_P^2$$

$$\frac{W_P}{N} \geq .00626$$

$$= 2.27 \times 10^{-6} N^2$$

$$\frac{W_P}{N} < .00626$$

$$\text{Stall occurs at } \frac{W_P}{N} = .00518$$

$$7. M_{PH} = .3479 \times 10^{-6} N_H^2 + .4959 \times 10^{-3} W_P N_H - .04155 W_P^2$$

$$\frac{W_P}{N_H} \geq .0009194$$

$$= .7463 \times 10^{-6} N_H^2$$

$$\frac{W_P}{N_H} < .0009194$$

$$\text{Stall occurs at } \frac{W_P}{N_H} = .0009194$$

$$8. \frac{dR_{29}}{dt} = 11.0 (W_{TH} - W_T)$$

$$9. T_{29} = T_{27} \left\{ 1 - E_{T_H} \left[1 - \left(\frac{P_{29}}{P_{285}} \right)^{.286} \right] \right\}$$

$$10. \frac{dP_{29}}{dt} = -1000 (P_{29} - 5.32 R_{29} T_{29})$$

$$11. C_{OH} = 415.6 (T_{27})^{\frac{1}{2}} \left[1 - \left(\frac{P_{29}}{P_{285}} \right)^{.286} \right]^{\frac{1}{2}}$$

UNCLASSIFIED

UNCLASSIFIED

Page 2 of 7
Revision: 1
Date: 5/15/69

I A-2 TURBOPUMP

$$12. \frac{u_H}{C_{OH}} = .04333 \frac{N_H}{C_{OH}}$$

$$13. ET_H = f\left(\frac{u_H}{C_{OH}}\right)$$

$$14. W_{TH} = \frac{P_{285}}{\sqrt{T_{27}}} f\left(\frac{P_{285}}{P_{29}}\right)$$

$$15. M_{TH} = W_{TH} (.04364 C_{OH} - .003793 N_H)$$

$$16. C_O = 415.6 (T_{29})^{\frac{1}{2}} \left[1 - \left(\frac{P_{30}}{P_{29}}\right)^{.286} \right]^{\frac{1}{2}}$$

$$17. W_T = \frac{P_{29}}{\sqrt{T_{29}}} f\left(\frac{P_{29}}{P_{30}}\right)$$

$$18. M_T = W_T (.01729 C_O - .001435 N)$$

$$19. \frac{dN_H}{dt} = 73.22 (M_{TH} - M_{PH})$$

$$20. \frac{dN}{dt} = 114.6 (M_T - M_P)$$

I A-2 TURBOPUMP

TABLE I A-2-1

$\frac{W_P}{N}$	$f \left(\frac{W_P}{N} \right)$
0.000×10^{-3}	$.7166 \times 10^{-6}$
2.934	.5972
4.891	.5524
6.847	.5345
7.825	.5196
8.803	.4957
9.292	.4807
10.27	.4389
10.96	.3762
11.74	.2359

UNCLASSIFIED

Page 4 of 7
Revision: 1
Date: 5/15/69

I A-2 TURBOPUMP
TABLE I A-2-2

$\frac{W_P}{N_H}$	$f\left(\frac{W_P}{N_H}\right)$
0.000×10^{-3}	1.311×10^{-6}
.9194	1.320
.9194	1.383
1.272	1.359
1.712	1.299
2.299	1.191
2.788	1.069
3.423	0.860
3.912	0.660
4.842	0.000

UNCLASSIFIED

I A-2 TURBOPUMP
TABLE I A-2-3

$\frac{u_H}{C_{OH}}$	$f\left(\frac{u_H}{C_{OH}}\right)$
0	0
.04	.240
.08	.455
.12	.620
.14	.681
.16	.732
.18	.763
.20	.779
.22	.765
.26	.723

UNCLASSIFIED

Page 6 of 7
Revision: 1
Date: 5/15/69

I A-2 TURBOPUMP

TABLE I A-2-4

P_{285}/P_{29}	$f(P_{285}/P_{29})$
1.0	0
1.1	.160
1.2	.210
1.4	.267
1.6	.299
2.0	.331
2.5	.353
3.0	.365
5.0	.380
8.0	.383

UNCLASSIFIED

I A-2 TURBOPUMP
TABLE I A-2-5

P_{29}/P_{30}	$f(P_{29}/P_{30})$
1.0	0
1.06	.88
1.14	1.33
1.24	1.71
1.34	1.97
1.50	2.26
1.70	2.49
2.0	2.66
2.2	2.69
2.4	2.70

UNCLASSIFIED

Page 1 of 1
Revision: 1
Date: 5/15/69

I A-3 PUMP DISCHARGE LINE

$$1. \frac{dW_4}{dt} = 65.8 (P_{45} - P_{19}) - .283 W_4 |W_4| \quad W_4 \geq 0$$

$$2. \frac{dW_{4a}}{dt} = 65.8 (P_{45a} - P_{19}) - .283 W_{4a} |W_{4a}| \quad W_{4a} \geq 0$$

$$3. \frac{dP_{19}}{dt} = \frac{1810 + 1.4P_{19}}{13.26} (W_4 + W_{4a} - W_{SSI} - W_{SSB} - W_5)$$

$$4. T_{19} = T_{45}$$

UNCLASSIFIED

UNCLASSIFIED

Page 1 of 1
Revision: 1
Date: 5/15/69

I A-4 TURBINE EXHAUST LINE

$$1. P_{30} = 5.32R_{30}T_{30}$$

$$2. \frac{dR_{30}}{dt} = \frac{1}{3.4844} (W_T + W_{TA} - W_{31})$$

$$3. W_{31} = 40.5 \sqrt{\frac{R_{30} + R_{32}(P_{30} - P_{32})}{2}}$$

$$4. T_{30} = T_{29}$$

$$5. T_{31} = T_{30}$$

UNCLASSIFIED

UNCLASSIFIED

Page 1 of 1
Revision: 1
Date: 5/15/69

I B-1 SUPPORT SYSTEM CONNECTION TO NOZZLE TORUS

1. P_{19} See Section IA-3 Eq. 3
2. T_{19} See Section IA-3 Eq. 4
3. $T_5 = T_{19}$
4. $\frac{dW_5}{dt} = 60.9 (P_{19} - P_5) - .201 W_5 |W_5|$
5. $\frac{dP_5}{dt} = \frac{1810 + 1.4P_5}{4.37} (W_5 - W_{NC})$

UNCLASSIFIED

UNCLASSIFIED

Page 1 of 1
Revision: 1
Date: 5/15/69

1 B-2 NOZZLE SKIRT/SIMULATOR COOLANT TUBES

$$1. \quad \frac{dT_{SKC}}{dt} = .0347 \left(.296 |W_{NC}|^{.8} (\varphi_{SK} - T_{SKC}) - 3.79 W_{NC} (T_{SKC} - T_5) \right)$$

$$2. \quad \frac{dH_{SK}}{dt} = .00337 \left(.0576 |W_N|^{.8} (T_{15} - \varphi_{SK}) - .296 |W_{NC}|^{.8} (\varphi_{SK} - T_{SKC}) \right)$$

$$3. \quad \varphi_{SK} = 6.55 H_{SK} + 35$$

UNCLASSIFIED

UNCLASSIFIED

Page 1 of 1
Revision: 1
Date: 5/15/69

I B-3 NOZZLE COOLANT TUBES

1.
$$\frac{dT_{NC}}{dt} = .2510 \left(.8200 |W_{NC}|^{.8} (\varphi_N - T_{NC}) - 3.840 W_{NC} (T_{NC} - T_{SKC}) \right)$$
2.
$$\frac{dH_N}{dt} = .001039 \left(.3070 |W_N|^{.8} (T_{15} - \varphi_N) - .8200 |W_{NC}|^{.8} (\varphi_N - T_{NC}) \right)$$
3.
$$\varphi_N = 3.230 H_N + 870.0$$
4.
$$\frac{dW_{NC}}{dt} = 99.80 \left(P_5 - P_7 - \frac{.02732}{R_7} |W_{NC}| W_{NC} \right)$$

UNCLASSIFIED

UNCLASSIFIED

Page 1 of 3
Revision: 1
Date: 5/15/69

I B-4 REFLECTOR INLET PLENUM

$$1. \frac{dR_7}{dt} = .2919 (W_{NC} - W_R - W_{DB})$$

$$2. \frac{dT_7}{dt} = \frac{.2919}{R_7} (W_{NC} T_{NC} - W_R T_7 - W_{DB} T_7)$$

$$3. P_7 = T_7 f_1(R_7) - f_2(R_7)$$

$$4. T_{7 \min} = 52. + .043 P_7$$

$$P_7 < 210 \text{ psia}$$

UNCLASSIFIED

UNCLASSIFIED

Page 2 of 3
Revision: 1
Date: 5/15/69

I B-4 REFLECTOR INLET PLENUM

TABLE I B-4-1

R_7 (lb/ft ³)	$f_1(R_7)$ (psia/°R)
0.0000	0.000
0.2516	1.426
0.6290	3.881
0.8806	5.733
1.132	7.787
1.635	12.53
2.020	16.62
2.520	23.20
3.019	31.87
3.271	37.15
3.744	49.82

UNCLASSIFIED

UNCLASSIFIED

Page 3 of 3
Revision: 1
Date: 5/15/69

I B-4 REFLECTOR INLET PLENUM

TABLE I B-4-2

R_7 (lb/ft ³)	$f_2(R_7)$ (psia)
0.0000	0.0
0.2516	15.63
0.5032	60.06
1.040	224.2
1.384	410.7
1.824	674.7
2.390	1089.0
2.768	1420.0
3.500	2160.0
3.744	2371.0

UNCLASSIFIED

UNCLASSIFIED

Page 1 of 2
Revision: 1
Date: 5/15/69

I B-5 REFLECTOR AND PERIPHERAL SHIELD

- 1) $\frac{d}{dt} H_r = .0002509 \left(1.774 \left| W_r \right| (T_7 - \phi_r) + 159.0 S_{NQ} \right)$
- 2) $\phi_r = f(H_r)$ (See Table I B-5-1)
- 3) $T_9 = .6419 \phi_r - (.6419 - 1) T_7$
- 4) $W_r = 12.04 \left(R_{10} \left| P_7 - P_{10} \right| \right)^{.5} \left[\frac{(P_7 - P_{10})}{\left| P_7 - P_{10} \right|} \right]$

UNCLASSIFIED

I B-5 REFLECTOR AND PERIPHERAL SHIELD (continued)

TABLE I B-5-1

ϕ_r vs H_r

<u>H_r (BTU/lb.)</u>	<u>ϕ_r ($^{\circ}$R)</u>
0	0
5	185
10	235
15	275
20	310
25	335
30	360
35	385
40	405
45	425
50	445
55	465
60	480
100	605

~~CONFIDENTIAL~~

Page 1 of 1
Revision: 1
Date: 5/15/69

I B-6 DOME END PLENUM

$$1) \quad \frac{d}{dt} R_{10} = .04824 (W_r + W_{ss} + W_{ssb} - W_c)$$

$$2) \quad \frac{d}{dt} T_{10} = .09648 (W_r T_9 + W_{ss} T_{22} + W_{ssb} T_{19} - W_c T_{10})$$

$$3) \quad P_{10} = 5.32 R_{10} T_{10}$$

~~CONFIDENTIAL~~

I B-9 CORE AND CORE PERIPHERY

- 1) $\frac{d}{dt} H_{c1} = .0009772 \left(3.699 |W_c| (T_{10} - \phi_{c1}) + 3995.S \right)$
- 2) $\phi_{c1} = f(H_{c1})$ (See Table I B-9-1)
- 3) $T_{c1e} = 1.057 \phi_{c1} - (1.057 - 1) T_{10}$
- 4) $\frac{d}{dt} H_{c2} = .0009772 \left(4.362 |W_c| (T_{c1e} - \phi_{c2}) + 6518.S \right)$
- 5) $\phi_{c2} = f(H_{c2})$ (See Table I B-9-1)
- 6) $T_{c2e} = 1.176 \phi_{c2} - (1.176 - 1) T_{c1e}$

I B-9 CORE AND CORE PERIPHERY (continued)

- 7) $\frac{d}{dt} H_{c3} = .0009772 \left(4.052 |W_c| (T_{c2e} - \phi_{c3}) + 3740.9 \right)$

- 8) $\phi_{c3} = f(H_{c3})$ (See Table I B-9-1)

- 9) $T_{15} = \left(.8926 \phi_{c3} - (.8926 - 1) T_{c2e} \right) .9918$

- 10) $\phi_c = .125 (3 \phi_{c1} + 2 \phi_{c2} + 3 \phi_{c3})$

- 11) $R_c = .159 R_{10} + .841 R_{15}$

- 12) $W_c = \left[\frac{|P_{10} - P_{15}|}{\frac{.005951}{R_{10}} + \frac{1.906 \times 10^{-4}}{R_{15}}} \right]^{.5} \cdot \left[\frac{(P_{10} - P_{15})}{|P_{10} - P_{15}|} \right]$

UNCLASSIFIED

Page 3 of 3
Revision: 1
Date: 5/15/69

I B-9 CORE AND CORE PERIPHERY (continued)

TABLE I B-9-1

ϕ_{cn} vs H_{cn} $n = 1, 2, 3$

<u>H_{cn} (BTU/lb.)</u>	<u>ϕ_{cn} ($^{\circ}$R)</u>
0.	0.
200.	1110.
400.	1630.
600.	2085.
800.	2530.
1000.	2950.
1200.	3350.
1400.	3760.
1600.	4170.
1800.	4580.
2000.	4990.
2200.	5400.
2400.	5810.

UNCLASSIFIED

UNCLASSIFIED

Page 1 of 1
Revision: 1
Date: 5/15/69

1 B-10 THRUST CHAMBER

$$1. \frac{dR_{15}}{dt} = .04346(W_C - W_N - W_{HB})$$

$$2. P_{15} = 5.32R_{15} T_{15}$$

$$3. W_N = \left[\frac{12.99P_{15}}{T_{15}^{.5}} \right]$$

$$4. \frac{dT_{15M}}{dt} = \frac{W_N^{.5}}{2.85} (T_{15} - T_{15M})$$

UNCLASSIFIED

UNCLASSIFIED

Page 1 of 2
Revision: 1
Date: 5/15/69

IB-11 TURBINE INLET LINE

1. $W_{27} = 3.96 \sqrt{R_{27}(P_{15} - P_{27})}$
2. $W_{DB} = .2045 \sqrt{R_7(P_7 - P_{15})}$
3. $W_{HB} = W_{27} - W_{DB}$
4. $P_{27} = 5.32 R_{27} T_{27}$
5. $\frac{dR_{27}}{dt} = \frac{1}{1.215} (W_{27} - W_V - W_{Va})$
6. $\frac{dT_{27}}{dt} = \frac{1}{1.215 R_{27}} \left[W_{HB}(T_{15} - T_{27}) - W_{DB}(T_{27} - T_7) \right]$
7. $W_V = 4f(\theta_V) \left[\frac{1}{2}(R_{27} + R_{285})(P_{27} - P_{285}) \right]^{\frac{1}{2}}$
8. $W_{Va} = 4f(\theta_{Va}) \left[\frac{1}{2}(R_{27} + R_{285})(P_{27} - P_{285}) \right]^{\frac{1}{2}}$
9. $\frac{dR_{285}}{dt} = \frac{1}{.1636} (W_V + W_{Va} - W_{TH} - W_{THa})$
10. $P_{285} = 5.32 R_{285} T_{27}$

UNCLASSIFIED

UNCLASSIFIED

Page 2 of 2
Revision: 1
Date: 5/15/69

I. B-11 TURBINE INLET LINE

TABLE I B-11-1

θ_v, θ_{va}	$f(\theta_v), f(\theta_{va})$
0	.00372
10	.01607
20	.03453
25	.1064
30	.1765
35	.2649
40	.3784
45	.5021
50	.6170
55	.7196
60	.7914
65	.8470
70	.8871
75	.9058
80	.9078
85	.8951
90	.8700

UNCLASSIFIED

I B-12 SUPPORT SYSTEM INLET AND BYPASS

- 1) θ_{ssv} = Independent variable
- 2) F_{ssv} = $f(\theta_{ssv})$ (See Table I B-12-1)
- 3) W_{ssi} = $3.472 F_{ssv} |P_{19} - P_{20}|^{.5} \left[\frac{(P_{19} - P_{20})}{|P_{19} - P_{20}|} \right]$
- 4) F_{ssb} = $f(\theta_{ssv})$ (See Table I B-12-2)
- 5) W_{ssb} = $.9343 F_{ssb} |P_{19} - P_{10}|^{.5} \left[\frac{(P_{19} - P_{10})}{|P_{19} - P_{10}|} \right]$
- 6) $\frac{d}{dt} P_{20}$ = $985.6 (W_{ssi} - W_{ss})$

I B-12 SUPPORT SYSTEM INLET AND BYPASS (continued)

TABLE I B-12-1

 F_{ssv} vs θ_{ssv}

θ_{ssv} (Deg.)	F_{ssv}
0.0	0.13013
7.0787	0.15335
17.191	0.18975
27.303	0.23095
37.416	0.27868
47.528	0.33580
57.640	0.40747
67.753	0.50332
77.865	0.64650
87.978	0.91153
90.000	1.00000

I B-12 SUPPORT SYSTEM INLET AND BYPASS (continued)

TABLE I B-12-2

 F_{ssb} vs θ_{ssv}

<u>θ_{ssv} (Deg.)</u>	<u>F_{ssb}</u>
0.0	1.0000
7.0787	0.9552
17.191	0.8913
27.303	0.8275
37.416	0.7637
47.528	0.6999
57.640	0.6362
67.753	0.5728
77.865	0.5089
87.978	0.4453
90.00	0.4325

I B-13 SUPPORT SYSTEM

- 1) $T_{20} = T_{19}$
- 2) $T_{ss1} = T_{20} + \left[\frac{.5837}{1 + 1.351|W_{ss}|} \right] (T_{ss4} - T_{ss1})$
- 3) $T_{ss1e} = 2 T_{ss1} - T_{20}$
- 4) $T_{ss2} = T_{ss1e} + 1.895 (\phi_{t2i} - T_{ss2})$
- 5) $T_{ss2e} = 2 T_{ss2} - T_{ss1e}$
- 6) $T_{ss3} = T_{ss2e} + 9.390 (\phi_{t2o} - T_{ss3}) + 2.066 (\phi_{t3j} - T_{ss3})$
- 7) $T_{ss3e} = 1.3 T_{ss3} - .3 T_{ss2e}$
- 8) $T_{ss4} = T_{ss3e} + \left[\frac{.5857}{1 + 1.351|W_{ss}|} \right] (T_{ss1} - T_{ss4})$
- 9) $T_{22} = 2 T_{ss4} - T_{ss3e}$

I B-13 SUPPORT SYSTEM (continued)

- 10) $\phi_{t2i} = \phi_{t2} + 1.054 |W_{ss}| (T_{ss2} - \phi_{t2i})$
- 11) $\phi_{t2o} = \phi_{t2} + .05321 |W_{ss}| (T_{ss3} - \phi_{t2o})$
- 12) $\phi_{t3i} = \phi_{t3} + .02171 |W_{ss}| (T_{ss3} - \phi_{t3i})$
- 13) $\frac{d}{dt} \phi_{t2} = 38.62 (\phi_{t2o} - \phi_{t2}) - .6024 (\phi_{t2} - \phi_{t2i}) + 2.419 S_{NQ}$
- 14) $\frac{d}{dt} \phi_{t3} = 1.157 (\phi_p - \phi_{t3}) - 57.04 (\phi_{t3} - \phi_{t3i}) + 2.123 S_{NQ}$

I B-13 SUPPORT SYSTEM (continued)

$$15) \frac{d}{dt} \phi_p = .3089 (\phi_{sg} - \phi_p) - .3312 (\phi_p - \phi_{t3}) + 1.0875 S_{NQ}$$

$$16) \frac{d}{dt} \phi_{sg} = 1.930 (\phi_{c2} - \phi_{sg}) - .08184 (\phi_{sg} - \phi_p) + .9786 S_{NQ}$$

$$17) P_{ss2} = P_{20} - .02005 (P_{20} - P_{10})$$

$$18) R_{ss2} = \left[\frac{P_{ss2}}{5.32 T_{ss2}} \right]$$

$$19) P_{ss2e} = P_{20} - .5355 (P_{20} - P_{10})$$

$$20) R_{ss2e} = \left[\frac{P_{ss2e}}{5.32 T_{ss2e}} \right]$$

$$21) R_{ss} = .7913 R_{ss2} + (1 - .7913) .4650 R_{ss2e}$$

$$22) W_{ss} = .8836 \left(R_{ss2e} |P_{20} - P_{10}| \right)^{.5} \left[\frac{(P_{20} - P_{10})}{|P_{20} - P_{10}|} \right]$$

UNCLASSIFIED

Page 1 of 1
Revision: 1
Date: 5/15/69

I B-14 REACTIVITY

$$1) \quad Dk_f = 21.31 R_c + 1.973 R_{ss} - 8.0 \times 10^{-4} (\phi_c - 520.0)$$

$$2) \quad Dk_d = 6.900 \sin^2 \left(\frac{\theta_{DM}}{2} \right) - 4.687$$

$$3) \quad Dk_t = Dk_f + Dk_d$$

UNCLASSIFIED

UNCLASSIFIED

Page 1 of 1
Revision: 1
Date: 5/15/69

I B-15 KINETICS

$$1) \quad \frac{d}{dt} S_N = 295.8 (Dk_t - 1) S_N + .0276 Cl_1 + .235 Cl_2 + 1.65 Cl_3$$

$$2) \quad \frac{d}{dt} Cl_1 = 81.07 S_N - .0276 Cl_1$$

$$3) \quad \frac{d}{dt} Cl_2 = 165.32 S_N - .235 Cl_2$$

$$4) \quad \frac{d}{dt} Cl_3 = 49.41 S_N - 1.65 Cl_3$$

$$5) \quad \frac{d}{dt} Q = .00635 (.06839 S_N - Q)$$

$$6) \quad S_{NQ} = 6.409 Q + .6301 S_N$$

$$7) \quad S = Q + S_N$$

UNCLASSIFIED

UNCLASSIFIED

Page 1 of 1
Revision: 1
Date: 5/15/69

I B-16 SKIRT EXTENSION

$$1. P_{32} = 5.32 R_{32} T_{32}$$

$$2. \frac{dR_{32}}{dt} = \frac{1}{2.3148} (W_{31} - W_{32})$$

$$3. T_{32} = T_{31}$$

$$4. W_{32} = 6.26 \frac{P_{32}}{\sqrt{T_{32}}}$$

UNCLASSIFIED

I C-1 NUCLEAR SUBSYSTEM CONTROLS

- 1) $T_{15D} =$ Independent variable
- 2) $T_{15E} = T_{15D} - T_{15M}$
- 3) $\frac{\theta_{D_M}^D}{\theta_{D_D}^D} = \frac{1}{1 + 0.16s + 0.025s^2}$
- 4) $\theta_{D_D}^D = \theta_{D_{D1}}^D + \theta_{D_{D2}}^D + \theta_{D_{D3}}^D$
- 5) $T_{15EC} = T_{15E}$ for $|T_{15E}| < 180$
 $= 180$ for $T_{15E} \geq 180$
 $= -180$ for $T_{15E} \leq -180$
- 6) $\frac{\theta_{D_{D1}}^D}{T_{15EC}} = \frac{0.1 (1 + 1.25s) (1 + 0.3s)}{(1 + 5.0s)(1 + 0.02s)}$

I C-1 NUCLEAR SUBSYSTEM CONTROLS (continued)

$$7) \quad \frac{\theta_{D2}^D}{T_{15EC}} = \frac{1.0 \cdot 10^{-4}}{s}$$

$$8) \quad \frac{d}{dt} \theta_{D3}^D = \begin{array}{ll} 0 & \text{for } |T_{15EC}| < 100 \\ 2 & \text{for } T_{15EC} \geq 100 \\ -2 & \text{for } T_{15EC} \leq -100 \text{ and } T_{15M} < 4500 \\ -7 & \text{for } T_{15EC} \leq -100 \text{ and } T_{15M} \geq 4500 \end{array}$$

I C-2 PROPELLANT FEEDSYSTEM CONTROLS

$$1. P_{15E} = P_{15D} - P_{15}$$

$$2. \frac{\theta_{VD}}{P_{15E}} = \frac{.05623 (1 + 10S)(1 + .5555S)}{S (1 + 1.5873S)(1 + .01S)}$$

$$3. \frac{\theta_V}{\theta_{VD}} = \frac{\theta_{Va}}{\theta_{VD}} = \frac{1}{1.75 \times 10^{-4} S^2 + 1.3 \times 10^{-2} S + 1}$$

$$0 < \phi_V, \theta_{VA} < 90^\circ$$

$$-450 < \dot{\theta}_V, \dot{\theta}_{Va} < 450^\circ/\text{sec}$$

STEADY STATE VARIABLES (Y(I))

CI1	2.8100 05	CI2	6.7710 04	CI3	2.8650 03	HC1	3.7500 02
HC2	1.2200 01	HC3	1.8970 03	HN	2.1890 02	HR	2.7540 01
H5K	1.3900 02		0.0	P5	9.1300 02	P19	9.3480 02
P20	8.5730 02	P24	3.5020 01	P29A	3.5720 01	P4P	2.1870 03
PH3G	3.3910 03	PHT2	5.4830 02	PHTJ	7.2710 02		0.0
Q	6.5430 00	R7	-6.3450 -01	R10	-3.9990 -01	R15	-1.8290 -02
R27	4.3600 -02	R2E5	2.4020 -02	R2E5A	2.4130 -02	R29	5.1150 -03
R29A	5.1150 -03	R30	3.7200 -03	R32	3.3220 -03	RPM	7.5500 03
RPMA	7.5500 03	RPMH	2.6050 04	RFMHA	2.6790 04	SN	9.5680 01
T7	2.0850 02	T1F	3.0220 02	T15M	4.5500 03	T27	1.6610 03
		T5K	6.2980 01		3.7510 01	T4D	9.0510 01
TNC	2.0850 02		0.0	THDD2	0.0	THDD3	0.0
	0.0510 01	TPSSV	4.7530 01		3.0010 01	THV	3.0010 01
	4.5700 01	THVA	-3.0010 01		-3.0010 01		-3.0010 01
	3.0010 01	W4	4.4960 01	W4A	4.4960 01		0.0
THVD	3.0010 01	WNC	6.8480 01		0.0	CT27	2.7450 -01
W5	6.8480 01						

CO	4.3980 03	COA	4.3980 03	COH	1.0750 04	COHA	1.0750 04	DKD	-1.2060 00
DKF	1.2060 00	DKT	-5.6510 -07	ETH	3.5880 -01	ETHA	5.5880 -01	P3	3.0000 01
P3A	3.0000 01	P4	6.0930 01	P4A	5.0930 01	P45	9.4350 02	P45A	9.4350 02
	0.0		0.0		0.0		0.0	P7	7.1740 02
P10	6.4270 02	P1E	4.5000 02	P15D	4.5000 02	P15E	1.2700 -09	P27	4.2930 02
P2E5	2.1220 02	P2E5A	2.1220 02	P30	2.5470 01	P31	0.0	P32	2.2750 01
PSS2	8.5300 02	PSS2E	7.4240 02	PHC	3.2280 03	PHC1	1.5670 03	PHC2	3.3900 03
	0.0		0.0		0.0		0.0	PHC3	4.7750 03
PHN	1.5770 03	PHR	3.4770 02	PHSK	9.4250 02	PHT2J	1.9240 02	PHT2PH	5.4750 02
PHF3J	6.9570 02	RC	7.8950 -02	RSS	9.5540 -01	RSS2	1.0050 00	RSS2E	6.2900 -01
S	1.0220 02	SNQ	1.0220 02	T3	4.0000 01	T45	5.4150 01	T45A	5.4150 01
	0.0		0.0		0.0		0.0	T5	5.4150 01
T9	2.9790 02	T1E	4.6250 03	T15D	4.6250 03	T15E	0.0	T20	5.4150 01
T22	6.0010 02	T29	1.2870 03	T29A	1.2870 03	T30	1.2870 03	T31	1.2870 03
T32	1.2870 03	TC1E	1.6400 03	TC2E	3.6980 03	TSS1	7.5660 01	TSS1E	9.7170 01
TSS2	1.5950 02	TSS2E	2.2180 02	TSS3	5.4590 02	TSS3E	6.4320 02	TSS4	6.2160 02
	0.0		0.0		0.0	TROP	1.2940 02	TROPA	1.2940 02
TROPH	7.3440 02	TROPHA	7.3440 02	TRQT	1.2940 02	TRQTA	1.2940 02	TRQTH	7.3440 02
TRQTHA	7.3440 02	THDD	9.0510 01	THDD1	0.0	THSSVD	4.7530 01	UCOH	1.0520 -01
	0.0		0.0		0.0		0.0	UCOHA	1.0520 -01
W27	3.9690 00	W31	3.9690 00	W32	3.9590 00	WC	8.7260 01	WDB	2.6640 00
WHB	1.3050 00	WN	8.5950 01	WP	4.4960 01	WPA	4.4960 01	WR	6.5810 01
WSS	1.0270 01	WSEB	1.1180 01	WSSI	1.0270 01	WT	1.9850 00	WTA	1.9850 00
	0.0	WTF	1.5850 00						
WV	1.9850 00	WVA	1.5850 00						

CONFIDENTIAL

CONFIDENTIAL

III A-1 DESIGN STEADY STATE

UNCLASSIFIED

IIIA 2 DESIGN FREQUENCY RESPONSE

Page 1 of 4
Revision: 1
Date: 5/15/69

(RAD./SEC.)	MAGNITUDE	$\frac{\Delta T_{15}}{\Delta \theta_{cr}}$		MAGNITUDE	$\frac{\Delta T_{15}}{\Delta \theta_{cr}}$		MAGNITUDE	$\frac{\Delta T_{15}}{\Delta \theta_{cr}}$	
		DECIBELS	PHASE		DECIBELS	PHASE		DECIBELS	PHASE
1.0000-07	3.7560 03	71.885	0.001	3.2180 02	50.152	0.001	1.3120 02	42.359	0.001
2.0000-03	4.1280 03	72.313	18.102	3.4580 02	50.775	16.735	1.4100 02	42.984	16.614
3.0000-03	4.5090 03	73.263	26.378	3.8070 02	51.610	21.681	1.5520 02	43.820	24.484
4.0000-03	5.7570 03	75.203	35.213	4.6640 02	53.375	33.651	1.9030 02	45.587	33.325
5.0000-02	8.5140 03	78.602	39.199	6.7650 02	55.506	38.395	2.7600 02	48.819	38.062
6.0000-02	1.4470 04	82.185	25.798	1.1360 03	51.110	6.821	4.6370 02	53.323	25.945
7.0000-02	1.7740 04	84.578	-16.997	1.4020 03	52.923	-3.984	5.7170 02	55.143	-15.395
8.0000-02	1.3280 04	82.461	-50.209	1.0620 03	50.520	-45.054	4.3250 02	52.720	-47.291
9.0000-02	1.3280 04	82.461	-50.209	1.0620 03	50.520	-45.054	4.3250 02	52.720	-47.291
1.0000-01	4.3990 03	72.866	-95.454	6.9420 02	56.829	-76.520	2.8200 02	49.004	-74.080
1.5700-01	2.4040 03	67.618	-99.694	3.6790 02	51.314	-83.951	1.4830 02	43.421	-89.589
2.0000-01	1.4390 03	62.163	-102.426	2.0930 02	46.435	-83.356	8.2970 01	38.378	-91.965
3.0000-01	8.9560 02	56.041	-109.472	1.3450 02	42.573	-79.605	5.0980 01	34.147	-92.302
4.0000-01	5.2390 02	54.384	-121.244	9.2370 01	39.710	-78.445	3.2420 01	30.217	-95.732
5.0000-01	2.7700 02	48.851	-135.897	6.2690 01	35.944	-79.535	1.9530 01	25.816	-101.076
6.0000-01	1.3350 02	42.510	-150.364	4.1680 01	32.399	-81.277	1.1100 01	20.908	-105.550
7.0000-01	5.7240 01	35.154	-163.217	2.7670 01	28.841	-83.000	6.2060 00	15.857	-107.265
8.0000-01	2.3490 01	27.416	-173.259	1.8000 01	25.134	-84.862	3.4380 00	10.727	-105.782
9.0000-01	9.2770 00	19.348	-181.319	1.1640 01	21.316	-86.906	2.0100 00	6.063	-102.686
1.0000-00	3.6540 00	11.256	-189.037	7.3820 00	17.363	-88.772	1.2250 00	1.765	-100.279
1.5700-00	1.4800 00	5.000	-198.686	4.6470 00	13.344	-90.410	7.6650 01	-2.310	-109.286
2.0000-00	5.7850 01	5.000	-213.129	2.9610 00	9.427	-94.263	4.8780 01	-6.236	-103.094
3.0000-00	2.2010 01	5.000	-233.106	1.8560 00	5.372	-94.218	3.0190 01	-10.403	-109.172
4.0000-00	7.7990 02	5.000	-259.749	1.1690 00	1.356	-97.218	1.8270 01	-14.766	-118.862
5.0000-00	2.5180 02	5.000	-69.540	7.2570 01	-2.784	-101.752	1.0360 01	-19.695	-133.111
6.0000-00				4.4140 01	-7.103	-108.554	5.3070 02	-25.000	-151.880

(RAD./SEC.)	MAGNITUDE	$\frac{\Delta P_{15}}{\Delta \theta_v}$		MAGNITUDE	$\frac{\Delta P_{15}}{\Delta \theta_d}$		MAGNITUDE	$\frac{\Delta P_{15}}{\Delta \theta_{gy}}$	
		DECIBELS	PHASE		DECIBELS	PHASE		DECIBELS	PHASE
1.0000-07	4.3080 02	52.685	0.001	3.1520 01	29.971	0.001	1.2880 01	22.199	0.001
2.0000-03	4.6340 02	53.319	16.916	3.4080 01	30.650	17.909	1.3930 01	22.877	17.747
3.0000-03	5.1090 02	54.167	24.925	3.7800 01	31.549	26.300	1.5440 01	23.774	26.050
4.0000-03	6.2770 02	55.654	33.929	4.6860 01	33.417	35.637	1.9140 01	25.639	35.253
5.0000-02	9.1340 02	58.216	38.839	6.8910 01	36.765	40.739	2.8140 01	28.985	40.151
6.0000-02	1.5410 03	63.757	26.897	1.1710 02	41.373	28.992	4.7810 01	33.590	28.094
7.0000-02	1.9110 03	65.623	-14.271	1.4630 02	43.303	-11.686	5.9680 01	35.517	-13.098
8.0000-02	1.4540 03	63.249	-46.022	1.1280 02	41.744	-42.578	4.5970 01	33.250	-44.800
9.0000-02	9.5250 02	55.577	-72.636	7.5870 01	37.501	-68.295	3.0850 01	29.785	-71.814
1.0000-01	5.0310 02	54.033	-87.883	4.1620 01	32.396	-83.257	1.6810 01	24.513	-88.809
1.5700-01	2.8270 02	46.012	-89.927	2.4280 01	27.705	-85.713	9.5630 00	19.702	-94.224
2.0000-01	1.7230 02	44.727	-89.712	1.5500 01	23.853	-86.495	6.0000 00	15.563	-99.171
3.0000-01	1.0060 02	40.555	-91.459	1.0470 01	20.412	-90.991	3.7880 00	11.568	-108.932
4.0000-01	6.1160 01	35.729	-90.697	6.6930 00	16.512	-90.792	2.1990 00	6.846	-123.614
5.0000-01	3.7010 01	31.366	-80.473	3.8830 00	11.782	-110.678	1.1280 00	1.049	-141.618
6.0000-01	2.8870 01	28.207	-72.752	2.0480 00	6.228	-119.636	5.0360 01	-5.959	-161.299
7.0000-01	2.2730 01	27.132	-77.649	9.9530 01	-3.041	-123.023	1.7010 01	-15.384	-185.920
8.0000-01	1.6270 01	24.205	-88.079	5.0050 01	-6.310	-121.174	3.5150 02	-29.082	-251.051
9.0000-01	1.0720 01	20.667	-100.844	2.6280 01	-11.676	-116.880	5.1030 02	-25.849	-5.470
1.0000-00	6.7480 00	16.583	-116.313	1.4500 01	-16.773	-112.211	6.8490 02	-23.288	-23.050
1.5700-00	4.1660 00	12.373	-134.991	8.3850 02	-21.529	-108.700	7.2700 02	-22.768	-46.960
2.0000-00	2.4490 00	7.776	-158.858	4.7340 02	-26.495	-105.735	7.0260 02	-23.065	-77.101
3.0000-00	1.4180 00	3.033	-185.690	2.6490 02	-31.530	-100.152	6.2990 02	-24.114	-113.900
4.0000-00	7.9760 01	-2.004	-211.565	1.5820 02	-35.300	-88.672	5.1900 02	-25.697	-156.386
5.0000-00	4.3100 01	-7.311	-229.186	1.1480 02	-35.300	-78.176	3.7990 02	-28.406	-199.278


Both turbine power control valves are moved

UNCLASSIFIED

CONTROLS & ACTS OUT P15=450, T15=4625, THSSV=47.53 X1=THV, X2=THD, X3=THSSV
PROGRAM E61904 TIME AND FREQUENCY TRANSFER FUNCTION (T15)/(X2)

Revisor 1


IIIA-2
Page 2 of 4



CONTROLS & ACTS OUT P15=450, T15=4625, THSSV=47.53 X1=THV, X2=THD, X3=THSSV
PROGRAM E61904 TIME AND FREQUENCY TRANSFER FUNCTION (T15)/(X3)

Revision 1


IIIA-2
Page 3 of 4



CONTRLRS & ACTS OUT P15=450.T15=4625.THSSV=47.53 X1=THV.X2=THD.X3=THSSV
PROGRAM E61904 TIME AND FREQUENCY TRANSFER FUNCTION (P15)/(X1)

Revision 1

IITA-2
Page 4 of 4



STEADY STATE VARIABLES (V(I))		RANGES	
C11	1.660D 04	C12	3.976D 03
HC2	1.342D 02		1.860D -02
HSK	3.017D 01		0.0
P20	1.451D 02	R29	3.789D 00
PHSG	7.426D 02	PHT2	3.926D 02
Q	3.866D -01	R7	2.586D -01
R27	3.434D -02	R285	1.323D -02
R29A	2.755D -03	R30	2.004D -03
RPMA	9.563E-03	RPMH	5.220D 03
T7	8.412D 01	T1C	1.052D 02
TNC	8.412D 01	TSKC	5.011D 01
	9.738D 01		0.0
	4.753D 01	THSSV	4.753D 01
	2.667D 01	THVA	2.667D 01
THVD	2.667D 01	W4	1.280D 01
W5	1.918D 01	WNC	1.918D 01

C13	1.693D 02
HN	-1.543D -02
P5	1.458D 02
P29A	3.789D 00
PHT3	4.917D 02
R10	1.657D -01
R28	1.567D -02
RPMH	5.220D 03
T15M	1.000D 03
	2.667D 01
	2.667D 01
W4A	1.280D 01
	0.0

MC1	6.616D 01
MR	3.066D -00
P19	1.470D 02
P1P	6.230D 02
	0.0
R15	1.128D -02
R29	2.755D -03
RPM	2.535D 03
SN	5.652D 00
T27	3.191D 02
THD	9.738D 01
THDD3	0.0
THV	2.667D 01
	2.667D 01
	0.0
CT27	2.045D -01

CD	1.971D 03	COA	1.971D 03	COH	4.689D 03	COHA	4.689D 03	DKD	-7.939D -01
DKF	7.939D -01	DKT	-6.032D -07	ETH	4.754D -01	ETHA	4.764D -01	P3	3.000D 01
P3A	3.000D 01	P4	3.354D 01	P4A	3.354D 01	P45	1.477D 02	P45A	1.477D 02
	0.0		0.0		0.0		0.0	P7	1.069D 02
P10	9.272D 01	P1E	6.000D 01	P15D	5.000D 01	P15E	-2.870D -08	P27	5.829D 01
P285	2.247D 01	P285A	2.247D 01	P30	2.755D 00	P31	0.0	P32	2.461D 00
PSS2	1.441D 02	PSS2E	1.171D 02	PHC	7.110D 02	PHC1	3.672D 02	PHC2	7.446D 02
	0.0		0.0		0.0		0.0	PHC3	1.032D 03
PHN	3.716D 02	PHR	1.134D 02	PHSK	2.326D 02	PHT2J	3.013D 02	PHT2PH	3.936D 02
PHT3J	4.888D 02	RC	3.584D -02	RSS	9.275D -02	RSS2	1.095D -01	RSS2E	6.293D -02
S	6.039D 00	SNQ	6.035D 00	T3	4.000D 01	T45	4.222D 01	T45A	4.222D 01
	0.0		0.0		0.0		0.0	T5	4.222D 01
T9	1.029D 02	T1E	1.000D 03	T15D	1.000D 03	T15E	0.0	T20	4.222D 01
T22	3.200D 02	T29	2.585D 02	T29A	2.585D 02	T30	2.585D 02	T31	2.585D 02
T32	2.585D 02	TC1E	3.821D 02	TC2E	8.094D 02	TSS1	9.359D 01	TSS1E	1.450D 02
TSS2	2.473D 02	TSS2E	3.496D 02	TSS3	4.059D 02	TSS3E	4.228D 02	TSS4	3.714D 02
	0.0		0.0		0.0		0.0	TRQP	1.458D 01
TRQPH	8.129D 01	TRQPHA	8.129D 01	TRQT	1.458D 01	TRQTA	1.458D 01	TRQTH	8.129D 01
TRQTHA	8.129D 01	THDD	9.738D 01	THDD1	0.0	THSSVD	4.753D 01	UCOH	8.519D -02
	0.0		0.0		0.0		0.0	UCOHA	8.519D -02
W27	9.582D -01	W31	9.582D -01	W32	9.582D -01	WC	2.489D 01	WDB	7.123D -01
WHB	2.459D -01	WN	2.465D 01	WP	1.280D 01	WPA	1.280D 01	WR	1.847D 01
WSS	1.604D 00	WSSB	4.820D 00	WSSI	1.604D 00	WT	4.791D -01	WTA	4.791D -01
	0.0	WTH	4.791D -01		0.0		0.0	WTHA	4.791D -01
WV	4.791D -01	WVA	4.791D -01						

III B-1 LOW POWER STEADY STATE

UNCLASSIFIED

UNCLASSIFIED

III B-2 LOW POWER FREQUENCY RESPONSE


(RAD./SEC.)	MAGNITUDE	$\frac{\Delta T_{15}}{\Delta \theta_V}$	DECIBELS	PHASE	MAGNITUDE	$\frac{\Delta T_{15}}{\Delta \theta_d}$	DECIBELS	PHASE	MAGNITUDE	$\frac{\Delta T_{15}}{\Delta \theta_{SSV}}$	DECIBELS	PHASE
1.0000-07	2.7190 02	48.187	-0.000	0.000	1.1270 02	41.072	0.000	0.000	2.3420 00	7.392	-180.000	
2.5000-03	2.7810 02	48.815	-0.031	1.1470 02	41.192	0.211	2.4040 00	7.617	-180.019			
3.9500-03	2.8500 02	49.027	-2.444	1.1700 02	41.361	-0.323	2.4720 00	7.860	-181.116			
5.2300 03	2.9440 02	49.178	-6.333	1.2020 02	41.595	-2.511	2.5670 00	8.189	-184.495			
1.0000-02	2.9720 02	49.460	-13.973	1.2160 02	41.701	-7.067	2.6090 00	8.331	-191.503			
1.5700-02	2.8110 02	48.376	-24.352	1.1770 02	41.416	-13.164	2.4880 00	7.916	-200.929			
2.5000-02	2.4640 02	47.871	-35.865	1.0970 02	40.726	-19.347	2.2080 00	6.879	-211.123			
3.9500-02	2.0930 02	46.374	-47.616	9.2960 01	39.909	-25.359	1.9080 00	5.609	-221.092			
6.2800-02	1.7070 02	44.644	-63.044	9.8190 01	39.207	-33.548	1.6180 00	4.179	-234.409			
1.0000-01	1.2800 02	42.141	-84.198	7.3250 01	37.296	-44.018	1.2720 00	2.091	-257.327			
1.5700-01	8.5100 01	38.598	-108.330	5.2730 01	35.076	-57.271	8.9370-01	-0.777	84.659			
2.5000-01	5.0070 01	37.991	-136.383	4.2970 01	32.662	-71.517	5.5570-01	-5.109	59.312			
3.9500-01	2.5360 01	28.419	-170.680	3.2400 01	30.209	-73.297	3.0770-01	-10.238	30.485			
6.2800-01	1.0210 01	20.755	-212.563	2.1180 01	26.516	-90.111	1.4300-01	-16.893	1.600			
1.0000 00	7.5100 00	10.906	-252.905	1.1430 01	21.170	-102.292	6.7000-02	-23.478	-18.586			
1.5700 00	1.0200 00	0.751	73.648	6.0570 00	15.645	-105.013	3.7960-02	-28.413	-30.691			
2.5000 00	3.3870-01	-6.399	42.669	3.3410 00	10.477	-102.743	2.2740-02	-32.862	-55.522			
3.9500 00	1.0990-01	-19.177	14.852	1.9770 00	5.921	-99.542	1.3930-02	-37.118	-71.186			
6.2800 00	3.2800-02	-29.683	-10.439	1.2050 00	1.623	-97.044	8.4070-03	-41.507	-83.687			
1.0000 01	7.4080-03	-30.000	-32.689	7.4680-01	-2.535	-95.682	4.9530-03	-46.102	-93.396			
1.5700 01	1.7550-04	-30.000	-60.876	4.7280-01	-6.507	-95.449	2.8920-03	-50.777	-100.353			
2.5000 01	1.4870-03	-30.000	-246.008	2.9560-01	-10.586	-96.354	1.6400-03	-55.704	-104.976			
3.9500 01	1.4230-03	-30.000	-260.021	1.8590-01	-14.612	-98.573	9.5410-04	-60.409	-107.985			
6.2800 01	1.0490-03	-30.000	86.167	1.1540-01	-18.758	-102.595	5.7060-04	-64.872	-111.919			
1.0000 02	7.1220-04	-30.000	67.663	7.0150-02	-23.079	-109.060	3.5350-04	-69.031	-120.787			

(RAD./SEC.)	MAGNITUDE	$\frac{\Delta P_{15}}{\Delta \theta_V}$	DECIBELS	PHASE	MAGNITUDE	$\frac{\Delta P_{15}}{\Delta \theta_d}$	DECIBELS	PHASE	MAGNITUDE	$\frac{\Delta P_{15}}{\Delta \theta_{SSV}}$	DECIBELS	PHASE
1.0000-07	2.1660-01	26.712	0.000	0.000	5.6970 00	-15.113	0.000	0.000	2.1260-01	-13.447	-180.000	
2.5000-03	2.2050 01	26.867	0.109	5.8220 00	15.302	1.345	2.1650-01	-13.292	-179.141			
3.9500-03	2.2490 01	27.038	-0.561	5.9660 00	15.414	1.267	2.2090-01	-13.119	-179.362			
6.2800-03	2.3120 01	27.279	-2.181	6.1850 00	15.827	-0.190	2.2730-01	-12.868	-180.844			
1.0000-02	2.3440 01	27.398	-7.551	6.3530 00	16.059	-4.011	2.3140-01	-12.712	-184.456			
1.5700-02	2.2730 01	27.133	-14.098	6.2830 00	15.963	-9.379	2.2680-01	-12.888	-189.395			
2.5000-02	2.1000 01	26.443	-21.228	6.0020 00	15.576	-15.145	2.1390-01	-13.396	-194.349			
3.9500-02	1.8880 01	25.525	-28.759	5.7140 00	15.139	-21.821	1.9900-01	-14.021	-199.361			
6.2800-02	1.6220 01	24.203	-38.726	5.3020 00	14.489	-32.208	1.7940-01	-14.921	-206.294			
1.0000-01	1.2460 01	21.907	-49.442	4.5150 00	13.094	-46.357	1.4800-01	-16.592	-213.955			
1.5700-01	8.5620 00	18.651	-55.944	3.5010 00	10.884	-60.580	1.1280-01	-18.955	-217.834			
2.5000-01	5.8970 00	15.412	-52.103	2.5520 00	8.161	-75.458	8.7670-02	-21.143	-212.159			
3.9500-01	4.8980 00	13.888	-46.257	1.7600 00	4.910	-94.786	7.8520-02	-22.100	-207.211			
6.2800-01	4.5440 00	13.148	-52.095	0.7100-01	-0.256	-118.562	7.3590-02	-22.663	-207.100			
1.0000 00	3.5100 00	11.150	-66.722	4.1390-01	-7.662	-133.926	6.3220-02	-23.977	-210.572			
1.5700 00	2.5290 00	8.059	-81.156	1.7440-01	-15.170	-134.265	5.2860-02	-25.540	-211.215			
2.5000 00	1.6330 00	4.257	-95.183	8.1130-02	-21.816	-126.013	4.5280-02	-26.881	-210.260			
3.9500 00	1.0170 00	0.115	-109.218	4.3480-02	-27.234	-117.035	4.0480 02	-27.854	-210.574			
6.2800 00	6.0550-01	-1.735	-116.344	2.4720-02	-37.138	-110.211	3.6730-02	-28.746	-214.489			
1.0000 01	3.4900-01	-9.177	-147.932	1.4220-02	-36.944	-105.178	3.2070-02	-29.892	-222.366			
1.5700 01	2.0370-01	-11.337	-167.264	8.2740-03	-41.687	-99.517	2.6210-02	-31.564	-233.387			
2.5000 01	1.1990-01	-18.427	-189.529	4.4330-03	-46.320	-89.595	1.9720-02	-34.102	-246.616			
3.9500 01	7.5360-02	-22.457	-208.499	3.2660-03	-49.719	-77.002	1.3440-02	-37.432	-259.375			
6.2800 01	4.9470-02	-26.113	-223.446	2.5720-03	-51.720	-69.523	8.4340-03	-41.479	-266.957			
1.0000 02	3.2170-02	-29.850	-232.371	2.1350-03	-53.412	-72.870	5.5000-03	-45.193	-274.135			

CONTRLS & ACTS OUT P15= 60, T15=1000, THSSV=47.53 X1=THV, X2=THD, X3=THSSV
PROGRAM E61904 TIME AND FREQUENCY TRANSFER FUNCTION (T15)/(X2)


Revision 1

IIIB-2
Page 2 of 4



CONTRLS & ACTS OUT P15 = 60, T15 = 1000, THSSV = 47.53 X1 = THV, X2 = THD, X3 = THSSV
PROGRAM E61904 TIME AND FREQUENCY TRANSFER FUNCTION (T15) / (X3)


Revision 1



CONTRLS & ACTS OUT P15 = 60, T15 = 1000, THSSV = 47.53 X1 = THV, X2 = THD, X3 = THSSV
PROGRAM E61904 TIME AND FREQUENCY TRANSFER FUNCTION (P15) / (X1)

Revision 1

IIIB-2
Page # of 4



UNCLASSIFIED

Page 1 of 7
Revision: 1
Date: 5/15/69

Variables Equation, Fortran

CI_j	= Precursor concentration in j^{th} group	
Co	= Isentropic spouting velocity	ft/sec
Dk_d	= Reactivity feedback of drums	\$
Dk_f	= Reactivity feedback of reactor	\$
Dk_t	= Total reactivity feedback	\$
ET	= Turbine efficiency	
f	= Function	
H	= Enthalpy of solid material	BTU/lb
M, TRQ	= Torque	lb-ft
N, RPM	= Speed	rpm
P	= Pressure	psia
Q	= Decay heat power	%
R	= Density	lb/ft ³
s	= Laplace operator	
S	= Thermal power in fueled sections	%
S_N	= Nuclear power	%
S_{NQ}	= Thermal power in unfueled sections	%
t	= Time	sec
T	= Fluid Temperature	°R
u	= Mean peripheral blade speed	ft/sec
W	= Mass flowrate	lb/sec
θ, TH	= Angular position	deg
ϕ, PH	= Material temperature	°R

UNCLASSIFIED

UNCLASSIFIED

Page 2 of 7
Revision: 1
Date: 5/15/69

Station

3	=	Pump inlet
4	=	Low speed pump discharge
45	=	High speed pump discharge
5	=	Nozzle inlet
7	=	Reflector inlet plenum
9	=	Peripheral shield exit plenum
10	=	Dome end plenum
15	=	Nozzle chamber
19	=	Support structure bypass control valve inlet
20	=	Support structure control valve discharge
22	=	Support system discharge
27	=	TPCV inlet
285	=	High speed turbine inlet
29	=	Low speed turbine inlet
30	=	Low speed turbine exit
31	=	Skirt extension inlet
32	=	Skirt extension outlet

Qualifying Subscripts Equation, Fortran

a	=	Parallel turbopump
C	=	Reactor core, average
C _i	=	Reactor core, i th section

UNCLASSIFIED

Qualifying Subscripts (continued)
Equation, Fortran


d	=	Drum
D	=	Demand
DB	=	Diluent bleed
e	=	Exit
E	=	Error
EC	=	Clamped error
EXT	=	Skirt extension
H	=	High speed
HB	=	Hot bleed
j	=	Radial inside
M	=	Measured
N	=	Nozzle
NC	=	Nozzle coolant
p	=	Pyrographite
P	=	Pump
R	=	Reflector
SG	=	Structural graphite
SK	=	Skirt
SKC	=	Skirt coolant
SS	=	Support system average
SSB	=	Support system bypass
SSI	=	Support system inlet
SSj	=	Support system, j th section
ssv	=	Support system control valve
T	=	Turbine

Qualifying Subscripts (continued)
Equation, Fortran


ti . = Stainless steel, ith section

V = Turbine power control valve


φ, PH = Radial outside



SCHEMATIC DIAGRAM OF E-1 ENGINE



SCHEMATIC DIAGRAM OF E-1 NUCLEAR SUBSYSTEM



SCHEMATIC DIAGRAM OF SUPPORT SYSTEM