Steady-State Flammable Gas Release Rate Calculation and Lower Flammability Level Evaluation for Hanford Tank Waste

J. E. Meacham

Washington River Protection Solutions

Richland, Washington 99352

U. S. Department of Energy Contract DE-AC27-08RV14800

EDT/ECN: ECN-721735-R11 UC:

Cost Center:

Charge Code:

B&R Code:

Total Pages: 93

Key Words: Double-shell tank, single-shell tank, DST, SST, flammability, time to lower flammability limit, TTLFL, hydrogen and headspace.

Abstract: This report assesses the steady state flammability level under off normal ventilation conditions in the tank headspace for 28 double-shell tanks (DST) and 149 single shell-tanks (SST) at the Hanford Site. Flammability was calculated using estimated gas release rates, Le Chatelier's rule, and lower flammability limits of fuels in an air mixture. This revision updates the hydrogen generation rate input data for all 177 tanks using waste composition information from the Best Basis Inventory Detail Report (data effective as of August 4, 2008). Assuming only barometric breathing, the shortest time to reach 25% of the lower flammability limit is 13 days for DSTs (i.e., tank 241-AZ-102) and 36 days for SSTs (i.e., tank 241-B-203). Assuming zero ventilation, the shortest time to reach 25% of the lower flammability limit is 12 days for DSTs (i.e., tank 241-AZ-102) and 34 days for SSTs (i.e., tank 241-B-203).

TRADEMARK DISCLAIMER: Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

Release Approval

11.17.08
Date

Approved for Public Release

Tank Farm Contractor (TFC) RECORD OF REVISION		(1) Document Number: RPP-5926	Page 1
(2) Title: Steady-State Flammable Gas Release Rate Calculation and Lower Flammability Level Evaluation for Hanford Tank Waste			
Change Control Record			
(3) Revision	(4) Description of Change – Replace, Add, and Delete Pages	Authorized for Release	
		(5) Resp. Engr. (print/sign/date)	(6) Resp. Mgr. (print/sign/date)
0	Original Release via EDT 628264	T. A. Hu 4/27/2000	K. M. Hodgson 4/27/2000
1	Total revision to address comments resulting from DOE-ORP review (ECN 664031)	T. A. Hu 2/23/2001	J. S. Garfield 2/23/2001
2	Total revision to update the hydrogen rates and flammability to Nov. 2001 BBI data. (ECN 665039)	T. A. Hu 6/30/2002	N. W. Kirch 6/30/2002
2A	Add Appendix I, flammability evaluation of 5 DSTs with highest LFL. (ECN 720321)	T. A. Hu 3/20/2003	N. W. Kirch 3/20/2003
3	Total revision to update the hydrogen rates and flammability to July 2003 BBI data.	T. A. Hu 9/30/2003	N. W. Kirch 9/30/2003
3A	Add Appendix J, flammability evaluation of vacuum retrieval project of 241-C Tank Farm 200-Series	T. A. Hu 11/19/2003	T. M. Horner 11/19/2003
3B	Add Appendix K, flammability evaluation to raise DST operation waste level to 460 inch.	T. A. Hu 12/23/2003	T. M. Horner 12/23/2003
3C	Add Appendix L, flammability evaluation of retrieval project on 241-C-103 and 241-C-105	T. A. Hu 1/22/2004	T. M. Horner 1/22/2004
3D	Add Appendix M, flammability evaluation of 241-AY-102 to support receiving condensate	T. A. Hu 4/20/2004	T. M. Horner 4/20/2004
3E	Update Appendix K, (Title, see Rev 3B) ECN-721735-R1	T. A. Hu 6/2/2004	T. M. Horner 6/2/2004
4	Complete revision of document as annual update per ECN-721735-R2	T. A. Hu 10/27/2004	T. M. Horner 10/27/2004
4A	Address ORP comments on Rev 4 and correct editorial errors per ECN-721735-R3	T. A. Hu 2/17/2005	T. M. Horner 2/17/2005
4B	Add Appendix I, flammability evaluation on raising the waste level to 460 inch for DSTs per ECN-721735-R4	T. A. Hu 4/27/2005	T. M. Horner 4/27/2005
4C	Delete the content of Appendix I per ECN-721735-R5	T. A. Hu 6/15/2005	T. M. Horner 6/15/2005
4D	Add Appendix I content with the flammability evaluation on the uncovered solids for DSTs per ECN-721735-6	T. A. Hu 7/28/2005	T. M. Horner 7/27/2005
4E	Add Appendix J content with the flammability evaluation on tank 241-C-103 retrieval per ECN-721735-R7	T. A. Hu 9/12/2005	T. M. Horner 9/12/2005
5	Complete revision of document as annual update per ECN-721735-R8	T. A. Hu 10/27/2005	M. A. Knight 10/27/2005
6	Complete revision of document as annual update per ECN-721735-R9	T. A. Hu 10/27/2006	N. W. Kirch 10/27/2006
7	Complete revision of document as annual update per ECN-721735-R10	T. A. Hu 10/25/2007	N. W. Kirch 10/25/2007
8	Complete revision of document as annual update per ECN-721735-R11	J. E. Meacham 11/17/2008	N. W. Kirch 11-17-2008

Steady-State Flammable Gas Release Rate Calculation and Lower Flammability Level Evaluation for Hanford Tank Waste

J. E. Meacham
Washington River Protection Solutions

Date Published
November 2008

Prepared for the U.S. Department of Energy
Assistant Secretary for Environmental Management

Contractor for the U.S. Department of Energy
Office of River Protection under Contract DE-AC27-08RV14800

Washington River Protection Solutions LLC
P.O. Box 1500
Richland, Washington

APPROVED FOR PUBLIC RELEASE; DISTRIBUTION UNLIMITED

EXECUTIVE SUMMARY

Flammable gases such as hydrogen, ammonia, and methane are observed in the tank headspace of the Hanford Site high-level waste tanks. This report assesses the steady-state flammability level under off-normal ventilation conditions in the tank headspace for 28 double-shell tanks (DST) and 149 single-shell tanks (SST) at the Hanford Site. Flammability was calculated using estimated gas release rates, Le Chatelier's rule, and lower flammability limits of fuels in an air mixture. A time-dependent equation of gas concentration, which is a function of the gas release and ventilation rates in the headspace, was developed. With this dynamic model, the time required to reach the specified flammability level at a given ventilation rate was calculated. Hydrogen generation rates were calculated using the empirical rate equation model provided in *Empirical Rate Equation Model and Rate Calculations of Hydrogen Generation for Hanford Tank Waste*, HNF-3851. The off-normal ventilation rate is assumed to be barometric breathing only or zero ventilation.

This revision updates the hydrogen generation rate input data for all 177 tanks using waste composition information from the Best Basis Inventory Detail Report in the *Tank Waste Information Network System* (data effective as of August 4, 2008), and the waste temperature data in the Surveillance Analysis Computer System. All DST waste temperatures were increased 5 °C to address potential small temperature increases. A 10,000 gallon water addition was also assumed for all DSTs and 100-series SSTs to address operations that involve small water additions. The smaller 200-series SSTs were assumed to have 1,000 gallon water additions. Gas diffusion through the concrete dome is included in the mass balance equations for SSTs under the zero ventilation condition.

Assuming only barometric breathing, the shortest time to reach 25% of the lower flammability limit is 13 days for DSTs (i.e., tank 241-AZ-102) and 36 days for SSTs (i.e., tank 241-B-203). Assuming zero ventilation, the shortest time to reach 25% of the lower flammability limit is 12 days for DSTs (i.e., tank 241-AZ-102) and 34 days for SSTs (i.e., tank 241-B-203).

CONTENTS

1.0	PURPOSE.....	1
2.0	BACKGROUND	1
3.0	ASSUMPTIONS.....	2
4.0	METHODOLOGY	3
4.1	HYDROGEN GENERATION SEMI-EMPIRICAL RATE EQUATIONS.....	3
4.2	FLAMMABILITY CALCULATION	4
4.3	TIME TO LFL WITH VENTILATION	6
4.4	TIME TO LFL WITH ZERO VENTILATION.....	8
4.5	MINIMUM VENTILATION RATE TO MAINTAIN HEADSPACE BELOW 25 OR 100 PERCENT OF THE LFL	9
5.0	INPUT DATA.....	10
6.0	COMPUTER SOFTWARE	12
7.0	RESULTS	13
7.1	DOUBLE-SHELL TANK RESULTS	13
7.2	SINGLE-SHELL TANK RESULTS	16
8.0	CONCLUSIONS.....	26
9.0	REFERENCES	26

APPENDICES

A	INPUT DATA FOR TIME TO THE LOWER FLAMMABILITY LIMIT CALCULATIONS	A-1
B	CALCULATIONS OF THE GAS DIFFUSION COEFFICIENTS FOR THE CONCRETE DOME OF SINGLE-SHELL TANKS	B-1
C	AMMONIA CONTRIBUTION TO FLAMMABILITY.....	C-1
D	PEER REVIEW CHECKLIST	D-1

LIST OF TABLES

Table 5-1. Curie to Watt Conversion Factors	11
Table 7-1. Double-Shell Tank Steady-State Flammable Gas Concentration and Time to Lower Flammability Limit Under Barometric Breathing	13
Table 7-2. Double-Shell Tank Time to Lower Flammability Limit Under Zero Ventilation	14
Table 7-3. Double-Shell Tank Hydrogen Generation Rate and Minimum Ventilation Rate Required to Maintain Headspace Flammable Gas Concentration Below Specified Level	15
Table 7-4. Single-Shell Tank Steady-State Flammable Gas Concentration and Time to Lower Flammability Limit Under Barometric Breathing	16
Table 7-5. Single-Shell Tank Time to Lower Flammability Limit Under Zero Ventilation	19
Table 7-6. Single-Shell Tank Hydrogen Generation Rate and Minimum Ventilation Rate Required to Maintain Headspace Flammable Gas Concentration Below Specified Level	22

LIST OF TERMS

BBI	best-basis inventory
DST	double-shell tank
GRE	gas release event
HEPA	high-efficiency particulate air (filter)
HGR	hydrogen generation rate
LFL	lower flammability limit
SACS	Surveillance Analysis Computer System
SST	single-shell tank
TCD	Tank Characterization Database
TOC	total organic carbon
TTLFL	time to lower flammability limit
TWINS	Tank Waste Information Network System

1.0 PURPOSE

This report evaluates steady-state flammability levels in tank headspaces under off-normal ventilation conditions for 177 underground nuclear waste storage tanks at the Hanford Site.

2.0 BACKGROUND

This document provides the technical basis for establishing flammable gas controls. The focus of this report is the loss of ventilation transient such that technical safety requirement surveillance frequencies and action completion times can be established. This report also provides the following:

- Estimates of the time to reach 25% of the lower flammability limit (LFL) and 100% of the LFL following the loss of normal ventilation in actively and passively ventilated double-shell tanks (DST) and single-shell tanks (SST)
- Estimates of the minimum ventilation rate required to maintain less than 25% and 100% of the LFL

Steady-state implies that no active operational changes and no gas release events (defined as a 500-ppm rise in hydrogen concentration followed by exponential decay of the released flammable gas) are occurring.

3.0 ASSUMPTIONS

Barometric breathing is taken to be the yearly average rate and variations brought about by seasonal effects over short durations are neglected.

Methane generation is assumed to be 10% of the model-calculated hydrogen generation from thermolysis and radiolysis. This is a reasonable estimate because, for all tanks, methane is less than 10% of the hydrogen in the generated gas as given in the gas generation study (PNNL-12181) and retained gas sampler results (PNNL-13000).

Peak waste temperatures for hydrogen generation in DSTs are assumed to be 5 °C higher than actually measured for the year to address potential small temperature increases.

Calculations include a 10,000 gallon water addition (1,000 gallon water addition to 200-series SSTs) to address operations that involve small water additions.

Hypothetical water additions are assumed to not significantly influence the overall tank hydrogen generation efficiency coefficient from corrosion (E_{H_2}).

When the solids and supernatant layers have different hydrogen generation efficiency coefficients from corrosion, the higher of the two (i.e., 0.5) is conservatively selected to represent the tank. This assumption simplifies the calculations and does not significantly affect results.

Tank headspaces are assumed to start at 2% of the LFL to account for ammonia contribution to flammability (see Appendix C).

Hydrogen and methane starting concentrations are assumed negligible.

Beta and gamma heat loads are assumed to be comprised of ^{90}Sr and ^{137}Cs . Alpha heat load was assumed to be comprised of ^{241}Am , ^{240}Pu , ^{239}Pu , and ^{238}Pu . These are reasonable simplifying assumptions given that these radionuclides dominate their respective heat loads.

Nitrous oxide concentration is assumed to be below 8% and therefore does not decrease the LFL for hydrogen, methane, or ammonia (see discussion in Section 4.2).

4.0 METHODOLOGY

The time to the lower flammability limit (TTLFL) is a matter of determining the rate of flammable gas accumulation in the tank headspace and then calculating the time necessary to reach flammability. The first step is to calculate the hydrogen generation (Section 4.1) and the gas mixture flammability (Section 4.2). Flammability at any given time is a balance between gas generation and the headspace ventilation rate (Sections 4.3 through 4.5).

4.1 HYDROGEN GENERATION SEMI-EMPIRICAL RATE EQUATIONS

A comprehensive hydrogen generation rate (HGR) model was developed and validated based on a large body of tank waste data (HNF-3851). The model constructed a set of semi-empirical rate equations to simulate the gas generation mechanisms of thermal chemical reactions, radiolysis of water and organic components, and corrosion processes. The rate equations are formulated as a function of physical and chemical properties of tank waste and are able to estimate the HGR of waste under current conditions, including the rates for newly mixed waste with known properties.

The empirical rate equation for hydrogen generation in Hanford Site waste contains contributions from thermal reactions, HGR_{thm} , radiolysis of water and organic, HGR_{rad} , and corrosion, HGR_{corr} . This rate equation is a function of waste composition (TOC , Al^{+3} , Na^+ , NO_2^- , NO_3^- , and OH^-), radiation dose, temperature, liquid fraction, and tank wetted area. Both the thermal and organic radiolysis rates follow Arrhenius behavior with a derived activation energy. The equation for HGR in the units of moles per kilogram per day can be summarized as follows (Equation 4-1):

$$HGR = HGR_{thm} + HGR_{rad} + HGR_{corr} \quad (4-1)$$

Where:

$$HGR_{thm} = a_{thm} \times (r_f \times [TOC]) \times [Al^{+3}]^{0.4} \times L_f \times \exp^{(-E_{thm}/RT)}$$

$$HGR_{rad} = [(G_{(H_2)_{H_2O}}^{\beta/\gamma} + G_{(H_2)_{ORG}}^{\beta/\gamma}) \times H_{Load}^{\beta/\gamma} + (G_{(H_2)_{H_2O}}^{\alpha} + G_{(H_2)_{ORG}}^{\alpha}) \times H_{Load}^{\alpha}] \times L_f \times CF_1$$

$$HGR_{corr} = R_{corr} \times E_{H_2} \times A_{wetted} / M_{tank} \times CF_2$$

with:

$$G_{(H_2)_{ORG}}^{\beta/\gamma} = a_{rad} \times \exp^{(-E_{rad}/RT)} \times (r_f \times [TOC])$$

$$G_{(H_2)_{H_2O}}^{\beta/\gamma} = \frac{0.32}{1 + 2.4[NO_3^-] + 0.62[NO_2^-] + 0.31[Na^+]_{ex}^2} + \frac{0.13}{1 + 139[NO_3^-] + 54[NO_2^-]}$$

$$G_{(H_2)_{ORG}}^{\alpha} = 0.5 \times a_{rad} \times \exp^{(-E_{rad}/RT)} \times r_f \times [TOC]$$

$$G_{(H_2)_{H_2O}}^{\alpha} = \frac{1.05}{1 + 2.4[NO_3^-] + 0.63[NO_2^-]} + \frac{0.35}{1 + 3900[NO_3^-] + 1400[NO_2^-]}$$

Where:

$E_{thm} = 89.6$ kJ/mole, the activation energy for the thermal reaction

$a_{thm} = 3.94 \text{ E}+09$ moles/kg-day, pre-exponential factor of the thermal rate

- $E_{\text{rad}} = 48.8 \text{ kJ/mole}$, activation energy in organic radiolysis, G
 $a_{\text{rad}} = 1.11 \text{ E+07 H}_2/100 \text{ eV}$, the pre-exponential term in organic radiolysis, G
 $r_f = 0.6$ for DSTs and 0.3 for SSTs (dimensionless), the total organic carbon reactivity coefficient. The 0.3 for SSTs is an average value from the tanks tested. If tank has a high fraction of energetic organic compounds, r_f can be adjusted to as high as 0.6.
 $R = 8.314 \text{ J/mole-K}$, gas constant
 $R_{\text{corr}} = 6.0 \text{ E-08}$ for DSTs and 2.4 E-07 for SSTs ($\text{ft}^3/\text{min-ft}^2$), corrosion coefficient
 E_{H_2} = hydrogen generation efficiency coefficient from corrosion is 0.20 if $[\text{NO}_3^-]$, $[\text{NO}_2^-]$, and $[\text{OH}^-] > 0.1$, otherwise it is 0.50.
 $[\text{TOC}]$ = total organic carbon concentration in the liquid waste, wt%
 Note: Insoluble energetic organic compounds (excluding oxalate) in the solid layer should be considered case by case when data is available
 $[\text{Al}^{+3}]$ = aluminum ion concentration in liquid waste, wt%
 $[\text{NO}_3^-]$ = nitrate ion concentration in the liquid waste, moles/L
 $[\text{NO}_2^-]$ = nitrite ion concentration in the liquid waste, moles/L
 $[\text{Na}^+]_{\text{ex}}$ = concentration of sodium minus nitrate and nitrite concentration in liquid waste, moles/L
 $H_{\text{Load}}^{\beta/\gamma}$ = total heat load of the tank from beta/gamma, watt/kg
 H_{Load}^{α} = total heat load of the tank from total alpha, watt/kg
 L_f = liquid weight fraction in the waste, dimensionless
 T = temperature of waste, K
 A_{wetted} = area of steel exposed to moisture-containing waste, ft^2
 M_{tank} = total waste mass in the tank, kg
 CF_1 = conversion factor from H_2 -watt/100 eV-kg to moles/kg-day
 CF_2 = conversion factor from $\text{m}^3/\text{kg-min}$ to moles/kg-day

In general, hydrogen generation from chemical reactions follows Arrhenius behavior and the rate from radiolysis is proportional to the radiation dose. Hydrogen generation from radiation effects in tank waste samples have been observed to be temperature dependent as provided in PNNL-12181. The analysis of all available gas generation data provided in HNF-3851 shows that this temperature-dependent reaction follows Arrhenius behavior, which may result from a multi-step degradation of organic compounds initiated by radiolysis, followed by thermal reactions. The water radiolysis rate is temperature independent, with the value reduced by scavenging effects.

4.2 FLAMMABILITY CALCULATION

The National Fire Protection Agency codes require that operations be terminated when the concentration of flammable gases exceeds 25% of the LFL. Based on the empirical rule developed by Le Chatelier in the late 19th century, the LFL of mixtures of multiple flammable gases in air can be determined. Le Chatelier's rule (*Limits of Flammability of Gases and Vapors*, [Coward and Jones 1952]) can be written in terms of the LFL concentration of the fuel mixture, LFL_m , as follows:

$$LFL_m = \frac{100}{\sum_i^n \left(\frac{C_i}{LFL_i} \right)} \quad (4-2)$$

where:

C_i = volume percent of fuel gas i in the fuel gas mixture
 LFL_i = volume percent of fuel gas i at its LFL in air alone.

In the tank headspace, hydrogen gas, ammonia, and methane are the flammable gases of concern. For tank waste conditions, the volume percents of the flammable gases vary over time depending on flammable gas release rates into the tank headspace, and thus, Equation 3-1 cannot be directly applied. WHC-SD-WM-ES-219 showed experimentally that the total flammability level LFL_f (the fraction of the LFL) of a mixture of hydrogen, ammonia, and methane in an air-nitrous oxide atmosphere can be computed using the principle of Le Chatelier's rule in terms of the individual fuel gas flammability as in Equation 4-3.

$$LFL_f = \frac{[H_2]}{LFL_{H_2}} + \frac{[NH_3]}{LFL_{NH_3}} + \frac{[CH_4]}{LFL_{CH_4}} \quad (4-3)$$

where:

$[H_2]$ = volume percent of hydrogen in the tank headspace
 $[NH_3]$ = volume percent of ammonia in the tank headspace
 $[CH_4]$ = volume percent of methane in the tank headspace
 LFL_{H_2} = volume percent of hydrogen at its LFL in air alone
 LFL_{NH_3} = volume percent of ammonia at its LFL in air alone
 LFL_{CH_4} = volume percent of methane at its LFL in air alone.

For simplicity, flammable gases with concentrations lower than that of methane are omitted. The flammability of the individual gases in air is fairly well characterized. The LFL_{H_2} , LFL_{NH_3} , and LFL_{CH_4} are 4, 15, and 5%, respectively, at the upward propagation LFL, which is more conservative than the downward propagation LFL. In addition to the flammable gases included in Equation 4-3, nitrous oxide was observed in the tank headspace. Nitrous oxide plays the role of oxidizer in the mixture and has the potential to decrease the amount of fuel required to reach the LFL. The effect of the multiple oxidizers (e.g., N_2O and O_2) was not addressed in Equation 4-3.

Pfahl and Shepherd (1997) from the California Institute of Technology conducted a series of flammability studies on gas mixtures generated from Hanford Site tank waste. The studies show that the established LFLs of individual fuels in the air will decrease if concentrated N_2O is present in the mixtures. For example, in the mixture NH_3 - N_2O -air with a ratio of 13.2-19.8-67.0, the system will be flammable, although the ammonia volume percent is 13.2 and is lower than the LFL_{NH_3} of 15% in air. This fuel-oxidizer mixture will be flammable with the ammonia volume percent as low as 8% if the N_2O concentration is 65%. For NH_3 - N_2O -air mixtures, Pfahl and Shepherd (Figure 32 in 1997 report) suggest that the ammonia flammability limit will be 15% if the N_2O does not exceed 8%. These test results are for turbulent conditions, with an ignition energy of 8 J. For a CH_4 - N_2O -air mixture, the data show that the ratio of 4.5-10.1-85.4 is not flammable. For an H_2 - N_2O -air mixture, the data show that a mixture with the ratio of

5.7-10-84.3 has incomplete combustion. It should be noted that the ignition energy of 8 J used in these experiments is very large compared to the energy in most electrostatic discharge sparks (typically a few millijoules) that might occur inside a Hanford Site tank.

This information suggests that the flammability limit established in the fuel-air mixture for each gas will not be reduced unless the N_2O volume percent exceeds 8%. In this evaluation, the volume percents of 4, 15, and 5% will be used for LFL_{H_2} , LFL_{NH_3} , and LFL_{CH_4} , respectively, in Equation 4-3. In each case, the concentration of nitrous oxide was evaluated and did not exceed 8%, therefore, the oxidizer effect of lowering these flammability limits can be ignored.

For ventilation interruptions, the time for the headspace to build up to flammable gas concentrations exceeding the LFL is one of the main concerns of this evaluation. A time-dependent flammability level, $LFL_f(t)$, of the mixture can be calculated using the time-dependent gas concentration and Le Chatelier's rule as provided in Equation 4-4:

$$LFL_f(t) = \frac{[H_2](t)}{LFL_{H_2}} + \frac{[NH_3](t)}{LFL_{NH_3}} + \frac{[CH_4](t)}{LFL_{CH_4}} \quad (4-4)$$

where:

- $[H_2](t)$ = hydrogen concentration (volume percent) at time t
- $[NH_3](t)$ = ammonia concentration (volume percent) at time t
- $[CH_4](t)$ = methane concentration (volume percent) at time t
- LFL_{H_2} = hydrogen LFL in air alone, 4%
- LFL_{NH_3} = ammonia LFL in air alone, 15%
- LFL_{CH_4} = methane LFL in air alone, 5%.

4.3 TIME TO LFL WITH VENTILATION

Under normal operating conditions, ventilation can be either active or passive. All DSTs and some SSTs are equipped with active ventilation systems. For active ventilation systems, the main ventilation flow is designed to go through an installed inlet filter. The 241-AP Tank Farm is an exception to this system; inlet air flows through cover blocks or gaps in riser covers, and other tank openings. The size of the inlet openings was designed to be either fully adjustable or to have just an on-off valve. These filtered inlets are used to control the ventilation rate and to adjust the negative pressure to prevent leakage of tank hazardous materials or to provide control for any other operational needs. For passively ventilated tanks, the ventilation flow goes mainly through high-efficiency particulate air (HEPA) breather filters.

Under normal operating conditions, the active ventilation rates range from 100 to 700 ft^3/min , while the passive ventilation rates range from 0.5 to 25 ft^3/min . On actively ventilated tanks, the off-normal operating ventilation condition considered in the flammability assessment is that the ventilation system is shut down and the air inlet is closed; on passively ventilated tanks, the HEPA breather filter isolation valve is closed. For these conditions, the only vent flow is through the gaps between the cover blocks or riser covers. The off-normal condition allows

three possible results: zero ventilation, ventilation from barometric breathing, or ventilation flow caused by natural breathing, which is a combination of barometric breathing, thermal convection, venturi effects, etc. The barometric breathing rate, V_{bb} , is estimated as 0.45% of the headspace volume per day (WHC-EP-0651) and is given in Equation 4-5:

$$V_{bb} = 0.45\% \cdot Vol_{headspace} \left(\frac{ft^3}{day} \right) \quad (4-5)$$

where:

$Vol_{headspace}$ = volume of the tank head space, ft^3 .

During off-normal operating conditions, the most likely ventilation rate is either natural breathing or barometric breathing. The natural breathing rate is estimated to be 5 to 10 times the barometric breathing rate. The zero-ventilation condition is considered to be impossible because of the many openings into the tanks. However, since 1980, an effort has been made to seal off the openings as much as possible for SSTs to prevent water intrusion. The barometric breathing rate was used for the DST and SST ventilation rate under off-normal operating conditions.

Gas concentration can be formulated from a mass balance as provided in Equation 4-6:

$$Vol \frac{\partial [C_g]}{\partial t} = R_g - V_r \cdot [C_g] \quad (4-6)$$

where:

$[C_g]$ = gas concentration, volume percent
 Vol = volume of the tank headspace, volume
 R_g = gas release rate from the waste surface, volume/time
 V_r = ventilation rate in the headspace, volume/time

Equation 4-6 can be changed to reflect diffusion losses rather than ventilation losses. Assuming that there is zero ventilation, but the gas can diffuse out through the concrete dome, then $V_r \cdot [C_g]$ term in Equation 4-6 is changed to the gas diffusion rate (see Section 4.4).

As given in Equation 4-6, the gas exhaust rate is simply the gas concentration times the output ventilation rate. By solving the differential Equation 4-6, a time-dependent gas concentration at time t , $[C_g](t)$, in units of volume percent is given in Equation 4-7:

$$[C_g]_{\%}(t) = [C_g]_{\%}(t_0) \exp(-\lambda t) + \left[\frac{R_g}{V_r} \right]_{\%} [1 - \exp(-\lambda t)] \quad (4-7)$$

with

$$\lambda = V_r / \text{Vol}$$

where:

$$\begin{aligned} R_g &= \text{hydrogen release rate from the waste surface, volume/time} \\ V_r &= \text{ventilation rate in the headspace, volume/time} \\ [C_g](t_0) &= \text{initial gas concentration at time } t, \text{ volume percent} \\ \text{Vol} &= \text{volume of the tank headspace, volume} \\ \lambda &= \text{decay parameter from the venting, inverse time} \\ t &= \text{time.} \end{aligned}$$

In Equation 4-7, the first term represents how the initial gas concentration decays away exponentially with the factor of $e^{(-\lambda t)}$ and second term represents how the gas level builds up in the form of $[R_g/V_r]_{\%}$ with the factor of $[1 - e^{(-\lambda t)}]$ as time goes on.

4.4 TIME TO LFL WITH ZERO VENTILATION

Under zero ventilation, the only gas release mechanism from the headspace is gaseous diffusion through the tank domes. For the case of gas exiting by diffusion through the dome, the mass balance equation can be written as a differential equation as given in Equation 4-8:

$$\text{Vol} \frac{\partial [C_g]}{\partial t} = R_g - A \times Q = R_g - A \times \frac{1}{\sum_i \frac{L_i}{D_i}} \times ([C_g] - [C_o]) \quad (4-8)$$

where:

$$\begin{aligned} [C_g] &= \text{gas concentration in the tank headspace, volume percent} \\ [C_o] &= \text{gas concentration outside the tank, volume percent} \\ \text{Vol} &= \text{volume of the tank headspace, volume} \\ R_g &= \text{gas release rate from the waste surface, volume/time} \\ Q &= \text{the diffusion flux, concentration/area-time} \\ A &= \text{the area of the dome to diffuse, area} \\ D_i &= \text{the } i^{\text{th}} \text{ layer effective diffusivity, area/time} \\ L_i &= \text{the thickness of the } i^{\text{th}} \text{ layer to diffuse, length.} \end{aligned}$$

The gas exhaust rate is the gas diffusion rate in Equation 4-8, which is the diffusion flux, Q_i , times the surface area of the dome. The diffusion flux is the gas concentration gradient between the headspace and outside over the path-length for diffusion times the diffusivity. The summation of the diffusion rates in Equation 4-8 accounts for several diffusion resistances in series (e.g., concrete, asphaltic membrane, gunite, and soil for a tank dome). By solving the

differential Equation 4-8, a time-dependent gas concentration at time t , $[C_g](t)$, in units of volume percent is given in Equation 4-9:

$$[C_g]_{\%}(t) = [C_g]_{\%}(t_0) \exp(-\lambda t) + \left[\frac{R_g}{A \times \frac{1}{\sum_i \frac{L_i}{D_i}}} \right] [1 - \exp(-\lambda t)] \quad (4-9)$$

with

$$\lambda = A \times [1/\sum (L_i/D_i)]/\text{Vol}$$

where:

- R_g = hydrogen release rate from the waste surface, volume/time
- $[C_g](t_0)$ = initial gas concentration at time t , volume percent
- Vol = volume of the tank headspace, volume
- λ = decay parameter from the diffusion, inverse time
- t = time.

4.5 MINIMUM VENTILATION RATE TO MAINTAIN HEADSPACE BELOW 25 OR 100 PERCENT OF THE LFL

Whether the headspace of a tank will reach the specified flammability limit or not depends on the balance between the gas release rates and the ventilation rates of the system. A ventilation rate, defined as the minimum vent rate, which the steady-state concentrations will just reach the specified flammability limit can be determined using Equations 4-4 and 4-7. If the headspace ventilation rate is larger than this minimum, the system will never reach the specified flammability limit. Ventilation rate is embedded in Equations 4-7, and a macro function is used to calculate the minimum ventilation needed to stay below the specified flammability limit (see Section 6.0).

5.0 INPUT DATA

The calculation requires the following concentration inputs to calculate HGR in the liquid: sodium (Na), aluminum (Al), hydroxide (OH), nitrite (NO₂), nitrate (NO₃), and total organic carbon (TOC). The following radionuclide concentrations are also required: cesium-137 (¹³⁷Cs), strontium-90 (⁹⁰Sr), americium-241 (²⁴¹Am), plutonium-238 (²³⁸Pu), plutonium-239 (²³⁹Pu), and plutonium-240 (²⁴⁰Pu). The peak annual averaged waste and headspace temperature, liquid and bulk water concentrations (wt%), and total waste volumes are also needed. Bulk and liquid specific gravity is required to convert waste volumes into total waste mass. All the above data is needed for both supernatant and solid layers. The Best Basis Inventory (BBI), Tank Characterization Database (TCD) accessed through the Tank Waste Information Network System (TWINS), and SACS were queried to obtain the required waste properties and compositions and are shown in Appendix A. Data missing from the database were estimated based on the methodology presented in SNL-000198.

The steps described below were necessary to convert raw BBI data to the format required for input data. Inputs and results are documented in a spreadsheet (*Raw Input Data for RPP-5926 Rev. 8 v1.xls*, SVF-1570):

In BBI detail calculations, more than one density was used in a waste layer for a number of tanks. A single representative density for each waste layer was calculated by weighted averaging and results are shown in Appendix A.

Data are required from the supernatant liquid layer, solid layer (the waste below the supernatant liquid layer), and the total waste. Waste compositions from various solid layer waste types were weight averaged.

Concentrations of TOC, nitrate ion, nitrite ion, and aluminum in the liquid phase and the liquid density for solid layer were assigned the same value as the supernatant liquid layer if no interstitial liquid data were available.

Al, Na, NO₂, NO₃, OH and TOC input concentrations were calculated by dividing the inventory of each analyte by waste volume as follows

$$\text{concentration} \left(\frac{\mu\text{g}}{\text{mL}} \right) = \frac{10^9 \left(\frac{\mu\text{g}}{\text{kg}} \right) \times \text{Inventory (kg)}}{\text{Volume (kL)} \times 10^6 \left(\frac{\text{mL}}{\text{kL}} \right)}$$

Radionuclide input concentrations were calculated by dividing total inventory by waste volume and representative density as follows:

$$\text{concentration} \left(\frac{\mu\text{Ci}}{\text{g}} \right) = \frac{10^6 \left(\frac{\mu\text{Ci}}{\text{Ci}} \right) \times \text{Inventory (Ci)}}{\text{Volume (kL)} \times 10^6 \left(\frac{\text{mL}}{\text{kL}} \right) \times \rho \left(\frac{\text{g}}{\text{mL}} \right)}$$

In BBI development, the total waste volume is divided into three parts: solid, liquid, and retained gas (if there is any). In the detail calculation report, the volume of retained gas is not reported because it has no contribution to the analytes inventory. Although the retained gas has

no contribution to the HGR calculations, it is part of the total waste volume and will impact the headspace volume calculation, and thus the flammability calculations. The reported retained gas volume is included in determining the waste depth and total waste volume for flammability calculations.

Tank waste and tank headspace temperature data were obtained from SACS for the time period from April 1, 2007 to April 1, 2008. The temperature data were reviewed to find the maximum waste temperature for the year. The temperatures measured on this day were averaged for each waste layer. That is, when multiple temperature readings within a waste layer (supernatant or solid layer) were available, then those temperatures were averaged for the day in which the thermocouples measured highest for the year. This process was repeated for headspace temperatures also. The yearly maximum was selected to conservatively include seasonal effects.

Tank capacity, headspace volume, and diameter are inputs for calculating fill fractions and the wetted surface area for corrosion. These values were obtained from RPP-13019. Gaseous diffusion through SST domes requires knowing the surface area, thickness, and diffusivity through the concrete domes. Thickness and diffusivities for asphaltic membrane, gunite, and soil are also required and were taken from RPP-18491. Data used for gaseous diffusion are shown in Appendix B.

Calculations assume an initial flammability of 2% of the LFL to account for ammonia contribution. The basis for ammonia contribution to flammability is given in Appendix C.

Radionuclide concentrations are given in curies and need to be converted to watts. Curie to watt conversions are reported in HNF-EP-0063 and shown in Table 5-1.

Table 5-1. Curie to Watt Conversion Factors.

¹³⁷ Cs* (watt/Ci)	⁹⁰ Sr* (watt/Ci)	²⁴¹ Am (watt/Ci)	²³⁸ Pu (watt/Ci)	²³⁹ Pu (watt/Ci)	²⁴⁰ Pu (watt/Ci)
4.82E-03	6.70E-03	3.34E-02	3.32E-02	3.11E-02	3.12E-02

Note: * Includes daughters with half-life less than parent radionuclides.

6.0 COMPUTER SOFTWARE

TTLFL is calculated by a multiuse spreadsheet that uses Microsoft Excel¹ 2007 software. The file name is DST AND SST TTLFL V1.XLS and is version 1.0. The Spreadsheet Verification and Release Form number is SVF-1536. One macro is used in the spreadsheet to calculate TTLFL. The TTLFL equations required an iteration-based macro function to be created. The TTLFL macro increases time by 0.1 days until the specified flammability (either 25 or 100% of the LFL) calculated by Equation 4-4 is reached.

¹ Excel is a registered trademark of Microsoft Corporation, Redmond, Washington.

7.0 RESULTS

Time to reach 25 and 100% LFLs was calculated for tank headspaces under barometric breathing and zero ventilation conditions. Sections 7.1 and 7.2 present results for DSTs and SSTs, respectively.

7.1 DOUBLE-SHELL TANK RESULTS

Table 7-1 presents results for DSTs under barometric breathing, while Table 7-2 gives results for zero ventilation. Table 7-3 shows hydrogen generation in each DST and minimum ventilation rates to keep flammability below 25 and 100% of the LFL. Results in all three tables include a 5 °C temperature increase and 10,000 gallon water addition.

Table 7-1. Double-Shell Tank Steady-State Flammable Gas Concentration and Time to Lower Flammability Limit Under Barometric Breathing.

Tank	Steady-State Concentration (% of LFL)	Time to Reach 25% of LFL (days)	Time to Reach 100% of LFL (days)
241-AN-101	62%	108	NA
241-AN-102	249%	22	112
241-AN-103	55%	125	NA
241-AN-104	87%	70	NA
241-AN-105	55%	125	NA
241-AN-106	49%	147	NA
241-AN-107	216%	25	136
241-AP-101	15%	NA	NA
241-AP-102	29%	423	NA
241-AP-103	111%	53	514
241-AP-104	29%	409	NA
241-AP-105	3%	NA	NA
241-AP-106	41%	198	NA
241-AP-107	17%	NA	NA
241-AP-108	59%	115	NA
241-AW-101	93%	64	NA
241-AW-102	11%	NA	NA
241-AW-103	22%	NA	NA
241-AW-104	42%	190	NA
241-AW-105	7%	NA	NA
241-AW-106	35%	261	NA
241-AY-101	35%	271	NA
241-AY-102	187%	29	168
241-AZ-101	166%	33	201
241-AZ-102	415%	13	60
241-SY-101	20%	NA	NA
241-SY-102	11%	NA	NA
241-SY-103	35%	264	NA

NA = Not Applicable, headspace will not reach specified flammability level.

Table 7-2. Double-Shell Tank Time to Lower Flammability Limit Under Zero Ventilation.

Tank	Time to Reach 25% of LFL (days)	Time to Reach 100% of LFL (days)
241-AN-101	85	364
241-AN-102	21	88
241-AN-103	96	408
241-AN-104	60	255
241-AN-105	96	409
241-AN-106	108	459
241-AN-107	24	102
241-AP-101	394	1680
241-AP-102	189	806
241-AP-103	47	200
241-AP-104	187	797
241-AP-105	>1826	>1826
241-AP-106	131	558
241-AP-107	349	1488
241-AP-108	90	382
241-AW-101	56	238
241-AW-102	576	>1826
241-AW-103	258	1101
241-AW-104	128	544
241-AW-105	1120	>1826
241-AW-106	154	655
241-AY-101	156	667
241-AY-102	28	118
241-AZ-101	31	132
241-AZ-102	12	53
241-SY-101	280	1193
241-SY-102	567	>1826
241-SY-103	155	659

Table 7-3. Double-Shell Tank Hydrogen Generation Rate and Minimum Ventilation Rate Required to Maintain Headspace Flammable Gas Concentration Below Specified Level.

Tank	Total HGR (ft³/day)	Concentration < 25% of LFL (ft³/min)	Concentration < 100% of LFL (ft³/min)
241-AN-101	3.4	0.28	0.065
241-AN-102	18	1.5	0.35
241-AN-103	4.3	0.35	0.081
241-AN-104	5.8	0.47	0.111
241-AN-105	2.8	0.23	0.054
241-AN-106	6.8	0.55	0.13
241-AN-107	14.1	1.15	0.27
241-AP-101	0.72	0.057	0.013
241-AP-102	1.9	0.15	0.036
241-AP-103	6.3	0.52	0.121
241-AP-104	5.5	0.450	0.106
241-AP-105	0.32	0.026	0.006
241-AP-106	2.3	0.18	0.043
241-AP-107	0.9	0.071	0.017
241-AP-108	1.9	0.15	0.036
241-AW-101	4.9	0.40	0.093
241-AW-102	0.80	0.064	0.015
241-AW-103	1.3	0.109	0.025
241-AW-104	3.0	0.24	0.056
241-AW-105	1.0	0.081	0.019
241-AW-106	2.0	0.16	0.037
241-AY-101	3.6	0.29	0.069
241-AY-102	17	1.4	0.33
241-AZ-101	20	1.7	0.39
241-AZ-102	42	3.4	0.80
241-SY-101	1.1	0.087	0.020
241-SY-102	1.7	0.14	0.032
241-SY-103	4.5	0.37	0.086

7.2 SINGLE-SHELL TANK RESULTS

Table 7-4 presents results for SSTs under barometric breathing, while Table 7-5 gives results for zero ventilation. Mass transfer through barometric breathing greatly exceeds that for dome diffusion. Table 7-4 results neglect diffusion losses, while Table 7-5 includes hydrogen and methane diffusion through the SST domes. Table 7-6 shows hydrogen generation in each SST and minimum ventilation rates to keep flammability below 25 and 100% of the LFL. Minimum ventilation rates also neglect diffusion mass transfer. Results in all three tables include a hypothetical 10,000 gallon water addition in the larger 100-series tanks and a 1,000 gallon water addition in the smaller 200-Series tanks.

Table 7-4. Single-Shell Tank Steady-State Flammable Gas Concentration and Time to Lower Flammability Limit Under Barometric Breathing.

Tank	Steady-State Concentration (% of LFL)	Time to Reach 25% of LFL (days)	Time to Reach 100% of LFL (days)
241-A-101	11%	NA	NA
241-A-102	4%	NA	NA
241-A-103	14%	NA	NA
241-A-104	3%	NA	NA
241-A-105	3%	NA	NA
241-A-106	10%	NA	NA
241-AX-101	8%	NA	NA
241-AX-102	4%	NA	NA
241-AX-103	6%	NA	NA
241-AX-104	5%	NA	NA
241-B-101	5%	NA	NA
241-B-102	4%	NA	NA
241-B-103	4%	NA	NA
241-B-104	7%	NA	NA
241-B-105	5%	NA	NA
241-B-106	4%	NA	NA
241-B-107	4%	NA	NA
241-B-108	4%	NA	NA
241-B-109	4%	NA	NA
241-B-110	7%	NA	NA
241-B-111	11%	NA	NA
241-B-112	4%	NA	NA
241-B-201	14%	NA	NA
241-B-202	13%	NA	NA
241-B-203	155%	36	228
241-B-204	140%	41	276
241-BX-101	4%	NA	NA
241-BX-102	5%	NA	NA
241-BX-103	8%	NA	NA
241-BX-104	5%	NA	NA
241-BX-105	4%	NA	NA
241-BX-106	4%	NA	NA
241-BX-107	7%	NA	NA
241-BX-108	4%	NA	NA
241-BX-109	7%	NA	NA
241-BX-110	6%	NA	NA
241-BX-111	5%	NA	NA

Table 7-4. Single-Shell Tank Steady-State Flammable Gas Concentration and Time to Lower Flammability Limit Under Barometric Breathing.

Tank	Steady-State Concentration (% of LFL)	Time to Reach 25% of LFL (days)	Time to Reach 100% of LFL (days)
241-BX-112	5%	NA	NA
241-BY-101	11%	NA	NA
241-BY-102	5%	NA	NA
241-BY-103	6%	NA	NA
241-BY-104	10%	NA	NA
241-BY-105	8%	NA	NA
241-BY-106	9%	NA	NA
241-BY-107	6%	NA	NA
241-BY-108	6%	NA	NA
241-BY-109	5%	NA	NA
241-BY-110	20%	NA	NA
241-BY-111	6%	NA	NA
241-BY-112	5%	NA	NA
241-C-101	4%	NA	NA
241-C-102	8%	NA	NA
241-C-103	6%	NA	NA
241-C-104	18%	NA	NA
241-C-105	9%	NA	NA
241-C-106	9%	NA	NA
241-C-107	42%	188	NA
241-C-108	6%	NA	NA
241-C-109	4%	NA	NA
241-C-110	5%	NA	NA
241-C-111	11%	NA	NA
241-C-112	13%	NA	NA
241-C-201	7%	NA	NA
241-C-202	7%	NA	NA
241-C-203	6%	NA	NA
241-C-204	6%	NA	NA
241-S-101	10%	NA	NA
241-S-102	4%	NA	NA
241-S-103	6%	NA	NA
241-S-104	7%	NA	NA
241-S-105	6%	NA	NA
241-S-106	7%	NA	NA
241-S-107	8%	NA	NA
241-S-108	7%	NA	NA
241-S-109	7%	NA	NA
241-S-110	9%	NA	NA
241-S-111	9%	NA	NA
241-S-112	5%	NA	NA
241-SX-101	7%	NA	NA
241-SX-102	12%	NA	NA
241-SX-103	43%	184	NA
241-SX-104	20%	NA	NA
241-SX-105	40%	209	NA
241-SX-106	7%	NA	NA
241-SX-107	8%	NA	NA
241-SX-108	4%	NA	NA
241-SX-109	25%	959	NA

Table 7-4. Single-Shell Tank Steady-State Flammable Gas Concentration and Time to Lower Flammability Limit Under Barometric Breathing.

Tank	Steady-State Concentration (% of LFL)	Time to Reach 25% of LFL (days)	Time to Reach 100% of LFL (days)
241-SX-110	14%	NA	NA
241-SX-111	11%	NA	NA
241-SX-112	7%	NA	NA
241-SX-113	3%	NA	NA
241-SX-114	15%	NA	NA
241-SX-115	4%	NA	NA
241-T-101	4%	NA	NA
241-T-102	6%	NA	NA
241-T-103	4%	NA	NA
241-T-104	6%	NA	NA
241-T-105	5%	NA	NA
241-T-106	4%	NA	NA
241-T-107	6%	NA	NA
241-T-108	4%	NA	NA
241-T-109	4%	NA	NA
241-T-110	13%	NA	NA
241-T-111	9%	NA	NA
241-T-112	4%	NA	NA
241-T-201	33%	304	NA
241-T-202	9%	NA	NA
241-T-203	20%	NA	NA
241-T-204	20%	NA	NA
241-TX-101	4%	NA	NA
241-TX-102	5%	NA	NA
241-TX-103	4%	NA	NA
241-TX-104	4%	NA	NA
241-TX-105	13%	NA	NA
241-TX-106	6%	NA	NA
241-TX-107	3%	NA	NA
241-TX-108	4%	NA	NA
241-TX-109	7%	NA	NA
241-TX-110	8%	NA	NA
241-TX-111	7%	NA	NA
241-TX-112	12%	NA	NA
241-TX-113	9%	NA	NA
241-TX-114	8%	NA	NA
241-TX-115	9%	NA	NA
241-TX-116	8%	NA	NA
241-TX-117	6%	NA	NA
241-TX-118	8%	NA	NA
241-TY-101	4%	NA	NA
241-TY-102	4%	NA	NA
241-TY-103	5%	NA	NA
241-TY-104	4%	NA	NA
241-TY-105	6%	NA	NA
241-TY-106	3%	NA	NA
241-U-101	4%	NA	NA
241-U-102	14%	NA	NA
241-U-103	24%	NA	NA
241-U-104	4%	NA	NA

Table 7-4. Single-Shell Tank Steady-State Flammable Gas Concentration and Time to Lower Flammability Limit Under Barometric Breathing.

Tank	Steady-State Concentration (% of LFL)	Time to Reach 25% of LFL (days)	Time to Reach 100% of LFL (days)
241-U-105	23%	NA	NA
241-U-106	12%	NA	NA
241-U-107	8%	NA	NA
241-U-108	14%	NA	NA
241-U-109	12%	NA	NA
241-U-110	6%	NA	NA
241-U-111	6%	NA	NA
241-U-112	4%	NA	NA
241-U-201	4%	NA	NA
241-U-202	4%	NA	NA
241-U-203	4%	NA	NA
241-U-204	7%	NA	NA

NA = Not Applicable, headspace will not reach specified flammability level.

Table 7-5. Single-Shell Tank Time to Lower Flammability Limit Under Zero Ventilation.

Tank	Time to Reach 25% of LFL (days)	Time to Reach 100% of LFL (days)
241-A-101	592	>1826
241-A-102	>1826	>1826
241-A-103	439	>1826
241-A-104	>1826	>1826
241-A-105	>1826	>1826
241-A-106	642	>1826
241-AX-101	not occur	not occur
241-AX-102	not occur	not occur
241-AX-103	not occur	not occur
241-AX-104	not occur	not occur
241-B-101	1725	>1826
241-B-102	>1826	>1826
241-B-103	>1826	>1826
241-B-104	1196	>1826
241-B-105	1588	>1826
241-B-106	>1826	>1826
241-B-107	>1826	>1826
241-B-108	>1826	>1826
241-B-109	>1826	>1826
241-B-110	1023	>1826
241-B-111	565	>1826
241-B-112	>1826	>1826
241-B-201	418	>1826
241-B-202	459	>1826
241-B-203	34	145
241-B-204	37	160
241-BX-101	>1826	>1826
241-BX-102	>1826	>1826
241-BX-103	864	>1826
241-BX-104	>1826	>1826
241-BX-105	>1826	>1826

Table 7-5. Single-Shell Tank Time to Lower Flammability Limit Under Zero Ventilation.

Tank	Time to Reach 25% of LFL (days)	Time to Reach 100% of LFL (days)
241-BX-106	>1826	>1826
241-BX-107	1088	>1826
241-BX-108	>1826	>1826
241-BX-109	1180	>1826
241-BX-110	1325	>1826
241-BX-111	>1826	>1826
241-BX-112	>1826	>1826
241-BY-101	595	>1826
241-BY-102	>1826	>1826
241-BY-103	1247	>1826
241-BY-104	644	>1826
241-BY-105	842	>1826
241-BY-106	761	>1826
241-BY-107	1308	>1826
241-BY-108	1424	>1826
241-BY-109	1783	>1826
241-BY-110	282	1247
241-BY-111	1267	>1826
241-BY-112	1652	>1826
241-C-101	>1826	>1826
241-C-102	835	>1826
241-C-103	1318	>1826
241-C-104	325	1457
241-C-105	751	>1826
241-C-106	755	>1826
241-C-107	128	555
241-C-108	1315	>1826
241-C-109	>1826	>1826
241-C-110	>1826	>1826
241-C-111	577	>1826
241-C-112	486	>1826
241-C-201	1155	>1826
241-C-202	1136	>1826
241-C-203	1182	>1826
241-C-204	1195	>1826
241-S-101	627	>1826
241-S-102	>1826	>1826
241-S-103	1351	>1826
241-S-104	1136	>1826
241-S-105	1468	>1826
241-S-106	982	>1826
241-S-107	873	>1826
241-S-108	1050	>1826
241-S-109	1082	>1826
241-S-110	797	>1826
241-S-111	803	>1826
241-S-112	1710	>1826
241-SX-101	not occur	not occur
241-SX-102	not occur	not occur
241-SX-103	not occur	not occur
241-SX-104	not occur	not occur

Table 7-5. Single-Shell Tank Time to Lower Flammability Limit Under Zero Ventilation.

Tank	Time to Reach 25% of LFL (days)	Time to Reach 100% of LFL (days)
241-SX-105	not occur	not occur
241-SX-106	not occur	not occur
241-SX-107	not occur	not occur
241-SX-108	not occur	not occur
241-SX-109	not occur	not occur
241-SX-110	not occur	not occur
241-SX-111	not occur	not occur
241-SX-112	not occur	not occur
241-SX-113	not occur	not occur
241-SX-114	not occur	not occur
241-SX-115	not occur	not occur
241-T-101	>1826	>1826
241-T-102	1226	>1826
241-T-103	>1826	>1826
241-T-104	1343	>1826
241-T-105	>1826	>1826
241-T-106	>1826	>1826
241-T-107	1415	>1826
241-T-108	>1826	>1826
241-T-109	>1826	>1826
241-T-110	475	>1826
241-T-111	793	>1826
241-T-112	>1826	>1826
241-T-201	166	721
241-T-202	736	>1826
241-T-203	289	1278
241-T-204	289	1281
241-TX-101	>1826	>1826
241-TX-102	>1826	>1826
241-TX-103	>1826	>1826
241-TX-104	>1826	>1826
241-TX-105	463	>1826
241-TX-106	1241	>1826
241-TX-107	>1826	>1826
241-TX-108	>1826	>1826
241-TX-109	1109	>1826
241-TX-110	841	>1826
241-TX-111	1118	>1826
241-TX-112	513	>1826
241-TX-113	719	>1826
241-TX-114	927	>1826
241-TX-115	738	>1826
241-TX-116	878	>1826
241-TX-117	1234	>1826
241-TX-118	846	>1826
241-TY-101	>1826	>1826
241-TY-102	>1826	>1826
241-TY-103	>1826	>1826
241-TY-104	>1826	>1826
241-TY-105	1309	>1826
241-TY-106	>1826	>1826

Table 7-5. Single-Shell Tank Time to Lower Flammability Limit Under Zero Ventilation.

Tank	Time to Reach 25% of LFL (days)	Time to Reach 100% of LFL (days)
241-U-101	>1826	>1826
241-U-102	439	>1826
241-U-103	239	1082
241-U-104	>1826	>1826
241-U-105	245	1093
241-U-106	525	>1826
241-U-107	933	>1826
241-U-108	429	>1826
241-U-109	541	>1826
241-U-110	1222	>1826
241-U-111	1229	>1826
241-U-112	>1826	>1826
241-U-201	>1826	>1826
241-U-202	>1826	>1826
241-U-203	>1826	>1826
241-U-204	951	>1826

not occur = Gaseous molecular diffusion through the tank domes prevents significant build up of flammable gases in AX and SX tanks as documented in RPP-18491.

Table 7-6. Single-Shell Tank Hydrogen Generation Rate and Minimum Ventilation Rate Required to Maintain Headspace Flammable Gas Concentration Below Specified Level.

Tank	Total HGR (ft³/day)	Concentration < 25% of LFL (ft³/min)	Concentration < 100% of LFL (ft³/min)
241-A-101	1.7	0.13	0.031
241-A-102	0.55	0.043	0.010
241-A-103	2.5	0.20	0.047
241-A-104	0.32	0.024	0.0057
241-A-105	0.33	0.025	0.0058
241-A-106	2.2	0.18	0.043
241-AX-101	1.4	0.11	0.025
241-AX-102	0.74	0.058	0.014
241-AX-103	1.2	0.096	0.022
241-AX-104	1.04	0.083	0.019
241-B-101	0.54	0.042	0.010
241-B-102	0.33	0.025	0.0058
241-B-103	0.34	0.026	0.0060
241-B-104	0.51	0.039	0.0091
241-B-105	0.46	0.035	0.0081
241-B-106	0.42	0.032	0.0076
241-B-107	0.40	0.030	0.0071
241-B-108	0.36	0.027	0.0064
241-B-109	0.37	0.028	0.0066
241-B-110	0.72	0.056	0.013
241-B-111	1.3	0.10	0.024
241-B-112	0.40	0.031	0.0072
241-B-201	0.086	0.0065	0.0015
241-B-202	0.080	0.0061	0.0014
241-B-203	0.30	0.022	0.0052
241-B-204	0.29	0.022	0.0052

Table 7-6. Single-Shell Tank Hydrogen Generation Rate and Minimum Ventilation Rate Required to Maintain Headspace Flammable Gas Concentration Below Specified Level.

Tank	Total HGR (ft ³ /day)	Concentration < 25% of LFL (ft ³ /min)	Concentration < 100% of LFL (ft ³ /min)
241-BX-101	0.37	0.029	0.0067
241-BX-102	0.49	0.038	0.0089
241-BX-103	1.06	0.085	0.020
241-BX-104	0.51	0.040	0.0093
241-BX-105	0.40	0.031	0.0072
241-BX-106	0.46	0.036	0.0084
241-BX-107	0.58	0.044	0.010
241-BX-108	0.34	0.026	0.0061
241-BX-109	0.68	0.053	0.013
241-BX-110	0.60	0.046	0.011
241-BX-111	0.44	0.034	0.0079
241-BX-112	0.47	0.036	0.0084
241-BY-101	1.3	0.107	0.025
241-BY-102	0.53	0.040	0.0094
241-BY-103	0.64	0.049	0.011
241-BY-104	1.2	0.09	0.022
241-BY-105	0.82	0.064	0.015
241-BY-106	1.0	0.077	0.018
241-BY-107	0.73	0.057	0.013
241-BY-108	0.71	0.056	0.013
241-BY-109	0.54	0.042	0.010
241-BY-110	2.8	0.22	0.053
241-BY-111	0.64	0.049	0.012
241-BY-112	0.58	0.045	0.010
241-C-101	0.44	0.034	0.0079
241-C-102	0.78	0.061	0.014
241-C-103	0.81	0.061	0.014
241-C-104	2.1	0.17	0.039
241-C-105	1.1	0.090	0.021
241-C-106	1.35	0.11	0.025
241-C-107	5.3	0.43	0.10
241-C-108	0.81	0.061	0.014
241-C-109	0.32	0.024	0.0057
241-C-110	0.45	0.034	0.0081
241-C-111	1.6	0.13	0.030
241-C-112	1.8	0.14	0.034
241-C-201	0.0627	0.0048	0.0011
241-C-202	0.0636	0.0048	0.0011
241-C-203	0.0614	0.0046	0.0011
241-C-204	0.0608	0.0046	0.0011
241-S-101	1.3	0.10	0.024
241-S-102	0.37	0.028	0.0067
241-S-103	0.74	0.058	0.014
241-S-104	0.82	0.064	0.015
241-S-105	0.56	0.043	0.010
241-S-106	0.75	0.058	0.014
241-S-107	0.96	0.075	0.018
241-S-108	0.6	0.046	0.011
241-S-109	0.61	0.046	0.011
241-S-110	1.0	0.078	0.018

Table 7-6. Single-Shell Tank Hydrogen Generation Rate and Minimum Ventilation Rate Required to Maintain Headspace Flammable Gas Concentration Below Specified Level.

Tank	Total HGR (ft³/day)	Concentration < 25% of LFL (ft³/min)	Concentration < 100% of LFL (ft³/min)
241-S-111	0.86	0.067	0.016
241-S-112	0.78	0.059	0.014
241-SX-101	0.99	0.077	0.018
241-SX-102	2.1	0.17	0.040
241-SX-103	7.1	0.58	0.14
241-SX-104	3.4	0.27	0.064
241-SX-105	7.7	0.62	0.15
241-SX-106	1.1	0.086	0.020
241-SX-107	1.7	0.14	0.033
241-SX-108	0.65	0.051	0.012
241-SX-109	5.5	0.44	0.10
241-SX-110	3.3	0.27	0.063
241-SX-111	2.3	0.18	0.043
241-SX-112	1.3	0.10	0.025
241-SX-113	0.33	0.025	0.0059
241-SX-114	3.3	0.26	0.062
241-SX-115	0.47	0.037	0.0086
241-T-101	0.42	0.032	0.0075
241-T-102	0.84	0.064	0.015
241-T-103	0.33	0.025	0.0059
241-T-104	0.51	0.039	0.0091
241-T-105	0.44	0.034	0.0079
241-T-106	0.32	0.024	0.0057
241-T-107	0.60	0.046	0.011
241-T-108	0.32	0.024	0.0056
241-T-109	0.34	0.026	0.0061
241-T-110	1.2	0.094	0.022
241-T-111	0.63	0.048	0.011
241-T-112	0.35	0.027	0.0062
241-T-201	0.21	0.016	0.0037
241-T-202	0.064	0.0049	0.0011
241-T-203	0.096	0.0073	0.0017
241-T-204	0.095	0.0072	0.0017
241-TX-101	0.51	0.039	0.0092
241-TX-102	0.56	0.043	0.010
241-TX-103	0.45	0.034	0.0081
241-TX-104	0.43	0.033	0.0078
241-TX-105	1.2	0.095	0.022
241-TX-106	0.70	0.054	0.013
241-TX-107	0.35	0.026	0.0062
241-TX-108	0.43	0.033	0.0077
241-TX-109	0.76	0.059	0.014
241-TX-110	0.84	0.065	0.015
241-TX-111	0.75	0.058	0.014
241-TX-112	0.97	0.076	0.018
241-TX-113	0.71	0.054	0.013
241-TX-114	0.69	0.053	0.012
241-TX-115	0.82	0.063	0.015
241-TX-116	0.65	0.049	0.011
241-TX-117	0.6	0.04	0.010

Table 7-6. Single-Shell Tank Hydrogen Generation Rate and Minimum Ventilation Rate Required to Maintain Headspace Flammable Gas Concentration Below Specified Level.

Tank	Total HGR (ft³/day)	Concentration < 25% of LFL (ft³/min)	Concentration < 100% of LFL (ft³/min)
241-TX-118	1.1	0.089	0.021
241-TY-101	0.38	0.029	0.0067
241-TY-102	0.35	0.027	0.0063
241-TY-103	0.57	0.044	0.010
241-TY-104	0.39	0.030	0.0070
241-TY-105	0.77	0.060	0.014
241-TY-106	0.34	0.026	0.0060
241-U-101	0.40	0.030	0.0071
241-U-102	1.4	0.111	0.026
241-U-103	1.7	0.13	0.032
241-U-104	0.40	0.031	0.0072
241-U-105	2.3	0.19	0.044
241-U-106	1.5	0.12	0.028
241-U-107	0.73	0.057	0.013
241-U-108	1.1	0.090	0.021
241-U-109	0.81	0.063	0.015
241-U-110	0.68	0.053	0.012
241-U-111	0.63	0.049	0.012
241-U-112	0.41	0.031	0.0073
241-U-201	0.031	0.0024	0.0006
241-U-202	0.031	0.0023	0.0005
241-U-203	0.030	0.0023	0.0005
241-U-204	0.073	0.0055	0.0013

8.0 CONCLUSIONS

Flammable gas concentrations, in terms of percent of the LFL in the tank headspace, were evaluated under off-normal conditions for all 177 tanks. Assuming barometric breathing only, the shortest time to reach 25% of the LFL is 36 days for SST 241-B-203 and 13 days for DST 241-AZ-102. Assuming zero ventilation, the shortest time to reach 25% of the LFL is 34 days for SST 241-B-203 and 12 days for DST 241-AZ-102.

The steady-state flammability level in the tank headspace was evaluated based on the steady-state flammable gas concentrations and Le Chatelier's rule. Overall, the calculations under off-normal conditions show that 20 DSTs and 7 SSTs will reach 25% of the LFL and 6 DSTs and 2 SSTs will reach 100% of the LFL if allowed to reach steady-state under barometric breathing only.

Results can be used to establish technical safety requirements for ventilation in tanks, to establish maximum permissible down times for active ventilation systems, to develop procedures for operations that require closing vent valves to HEPA filters on passively ventilated tanks, and to support the technical basis for flammable gas control strategies.

9.0 REFERENCES

- Coward, H. F., and G. W. Jones, 1952, *Limits of Flammability of Gases and Vapors*, Bumines B. 503, 155 pp.
- HNF-3851, 2004, *Empirical Rate Equation Model and Rate Calculations of Hydrogen Generation for Hanford Tank Waste*, Rev. 1, CH2M HILL Hanford Group, Inc., Richland, Washington.
- HNF-EP-0063, 2008, *Hanford Site Solid Waste Acceptance Criteria*, Rev. 14 (reissue), Fluor Hanford, Richland, Washington.
- Pfahl, U., and J. Shepherd, 1997, *Flammability and Flame Propagation in H_2 - N_2O - CH_4 - NH_3 - O_2 - N_2 Mixtures*, Explosion Dynamics Laboratory Report FM97-4, Graduate Aeronautical Laboratories, California Institute of Technology, Pasadena, California.
- PNNL-12181, 1999, *Thermal and Radiolytic Gas Generation Tests on Material from Tanks 241-U-103, 241-AW-101, 241-S-106, and 241-S-102: Status Report*, Pacific Northwest National Laboratory, Richland, Washington.
- PNNL-13000, 1999, *Retained Gas Sampling Results for the Flammable Gas Program*, Rev. 0, Pacific Northwest National Laboratory, Richland, Washington.
- RPP-13019, 2003, *Determination of Hanford Waste Tank Volumes*, Rev. 0, CH2M HILL Hanford Group, Inc., Richland, Washington.

- RPP-18491, 2003, *Flammable Gas Diffusion Through Single-Shell Tank Domes*, Rev. 0, CH2M HILL Hanford Group, Inc., Richland, Washington.
- SACS, 2008, Surveillance Analysis Computer System, Queried August 4, 2008, [Tank temperature data April 2007 through April 2008], HISI ID No. 242, CH2M HILL Hanford Group, Inc., Richland, Washington.
- SNL-000198, 1999, *Flammable Gas Safety Analysis Data Review*, Sandia National Laboratory, Albuquerque, New Mexico.
- SVF-1536, 2008, *DST and SST TTLFL v1.xls*, Version 1, Washington River Protection Solutions, Richland, Washington.
- SVF-1570, 2008, *Raw Input Data for RPP-5926 Rev. 8 v1.xls*, Version 1, Washington River Protection Solutions, Richland, Washington.
- TWINS, 2008, *Tank Waste Information Network System*, Queried August 4, 2008, [Best Basis Inventory data], internet address: <http://twins.pnl.gov/twins.htm>.
- WHC-EP-0651, 1993, *Barometric Pressure Variations*, Westinghouse Hanford Company, Richland, Washington.
- WHC-SD-WM-ES-219, 1992, *Laboratory Flammability Studies of Mixtures of Hydrogen, Nitrous Oxide, and Air*, Rev. 0, Westinghouse Hanford Company, Richland, Washington.

APPENDIX A

**INPUT DATA FOR TIME TO THE LOWER FLAMMABILITY LIMIT
CALCULATIONS**

Table A-1. Tank Waste Chemical Concentrations.

Tank	Layer	OH ⁻ (µg/mL)	TOC (µg/mL)	NO ₂ ⁻ (µg/mL)	NO ₃ ⁻ (µg/mL)	Na ⁺ (µg/mL)	Al ³⁺ (µg/mL)
241-AN-101	Supernatant	3.28E+04	5.37E+03	1.11E+05	1.62E+05	2.10E+05	1.91E+04
241-AN-101	Solid	4.81E+04	4.04E+03	1.22E+05	1.90E+05	2.36E+05	3.79E+04
241-AN-102	Supernatant	8.18E+03	2.41E+04	8.71E+04	1.97E+05	2.12E+05	1.32E+04
241-AN-102	Solid	8.18E+03	2.41E+04	8.71E+04	1.97E+05	2.12E+05	1.32E+04
241-AN-103	Supernatant	6.73E+04	3.05E+03	1.30E+05	1.28E+05	2.70E+05	3.00E+04
241-AN-103	Solid	6.73E+04	3.05E+03	1.30E+05	1.28E+05	2.70E+05	3.00E+04
241-AN-104	Supernatant	6.53E+04	3.14E+03	1.19E+05	1.89E+05	2.58E+05	3.90E+04
241-AN-104	Solid	6.53E+04	3.14E+03	1.19E+05	1.89E+05	2.58E+05	3.90E+04
241-AN-105	Supernatant	5.98E+04	2.76E+03	1.19E+05	1.56E+05	2.47E+05	0.00E+00
241-AN-105	Solid	5.98E+04	2.76E+03	1.19E+05	1.56E+05	2.47E+05	4.17E+04
241-AN-106	Supernatant	6.45E+03	1.38E+03	3.34E+04	1.04E+04	7.05E+04	1.58E+03
241-AN-106	Solid	6.45E+03	1.39E+03	3.35E+04	1.04E+04	7.05E+04	1.58E+03
241-AN-107	Supernatant	1.80E+04	3.25E+04	6.67E+04	2.09E+05	2.08E+05	1.12E+03
241-AN-107	Solid	1.80E+04	3.25E+04	6.67E+04	2.09E+05	2.08E+05	1.12E+03
241-AP-101	Supernatant	1.79E+04	9.97E+02	2.10E+04	1.71E+05	1.11E+05	5.80E+03
241-AP-101	Solid	1.79E+04	9.97E+02	2.10E+04	1.71E+05	1.11E+05	5.80E+03
241-AP-102	Supernatant	3.42E+04	2.38E+03	9.57E+04	1.67E+05	1.85E+05	2.42E+04
241-AP-102	Solid	3.42E+04	2.38E+03	9.57E+04	1.67E+05	1.85E+05	2.42E+04
241-AP-103	Supernatant	2.31E+04	7.11E+03	8.79E+04	1.55E+05	1.95E+05	2.07E+04
241-AP-103	Solid	2.31E+04	7.11E+03	8.79E+04	1.55E+05	1.95E+05	2.07E+04
241-AP-104	Supernatant	2.69E+04	6.76E+03	9.50E+04	1.43E+05	1.92E+05	2.34E+04
241-AP-104	Solid	2.69E+04	6.76E+03	9.50E+04	1.43E+05	1.92E+05	2.34E+04
241-AP-105	Supernatant	1.04E+04	1.01E+03	2.22E+04	2.08E+05	1.18E+05	7.05E+03
241-AP-105	Solid	1.04E+04	1.01E+03	2.22E+04	2.08E+05	1.18E+05	7.05E+03
241-AP-106	Supernatant	7.37E+03	3.46E+03	4.14E+04	7.07E+04	1.03E+05	1.35E+04
241-AP-106	Solid	7.37E+03	3.46E+03	4.14E+04	7.07E+04	1.03E+05	1.35E+04
241-AP-107	Supernatant	1.88E+04	1.61E+03	3.23E+04	1.53E+05	1.25E+05	9.10E+03
241-AP-107	Solid	1.88E+04	1.61E+03	3.23E+04	1.53E+05	1.25E+05	9.10E+03
241-AP-108	Supernatant	3.66E+04	3.50E+03	7.98E+04	1.75E+05	2.07E+05	2.31E+04
241-AP-108	Solid	3.66E+04	3.50E+03	7.98E+04	1.75E+05	2.07E+05	2.31E+04
241-AW-101	Supernatant	9.95E+04	2.61E+03	1.05E+05	1.71E+05	2.33E+05	2.95E+04
241-AW-101	Solid	9.95E+04	2.61E+03	1.05E+05	1.71E+05	2.33E+05	2.95E+04
241-AW-102	Supernatant	1.65E+04	1.10E+03	2.20E+04	1.69E+05	1.10E+05	6.16E+03
241-AW-102	Solid	1.65E+04	1.10E+03	2.20E+04	1.69E+05	1.10E+05	6.16E+03
241-AW-103	Supernatant	1.31E+04	1.88E+03	3.36E+04	9.66E+04	1.01E+05	8.12E+03
241-AW-103	Solid	2.72E+04	6.11E+03	9.31E+04	2.47E+05	2.01E+05	8.08E+03
241-AW-104	Supernatant	2.56E+04	4.33E+03	7.52E+04	1.14E+05	1.72E+05	2.58E+04
241-AW-104	Solid	3.63E+04	3.26E+03	7.33E+04	1.08E+05	2.26E+05	2.91E+04
241-AW-105	Supernatant	4.81E+03	5.56E+02	3.06E+03	2.73E+04	2.30E+04	1.90E+02
241-AW-105	Solid	4.81E+03	5.56E+02	3.06E+03	2.73E+04	2.30E+04	1.90E+02
241-AW-106	Supernatant	1.17E+04	2.33E+03	3.26E+04	1.27E+05	1.19E+05	9.77E+03
241-AW-106	Solid	1.17E+04	2.33E+03	3.26E+04	1.27E+05	1.19E+05	9.77E+03
241-AY-101	Supernatant	9.58E+03	6.00E+02	9.77E+03	5.30E+04	4.70E+04	2.47E+03
241-AY-101	Solid	3.75E+02	1.03E+03	3.93E+04	3.77E+03	1.27E+05	8.63E+02
241-AY-102	Supernatant	3.85E+04	1.88E+03	4.14E+04	1.13E+05	1.28E+05	7.06E+03
241-AY-102	Solid	5.52E+02	1.53E+03	7.25E+03	3.88E+02	7.03E+04	3.41E+02
241-AZ-101	Supernatant	1.24E+04	5.58E+02	6.69E+04	5.75E+04	1.21E+05	6.59E+03
241-AZ-101	Solid	1.24E+04	5.58E+02	6.69E+04	5.75E+04	1.21E+05	6.59E+03
241-AZ-102	Supernatant	2.09E+03	1.09E+03	3.51E+04	1.39E+04	5.98E+04	5.79E+02
241-AZ-102	Solid	2.09E+03	1.09E+03	3.51E+04	1.39E+04	5.98E+04	5.79E+02

Table A-1. Tank Waste Chemical Concentrations.

Tank	Layer	OH ⁻ (µg/mL)	TOC (µg/mL)	NO ₂ ⁻ (µg/mL)	NO ₃ ⁻ (µg/mL)	Na ⁺ (µg/mL)	Al ³⁺ (µg/mL)
241-SY-101	Supernatant	1.11E+04	9.92E+02	9.30E+03	5.77E+04	5.61E+04	3.78E+03
241-SY-101	Solid	1.11E+04	9.92E+02	9.30E+03	5.77E+04	5.61E+04	3.78E+03
241-SY-102	Supernatant	8.83E+03	7.95E+02	7.73E+03	4.62E+04	4.41E+04	2.93E+03
241-SY-102	Solid	2.07E+04	3.61E+03	5.61E+04	1.27E+05	1.34E+05	7.61E+03
241-SY-103	Supernatant	3.74E+04	6.23E+03	1.52E+05	1.68E+05	2.15E+05	4.07E+04
241-SY-103	Solid	3.74E+04	6.23E+03	1.52E+05	1.68E+05	2.15E+05	4.07E+04
241-A-101	Supernatant	4.27E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-A-101	Solid	4.27E+04	3.74E+03	1.65E+05	2.33E+05	2.78E+05	5.18E+04
241-A-102	Supernatant	1.73E+04	4.42E+03	1.73E+05	1.89E+05	2.00E+05	4.10E+04
241-A-102	Solid	1.73E+04	4.42E+03	1.72E+05	1.89E+05	2.00E+05	4.09E+04
241-A-103	Supernatant	4.89E+04	8.29E+03	1.24E+05	2.42E+05	2.35E+05	3.55E+04
241-A-103	Solid	4.89E+04	8.31E+03	1.24E+05	2.42E+05	2.35E+05	3.55E+04
241-A-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-A-104	Solid	4.27E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-A-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-A-105	Solid	4.27E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-A-106	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-A-106	Solid	4.27E+04	1.10E+04	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-AX-101	Supernatant	3.90E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-AX-101	Solid	3.90E+04	3.98E+03	1.73E+05	2.72E+05	2.82E+05	5.03E+04
241-AX-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-AX-102	Solid	3.89E+04	2.30E+04	1.07E+05	1.76E+05	1.98E+05	2.75E+04
241-AX-103	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-AX-103	Solid	3.89E+04	4.03E+03	1.22E+05	1.91E+05	2.36E+05	3.79E+04
241-AX-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-AX-104	Solid	3.89E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-B-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-101	Solid	1.70E+04	6.77E+00	1.32E+05	3.56E+05	2.26E+05	7.23E+02
241-B-102	Supernatant	1.70E+04	3.38E+00	8.47E+03	2.17E+05	1.13E+05	3.61E+02
241-B-102	Solid	1.70E+04	3.38E+00	8.52E+03	2.17E+05	1.13E+05	3.61E+02
241-B-103	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-103	Solid	1.70E+04	3.38E+00	8.50E+03	2.18E+05	1.13E+05	3.62E+02
241-B-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-104	Solid	1.70E+04	3.38E+00	8.49E+03	2.16E+05	1.13E+05	3.62E+02
241-B-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-105	Solid	1.70E+04	3.38E+00	8.51E+03	2.16E+05	1.13E+05	3.62E+02
241-B-106	Supernatant	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.60E+02
241-B-106	Solid	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.60E+02
241-B-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-107	Solid	1.70E+04	5.04E+00	6.51E+03	3.31E+05	1.46E+05	2.01E+01
241-B-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-108	Solid	1.70E+04	3.71E+00	5.38E+04	3.76E+05	1.74E+05	8.98E+02
241-B-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-109	Solid	1.70E+04	3.39E+00	8.51E+03	2.17E+05	1.13E+05	3.61E+02
241-B-110	Supernatant	1.70E+04	5.55E+03	3.95E+04	7.78E+04	9.55E+04	1.04E+04
241-B-110	Solid	1.70E+04	5.55E+03	3.95E+04	7.78E+04	9.55E+04	1.04E+04
241-B-111	Supernatant	1.70E+04	5.55E+03	3.95E+04	7.78E+04	9.55E+04	1.04E+04
241-B-111	Solid	1.70E+04	5.55E+03	3.95E+04	7.78E+04	9.55E+04	1.04E+04
241-B-112	Supernatant	1.70E+04	1.82E+04	1.17E+05	2.17E+05	2.55E+05	4.73E+04
241-B-112	Solid	1.70E+04	1.82E+04	1.17E+05	2.17E+05	2.55E+05	4.73E+04

Table A-1. Tank Waste Chemical Concentrations.

Tank	Layer	OH ⁻ (µg/mL)	TOC (µg/mL)	NO ₂ ⁻ (µg/mL)	NO ₃ ⁻ (µg/mL)	Na ⁺ (µg/mL)	Al ³⁺ (µg/mL)
241-B-201	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-201	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-B-202	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-202	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-B-203	Supernatant	1.70E+04	9.60E+01	1.57E+03	5.65E+04	3.12E+04	0.00E+00
241-B-203	Solid	1.70E+04	9.60E+01	1.57E+03	5.65E+04	3.12E+04	0.00E+00
241-B-204	Supernatant	1.70E+04	7.53E+01	1.36E+03	3.47E+04	2.78E+04	0.00E+00
241-B-204	Solid	1.70E+04	7.53E+01	1.36E+03	3.47E+04	2.78E+04	0.00E+00
241-BX-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-101	Solid	1.70E+04	4.98E+03	6.43E+04	1.21E+05	1.42E+05	5.17E+03
241-BX-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-102	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-BX-103	Supernatant	1.70E+04	3.64E+03	1.37E+04	4.44E+04	3.88E+04	1.77E+04
241-BX-103	Solid	1.70E+04	3.64E+03	1.37E+04	4.44E+04	3.88E+04	1.77E+04
241-BX-104	Supernatant	1.70E+04	3.19E+03	6.37E+04	1.34E+05	1.40E+05	2.84E+03
241-BX-104	Solid	1.70E+04	3.19E+03	6.37E+04	1.34E+05	1.40E+05	2.84E+03
241-BX-105	Supernatant	1.70E+04	9.44E+03	4.00E+04	1.17E+05	1.24E+05	5.94E+03
241-BX-105	Solid	1.70E+04	9.44E+03	4.00E+04	1.17E+05	1.24E+05	5.94E+03
241-BX-106	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-106	Solid	1.70E+04	1.82E+04	1.17E+05	2.17E+05	2.55E+05	4.72E+04
241-BX-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-107	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-BX-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-108	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-BX-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-109	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-BX-110	Supernatant	1.70E+04	1.52E+04	5.22E+04	4.12E+05	2.10E+05	1.91E+04
241-BX-110	Solid	1.70E+04	1.52E+04	5.21E+04	4.12E+05	2.01E+05	8.08E+03
241-BX-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-111	Solid	1.70E+04	1.70E+03	1.06E+05	1.85E+05	2.26E+05	4.87E+04
241-BX-112	Supernatant	1.70E+04	0.00E+00	3.52E+04	9.86E+04	7.78E+04	4.78E+01
241-BX-112	Solid	1.70E+04	0.00E+00	3.52E+04	9.86E+04	7.78E+04	4.78E+01
241-BY-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-101	Solid	3.83E+04	1.82E+04	1.17E+05	2.17E+05	2.56E+05	4.73E+04
241-BY-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-102	Solid	3.83E+04	1.55E+03	8.41E+04	1.48E+05	2.34E+05	5.66E+04
241-BY-103	Supernatant	3.15E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-103	Solid	3.15E+04	1.59E+03	4.49E+04	1.41E+05	1.80E+05	3.46E+04
241-BY-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-104	Solid	3.83E+04	2.37E+03	1.11E+05	2.07E+05	2.48E+05	7.19E+04
241-BY-105	Supernatant	3.83E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-105	Solid	3.83E+04	2.43E+03	6.86E+04	1.99E+05	2.08E+05	3.92E+04
241-BY-106	Supernatant	3.58E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-106	Solid	3.58E+04	2.67E+03	7.83E+04	1.10E+05	1.64E+05	3.98E+04
241-BY-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-107	Solid	3.83E+04	2.40E+03	1.17E+05	1.31E+05	2.43E+05	5.12E+04
241-BY-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-108	Solid	3.83E+04	2.37E+03	7.85E+04	2.94E+05	2.82E+05	3.63E+04
241-BY-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-109	Solid	3.83E+04	1.88E+03	8.29E+04	1.90E+05	2.10E+05	3.88E+04

Table A-1. Tank Waste Chemical Concentrations.

Tank	Layer	OH ⁻ (µg/mL)	TOC (µg/mL)	NO ₂ ⁻ (µg/mL)	NO ₃ ⁻ (µg/mL)	Na ⁺ (µg/mL)	Al ³⁺ (µg/mL)
241-BY-110	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-110	Solid	3.83E+04	1.94E+04	1.24E+05	1.24E+05	2.54E+05	6.58E+04
241-BY-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-111	Solid	3.83E+04	1.28E+03	5.46E+04	2.01E+05	2.17E+05	4.30E+04
241-BY-112	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-112	Solid	3.83E+04	1.72E+03	1.41E+05	1.90E+05	2.44E+05	5.54E+04
241-C-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-101	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-C-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-102	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-C-103	Supernatant	1.01E-01	5.30E-01	3.85E+01	5.13E+01	1.26E+02	1.20E+00
241-C-103	Solid	1.01E-01	5.30E-01	3.85E+01	5.13E+01	1.26E+02	1.20E+00
241-C-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-104	Solid	1.70E+04	5.60E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-C-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-105	Solid	1.70E+04	2.87E+03	3.70E+04	3.43E+04	1.14E+05	9.02E+00
241-C-106	Supernatant	7.02E+03	3.32E+02	5.43E+01	6.02E+01	9.78E+03	9.38E+01
241-C-106	Solid	7.02E+03	3.32E+02	5.43E+01	6.02E+01	9.78E+03	9.38E+01
241-C-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-107	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-C-108	Supernatant	6.83E+03	8.65E+02	2.72E+04	1.81E+03	5.10E+04	1.19E+03
241-C-108	Solid	6.83E+03	8.65E+02	2.72E+04	1.81E+03	5.10E+04	1.19E+03
241-C-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-109	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-C-110	Supernatant	1.70E+04	5.80E+02	4.60E+03	6.03E+04	3.05E+04	2.09E+02
241-C-110	Solid	1.70E+04	5.80E+02	4.60E+03	6.03E+04	3.05E+04	2.09E+02
241-C-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-111	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-C-112	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-112	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-C-201	Supernatant	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-201	Solid	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-202	Supernatant	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-202	Solid	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-203	Supernatant	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-203	Solid	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-204	Supernatant	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-204	Solid	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-101	Supernatant	4.76E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-101	Solid	4.76E+04	1.79E+03	1.13E+05	2.14E+05	2.22E+05	2.99E+04
241-S-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-102	Solid	3.76E+04	3.76E+03	1.27E+05	1.55E+05	2.34E+05	5.62E+04
241-S-103	Supernatant	3.65E+04	4.68E+03	1.47E+05	2.16E+05	2.28E+05	3.20E+04
241-S-103	Solid	3.65E+04	4.68E+03	1.47E+05	2.16E+05	2.28E+05	3.20E+04
241-S-104	Supernatant	5.10E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-104	Solid	5.10E+03	3.96E+02	3.82E+04	2.68E+05	1.98E+05	1.19E+04
241-S-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-105	Solid	8.18E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04
241-S-106	Supernatant	5.55E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-106	Solid	5.55E+04	1.98E+03	1.04E+05	2.36E+05	2.44E+05	3.80E+04

Table A-1. Tank Waste Chemical Concentrations.

Tank	Layer	OH ⁻ (µg/mL)	TOC (µg/mL)	NO ₂ ⁻ (µg/mL)	NO ₃ ⁻ (µg/mL)	Na ⁺ (µg/mL)	Al ³⁺ (µg/mL)
241-S-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-107	Solid	2.99E+04	1.18E+03	7.11E+04	1.14E+05	1.56E+05	1.07E+04
241-S-108	Supernatant	4.81E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-108	Solid	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.77E+04
241-S-109	Supernatant	8.19E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-109	Solid	8.19E+04	1.11E+03	8.49E+04	1.32E+05	2.19E+05	4.59E+04
241-S-110	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-110	Solid	8.18E+04	2.28E+03	8.58E+04	2.17E+05	2.11E+05	3.10E+04
241-S-111	Supernatant	5.10E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-111	Solid	5.10E+04	1.49E+03	8.39E+04	1.93E+05	2.23E+05	3.64E+04
241-S-112	Supernatant	1.24E+05	0.00E+00	0.00E+00	0.00E+00	1.98E+05	2.39E+04
241-S-112	Solid	1.24E+05	0.00E+00	0.00E+00	0.00E+00	1.98E+05	2.39E+04
241-SX-101	Supernatant	4.87E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-101	Solid	4.87E+04	3.35E+02	7.49E+04	1.08E+05	2.42E+05	8.00E+04
241-SX-102	Supernatant	5.01E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-102	Solid	5.01E+04	1.51E+03	1.51E+05	1.57E+05	2.35E+05	4.56E+04
241-SX-103	Supernatant	4.52E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-103	Solid	4.52E+04	3.38E+03	1.57E+05	1.56E+05	2.40E+05	4.44E+04
241-SX-104	Supernatant	3.05E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-104	Solid	3.05E+04	2.13E+03	1.17E+05	2.90E+05	2.50E+05	3.56E+04
241-SX-105	Supernatant	4.09E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-105	Solid	4.09E+04	3.26E+03	1.43E+05	1.64E+05	2.36E+05	4.41E+04
241-SX-106	Supernatant	3.19E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-106	Solid	3.19E+04	3.14E+03	1.49E+05	2.45E+05	2.17E+05	2.26E+04
241-SX-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-107	Solid	6.07E+04	1.01E+03	9.86E+04	2.17E+05	2.55E+05	4.72E+04
241-SX-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-108	Solid	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-SX-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-109	Solid	6.07E+04	9.20E+03	1.07E+05	1.76E+05	1.98E+05	2.75E+04
241-SX-110	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-110	Solid	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-SX-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-111	Solid	6.07E+04	1.01E+03	9.89E+04	2.17E+05	2.55E+05	4.71E+04
241-SX-112	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-112	Solid	6.07E+04	1.01E+03	9.88E+04	2.17E+05	2.55E+05	4.72E+04
241-SX-113	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-113	Solid	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-SX-114	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-114	Solid	6.07E+04	1.01E+03	9.88E+04	2.17E+05	2.51E+05	4.73E+04
241-SX-115	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-115	Solid	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-T-101	Supernatant	4.81E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-101	Solid	4.81E+04	4.04E+03	1.22E+05	1.89E+05	2.37E+05	3.77E+04
241-T-102	Supernatant	6.25E+01	4.50E+02	2.29E+04	1.09E+05	6.46E+04	8.46E+03
241-T-102	Solid	6.25E+01	4.50E+02	2.29E+04	1.09E+05	6.46E+04	8.46E+03
241-T-103	Supernatant	1.70E+04	5.55E+03	3.96E+04	7.80E+04	9.53E+04	1.04E+04
241-T-103	Solid	1.70E+04	5.55E+03	3.96E+04	7.80E+04	9.53E+04	1.04E+04
241-T-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-104	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03

Table A-1. Tank Waste Chemical Concentrations.

Tank	Layer	OH ⁻ (µg/mL)	TOC (µg/mL)	NO ₂ ⁻ (µg/mL)	NO ₃ ⁻ (µg/mL)	Na ⁺ (µg/mL)	Al ⁺³ (µg/mL)
241-T-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-105	Solid	1.70E+04	2.98E+03	5.42E+04	3.71E+04	8.84E+04	3.62E+02
241-T-106	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-106	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-T-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-107	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-T-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-108	Solid	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.61E+02
241-T-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-109	Solid	1.70E+04	3.37E+00	8.50E+03	2.17E+05	1.13E+05	3.61E+02
241-T-110	Supernatant	1.70E+04	4.50E+01	5.90E+01	1.83E+04	3.70E+04	0.00E+00
241-T-110	Solid	1.70E+04	4.50E+01	5.90E+01	1.83E+04	3.70E+04	0.00E+00
241-T-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-111	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-T-112	Supernatant	1.70E+04	1.61E+03	3.88E+04	2.33E+04	5.72E+04	5.04E+00
241-T-112	Solid	1.70E+04	1.61E+03	3.88E+04	2.33E+04	5.72E+04	5.04E+00
241-T-201	Supernatant	1.70E+04	7.78E+01	3.35E+02	4.61E+04	2.51E+04	0.00E+00
241-T-201	Solid	1.70E+04	7.78E+01	3.35E+02	4.61E+04	2.51E+04	0.00E+00
241-T-202	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-202	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-T-203	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-203	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-T-204	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-204	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-TX-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-101	Solid	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04
241-TX-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-102	Solid	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04
241-TX-103	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-103	Solid	1.70E+04	3.88E+03	1.18E+05	1.91E+05	2.32E+05	3.65E+04
241-TX-104	Supernatant	1.70E+04	1.36E+03	9.42E+04	3.54E+05	2.06E+05	3.19E+03
241-TX-104	Solid	1.70E+04	1.36E+03	9.43E+04	3.53E+05	2.05E+05	3.19E+03
241-TX-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-105	Solid	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04
241-TX-106	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-106	Solid	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04
241-TX-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-107	Solid	1.70E+04	3.22E+03	1.16E+05	1.97E+05	2.40E+05	4.03E+04
241-TX-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-108	Solid	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04
241-TX-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-109	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-TX-110	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-110	Solid	1.70E+04	4.02E+03	1.22E+05	1.90E+05	2.37E+05	3.78E+04
241-TX-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-111	Solid	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04
241-TX-112	Supernatant	4.81E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-112	Solid	4.81E+04	3.47E+03	1.06E+05	1.94E+05	2.18E+05	3.26E+04
241-TX-113	Supernatant	4.81E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-113	Solid	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04

Table A-1. Tank Waste Chemical Concentrations.

Tank	Layer	OH ⁻ (µg/mL)	TOC (µg/mL)	NO ₂ ⁻ (µg/mL)	NO ₃ ⁻ (µg/mL)	Na ⁺ (µg/mL)	Al ³⁺ (µg/mL)
241-TX-114	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-114	Solid	1.70E+04	1.53E+03	5.15E+04	2.07E+05	1.60E+05	1.45E+04
241-TX-115	Supernatant	4.81E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-115	Solid	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04
241-TX-116	Supernatant	2.54E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-116	Solid	2.54E+03	3.19E+02	1.05E+04	3.79E+05	1.51E+05	8.79E+00
241-TX-117	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-117	Solid	1.70E+04	3.38E+00	8.50E+03	2.17E+05	2.36E+05	3.79E+04
241-TX-118	Supernatant	4.81E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-118	Solid	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04
241-TY-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TY-101	Solid	1.70E+04	3.38E+00	8.47E+03	2.17E+05	1.13E+05	3.61E+02
241-TY-102	Supernatant	4.81E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TY-102	Solid	4.81E+04	2.18E+03	6.98E+04	2.02E+05	1.79E+05	2.06E+04
241-TY-103	Supernatant	4.81E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TY-103	Solid	4.81E+04	4.02E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04
241-TY-104	Supernatant	1.70E+04	2.12E+03	1.13E+04	9.90E+04	8.34E+04	5.70E+02
241-TY-104	Solid	1.70E+04	2.12E+03	1.13E+04	9.90E+04	8.34E+04	5.70E+02
241-TY-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TY-105	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-TY-106	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TY-106	Solid	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-U-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-101	Solid	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-U-102	Supernatant	2.93E+04	1.12E+04	1.46E+05	1.98E+05	2.23E+05	3.33E+04
241-U-102	Solid	2.93E+04	1.12E+04	1.46E+05	1.98E+05	2.23E+05	3.32E+04
241-U-103	Supernatant	3.08E+04	1.24E+04	1.37E+05	1.52E+05	2.31E+05	4.09E+04
241-U-103	Solid	3.08E+04	1.24E+04	1.37E+05	1.52E+05	2.30E+05	4.09E+04
241-U-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-104	Solid	4.91E+04	9.58E+03	1.05E+05	2.07E+05	2.03E+05	3.21E+04
241-U-105	Supernatant	2.09E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-105	Solid	2.09E+04	1.64E+04	1.08E+05	1.81E+05	2.27E+05	2.98E+04
241-U-106	Supernatant	5.11E+03	3.38E+04	9.90E+04	2.48E+05	2.23E+05	1.20E+04
241-U-106	Solid	5.11E+03	3.38E+04	9.87E+04	2.49E+05	2.23E+05	1.20E+04
241-U-107	Supernatant	3.13E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-107	Solid	3.13E+04	6.28E+03	1.28E+05	1.42E+05	2.05E+05	4.10E+04
241-U-108	Supernatant	4.92E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-108	Solid	4.92E+04	7.07E+03	1.34E+05	1.84E+05	2.28E+05	3.05E+04
241-U-109	Supernatant	4.42E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-109	Solid	4.42E+04	6.53E+03	1.28E+05	1.85E+05	2.28E+05	2.92E+04
241-U-110	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-110	Solid	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-U-111	Supernatant	3.39E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-111	Solid	3.39E+04	5.41E+03	1.20E+05	1.67E+05	2.39E+05	3.66E+04
241-U-112	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-112	Solid	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03
241-U-201	Supernatant	1.26E+04	0.00E+00	2.07E+04	1.43E+05	1.16E+05	1.41E+02
241-U-201	Solid	1.26E+04	0.00E+00	2.07E+04	1.43E+05	1.16E+05	1.41E+02
241-U-202	Supernatant	1.79E+04	1.41E+02	2.45E+04	1.52E+05	1.20E+05	2.39E+02
241-U-202	Solid	1.79E+04	1.41E+02	2.45E+04	1.52E+05	1.20E+05	2.39E+02

Table A-1. Tank Waste Chemical Concentrations.

Tank	Layer	OH ⁻ (μg/mL)	TOC (μg/mL)	NO ₂ ⁻ (μg/mL)	NO ₃ ⁻ (μg/mL)	Na ⁺ (μg/mL)	Al ⁺³ (μg/mL)
241-U-203	Supernatant	4.75E+03	0.00E+00	1.94E+04	1.44E+05	1.00E+05	1.88E+02
241-U-203	Solid	4.75E+03	0.00E+00	1.94E+04	1.44E+05	1.00E+05	1.88E+02
241-U-204	Supernatant	1.61E+03	8.10E+01	7.03E+03	5.53E+04	3.93E+04	1.46E+01
241-U-204	Solid	1.61E+03	8.10E+01	7.03E+03	5.53E+04	3.93E+04	1.46E+01

Table A-2. Tank Waste Radionuclide Concentrations.

Tank	Layer	⁹⁰ Sr (μCi/g)	²⁴¹ Am (μCi/g)	²⁴⁰ Pu (μCi/g)	²³⁹ Pu (μCi/g)	²³⁸ Pu (μCi/g)	¹³⁷ Cs (μCi/g)
241-AN-101	Supernatant	1.21E+00	1.62E-03	2.38E-05	1.42E-04	4.29E-06	1.77E+02
241-AN-101	Solid	2.23E+01	3.54E-02	2.31E-03	9.97E-03	3.97E-04	1.67E+02
241-AN-102	Supernatant	5.12E+01	1.15E-01	8.81E-04	3.40E-03	2.39E-04	2.55E+02
241-AN-102	Solid	1.24E+02	5.97E-01	1.05E-02	4.04E-02	2.84E-03	2.41E+02
241-AN-103	Supernatant	1.08E-02	4.09E-03	4.47E-05	1.72E-04	1.21E-05	3.90E+02
241-AN-103	Solid	2.02E+00	3.52E-03	3.58E-04	1.38E-03	9.69E-05	1.87E+02
241-AN-104	Supernatant	5.32E-02	2.51E-04	1.34E-05	5.16E-05	3.64E-06	3.20E+02
241-AN-104	Solid	2.61E+01	1.89E-02	7.43E-04	2.86E-03	2.01E-04	2.74E+02
241-AN-105	Supernatant	2.22E-02	1.01E-02	1.10E-04	4.24E-04	2.98E-05	1.88E+02
241-AN-105	Solid	8.64E+00	6.92E-03	4.67E-04	1.79E-03	1.26E-04	2.28E+02
241-AN-106	Supernatant	3.21E-02	1.28E-05	1.18E-04	5.61E-04	2.90E-05	1.90E+01
241-AN-106	Solid	1.30E+03	1.55E+00	1.80E-01	8.47E-01	2.63E-02	1.86E+02
241-AN-107	Supernatant	4.88E+01	5.09E-01	8.21E-03	3.16E-02	2.23E-03	1.90E+02
241-AN-107	Solid	1.51E+02	9.30E-01	1.43E-02	5.49E-02	3.86E-03	2.13E+02
241-AP-101	Supernatant	1.85E-01	1.11E-04	8.48E-06	4.64E-05	9.11E-06	4.84E+01
241-AP-101	Solid	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-AP-102	Supernatant	2.57E-01	1.26E-03	3.83E-05	2.26E-04	5.71E-06	1.60E+02
241-AP-102	Solid	3.34E-01	7.65E-04	8.86E-05	5.26E-04	1.31E-05	7.65E+01
241-AP-103	Supernatant	1.42E+00	4.96E-03	1.72E-04	1.02E-03	1.36E-04	1.58E+02
241-AP-103	Solid	2.22E-01	2.63E-04	1.61E-04	9.56E-04	3.07E-05	1.02E+02
241-AP-104	Supernatant	7.49E-01	1.90E-03	5.59E-05	3.31E-04	6.30E-05	1.70E+02
241-AP-104	Solid	1.76E+01	1.95E-02	3.28E-03	1.26E-02	8.86E-04	2.23E+02
241-AP-105	Supernatant	3.29E-01	1.63E-04	7.45E-06	4.55E-05	8.73E-06	4.99E+01
241-AP-105	Solid	1.62E+01	5.27E-03	8.89E-04	3.42E-03	2.40E-04	2.05E+02
241-AP-106	Supernatant	8.94E-01	4.98E-04	1.05E-05	6.11E-05	1.66E-06	1.32E+02
241-AP-106	Solid	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-AP-107	Supernatant	4.06E-01	2.28E-04	1.64E-05	8.06E-05	3.55E-06	6.27E+01
241-AP-107	Solid	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-AP-108	Supernatant	6.57E-01	1.34E-03	5.41E-05	2.85E-04	1.72E-05	1.34E+02
241-AP-108	Solid	4.24E-01	2.21E-04	4.33E-05	2.14E-04	1.55E-05	1.19E+02
241-AW-101	Supernatant	2.31E-01	1.84E-04	7.27E-05	2.80E-04	1.96E-05	2.34E+02
241-AW-101	Solid	3.34E+01	4.75E-02	1.16E-02	4.45E-02	3.13E-03	1.94E+02
241-AW-102	Supernatant	2.31E-01	1.79E-04	1.17E-05	6.65E-05	1.29E-05	5.04E+01
241-AW-102	Solid	4.93E+02	1.82E+00	9.24E-02	4.45E-01	7.44E-03	6.49E+01
241-AW-103	Supernatant	1.64E-01	4.29E-05	2.07E-05	9.74E-05	8.53E-06	8.37E+01
241-AW-103	Solid	6.22E+00	9.76E-02	6.14E-02	2.17E-01	2.08E-02	2.52E+01
241-AW-104	Supernatant	1.10E+00	1.16E-03	1.89E-05	1.06E-04	3.26E-06	1.62E+02
241-AW-104	Solid	4.99E-01	6.91E-02	1.38E-01	4.92E-01	4.77E-02	1.46E+02
241-AW-105	Supernatant	1.94E-02	7.06E-05	6.23E-05	2.21E-04	2.12E-05	8.79E+00
241-AW-105	Solid	3.42E+01	7.27E-01	2.76E-01	9.84E-01	9.46E-02	4.10E+01

Table A-2. Tank Waste Radionuclide Concentrations.

Tank	Layer	⁹⁰ Sr (μCi/g)	²⁴¹ Am (μCi/g)	²⁴⁰ Pu (μCi/g)	²³⁹ Pu (μCi/g)	²³⁸ Pu (μCi/g)	¹³⁷ Cs (μCi/g)
241-AW-106	Supernatant	3.74E-01	5.49E-04	1.35E-04	8.69E-04	1.41E-05	9.38E+01
241-AW-106	Solid	2.18E+01	2.75E-02	2.50E-02	9.58E-02	6.76E-03	2.75E+02
241-AY-101	Supernatant	6.65E-01	3.34E-03	6.89E-04	3.08E-03	1.16E-04	1.74E+01
241-AY-101	Solid	3.00E+03	2.12E+01	3.32E-01	1.08E+00	8.96E-02	1.01E+02
241-AY-102	Supernatant	1.28E-01	1.57E-04	4.10E-05	1.74E-04	2.05E-05	9.41E+01
241-AY-102	Solid	4.63E+03	5.44E+00	4.05E-01	1.76E+00	6.52E-02	2.50E+02
241-AZ-101	Supernatant	6.91E-01	1.79E-04	3.52E-04	1.23E-03	1.24E-04	1.25E+03
241-AZ-101	Solid	1.58E+04	8.03E+01	1.04E+00	3.69E+00	3.51E-01	6.99E+02
241-AZ-102	Supernatant	1.64E+00	8.40E-04	1.83E-03	6.71E-03	6.30E-04	7.90E+02
241-AZ-102	Solid	6.37E+03	5.05E+01	6.16E-01	2.34E+00	3.38E-01	6.04E+02
241-SY-101	Supernatant	1.89E-02	3.68E-05	5.87E-06	2.71E-05	2.05E-06	2.07E+01
241-SY-101	Solid	5.13E+01	4.90E-01	9.26E-03	4.31E-02	8.99E-03	1.33E+02
241-SY-102	Supernatant	2.70E-01	1.58E-03	1.77E-04	8.19E-04	3.01E-05	1.82E+01
241-SY-102	Solid	1.65E+02	1.72E+01	9.43E-01	4.09E+00	1.88E-01	9.55E+01
241-SY-103	Supernatant	1.84E+00	6.79E-03	7.85E-06	3.66E-05	1.24E-06	2.63E+02
241-SY-103	Solid	2.88E+01	6.09E-01	1.21E-02	5.66E-02	1.91E-03	1.93E+02
241-A-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-A-101	Solid	6.22E+01	2.13E-01	1.09E-02	4.52E-02	1.96E-03	1.56E+02
241-A-102	Supernatant	6.42E-01	7.06E-04	5.41E-04	2.34E-03	9.29E-05	2.88E+02
241-A-102	Solid	3.04E+02	1.08E+00	3.12E-01	1.35E+00	5.35E-02	1.36E+02
241-A-103	Supernatant	1.16E+00	2.20E-03	3.35E-03	1.44E-02	5.73E-04	1.63E+02
241-A-103	Solid	5.80E+01	1.22E-01	2.61E-02	1.14E-01	4.37E-03	1.30E+02
241-A-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-A-104	Solid	2.07E+04	8.02E+00	1.48E+00	6.76E+00	2.17E-01	5.61E+02
241-A-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-A-105	Solid	1.22E+04	2.62E+01	6.35E-01	2.60E+00	1.18E-01	4.58E+02
241-A-106	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-A-106	Solid	8.77E+02	1.15E+00	4.64E-01	2.03E+00	7.67E-02	1.15E+02
241-AX-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-AX-101	Solid	8.73E+01	1.70E-01	1.17E-02	5.02E-02	2.01E-03	1.61E+02
241-AX-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-AX-102	Solid	1.17E+03	1.20E+01	2.73E-01	8.55E-01	7.64E-02	1.26E+02
241-AX-103	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-AX-103	Solid	6.35E+02	1.14E+00	3.66E-02	1.45E-01	6.58E-03	1.65E+02
241-AX-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-AX-104	Solid	3.71E+04	1.88E+01	1.31E+00	5.34E+00	2.44E-01	8.99E+02
241-B-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-101	Solid	2.96E+02	2.28E+00	1.55E-01	5.02E-01	4.27E-02	3.16E+00
241-B-102	Supernatant	1.53E+00	1.23E-03	4.69E-04	4.14E-03	2.98E-05	6.46E+00
241-B-102	Solid	5.37E-01	4.48E-04	3.31E-03	2.93E-02	2.11E-04	2.40E+00
241-B-103	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-103	Solid	1.27E+00	1.39E-03	1.70E-02	1.50E-01	1.08E-03	2.42E+00
241-B-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-104	Solid	1.80E+00	2.47E-03	4.71E-03	4.40E-02	2.93E-04	6.01E+00
241-B-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-105	Solid	5.05E-01	7.91E-04	3.86E-03	3.43E-02	2.45E-04	2.13E+00
241-B-106	Supernatant	1.53E+00	1.23E-03	4.68E-04	4.15E-03	2.98E-05	6.45E+00
241-B-106	Solid	4.46E+01	9.92E-03	3.14E-03	2.92E-02	1.98E-04	1.41E+01
241-B-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-107	Solid	2.92E+00	4.62E-03	4.74E-03	4.03E-02	3.17E-04	1.00E+01

Table A-2. Tank Waste Radionuclide Concentrations.

Tank	Layer	⁹⁰ Sr (μCi/g)	²⁴¹ Am (μCi/g)	²⁴⁰ Pu (μCi/g)	²³⁹ Pu (μCi/g)	²³⁸ Pu (μCi/g)	¹³⁷ Cs (μCi/g)
241-B-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-108	Solid	1.41E+00	1.90E-04	4.83E-04	3.29E-03	3.79E-05	1.15E+01
241-B-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-109	Solid	3.95E-01	7.82E-04	3.33E-03	2.47E-02	2.46E-04	1.36E+00
241-B-110	Supernatant	1.76E+00	5.67E-03	9.83E-04	4.24E-03	1.72E-04	1.07E+01
241-B-110	Solid	7.06E+01	7.20E-02	1.08E-02	1.01E-01	3.04E-03	9.90E+00
241-B-111	Supernatant	1.76E+00	5.67E-03	9.83E-04	4.24E-03	1.72E-04	1.07E+01
241-B-111	Solid	1.74E+02	8.50E-02	1.09E-02	8.63E-02	2.87E-03	1.13E+02
241-B-112	Supernatant	1.38E+00	4.48E-03	8.01E-04	3.34E-03	1.25E-04	9.27E+01
241-B-112	Solid	3.84E+00	1.16E-03	3.55E-04	2.52E-03	3.74E-05	3.14E+01
241-B-201	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-201	Solid	1.55E+00	2.82E-02	4.33E-02	7.51E-01	6.09E-03	1.24E-01
241-B-202	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-B-202	Solid	2.72E+00	6.67E-02	2.16E-02	1.28E-01	1.97E-03	6.96E-02
241-B-203	Supernatant	7.05E-05	4.58E-05	4.86E-04	3.83E-03	3.21E-05	8.19E-05
241-B-203	Solid	6.30E-02	3.46E-02	2.95E-02	2.33E-01	1.96E-03	6.03E-03
241-B-204	Supernatant	3.14E-05	1.78E-07	4.70E-06	6.98E-05	2.29E-07	3.62E-05
241-B-204	Solid	2.37E-03	3.85E-02	2.51E-02	1.99E-01	1.67E-03	2.39E-02
241-BX-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-101	Solid	2.32E+02	1.42E-01	1.32E-01	6.39E-01	2.04E-02	8.28E+01
241-BX-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-102	Solid	2.85E+02	3.57E-03	3.51E-03	1.67E-02	3.25E-04	3.09E+01
241-BX-103	Supernatant	4.43E-01	5.44E-03	1.16E-03	4.92E-03	1.12E-04	5.23E-01
241-BX-103	Solid	4.23E+02	3.44E-01	4.94E-01	2.18E+00	4.72E-02	4.59E+01
241-BX-104	Supernatant	1.20E+00	2.10E-04	3.19E-05	1.68E-04	2.53E-06	8.81E+01
241-BX-104	Solid	1.76E+02	5.35E-01	4.50E-02	3.49E-01	3.35E-03	5.53E+01
241-BX-105	Supernatant	5.30E+00	1.91E-02	2.53E-03	1.08E-02	2.46E-04	8.44E+01
241-BX-105	Solid	1.66E+02	5.93E-02	1.92E-02	9.64E-02	1.99E-03	6.69E+01
241-BX-106	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-106	Solid	2.84E+02	2.50E-01	4.01E-02	1.96E-01	5.01E-03	7.28E+01
241-BX-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-107	Solid	6.82E+00	1.30E-02	5.61E-03	5.16E-02	3.51E-04	1.22E+01
241-BX-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-108	Solid	1.17E+02	1.86E-02	5.13E-03	4.76E-02	3.23E-04	2.06E+01
241-BX-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-109	Solid	9.73E+01	5.34E-03	1.05E-03	9.73E-03	6.57E-05	9.82E+00
241-BX-110	Supernatant	1.21E+00	3.92E-03	7.00E-04	2.92E-03	1.09E-04	8.07E+01
241-BX-110	Solid	7.14E+00	4.73E-03	1.81E-03	1.52E-02	1.40E-04	4.47E+01
241-BX-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BX-111	Solid	1.05E+01	3.43E-03	1.64E-03	1.45E-02	1.14E-04	5.90E+01
241-BX-112	Supernatant	5.64E-01	1.38E-04	1.92E-04	1.35E-03	1.30E-05	6.66E-01
241-BX-112	Solid	5.28E+00	2.41E-02	1.58E-02	1.45E-01	9.91E-04	3.70E+01
241-BY-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-101	Solid	5.22E+01	9.93E-03	1.24E-03	1.08E-02	9.13E-05	8.28E+01
241-BY-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-102	Solid	9.54E+00	5.04E-02	5.15E-03	2.16E-02	8.02E-04	6.06E+01
241-BY-103	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-103	Solid	1.03E+01	1.16E-02	1.34E-03	5.61E-03	1.99E-04	6.08E+01
241-BY-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-104	Solid	1.25E+02	5.52E-02	5.83E-03	2.94E-02	8.21E-04	7.91E+01

Table A-2. Tank Waste Radionuclide Concentrations.

Tank	Layer	⁹⁰ Sr (μCi/g)	²⁴¹ Am (μCi/g)	²⁴⁰ Pu (μCi/g)	²³⁹ Pu (μCi/g)	²³⁸ Pu (μCi/g)	¹³⁷ Cs (μCi/g)
241-BY-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-105	Solid	3.89E+01	3.60E-02	3.91E-03	2.38E-02	4.73E-04	4.24E+01
241-BY-106	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-106	Solid	4.62E+01	1.44E-02	1.20E-03	8.72E-03	1.19E-04	1.03E+02
241-BY-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-107	Solid	3.90E+01	1.18E-02	1.33E-03	8.10E-03	1.61E-04	1.04E+02
241-BY-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-108	Solid	9.38E+01	3.04E-02	3.43E-03	2.26E-02	3.83E-04	3.84E+01
241-BY-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-109	Solid	7.04E+00	3.69E-02	4.35E-03	1.82E-02	6.42E-04	4.54E+01
241-BY-110	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-110	Solid	6.61E+01	2.75E-02	3.81E-03	2.22E-02	4.81E-04	7.98E+01
241-BY-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-111	Solid	9.32E+00	6.14E-02	6.28E-03	2.63E-02	9.79E-04	5.43E+01
241-BY-112	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-BY-112	Solid	1.07E+01	4.29E-02	4.40E-03	1.84E-02	6.87E-04	5.80E+01
241-C-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-101	Solid	5.82E+01	1.45E-01	1.39E-01	7.86E-01	1.07E-02	4.63E+01
241-C-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-102	Solid	1.26E+01	5.17E-01	4.02E-01	1.68E+00	4.21E-02	1.16E+01
241-C-103	Supernatant	6.63E-02	5.09E-06	1.60E-06	1.03E-05	2.81E-06	9.80E-02
241-C-103	Solid	6.51E+02	3.54E-01	7.48E-02	3.59E-01	1.03E-01	5.75E+01
241-C-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-104	Solid	2.44E+02	2.69E+00	4.87E-01	1.89E+00	2.62E-01	4.85E+01
241-C-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-105	Solid	5.18E+02	1.54E+00	5.03E-01	2.56E+00	3.99E-02	8.99E+01
241-C-106	Supernatant	3.93E-02	4.14E-06	8.49E-07	3.99E-06	6.21E-07	3.90E-01
241-C-106	Solid	3.79E+03	4.10E+00	2.25E-01	1.05E+00	1.65E-01	8.32E+01
241-C-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-107	Solid	1.31E+03	4.59E+00	2.44E-01	1.51E+00	2.96E-02	3.71E+01
241-C-108	Supernatant	7.90E-01	1.79E-04	2.82E-04	1.34E-03	1.90E-04	1.61E+01
241-C-108	Solid	1.98E+01	2.93E-02	9.28E-04	8.53E-03	5.81E-05	1.93E+02
241-C-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-109	Solid	4.38E+00	1.38E-02	9.05E-03	8.34E-02	5.67E-04	1.45E+01
241-C-110	Supernatant	1.75E-02	1.76E-05	1.01E-04	1.50E-03	4.91E-06	3.11E+00
241-C-110	Solid	3.49E+00	4.28E-02	7.85E-03	7.21E-02	4.91E-04	1.37E+01
241-C-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-111	Solid	2.38E+03	5.50E-01	9.56E-02	4.92E-01	8.75E-03	5.19E+01
241-C-112	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-112	Solid	7.35E+02	6.34E-01	1.59E-02	1.24E-01	1.03E-02	3.28E+02
241-C-201	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-201	Solid	2.43E+02	2.67E+00	3.62E+00	1.68E+01	5.17E-01	9.83E+00
241-C-202	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-202	Solid	4.61E+02	1.28E+00	3.21E+00	1.49E+01	4.58E-01	8.50E+00
241-C-203	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-203	Solid	2.26E+02	3.51E-02	1.14E-01	5.29E-01	1.63E-02	1.31E+01
241-C-204	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-C-204	Solid	1.54E+02	3.59E-03	2.36E-03	1.10E-02	3.38E-04	6.06E+00
241-S-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-101	Solid	1.87E+02	1.00E-01	2.87E-02	1.46E-01	2.95E-03	1.02E+02

Table A-2. Tank Waste Radionuclide Concentrations.

Tank	Layer	⁹⁰ Sr (μCi/g)	²⁴¹ Am (μCi/g)	²⁴⁰ Pu (μCi/g)	²³⁹ Pu (μCi/g)	²³⁸ Pu (μCi/g)	¹³⁷ Cs (μCi/g)
241-S-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-102	Solid	2.28E+02	6.27E-02	1.20E-02	5.90E-02	1.43E-03	7.16E+01
241-S-103	Supernatant	2.31E-01	8.09E-04	8.45E-06	3.93E-05	1.33E-06	2.03E+02
241-S-103	Solid	2.61E+01	9.36E-02	1.36E-02	6.52E-02	1.88E-03	1.23E+02
241-S-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-104	Solid	1.94E+02	1.07E-01	3.83E-02	1.88E-01	5.21E-03	3.90E+01
241-S-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-105	Solid	2.32E+00	3.05E-03	7.25E-04	3.63E-03	7.94E-05	3.12E+01
241-S-106	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-106	Solid	1.11E+01	1.96E-02	1.32E-03	6.04E-03	2.06E-04	8.32E+01
241-S-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-107	Solid	1.18E+02	3.11E-01	1.06E-01	5.04E-01	1.18E-02	6.18E+01
241-S-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-108	Solid	1.90E+01	7.69E-02	5.96E-03	2.79E-02	8.76E-04	8.73E+01
241-S-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-109	Solid	1.35E+01	1.14E-02	2.83E-03	1.44E-02	2.83E-04	1.19E+01
241-S-110	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-110	Solid	8.53E+01	1.23E-01	2.49E-02	1.26E-01	2.55E-03	6.63E+01
241-S-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-111	Solid	1.66E+02	1.48E-02	1.43E-03	6.89E-03	1.90E-04	9.37E+01
241-S-112	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-S-112	Solid	3.01E+00	7.80E-04	2.68E-04	1.38E-03	2.48E-05	1.80E-01
241-SX-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-101	Solid	1.03E+02	1.91E-01	3.39E-02	1.66E-01	4.45E-03	9.16E+01
241-SX-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-102	Solid	7.43E+01	1.22E-01	1.21E-02	5.77E-02	1.64E-03	1.28E+02
241-SX-103	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-103	Solid	1.40E+02	2.15E-01	1.56E-02	7.61E-02	1.98E-03	1.13E+02
241-SX-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-104	Solid	1.29E+02	1.25E-01	3.42E-02	1.74E-01	3.41E-03	7.92E+01
241-SX-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-105	Solid	2.29E+02	2.56E-01	5.74E-02	2.89E-01	6.42E-03	8.64E+01
241-SX-106	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-106	Solid	1.10E+01	1.47E-01	1.86E-02	8.68E-02	2.93E-03	1.20E+02
241-SX-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-107	Solid	1.81E+03	8.84E-01	1.08E-01	5.19E-01	1.81E-02	7.47E+01
241-SX-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-108	Solid	2.34E+03	1.46E+00	2.96E-01	1.49E+00	3.66E-02	1.50E+02
241-SX-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-109	Solid	5.17E+02	2.91E-01	3.75E-02	1.79E-01	6.27E-03	7.21E+01
241-SX-110	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-110	Solid	4.15E+03	1.90E+00	1.18E-01	5.04E-01	3.23E-02	1.05E+02
241-SX-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-111	Solid	2.40E+03	1.13E+00	1.01E-01	4.64E-01	2.11E-02	8.43E+01
241-SX-112	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-112	Solid	2.53E+03	1.20E+00	1.15E-01	5.31E-01	2.27E-02	8.34E+01
241-SX-113	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-113	Solid	2.50E+01	1.08E-01	9.47E-03	4.88E-02	8.77E-04	1.84E+01
241-SX-114	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-114	Solid	1.67E+03	8.12E-01	9.20E-02	4.37E-01	1.63E-02	7.99E+01

Table A-2. Tank Waste Radionuclide Concentrations.

Tank	Layer	⁹⁰ Sr (μCi/g)	²⁴¹ Am (μCi/g)	²⁴⁰ Pu (μCi/g)	²³⁹ Pu (μCi/g)	²³⁸ Pu (μCi/g)	¹³⁷ Cs (μCi/g)
241-SX-115	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-SX-115	Solid	1.23E+04	1.42E+01	3.78E+00	1.61E+01	1.04E+00	1.87E+01
241-T-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-101	Solid	6.01E-01	1.17E-01	7.82E-02	3.58E-01	9.08E-03	6.17E+01
241-T-102	Supernatant	7.77E-01	3.76E-03	1.04E-03	4.48E-03	1.81E-04	4.13E+01
241-T-102	Solid	1.16E+02	1.63E-01	6.88E-03	2.95E-02	6.65E-04	1.50E+01
241-T-103	Supernatant	1.76E+00	8.57E-03	1.48E-03	6.39E-03	2.59E-04	1.07E+01
241-T-103	Solid	4.02E+00	3.45E-03	5.71E-03	2.44E-02	5.51E-04	1.17E+00
241-T-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-104	Solid	1.84E+00	1.83E-02	1.51E-02	1.25E-01	1.58E-03	1.42E-01
241-T-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-105	Solid	4.72E+01	5.84E-02	2.93E-02	2.77E-01	2.01E-03	8.42E+00
241-T-106	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-106	Solid	4.57E+00	4.27E-02	2.00E-02	1.34E-01	1.56E-03	1.40E+01
241-T-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-107	Solid	9.14E+01	5.89E-02	3.48E-02	3.04E-01	2.29E-03	1.34E+01
241-T-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-108	Solid	1.61E+00	4.69E-03	6.74E-03	6.05E-02	4.25E-04	6.17E+00
241-T-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-109	Solid	2.38E-01	2.19E-04	1.04E-03	9.12E-03	6.58E-05	1.94E+00
241-T-110	Supernatant	3.90E-04	2.89E-06	9.97E-06	1.48E-04	1.83E-06	2.55E-03
241-T-110	Solid	2.48E-02	4.97E-03	5.88E-03	5.61E-02	3.63E-04	1.36E-02
241-T-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-111	Solid	3.71E+00	4.68E-02	1.44E-02	1.24E-01	6.03E-04	9.28E-02
241-T-112	Supernatant	5.52E-01	1.03E-02	1.78E-03	7.69E-03	3.12E-04	3.37E+00
241-T-112	Solid	1.81E-03	1.53E-02	2.41E-02	2.14E-01	1.53E-03	3.52E-03
241-T-201	Supernatant	3.21E-05	6.34E-08	1.67E-06	2.49E-05	8.15E-08	3.71E-05
241-T-201	Solid	6.11E-02	3.96E-02	4.52E-02	6.71E-01	2.20E-03	2.02E-02
241-T-202	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-202	Solid	2.04E-03	3.22E-02	2.11E-02	1.67E-01	1.40E-03	6.17E-03
241-T-203	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-203	Solid	2.01E-03	3.75E-02	2.81E-02	2.24E-01	1.87E-03	6.09E-03
241-T-204	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-T-204	Solid	3.66E-03	2.28E-02	2.39E-02	1.89E-01	1.59E-03	6.23E-03
241-TX-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-101	Solid	2.93E+02	4.25E-01	1.25E-01	5.90E-01	1.89E-02	6.12E+01
241-TX-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-102	Solid	1.43E+00	1.45E-01	1.52E-02	7.23E-02	2.46E-03	7.97E+01
241-TX-103	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-103	Solid	6.62E-01	1.43E-01	1.50E-02	7.18E-02	2.43E-03	7.96E+01
241-TX-104	Supernatant	5.89E-01	8.80E-03	8.10E-05	3.86E-04	1.32E-05	2.11E+02
241-TX-104	Solid	1.49E+02	1.59E-01	2.17E-02	1.06E-01	3.05E-03	5.91E+01
241-TX-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-105	Solid	1.77E+00	1.59E-01	1.67E-02	7.95E-02	2.71E-03	6.47E+01
241-TX-106	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-106	Solid	5.52E+00	1.53E-01	1.68E-02	8.06E-02	2.64E-03	7.53E+01
241-TX-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-107	Solid	4.97E+00	1.69E+00	1.77E-01	8.41E-01	2.88E-02	9.28E+01
241-TX-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-108	Solid	4.79E+00	1.49E-01	1.55E-02	7.45E-02	2.53E-03	6.84E+01

Table A-2. Tank Waste Radionuclide Concentrations.

Tank	Layer	⁹⁰ Sr (μCi/g)	²⁴¹ Am (μCi/g)	²⁴⁰ Pu (μCi/g)	²³⁹ Pu (μCi/g)	²³⁸ Pu (μCi/g)	¹³⁷ Cs (μCi/g)
241-TX-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-109	Solid	4.38E+00	1.38E-02	9.05E-03	8.34E-02	5.70E-04	1.44E+01
241-TX-110	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-110	Solid	9.33E-01	1.54E-01	1.66E-02	8.20E-02	2.64E-03	5.97E+01
241-TX-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-111	Solid	1.06E+00	1.51E-01	1.65E-02	8.28E-02	2.59E-03	5.67E+01
241-TX-112	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-112	Solid	6.60E-01	1.57E-01	1.65E-02	7.94E-02	2.66E-03	6.22E+01
241-TX-113	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-113	Solid	1.27E+00	6.72E-03	1.68E-03	1.32E-02	1.57E-04	7.48E+00
241-TX-114	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-114	Solid	6.61E-01	1.48E-01	1.59E-02	7.75E-02	2.54E-03	5.42E+01
241-TX-115	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-115	Solid	1.96E+00	1.60E-01	1.67E-02	7.97E-02	2.72E-03	6.51E+01
241-TX-116	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-116	Solid	3.10E-01	6.88E-02	9.33E-03	5.34E-02	1.30E-03	3.20E+01
241-TX-117	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-117	Solid	4.63E-01	1.00E-01	1.20E-02	6.32E-02	1.79E-03	5.66E+01
241-TX-118	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TX-118	Solid	1.10E+02	3.61E+00	4.93E-01	2.34E+00	8.03E-02	4.92E+01
241-TY-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TY-101	Solid	8.66E+00	1.27E-02	1.44E-02	1.72E-01	8.20E-04	3.68E-01
241-TY-102	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TY-102	Solid	2.38E+00	2.49E-03	2.02E-04	1.33E-03	2.39E-05	2.61E+01
241-TY-103	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TY-103	Solid	6.37E+01	2.45E-02	1.93E-02	1.60E-01	2.03E-03	2.54E+01
241-TY-104	Supernatant	4.66E-02	3.78E-04	2.64E-04	1.11E-03	6.07E-05	8.86E+00
241-TY-104	Solid	7.87E+01	7.93E-02	1.36E-02	1.72E-01	7.57E-04	3.21E+01
241-TY-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TY-105	Solid	1.34E+02	7.55E-03	2.27E-03	2.12E-02	1.43E-04	5.69E+00
241-TY-106	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-TY-107	Solid	1.10E+02	1.66E-02	2.04E-03	1.90E-02	1.28E-04	5.15E+01
241-U-101	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-101	Solid	3.38E+02	2.05E-02	7.86E-03	4.06E-02	7.27E-04	5.22E+01
241-U-102	Supernatant	4.14E+00	7.80E-03	6.59E-05	3.14E-04	1.08E-05	2.77E+02
241-U-102	Solid	7.67E+01	1.18E-01	2.30E-02	1.14E-01	2.79E-03	1.28E+02
241-U-103	Supernatant	5.90E+00	1.28E-02	5.97E-05	2.74E-04	9.34E-06	2.82E+02
241-U-103	Solid	2.08E+01	8.50E-02	9.06E-03	4.31E-02	1.27E-03	1.00E+02
241-U-104	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-104	Solid	2.29E+00	1.27E-03	6.00E-04	4.74E-03	3.97E-05	2.01E-01
241-U-105	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-105	Solid	1.03E+01	3.62E-01	5.41E-02	2.59E-01	7.70E-03	1.24E+02
241-U-106	Supernatant	3.73E+01	2.14E-01	9.19E-04	4.22E-03	1.44E-04	1.92E+02
241-U-106	Solid	5.40E+01	6.83E-01	4.35E-02	2.00E-01	6.80E-03	1.32E+02
241-U-107	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-107	Solid	1.90E+00	2.15E-01	3.04E-02	1.42E-01	4.80E-03	6.90E+01
241-U-108	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-108	Solid	6.87E+00	3.45E-02	1.43E-02	6.53E-02	1.71E-03	1.12E+02
241-U-109	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-109	Solid	6.31E+00	2.35E-02	2.37E-03	1.11E-02	3.56E-04	1.03E+02

Table A-2. Tank Waste Radionuclide Concentrations.

Tank	Layer	⁹⁰ Sr (μCi/g)	²⁴¹ Am (μCi/g)	²⁴⁰ Pu (μCi/g)	²³⁹ Pu (μCi/g)	²³⁸ Pu (μCi/g)	¹³⁷ Cs (μCi/g)
241-U-110	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-110	Solid	1.47E+02	7.36E-02	3.16E-02	1.84E-01	2.74E-03	1.65E+01
241-U-111	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-111	Solid	3.41E+01	1.12E-01	1.85E-02	9.12E-02	2.48E-03	1.14E+02
241-U-112	Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
241-U-112	Solid	1.50E+02	3.36E-03	2.11E-03	1.91E-02	1.34E-04	2.74E+01
241-U-201	Supernatant	9.19E-03	4.31E-04	3.45E-05	1.82E-04	2.74E-06	1.97E+01
241-U-201	Solid	1.31E-01	1.53E-03	3.52E-04	1.86E-03	2.80E-05	4.31E+00
241-U-202	Supernatant	4.38E-04	7.19E-06	8.73E-07	4.59E-06	6.91E-08	1.39E+01
241-U-202	Solid	5.60E-02	1.89E-03	4.93E-04	2.59E-03	3.91E-05	3.77E+00
241-U-203	Supernatant	3.85E-04	6.95E-06	3.71E-06	1.95E-05	2.93E-07	1.31E+01
241-U-203	Solid	1.15E-01	1.54E-03	2.88E-04	1.52E-03	2.29E-05	3.55E+00
241-U-204	Supernatant	1.61E-04	8.47E-06	6.69E-07	3.54E-06	5.32E-08	5.59E+00
241-U-204	Solid	3.46E+00	2.22E-02	1.21E-02	6.34E-02	9.56E-04	4.54E+00

Table A-3. Tank Waste Physical Properties.

Tank	Layer	Bulk SpG	Liquid SpG	Non-RG Waste Volume (kL)	Water in Bulk (wt%)	Water in Liquid (wt%)	T _{Waste} (°C)	T _{Headspace} (°C)
241-AN-101	Supernatant	1.40	1.40	4208	52.1%	52.1%	25	20
241-AN-101	Solid	1.55	1.45	118	40.3%	49.1%	20	20
241-AN-102	Supernatant	1.41	1.41	3446	48.9%	48.9%	30	29
241-AN-102	Solid	1.53	1.41	584	39.9%	48.9%	29	29
241-AN-103	Supernatant	1.48	1.48	1769	46.7%	46.7%	33	26
241-AN-103	Solid	1.52	1.48	1858	34.9%	46.7%	35	26
241-AN-104	Supernatant	1.40	1.40	2298	51.1%	51.1%	32	26
241-AN-104	Solid	1.48	1.40	1685	45.7%	51.1%	36	26
241-AN-105	Supernatant	1.42	1.42	2227	49.9%	49.9%	31	26
241-AN-105	Solid	1.49	1.42	2034	44.4%	49.9%	32	26
241-AN-106	Supernatant	1.15	1.15	1815	80.1%	80.1%	27	26
241-AN-106	Solid	1.48	1.15	1054	39.1%	80.1%	33	26
241-AN-107	Supernatant	1.43	1.43	3297	51.5%	51.5%	30	28
241-AN-107	Solid	1.48	1.43	872	44.3%	51.5%	32	28
241-AP-101	Supernatant	1.24	1.24	4363	72.7%	72.7%	19	21
241-AP-101	Solid	0.00	1.24	0	0.0%	0.0%	0	21
241-AP-102	Supernatant	1.37	1.37	4004	55.0%	55.0%	22	22
241-AP-102	Solid	1.73	1.37	105	36.7%	55.0%	22	22
241-AP-103	Supernatant	1.39	1.39	4233	53.8%	53.8%	29	31
241-AP-103	Solid	1.68	1.39	66	40.9%	53.8%	26	31
241-AP-104	Supernatant	1.41	1.41	1789	54.1%	54.1%	37	33
241-AP-104	Solid	1.61	1.41	68	44.0%	54.1%	32	33
241-AP-105	Supernatant	1.27	1.27	562	65.0%	65.0%	21	19
241-AP-105	Solid	1.61	1.27	396	47.7%	65.0%	20	19
241-AP-106	Supernatant	1.21	1.21	4301	72.4%	72.4%	19	19
241-AP-106	Solid	0.00	1.21	0	0.0%	72.4%	0	19
241-AP-107	Supernatant	1.28	1.28	4274	67.6%	67.6%	18	17
241-AP-107	Solid	0.00	1.28	0	0.0%	0.0%	0	17
241-AP-108	Supernatant	1.41	1.41	4337	50.8%	50.8%	20	22
241-AP-108	Solid	1.55	1.41	383	45.0%	50.8%	19	22

Table A-3. Tank Waste Physical Properties.

Tank	Layer	Bulk SpG	Liquid SpG	Non-RG Waste Volume (kL)	Water in Bulk (wt%)	Water in Liquid (wt%)	T _{Waste} (°C)	T _{Headspace} (°C)
241-AW-101	Supernatant	1.47	1.47	2770	43.8%	43.8%	33	26
241-AW-101	Solid	1.49	1.47	1498	43.9%	43.8%	35	26
241-AW-102	Supernatant	1.24	1.24	3602	79.5%	79.5%	20	20
241-AW-102	Solid	1.60	1.24	184	33.4%	79.5%	21	20
241-AW-103	Supernatant	1.24	1.24	2930	69.1%	69.1%	20	20
241-AW-103	Solid	1.49	1.42	1211	54.5%	50.5%	20	20
241-AW-104	Supernatant	1.36	1.36	3070	66.6%	66.6%	25	24
241-AW-104	Solid	1.46	1.40	963	51.2%	57.0%	26	24
241-AW-105	Supernatant	1.06	1.06	631	90.3%	90.3%	18	20
241-AW-105	Solid	1.33	1.06	940	63.3%	90.3%	18	20
241-AW-106	Supernatant	1.22	1.22	3225	70.7%	70.7%	24	22
241-AW-106	Solid	1.77	1.22	1062	29.7%	70.7%	33	22
241-AY-101	Supernatant	1.12	1.12	3019	81.2%	81.2%	24	23
241-AY-101	Solid	1.78	1.29	397	30.0%	81.2%	34	23
241-AY-102	Supernatant	1.30	1.30	3114	64.2%	64.2%	39	38
241-AY-102	Solid	1.59	1.15	571	39.2%	82.0%	53	38
241-AZ-101	Supernatant	1.24	1.24	2975	72.0%	72.0%	49	46
241-AZ-101	Solid	1.61	1.24	197	34.3%	72.0%	58	46
241-AZ-102	Supernatant	1.14	1.14	3163	83.7%	83.7%	55	55
241-AZ-102	Solid	1.41	1.14	396	54.8%	83.7%	67	55
241-SY-101	Supernatant	1.13	1.13	3225	81.9%	81.9%	21	20
241-SY-101	Solid	1.51	1.13	964	41.5%	81.9%	23	20
241-SY-102	Supernatant	1.12	1.12	1384	82.1%	82.1%	22	21
241-SY-102	Solid	1.55	1.31	769	47.1%	66.1%	25	21
241-SY-103	Supernatant	1.49	1.49	1444	47.1%	47.1%	31	25
241-SY-103	Solid	1.55	1.49	1353	36.9%	47.1%	27	25
241-A-101	Supernatant	0.00	0.00	0	46.9%	46.9%	0	33
241-A-101	Solid	1.46	1.49	1211	31.6%	46.9%	44	33
241-A-102	Supernatant	1.57	1.57	12	46.2%	46.2%	36	35
241-A-102	Solid	1.67	1.57	139	37.0%	46.2%	36	35
241-A-103	Supernatant	1.51	1.51	17	50.3%	50.3%	36	34
241-A-103	Solid	1.37	1.51	1417	41.3%	50.3%	40	34
241-A-104	Supernatant	0.00	0.00	0	0.0%	0.0%	0	34
241-A-104	Solid	0.95	1.17	106	0.0%	75.0%	74	34
241-A-105	Supernatant	0.00	0.00	0	0.0%	0.0%	59	59
241-A-105	Solid	1.54	1.17	139	0.0%	0.0%	59	59
241-A-106	Supernatant	0.00	0.00	0	0.0%	0.0%	50	50
241-A-106	Solid	1.70	1.17	299	34.3%	75.0%	50	50
241-AX-101	Supernatant	0.00	0.00	0	43.1%	43.1%	0	27
241-AX-101	Solid	1.70	1.53	1353	32.7%	43.1%	35	27
241-AX-102	Supernatant	0.00	0.00	0	0.0%	0.0%	0	23
241-AX-102	Solid	1.58	1.39	113	35.6%	51.0%	24	23
241-AX-103	Supernatant	0.00	0.00	0	49.1%	49.1%	0	32
241-AX-103	Solid	1.58	1.45	403	43.3%	49.1%	39	32
241-AX-104	Supernatant	0.00	0.00	0	0.0%	0.0%	0	32
241-AX-104	Solid	1.80	1.17	28	8.2%	75.0%	32	32
241-B-101	Supernatant	0.00	0.00	0	50.0%	50.0%	0	33
241-B-101	Solid	1.51	1.53	411	40.4%	50.0%	39	33
241-B-102	Supernatant	1.26	1.26	15	69.6%	69.6%	18	21
241-B-102	Solid	1.61	1.26	106	45.2%	69.6%	18	21

Table A-3. Tank Waste Physical Properties.

Tank	Layer	Bulk SpG	Liquid SpG	Non-RG Waste Volume (kL)	Water in Bulk (wt%)	Water in Liquid (wt%)	T _{Waste} (°C)	T _{Headspace} (°C)
241-B-103	Supernatant	0.00	0.00	0	69.6%	69.6%	0	20
241-B-103	Solid	1.61	1.26	211	49.5%	69.6%	17	20
241-B-104	Supernatant	0.00	0.00	0	69.6%	69.6%	0	22
241-B-104	Solid	1.38	1.26	1417	47.5%	69.6%	22	22
241-B-105	Supernatant	0.00	0.00	0	69.6%	69.6%	0	18
241-B-105	Solid	1.65	1.26	1098	43.3%	69.6%	19	18
241-B-106	Supernatant	1.26	1.26	4	67.2%	67.2%	18	20
241-B-106	Solid	1.38	1.26	460	59.9%	67.2%	23	20
241-B-107	Supernatant	0.00	0.00	0	57.5%	57.5%	0	31
241-B-107	Solid	1.63	1.34	611	40.1%	57.5%	16	31
241-B-108	Supernatant	0.00	0.00	0	69.6%	69.6%	0	20
241-B-108	Solid	1.70	1.38	350	34.5%	69.6%	21	20
241-B-109	Supernatant	0.00	0.00	0	69.6%	69.6%	0	20
241-B-109	Solid	1.82	1.26	475	39.4%	69.6%	20	20
241-B-110	Supernatant	1.19	1.19	4	76.2%	76.2%	21	22
241-B-110	Solid	1.36	1.19	925	58.3%	76.2%	21	22
241-B-111	Supernatant	1.19	1.19	4	76.2%	76.2%	24	24
241-B-111	Solid	1.27	1.19	910	63.1%	76.2%	24	24
241-B-112	Supernatant	1.51	1.51	11	46.2%	46.2%	25	20
241-B-112	Solid	1.49	1.51	121	41.0%	46.2%	25	20
241-B-201	Supernatant	0.00	0.00	0	0.0%	0.0%	0	20
241-B-201	Solid	1.26	1.17	111	64.2%	75.0%	18	20
241-B-202	Supernatant	0.00	0.00	0	0.0%	0.0%	0	19
241-B-202	Solid	1.22	1.17	108	75.9%	83.0%	16	19
241-B-203	Supernatant	1.05	1.05	2	89.4%	89.4%	20	21
241-B-203	Solid	1.19	1.05	188	75.7%	89.4%	17	21
241-B-204	Supernatant	1.05	1.05	3	91.4%	91.4%	19	21
241-B-204	Solid	1.19	1.05	184	77.3%	91.4%	17	21
241-BX-101	Supernatant	0.00	0.00	0	0.0%	0.0%	0	22
241-BX-101	Solid	1.68	1.28	180	15.5%	75.0%	22	22
241-BX-102	Supernatant	0.00	0.00	0	0.0%	0.0%	0	21
241-BX-102	Solid	1.12	1.17	298	32.2%	75.0%	20	21
241-BX-103	Supernatant	1.07	1.07	50	77.8%	77.8%	23	22
241-BX-103	Solid	1.66	1.07	235	49.6%	77.8%	21	22
241-BX-104	Supernatant	1.28	1.28	11	59.1%	59.1%	30	25
241-BX-104	Solid	1.68	1.28	369	26.9%	59.1%	30	25
241-BX-105	Supernatant	1.29	1.29	18	68.7%	68.7%	20	20
241-BX-105	Solid	1.69	1.29	254	13.8%	68.7%	20	20
241-BX-106	Supernatant	0.00	0.00	0	46.2%	46.2%	0	20
241-BX-106	Solid	1.62	1.51	143	39.9%	46.2%	20	20
241-BX-107	Supernatant	0.00	0.00	0	0.0%	0.0%	0	20
241-BX-107	Solid	1.44	1.17	1313	50.5%	75.0%	22	20
241-BX-108	Supernatant	0.00	0.00	0	0.0%	0.0%	0	20
241-BX-108	Solid	1.46	1.17	119	17.2%	75.0%	20	20
241-BX-109	Supernatant	0.00	0.00	0	0.0%	0.0%	0	21
241-BX-109	Solid	1.52	1.17	730	50.6%	72.0%	21	21
241-BX-110	Supernatant	1.44	1.44	5	53.1%	53.1%	20	22
241-BX-110	Solid	1.67	1.44	807	41.7%	53.1%	22	22
241-BX-111	Supernatant	0.00	0.00	0	51.2%	51.2%	0	21
241-BX-111	Solid	1.45	1.45	713	24.8%	51.2%	20	21

Table A-3. Tank Waste Physical Properties.

Tank	Layer	Bulk SpG	Liquid SpG	Non-RG Waste Volume (kL)	Water in Bulk (wt%)	Water in Liquid (wt%)	T _{Waste} (°C)	T _{Headspace} (°C)
241-BX-112	Supernatant	1.18	1.18	5	67.6%	67.6%	19	19
241-BX-112	Solid	1.31	1.18	617	63.3%	67.6%	21	19
241-BY-101	Supernatant	0.00	0.00	0	46.2%	46.2%	0	25
241-BY-101	Solid	1.84	1.51	1400	22.3%	46.2%	27	25
241-BY-102	Supernatant	0.00	0.00	0	50.8%	50.8%	0	22
241-BY-102	Solid	1.57	1.46	1054	31.1%	50.8%	22	22
241-BY-103	Supernatant	0.00	0.00	0	59.0%	59.0%	0	23
241-BY-103	Solid	1.66	1.29	1564	27.8%	59.0%	24	23
241-BY-104	Supernatant	0.00	0.00	0	48.9%	48.9%	0	24
241-BY-104	Solid	1.71	1.51	1533	25.9%	48.9%	38	24
241-BY-105	Supernatant	0.00	0.00	0	51.3%	51.3%	0	21
241-BY-105	Solid	1.80	1.44	1821	17.9%	51.3%	35	21
241-BY-106	Supernatant	0.00	0.00	0	59.4%	59.4%	0	37
241-BY-106	Solid	1.65	1.31	1623	26.8%	59.4%	32	37
241-BY-107	Supernatant	0.00	0.00	0	48.6%	48.6%	0	24
241-BY-107	Solid	1.69	1.46	1028	37.8%	48.6%	30	24
241-BY-108	Supernatant	0.00	0.00	0	32.7%	32.7%	0	27
241-BY-108	Solid	1.48	1.33	841	27.3%	32.7%	35	27
241-BY-109	Supernatant	0.00	0.00	0	53.0%	53.0%	0	17
241-BY-109	Solid	1.71	1.50	1086	42.0%	53.0%	18	17
241-BY-110	Supernatant	0.00	0.00	0	39.9%	39.9%	0	20
241-BY-110	Solid	1.57	1.44	1384	28.3%	39.9%	33	20
241-BY-111	Supernatant	0.00	0.00	0	53.8%	53.8%	0	19
241-BY-111	Solid	1.67	1.42	1523	35.2%	53.8%	25	19
241-BY-112	Supernatant	0.00	0.00	0	48.5%	48.5%	0	22
241-BY-112	Solid	1.74	1.47	1083	29.6%	48.5%	28	22
241-C-101	Supernatant	0.00	0.00	0	0.0%	0.0%	0	32
241-C-101	Solid	1.78	1.17	333	23.4%	74.0%	32	32
241-C-102	Supernatant	0.00	0.00	0	0.0%	0.0%	0	27
241-C-102	Solid	1.68	1.17	1196	42.9%	75.0%	28	27
241-C-103	Supernatant	0.98	0.98	1	98.0%	98.0%	43	23
241-C-103	Solid	1.61	0.98	9	14.5%	98.0%	43	23
241-C-104	Supernatant	0.00	0.00	0	0.0%	0.0%	0	34
241-C-104	Solid	1.68	1.17	980	47.9%	81.0%	38	34
241-C-105	Supernatant	0.00	0.00	0	0.0%	0.0%	0	43
241-C-105	Solid	1.55	1.23	500	28.3%	67.0%	49	43
241-C-106	Supernatant	1.02	1.02	0	97.8%	97.8%	31	26
241-C-106	Solid	1.56	1.02	10	41.9%	97.8%	30	26
241-C-107	Supernatant	0.00	0.00	0	0.0%	0.0%	0	40
241-C-107	Solid	1.55	1.17	935	47.5%	79.0%	43	40
241-C-108	Supernatant	1.12	1.12	2	83.2%	83.2%	0	24
241-C-108	Solid	1.48	1.12	27	38.2%	83.2%	25	24
241-C-109	Supernatant	0.00	0.00	0	0.0%	0.0%	0	25
241-C-109	Solid	1.43	1.17	38	54.1%	75.0%	25	25
241-C-110	Supernatant	1.10	1.10	4	82.9%	82.9%	21	24
241-C-110	Solid	1.44	1.10	670	60.2%	82.9%	24	24
241-C-111	Supernatant	0.00	0.00	0	0.0%	0.0%	0	19
241-C-111	Solid	1.55	1.17	217	36.1%	75.0%	23	19
241-C-112	Supernatant	0.00	0.00	0	0.0%	0.0%	0	27
241-C-112	Solid	1.58	1.17	393	51.8%	75.0%	27	27

Table A-3. Tank Waste Physical Properties.

Tank	Layer	Bulk SpG	Liquid SpG	Non-RG Waste Volume (kL)	Water in Bulk (wt%)	Water in Liquid (wt%)	T _{Waste} (°C)	T _{Headspace} (°C)
241-C-201	Supernatant	1.00	1.00	0	100.0%	100.0%	16	20
241-C-201	Solid	1.75	1.00	1	24.4%	100.0%	16	20
241-C-202	Supernatant	1.00	1.00	0	100.0%	100.0%	16	19
241-C-202	Solid	1.75	1.00	1	24.4%	100.0%	16	19
241-C-203	Supernatant	1.00	1.00	0	100.0%	100.0%	19	19
241-C-203	Solid	1.93	1.00	0	35.5%	100.0%	15	19
241-C-204	Supernatant	1.00	1.00	0	100.0%	100.0%	17	16
241-C-204	Solid	1.77	1.00	1	38.2%	100.0%	17	16
241-S-101	Supernatant	0.00	0.00	0	50.7%	50.7%	0	30
241-S-101	Solid	1.65	1.47	1332	39.2%	50.7%	38	30
241-S-102	Supernatant	0.00	0.00	0	0.0%	0.0%	0	25
241-S-102	Solid	1.53	1.46	113	28.0%	48.5%	28	25
241-S-103	Supernatant	1.45	1.45	4	49.8%	49.8%	25	24
241-S-103	Solid	1.62	1.47	892	35.7%	49.8%	29	24
241-S-104	Supernatant	0.00	0.00	0	55.1%	55.1%	0	31
241-S-104	Solid	1.67	1.37	1090	38.8%	55.1%	38	31
241-S-105	Supernatant	0.00	0.00	0	49.1%	49.1%	0	22
241-S-105	Solid	1.66	1.45	1536	7.7%	49.1%	26	22
241-S-106	Supernatant	0.00	0.00	0	54.2%	54.2%	0	21
241-S-106	Solid	1.72	1.43	1723	34.5%	54.2%	25	21
241-S-107	Supernatant	0.00	0.00	0	0.0%	0.0%	0	26
241-S-107	Solid	1.78	1.31	1356	34.1%	64.0%	33	26
241-S-108	Supernatant	0.00	0.00	0	49.1%	49.1%	0	23
241-S-108	Solid	1.68	1.45	2082	30.4%	49.1%	28	23
241-S-109	Supernatant	0.00	0.00	0	53.1%	53.1%	0	21
241-S-109	Solid	1.66	1.49	2017	10.7%	53.1%	26	21
241-S-110	Supernatant	0.00	0.00	0	49.3%	49.3%	0	26
241-S-110	Solid	1.66	1.43	1473	20.0%	49.3%	42	26
241-S-111	Supernatant	0.00	0.00	0	51.0%	51.0%	0	24
241-S-111	Solid	1.43	1.45	1517	29.0%	51.0%	27	24
241-S-112	Supernatant	1.27	1.27	0	73.3%	73.3%	29	21
241-S-112	Solid	1.90	1.27	9	22.8%	73.3%	29	21
241-SX-101	Supernatant	0.00	0.00	0	49.1%	49.1%	0	38
241-SX-101	Solid	1.68	1.48	1584	26.6%	49.1%	51	38
241-SX-102	Supernatant	0.00	0.00	0	48.1%	48.1%	0	34
241-SX-102	Solid	1.70	1.46	1292	39.3%	48.1%	52	34
241-SX-103	Supernatant	0.00	0.00	0	46.6%	46.6%	0	27
241-SX-103	Solid	1.73	1.47	1926	30.5%	46.6%	58	27
241-SX-104	Supernatant	0.00	0.00	0	45.3%	45.3%	0	35
241-SX-104	Solid	1.69	1.47	1688	28.2%	45.3%	56	35
241-SX-105	Supernatant	0.00	0.00	0	42.9%	42.9%	0	34
241-SX-105	Solid	1.63	1.47	1422	35.1%	42.9%	60	34
241-SX-106	Supernatant	0.00	0.00	0	49.4%	49.4%	0	26
241-SX-106	Solid	1.58	1.29	1501	39.8%	49.4%	33	26
241-SX-107	Supernatant	0.00	0.00	0	0.0%	0.0%	0	53
241-SX-107	Solid	1.77	1.50	356	22.7%	51.9%	69	53
241-SX-108	Supernatant	0.00	0.00	0	0.0%	0.0%	0	59
241-SX-108	Solid	1.77	1.17	280	2.0%	75.0%	76	59
241-SX-109	Supernatant	0.00	0.00	0	0.0%	0.0%	0	48
241-SX-109	Solid	1.73	1.39	913	23.2%	51.0%	55	48

Table A-3. Tank Waste Physical Properties.

Tank	Layer	Bulk SpG	Liquid SpG	Non-RG Waste Volume (kL)	Water in Bulk (wt%)	Water in Liquid (wt%)	T _{Waste} (°C)	T _{Headspace} (°C)
241-SX-110	Supernatant	0.00	0.00	0	0.0%	0.0%	0	60
241-SX-110	Solid	1.76	1.17	212	22.8%	75.0%	69	60
241-SX-111	Supernatant	0.00	0.00	0	0.0%	0.0%	0	61
241-SX-111	Solid	1.76	1.50	436	22.9%	51.9%	67	61
241-SX-112	Supernatant	0.00	0.00	0	0.0%	0.0%	0	53
241-SX-112	Solid	1.77	1.50	283	22.7%	51.9%	61	53
241-SX-113	Supernatant	0.00	0.00	0	0.0%	0.0%	0	28
241-SX-113	Solid	1.43	1.17	72	46.0%	75.0%	28	28
241-SX-114	Supernatant	0.00	0.00	0	51.9%	51.9%	0	58
241-SX-114	Solid	1.75	1.50	588	23.9%	51.9%	72	58
241-SX-115	Supernatant	0.00	0.00	0	0.0%	0.0%	0	25
241-SX-115	Solid	1.77	1.17	16	10.1%	75.0%	25	25
241-T-101	Supernatant	0.00	0.00	0	49.1%	49.1%	0	23
241-T-101	Solid	1.54	1.45	376	39.5%	49.1%	23	23
241-T-102	Supernatant	1.14	1.14	48	79.8%	79.8%	18	18
241-T-102	Solid	1.80	1.14	72	29.6%	79.8%	18	18
241-T-103	Supernatant	1.19	1.19	15	71.6%	71.6%	19	21
241-T-103	Solid	1.71	1.19	87	37.2%	71.6%	19	21
241-T-104	Supernatant	0.00	0.00	0	0.0%	0.0%	0	22
241-T-104	Solid	1.29	1.17	1199	70.5%	84.0%	19	22
241-T-105	Supernatant	0.00	0.00	0	0.0%	0.0%	0	16
241-T-105	Solid	1.46	1.18	371	53.0%	80.0%	17	16
241-T-106	Supernatant	0.00	0.00	0	0.0%	0.0%	0	22
241-T-106	Solid	1.59	1.17	82	16.7%	75.0%	20	22
241-T-107	Supernatant	0.00	0.00	0	0.0%	0.0%	0	21
241-T-107	Solid	1.56	1.17	655	45.7%	84.0%	19	21
241-T-108	Supernatant	0.00	0.00	0	69.6%	69.6%	0	22
241-T-108	Solid	1.55	1.26	60	34.5%	69.6%	16	22
241-T-109	Supernatant	0.00	0.00	0	69.6%	69.6%	0	22
241-T-109	Solid	1.65	1.26	235	48.7%	69.6%	23	22
241-T-110	Supernatant	1.05	1.05	3	86.8%	86.8%	19	22
241-T-110	Solid	1.25	1.05	1397	75.5%	86.8%	18	22
241-T-111	Supernatant	0.00	0.00	0	0.0%	0.0%	0	23
241-T-111	Solid	1.24	1.17	1691	75.3%	75.0%	22	23
241-T-112	Supernatant	1.10	1.10	26	85.1%	85.1%	19	23
241-T-112	Solid	1.28	1.10	226	73.9%	85.1%	23	23
241-T-201	Supernatant	1.06	1.06	8	91.2%	91.2%	19	21
241-T-201	Solid	1.31	1.06	107	67.5%	91.2%	21	21
241-T-202	Supernatant	0.00	0.00	0	0.0%	0.0%	0	21
241-T-202	Solid	1.18	1.17	77	75.8%	75.0%	21	21
241-T-203	Supernatant	0.00	0.00	0	0.0%	0.0%	0	20
241-T-203	Solid	1.22	1.17	136	76.2%	85.0%	21	20
241-T-204	Supernatant	0.00	0.00	0	0.0%	0.0%	0	20
241-T-204	Solid	1.18	1.17	136	75.0%	75.0%	21	20
241-TX-101	Supernatant	0.00	0.00	0	49.1%	49.1%	0	23
241-TX-101	Solid	1.74	1.45	344	25.1%	49.1%	25	23
241-TX-102	Supernatant	0.00	0.00	0	49.1%	49.1%	0	24
241-TX-102	Solid	1.61	1.45	821	31.2%	49.1%	26	24
241-TX-103	Supernatant	0.00	0.00	0	49.7%	49.7%	0	21
241-TX-103	Solid	1.61	1.44	548	31.2%	49.7%	22	21

Table A-3. Tank Waste Physical Properties.

Tank	Layer	Bulk SpG	Liquid SpG	Non-RG Waste Volume (kL)	Water in Bulk (wt%)	Water in Liquid (wt%)	T _{Waste} (°C)	T _{Headspace} (°C)
241-TX-104	Supernatant	1.44	1.44	9	51.9%	51.9%	21	21
241-TX-104	Solid	1.74	1.44	253	45.5%	51.9%	21	21
241-TX-105	Supernatant	0.00	0.00	0	49.1%	49.1%	0	23
241-TX-105	Solid	1.63	1.45	2181	29.4%	49.1%	33	23
241-TX-106	Supernatant	0.00	0.00	0	49.1%	49.1%	0	25
241-TX-106	Solid	1.62	1.45	1318	30.4%	49.1%	25	25
241-TX-107	Supernatant	0.00	0.00	0	49.9%	49.9%	0	17
241-TX-107	Solid	1.78	1.46	112	27.7%	49.9%	22	17
241-TX-108	Supernatant	0.00	0.00	0	49.1%	49.1%	0	20
241-TX-108	Solid	1.62	1.45	478	30.7%	49.1%	21	20
241-TX-109	Supernatant	0.00	0.00	0	0.0%	0.0%	0	41
241-TX-109	Solid	1.43	1.17	1375	54.1%	75.0%	35	41
241-TX-110	Supernatant	0.00	0.00	0	49.1%	49.1%	0	22
241-TX-110	Solid	1.62	1.45	1769	30.6%	49.1%	28	22
241-TX-111	Supernatant	0.00	0.00	0	49.1%	49.1%	0	26
241-TX-111	Solid	1.61	1.45	1381	31.3%	49.1%	29	26
241-TX-112	Supernatant	0.00	0.00	0	51.6%	51.6%	0	25
241-TX-112	Solid	1.63	1.42	2398	29.1%	51.6%	28	25
241-TX-113	Supernatant	0.00	0.00	0	49.1%	49.1%	0	22
241-TX-113	Solid	1.61	1.45	2416	15.5%	49.1%	23	22
241-TX-114	Supernatant	0.00	0.00	0	61.2%	61.2%	0	18
241-TX-114	Solid	1.63	1.33	2012	29.0%	61.2%	21	18
241-TX-115	Supernatant	0.00	0.00	0	49.1%	49.1%	0	21
241-TX-115	Solid	1.63	1.45	2093	29.5%	49.1%	22	21
241-TX-116	Supernatant	0.00	0.00	0	53.0%	53.0%	0	20
241-TX-116	Solid	1.66	1.39	2264	21.2%	53.0%	21	20
241-TX-117	Supernatant	0.00	0.00	0	69.6%	69.6%	0	20
241-TX-117	Solid	1.58	1.26	1817	27.0%	69.6%	21	20
241-TX-118	Supernatant	0.00	0.00	0	49.1%	49.1%	0	25
241-TX-118	Solid	1.69	1.45	935	44.7%	49.1%	29	25
241-TY-101	Supernatant	0.00	0.00	0	69.6%	69.6%	0	20
241-TY-101	Solid	1.63	1.26	447	44.2%	69.6%	19	20
241-TY-102	Supernatant	0.00	0.00	0	57.8%	57.8%	0	19
241-TY-102	Solid	1.76	1.36	262	32.0%	57.8%	16	19
241-TY-103	Supernatant	0.00	0.00	0	49.1%	49.1%	0	22
241-TY-103	Solid	1.68	1.45	585	51.7%	49.1%	25	22
241-TY-104	Supernatant	1.18	1.18	5	77.5%	77.5%	16	21
241-TY-104	Solid	1.65	1.18	163	51.9%	77.5%	22	21
241-TY-105	Supernatant	0.00	0.00	0	0.0%	0.0%	0	23
241-TY-105	Solid	1.53	1.17	874	39.4%	75.0%	25	23
241-TY-106	Supernatant	0.00	0.00	0	0.0%	0.0%	0	19
241-TY-107	Solid	1.40	1.17	62	38.1%	75.0%	16	19
241-U-101	Supernatant	0.00	0.00	0	0.0%	0.0%	0	21
241-U-101	Solid	1.77	1.17	87	29.8%	76.0%	21	21
241-U-102	Supernatant	1.48	1.48	4	47.5%	47.5%	27	23
241-U-102	Solid	1.67	1.48	1234	34.1%	47.5%	29	23
241-U-103	Supernatant	1.44	1.44	2	49.9%	49.9%	28	27
241-U-103	Solid	1.52	1.44	1576	39.5%	49.9%	29	27
241-U-104	Supernatant	0.00	0.00	0	0.0%	0.0%	0	24
241-U-104	Solid	1.12	1.40	205	71.4%	55.0%	28	24

Table A-3. Tank Waste Physical Properties.

Tank	Layer	Bulk SpG	Liquid SpG	Non-RG Waste Volume (kL)	Water in Bulk (wt%)	Water in Liquid (wt%)	T _{Waste} (°C)	T _{Headspace} (°C)
241-U-105	Supernatant	0.00	0.00	0	51.6%	30.4%	0	29
241-U-105	Solid	1.67	1.46	1336	30.4%	30.4%	31	29
241-U-106	Supernatant	1.34	1.34	6	48.6%	48.6%	24	28
241-U-106	Solid	1.55	1.34	638	41.6%	48.6%	30	28
241-U-107	Supernatant	0.00	0.00	0	49.6%	49.6%	0	25
241-U-107	Solid	1.74	1.43	1113	32.6%	49.6%	24	25
241-U-108	Supernatant	0.00	0.00	0	49.9%	49.9%	0	22
241-U-108	Solid	1.68	1.40	1641	36.9%	49.9%	27	22
241-U-109	Supernatant	0.00	0.00	0	50.7%	50.7%	0	23
241-U-109	Solid	1.47	1.47	1518	28.8%	50.7%	26	23
241-U-110	Supernatant	0.00	0.00	0	0.0%	0.0%	0	28
241-U-110	Solid	1.72	1.17	665	30.5%	75.0%	29	28
241-U-111	Supernatant	0.00	0.00	0	52.6%	52.6%	0	24
241-U-111	Solid	1.63	1.40	840	35.9%	52.6%	23	24
241-U-112	Supernatant	0.00	0.00	0	0.0%	0.0%	0	21
241-U-112	Solid	1.74	1.17	172	32.3%	75.0%	21	21
241-U-201	Supernatant	1.26	1.26	4	69.3%	69.3%	21	23
241-U-201	Solid	1.63	1.26	11	27.1%	69.3%	23	23
241-U-202	Supernatant	1.28	1.28	4	69.1%	69.1%	18	20
241-U-202	Solid	1.51	1.28	10	27.8%	69.1%	20	20
241-U-203	Supernatant	1.28	1.28	4	68.7%	68.7%	19	20
241-U-203	Solid	1.59	1.28	9	40.2%	68.7%	19	20
241-U-204	Supernatant	1.11	1.11	4	87.0%	87.0%	18	19
241-U-204	Solid	1.47	1.11	7	26.2%	87.0%	18	19

APPENDIX B

**CALCULATIONS OF THE GAS DIFFUSION COEFFICIENTS FOR THE CONCRETE
DOME OF SINGLE SHELL TANKS**

B1.0 APPROACH

Hydrogen (and other decomposition gases) would begin to build in concentration in the headspace under zero ventilation. Headspace concentration would increase until the system reached steady state and the diffusion outflow equaled the gas generation rate.

The approach used to estimate hydrogen diffusion through a single-shell tank dome is documented in RPP-18491 and is summarized as follows:

1. Estimate the effective diffusivity for hydrogen through concrete, asphaltic membrane, mortar/gunite, and soil (as appropriate).
2. Calculate a diffusion resistance term for each of the barriers listed in 1 above.
3. Sum the resistances for the respective diffusion barriers.
4. Calculate the amount of hydrogen that could diffuse through the dome.

B2.0 DOME DIFFUSION INPUTS

Table B-1 discusses diffusion barriers and coefficients taken from RPP-18491. Table B-2 shows diffusion resistance and diffusion rates through all 149 single-shell tank domes.

B3.0 REFERENCES

RPP-18491, 2003, *Flammable Gas Diffusion Through Single-Shell Tank Domes*, Rev. 0, CH2M HILL Hanford Group, Inc., Richland, Washington.

Table B-1. The Thickness of Dome Coatings for 149 Single-Shell Tanks and Diffusion Coefficients for Hydrogen and Methane.

Tank	Dome Area (cm ²)	Tank Dome Coatings	Concrete Thick (cm)	Asphaltic Thick (cm)	Gunitite Thick (cm)	Soil Thick (cm)	Concrete De of H ₂ (cm ² /sec)	Asphaltic De of H ₂ (cm ² /sec)	Gunitite De of H ₂ (cm ² /sec)	Soil De of H ₂ (cm ² /sec)	Concrete De of CH ₄ (cm ² /sec)	Asphaltic De of CH ₄ (cm ² /sec)	Gunitite De of CH ₄ (cm ² /sec)	Soil De of CH ₄ (cm ² /sec)
A-101	4.39E+06	2-Ply	38.1	0.6350	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
A-102	4.39E+06	2-Ply	38.1	0.6350	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
A-103	4.39E+06	2-Ply	38.1	0.6350	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
A-104	4.39E+06	2-Ply	38.1	0.6350	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
A-105	4.39E+06	2-Ply	38.1	0.6350	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
A-106	4.39E+06	2-Ply	38.1	0.6350	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
AX-101	4.39E+06	No Coatings	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
AX-102	4.39E+06	No Coatings	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
AX-103	4.39E+06	No Coatings	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
AX-104	4.39E+06	No Coatings	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-101	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-102	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-103	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-104	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-105	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-106	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-107	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-108	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-109	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-110	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-111	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-112	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-201	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-202	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-203	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-204	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-101	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-102	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-103	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-104	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-105	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-106	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-107	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-108	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-109	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-110	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-111	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-112	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-101	4.38E+06	Hardener + 3-Ply + ¼ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-102	4.38E+06	Hardener + 3-Ply + ¼ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-103	4.38E+06	Hardener + 3-Ply + ¼ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037

Table B-1. The Thickness of Dome Coatings for 149 Single-Shell Tanks and Diffusion Coefficients for Hydrogen and Methane.

Tank	Dome Area (cm ²)	Tank Dome Coatings	Concrete Thick (cm)	Asphaltic Thick (cm)	Gunitite Thick (cm)	Soil Thick (cm)	Concrete De of H ₂ (cm ² /sec)	Asphaltic De of H ₂ (cm ² /sec)	Gunitite De of H ₂ (cm ² /sec)	Soil De of H ₂ (cm ² /sec)	Concrete De of CH ₄ (cm ² /sec)	Asphaltic De of CH ₄ (cm ² /sec)	Gunitite De of CH ₄ (cm ² /sec)	Soil De of CH ₄ (cm ² /sec)
BY-104	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-105	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-106	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-107	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-108	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-109	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-110	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-111	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-112	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-101	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-102	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-103	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-104	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-105	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-106	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-107	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-108	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-109	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-110	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-111	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-112	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-201	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-202	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-203	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-204	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-101	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-102	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-103	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-104	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-105	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-106	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-107	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-108	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-109	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-110	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-111	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-112	4.38E+06	Hardener + 3-Ply + ¾ Gunitite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-101	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-102	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-103	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-104	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-105	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037

Table B-1. The Thickness of Dome Coatings for 149 Single-Shell Tanks and Diffusion Coefficients for Hydrogen and Methane.

Tank	Dome Area (cm ²)	Tank Dome Coatings	Concrete Thick (cm)	Asphaltic Thick (cm)	Gunitc Thick (cm)	Soil Thick (cm)	Concrete De of H ₂ (cm ² /sec)	Asphaltic De of H ₂ (cm ² /sec)	Gunitc De of H ₂ (cm ² /sec)	Soil De of H ₂ (cm ² /sec)	Concrete De of CH ₄ (cm ² /sec)	Asphaltic De of CH ₄ (cm ² /sec)	Gunitc De of CH ₄ (cm ² /sec)	Soil De of CH ₄ (cm ² /sec)
SX-106	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-107	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-108	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-109	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-110	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-111	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-112	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-113	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-114	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-115	4.39E+06	Hardener	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-101	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-102	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-103	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-104	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-105	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-106	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-107	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-108	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-109	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-110	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-111	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-112	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-201	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-202	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-203	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-204	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-101	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-102	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-103	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-104	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-105	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-106	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-107	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-108	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-109	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-110	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-111	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-112	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-113	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-114	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-115	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-116	4.38E+06	Hardener + 3-Ply + ¾ Gunitc	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037

Table B-1. The Thickness of Dome Coatings for 149 Single-Shell Tanks and Diffusion Coefficients for Hydrogen and Methane.

Tank	Dome Area (cm ²)	Tank Dome Coatings	Concrete Thick (cm)	Asphaltic Thick (cm)	Gunite Thick (cm)	Soil Thick (cm)	Concrete De of H ₂ (cm ² /sec)	Asphaltic De of H ₂ (cm ² /sec)	Gunite De of H ₂ (cm ² /sec)	Soil De of H ₂ (cm ² /sec)	Concrete De of CH ₄ (cm ² /sec)	Asphaltic De of CH ₄ (cm ² /sec)	Gunite De of CH ₄ (cm ² /sec)	Soil De of CH ₄ (cm ² /sec)
TX-117	4.38E+06	Hardener + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-118	4.38E+06	Hardener + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TY-101	4.38E+06	Hardener + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TY-102	4.38E+06	Hardener + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TY-103	4.38E+06	Hardener + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TY-104	4.38E+06	Hardener + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TY-105	4.38E+06	Hardener + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TY-106	4.38E+06	Hardener + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-101	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-102	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-103	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-104	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-105	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-106	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-107	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-108	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-109	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-110	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-111	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-112	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-201	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-202	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-203	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-204	1.46E+05	Hardener + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037

Table B-2. The Diffusion Resistance and Gas Diffusion Rates of Hydrogen and Methane for 149 Single-Shell Tanks.

Tank	Concrete Resist of H ₂ (sec/cm)	Asphaltic Resist of H ₂ (sec/cm)	Gunitite Resist of H ₂ (sec/cm)	Soil Resist of H ₂ (sec/cm)	Concrete Resist of CH ₄ (sec/cm)	Asphaltic Resist of CH ₄ (sec/cm)	Gunitite Resist of CH ₄ (sec/cm)	Soil Resist of CH ₄ (sec/cm)	Total Resist of H ₂ (sec/cm)	Total Resist of CH ₄ (sec/cm)	H ₂ Diff Rate Ai/Ri (cfm)	CH ₄ Diff Rate Ai/Ri (cfm)
A-101	1.00E+04	1.27E+06	0.00E+00	3.05E+03	3.18E+04	1.27E+06	0.00E+00	9.89E+03	1.28E+06	1.31E+06	7.25E-03	7.09E-03
A-102	1.00E+04	1.27E+06	0.00E+00	3.05E+03	3.18E+04	1.27E+06	0.00E+00	9.89E+03	1.28E+06	1.31E+06	7.25E-03	7.09E-03
A-103	1.00E+04	1.27E+06	0.00E+00	3.05E+03	3.18E+04	1.27E+06	0.00E+00	9.89E+03	1.28E+06	1.31E+06	7.25E-03	7.09E-03
A-104	1.00E+04	1.27E+06	0.00E+00	3.05E+03	3.18E+04	1.27E+06	0.00E+00	9.89E+03	1.28E+06	1.31E+06	7.25E-03	7.09E-03
A-105	1.00E+04	1.27E+06	0.00E+00	3.05E+03	3.18E+04	1.27E+06	0.00E+00	9.89E+03	1.28E+06	1.31E+06	7.25E-03	7.09E-03
A-106	1.00E+04	1.27E+06	0.00E+00	3.05E+03	3.18E+04	1.27E+06	0.00E+00	9.89E+03	1.28E+06	1.31E+06	7.25E-03	7.09E-03
AX-101	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
AX-102	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
AX-103	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
AX-104	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
B-101	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-102	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-103	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-104	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-105	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-106	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-107	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-108	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-109	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-110	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-111	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-112	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-201	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
B-202	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
B-203	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
B-204	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
BX-101	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-102	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-103	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-104	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-105	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-106	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-107	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-108	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-109	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-110	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-111	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-112	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BY-101	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-102	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-103	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03

Table B-2. The Diffusion Resistance and Gas Diffusion Rates of Hydrogen and Methane for 149 Single-Shell Tanks.

Tank	Concrete Resist of H ₂ (sec/cm)	Asphaltic Resist of H ₂ (sec/cm)	Gunitite Resist of H ₂ (sec/cm)	Soil Resist of H ₂ (sec/cm)	Concrete Resist of CH ₄ (sec/cm)	Asphaltic Resist of CH ₄ (sec/cm)	Gunitite Resist of CH ₄ (sec/cm)	Soil Resist of CH ₄ (sec/cm)	Total Resist of H ₂ (sec/cm)	Total Resist of CH ₄ (sec/cm)	H ₂ Diff Rate Ai/Ri (cfm)	CH ₄ Diff Rate Ai/Ri (cfm)
BY-104	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-105	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-106	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-107	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-108	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-109	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-110	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-111	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-112	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
C-101	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-102	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-103	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-104	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-105	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-106	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-107	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-108	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-109	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-110	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-111	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-112	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-201	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
C-202	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
C-203	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
C-204	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
S-101	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-102	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-103	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-104	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-105	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-106	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-107	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-108	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-109	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-110	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-111	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-112	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
SX-101	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-102	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-103	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-104	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-105	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-106	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01

Table B-2. The Diffusion Resistance and Gas Diffusion Rates of Hydrogen and Methane for 149 Single-Shell Tanks.

Tank	Concrete Resist of H ₂ (sec/cm)	Asphaltic Resist of H ₂ (sec/cm)	Gunite Resist of H ₂ (sec/cm)	Soil Resist of H ₂ (sec/cm)	Concrete Resist of CH ₄ (sec/cm)	Asphaltic Resist of CH ₄ (sec/cm)	Gunite Resist of CH ₄ (sec/cm)	Soil Resist of CH ₄ (sec/cm)	Total Resist of H ₂ (sec/cm)	Total Resist of CH ₄ (sec/cm)	H ₂ Diff Rate Ai/Ri (cfm)	CH ₄ Diff Rate Ai/Ri (cfm)
SX-107	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-108	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-109	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-110	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-111	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-112	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-113	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-114	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-115	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
T-101	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-102	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-103	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-104	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-105	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-106	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-107	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-108	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-109	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-110	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-111	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-112	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-201	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
T-202	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
T-203	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
T-204	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
TX-101	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-102	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-103	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-104	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-105	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-106	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-107	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-108	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-109	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-110	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-111	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-112	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-113	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-114	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-115	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-116	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-117	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-118	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03

Table B-2. The Diffusion Resistance and Gas Diffusion Rates of Hydrogen and Methane for 149 Single-Shell Tanks.

Tank	Concrete Resist of H ₂ (sec/cm)	Asphaltic Resist of H ₂ (sec/cm)	Gunite Resist of H ₂ (sec/cm)	Soil Resist of H ₂ (sec/cm)	Concrete Resist of CH ₄ (sec/cm)	Asphaltic Resist of CH ₄ (sec/cm)	Gunite Resist of CH ₄ (sec/cm)	Soil Resist of CH ₄ (sec/cm)	Total Resist of H ₂ (sec/cm)	Total Resist of CH ₄ (sec/cm)	H ₂ Diff Rate Ai/Ri (cfm)	CH ₄ Diff Rate Ai/Ri (cfm)
TY-101	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TY-102	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TY-103	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TY-104	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TY-105	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TY-106	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
U-101	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-102	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-103	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-104	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-105	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-106	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-107	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-108	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-109	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-110	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-111	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-112	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-201	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
U-202	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
U-203	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
U-204	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04

APPENDIX C
AMMONIA CONTRIBUTION TO FLAMMABILITY

C1.0 PURPOSE

This appendix establishes a reasonably conservative ammonia contribution to flammability for double-shell tank (DST) and single-shell tank (SST) time to the lower flammability limit (TTLFL) calculations.

C2.0 BACKGROUND

Headspace flammability is dominated by hydrogen, and although a gas mixture of several fuel components (e.g., methane, hydrocarbons, ammonia) can exist, the mixture behaves like a hydrogen-air system with respect to flammability (RPP-7771). The previous approach for ammonia contribution to flammability was to assume a constant release rate (as determined by Equation C-1) and include this contribution along with hydrogen and methane generation.

$$R_g = h \cdot A \cdot (C_l - K_H \cdot P_g) \quad (C - 1)$$

Where

R_g = ammonia release rate, kg-mole/s

h = overall mass transport coefficient from liquid to vapor, m/s

A = effective transport area, m^2

C_l = current ammonia concentration in liquid, kg-mole/ m^3

K_H = Henry's Law constant, kg-mole/ m^3 -atm

P_g = ammonia partial pressure, atm

The product $h \cdot A$ was estimated through Equation C-2.

$$h \cdot A = \left[\frac{C_g^{ss} \cdot V_r}{(C_l - K_H \cdot P_g)} \right] \quad (C - 2)$$

Where

C_g^{ss} = steady-state headspace ammonia concentration, kg-mole/ m^3

V_r = ventilation rate, m^3/s

Steady-state ammonia concentration (C_g^{ss}), headspace ventilation rate (V_r), and ammonia liquid concentration (C_l) must be known simultaneously for current conditions to accurately estimate the product $h \cdot A$. Estimates of $h \cdot A$ were based on the best available information; however, these data are not routinely collected and the available data in some cases do not accurately reflect current waste tank conditions. To remedy this, a reasonably conservative ammonia flammability contribution for use in TTLFL calculations is developed here.

C3.0 AMMONIA DATA

Ammonia is of interest in Tank Farms as a flammable gas hazard and noxious vapor hazard so a significant amount of data exists. This section reviews data collected over more than 15 years and examines mass transfer characteristics that will help determine a reasonably conservative ammonia contribution to flammability.

C3.1 MEASURED AMMONIA CONCENTRATIONS

Ammonia concentrations have been measured at the source (i.e., tank headspace or ventilation stack) more than 1,500 times. Most measurements were made under quiescent waste conditions, but data have also been collected during waste disturbing activities.

C3.1.1 Quiescent Waste Conditions

Table C-1 shows the maximum ammonia concentration measured for each source and when this maximum occurred. Slightly more than 70% of the tank headspaces (127 of 177) have been analyzed for ammonia. Sampling was targeted at those tanks that were most likely to contain noxious vapors, so ammonia concentrations in the 50 non-sampled tanks are expected to be lower.

Table C-1 data are sorted from the highest to lowest measured concentration. Tank 241-U-103 has the highest measured concentration, 2502 ppm or 1.67% of the LFL.

Table C-1. Maximum Measured Concentrations.*

Tank Name	Sample Location	Maximum Measured Concentration (ppmv)	Maximum Measured Concentration (% of LFL)	Sample Date
241-U-103	Headspace	2502	1.67%	12/15/2004
241-U-105	Headspace	2383	1.59%	12/27/2004
241-U-102	Headspace	2046	1.36%	11/29/2004
241-U-108	Headspace	1216	0.81%	11/28/2004
241-BY-108	Headspace	1140	0.76%	10/27/1994
241-U-106	Headspace	1013	0.68%	3/7/1995
241-TX-110	Headspace	1000	0.67%	9/23/1997
241-BY-107	Headspace	978	0.65%	10/26/1994
241-U-101	Headspace	949	0.63%	1/26/2005
241-S-101	Headspace	940	0.63%	2/1/2005
241-S-102	Headspace	805	0.54%	9/19/1996
241-A-101	Headspace	800	0.53%	6/8/1995
241-U-110	Headspace	728	0.49%	12/20/2004
241-U-111	Headspace	682	0.45%	2/28/1995
241-TX-111	Headspace	638	0.43%	10/12/1995
241-U-109	Headspace	608	0.41%	8/10/1995
241-C-104	Headspace	561	0.37%	6/15/2004

Table C-1. Maximum Measured Concentrations.*

Tank Name	Sample Location	Maximum Measured Concentration (ppmv)	Maximum Measured Concentration (% of LFL)	Sample Date
241-SY-102	Headspace	551†	0.37%	9/12/2000
241-U-107	Headspace	474	0.32%	2/17/1995
SY Ventilation	Vent Stack	442†	0.29%	8/30/2000
241-BY-110	Headspace	426	0.28%	11/11/1994
241-C-103	Headspace	349	0.23%	5/20/1994
241-U-112	Headspace	326	0.22%	7/9/1996
241-C-102	Headspace	317	0.21%	6/24/2004
241-BY-104	Headspace	286	0.19%	4/22/1994
241-A-106	Headspace	280	0.19%	1/16/1997
241-A-103	Headspace	273	0.18%	11/9/1995
241-S-107	Headspace	270	0.18%	2/7/2005
241-BX-104	Headspace	269	0.18%	8/22/1996
241-A-102	Headspace	263	0.18%	11/10/1995
241-AP-104	Headspace	260	0.17%	11/28/2000
241-TX-106	Headspace	260	0.17%	3/5/1997
241-AP-102	Headspace	234	0.16%	3/28/2001
241-T-111	Headspace	227	0.15%	1/20/1995
241-AN-101	Headspace	219	0.15%	4/24/2001
241-AP-106	Headspace	197	0.13%	5/8/2001
241-SX-106	Headspace	188	0.13%	3/24/1995
241-BY-102	Headspace	180	0.12%	11/21/1995
241-TX-102	Headspace	170	0.11%	10/13/1997
241-TX-114	Headspace	170	0.11%	3/25/1997
241-BX-105	Headspace	155	0.10%	4/24/1996
241-C-110	Headspace	154	0.10%	6/9/2004
241-S-103	Headspace	153	0.10%	6/12/1996
241-S-110	Headspace	153	0.10%	12/5/1995
241-T-107	Headspace	127	0.08%	1/18/1995
241-S-111	Headspace	124	0.08%	3/21/1995
241-TX-112	Headspace	120	0.08%	12/9/1997
241-T-104	Headspace	110	0.07%	2/7/1996
241-TX-103	Headspace	110	0.07%	10/24/1997
241-T-110	Headspace	109	0.07%	8/31/1995
241-C-101	Headspace	99	0.07%	9/1/1994
241-BX-103	Headspace	96	0.06%	8/1/1996
241-BY-106	Headspace	92	0.06%	5/4/1994
241-S-112	Headspace	90	0.06%	7/11/1995
241-BX-107	Headspace	89	0.06%	11/17/1995
241-C-107	Headspace	87	0.06%	9/29/1994
241-SX-103	Headspace	80	0.05%	3/23/1995
241-AP-101	Headspace	72	0.05%	7/10/2001
241-BY-112	Headspace	71	0.05%	11/18/1994
241-BX-110	Headspace	66	0.04%	4/30/1996
241-BY-101	Headspace	65	0.04%	8/29/1996

Table C-1. Maximum Measured Concentrations.*

Tank Name	Sample Location	Maximum Measured Concentration (ppmv)	Maximum Measured Concentration (% of LFL)	Sample Date
241-BX-111	Headspace	64	0.04%	8/27/1996
241-TY-104	Headspace	62	0.04%	4/27/1995
241-BY-105	Headspace	61	0.04%	5/9/1994
241-BY-111	Headspace	61	0.04%	11/16/1994
241-TY-103	Headspace	54	0.04%	11/22/1996
241-A-105	Headspace	54	0.04%	3/6/2005
241-BX-106	Headspace	51	0.03%	8/15/1996
241-S-109	Headspace	48	0.03%	6/4/1996
241-BY-109	Headspace	46	0.03%	9/22/1994
241-AX-101	Headspace	44	0.03%	6/15/1995
241-AX-103	Headspace	44	0.03%	6/21/1995
241-TX-118	Headspace	43	0.03%	9/7/1994
241-S-106	Headspace	39	0.03%	6/13/1996
241-S-105	Headspace	38	0.03%	12/7/1995
241-AX-102	Headspace	37	0.02%	6/27/1995
241-BY-103	Headspace	35	0.02%	5/5/1994
241-SX-105	Headspace	30	0.02%	7/26/1995
241-TX-104	Headspace	30	0.02%	5/5/1997
241-S-108	Headspace	27	0.02%	12/6/1995
241-TY-103	Headspace	27	0.02%	8/5/1994
241-C-112	Headspace	26	0.02%	7/1/2004
241-SX-104	Headspace	26	0.02%	7/25/1995
241-TX-108	Headspace	26	0.02%	12/5/1997
241-B-107	Headspace	26	0.02%	7/23/1996
241-TX-113	Headspace	24	0.02%	8/6/1997
241-T-101	Headspace	23	0.02%	12/1/1997
241-TX-105	Headspace	21	0.01%	12/20/1994
241-SX-109	Headspace	18	0.01%	8/1/1995
241-TY-101	Headspace	18	0.01%	8/5/1994
241-SX-102	Headspace	16	0.01%	7/19/1995
241-TX-116	Headspace	15	0.01%	9/18/1997
241-C-109	Headspace	11	0.01%	8/10/1994
241-B-103	Headspace	10	0.01%	2/8/1995
241-C-106	Headspace	8.8	0.01%	2/15/1994
241-C-111	Headspace	6.8	0.00%	9/13/1994
241-B-105	Headspace	5.9	0.00%	7/30/1996
241-B-102	Headspace	5.5	0.00%	4/18/1996
241-SX-101	Headspace	4.2	0.00%	7/21/1995
241-TY-102	Headspace	4.1	0.00%	4/12/1996
241-C-108	Headspace	3.3	0.00%	8/5/1994
241-B-202	Headspace	3.0	0.00%	7/18/1996
241-BX-102	Headspace	3.0	0.00%	7/31/1996
241-C-105	Headspace	2.7	0.00%	2/16/1994
241-U-201	Headspace	1.8	0.00%	11/19/2004

Table C-1. Maximum Measured Concentrations.*

Tank Name	Sample Location	Maximum Measured Concentration (ppmv)	Maximum Measured Concentration (% of LFL)	Sample Date
241-U-203	Headspace	1.2	0.00%	11/23/2004
241-AY-102	Headspace	1.0	0.00%	3/18/2004
241-C-204	Headspace	0.8	0.00%	7/2/1996
241-A-104	Headspace	0.7	0.00%	3/2/2005
241-S-104	Headspace	0.7	0.00%	2/14/2005
241-C-203	Headspace	0.6	0.00%	5/12/2004
241-U-202	Headspace	0.6	0.00%	11/19/2004
241-U-204	Headspace	0.2	0.00%	8/8/1995
241-AN-106	Headspace	< 14	NA	6/21/2001
241-AX-104	Headspace	< 14	NA	1/23/1997
241-C-201	Headspace	< 1.4	NA	6/19/1996
241-C-202	Headspace	< 0.7	NA	6/25/1996
241-SX-107	Headspace	< 14	NA	5/19/1997
241-SX-108	Headspace	< 14	NA	7/16/1997
241-SX-110	Headspace	< 14	NA	7/30/1997
241-SX-111	Headspace	< 14	NA	5/22/1997
241-SX-112	Headspace	< 14	NA	6/18/1997
241-SX-114	Headspace	< 14	NA	6/25/1997
241-TX-101	Headspace	< 14	NA	10/28/1997
241-TX-115	Headspace	< 14	NA	11/20/1997
241-TX-117	Headspace	< 14	NA	12/11/1997
241-TY-105	Headspace	< 14	NA	10/20/1997
241-U-104	Headspace	< 0.71	NA	7/16/1996
AN Ventilation	Vent Stack	< 14	NA	7/27/2000
AP Ventilation	Vent Stack	< 14	NA	6/22/2000
AW Ventilation	Vent Stack	< 14	NA	6/14/2000
AY/AZ Vent Sys	Vent Stack	< 14	NA	8/14/2000

Note: * Data from Tank Waste Information Network (TWINS), Queried 08/14/2008, [Vapor, Headspace Sample Analysis, Analysis Results], <http://twins.pnl.gov/twins.htm>.

† Data represent transient peak from remediation of 241-SY-101.

NA = Not Available

In addition to the data shown in Table C-1, 241-SY-101 ammonia concentrations were monitored by an E+ Standard Hydrogen Monitoring System. Headspace concentrations ranged between 200 to 2000 ppm and reached a peak of 2700 ppm during a ventilation outage in May 2001. Tank 241-SY-101 still had a significant crust layer covering 75% of the waste surface at this time and the supernatant obviously still contained significant ammonia. Since then, 241-SY-101 was returned to active service and many waste transfers have passed through the tank. The 241-SY-101 liquid waste no longer contains the high ammonia concentrations it held before and immediately after remediation.

Ammonia contribution to flammability under normal conditions is small with all maximums being less than 2% of the LFL. Statistical analysis of tank headspace vapor data (RPP-21972) showed ammonia temporal variances (i.e., the variability in headspace concentrations measured

in samples collected on different dates) are low. Average temporal variance was only 36% and the maximum observed variance in tanks under passive ventilation was 106% (Tank 241-S-103). Temporal variabilities were similar regardless whether samples were taken six months or more than five years apart. Results suggest that the maximums shown in Table C-1 are reasonably conservative and are only modestly influenced by the slowly changing tank conditions.

C3.1.2 Waste Disturbing Activities

In addition to the data shown in Table C-1, direct reading instruments have been used to measure ammonia during waste disturbing activities. The highest ammonia concentration ever measured was 7,400 ppm (~4.9% of the LFL) in the 241-SY-102 headspace during a transfer from 241-SY-101 in February 2000 (PNNL-13933). Liquid waste containing entrained air (from the 241-SY-102 drop leg siphon break) was injected into the 241-SY-102 supernatant layer. This relatively high ammonia release was a result of mixing and stripping by entrained air bubbles. Ammonia concentration quickly dropped from this peak measurement and was about 3,500 ppm (~2.3% of the LFL) after 24 hours. Ammonia concentration in 241-SY-101 peaked at 2,000 ppm (~1.3% of the LFL) during this transfer and quickly dropped to about 100 ppm (<0.1% of the LFL) after 24 hours.

The next highest measurement was 4,000 ppm (~2.7% of the LFL) during saltwell pumping of tank 241-U-105 (PNNL-13933). Ammonia headspace concentrations slowly increased from about 2,000 ppm to about 4,000 ppm from January 21 to April 3, 2000, as the higher concentration ammonia solution towards the bottom of the tank was exposed to the headspace. From Table C-1, Tank 241-U-105 ammonia headspace concentration was 2,583 ppm on December 27, 2004, a slightly higher quiescent concentration than before saltwell pumping.

Negligible ammonia was released during Tank 241-S-106 saltwell pumping and headspace measurements failed to exceed detection limits. Tank 241-A-101 headspace ammonia concentrations were about 800 ppm before saltwell pumping began, and stayed a relatively constant 1,500 ppm during saltwell pumping in late 2002. No headspace measurements have been made since saltwell pumping was completed.

The available ammonia data taken during waste disturbing activities suggest that ammonia concentrations can spike temporarily, before returning to concentrations near steady-state quiescent conditions. Concentrations are always limited to equilibrium with the maximum concentration found in the waste liquid (see next Section C3.2).

C3.2 THEORETICAL MAXIMUM (EQUILIBRIUM) CONCENTRATIONS

The partial pressure of ammonia over a dilute solution at equilibrium can be approximated through Henry's Law (see Equation C-3). Liquid ammonia concentrations have been measured in 56 tanks and Henry's law constants can be estimated from values in the open literature and simulant testing performed at the Hanford Site.

$$P_g = \frac{C_l}{K_H} \quad (C - 3)$$

Where

- P_g = ammonia partial pressure, atm
 C_l = ammonia concentration in the liquid, kg-mole/m³
 K_H = Henry's Law constant, kg-mole/m³-atm

C3.2.1 Estimating Henry's Law Constants for Ammonia

The Henry's Law constant is a function of temperature in pure water. In mixed salt solutions, Henry's Law constants are functions of both temperature and the concentrations of the ions in the solution. "The Estimation of Gas Solubility in Salt Solutions at Temperature from 273 K to 363 K" (Weisenberger and Schumpe 1996) provides a formula to calculate Henry's Law constants (shown in Equation C-4).

$$K_H = K_H^0 \times 10^{-\sum_i (h_i + h_g) C_i} \quad (C - 4)$$

Where

- K_H = Henry's Law constant in salt solution, kg-mole/m³-atm
 K_H^0 = Henry's Law constant in the pure water, kg-mole/m³-atm
 h_i = ionic dependent coefficient, m³/kg-mole
 h_g = gas specific constant for ammonia, m³/kg-mole
 C_i = ion concentration in the solution, kg-mole/m³

An expression for K_H^0 as a function of temperature is given in Clegg and Brimblecombe (1989) and is shown in Equation C-5. Equation C-5 results are for ammonia dissolved in pure water and have units of mole/kg of water-atm, which is approximately equal to kg-mole/m³-atm over the temperature range and ammonia concentrations of interest.

$$K_H^0 = e^{-8.0964 + 3917.50/T - 0.00314 T} \quad (C - 5)$$

Where

- K_H^0 = Henry's Law constant in the pure water, mole/kg of water-atm
 T = temperature, K

C3.2.2 Correction Factors for High Ionic Strength Solutions

The Weisenberger and Schumpe (1996) formula (Equation C-4) is accurate for solutions up to 5 molar, and is known to under-predict ammonia solubility at higher concentrations. Simulant experiments performed at Hanford (RPP-4941) examined Henry's Law constants for higher ionic strengths. The study covered solution concentrations ranging from 5 to 20 molar at temperatures of 21 °C to 70 °C. Henry's Law correction factors as a function of temperature and ionic strength are given in Table C-2 and plotted in Figure C-1 (*RPP-5926 Figure C-1.xls*, SVF-1549).

Table C-2. Ratio of Measured Henry's Law Constant to Calculated Henry's Law Constant at Various Ionic Strengths and Temperatures.*

Ionic Strength (kg-mole/m ³)	$K_{\text{meas}}/K_{\text{calc}}$ at 21.5 °C	$K_{\text{meas}}/K_{\text{calc}}$ at 30 °C	$K_{\text{meas}}/K_{\text{calc}}$ at 40 °C	$K_{\text{meas}}/K_{\text{calc}}$ at 50 °C	$K_{\text{meas}}/K_{\text{calc}}$ at 60 °C	$K_{\text{meas}}/K_{\text{calc}}$ at 70 °C
20	2.17	2.38	2.42	2.85	3.68	4.96
15	1.52	1.68	2.17	2.41	2.67	3.34
10	1.33	1.46	1.53	1.76	1.94	2.01
5	1.10	1.33	1.13	0.97	1.61	1.55

Notes: * Data from RPP-4941, Appendix H.

Figure C-1. Henry's Law Correction Factors

Examining Figure C-1, the ratio between measured and calculated Henry's Law constants vary approximately linearly with increasing ionic strength. Increasing temperature appears also to increase the ratio. Linear fit equations in 10 °C intervals are shown on the Figure C-1 legend. Knowing waste temperatures, liquid ammonia concentrations, and ion concentrations coupled with the ionic and gas specific dependent coefficients (h_i and h_g), maximum theoretical ammonia concentrations can be calculated.

C.3.2.3 Calculated Maximum Headspace Concentrations

The linear equations shown on Figure C-1 provide correction factors to the calculated Henry's Law constant (Equation C-6).

$$K_{H \text{ in solution}} = K_H^0 \times 10^{-\sum_i (h_i + h_g) C_i} \times (\text{Correction Factor}) \quad (\text{C} - 6)$$

Waste temperatures were rounded to the nearest 10 °C for selecting temperature/ionic strength correction factors shown in Figure C-1. This was assumed to be sufficiently accurate for temperatures that fall between the 10 °C intervals. Waste temperatures lower than 20 °C used the temperature/ionic strength correction factors determine for 20 °C. Equilibrium ammonia concentrations were calculated in a separate spreadsheet (*RPP-5926 Ammonia Evaluation.xls*, SVF-1549) and results are shown in Table C-3. TTLFL results under hypothetical zero ventilation (see main text) are included in last column of Table C-3.

Table C-3. Maximum Theoretical Headspace Ammonia Concentrations.

Tank	C_i^1 (kg-mole/m ³)	$K_{H \text{ in solution}}^1$ (kg-mole/m ³ -atm)	P_g^1 (atm)	LFL ¹ (%)	TTLFL ² (days)
241-SX-103	0.106	3.5	3.01E-02	20	NA
241-SX-105	0.071	3.7	1.94E-02	13	NA
241-SX-102	0.080	4.9	1.66E-02	11	NA
241-SY-101	0.271 ³	18.2	1.49E-02	10	1193
241-SX-106	0.147	10.1	1.46E-02	9.7	NA
241-SX-108	0.076	5.3	1.44E-02	9.6	NA
241-S-102	0.100	7.1	1.41E-02	9.4	>1826
241-A-101	0.031	3.3	9.36E-03	6.2	>1826
241-BY-106	0.060	7.4	8.13E-03	5.4	>1826
241-S-101	0.071	8.9	7.94E-03	5.3	>1826
241-U-103	0.082	10.8	7.62E-03	5.1	1082
241-U-105	0.094	12.4	7.59E-03	5.1	1093
241-SY-103	0.076	10.3	7.38E-03	4.9	659
241-AX-101	0.032	4.7	6.81E-03	4.5	NA
241-S-111	0.088	14.1	6.25E-03	4.2	>1826
241-A-103	0.031	5.0	6.19E-03	4.1	>1826
241-S-103	0.083	13.4	6.16E-03	4.1	>1826
241-SX-104	0.047	7.9	5.91E-03	3.9	NA
241-U-108	0.062	10.9	5.66E-03	3.8	>1826
241-U-109	0.065	14.2	4.54E-03	3.0	>1826
241-C-103	0.071	17.1	4.16E-03	2.8	>1826
241-AN-103	0.020	5.7	3.55E-03	2.4	408
241-SX-101	0.008	2.6	3.01E-03	2.0	NA
241-U-102	0.044	15.3	2.86E-03	1.9	>1826
241-U-106	0.062	21.7	2.85E-03	1.9	>1826

Table C-3. Maximum Theoretical Headspace Ammonia Concentrations.

Tank	C_1^1 (kg-mole/m ³)	$K_{H \text{ in solution}}^1$ (kg-mole/m ³ -atm)	P_g^1 (atm)	LFL ¹ (%)	TTLFL ² (days)
241-SY-102	0.068 ⁴	33.6	2.01E-03	1.3	>1826
241-AN-104	0.014	7.4	1.95E-03	1.3	255
241-AZ-102	0.026	13.3	1.94E-03	1.3	53
241-AN-105	0.012	7.4	1.68E-03	1.1	409
241-T-110	0.088	53.3	1.65E-03	1.1	>1826
241-U-107	0.024	16.8	1.41E-03	0.94	>1826
241-AW-106	0.021	18.5	1.12E-03	0.75	655
241-S-106	0.014	12.6	1.12E-03	0.75	>1826
241-AP-107	0.062	60.1	1.04E-03	0.69	1488
241-AP-108	0.047	49.5	9.49E-04	0.63	382
241-AP-105	0.019	20.5	9.27E-04	0.62	>1826
241-AN-102	0.012	14.5	8.51E-04	0.57	88
241-AN-107	0.012	16.7	7.41E-04	0.49	102
241-AP-101	0.026	35.0	7.36E-04	0.49	1680
241-AP-102	0.026	35.3	7.31E-04	0.49	806
241-AW-105	0.059	83.8	7.08E-04	0.47	>1826
241-AZ-101	0.007	10.5	7.00E-04	0.47	132
241-AP-103	0.015	30.2	4.86E-04	0.32	200
241-AW-103	0.030	62.2	4.83E-04	0.32	1101
241-AY-101	0.007	20.5	3.24E-04	0.22	667
241-AN-106	0.012	42.9	2.87E-04	0.19	459
241-AY-102	0.004	19.4	2.24E-04	0.15	118
241-AP-104	0.008	40.0	1.95E-04	0.13	797
241-AW-104	0.010	62.2	1.60E-04	0.11	544
241-AP-106	0.004	35.8	1.11E-04	0.07	558
241-T-203	0.006	54.7	1.07E-04	0.07	1278
241-AW-102	0.004	47.3	9.21E-05	0.06	>1826
241-AW-101	0.001	7.1	8.26E-05	0.06	238
241-B-204	0.006	72.6	8.08E-05	0.05	160
241-B-203	0.006	79.4	7.39E-05	0.05	145
241-AN-101	0.002	42.6	5.51E-05	0.04	364

Note: ¹ Data from *RPP-5926 Ammonia Evaluation.xls*, SVF-1549.

² TTLFL data for hypothetical zero ventilation case from main text (i.e., Revision 8 of this document).

³ 241-SY-101 ammonia liquid data taken before remediation by back-flush and dilution (PNNL-13933).

⁴ 241-SY-102 high ammonia concentration measured soon after 241-SY-101 transfer. Previous maximum measured in 1997 was only 0.005 kg-mole/m³.

NA = Not Applicable, steady-state flammable gas concentrations remain low through tank dome diffusion.

Data in Table C-3 are sorted from highest to lowest theoretical ammonia concentration. Tanks with equilibrium ammonia concentrations greater than 2% of the LFL have long TTLFLs. Highest theoretical concentrations are estimated for SX Farm; however, steady-state flammable gas concentrations remain low for SX and AX tanks by gaseous molecular diffusion through the tank domes. Ammonia data for 241-S-102 predates retrieval, and current concentrations would be only a fraction of the concentration shown in Table C-3. Ammonia data for 241-SY-101 predates remediation by flush and dilution, and current concentrations would be significantly lower.

Tanks 241-S-102, 241-A-101, 241-BY-106 and 241-S-101 have TTLFLs longer than 5 years. Tanks 241-U-103 and 241-U-105 have calculated ammonia equilibrium concentrations of 5.1%

of the LFL, but take more than 3 years to reach the LFL under hypothetical zero ventilation conditions. The tank with the shortest TTLFL with an equilibrium concentration higher than 2% of the LFL is 241-AN-103. However, it still takes a year to reach the LFL under hypothetical zero ventilation conditions, and has a calculated equilibrium ammonia concentration of only 2.4% of the LFL.

C3.3 AMMONIA MASS TRANSFER

This section examines limitations in reaching some of the peak concentrations shown in Table C-3.

C.3.3.1 Molecular Diffusion Through Waste Liquid

In the absence of mechanical agitation or convective movement, mass transfer is limited to molecular diffusion. Ammonia is produced predominantly in the waste liquid through degradation of organic complexants (RPP-21854). Ammonia transport is not possible through the tank shell, so there must be a bulk gradient within the non-convective waste layers with higher concentrations towards the tank bottom and lower concentrations towards the top.

It takes years for ammonia to molecularly diffuse through the liquid waste. This can be illustrated using tank 241-U-103. PNNL-13000 contains liquid ammonia measurements for several SST wastes. The data have considerable uncertainty and are heavily caveated but are sufficient to determine a time scale for molecular diffusion through non-convective waste layers. From PNNL-13000, ammonia concentration near the waste surface (segment 2) of tank 241-U-103 was about 0.0026 kg-mole/m³ and was about 0.084 kg-mole/m³ 57 inches (145 cm) deeper at segment 5.

Equation C-7 governs one-dimensional diffusion (assuming constant D, and negligible net flow):

$$D \frac{\partial^2 C}{\partial x^2} = \frac{\partial C}{\partial t} \quad (C-7)$$

Where

- D = diffusivity
- C = concentration
- x = length
- t = time

Diffusion is analogous to flow of heat in a solid and is expressed by the same partial differential equation [*Conduction of Heat in Solids* (Carslaw and Jaeger 2003)] with a few appropriate term substitutions:

$$K \frac{\partial^2 v}{\partial x^2} = \frac{\partial v}{\partial t} \quad (C-8)$$

Where

K = thermal conductivity
 v = temperature
 x = length
 t = time

Figure C-2 shows the temperature profile in Tank 241-U-103. Heat is generated throughout the waste layer and temperature profiles indicate conduction through the waste solids (non-convective layer). To simplify the analysis, temperature at the bottom is assumed to remain constant in the lower 100 inches of waste and the top of the waste layer is assumed to be an adiabatic boundary.

Figure C-2. Temperature Profile in Tank 241-U-103

Ammonia is also generated throughout the waste liquid, and generation is most likely highest towards the bottom where temperature is highest. For this analysis, ammonia concentration is assumed to remain constant in the lower 100 inches (through continued slow organic degradation) of the waste and mass transfer out of the top of the waste layer is assumed to stop.

This is a simplification of the scenario, because ammonia production would continue wherever liquid waste resides (including the top 59 inches). However, ammonia generation and release are slow relative to hydrogen generation and release (see Section C3.3.3).

Diffusion is analogous to heat flow in a solid of thickness l bounded by two parallel planes where one end is at a constant temperature and the other end is insulated (see Figure C-3).

Figure C-3. One-Dimensional Heat Conduction Analogy.

Carslaw and Jaeger (2003) give the solution shown in Equation C-9 for the boundary conditions where the end $x = 0$ is insulated and the end $x = l$ is kept at constant temperature V . The initial temperature in the slab is $f(x')$.

$$v = V + \frac{2}{l} \sum_{n=0}^{\infty} e^{-K(2n+1)^2 \pi^2 t / 4l^2} \cos \frac{(2n+1)\pi x}{2l} \left\{ \frac{2l(-1)^{n+1} V}{(2n+1)\pi} + \int_0^l f(x') \cos \frac{(2n+1)\pi x'}{2l} dx' \right\} \quad (\text{C-9})$$

The initial ammonia concentration in the waste liquid is assumed to vary linearly from V at segment 5 (i.e., $x = l$) to V_i at segment 2 (i.e., at $x = 0$), thus

$$f(x') = \frac{(V - V_i)}{l} x' + V_i$$

and the integration interval becomes

$$\frac{(V - V_i)}{l} \int_0^l x' \cos \frac{(2n+1)\pi x'}{2l} dx' + V_i \int_0^l \cos \frac{(2n+1)\pi x'}{2l} dx'$$

Integrating results in

$$\begin{aligned} & \frac{(V - V_i)}{l} \left[\frac{4l^2}{[(2n+1)\pi]^2} \cos \frac{(2n+1)\pi x'}{2l} + \frac{2lx}{(2n+1)\pi} \sin \frac{(2n+1)\pi x'}{2l} \right]_0^l \\ & + V_i \left[\frac{2l}{(2n+1)\pi} \sin \frac{(2n+1)\pi x'}{2l} \right]_0^l \end{aligned}$$

Evaluating the integral, $\sin(0) = 0$, $\cos(0) = 1$, $\sin \frac{(2n+1)\pi}{2} = (-1)^n$, and $\cos \frac{(2n+1)\pi}{2} = 0$, and Equation C-9 now becomes

$$\begin{aligned} v = V + \frac{2}{l} \sum_{n=0}^{\infty} e^{-K(2n+1)^2 \pi^2 t / 4l^2} \left[\cos \frac{(2n+1)\pi x}{2l} \right] & \left\{ \frac{2l(-1)^{n+1}V}{(2n+1)\pi} \right. \\ & + \frac{(V - V_i)}{l} \left[\frac{2l^2(-1)^n}{(2n+1)\pi} - \frac{4l^2}{[(2n+1)\pi]^2} \right] + V_i \left[\frac{2l(-1)^n}{(2n+1)\pi} \right] \Bigg\} \end{aligned} \quad (C-10)$$

The point of interest is at the insulated end (i.e., where $x = 0$), thus the cosine term is always equal to 1. With the cosine term equal to 1, l can be factored out and Equation C-10 simplifies to

$$\begin{aligned} v = V + 4 \sum_{n=0}^{\infty} e^{-K(2n+1)^2 \pi^2 t / 4l^2} & \left\{ \frac{(-1)^{n+1}V}{(2n+1)\pi} + (V - V_i) \left[\frac{(-1)^n}{(2n+1)\pi} - \frac{2}{[(2n+1)\pi]^2} \right] \right. \\ & + V_i \left[\frac{(-1)^n}{(2n+1)\pi} \right] \Bigg\} \end{aligned} \quad (C-11)$$

Dividing both sides by V , and recognizing that $C = v$, $C_0 = V$, $V_i = C_i$ and $K = D$; Equation C-11 after simplification becomes

$$\frac{C}{C_0} = 1 - 8 \sum_{n=0}^{\infty} \frac{(1 - C_i/C_0)}{(2n+1)\pi} e^{-D(2n+1)^2 \pi^2 t / 4l^2} \quad (C-12)$$

Table C-4 shows the liquid waste levels for tanks with hypothetical equilibrium ammonia headspace concentrations above 2 % of the LFL (excluding SX and AX Tanks that allow substantial flammable gas diffusion through the domes). Tank 241-U-103 has the shallowest liquid height at 60 inches (~152 cm). This tank will be used for illustration purposes because it has the shortest diffusion path length. Using Equation C-12 and the 241-U-103 data described earlier (i.e., $C_i = 0.0026 \text{ kg-moles/m}^3$, $C_0 = 0.084 \text{ kg-moles/m}^3$, and $l = 145 \text{ cm}$) and a diffusivity of $0.00002 \text{ cm}^2/\text{s}$ for ammonia in water (Perry's 1984) results in the plot shown in Figure C-4 (SVF-1560).

Table C-4. Waste Levels.*

Tank	Total Waste Level (inches)	Waste Liquid Level (inches)
241-A-101	127	127†
241-S-101	137	125†
241-U-105	137	101†
241-BY-106	168	84†
241-S-111	153	99†
241-SY-103‡	~268	~268
241-U-103	162	60†
241-S-103	93	92†
241-U-108	152	116†
241-A-103	140	140†
241-U-109	155	78†
241-U-106	76	72†
241-U-102	138	82†
241-SY-101	401	401
241-AN-103‡	~350	~348

Notes: * Data from PCSACS accessed 08/25/2008.

† Liquid level from neutron probe measurements.

‡ Tanks 241-SY-103 and 241-AN-103 waste levels fluctuate as buoyant displacement gas release events occur.

Examining Figure C-4, when mass transfer into the tank headspace is hypothetically stopped, ammonia concentration near the top of the liquid waste layer asymptotically approaches C_0 (the concentration at a depth of 145 cm). After one year, concentration at the top boundary (C) is only about 22% of C_0 and is only 45% of C_0 after five years. This helps explain the relatively low ammonia temporal variability observed in headspace measurements.

TTLFL results show that hydrogen and methane generation will bring headspace concentration to the LFL in the bounding tank (241-AZ-102) in about 52 days. From Table C-3, 14 tank headspaces reach the LFL in a year or less, with only 241-AN-104 having a calculated equilibrium ammonia concentration more than 2% of the LFL. Because the TTLFL interval of interest ranges from weeks to months, using maximum equilibrium ammonia concentrations in TTLFL calculations results in gross over-conservatism.

Figure C-4. Ammonia Concentration Change as a Function of Time

C3.3.2 Natural Convection

Waste configurations differ significantly between DSTs and SSTs. While SSTs have no or negligible supernatant layers, most DSTs have some waste solids at the bottom covered by a significant liquid waste layer. This leads to a temperature gradient between the bottom and top as observed in the two thermocouple trees for tank 241-SY-103 (Figure C-5). A simple check shows that natural convective heat transfer through the liquid waste layer exceeds conduction by several orders of magnitude.

The Nusselt number (Nu) is the ratio of convective to conductive heat transfer and can be calculated for a characteristic length. The average Nusselt number can be related to the Grashof and Prandtl numbers by an equation of the form (Kreith and Black 1980)

$$\overline{Nu}_f = C(Gr_f Pr_f)^n \quad (C - 13)$$

Where

f = subscript indicating physical properties at the average temperature

C = empirical constant

n = empirical exponential term

The Grashof number is given by (Kreith and Black 1980)

$$Gr = \frac{\beta g \rho^2 (T_s - T_\infty) L^3}{\mu^2} \quad (C - 14)$$

Where

β = volumetric thermal expansion coefficient, K^{-1}

g = gravitational constant, 9.8 m/s^2

ρ = density, kg/m^3

$T_s - T_\infty$ = temperature difference, K

L = characteristic length, m

μ = viscosity, Pa-s (kg/m-s)

Figure C-5. Temperature Profile in Tank 241-SY-103

The Prandtl number is given by (Kreith and Black 1980)

$$Pr = \frac{C_P \mu}{K} \quad (C - 15)$$

Where

C_P = specific heat, j/kg-K

K = thermal conductivity, watt/m-K

The average temperature within the convective layer is about 80 °F (300 K). Specific heat for water at 300 K is about 4180 j/kg-K (CRC 1980). Viscosity for the saturated liquid waste was estimated to be 1 to 10 cp (PNNL-11296). Thermal conductivity of water at 300 K is about 0.609 watt/m-K (CRC 1980). The Prandtl number is

$$Pr = \frac{\left(4180 \frac{\text{j}}{\text{kg-K}}\right) \left(0.005 \frac{\text{kg}}{\text{m-s}}\right)}{\left(0.609 \frac{\text{j}}{\text{s-m-K}}\right)} \approx 34$$

The volumetric thermal expansion coefficient for water at 300 K is 0.0002761 K^{-1} (CRC 1980). Density of the 241-SY-103 convective layer is about 1490 kg/m^3 (TWINS 2008). From Figure C-5, there is about a 7°F (4 K) temperature drop between the waste solids layer and the crust layer. The length from the top of the waste solids to the bottom of the crust layer is about 123 inches (3.12 m). Using these values, the Grashof number is

$$\text{Gr} = \frac{(0.0002761)(9.8)(1490)^2(4)(3.12)^3}{(0.005)^2} \approx 2.92 \times 10^{10}$$

The product GrPr is 9.9×10^{11} . For a geometry of a lower warm plate and an upper cool plate, C is 0.58 and $n=0.2$ (Kreith and Black 1980). The Nusselt number is then

$$\overline{\text{Nu}}_f = 0.58(1.0 \times 10^{12})^{0.2} \approx 145$$

Heat transfer through convection is about two orders of magnitude higher than conductive heat transfer suggesting the convective layer is well mixed. This is corroborated by other studies that examined DSTs (e.g., RPP-16841) and the temperature measurements which are fairly uniform through the liquid waste layer.

Convective mixing coupled with active ventilation results in the relatively low ammonia partial pressures shown in Table C-3 for DST wastes. Considerable time would be required to bring liquid ammonia concentrations up to the levels necessary to exert an ammonia partial pressure that contributed 2% to the LFL. For example, from Table C-1 the headspace concentration in the convectively mixed tank 241-AP-104 was 260 ppm in November 2000. Ventilation through this tank was maybe as high as $150 \text{ ft}^3/\text{min}$ and there were approximately 403 inches of waste. Assuming steady-state had been achieved, the ammonia generation rate to maintain this steady-state would have been approximately

$$\frac{\left(150 \frac{\text{ft}^3}{\text{min}}\right) \left(\frac{1 \text{ min}}{60 \text{ s}}\right) \left(\frac{1 \text{ m}^3}{35.3 \text{ ft}^3}\right) \left(\frac{0.00026 \text{ m}^3 \text{ of } \text{NH}_3}{1 \text{ m}^3}\right) \left(\frac{1 \text{ kg-mole of } \text{NH}_3}{22.4 \text{ m}^3 \text{ of } \text{NH}_3}\right)}{(403 \text{ inches}) \left(\frac{2750 \text{ gallons}}{1 \text{ inch}}\right) \left(\frac{1 \text{ m}^3}{264 \text{ gallons}}\right)} \approx 1.96 \times 10^{-10} \frac{\text{kg-moles of } \text{NH}_3}{\text{m}^3\text{-s}}$$

Using the data from Table C-3 and the estimated ammonia generation rate, it is possible to calculate how long it would take for ammonia to contribute 2% of the LFL (i.e., reach a partial pressure of 0.003 atm in the headspace) assuming zero ventilation. From Equation C-3, ammonia liquid waste concentration would need to increase from $0.008 \text{ kg-mole/m}^3$ to

$$\left(40.0 \frac{\text{kg-mole}}{\text{m}^3\text{-atm}}\right) (0.003 \text{ atm}) = 0.120 \frac{\text{kg-mole}}{\text{m}^3}.$$

Total waste volume in 241-AP-104 was about 4198 m^3 in November 2000. The kg-moles of ammonia accumulated in the waste would need to be

$$\left(0.120 \frac{\text{kg-mole}}{\text{m}^3} - 0.008 \frac{\text{kg-mole}}{\text{m}^3}\right) (4198 \text{ m}^3) \approx 470 \text{ kg-moles}.$$

The time required to generate the ammonia to reach a contribution of 2% LFL would be

$$\frac{470 \text{ kg} - \text{moles}}{(1.96 \times 10^{-10} \frac{\text{kg-moles of NH}_3}{\text{m}^3\text{-s}})(4198 \text{ m}^3)} \approx 5.7 \times 10^8 \text{ s or 18 years.}$$

Even if the ammonia generation rate in 241-AP-104 were an order of magnitude higher, it would still take close to two years for ammonia to contribute 2% of the LFL.

The only convectively mixed tanks with relatively high ammonia partial pressures are (in decreasing order) 241-SY-103, 241-SY-101, 241-AN-103 and 241-AN-104. Examining these tanks more closely, the reason for these exceptions becomes apparent; all have thick contiguous floating crust layers (23, 35, 35 and 16 inches, respectively). Tank 241-SY-101 had a floating crust layer when the liquid ammonia concentration was measured, but has since been remediated.

Convective mixing keeps temperatures and ammonia concentrations fairly uniform through the waste liquid, however, temperature trends show a linear decrease through the crust layer. Although mass transfer through the liquid layer would be relatively fast, the floating crust provides a barrier to convective mass transfer. About 96% of the crust (RPP-6655) is below the liquid surface so heat (and mass) transfer through this region is by conduction (diffusion for mass).

Crusts are a mixture of solids, liquid and gas. Ammonia must diffuse through the connected porosity which would have to be considerably more tortuous than the simple diffusion presented in Section C3.3.1. Effective diffusivity through the brine laden crust (or non-convective waste for that matter) would likely be more than an order of magnitude lower than the diffusivity of ammonia through water. It would take years for headspace concentrations to reach equilibrium concentrations in the tanks with floating crust layers.

C3.3.3 Mechanical Mixing

Mechanical mixing does occur to a limited extent, with the most significant mechanism being buoyant displacement gas release events (BDGREs) in a few DSTs. BDGREs occur in tanks 241-SY-103, 241-AN-103, 241-AN-104, 241-AN-105 and 241-AW-101. In a BDGRE, a portion, or “gob,” of the non-convective layer accumulates gas until it becomes sufficiently buoyant to overcome the weight and strength of material restraining it. At that point, it suddenly breaks away and rises through the convective layer. The trapped gas bubbles expand as the gob rises, failing the surrounding material and disturbing the crust layer, so a portion of the gas can escape from the gob into the headspace.

BDGREs mechanically mix a portion of the crust layer; however, they occur infrequently (currently about every six months for 241-SY-103) and are relatively small (releasing just a few cubic meters of gas). Before remediation, Tank 241-SY-101 use to have vigorous BDGREs that would involve six to eight gobs that significantly mixed the crust layer. BDGREs in the other tanks disturb only a fraction of the floating crust layer and are short duration lasting hours to a couple of days. Therefore, BDGREs would not significantly decrease the time required to reach ammonia equilibrium concentration.

Tanks not subject to BDGREs also generate non-condensable gasses (predominately hydrogen), but the gas percolates through waste solids at about the same rate it is generated. Gas percolation could slightly increase mixing through liquid saturated solid layers, but gas generation is slow and this effect would be small.

Some DSTs (e.g., 241-AY-102) have had caustic additions which might increase supernatant densities above that of the solid's interstitial liquid. Analysis (RPP-29464) suggests that such density gradients might lead to porous media convection. Ammonia is retained in the waste liquid the bulk of which is supernatant in DSTs. Porous media convection would have a negligible effect on ammonia release from DST wastes.

C4.0 ANALYSIS

Data in Section C.3.1.1 show that ammonia headspace concentrations under normal operating conditions are low with only 3 of the 127 tanks measured reaching more than 1% of the LFL, and all were below 2% of the LFL. Statistical analysis of ammonia headspace data indicate that concentrations are only modestly influenced by the slowly changing tank conditions.

Only during waste disturbing activities discussed in Section C.3.1.2 did headspace concentrations exceed 2% of the LFL, and then only in a limited number of tanks that contained high liquid ammonia concentrations. Elevated ammonia concentrations during waste disturbing activities are only temporary and relatively short compared to calculated TTLFLs and the mass transport limitations discussed in Section C3.3.

Liquid ammonia concentrations can be considerable in the wastes, and calculations performed in Section C3.2.3 show that hypothetical headspace maximums might be significant. Once tanks that have low flammability ensured by gaseous diffusion through tank domes (i.e., the AX and SX tanks) and 241-S-102 and 241-SY-101 are eliminated, then only 16 tanks had theoretical maximum concentrations greater than 2% of the LFL. Analyses in Section C3.3 suggest limits on how quickly maximum concentration could be reached. Molecular diffusion requires years for ammonia to move through non-convective waste layers.

Most DST liquid wastes exert low ammonia vapor pressures because mass transport through the convective layers is relatively fast. If ventilation were stopped, it would take many years to accumulate sufficient ammonia in the waste liquid to significantly increase headspace flammability. DSTs with ammonia equilibrium vapor pressures greater than 2% of the LFL all have floating crust layers. Although convective mass transfer through the liquid layer is fast, floating crusts provide a barrier to convection. Ammonia must diffuse through the connected porosity within the floating crusts. Time spans to reach these higher equilibrium concentrations are beyond the weeks to months of interest in TTLFL calculations. The use of maximum equilibrium ammonia concentrations in TTLFL calculations results in gross over-conservatism.

A reasonably conservative ammonia flammability contribution would be a value slightly higher than the maximum concentration measured under quiescent conditions. The maximum measured under quiescent conditions was 1.67% of the LFL in Tank 241-U-103. Starting TTLFL calculations at 2% of the LFL would be a reasonably conservative representation of ammonia flammability. This remains a reasonably conservative assumption even as wastes are moved from SSTs to DSTs and among the DSTs. Interim stabilization already moved most of the high ammonia producing liquid waste into the DSTs and ammonia generation should continue to decrease as wastes are mixed and decay power decreases.

C5.0 CONCLUSIONS

The previous ammonia flammability methodology required steady-state ammonia concentrations, headspace ventilation rates, and ammonia liquid concentrations to be known simultaneously for current conditions. These data are not routinely collected and the available data in some cases do not accurately reflect current waste tank conditions. This appendix demonstrates that a reasonably conservative single value can be added to TTLFL calculations to account for ammonia contribution to total flammability. Starting TTLFL calculations at 2% of the LFL is a reasonably conservative representation of ammonia contribution to flammability.

C6.0 REFERENCES

- Carslaw, H. S., and J. C. Jaeger, 2003, *Conduction of Heat in Solids*, Second Edition, Oxford University Press, Oxford, United Kingdom.
- Clegg, S. L., and P. Brimblecombe, 1989, *Journal of Physical Chemistry*, Vol. 93, pg. 7237.
- CRC, 1980, *Handbook of Chemistry and Physics*, 61st Edition, CRC Press, Inc., Boca Raton, Florida.
- Kreith, F. and W. Z. Black, 1980, *Basic Heat Transfer*, Harper & Row, Publishers, Inc., New York, New York.
- Perry, R. H. and D. W. Green, 1984, *Perry's Chemical Engineers' Handbook*, Sixth Edition, McGraw-Hill Book Company, New York, New York.
- PNNL-13000, 1999, *Retained Gas Sampling Results for the Flammable Gas Program*, Rev. 0, Pacific Northwest National Laboratory, Richland, Washington.
- PNNL-13933, 2002, *Review of the Technical Basis of the Hydrogen Control Limit for Operations in Hanford Tank Farms*, Rev. 1, Pacific Northwest National Laboratory, Richland, Washington.
- RPP-4941, 2000, *Methodology for Predicting Flammable Gas Mixtures in Double-Contained Receiver Tanks*, Rev. 0-B, CH2M HILL Hanford Group, Inc., Richland, Washington.

- RPP-6655, 2000, *Data Observations on Double-Shell Flammable Gas Watch List Tank Behavior*, Rev. 0, CH2MHILL Hanford Group, Inc., Richland, Washington.
- RPP-7771, 2001, *Flammable Gas Safety Issue Resolution*, Rev. 0A, CH2M HILL Hanford Group, Inc., Richland, Washington.
- RPP-16841, 2003, *Engineering Evaluation of 241-C-106 Waste Transfer into Tank 241-AN-106*, Rev. 0, CH2M HILL Hanford Group, Inc., Richland, Washington.
- RPP-21854, 2004, *Occurrence and Chemistry of Organic Compounds in Hanford Site Waste Tanks*, Rev. 0, CH2M HILL Hanford Group, Inc., Richland, Washington.
- RPP-21972, 2006, *Statistical Analysis of Tank Headspace Vapor Data*, Rev. 1, CH2M HILL Hanford Group, Inc., Richland, Washington.
- RPP-29464, 2006, *Caustic Dynamic Mixing Analysis for Tank 241-AY-102*, Rev. 0, CH2M HILL Hanford Group, Inc., Richland, Washington.
- SVF-1549, 2008, *RPP-5926 Ammonia Evaluation*, v1.0, Washington River Protection Solutions, Richland, Washington.
- SVF-1560, 2008, *RPP-5926 Figure C-4*, v1.0, Washington River Protection Solutions, Richland, Washington.
- Tank Waste Information Network (TWINS), Queried 08/14/2008,
<http://twins.pnl.gov/twins.htm>.
- Weisenberger, S., and A. Schumpe, 1996, "The Estimation of Gas Solubilities in Salt Solutions at Temperature from 273 K to 363 K," *AIChE Journal*, Vol. 42, pg. 299.

APPENDIX D
PEER REVIEW CHECKLIST

Calculation Review ChecklistCalculation Reviewed: RPP-5926 Revision 8Scope of Review: Entire document
(e.g., document section or portion of calculation)Engineer/Analyst: J. E. Meacham Date: November 17, 2008Organizational Manager: N. W. Kirch Date: November 17, 2008This document consists of 91 pages and the following attachments (if applicable):

Yes No NA*

☒	☐	☐	1.	Analytical and technical approaches and results are reasonable and appropriate.
☒	☐	☐	2.	Necessary assumptions are reasonable, explicitly stated, and supported.
☒	☐	☐	3.	Ensure calculations that use software include a paper printout, microfiche, CD-ROM, or other electronic file of the input data and identification to the computer codes and versions used, or provide alternate documentation to uniquely and clearly identify the exact coding and execution process.
☒	☐	☐	4.	Input data were checked for consistency with original source information.
☐	☐	☒	5.	Key input data (e.g., dimensions, performance characteristics) that may affect equipment design is identified.
☒	☐	☐	6.	For both qualitative and quantitative data, uncertainties are recognized and discussed and the data is presented in a manner to minimize design interpretations.
☒	☐	☐	7.	Mathematical derivations were checked, including dimensional consistency of results.
☒	☐	☐	8.	Calculations are sufficiently detailed such that a technically qualified person can understand the analysis without requiring outside information.
☒	☐	☐	9.	Software verification and validation are addressed adequately.
☒	☐	☐	10.	Limits/criteria/guidelines applied to the analysis results are appropriate and referenced. Limits/criteria/guidelines were checked against references.
☒	☐	☐	11.	Conclusions are consistent with analytical results and applicable limits.
☒	☐	☐	12.	Results and conclusions address all points in the purpose.
☒	☐	☐	13.	Referenced documents are retrievable or otherwise available.
☒	☐	☐	14.	The version or revision of each reference is cited.
☒	☐	☐	15.	The document was prepared in accordance with TFC-ENG-DESIGN-C-10 Attachment A, "Calculation Format and Preparation Instructions."
☒	☐	☐	16.	Impacts on requirements have been assessed and change documentation initiated to incorporate revisions to affected documents, as appropriate.
☒	☐	☐	17.	All checker comments have been dispositioned and the design media matches the calculations.

J. M. Conner
Checker (printed name and signature)

11/17/08
Date

5. Calculations do not involve equipment design.