

Evaluation of the Temporary Tent Cover Truss System, AP Primary Vent System

M. A. Haq

Washington River Protection Solutions LLC

Richland, WA 99352

U.S. Department of Energy Contract DE-AC27-08RV14800

EDT/ECN: 823438

UC: N/A

Cost Center: 7G110

Charge Code: 200065

B&R Code: N/A

Total Pages: 26


Key Words: AP tank farms, Central Exhaust Station Enclosure, Tent Cover, Tubular Truss System

Abstract: The purpose of this calculation is to evaluate a temporary tent cover truss system. This system will be used to provide weather protection to the workers during replacement of the filter for the Primary Ventilation System in AP Tank Farm. The truss system has been fabricated utilizing tubes and couplers, which are normally used for scaffoldings.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

J.E. Fot
Release Approval

12-31-2009
Date



Release Stamp

Approved For Public Release

Calculation Review Checklist.

Calculation Reviewed: RPP-CALC-44193 R0

Scope of Review: Entire Calculations
(e.g., document section or portion of calculation)

Engineer/Analyst: M. A. Haq *M.A. Haq* Date: 12/30/09

Organizational Manager: M. A. Roberts *M.A. Roberts* Date: 12/30/2009

This document consists of 10 pages and the following attachments (if applicable):

ATTACH. A: Photos of Tent Cover Truss System

ATTACH B: Sketch for the Tent Cover truss System

ATTACH C: Field Sketch for Typical Tent Cover Truss

ATTACH D: Density of Snow Cover Info.]

ATTACH E: Alternate Calc. to verify the Strl Integrity of the Truss System during Hoisting & Rigging

Yes No NA*

- | | | | |
|-------------------------------------|--------------------------|-------------------------------------|---|
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 1. Analytical and technical approaches and results are reasonable and appropriate. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 2. Necessary assumptions are reasonable, explicitly stated, and supported. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 3. Ensure calculations that use software include a paper printout, microfiche, CD-ROM, or other electronic file of the input data and identification to the computer codes and versions used, or provide alternate documentation to uniquely and clearly identify the exact coding and execution process. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 4. Input data were checked for consistency with original source information. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 5. Key input data (e.g., dimensions, performance characteristics) that may affect equipment design is identified. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 6. For both qualitative and quantitative data, uncertainties are recognized and discussed and the data is presented in a manner to minimize design interpretations. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 7. Mathematical derivations were checked, including dimensional consistency of results. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 8. Calculations are sufficiently detailed such that a technically qualified person can understand the analysis without requiring outside information. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 9. Software verification and validation are addressed adequately. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 10. Limits/criteria/guidelines applied to the analysis results are appropriate and referenced. Limits/criteria/guidelines were checked against references. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 11. Conclusions are consistent with analytical results and applicable limits. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 12. Results and conclusions address all points in the purpose. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 13. Referenced documents are retrievable or otherwise available. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 14. The version or revision of each reference is cited. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 15. The document was prepared in accordance with Attachment A, "Calculation Format and Preparation Instructions." |
| <input type="checkbox"/> | <input type="checkbox"/> | <input checked="" type="checkbox"/> | 16. Impacts on requirements have been assessed and change documentation initiated to incorporate revisions to affected documents, as appropriate. |
| <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | 17. All checker comments have been dispositioned and the design media matches the calculations. <u>or notation has been added</u> |

T.S. Mackey *T.S. Mackey* 12/30/09
Checker (printed name and signature) Date

* If No or NA is chosen, an explanation must be provided on or attached to this form.

Item 16: No impact to requirements and no change documentation is required.

ANALYTICAL COMPUTATIONS

RPP-CALC-44193, R0

Subject: Evaluation of the Temporary Tent Cover Truss System, AP Primary Vent. System

Originator: M. A. Haq *M.A. Haq*

Date: 12/22/09

Checker: TC Mackey

Date: 12/30/09

Organizational Mgr.: M A. Roberts *M.A. Roberts*

Date: 12/30/2009

1.0 Objective/Purpose:

The purpose of this calculation is to evaluate the tent cover truss system (see Attach. A for the photos of this system). This system will be used to provide weather protection to the workers during replacement of the filter for the Primary Ventilation System in AP Tank Farm. The truss system has been fabricated utilizing tubes and couplers, which are normally used for scaffoldings. This system, presently located near the Primary Ventilation System, consists of 23 feet wide wide trusses, with their bottom chord members extending 26 feet wide, and is 36 feet long (see Attach. B for the field dimensions of the typical truss). This truss system will be lifted from the ground, and placed on top of the concrete walls of Central Exhaust Station Enclosure (see drawings H-2-90456, and H-2-90457, Sh 1 for the enclosure), as a temporary roof structure. The shorter side of the truss system, 23 feet wide, will be sitting on the east-west concrete walls (see Plan, dwg H-2-90456 for concrete walls, located with dimension of 23'-3", outer face of east wall to outer face of west wall). The truss system will overhang approximately 8' - (9-1/2)" beyond the south wall. The overhang portion of the truss system will be supported on two posts. The arrangement of the truss support system has been shown in Attach. B. Once installed, the truss system will be covered with tarp, for weather protection.

2.0 Results/Conclusions:

This is a temp tent. RPP-7933 only requires 55 mph. Conc. block sizes are only recommended but not required.
~~The truss support assembly meets the requirements for natural phenomena hazards loads in accordance with TFC-ENG-STD-06 (Ref. 3) for PC-1 structure. However, the temporary truss system is restricted for snow loading (up to 3/8" thick fresh snow). The truss system has to be cleared off snow, if snow exceeds more than 3/8". The tarp, covering the truss system, has not been evaluated for wear and tear due to snow or ice loadings.~~

No seismic analysis has been performed, since this is a temporary structure. Moreover, based on engineering judgement, it is expected that wind loading will govern.

Alternate calculations have been done to check the integrity of the truss system framing (see Attach E).

Add clamps over the horizontal member couplings (where the tubular members are connected to each other). The truss system can be lifted by using the following two options:

- Use four pick points on east and west sides of the truss system.
- In case two interior pick points are used for lifting, add bracings (as shown on the Sketch on pg E-3). Double clamp the added bracings or use double bracings.

3.0 Input Data:

- Dimensions of the truss system were obtained from the field (See Attach. C). The components of the truss system consist of 2" diameter tubes, and couplers, normally used by Safway Scaffoldings.
- Tent Cover Truss System weight is 3100 lbs. This weight was taken in the field by lifting the truss system from the ground, using a dynamometer. If proposed bracings, as shown on the Sketch on pg. E-3 are added, it will add approximately 400 lbs to the truss system.
- The truss system assembly has been analyzed as PC-1 per TFC-ENG-STD-06 (Ref. 3). *for wind only.*

can 12/30/09

Subject: Evaluation of the Temporary Tent Cover Truss System, AP Primary Vent. System

Originator: M. A. Haq *M. A. Haq* Date: 12/22/09

Checker: TC Mackey Date: 12/30/09

Organizational Mgr.: M. A. Roberts *M. A. Roberts* Date: 12/30/2009

4.0 Assumptions:

None

5.0 Method of Analysis

Manual calculations are used for this analysis using MathCAD. The truss system is analyzed for wind loading per ASCE 7-05 (Ref. 1)

Design Wind Force

The wind loads are determined from ASCE 7-05 (Ref. 1) Method 1, Simplified Procedure.

$V = 85$ mph (Table 3, Ref. 3)

Evaluation of the Truss System

a). Evaluation of the Truss System Portion Positioned on the Concrete Walls

Slope of the roof truss (based on $\tan = 4'-0''/11'-6''$ from Attach. B) = 18.8 degrees

Using Fig. 6-2, pg 37 (Ref. 1), the maximum wind force in the longitudinal direction for a wind velocity of 85 mph, with angle roof of 20 degrees, Zone E (vertical pressure) is 13.8 psf. Note: Fig. 6.2 is based on a structure height of 30 feet, however the adjustment factor λ for this height, according to table on pg 40 of Ref. 1 is 1.

$w_1 := 13.8 \cdot \text{psf}$ Uplift pressure on the truss system

$L_1 := 27 \cdot \text{ft}$ Length of truss system

$L_2 := 36 \cdot \text{ft}$ Total length of the truss system

$W_1 := 23 \cdot \text{ft}$ Width of the truss system

$U_1 := w_1 \cdot L_1 \cdot W_1$ Total uplift force on the truss system

$U_1 = 8.57 \times 10^3 \text{ lbf}$

$w_{\text{truss}} := 3100 \cdot \text{lbf}$ Total weight of the truss system.

$w_{\text{truss1}} := w_{\text{truss}} \cdot \frac{L_1}{L_2}$ Weight of truss system, positioned on the concrete walls. Note: 27 feet length of truss system is being supported on concrete walls

$w_{\text{truss1}} = 2.325 \times 10^3 \text{ lbf}$

$U_{\text{net1}} := U_1 - w_{\text{truss1}}$ Net uplift on the truss system (positioned on the concrete walls)

$U_{\text{net1}} = 6.245 \times 10^3 \text{ lbf}$

ANALYTICAL COMPUTATIONS

RPP-CALC-44193, R0

Subject: Evaluation of the Temporary Tent Cover Truss System, AP Primary Vent. System

Originator: M. A. Haq *M.A. Haq*

Date: 12/22/09

Checker: TC Mackey

Date: 12/30/09

Organizational Mgr.: M. A. Roberts *M.A. Roberts*

Date: 12/30/2009

$$U_{\text{concblock1}} := \frac{U_{\text{net1}}}{4}$$

Uplift on each concrete block. Each corner of the truss system, positioned on the concrete walls, is to be tied with a a concrete block on the ground, using a guy wire or rope.

$$U_{\text{concblock1}} = 1.561 \times 10^3 \text{ lbf}$$

$$w_{\text{concblock1}} := 3600 \cdot \text{lbf}$$

Weight of the concrete block, 2' x 6' x 2' (depth)

$$w_{\text{concblock1}} > U_{\text{concblock1}}$$

Okay

$$F_{\text{sliding1}} := U_{\text{concblock1}}$$

Horizontal sliding force, assuming that the guy wire from the truss system is attached to the concrete block at 45 degrees.

$$\mu_{\text{concrblock1}} := 0.5$$

Coefficient of friction between concrete block and gravelled surface (see pg C-3, Ref. 2)

$$F_{\text{resist1}} := \mu_{\text{concrblock1}} \cdot w_{\text{concblock1}}$$

Frictional force resisting sliding force

$$F_{\text{resist1}} = 1.8 \times 10^3 \text{ lbf}$$

$$F_{\text{resist1}} > F_{\text{sliding1}}$$

Okay

Use Concrete Block, 2' x 6' x 2' *2.5 x 5 x 2.5* *WT Resist = 1561 x (1561 x 2) = 4683[#]*

Sizing concrete block size, in case the concrete block has to be positioned up to 45 degrees from its position to avoid interferences on the grade

12/30/09

$$U_{\text{concblock3}} := U_{\text{concblock1}} \cdot \frac{1}{\cos(45 \cdot \text{deg})}$$

Net uplift from the truss system on the concrete block, in case it is orientated 45 degrees in the plan from its position *Uplift is the same as above*

$$U_{\text{concblock3}} = 2.208 \times 10^3 \text{ lbf}$$

Weight of the concrete block, 2.5' x 5' x 2.5' *12/30/09*

$$w_{\text{concblock3}} := 4600 \cdot \text{lbf}$$

$$w_{\text{concblock3}} > U_{\text{concblock3}}$$

Okay

$$F_{\text{sliding3}} := U_{\text{concblock3}}$$

Horizontal sliding force, assuming that the guy wire from the truss system is attached to the concrete block at 45 degrees.

$$\mu_{\text{concrblock3}} := 0.5$$

Coefficient of friction between concrete block and gravelled surface (see pg C-3, Ref. 2)

ANALYTICAL COMPUTATIONS

RPP-CALC-44193, R0

Subject: Evaluation of the Temporary Tent Cover Truss System, AP Primary Vent. System

Originator: M. A. Haq *M.A. Haq* **Date:** 12/22/09

Checker: TC Mackey **Date:** 12/30/09

Organizational Mgr.: M A. Roberts *M.A. Roberts* **Date:** 12/30/09

$$F_{\text{resist}3} := \mu_{\text{concrblock}3} \cdot W_{\text{concrblock}3}$$

Frictional force resisting sliding force

$$F_{\text{resist}3} = 2.3 \times 10^3 \text{ lbf}$$

$$F_{\text{resist}3} > F_{\text{sliding}1}$$

Okay

Use Concrete Block, 2.5' x 5' x 2.5, in case the concrete block has to be rotated up to 45 degrees (in the plan) to miss interferences on the grade (see Sketch on pg B-2 for conc. blocks, 4600 lbs).

Check Size of Guy Wire

Guy wire or rope will be attached from each corner of the truss system (positioned on the walls) to the concrete blocks as shown in Attach. B.

$$P_{\text{wire}} := \frac{U_{\text{concrblock}3}}{\sin(45\text{-deg})}$$

Tension force on the wire

$$P_{\text{wire}} = 3.122 \times 10^3 \text{ lbf}$$

$$P_{\text{capacity}} := 10.7 \cdot 2 \cdot \text{kip}$$

Tensile capacity of 1/2" ϕ , 6 x 19 Fiber Core Wire Rope (See pg A-13, Ref.2)

$$\text{FOS}_{\text{wire}} := \frac{P_{\text{capacity}}}{P_{\text{wire}}}$$

$$\text{FOS}_{\text{wire}} = 6.854$$

Okay

Use 1/2" ϕ , 6 x 19 Fiber Core Wire Rope or equivalent wire rope, with a minimum breaking strength or capacity of 10 kips

b. Evaluation of the Truss System portion, positioned on the Posts

Using figure 6-2, pg 37 (Ref. 1), the maximum wind force in longitudinal direction for wind velocity of 85 mph, with angle roof 20 degrees, Zone E (vertical pressure) is 13.8 psf.

$$w_{\text{up}} := 13.8 \cdot \text{psf}$$

Uplift force on the truss system

$$L_3 := 9 \cdot \text{ft}$$

Length of truss system

$$L_{\text{total}} := 36 \cdot \text{ft}$$

Total length of the truss system

$$W_{\text{truss}} := 23 \cdot \text{ft}$$

Width of the truss system

ANALYTICAL COMPUTATIONS

RPP-CALC-44193, R0

Subject: Evaluation of the Temporary Tent Cover Truss System, AP Primary Vent. System

Originator: M. A. Haq *M.A. Haq*

Date: 12/22/09

Checker: TC Mackey

Date: 12/30/09

Organizational Mgr.: M A. Roberts *M.A. Roberts*

Date: 12/30/2009

$$U_2 := w_1 \cdot L_3 \cdot W_1$$

Total uplift force on the truss system

$$U_2 = 2.857 \times 10^3 \text{ lbf}$$

$$w_{\text{truss2}} := 3100 \cdot \text{lbf}$$

Total weight of the truss system.

$$w_{\text{truss2}} := w_{\text{truss}} \cdot \frac{L_3}{L_2}$$

Weight of truss system, supported by the posts.
Note: 9 feet length of truss system is being supported by the two posts

$$w_{\text{truss2}} = 775 \text{ lbf}$$

$$U_{\text{net2}} := U_2 - w_{\text{truss2}}$$

Net uplift on the truss system (supported on the posts)

$$U_{\text{net2}} = 2.082 \times 10^3 \text{ lbf}$$

$$U_{\text{concblock2}} := \frac{U_{\text{net2}}}{4}$$

Uplift on each concrete block. Each corner of the truss system, positioned on the concrete walls, is to be tied with a a concrete block on the ground, using a guy wire or rope.

$$U_{\text{concblock2}} = 520.4 \text{ lbf} \quad \checkmark$$

Weight of the concrete block, 3' x 3' x 1 (depth)

$$w_{\text{concblock2}} := 1350 \cdot \text{lbf}$$

$$w_{\text{concblock2}} > U_{\text{concblock2}}$$

Okay

$$F_{\text{sliding2}} := U_{\text{concblock2}}$$

Horizontal sliding force, assuming that the guy wire from the truss system is attached to the concrete block at 45 degrees.

$$\mu_{\text{concrblock2}} := 0.5$$

Coefficient of friction between concrete block and gravelled surface (see pg C-3, Ref.)

$$F_{\text{resist2}} := \mu_{\text{concrblock2}} \cdot w_{\text{concblock2}}$$

Frictional force resisting sliding force

$$F_{\text{resist2}} = 675 \text{ lbf}$$

$$F_{\text{resist2}} > F_{\text{sliding2}}$$

Okay

Use Concrete Block, 3' x 3' x 1' ^{1350 #} + 200 #

$$WT. Req'd = 520 + (520 \times 2) = 1560 \#$$

TCM 12/30/09

Check Post for supporting the Truss System (see Attach B)

ANALYTICAL COMPUTATIONS

RPP-CALC-44193, R0

Subject: Evaluation of the Temporary Tent Cover Truss System, AP Primary Vent. System**Originator:** M. A. Haq *M.A. Haq*

Date: 12/22/09

Checker: TC Mackey

Date: 12/30/09

Organizational Mgr.: M A. Roberts *M.A. Roberts*

Date: 12/30/2009

Try tubular size 2" ϕ (normally used by Safway Scaffolding)Properties of tubular post 2" ϕ (See pg A-12, Ref. 2):

$$A_{\text{post}} := 0.75 \cdot \text{in}^2$$

Area of the post

$$I_{\text{post}} := 0.29 \cdot \text{in}^4$$

Moment of inertia of the post

$$S_{\text{post}} := .310 \cdot \text{in}^3$$

Section modulus of the post

$$r_{\text{post}} := \sqrt{\frac{I_{\text{post}}}{A_{\text{post}}}}$$

Radius of gyration of the post

$$r_{\text{post}} = 0.622 \text{ in}$$

$$L_{\text{post}} := 8 \cdot \text{ft} + 3 \cdot \text{in}$$

Height of the post

$$K_{\text{post}} := 1$$

Effective length factor of post, pg 3-5, Ref. 4

$$F_y := 36 \cdot \text{ksi}$$

Yield stress of steel

$$E := 29 \cdot 10^3 \cdot \text{ksi}$$

Elastic modulus of steel

$$SL_{\text{post}} := \frac{K_{\text{post}} \cdot L_{\text{post}}}{r_{\text{post}}}$$

Effective slenderness ratio of the post

$$\frac{K_{\text{post}} \cdot L_{\text{post}}}{r_{\text{post}}} = 159.209$$

$$C_c := \sqrt{\frac{2 \cdot \pi^2 \cdot E}{F_y}}$$

$$C_c = 126.099$$

ANALYTICAL COMPUTATIONS

RPP-CALC-44193, R0

Subject: Evaluation of the Temporary Tent Cover Truss System, AP Primary Vent. System

Originator: M. A. Haq *M. A. Haq*

Date: 12/22/09

Checker: TC Mackey

Date: 12/30/09

Organizational Mgr.: M. A. Roberts *M. A. Roberts*

Date: 12/30/2009

$$\frac{K_{\text{post}} \cdot L_{\text{post}}}{r_{\text{post}}} > C_c$$

$$F_a := \frac{12 \cdot \pi^2 \cdot E}{23 \cdot \left(\frac{K_{\text{post}} \cdot L_{\text{post}}}{r_{\text{post}}} \right)^2}$$

Allowable Axial Stress per Eq E2-2,
pg 5-42, Ref. 4

$$F_a = 5.891 \times 10^3 \text{ psi}$$

Load on the post

$$w_{\text{tarp}} := 500 \cdot \text{lbf}$$

Assume weight of the tarp on truss

$$w_{\text{truss}} := 3100 \cdot \text{lbf}$$

Weight of truss

$$w := w_{\text{truss}} + w_{\text{tarp}}$$

Total weight of the truss system

$$P_{\text{deadload}} := \left(w \cdot \frac{L_3}{L_1} \cdot \frac{1}{2} \right) \cdot \frac{1}{2}$$

Dead load on the post

$$P_{\text{deadload}} = 300 \text{ lbf}$$

$$W_{\text{snow}} := 20 \cdot \text{psf}$$

Snow load, Sect. 3.5.2, Ref. 3

$$P_{\text{snow}} := \left(\frac{W_{\text{snow}} \cdot L_3 \cdot W_1}{2} \right) \cdot \frac{1}{2}$$

Snow load on the post

$$P_{\text{post}} := P_{\text{deadload}} + P_{\text{snow}}$$

Total load on the post

$$P_{\text{post}} = 1.335 \times 10^3 \text{ lbf}$$

$$f_a := \frac{P_{\text{post}}}{A_{\text{post}}}$$

Axial Stress on the post

$$f_a = 1.78 \times 10^3 \text{ psi}$$

$$F_a > f_a$$

Okay

Use Tubular or Pipe with 2" ϕ

Subject: Evaluation of the Temporary Tent Cover Truss System, AP Primary Vent. System

Originator: M. A. Haq *M.A. Haq* Date: 12/22/09

Checker: TC Mackey Date: 12/30/09

Organizational Mgr.: M A. Roberts *M.A. Roberts* Date: 12/30/2009

Evaluation of the Typical Truss for Snow Loading

There are 10 trusses in the truss system, spaced at 4 feet c/c, as shown on the sketch on pg. B-2

$$w_{\text{truss3}} := \frac{w}{9} \quad \text{Weight of a typical truss}$$

$$R_{\text{truss}} := \frac{w_{\text{truss3}}}{2} \quad \text{Reaction at the truss support for a typical truss}$$

$$R_{\text{truss}} = 200 \text{ lbf}$$

$$W_1 = 23 \text{ ft} \quad \text{Width of a truss}$$

$$h_1 := 4 \cdot \text{ft} \quad \text{Height of the truss}$$

$$S_{\text{truss}} := \left(\frac{h_1}{\frac{W_1}{2}} \right) \quad \text{Slope of the truss}$$

$$S_{\text{truss}} = 0.348$$

$$\theta_{\text{truss}} := 19.2 \quad \text{Slope of the truss in degrees}$$

$$F_{\text{top.chord}} := \frac{R_{\text{truss}}}{\sin(\theta_{\text{truss}} \cdot \text{deg})} \quad \text{Force in the top chord of truss (at the end of truss)}$$

$$F_{\text{top.chord}} = 608.149 \text{ lbf}$$

$$F_{\text{bot.chord}} := F_{\text{top.chord}} \cdot \cos(\theta_{\text{truss}} \cdot \text{deg}) \quad \text{Force in the bottom chord}$$

$$F_{\text{bot.chord}} = 574.322 \text{ lbf}$$

The bottom chords of trusses, made of 2" diameter Safway tubular members is clamped with typical Safway clamps. These clamps, CRA-19 and CSA-19, have been rated with 1000 lbs load for new clamps, as shown on pg B-2., Ref 2. Peter Elsabally, Safway Scaffolding (1-206-523-6560), suggested downgrading it (with a .75 factor) for used clamps. The bottom chord at its clamped location needs to be checked for its structural integrity, since this will be the weakest link.

$$P_{\text{clamp}} := 0.75 \cdot 1000 \cdot \text{lbf}$$

ANALYTICAL COMPUTATIONS

RPP-CALC-44193, R0

Subject: Evaluation of the Temporary Tent Cover Truss System, AP Primary Vent. System

Originator: M. A. Haq *M.A. Haq* **Date:** 12/22/09

Checker: TC Mackey **Date:** 12/30/09

Organizational Mgr: M A. Roberts *M.A. Roberts* **Date:** 12/30/2009

$$P_{\text{clamp}} = 750 \text{ lbf}$$

$$P_{\text{clamp}} > F_{\text{bot.chord}} \quad \text{Okay}$$

$$d_{\text{snow}} := 550 \cdot \frac{2.20}{3.281^3}$$

Density of firm snow (550 kg per cubic meter, see Attach. D)

Note: 1 kg = 2.20 lbs, 1 meter = 3.281 feet

$$d_{\text{snow}} = 34.258$$

Density of snow in lbs per cu ft

$$w_{\text{firm.snow}} := \frac{d_{\text{snow}}}{12} \cdot \left(\frac{3}{8}\right)$$

Weight of snow (assuming 3/8" thick) on the truss in psf

$$w_{\text{firm.snow}} = 1.071$$

$$R_{\text{truss.snow}} := \frac{23 \cdot 4 \cdot w_{\text{firm.snow}}}{2} \cdot \text{lbf}$$

Reaction at the truss due to firm snow. Note that the typical truss is 23 ft wide, and spacing of trusses is 4 ft c/c.

$$R_{\text{truss.snow}} = 49.246 \text{ lbf}$$

$$F_{\text{bot.chord1}} := F_{\text{bot.chord}} + F_{\text{bot.chord}} \cdot \frac{R_{\text{truss.snow}}}{R_{\text{truss}}}$$

Tension force at the bottom chord of truss by including 3/8" thick snow

$$F_{\text{bot.chord1}} = 715.738 \text{ lbf}$$

$$F_{\text{bot.chord1}} < P_{\text{clamp}} \quad \text{Okay}$$

Remove snow on the truss system, if it exceeds 3/8" in thickness

NOTE: If proposed bracings, as shown on the Sketch on pg. E-3 are added, it will add approximately 400 lbs to the truss system. The extra weight will help in overcoming the uplift due to wind, and will make the truss system more conservative. Therefore, there is no need to reanalyze the truss system

6.0 References

- 1.0 ASCE 7-05, Minimum Design Loads for Buildings and Other Structures, ASCE, Structural Engineering Institute.
- 2.0 RPP-CALC-42370, Analysis of Existing Scaffolds at AN & AW Tank Farm Skids, Rev. 0
- 3.0 TFC-ENG-STD-06, Rev. C-3, Design Loads for Tank Farm Facilities, CH2M Hill Hanford Group, Inc., Richland, Washington.
- 4.0 AISC, Steel construction, Allowable Stress Design, 9th Edition, American Institute of Steel

ANALYTICAL COMPUTATIONS

RPP-CALC-44193, R0

Subject: Evaluation of the Temporary Tent Cover Truss System, AP Primary Vent. System

Originator: M. A. Haq *M.A. Haq* **Date:** 12/22/09
Checker: TC Mackey **Date:** 12/30/09
Organizational Mgr.: M A. Roberts *M.A. Roberts* **Date:** 12/30/2009

Construction, Chicago, Illinois.

5.0 H-2-90456, Sh 1, Structural, Central Exhaust STA Plans, Sect & Detail.

6.0 H-2-90457, Structural Central Exh Sta Sect & Det.

ATACHMENT A

(Photos of Tent Cover Truss System)







ATTACHMENT B

(Sketch for Tent Cover Truss System Support)

ATTACHMENT C

(Field Sketch for Typical Tent Cover Truss)


ATACHMENT D

(Density of Snow Cover Info.)

RPP-CALC-44193R0

Density of Snow Cover

Snow Type	Density (kg/m ³)	Snow Depth for One Inch Water
Wild Snow	10 to 30	98" to 33"
Ordinary new snow immediately after falling in still air	50 to 65	20" to 15"
Settling Snow	70 to 90	14" to 11"
Average wind-toughened snow	280	3.5"
Hard wind slab	350	2.8"
New firn snow	400 to 550	2.5" to 1.8"
Advanced firn snow	550 to 650	1.8" to 1.5"
Thawing firn snow	600 to 700	1.6" to 1.4"



Slide 35 of 107

PG. D-2

ATTACHMENT E

(Alternate Calc. to verify the Strl. Integrity of the Truss System during Hoisting & Rigging)

ANALYTICAL CALCULATIONS


Page 1 of 2

Subject AP VENT SYSTEM TENT COVER HOISTING CALC
 Originator Paul DeBaigne P.D.B. Date 12/28/09
 Checker T.C. Mackey T.C. Mackey Date 12/29/09


STATEMENT:

THIS IS AN ALTERNATIVE CALCULATION TO VERIFY THE STRUCTURAL INTEGRITY OF THE FRAMING OF THE TRUSS FOR HOISTING & RIGGING.

CALCULATION:



→ ANALYZE AS A SOLID UNIT:



⇒ WEIGHT OF TRUSS SYSTEM = 3100 lb, DIST'D LOAD (w) = $\frac{3100}{36} = 86.11 \#/ft$

→ TRIANGLE PROPERTIES: AISC, LRFD, 3rd ed, p. 17-34

$c = \frac{1}{3}(48") = 16"$, $c_1 = 32"$

$I_{tube} = 0.29 in^4$, $A_{tube} = 0.75 in^2$

$I = \sum I + A c^2$, $I = 2(0.29 + 0.75(16")^2) + (0.29 + 0.75(32")^2)$, $I = 408.87 in^4$

$M_{max} = 0.100 w L^2 = 1240 \#-ft = 14.88 K-ft$, $L = 12'-0"$


Top Chord (Compression):

$F_b = \frac{M c}{I}$, $F_{bT} = 1.16 KSI \times 1.25 IMPACT = 1.45 KSI \checkmark OK$
 $c = 32"$

Bottom Chord (Tension):

$F_b = \frac{M c}{I}$, $F_{bB} = 0.58 KSI \times 1.25 IMPACT = 0.73 KSI \checkmark OK$
 $c = 16"$

Check BOTTOM CHORD FOR LOCAL BUCKLING:



INDIV. TRUSS WEIGHT = 310 #

LOAD ON TOP + BOTTOM CHORDS:

$310 \# / 3 = 103.34 \#$

$S_{tube} = 0.810 in^3$

$F_b = 0.6 F_y$, $F_y = 36 KSI$, $F_b = 21.6 KSI$


$F_b = 20 KSI$

$(F_b = 20 KSI) < (F_b = 21.6 KSI) \checkmark OK$


ANALYTICAL CALCULATIONS

Subject AP VENT SYSTEM TENT COVER HOISTING CALL
 Originator Paul DeBunione RLB Date 12/28/09
 Checker J.C. Mackey J.C. Mackey Date 12/29/09

- TRY 4 INTERIOR PICK POINTS WITH ENDS BRACED:



TRUSS WEIGHT = 310# EACH



$A_{TUBE} = 0.75 \text{ in}^2$
 $E_{M4} = 155 \#(4') + 155 \#(8') + 155 \#(8') - R_v(8')$
 $R_v = 460 \#$

$L_{BRACE} = \sqrt{4^2 + 8^2}$ $L_{BRACE} = 8.944'$

$P_{BRACE} = \frac{L_{BRACE}}{4}$ $P_{BRACE} = 1040 \#$

$F_T = \frac{P}{A} = \frac{1040 \#}{0.75 \text{ in}^2}$

$F_T = 1.39 \text{ KSI}$


$F_T = 0.6 F_y, F_y = 36 \text{ KSI}$

$F_T = 21.6 \text{ KSI}$

$F_T < F_c \quad \checkmark \text{ OK}$

-> 3-DIMENSIONAL STRESS OK BY INSPECTION.

- CHECK COMBINED BENDING + COMPRESSION BETWEEN PICK POINTS:




$V_R = \text{TRUSS SYSTEM WEIGHT} / 4 \text{ SLINGS}$

$V_R = \frac{3100 \#}{4}$ $V_R = 775 \#$

$P_R = 775 \# / \cos(10^\circ)$ $P_R = 786.96 \#$

$H_R = 775 \# \tan(10^\circ)$ $H_R = 136.65 \# \times 1.25 \text{ IMPACT}$ $H_R = 170.8 \#$



$R_R = \frac{P_R}{\cos(60^\circ)}$ $R_R = 837.5 \# \times 1.25 \text{ IMPACT}$
 $R_R = 1046.88 \#$


STRESS IN BOTTOM STRUTS FROM BENDING
 $F_b = 20 \text{ KSI}$

ADD AXIAL COMPRESSION, $H_R = 170.8 \#$
 $F_c = \frac{P}{A} = \frac{H_R}{A}$ $F_c = 0.23 \text{ KSI}$

$F_c = 5.89 \text{ KSI}$

$F_b = 21.6 \text{ KSI}$

$\frac{F_c}{F_c} + \frac{F_b}{F_b} = \frac{0.23}{5.89} + \frac{20}{21.6} = 0.965 < 1.0 \quad \checkmark \text{ OK}$



TRUSS SYSTEM
(DURING HOISTING & RIGGING)