S

Steady State Flammable Gas Release Rate Calculation and Lower Flammability Level Evaluation for Hanford Tank Waste

T. A. Hu

CH2M HILL Hanford Group, Inc.

Richland, WA 99352

U.S. Department of Energy Contract DE-AC27-99RL14047

EDT/ECN: 721735-R10

UC:

Cost Center: 7T600

Charge Code: 502298

B&R Code: N/A

Total Pages:

Key Words: hydrogen generation rate; flammable gas; lower flammability limit, rate equation model, ammoniam, methane, liquid/vapor equilibrium, time to 25% and 100% of the LFL, minimum vent rate.

Abstract: Assess the steady-state flammability level at normal and off-normal ventilation conditions. The methodology of flammability analysis for Hanford tank waste is developed. The hydrogen generation rate model was applied to calculate the gas generation rate for 177 tanks. Flammability concentrations and the time to reach 25% and 100% of the lower flammability limit, and the minimum ventilation rate to keep from 100 of the LFL are calculated for 177 tanks at various scenarios.

TRADEMARK DISCLAIMER. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof or its contractors or subcontractors.

Printed in the United States of America. To obtain copies of this document, contact: Document Control Services, P.O. Box 950, Mailstop H6-08, Richland WA 99352, Phone (509) 372-2420; Fax (509) 376-4989.

M. Washington *M. Washington*
Release Approval Date

Approved For Public Release

Tank Farm Contractor (TFC) RECORD OF REVISION		(1) Document Number: RPP-5926	Page 1
(2) Title: Steady State Flammable Gas Release Rate Calculation and Lower Flammability Level Evaluation for Hanford Tank Waste			
Change Control Record			
(3) Revision	(4) Description of Change – Replace, Add, and Delete Pages	Authorized for Release	
		(5) Resp. Engr. (print/sign/date)	(6) Resp. Mgr. (print/sign/date)
0	Original Release via EDT 628264	T. A. Hu 4/27/2000	K. M. Hodgson 4/27/2000
1	Total revision to address comments resulting from DOE-ORP review. (ECN 664031)	T. A. Hu 2/23/2001	J. S. Garfield 2/23/2001
2	Total revision to update the hydrogen rates and flammability to Nov. 2001 BBI data. (ECN 665039)	T. A. Hu 6/30/2002	N. W. Kirch 6/30/2002
2A	Add Appendix I, flammability evaluation of 5 DSTs with highest LFL. (ECN 720321)	T. A. Hu 3/20/2003	N. W. Kirch 3/20/2003
3	Total revision to update the hydrogen rates and flammability to July 2003 BBI data.	T. A. Hu 9/30/2003	N. W. Kirch 9/30/2003
3A	Add Appendix J, flammability evaluation of vacuum retrieval project of 241-C Tank Farm 200-Series.	T. A. Hu 11/19/2003	T. M. Horner 11/19/2003
3B	Add Appendix K, flammability evaluation to raise DST operation waste level to 460 inch.	T. A. Hu 12/23/2003	T. M. Horner 12/23/2003
3C	Add Appendix L, flammability evaluation of retrieval project on 241-C-103 and 241-C-105	T. A. Hu 1/22/2004	T. M. Horner 1/22/2004
3D	Add Appendix M, flammability evaluation of 241-AY-102 to support receiving condensate	T. A. Hu 4/20/2004	T. M. Horner 4/20/2004
3E	Update Appendix K, (Title, See Rev 3B) ECN-721735-R1	T. A. Hu 6/2/2004	T. M. Horner 6/2/2004
4	Complete revision of document as annual update per ECN-721735-R2	T. A. Hu 10/27/2004	T. M. Horner 10/27/2004
4A	Address ORP comments on Rev 4 and correct editorial errors per ECN-721735-R3	T. A. Hu 2/17/2005	T. M. Horner 2/17/2005
4B	Add Appendix I, flammability evaluation on raising the waste level to 460 inch for DSTs per ECN-721735-R4	T. A. Hu 4/27/2005	T. M. Horner 4/27/2005
4C	Delete the content of Appendix I per ECN-721735-R5	T. A. Hu 6/15/2005	T. M. Horner 6/15/2005
4D	Add Appendix I content with the flammability evaluation on the uncovered solids for DSTs per ECN-721735-R6	T. A. Hu 7/28/2005	T. M. Horner 7/28/2005
4E	Add Appendix J content with the flammability evaluation on tank 241-C-103 retrieval per ECN-721735-R7	T. A. Hu 9/12/2005	T. M. Horner 9/12/2005
5	Complete revision of document as annual update per ECN-721735-R8	T. A. Hu 10/27/2005	Mark Knight 10/27/2005
6	Complete revision of document as annual update per ECN-721735-R9	T. A. Hu 10/27/2006	N. W. Kirch 10/27/2006
7RS	Complete revision of document as annual update per ECN-721735-R10	T. A. Hu <i>aut</i> 10-25-07	N. W. Kirch <i>NWK</i> 10-25-07

DISTRIBUTION SHEET

To Distribution	From Process/Waste Transfer Engineering	Page 1 of 1			
		Date 10/25/07			
Project Title/Work Order RPP-5926, Rev. 7, Steady-State Flammable Gas Release Rate Calculation and Lower Flammability Level Evaluation for Hanford Tank Waste		EDT No. NA			
		ECN No. 721735-R10			
Name	MSIN	Text With All Attach.	Text Only	Attach./ Appendix Only	EDT/ECN Only

CH2M HILL Hanford Group, Inc.

S. J. Eberlein	R2-58	X			
J. M. Gribbsby	S7-90	X			
T. G. Goetz	R2-58	X			
K. D. Fowler	S5-08	X			
T. A. Hu	S5-08	XX			
N. W. Kirch	S5-08	X			
L. J. Kripps	S7-90	X			
T. C. Oten	S5-07	X			

Office of River Protection

DOE Reading Room	H2-53	X			
M. R. Moreno	H6-60	X			
W. B. Scott	H6-60	X			
J. S. Shuen	H6-60	X			

Steady-State Flammable Gas Release Rate Calculation and Lower Flammability Level Evaluation for Hanford Tank Waste

T. A. Hu
CH2M HILL Hanford Group, Inc.

Date Published
October 2007

Prepared for the U.S. Department of Energy
Assistant Secretary for Environmental Management

Contractor for the U.S. Department of Energy
Office of River Protection under Contract DE-AC27-99RL14047

CH2MHILL
Hanford Group, Inc.

P.O. Box 1500
Richland, Washington

Release Approval

Date

EXECUTIVE SUMMARY

Flammable gases such as hydrogen, ammonia, and methane are observed in the tank dome space of the Hanford Site high-level waste tanks. This report assesses the steady-state flammability level under normal and off-normal ventilation conditions in the tank dome space for 177 double-shell tanks and single-shell tanks at the Hanford Site. The steady-state flammability level was estimated from the gas concentration of the mixture in the dome space using estimated gas release rates, Le Chatelier's rule and lower flammability limits of fuels in an air mixture. A time-dependent equation of gas concentration, which is a function of the gas release and ventilation rates in the dome space, has been developed for both soluble and insoluble gases. With this dynamic model, the time required to reach the specified flammability level at a given ventilation condition can be calculated.

In the evaluation, hydrogen generation rates can be calculated for a given tank waste composition and its physical condition (e.g., waste density, waste volume, temperature) using the empirical rate equation model provided in HNF-3851, *Empirical Rate Equation Model and Rate Calculations of Hydrogen Generation for Hanford Tank Waste*. The release rate of other insoluble gases and the mass transport properties of the soluble gas can be derived from the observed steady-state gas concentration under normal ventilation conditions. The off-normal ventilation rate is assumed to be natural barometric breathing only. A large body of data is required to do both the hydrogen generation rate calculation and the flammability level evaluation. For tank waste that does not have sample data, a statistical-based value from probability distribution regression was used based on data from tanks having similar waste types.

This report (Revision 7) updates the input data of hydrogen generation rate calculations in Revision 6 for 177 tanks using the waste composition information in the Best-Basis Inventory Detail Report¹ in the *Tank Waste Information Network System* (data effective as of April 1, 2007), and the waste temperature data in the Surveillance Analysis Computer System (SACS)² for the time period from April 1, 2006 through April 1, 2007. However, the release rate of methane, ammonia, and nitrous oxide is based on the input data (dated October 1999) as stated in Revision 0 of this report. In the flammability evaluations with zero ventilation, an increase of 5 °C of the waste temperatures for all double-shell tanks, and water addition of 10 kgal and 1 kgal for 100- and 200-series tanks, respectively, are performed to address the issues of routine water additions. Annual maximum waste temperatures are used based on highest temperatures for any one day. Also the gas diffusion effect through the concrete dome space is included in the mass balance equations for single-shell tanks under the zero ventilation condition.

Overall, the flammability assessment indicates that no tank will exceed 25% of the lower flammability limit under normal ventilation conditions. Off-normal ventilation conditions

¹ TWINS, 2007, *Tank Waste Information Network System*, Internet address: <http://twins.pnl.gov/twins.htm>, queried September 17, 2007.

² SACS, 2007, Surveillance Analysis Computer System, queried September 17, 2007, SACSPROD database; also available at <http://twins.pnl.gov/twins.htm>.

evaluated in this report included shutdown of the active ventilation system coupled with closure of the air inlet for actively ventilated systems and isolation of the high-efficiency particulate air breather filter for passively ventilated tanks. Considering the 10 and 1 kgal water additions and 5 °C temperature increases for double-shell tanks with the barometric breathing rate, the shortest time to reach 25% of the lower flammability limit is 10 days for double-shell tanks (i.e., tank 241-AZ-102) and 39 days for single-shell tanks (i.e., tank 241-B-203). Considering 10 and 1 kgal water additions and 5 °C temperature increases for double-shell tanks under zero ventilation scenario with only a diffusion mechanism for gas releases for single-shell tanks, the shortest time to reach 25% of the lower flammability limit is 10 days for double-shell tanks (i.e., tank 241-AZ-102) and 35 days for single-shell tanks (i.e., tank 241-B-203). Note that off-normal ventilation conditions rarely occur.

CONTENTS

1.0	INTRODUCTION AND BACKGROUND	1-1
1.1	REVISION 1	1-2
1.2	REVISION 2	1-2
1.3	REVISION 2A	1-3
1.4	REVISION 3	1-3
1.5	REVISIONS 3A THROUGH 3E	1-3
1.6	REVISION 4	1-3
1.7	REVISION 4-A	1-4
1.8	REVISION 5	1-4
1.9	REVISION 6	1-4
1.10	REVISION 7	1-5
1.11	GAS GENERATION	1-5
1.12	DOCUMENT ORGANIZATION	1-6
2.0	HYDROGEN GENERATION RATE MODEL	2-1
2.1	SEMI-EMPIRICAL RATE EQUATIONS	2-1
3.0	METHODOLOGY TO ESTIMATE STEADY-STATE FLAMMABILITY LEVEL	3-1
3.1	LOWER FLAMMABILITY LIMITS	3-1
3.2	VENTILATION CONDITIONS IN TANK DOME SPACE	3-3
3.3	TIME-DEPENDENT GAS CONCENTRATION MODEL	3-4
	3.3.1 Insoluble Gas	3-5
	3.3.2 Soluble Gas	3-7
3.4	STEADY-STATE GAS CONCENTRATION AND GAS RELEASE RATE	3-9
3.5	TIME TO REACH LOWER FLAMMABILITY LIMIT	3-12
3.6	THE MINIMUM VENTILATION RATE TO MAINTAIN DOME SPACE BELOW 25 OR 100 PERCENT OF THE LOWER FLAMMABILITY LIMIT	3-13
3.7	TIME-DEPENDENT GAS CONCENTRATION UNDER ZERO VENTILATION CONDITION	3-14
3.8	TANK WASTE TEMPERATURE INCREASE RATE	3-15
4.0	EVALUATIONS OF STEADY-STATE FLAMMABILITY LEVEL	4-1
4.1	HYDROGEN GENERATION RATE MODEL CALCULATIONS	4-1
	4.1.1 Input Data	4-2
	4.1.2 Derived Data	4-4
	4.1.3 Calculated Hydrogen Generation Rates	4-5
4.2	TANK VENTILATION RATES AND STEADY-STATE GAS CONCENTRATIONS	4-7
4.3	STEADY-STATE GAS RELEASE RATES FOR H ₂ , NH ₃ , CH ₄ , AND N ₂ O	4-7

4.4	STEADY-STATE MASS TRANSPORT PROPERTIES “h” AND “A” FOR AMMONIA.....	4-9
4.5	FLAMMABILITY EVALUATION AND RESULTS.....	4-12
4.5.1	Off-Normal Condition With Barometric Breathing.....	4-13
4.5.2	Off-Normal Condition with Zero Ventilation.....	4-15
4.6	DISCUSSION.....	4-23
5.0	SUMMARY AND CONCLUSIONS	5-1
6.0	REFERENCES	6-1

APPENDICES

A	INPUT DATA FOR HYDROGEN GENERATION RATE CALCULATIONS FROM BEST BASIS UBVEBTORY DETAIL CALCULATION REPORT AND DERIVATION DOCUMENT (QUERIED ON SEPTEMBER 27, 2006).....	A-i
B	HYDROGEN GENERATION RATE CALCULATIONS FROM EMPIRICAL RATE EQUATION MODEL FOR 177 HANFORD TANKS.....	B-i
C	CALCULATIONS OF THE HENRY'S LAW CONSTANTS AND THE MASS TRANSPORT PRODUCTS OF h AND A.....	C-i
D	CALCULATION RESULTS OF STEADY-STATE FLAMMABILITY EVALUATIONS IN TANK DOME SPACES FOR 177 HANFORD TANKS	D-i
E	EQUATIONS TO CALCULATE THE MASS TRANSPORT COEFFICIENT h FOR SOLUBLE GAS.....	E-i
F	CALCULATIONS OF THE GAS DIFFUSION COEFFICIENTS FOR THE CONCRETE DOME OF SINGLE-SHELL TANKS	F-i
G	FLAMMABILITY EVALUATION OF TIME TO 25% OF THE LOWER FLAMMABILITY LIMIT TO SUPPORT THE VACUUM RETRIEVAL PROJECT.....	G-i
H	FLAMMABILITY EVALUATION OF TIME TO REACH 25% AND 100% OF THE LOWER FLAMMABILITY LIMIT FOR DOUBLE-SHELL TANK 241-AY-102 AT VARIOUS WASTE LEVELS WHILE RECEIVING EXHAUSTER CONDENSATE COLLECTED FROM CATCH TANK 241-AZ-151	H-i
I	PEER REVIEW CHECKLIST	I-i

LIST OF FIGURES

Figure 3-1. A Simplified Tank System for Time-Dependent Gas Concentration Model.....	3-5
Figure 4-1. Ammonia Concentration and Release Rate for Double-Shell Tank 241-SY-101 Before and After Loss of Active Ventilation.....	4-9

LIST OF TABLES

Table 2-1. Comparison of Model-Calculated and Field-Observed Hydrogen Generation Rates	2-3
Table 4-1. Calculated Top Ten Hydrogen Generation Rates In Dome Space for 177 Tanks With Current Waste.....	4-6
Table 4-2. The Calculation of Ammonia Transport Properties	4-11
Table 4-3. Time ^{a, b} to Reach 25% and 100% of the Lower Flammability Limit With Water Addition ^c and 5 °C Temperature Increase ^d Under Barometric Breathing Condition	4-14
Table 4-4. The Hydrogen Generation Rates, Time To 25% and 100% of the Lower Flammability Limit and Minimum Vent Rate With 10 kgal Water Addition and 5 °C Temperature Increase Under Zero Ventilation for Double-Shell Tanks.	4-18
Table 4-5. The Hydrogen Generation Rates, Time To 25% and 100% of the Lower Flammability Limit and Minimum Vent Rate with Water Addition ^a Under Zero Ventilation (Except Gas Diffusion Mechanism Through The Dome) for Single-Shell Tanks	4-19

LIST OF TERMS

BBI	best-basis inventory
DST	double-shell tank
GRE	gas release event
HEPA	high-efficiency particulate air
HGR	hydrogen generation rate
LFL	lower flammability limit
SACS	Surveillance Analysis Computer System
SST	single-shell tank
TCD	Tank Characterization Database
TOC	total organic carbon
TWINS	Tank Waste Information Network System

1.0 INTRODUCTION AND BACKGROUND

This report provides the methodology to predict the steady-state gas release rate and to evaluate the steady-state flammability level of the tank dome space under both normal and off-normal ventilation operating conditions for 177 underground nuclear waste storage tanks at the Hanford Site. Revision 0 of this report replaced two previous calculation notes: HNF-SD-WM-CN-116, *Calculation Note Hydrogen Generation Rates At Steady State Flammable Gas Concentrations for Single-Shell Tanks*, and HNF-SD-WM-CN-117, *Calculations of Hydrogen Release Rate at Steady State for Double-Shell Tanks*. Revision 0 also provided the technical basis for establishing flammable gas controls. The focus of this report is the loss of ventilation transient such that technical safety requirement surveillance frequencies and action times can be established. This report also provides the following:

- Estimates of the flammable gas release rates in the tank dome space
- Estimates of the time to reach 25% of the lower flammability limit (LFL) and 100% of the LFL following the loss of normal ventilation in actively and passively ventilated double-shell tanks (DST) and single-shell tanks (SST)
- Estimates of the minimum ventilation rate required to maintain less than 25% of the LFL
- Estimates of the maximum dome space concentrations following an extended loss of normal ventilation.

The methodology presented in this report can be used in other applications.

To clarify the application of the subject document, “steady-state” has been defined as the condition of no active operational changes to the tank, and the non-GRE (gas release event) condition with GRE defined as a 500-ppm rise in hydrogen concentration followed by exponential decay of the released flammable gas. For this application the following assumptions were used: (1) long-term variations in ventilation rates brought about by seasonal effects or ventilation rate changes within the exhaust system operating range are minimal and neglected; (2) the variability of the hydrogen concentration about the baseline is less than that produced by a GRE. When the results from only one sample were available, the sample was assumed to have been taken at steady-state condition unless clear documentation shows the existence of a GRE condition.

This report is organized as follows: Chapter 2.0 describes the hydrogen generation rate (HGR) model calculation and summarizes the empirical equation of HGRs. Chapter 3.0 describes the methodology to evaluate the flammability level of the gas mixture in the dome space. Details of the validity of the LFLs in air, ammonia liquid-vapor equilibrium model, time-dependent gas concentration model, and the flammability level calculations are discussed. Chapter 4.0 discusses the input data and results of the gas generation calculations and the flammability evaluations under various ventilation conditions. Chapter 5.0 gives the overall summary and conclusions. Detailed formula, input data, and calculation results for 177 DST and SSTs are

given in Appendices A through F. In addition, flammable gas evaluations for special cases or some scenarios are given in Appendices G and H.

1.1 REVISION 1

Revision 1 of this report differs from Revision 0 in the following ways:

- The mass balance equation (Equation 3-5) and its derived equations in the methodology of flammability assessment section (Chapter 3.0) were modified by redefining the ventilation rate as the outlet measurement or calculated outlet flow for natural breathing plus gas generation to reflect total gas leaving the tank.
- The input data and calculations for DST 241-SY-101 were updated to reflect the tank waste status after 616 kgal of active flammable-gas-generation waste material were transferred between December 1999 and February 2000, as provided in RPP-6517, *Evaluation of Hanford High-Level Waste Tank 241-SY-101*. As of April 2001, the HGR in DST 241-SY-101 was $3.1 \text{ E-3 ft}^3/\text{min}$, which is one-tenth the generation rate before the remediation task. Other than the data for DST 241-SY-101, all the input data used were from Revision 0, which presents data as of October 1999, unless noted in Revision 1.
- The liquid/vapor equilibrium model was added to address the behavior of the highly soluble gas ammonia.
- The off-normal ventilation calculations used in the flammability assessment were more clearly defined and text was added.

1.2 REVISION 2

Revision 2 was issued to cover the following items:

- The U.S. Department of Energy's comments on Revision 1 were resolved. Primarily, the off-normal ventilation conditions were redefined and it was clarified that the off-normal conditions rarely occur. Second, the discussions on the discrepancies of the ammonia mass transport properties between the field data-derived values and the direct calculation of mass transport coefficient, h , and using 100% surface area were redone. Third, several editorial errors were identified and corrected.
- The HGRs for 177 tanks were updated using the waste composition information in the latest best-basis inventory (BBI) detailed calculation report generated by the *Tank Waste Information Network System* (TWINS) and temperature data in Surveillance Analysis Computer System (SACS) (dated November 2001) as the input data. In this revision, DST 241-AY-102 has the highest HGR instead of DST 241-AN-102 (Revision 1). This is because the updated input data for DST 241-AY-102 include the waste received from SST 241-C-106, and the tank also shows higher tank waste temperature than previously.

- The flammability calculations for the 177 tanks were updated to reflect the updated HGRs. For off-normal ventilation condition, the updated flammability calculations were performed at barometric breathing rate for DSTs, and at both barometric breathing and zero ventilation rates for SST. The SSTs was sealed off as much as possible under the interim stabilization project.
- Using BBI data dated November 15, 2001, SST 241-A-101 has the greatest HGR among the SSTs, but the tank was undergoing saltwell pumping, which reduced both the HGR and flammability. The HGR and flammability are recalculated based on the latest waste volume information (February 28, 2002) to reflect the saltwell pumping activity.
- To address routine water addition and other possible waste transfer operations, flammability assessments were performed on several waste addition cases. The resulting information were used to determine the flammable gas control for the ventilation surveillance frequency and the waste compatibility program.

1.3 REVISION 2A

Revision 2A made no changes to the text or Appendices A through H. It added a new Appendix I (subsequently changed to Appendix H in Revision 3. The new Appendix I contained flammability evaluations on the sensitivity of waste temperature and water addition under zero ventilation condition for top three flammability-level and aging-waste DSTs.

Appendix I contained a complete set of equations derived for flammability evaluations under zero ventilation condition for both soluble and insoluble gases. A simple and conservative heat transfer model (RPP-6213, *Hanford Waste Tank Bump Accident and Consequence Analysis*), used in evaluation of the steam bump hazard, was used for tank waste temperature increase analysis in the gas generation rate calculations.

1.4 REVISION 3

Revision 3 updated the HGR calculations and thus changed the flammability evaluations based on the latest BBI data from July 15, 2003, which resulted in changes to Appendices A, B, D, and H. The text was modified to reflect the changes.

1.5 REVISIONS 3A THROUGH 3E

Revision 3A to 3E made no changes to the main text or Appendices A through I of Revision 3. It added a new Appendix J to M (Appendices J and M were subsequently changed to Appendices F and G in Revision 4).

1.6 REVISION 4

In Revision 4, the HGR equation model has been upgraded and documented (HNF-3851, *Empirical Rate Equation Model and Rate Calculations of Hydrogen Generation for Hanford*

Tank Waste) following the Waste Treatment Project studies (24590-WTP-RPT-RT-04-0002) on the applicability of the HGR model on the waste treatment processes. In this revision the methodology to calculate the HGR is also, updated using the latest HGR model. The improvements to the HGR model include the following:

- Development of water radiolysis equation which is more accurate and covers a wider range of tank waste concentrations
- Addition of the radiolysis term from total alpha contribution for both organic and water radiolysis
- Introduction of the hydrogen generation efficiency on the corrosion mechanism to remove conservatism from the model
- Refit of both thermolysis and radiolysis equations because of the changes to the water radiolysis equation and the new gas generation data.

Revision 4 also introduces the diffusion effect through the concrete dome of the SSTs by adding the diffusion term in the mass balance equation. A time-dependent gas concentration equation to include the diffusion mechanism has been developed and applied to the flammable gas evaluation for SSTs. The gas diffusion coefficients for the calculations are taken from RPP-18491, *Flammable Gas Diffusion Through Single-Shell Tank Domes*.

The HGR calculation was also updated in Revision 4 and the flammability evaluation was changed based on the latest BBI data from September 27, 2004, and the latest temperature data from SACS from April 1, 2003 to April 1, 2004.

1.7 REVISION 4-A

Revision 4-A is intended to address comments from the U.S. Department of Energy, Office of River Protection and correct editorial errors.

1.8 REVISION 5

Revision 5 updated the HGR calculations and thus changed the flammability evaluations based on the latest BBI data queried on September 21, 2005, which resulted in changes to Appendices A, B, D, and I. The text was modified to reflect the changes.

1.9 REVISION 6

Revision 6 updated the HGR calculations and thus changed the flammability evaluations based on the latest BBI data queried on September 27, 2006 (effective as of April 1, 2006), and the

waste temperature data in SACS³ (April 1, 2005 through April 1, 2006). This data update resulted in changes to Appendices A, B, and D. The text was modified to reflect the changes.

1.10 REVISION 7

Revision 7 updated the HGR calculations and thus changed the flammability evaluations based on the latest BBI data queried on September 17, 2007 (effective as of April 1, 2007), and the waste temperature data in SACS⁴ (April 1, 2006 through April 1, 2007). This data update resulted in changes to Appendices A, B, and D. The text was modified to reflect the changes.

1.11 GAS GENERATION

The gases generated in the tank waste are a mixture of hydrogen, nitrogen, ammonia, nitrous oxide, methane, and other hydrocarbons. Hydrogen is the most abundant gas and contributes more than 90% of the flammable components in the dome space for most of the storage tanks containing gas-generating waste. All of these gases except ammonia have low solubility and are almost fully released to the dome space or partially trapped in the solid layers of waste. Because of its high solubility, 99% of the ammonia generated is dissolved and stored in the liquid waste (PNNL-11450, *Composition and Quantities of Retained Gas Measured in Hanford Waste Tanks 241-AW-101, A-101, AN-105, AN-104, and AN-103*) rather than being released to the dome space. For most of the tanks, little methane is generated, but methane is the major species among the observed hydrocarbon vapors. Nitrous oxide is not flammable by itself, but it is an oxidizer. Studies provided in *Flammability and Flame Propagation in H₂-N₂O-CH₄-NH₃-O₂-N₂ Mixtures*, Explosion Dynamics Laboratory Report FM97-4 (Pfahl and Shepherd 1997), show that concentrated nitrous oxide can lower the flammability limit of fuels in an air mixture.

Understanding gas generation phenomena and predicting the gas generation and gas release rates are important in controlling the flammable gas hazard and planning daily operations in the tank farms. For example, the overall rate of generation is needed to verify that any given tank has sufficient ventilation to ensure that the level of flammable gases is maintained below the operational flammability limit in its dome space. In the past decade, many studies (HNF-SP-1193, *Flammable Gas Project Topical Report*) have been conducted on the mechanisms of gas generation, gas release, and gas retention of tank waste using simulated or actual waste. Systematic tank waste characterization programs and various tank safety programs have generated a tremendous amount of tank waste data. This information provided the basis for HNF-3851. The model is tank-waste-constituent- and tank-condition-based and provides a tool to estimate the generation rate for not only the current tank waste contents, but also tanks with contents that have changed. The other observed gases—ammonia, methane, and nitrous oxide—

³ SACS, 2006, Surveillance Analysis Computer System, queried September 27, 2006, SACSPROD database; also available at <http://twins.pnl.gov/twins.htm>.

⁴ SACS, 2007, Surveillance Analysis Computer System, queried September 17, 2007, SACSPROD database; also available at <http://twins.pnl.gov/twins.htm>.

are not modeled to have a general rate equation for calculating generation rates as a function of waste constituents.

The report provides the methodology for calculating gas release rates. The HGR equation model (HNF-3851) is used to estimate the hydrogen release rate by subtracting the field-observed gas accumulation rate, if any, from the model-calculated generation rate. The gas release rates for ammonia, methane, and nitrous oxide—the minor gases of interest observed in tank dome spaces—are derived from vapor concentration data, ventilation rates in the respective tank dome spaces, and other information about tank waste.

While updating the DST 241-SY-101 calculations for the Revision 1 of the report, the dome space steady-state ammonia concentration in DST 241-SY-101 rose from a prerediation concentration of 4 ppm (before the waste was transferred) to 400 ppm (January 14, 2001). Based on the value of 400 ppm, the derived ammonia release rate, if used as a constant, will predict a value of 108% of the LFL as the steady-state ammonia concentration under the off-normal condition of a loss of ventilation. This is a factor of 50 times larger than the equilibrium value predicted by the model. Apparently, treating the ammonia release rate as constant is over-conservative when the ammonia concentration in the dome space is high. Therefore, the liquid-vapor equilibrium model provided in RPP-4941, *Methodology for Predicting Flammable Gas Mixtures in Double-Contained Receiver Tanks*, is introduced into the methodology to address the dome space calculations for ammonia. A time-dependent equation for gas concentration in a tank dome space was developed by solving the mass balance equations for the gas volume. Once the steady-state gas release rates or the mass transport properties of soluble gas are obtained, a time-dependent gas concentration can be derived from the equation for a given ventilation condition. Therefore, the flammability level of the gas mixture in a dome space can be calculated under both normal and off-normal ventilation conditions. Also, the time required to reach a specified flammability level in a dome space and the minimum ventilation rate required to prevent reaching that level can be estimated.

1.12 DOCUMENT ORGANIZATION

Attachment A to TFC-ENG-DESIGN-C-10, *Engineering Calculations*, provides a list of certain sections to be included in engineering documents. The following notes where the sections in this document correspond to the TFC-ENG-DESIGN-C-10 attachment.

1. Title and Identifier (required) – See title page.
2. Objective/Purpose (required) – See Chapter 1.0.
3. Summary of Results and Conclusions (optional depending on calculation length or complexity) – See Executive Summary.
4. Introduction/Background (optional) – See Chapter 1.0.
5. Input Data (required) – See Chapter 4.0 and Appendix A, B, C, D, F.
6. Assumptions (required if assumptions are made) – See Chapters 2.0 and 3.0.

7. Method of Analysis (required) – Calculation methods are in Chapter 3.0 and spreadsheets in appendices.
8. Use of Computer Software (required if software is used) – The only software used are Excel⁵ spreadsheets.

The cases study uses a validated Excel spreadsheet, documented in Chapters 3.0 and 4.0, to calculate the HGRs and the time to 25% and 100% of the LFL, minimum ventilation rate. The spreadsheet was verified in compliance with TFC-ENG-CHEM-D-33,⁶ *Spreadsheet Verification*, and is documented in spreadsheet verification form SVF-032, Rev 4.

Spreadsheet owner: T. A. Hu

Spreadsheet name: RPP-5926-8050-R4-LFL-CAL-T2-102004.xls

Spreadsheet location: U:\FlamGas\RPP-5926 Rev 4\Calculations

This verified spreadsheet was used with the update input data to calculate the gas generation rates, then calculates the flammability and time to LFL for a given ventilation rate.

The input data for HGR calculation is prepared by converting the latest BBI data with the spreadsheet "InputTimeToLFL101504.xls." The spreadsheet was verified in compliance with TFC-ENG-CHEM-D-33 and is documented in spreadsheet verification form SVF-275, Rev 0.

Spreadsheet owner: T. A. Hu

Spreadsheet name: InputTimeToLFL101504.xls

Spreadsheet location: U:\FlamGas\RPP-5926 Rev 4\Calculations

9. Results (required) – See Chapter 4.0 as well as various summary tables.
10. Conclusions (required) – See Section 5.0.
11. Recommendations (optional) – None included.

⁵ Excel is a registered trademark of Microsoft Corporation, Redmond, Washington.

⁶ TFC-ENG-CHEM-D-33 has been replaced by TFC-ENG-DESIGN-C-32, *Spreadsheet Development and Verification*.

This page intentionally left blank.

2.0 HYDROGEN GENERATION RATE MODEL

Several hydrogen rate models have been proposed (WHC-EP-0702, *Criteria for Flammable Gas Watch List Tanks*; WHC-SD-WM-TI-724, *Methodology for Flammable Gas Evaluations*; WHC-SD-WM-SARR-015, *Topical Report on Flammable Gases in Non-Burping Waste Tanks*; PNNL-11297, *Status and Integration of Studies of Gas Generation in Hanford Wastes*; and HNF-SD-WM-CN-117) to estimate the HGR for Hanford tank waste, but these models are based on either the waste simulant data or very limited tank waste data. A more comprehensive HGR model (described in *Empirical Rate Equation Model of Hydrogen Generation for Hanford Tank Waste*, paper presented at American Nuclear Society, 1999 Winter Meeting, and HNF-3851) was developed and validated based on a large body of tank waste data. The model constructed a set of semi-empirical rate equations to simulate the gas generation mechanisms of thermal chemical reactions, radiolysis of water and organic components, and corrosion processes. The rate equations are formulated as a function of physical and chemical properties of tank waste and are able to estimate the HGR of waste under current conditions, including the rates for newly mixed waste with known properties. The model has been applied to calculate the generation rate for more than 28 SSTs and DSTs and shows good agreement with field-observed rates.

2.1 SEMI-EMPIRICAL RATE EQUATIONS

The empirical rate equation for hydrogen generation in Hanford Site waste developed above contains the simulation of thermal reaction, HGR_{thm} , radiolysis of water and organic, HGR_{rad} , and the corrosion process, HGR_{corr} . This rate equation is a function of waste composition (TOC, Al^{+3} , NO_3^- , NO_2^- and Na^+), radiation dose, temperature, liquid fraction, and tank wetted area. Both the thermal and organic radiolysis rates follow Arrhenius behavior with a derived activation energy. The equation for HGR in the units of moles per kilogram per day can be summarized as follows (Equation 2-1):

$$HGR = HGR_{thm} + HGR_{rad} + HGR_{corr} \quad (2-1)$$

where:

$$HGR_{thm} = a_{thm} \times (r_f \times [TOC]) \times [Al^{+3}]^{0.4} \times L_f \times \exp^{(-E_{thm} / RT)}$$

$$HGR_{rad} = [(G_{(H_2)}^{rad} / H_2O)^{\beta_{1\gamma}} + G_{(H_2)}^{rad} / H_2O]^{\beta_{1\gamma}} \times H_{Loud}^{\beta_{1\gamma}} + (G_{(H_2)}^{org} / H_2O)^{\alpha} + G_{(H_2)}^{org} / H_2O]^{\alpha} \times H_{Loud}^{\alpha} \times L_f \times CF_1$$

$$HGR_{corr} = R_{corr} \times E_{H_2} \times A_{wetted} / M_{tank} \times CF_2$$

with:

$$G_{(H_2)}^{org} / H_2O = a_{rad} \times \exp^{(-E_{rad} / RT)} \times (r_f \times [TOC])$$

$$G_{(H_2)_{H_2O}}^{\beta/\gamma} = \frac{0.32}{1 + 2.4[NO_3^-] + 0.62[NO_2^-] + 0.31[Na^+]_{ex}^2} + \frac{0.13}{1 + 139[NO_3^-] + 54[NO_2^-]}$$

$$G_{(H_2)_{ORG}}^{\alpha} = 0.5 \times a_{rad} \times \exp^{(-E_{rad}/RT)} \times (r_f \times [TOC])$$

$$G_{(H_2)_{H_2O}}^{\alpha} = \frac{1.05}{1 + 2.4[NO_3^-] + 0.63[NO_2^-]} + \frac{0.35}{1 + 3900[NO_3^-] + 1400[NO_2^-]}$$

and:

- E_{thm} = 89.6 kJ/mole, the activation energy for the thermal reaction
- a_{thm} = 3.94 E+09 mole/kg-day, pre-exponential factor of the thermal rate
- E_{rad} = 48.8 kJ/mole, activation energy in organic radiolysis, G
- a_{rad} = 1.11 E+07 H₂/100 eV, the pre-exponential term in organic radiolysis, G
- r_f = 0.6 for DSTs and 0.3 for SSTs (unitless), the total organic carbon reactivity coefficient
 Note: The $r_f = 0.3$ for SSTs is an average value from the tanks tested. If tank has a high fraction of energetic organic compounds, the r_f can be adjusted to as high as 0.6.
- R = 8.314 J/mole/K, gas constant
- R_{corr} = 6.0 E-08 for DSTs and 2.4 E-07 for SSTs (ft³/min/ft²), corrosion coefficient
- E_{H_2} = the hydrogen generation efficiency coefficient from corrosion is 20 percent if $[NO_3^-]$, $[NO_2^-]$, and $[OH^-] > 0.1$, otherwise it is 50 percent.
- $[TOC]$ = total organic carbon concentration in the liquid waste (wt%)
 Note: Insoluble energetic organic compounds (excluding oxalate) in the solid layer should be considered case by case when data is available
- $[Al^{+3}]$ = aluminum ion concentration in liquid waste (wt%)
- $[NO_3^-]$ = nitrate ion concentration in the liquid waste (moles/L)
- $[NO_2^-]$ = nitrite ion concentration in the liquid waste (moles/L)
- $[Na^+]_{ex}$ = concentration of sodium minus nitrate and nitrite concentration in liquid waste (moles/L)
- $H_{load}^{\beta/\gamma}$ = total heat load of the tank from beta/gamma (Watt/kg)
- H_{load}^{α} = total heat load of the tank from total alpha (Watt/kg)
- L_f = liquid weight fraction in the waste (unitless)
- T = temperature of waste (K)
- A_{wetted} = area of steel exposed to moisture-containing waste (ft²)
- M_{tank} = total mass in the waste (kg)
- CF_1 = conversion factor from (H₂/100 eV)(Watts/kg) to (Mole/kg-day)
- CF_2 = conversion factor from (m³/kg-min) to (Mole/kg-day).

In general, the HGR caused by chemical reactions follows Arrhenius behavior and the rate from radiolysis is proportional to the radiation dose. In addition, the HGRs from radiation effects in tank waste samples have been observed to be temperature dependent as provided in PNNL-12181, *Thermal and Radiolytic Gas Generation on Material from Tanks 241-U-103*,

241-AW-101, 241-S-106, and 241-S-102: Status Report. The analysis of all available gas generation data provided in HNF-3851 shows that this temperature-dependent reaction follows Arrhenius behavior, which may result from a multi-step degradation of organic compounds initiated by radiolysis, followed by thermal reactions. The water radiolysis rate is assumed to be temperature independent, with the G_{H_2O} value reduced by scavenging effects.

The numerical parameters in the equations are established by analyzing gas generation kinetic data from waste samples with the aid of tank field surveillance data and tank waste characterization data. The reactivity coefficient, r_f , was used to adjust for differences in reactivity of total organic carbon (TOC) among the tanks. HNF-3851 describes this model in detail. For comparison, Table 2-1 lists the field-observed and model-calculated total HGRs, and the ratio between these values for 28 tanks.

Table 2-1. Comparison of Model-Calculated and Field-Observed Hydrogen Generation Rates. (2 sheets)

Tanks	G_{mod} (ft ³ /min) Total HGR from Model	G_{field} (ft ³ /min) Total HGR from Field	G_{mod} (L/day) Total HGR from Model	G_{field} (L/day) Total HGR from Field	Ratio Between Model and Field
241-AN-101	1.73E-04	2.50E-04	7	10	0.69
241-AN-103	4.54E-03	4.76E-03	186	195	0.95
241-AN-104	5.53E-03	2.55E-03	227	104	2.17
241-AN-105	5.14E-03	3.06E-03	211	125	1.68
241-AN-107	1.09E-02	5.25E-03	447	214	2.09
241-AW-101	3.55E-03	3.17E-03	146	129	1.12
241-AY-102	2.10E-02	1.70E-02	859	691	1.24
241-AZ-101	2.79E-02	9.44E-03	1,144	385	2.97
241-AZ-102	2.90E-02	1.90E-02	1,190	775	1.54
241-SY-101	5.96E-02	2.44E-02	2,441	993	2.45
241-SY-102	9.66E-04	7.26E-04	40	30	1.34
241-SY-103	3.63E-03	3.54E-03	149	145	1.02
241-A-101	5.64E-03	2.14E-03	231	87	2.65
241-C-104	2.56E-03	2.21E-03	105	90	1.16
241-C-106	1.62E-02	9.03E-03	664	368	1.80
241-S-102	1.25E-03	1.64E-03	51	67	0.77
241-SX-101	6.64E-04	4.20E-04	27	17	1.59
241-SX-103	3.03E-03	1.27E-03	124	52	2.40
241-SX-104	1.31E-03	2.51E-04	53	10	5.23
241-SX-105	5.77E-03	4.82E-03	236	197	1.20
241-SX-106	1.53E-03	1.24E-03	63	50	1.25
241-U-102	1.05E-03	1.10E-03	43	45	0.96
241-U-103	1.46E-03	1.48E-03	60	60	1.00
241-U-105	1.37E-03	1.61E-03	56	65	0.86

Table 2-1. Comparison of Model-Calculated and Field-Observed
Hydrogen Generation Rates. (2 sheets)

Tanks	G_{mod} (ft ³ /min) Total HGR from Model	G_{field} (ft ³ /min) Total HGR from Field	G_{mod} (L/day) Total HGR from Model	G_{field} (L/day) Total HGR from Field	Ratio Between Model and Field
241-U-106	1.12E-03	6.62E-04	46	27	1.70
241-U-107	4.71E-04	8.27E-04	19	34	0.57
241-U-108	9.42E-04	1.41E-03	39	57	0.67
241-U-109	5.44E-04	7.11E-04	22	29	0.77

Note:

HGR = hydrogen generation rate.

Among these 28 tanks, six SSTs and two DSTs are underestimated by the model comparing the field-estimated rate (i.e., the ratio is less than one). Again, these eight tanks have relatively low generation rates (below 70 L/day) except for DST 241-AN-103, which has a rate of 195 L/day with the ratio of 0.95. Overall the model-predicted rates agree very well, within a factor of three, with field-estimated rates.

3.0 METHODOLOGY TO ESTIMATE STEADY-STATE FLAMMABILITY LEVEL

This chapter describes the methodology used to evaluate the steady-state flammability level in the dome space for all DSTs and SSTs. The methodology also provides a technical basis for flammable gas controls in tank farm operations. The evaluation will address the flammability level in the dome space under both normal and off-normal ventilation conditions. In the evaluation, the steady-state gas release rates and ventilation rates are needed to derive the steady-state gas concentration under given ventilation conditions. Based on the flammable gas concentrations, the level of flammability of the mixture can be calculated. Under current normal ventilation conditions, the steady-state flammability level in the tank dome space is below 25% of the LFL for all tanks (HNF-3294, *Adequacy of Ventilation Rates to Remediate Flammable Gas Levels in Headspace of Hanford Tanks – Status Report*). The primary evaluation is focused on the flammable gas level under off-normal ventilation conditions.

The major gases of concern were identified as hydrogen, ammonia, nitrous oxide, and methane in the tank dome space. Among these identified gases, hydrogen is the primary flammable gas in the tank dome space. The gas release rate of hydrogen in the dome space can be determined by subtracting the gas accumulation rate from the generation rate calculated with the rate equation model described in Chapter 2.0. The other two flammable gases, ammonia and methane, have much lower concentrations in the dome space and have no general model for calculating their gas generation rates; therefore, the steady-state gas release rates for ammonia and methane are estimated by their steady-state gas concentrations under normal ventilation conditions. Nitrous oxide is an oxidizer; the concern is whether its concentration is high enough to lower the LFL of hydrogen, ammonia, and methane as established in air. The gas release rate of nitrous oxide also is derived by the steady-state gas concentration under normal ventilation conditions.

To evaluate the flammable gas level, a time-dependent gas concentration model was established. This model can calculate the steady-state flammability level for a given ventilation condition. The model also can estimate the time required to reach certain flammability levels in the dome space under different ventilation conditions and calculate the minimum ventilation rate to keep the dome space below the specified flammability limit.

3.1 LOWER FLAMMABILITY LIMITS

The National Fire Protection Agency codes require that operations be terminated when the concentration of flammable gases exceeds 25% of the LFL. Based on the empirical rule developed by Le Chatelier in the late 19th century, the LFL of mixtures of multiple flammable gases in air can be determined. Le Chatelier's rule (*Limits of Flammability of Gases and Vapors*, [Coward and Jones 1952]) can be written in terms of the LFL concentration of the fuel mixture, LFL_m , as follows:

$$LFL_m = \frac{100}{\sum_i^n \left(\frac{C_i}{LFL_i} \right)} \quad (3-1)$$

where:

C_i = volume percent of fuel gas i in the fuel gas mixture
 LFL_i = volume percent of fuel gas i at its LFL in air alone.

In the tank dome space, hydrogen gas, ammonia, and methane are the flammable gases of concern. For tank waste conditions, the volume percents of the flammable gases vary over time depending on individual flammable gas release rate in the tank head space, and thus, Equation 3-1 cannot apply directly. WHC-SD-WM-ES-219, *Laboratory Flammability Studies of Mixtures of Hydrogen, Nitrous Oxide, and Air*, has shown experimentally that the total flammability level LFL_f (the fraction of the LFL) of a mixture of hydrogen, ammonia, and methane in an air-nitrous oxide atmosphere can be computed using the principle of Le Chatelier's rule in terms of the individual fuel gas flammability as in Equation 3-2.

$$LFL_f = \frac{[H_2]}{LFL_{H_2}} + \frac{[NH_3]}{LFL_{NH_3}} + \frac{[CH_4]}{LFL_{CH_4}} \quad (3-2)$$

where:

$[H_2]$ = volume percent of hydrogen in the tank headspace
 $[NH_3]$ = volume percent of ammonia in the tank headspace
 $[CH_4]$ = volume percent of methane in the tank headspace
 LFL_{H_2} = volume percent of hydrogen at its LFL in air alone
 LFL_{NH_3} = volume percent of ammonia at its LFL in air alone
 LFL_{CH_4} = volume percent of methane at its LFL in air alone.

For simplicity, in Equation 3-2, flammable gases with concentrations lower than that of methane are omitted. The flammability of the individual gases in air is fairly well characterized. The LFL_{H_2} , LFL_{NH_3} and LFL_{CH_4} are 4, 15, and 5%, respectively, at the upward propagation LFL, which is more conservative than the downward propagation LFL. In addition to the flammable gases included in Equation 3-2, nitrous oxide was observed in the tank dome space. Nitrous oxide plays the role of oxidizer in the mixture and has the potential to decrease the amount of fuel required to reach the LFL. The effect of the multiple oxidizers (e.g., N_2O and O_2) was not addressed in Equation 3-2.

Pfahl and Shepherd (1997) from the California Institute of Technology have conducted a series of flammability studies on gas mixtures generated from Hanford Site tank waste. The studies show that the established LFLs of individual fuels in the air will decrease if concentrated N_2O is present in the mixtures. For example, in the mixture NH_3 - N_2O -air with a ratio of 13.2-19.8-67.0, the system will be flammable, although the ammonia volume percent is 13.2 and is lower than the LFL_{NH_3} of 15% in air. This fuel-oxidizer mixture will be flammable with the ammonia volume percent as low as 8% if the N_2O concentration is 65%. For NH_3 - N_2O -air mixtures,

Pfahl and Shepherd (Figure 32 in 1997 report) suggest that the ammonia flammability limit will be 15% if the N_2O does not exceed 8%. These test results are for turbulent conditions, with an ignition energy of 8 J. For a CH_4 - N_2O -air mixture, the data show that the ratio of 4.5-10.1-85.4 is not flammable. For an H_2 - N_2O -air mixture, the data show that a mixture with the ratio of 5.7-10-84.3 has incomplete combustion. It should be noted here that the ignition energy of 8 J used in these experiments is very large compared to the energy in most electrostatic discharge sparks (typically a few millijoules) that might occur inside a Hanford Site tank.

This information suggests that the flammability limit established in the fuel-air mixture for each gas will not be reduced unless the N_2O volume percent exceeds 8%. In this evaluation, the volume percents of 4, 15, and 5% will be used for LFL_{H_2} , LFL_{NH_3} and LFL_{CH_4} , respectively, in Equation 3-2. In each case, the concentration of nitrous oxide was evaluated and did not exceed 8%, therefore, the oxidizer effect of lowering these flammability limits can be ignored.

3.2 VENTILATION CONDITIONS IN TANK DOME SPACE

Under normal operating conditions, the ventilation conditions can be active ventilation or passive ventilation. The tank dome spaces of all DSTs and some SSTs are equipped with an active ventilation system. For active ventilation systems, the main ventilation flow is designed to go through an installed inlet filter. The 241-AP Tank Farm is an exception to this system; inlet air flows through cover blocks or gaps in riser covers, and other tank openings. The size of the inlet openings was designed to be either fully adjustable or to have just an on-off valve. These filtered inlets are used to control the ventilation rate and to adjust the negative pressure to prevent leakage of tank hazardous materials or to provide control for any other operational needs. For passively ventilated tanks, the ventilation flow goes mainly through high-efficiency particulate air (HEPA) breather filters. Under normal operating conditions, the active ventilation rates range from 100 to 700 ft^3/min , while the passive ventilation rates typically range from 0.5 to 10 ft^3/min . On actively ventilated tanks, the off-normal operating ventilation condition considered in the flammability assessment is that the ventilation system is shut down and the air inlet is closed; on passively ventilated tanks, the HEPA breather filter isolation valve is closed or a blank is installed. For these conditions, the only venting flow is through the gaps between the cover blocks or riser covers. The off-normal condition allows three possible tank ventilation conditions: no ventilation flow, ventilation flow caused only by barometric breathing, or ventilation flow caused by natural breathing, which is a combination of ventilation by barometric breathing plus thermal convection. The barometric breathing rate, V_{bb} , is estimated as 0.45% of the dome space volume per day (WHC-EP-0651, *Barometric Pressure Variations*) and is given in Equation 3-3:

$$V_{bb} = 0.45\% \cdot Vol_{headspace} \left(\frac{ft^3}{day} \right) \quad (3-3)$$

where:

$Vol_{headspace}$ = volume of the tank dome space (ft^3).

During off-normal operating conditions, the most likely ventilation rate is either natural breathing or barometric breathing. The natural breathing rate is estimated to be 5 to 10 times the barometric breathing rate, but the estimation of the thermal convection flow is not available. In general, the zero-flow condition is considered to be impossible because of the many openings into the tanks. However, since 1980, a great effort has been made to seal off the openings as much as possible for SSTs under the interim stabilization project to prevent water intrusion. In this evaluation, the barometric breathing rate, which is more conservative but reasonable, will be used for the ventilation rate for DSTs when normal ventilation is not present. For SSTs, both barometric breathing rate and zero ventilation rate will be evaluated under off-normal ventilation condition. As shown in the calculations later, there is not much difference between the zero and barometric breathing rate in terms of time to reach 25% and 100% of the LFL because the barometric breathing rate is very small and close to zero. Using a tracer gas, the measured passive ventilation rates (PNNL-11925, *Waste Tank Ventilation Rates Measured with A Tracer Gas Method, Fiscal Year 1998 Summary*) under normal ventilation conditions in SSTs ranged from 1.7 to 10 ft³/min for most tanks. No similar measurements for the passive rates (i.e., the active ventilation system is shut down with the air-inlet open) are available for DSTs. Unfortunately, no ventilation rate measurements have been made for the condition where the air inlet is shut off. For the off-normal condition, based on Equation 3-3, the calculated barometric breathing rate for most tanks is around 0.5 ft³/min or less (as shown in Table D-2 of Appendix D), which is one-third to one-twentieth of normal conditions.

3.3 TIME-DEPENDENT GAS CONCENTRATION MODEL

An equation was developed to calculate the time-dependent flammable gas concentration in the dome space. The concentration is a function of the gas release rate and the ventilation rate. Figure 3-1 shows a simplified tank dome space system.

In general, most of the tanks contain supernatant liquid and sludge/saltcake layers. A few tanks, including DST 241-AN-103, have a thin crust layer above the supernatant liquid. The gas release rate (R_g) is the net result of the generation rate (G_r) and the accumulation rate (A_r). The gas accumulation rate refers to the rate at which gas is trapped in the sludge/saltcake layer. The ventilation flows (V_r) are available as field measurements taken at the output streams. These flows are the sum of air inflows from the inlets and tank cracks and openings and the gases released from tank waste. The gas volume change rate can be formulated from a mass balance as provided in Equation 3-4:

$$\begin{array}{l} \text{Gas Change Rate in} \\ \text{Tank Dome Space} \end{array} = \begin{array}{l} \text{Gas Release Rate from} \\ \text{the Waste Surface} \end{array} - \text{Gas Exit Rate} \quad (3-4)$$

Equation 3-4 can be changed to calculate the gas volume change rate for SSTs where the tank dome is made of concrete. Assuming that there is no ventilation flow available but the gas can diffuse out through the concrete dome, then the "Gas Exit Rate" term in Equation 3-4 is changed to the gas diffusion rate.

Figure 3-1. A Simplified Tank System for Time-Dependent Gas Concentration Model.

3.3.1 Insoluble Gas

For the less soluble gases such as hydrogen or methane, the gas release rate can be considered to be constant; therefore, the mass balance equation can be written as a differential equation as given in Equation 3-5:

$$Vol \frac{\partial [C_g]}{\partial t} = R_g - V_r \cdot [C_g] \quad (3-5)$$

where:

- $[C_g]$ = gas concentration (volume percent)
- Vol = volume of the tank dome space (volume)
- R_g = gas release rate from the waste surface (volume/time)
- V_r = ventilation rate in the dome space (volume/time).

As given in Equation 3-5, the gas exhaust rate is simply the gas concentration times the output ventilation rate. By solving the differential Equation 3-5, a time-dependent gas concentration at time t , $[C_g](t)$, in units of volume percent is given in Equation 3-6:

$$[C_g]_{\%}(t) = [C_g]_{\%}(t_0) \exp(-\lambda t) + \left[\frac{R_g}{V_r} \right]_{\%} [1 - \exp(-\lambda t)] \quad (3-6)$$

with

$$\lambda = V_r / \text{Vol}$$

where:

- R_g = hydrogen release rate from the waste surface (volume/time)
- V_r = ventilation rate in the dome space (volume/time)
- $[C_g](t_0)$ = initial gas concentration at time t (volume percent)
- Vol = volume of the tank dome space (volume)
- λ = decay parameter from the venting (inverse time)
- t = time.

In Equation 3-6, the first term represents how the initial gas concentration decays away exponentially with the factor of $e^{(-\lambda t)}$ and second term represents how the gas level builds up in the form of $[R_g/V_r]_{\%}$ with the factor of $[1 - e^{(-\lambda t)}]$ as time goes on.

For the case of gas exiting by the diffusion effect through the dome, the mass balance equation can be written as a differential equation as given in Equation 3-6a:

$$\text{Vol} \frac{\partial [C_g]}{\partial t} = R_g - A \times Q = R_g - A \times \frac{1}{\sum_i \frac{L_i}{D_i}} \times ([C_g] - [C_o]) \quad (3-6a)$$

where:

- $[C_g]$ = gas concentration in the tank headspace (volume percent)
- $[C_o]$ = gas concentration outside the tank (volume percent)
- Vol = volume of the tank dome space (volume)
- R_g = gas release rate from the waste surface (volume/time)
- Q = the diffusion flux (concentration/area-time)
- A = the area of the dome to diffuse (area)
- D_i = the i th layer effective diffusivity (area/time)
- L_i = the thickness of the i th layer to diffuse (length).

As given in Equation 3-6a, the gas exhaust rate is the gas diffusion rate, which is the diffusion flux, Q_i , times the surface area of the dome. The diffusion flux is defined as the simply the gas concentration gradient between the dome space and outside over the path-length for diffusion times the diffusivity. The summation of the diffusion rates in Equation 3-6a accounts for several diffusion resistances in series (e.g. paint, concrete, and soil for a transfer structure wall). Assuming the gas concentration outside is diluted infinitely becoming zero. By solving the

differential Equation 3-6a, a time-dependent gas concentration at time t , $[C_g](t)$, in units of volume percent is given in Equation 3-6b:

$$[C_g]_{\%}(t) = [C_g]_{\%}(t_0) \exp(-\lambda t) + \left[\frac{R_g}{A \times \frac{1}{\sum_i \frac{L_i}{D_i}}} \right] [1 - \exp(-\lambda t)] \quad (3-6b)$$

with

$$\lambda = A \times [1/\sum (L_i/D_i)]/\text{Vol}$$

where:

- R_g = hydrogen release rate from the waste surface (volume/time)
- V_r = ventilation rate in the dome space (volume/time)
- $[C_g](t_0)$ = initial gas concentration at time t (volume percent)
- Vol = volume of the tank dome space (volume)
- λ = decay parameter from the diffusion (inverse time)
- t = time.

3.3.2 Soluble Gas

For a highly soluble gas, such as ammonia, the gas release rate from liquid waste is not a constant, but depends on the material transport properties and the ammonia concentration gradient between the liquid and vapor phases and appropriate Henry's Law constants. Thus the differential equation of mass balance in Equation 3-5 and the time-dependent gas concentration Equation 3-6 have different formats. For a closed system, Henry's Law describes the relationship of a soluble gas in the liquid and vapor phases as provided in Equation 3-7:

$$C_l = K_H \cdot P_g \quad (3-7)$$

where:

- C_l = ammonia concentration in the liquid phase (kg-mole/m³)
- K_H = Henry's Law constant (kg-mole/m³-atm)
- P_g = partial pressure of the ammonia (atm).

The Henry's Law constant is a function of temperature in pure water. In mixed salt solutions, Henry's Law constants are functions of both temperature and the concentrations of the ions in the solution. "The Estimation of Gas Solubility in Salt Solutions at Temperature from 273 K to 363 K," AICHE Journal (Weisenberger and Schumpe 1996), provides a formula to calculate Henry's Law constant as given in Equation 3-8:

$$K_H = K_H^o \cdot 10^{-\sum_i (h_i + h_g) \cdot C_i} \quad (3-8)$$

with

$$K_H^o = e^{(-8.0964 + 3917.5/T - 0.00314T)}$$

where:

- K_H^o = Henry's Law constant in the pure water (kg-mole/m³-atm)
- h_i = ionic dependent coefficient
- h_g = gas specific constant for ammonia
- C_i = ion concentration in the solution
- T = temperature of waste (K).

However, the Weisenberger and Schumpe (1996) formula is good only for the solution up to 5 M. RPP-4941 reported Henry's Law constants for DST 241-SY-101 simulant waste at different dilution conditions and temperatures. This study covers solution concentrations ranging from 5 to 21 M at temperatures of 20 °C to 70 °C. These results provide a correction factor to the calculated Henry's Law constant from the Weisenberger and Schumpe (1996) formula. For example, the measured Henry's Law constant is five times the calculation from the Weisenberger and Schumpe (1996) formula for the undiluted sample of 21 M at 70 °C.

For soluble gas, the gas release rate depends on the equilibrium mechanism between the liquid and vapor phases described earlier. A comprehensive soluble gas transfer methodology applied to Hanford Site waste has been described in RPP-4941.

Consider the two-film theory of gas transfer. The ammonia release will encounter the resistance from two films, the liquid film and the gas film, between the bulk liquid and bulk vapor phases. The release rate is proportional to the difference between the ammonia liquid concentration and the ammonia vapor concentration before reaching equilibrium. It also is proportional to the mass transport coefficient, h , and the effective area, A . Therefore, the release rate can be derived as provided in Equation 3-9:

$$R_g = h \cdot A \cdot (C_l - C_l^{EQ}) = h \cdot A \cdot (C_l - K_H \cdot P_g) = h \cdot A \cdot (C_l - K_H \cdot P \cdot \nu \cdot C_g) \quad (3-9)$$

where:

- h = overall mass transport coefficient from liquid to vapor (m/sec)
- A = effective area for the transport (m²)
- C_l^{EQ} = corresponding liquid ammonia concentration in equilibrium at the current ammonia vapor pressure (kg-mole/m³)
- C_l = current ammonia concentration in liquid (kg-mole/m³)
- P_g = ammonia gas partial pressure (atm)
- P = dome space total pressure (atm)
- ν = specific molar volume of gas in the dome space (m³/kg-mole)
- C_g = current ammonia concentration in the dome space (volume percent)
- K_H = Henry's Law constant (kg-mole/m³-atm).

As Equation 3-9 shows, the ammonia gas release rate clearly is a function of the ammonia concentrations in the liquid and vapor phases and the Henry's Law constant for ammonia in the solution. In the two-film-theory of gas transfer, the overall mass transport coefficient h contains the transport coefficient h_l for gas through the liquid film and h_g for the gas through the gas film. Equations of the calculated h are described in detail in RPP-4941 and summarized in Appendix E.

A sensitivity study indicates that the overall mass transport coefficient, h , varies by several factors, while the effective tank waste surface area, A , for mass transport is difficult to determine, particularly for the SSTs, where the waste surfaces are mostly crusts. Dome space ammonia concentrations would be overestimated by several orders of magnitude if the full area for the SST is used as the effective transport surface. As discussed in Section 3.4, however, the product of h and A can be determined by field data at steady-state conditions. Once h times A is determined, the gas release rate can be calculated by Equation 3-9. Applying the ammonia release rate from Equation 3-9 to the mass balance in Equation 3-5 results in Equation 3-10:

$$Vol \frac{\partial [C_g]}{\partial t} = h \cdot A \cdot (C_l - K_H \cdot P \cdot v \cdot C_g) - [V_r] \cdot [C_g] \quad (3-10)$$

Dividing by Vol and rearranging the terms, Equation 3-10 becomes Equation 3-11:

$$\frac{\partial [C_g]}{\partial t} = k_2 - k_1 \cdot [C_g] \quad (3-11)$$

with $k_1 = [V_r + h \cdot A \cdot K_H \cdot P \cdot v] / [Vol]$

and $k_2 = [h \cdot A \cdot C_l] / [Vol]$.

The solution of Equation 3-11 is given as Equation 3-12:

$$[C_g](t) = [C_g](t_0) \exp(-k_1 \cdot t) + \left[\frac{k_2}{k_1} \right] [1 - \exp(-k_1 \cdot t)]. \quad (3-12)$$

3.4 STEADY-STATE GAS CONCENTRATION AND GAS RELEASE RATE

For insoluble gas, when the systems reach steady state (set time, t , to infinity in Equation 3-6), the exponential term drops out from Equation 3-6 and a steady-state gas concentration is given in Equation 3-13:

$$[C_g]_{\%}^{ss} = \left[\frac{R_g}{V_r} \right] \times 100 \quad (3-13)$$

where:

$$\begin{aligned} [C_g]_{\%}^{ss} &= \text{steady-state gas concentration (volume percent)} \\ R_g &= \text{gas release rate (volume/time)} \\ V_r &= \text{ventilation rate in the dome space (volume/time)}. \end{aligned}$$

Using Equation 3-13, the steady-state gas concentrations in the tank dome space can be calculated by knowing the gas release rate and the ventilation rate.

The gas release rate, R_g , can be estimated by subtracting the gas accumulation rate from the gas generation rate as shown in Equation 3-14:

$$R_g = G_r - A_r \quad (3-14)$$

where:

$$\begin{aligned} G_r &= \text{gas generation rate from waste (volume/ time)} \\ A_r &= \text{gas accumulation rate due to gas trapping (volume/ time)}. \end{aligned}$$

For hydrogen, the generation rate can be calculated using the empirical rate equation described in Section 2.1. The accumulation rate (HNF-3851) can be determined in the field, based on the waste level change rate and the gas composition data from the retained gas sampler. If the waste level does not change noticeably, the hydrogen release rate will be the same as the HGR.

For other insoluble gases, no gas generation rate model is available. Therefore, the steady-state gas release rate can be estimated from the known steady-state concentration in the dome space under normal ventilation conditions by rearranging Equation 3-13 as shown in Equation 3-15:

$$R_g = \left(\frac{[C_g]_{\%}^{ss}}{100} \right) \cdot V_r \quad (3-15)$$

where:

$$\begin{aligned} [C_g]_{\%}^{ss} &= \text{steady-state gas concentration (volume percent)} \\ R_g &= \text{gas release rate (volume/time)} \\ V_r &= \text{ventilation rate in the dome space (volume/time)}. \end{aligned}$$

In this report, the gas release rates for methane and nitrous oxide were obtained from their steady-state concentrations under normal ventilation conditions using Equation 3-15. Then the calculated gas release rate was used to calculate the steady-state concentrations for off-normal conditions. This methodology is a reasonable way to determine methane concentrations under off-normal conditions because methane is insoluble and whatever gases are generated are released directly to the dome space.

For highly soluble gases, from Equation 3-12, the steady-state concentration can be expressed as Equation 3-16:

$$[C_g]^{ss} = \left[\frac{k_2}{k_1} \right] = \left[\frac{h \cdot A \cdot C_l}{V_r + h \cdot A \cdot K_H \cdot P \cdot v} \right] \quad (3-16)$$

As discussed in Section 3.3, the mass transport properties, the product of h and A , are difficult to estimate directly from tank waste properties, particularly for tank waste covered with an irregular crust layer. However, for the known steady-state vapor concentration C_g^{ss} , the liquid concentration C_l , along with Henry's Law constant and the ventilation rate V_r , the product of h and A can be determined. By rearranging Equation 3-16, the product of h and A can be expressed as Equation 3-17:

$$h \cdot A = \left[\frac{C_g^{ss} \cdot V_r}{(C_l - K_H \cdot P \cdot v \cdot C_g^{ss})} \right] \quad (3-17)$$

Once the product of h and A is determined from the steady state under normal ventilation conditions, the steady-state concentration under off-normal condition can be calculated using Equation 3-16. In addition, under the off-normal ventilation conditions, the ammonia concentration can be estimated using the time-dependent gas concentration of Equation 3-12, as well as the gas release rate of Equation 3-9.

Note that the product of h and A depends on the waste configuration and will be different if the waste is perturbed or changed physically. For the off-normal ventilation calculations, the overall steady-state ammonia concentration is governed by the liquid ammonia concentration. The product of h and A will change only the ammonia release rate, which indicates how fast the system will reach the steady state.

The steady-state flammability evaluation of this work is based on current tank waste data at storage conditions. For those tanks actively receiving waste, including DSTs 241-AP-108 and 241-AN-101 as dilute receiver tanks, the flammability level will be reevaluated during the waste transfer compatibility assessment based on the predicted post-transfer condition of the tank waste. For hydrogen, the release rate still can be calculated based on the predicted tank waste condition using this rate equation model. For methane, because steady-state methane vapor data are not available before the waste transfer, the release rate will be estimated as 10% of the model-calculated HGR. This is a reasonable estimate because, for all tanks, methane is less than 10 volume percent of the hydrogen in the generated gas as given in the gas generation study by PNNL-12181 and retained gas sampler results in PNNL-13000, *Retained Gas Sampling Results for the Flammable Gas Program*. For ammonia, instead of estimating the release rate, the ammonia vapor concentration at thermodynamic equilibrium for a given waste condition will be used as a bounding value in the flammability level evaluation. This ammonia vapor concentration can be calculated based on the measured liquid ammonia concentration and other tank waste conditions using Henry's Law and the Weisenberger and Schumpe (1996) model as

described earlier. For the off-normal ventilation condition, which is about 0.5 ft³/min or less, an equilibrium prediction of the ammonia concentration is reasonable and conservative.

3.5 TIME TO REACH LOWER FLAMMABILITY LIMIT

For active ventilation system interruptions, the time for the dome space to build up to flammable gas concentrations exceeding the LFL is one of the main concerns of this evaluation.

A time-dependent flammability level, $LFL_f(t)$ of the mixture can be calculated using the time-dependent gas concentration (Equation 3-6 for insoluble gas or Equation 3-12 for soluble gas) and Le Chatelier's rule (Equation 3-2) as provided in Equation 3-18:

$$LFL_f(t) = \frac{[H_2](t)}{LFL_{H_2}} + \frac{[NH_3](t)}{LFL_{NH_3}} + \frac{[CH_4](t)}{LFL_{CH_4}} \quad (3-18)$$

where:

$[H_2](t)$	= hydrogen concentration (volume percent) at time t
$[NH_3](t)$	= ammonia concentration (volume percent) at time t
$[CH_4](t)$	= methane concentration (volume percent) at time t
LFL_{H_2}	= volume percent of hydrogen at its LFL in air alone
LFL_{NH_3}	= volume percent of ammonia at its LFL in air alone
LFL_{CH_4}	= volume percent of methane at its LFL in air alone.

The volume percent of the LFLs; LFL_{H_2} , LFL_{NH_3} , and LFL_{CH_4} are 4, 15, and 5%, respectively, which have been established for a fuel-air mixture.

The time to reach a specified gas concentration under given ventilation conditions for insoluble gas can be obtained by rewriting Equation 3-6 as Equation 3-19:

$$t = \frac{\ln \left\{ \frac{R_g - V_r \cdot C_g(t_0)}{R_g - V_r \cdot C_g(t)} \right\}}{\lambda} \quad (3-19)$$

with

$$\lambda = V_r / Vol$$

where:

R_g	= gas release rate (volume/time)
V_r	= barometric breathing rate (volume/time)
$[C_g](t_0)$	= initial gas concentration at time t_0 (volume percent)
$[C_g](t)$	= gas concentration at time t (volume percent).

Similarly, for soluble gases, the time to reach a specified gas concentration under a given ventilation condition can be obtained by rewriting Equation 3-12 as Equation 3-20:

$$t = \frac{\ln \left\{ \frac{k_2 - k_1 \cdot C_g(t_0)}{k_2 - k_1 \cdot C_g(t)} \right\}}{k_1} \quad (3-20)$$

with $k_1 = [V_r + h \cdot A \cdot K_H \cdot P \cdot v] / [Vol]$

and $k_2 = [h \cdot A \cdot C_l] / [Vol]$.

However, the time to reach a specified flammability limit of the mixture was not calculated explicitly. A customized Excel macro function, which was developed using Visual Basic⁷ and is based on Equation 3-19 for an insoluble gas and Equation 3-20 for a soluble gas, is used to calculate the time to reach a specific flammability limit.

3.6 THE MINIMUM VENTILATION RATE TO MAINTAIN DOME SPACE BELOW 25 OR 100 PERCENT OF THE LOWER FLAMMABILITY LIMIT

Whether the dome space of a tank will reach the specified flammability limit or not depends on the competition between the gas release rates and the ventilation rates of the system. For steady state, the flammability level as the fraction of the LFL of the mixture in the dome space can be calculated using Equation 3-2. For insoluble gas, the required steady-state gas concentrations in Equation 3-2 can be calculated using Equation 3-13 for insoluble gas and Equation 3-16 for soluble gas, where the ventilation rate is embedded in both equations. If the ventilation rate is zero (i.e., no gas exits the tank), the system will reach the LFL sooner or later, and then flammability will continue to increase beyond 100% of the LFL. The ventilation will reduce the steady-state concentration. A ventilation rate, defined as the minimum vent rate, which the steady-state concentrations will just reach the specified flammability limit using Equation 3-2 for parameters in Equations 3-13 and 3-16. If the dome space ventilation rate is larger than this minimum, the system will never reach the specified flammability limit. Again, the ventilation rate is embedded in the equation, and a customized Excel macro function developed using Visual Basic code is used to calculate the minimum ventilation needed to stay below the specified flammability limit.

⁷ Visual Basic is a registered trademark of Microsoft Corporation.

3.7 TIME-DEPENDENT GAS CONCENTRATION UNDER ZERO VENTILATION CONDITION

For insoluble gas, under zero ventilation, the mass balance equation (Equation 3-5) can be rewritten as Equation 3-21:

$$Vol \frac{\partial [C_g]}{\partial t} = R_g \quad (3-21)$$

where:

- $[C_g]$ = gas concentration (volume percent)
- Vol = volume of the tank dome space (volume)
- R_g = gas release rate from the waste surface (volume/time).

By solving the differential Equation 3-21, a time-dependent gas concentration at time t , $[C_g]_{\%}(t)$, in the unit of volume percent is given in Equation 3-22:

$$[C_g]_{\%}(t) = [C_g]_{\%}(t_0) + \left[\frac{R_g}{Vol} \cdot t \right]_{\%} \quad (3-22)$$

where:

- R_g = gas release rate from the waste surface (volume/time)
- $[C_g]_{\%}(t_0)$ = initial gas concentration at time t (volume percent)
- Vol = volume of the tank dome space (volume).

In Equation 3-22, $[C_g]_{\%}(t_0)$ represents initial gas concentration and $[R_g t / Vol]_{\%}$ represents how the gas level builds up as time goes on. In the actual calculation in Chapter 4.0, the gas concentration was calculated analytically as shown in Equation 3-23 instead of as shown in Equation 3-22, because the hydrogen release rate is variable as time progresses rather than a fixed value. This is because the tank waste heats up under the zero ventilation condition and the hydrogen release rate increases.

$$[C_g]_{\%}(t) = [C_g]_{\%}(t_0) + \sum_{t=0}^t \left[\frac{R_g(t)}{Vol} \cdot t \right]_{\%} \quad (3-23)$$

The summation of gas concentration in the second term on the right side of Equation 3-23 is calculated in the time step of 1 day. As shown in Chapter 4.0, the time step of 1 day is a reasonable choice considering the change of HGR for the temperature increase rates used.

For a highly soluble gas such as ammonia, the mass balance in Equation 3-10 can be rewritten for the zero ventilation condition as shown in Equation 3-24:

$$Vol \frac{\partial [C_g]}{\partial t} = h \cdot A \cdot (C_i - K_H \cdot P \cdot v \cdot C_g) \quad (3-24)$$

where:

h	=	overall mass transport coefficient from liquid to vapor (m/sec)
A	=	effective area for the transport (m^2)
C_l	=	current ammonia concentration in liquid (kg-mole/ m^3)
P	=	dome space total pressure (atm)
ν	=	specific molar volume of gas in the dome space (m^3 /kg-mole)
C_g	=	current ammonia concentration in the dome space (volume percent)
K_H	=	Henry's Law constant (kg-mole/ m^3 -atm).

Dividing by Vol and rearranging the terms, Equation 3-24 becomes Equation 3-25:

$$\frac{\partial[C_g]}{\partial t} = g_2 - g_1 \cdot [C_g] \quad (3-25)$$

with

$$g_1 = \frac{[h \cdot A \cdot K_H \cdot P \cdot \nu]}{Vol}$$

and

$$g_2 = \frac{[h \cdot A \cdot C_l]}{Vol}$$

The solution of Equation 3-25 is given as Equation 3-26:

$$[C_g](t) = [C_g](t_0) \exp(-g_1 \cdot t) + \left[\frac{g_2}{g_1} \right] [1 - \exp(-g_1 \cdot t)] \quad (3-26)$$

In some cases, particularly when hA is large, the $g_1 t$ is much greater than one in a few days. So the decay rate $\exp(-g_1 \cdot t)$ goes to zero in a few days, thus the vapor concentration is simply the vapor equilibrium concentration C_{eq} with liquid phase as shown in Equation 3-27:

$$C_{eq} = \frac{C_l}{K_H \cdot P \cdot \nu} \quad (3-27)$$

3.8 TANK WASTE TEMPERATURE INCREASE RATE

Under normal operation, tank waste temperature ranged from an ambient temperature as low as 15 °C up to 78 °C. This tank waste temperature range reflected seasonal temperature changes, which oscillate up and down throughout the year. During the off-normal operation, however, the tank waste temperature could increase due to the loss of active or passive ventilation. For DSTs, the tank waste temperature could increase even more if the ventilation of the annulus is shut down. For example, the tank waste temperature of DST 241-AY-102 increased 13 °F in one month while the annulus ventilation was shut down. It is known that the flammable gas generation rate is a function of temperature. In the HGR model (HNF-3851), the thermolysis

rate and the organic G value of the radiolysis rate are an exponential function of temperature. In this section, a simple and conservative heat transfer model (RPP-6213), used in evaluation of the steam bump hazard, is used for tank waste temperature increase analysis in the gas generation rate calculations and is described below.

With the tank under the zero ventilation condition, the temperature change with time can be estimated using a lumped capacitance solution for the transient waste temperature as shown in Equation 3-28:

$$(\rho_{ncl} \cdot V_{ncl} \cdot c_{ncl} + \rho_{cl} \cdot V_{cl} \cdot c_{cl}) \frac{\partial T}{\partial t} = Q - \frac{k_s \cdot A \cdot (T - T_{\infty,s})}{R} - \frac{k_s \cdot A \cdot (T - T_{\infty,a})}{\delta} \quad (3-28)$$

where:

- V_{ncl} = volume of the nonconvective layer (m^3)
- ρ_{ncl} = density of the nonconvective layer (kg/m^3)
- c_{ncl} = specific heat of the nonconvective layer ($\text{J}/\text{kg}\cdot\text{K}$)
- V_{cl} = volume of the convective layer (m^3)
- ρ_{cl} = density of the convective layer (kg/m^3)
- c_{cl} = specific heat of the convective layer ($\text{J}/\text{kg}\cdot\text{K}$)
- Q = tank waste heat load (Watt)
- k_s = soil thermal conductivity ($\text{Watt}/\text{m}\cdot\text{K}$)
- A = tank heat transfer area (m^2)
- T = waste average temperature (K)
- $T_{\infty,s}$ = average ambient soil temperature (K)
- $T_{\infty,a}$ = average ambient air temperature (K)
- δ = soil thickness (m)
- R = tank radius as the length scale for heat conduction from tank bottom to soil (m).

The right side of Equation 3-28 represents the net heat generation rate, which is the total heat source generation rate Q from tank waste minus the downward (second term) and upward (third term) heat transfer rates. For a given tank waste temperature T along with other waste conditions, the temperature increase rate $\partial T/\partial t$ can simply be calculated by dividing the net heat generation rate by the product of mass of waste and waste specific heat using Equation 3-28. The following parameter values were taken from RPP-6213 and apply to all tanks:

- Heat capacity: 3,300 J/kg-K
- Air temperature: 285 K
- Soil temperature: 287 K
- Heat exchange area: 411 m^2
- Soil thermal conductivity: 1 W/m-K
- Soil overburden thickness: 4 m
- Tank radius: 11 m.

Note that Equation 3-28 can be used for tanks having similar waste temperatures for convective and nonconvective layers. For tanks having distinct temperatures between layers (e.g., aging tank waste [241-AY/AZ Tank Farms]), the energy balance equation should be written for each layer as shown in Equations 3-29 and 3-30:

$$\rho_{cl} \cdot V_{cl} \cdot c_{cl} \frac{\partial T_{cl}}{\partial t} = Q_{cl} - \frac{k_s \cdot A}{\delta} (T_{cl} - T_{\infty,a}) + h_{ex} \cdot A \cdot (T_{ncl} - T_{cl}) \quad (3-29)$$

$$\rho_{ncl} \cdot V_{ncl} \cdot c_{ncl} \frac{\partial T_{ncl}}{\partial t} = Q_{ncl} - \frac{k_s \cdot A}{R} (T_{ncl} - T_{\infty,s}) - h_{ex} \cdot A \cdot (T_{ncl} - T_{cl}) \quad (3-30)$$

where:

- T_{cl} = waste temperature of the convective layer (K)
- Q_{cl} = tank waste heat load of the convective layer (Watt)
- T_{ncl} = waste temperature of the nonconvective layer (K)
- Q_{ncl} = tank waste heat load of the nonconvective layer (Watt)
- h_{ex} = heat transfer coefficient for heat exchange between two layers (W/m²/K).

Symbols that are not defined in Equations 3-29 and 3-30 are defined in Equation 3-28. As described in RPP-6213, the heat exchange coefficient was adjusted to meet the quasi-steady approximation in Equation 3-31:

$$\frac{\partial T_{cl}}{\partial t} = \frac{\partial T_{ncl}}{\partial t} \quad (3-31)$$

For the given waste temperatures and other waste conditions, once h_{ex} is determined, the temperature increase rate $\partial T_{ncl}/\partial t$ or $\partial T_{cl}/\partial t$ can be calculated.

As shown in Equations 3-28 to 3-30, this heat transfer model is relatively conservative in terms of overestimating the heat-up rate because it considers only the upward and downward heat transfer but neglects the heat transfer from the sides. Additionally, the temperature increase rates for the convective and nonconvective layers may be different throughout the heatup process while Equation 3-31 assumes they are the same. For example, while DST 241-AY-102 lost annulus cooling in August 2001, it was observed that the temperature increase rate for the convective layer was slower than the temperature increase rate for the nonconvective layer in the first few weeks; in time, the two temperature increase rates got closer. The calculated temperature increase rate (0.27 °C/day from Table H-2 of Revision 3) using Equation 3-31 is comparable, but larger than the rate observed (0.24 °C/day estimated from the temperature data on personal computer interface for SACS) in August 2001. Overall, the temperature data of DST 241-AY-102 validates that the assumption of Equation 3-31 is reasonable and conservative.

This page intentionally left blank.

4.0 EVALUATIONS OF STEADY-STATE FLAMMABILITY LEVEL

In this chapter, steady-state gas releases from the 28 DSTs and 149 SSTs are evaluated quantitatively against tank ventilation conditions using the methodology described in Chapters 2.0 and 3.0 to determine if the resulting flammability level becomes a safety concern.

Section 4.1 contains the calculated HGRs and discusses collection of input data and setup of the Excel spreadsheet for rate calculations. Section 4.2 covers the data collection, estimation of ventilation rates for both normal and off-normal conditions, and the steady-state gas concentrations for the normal ventilation rate. Section 4.3 discusses the steady-state gas release rates for the flammability level evaluation. For hydrogen, the gas release rate is the net result of the model-calculated gas generation rate minus the field-estimated gas accumulation rate. For ammonia, methane, and nitrous oxide, the gas release rates were extrapolated from steady-state concentrations at normal ventilation rates. For those tanks showing higher predicted steady-state ammonia concentrations (more than 0.5%) under off-normal ventilation conditions and flammability levels exceeding 25% of the LFL in Revision 0, the ammonia concentration has been reanalyzed with the liquid/vapor equilibrium model as described in Section 3.4. Section 4.4 describes the evaluation of flammability levels in the tank dome space for all 177 tanks. The evaluations include the following:

- Calculation of total flammability level, as well as the distribution from each flammable gas under both normal and off-normal ventilation conditions
- The time required for the flammable gases concentration in the tank dome space to reach various flammability levels when the normal ventilation system is shut down
- The minimum ventilation rate required to keep the dome space concentration below the specified flammability limit.

Details of the results of the inventory data from BBI and surveillance data from SACS, HGR calculations, ammonia mass transport properties, and flammability evaluations in the tank dome space for the 177 tanks are given in Appendices A through F. Appendices G and H provide flammability evaluation for C-200 series SSTs and DST 241-AY-102, respectively, under special conditions.

4.1 HYDROGEN GENERATION RATE MODEL CALCULATIONS

In the evaluation, the HGR was calculated for each tank based on the semi-empirical rate equation model. The total generation rate was calculated for each waste layer in each tank. The generation rate is a function of tank waste conditions; thus, a large tank waste database is needed. The analytical and surveillance data necessary to perform the rate calculations are available for some tanks. For those tanks without current measured data, process history data and waste type information were used.

An Excel spreadsheet was set up to calculate HGRs for all 177 Hanford Site DSTs and SSTs. The spreadsheet has four sections covering input data (Section 4.1.1), derived data

(Section 4.1.2), and calculated unit rates and total rates (Section 4.1.3). The spreadsheet was set up to allow for easy upgrades and to facilitate checking the rate calculations.

4.1.1 Input Data

The data required to estimate hydrogen generation include the concentrations of TOC, hydroxide, nitrate ion, nitrite ion, sodium ion, and aluminate ion in the liquid phase; the total heat load for plutonium (^{238}Pu , ^{239}Pu , and ^{240}Pu), americium (^{241}Am) cesium (^{137}Cs) and strontium (^{90}Sr); liquid and bulk densities; total solids and supernatant liquid tank waste volumes; the weight percent of water for liquid and sludge layers; tank waste temperature, and the tank dome space temperature. The organic species present provide the source term for thermolysis and organic radiolysis and the TOC data are used as an indicator of organic species. Aluminate is a catalyst in the thermal reaction and the aluminum ion concentration was used in the thermolysis rate calculation. Nitrate, nitrite, and sodium concentrations are used to estimate the scavenger effect for radiolysis of pure water. Also nitrate, nitrite, and hydroxide are used to evaluate the efficiency of hydrogen generation from the corrosion process of tank liner. Tank waste temperature is needed to calculate the radiolysis G-value and to account for the Arrhenius behavior of the thermolysis rate. The cesium and strontium concentrations are used to estimate the heat load from beta/gamma radiation of the tank waste, which is the power source for both water and organic radiolysis. Similarly, plutonium isotopes and americium are used to estimate the heat load from total alpha of the tank, and also function as the power source for both water and organic radiolysis. Weight-percent water data were used to estimate the liquid fraction of the waste because the model considers that gas generation reactions occur most effectively in the liquid phase. The density and waste volume are used to calculate the total mass of the waste and to estimate the wetted tank surface area to calculate the corrosion rates. The temperature in the tank dome space is used to convert the total gas generation rate from mole to volume per unit time.

The BBI, Tank Characterization Database (TCD), and SACS were queried to obtain the required waste properties and compositions. Data missing from the database were estimated, based on the methodology presented in SNL-000198, *Flammable Gas Safety Analysis Data Review*.

In Revision 0 of this report, the input data used were prepared based on data available as of October 1999 and documented in RPP-6069, *Input Data for Hydrogen Generation Rate Model Calculation*. In Revision 7 of this report, the input data of waste compositions including TOC, nitrate ion, nitrite ion, aluminum, cesium, strontium, density, and volume were queried from the BBI detail calculation database, and the preferred density and weight percent water in TWINS (queried on September 17, 2007). Note that the date of data quoted in the parenthesis is referred to as the date of data published, but is not the date of data gathering. The actual cut-off date of the data gathering of April 1, 2007, can be found in the inventory derivation documents. In addition, if the concentrations of TOC, nitrate ion, nitrite ion, and aluminum in liquid phase were not available from the BBI detailed calculations, the values prepared in Revision 0 were used or defaulted to the values in Revision 6, instead.

To extract the information from the BBI detail report to the format of the required input data, several things were done:

- The required data were downloaded from BBI detail calculation database and listed in Appendix A.
- In BBI detail calculations, more than one density was used in a waste layer for a number of tanks. A single representative density labeled as preferred density was chosen for each waste layer for 177 tanks, and the preferred density along with weight percent water data were listed in Appendix A.
- In BBI detail calculations, the multiplier was introduced to compensate for differences in weight-percent water and density when the concentration data came from different data sources for a given waste layer. The concentrations used in the input data of Revision 6 of this report were recalculated by dividing the inventory of each analyte with the preferred density and the waste volume as

$$\text{In BBI:} \quad \text{Inventory} = \text{density} \times \text{Volume} \times \text{Concentration} \times \text{Multiplier} \quad (4-1)$$

$$\text{In this report:} \quad \text{NewConcentration} = \text{Inventory} \div (\text{PreferredDensity} \times \text{Volume}) \quad (4-2)$$

- The input data required the information from the supernatant liquid layer, solid layer (the waste below the supernatant liquid layer), and the total waste. The values of waste composition from various waste types of the solid layer were weight averaged to one value.
- The concentrations of TOC, nitrate ion, nitrite ion, and aluminum in the liquid phase and the liquid density for solid layer were assigned the same value as the supernatant liquid layer if no interstitial liquid data were available. The final waste inventory data are listed in Table B-1 of Appendix B.

In BBI development, the total waste volume is divided into three parts: solid, liquid, and retained gas (if there is any). In the detail calculation report, the volume of retained gas is not reported because it has no contribution to the analytes inventory. Although the retained gas has no contribution to the HGR calculations, it is part of the total waste volume and will impact the headspace volume calculation, and thus the flammability calculations. The reported retained gas volume is included in determining the waste depth and total waste volume for flammability calculations. Table A-3 in Appendix A lists the tanks with reported retained gas inventory from the BBI derivation document in TWINS.

The required temperature data of the tank waste and tank headspace were obtained from SACS for the time period from April 1, 2006 to April 1, 2007. The maximum temperature from April 1, 2006 to April 1, 2007, was used to obtain an averaging temperature within each waste layer (supernatant and solid layers) and the headspace. The maximum value over a one year period throughout the tank was used to cover the seasonal effect. The temperature sensitivity study on the aging waste tanks was performed in Appendix H of Revision 3 of this report to prevent the

possible underestimation of the temperature gradient vertically caused by cooling for using the average value.

With the given tank waste inventory data, physical properties like volume and density, and the waste and headspace temperature data as discussed above, an input data spreadsheet for HGR calculation was prepared and is listed in Table B-1 of Appendix B. For data not available from Appendix A, the information and data from previous revisions of this report are used.

In Revision 0 of this report, missing data were estimated, based on the methodology presented in SNL-000198. Waste tanks were first classified into one of six groups, based on the volumes of the liquid, saltcake, and sludge layers. The criteria for the various tank classifications also are presented in SNL-000198. Data from tanks in a given classification were used to create a distribution that was assumed to describe the total population of data for a given tank classification. This distribution then was used to provide a range of data including the missing data. In cases where insufficient data were available to create a statistically valid distribution, data from similar groups of tanks were combined to create a distribution of data (SNL-000198). For single-point calculations, the mean of the distribution is used to describe the missing values. In Monte Carlo statistical analyses, the full range of data for the tank waste classification was used.

This methodology of providing values and distributions for missing data was not optimized to provide the “best” waste properties or compositions with respect to waste chemical makeup. This methodology was prepared to determine missing data for flammable gas safety analyses. Because sufficient analytical data for all waste types are not available to estimate the missing data at the waste-type level, the methodology in SNL-000198 was used to determine overall composition ranges when a finer resolution of data was not statistically justified. As a result, the mean values used in this analysis were not optimized based on waste characteristics, but were developed to fit the available data related to flammable gas safety analyses.

The SST 241-A-105 HGR has not been calculated. The steel liner leaked and the tank has been interim stabilized. The waste moisture content is unknown, but is expected to be very low. The HGR is very sensitive to moisture content (the main hydrogen source). Because this key parameter is unknown and cannot be estimated, no attempt is made to estimate the corresponding HGR. The input data of DST 241-AY-102 are from the latest core sampling results and the HGRs of the solid layer are calculated by individual segments of the core sampling results. The latest sampling has reflected either depleted (Revision 4 using core 312 data) or very low (Revision 5 using core 319 data) nitrate and nitrite values on the bottom segment in the tank and results in a HGR increase compared to the HGR calculated by the averaged value of the BBI data.

4.1.2 Derived Data

Once the input data were provided, the derived data were calculated before performing the final rate calculations. In the “derived data section” the input data are converted to the system of units used in the equations and other necessary parameters are derived. The derivation includes waste level, the tank surface area wetted by the waste, total mass, liquid fractions of the layers, layer

heat load, layer density, total heat load, conversion of nitrate ion and nitrite ion to units of “moles per liter,” conversion of TOC and aluminum to units of “weight percent,” and water radiolysis and total radiolysis G-values. The purpose of the derived data section is twofold. First, necessary unit conversions were built into the spreadsheet so the spreadsheet can take the input data directly from the TCD. Second, it prepares the necessary parameters, which reduces the cumbersome task of completing the rate calculations and makes error checking easier and more effective. Details of the derived data are provided in Appendix B, Table B-2.

4.1.3 Calculated Hydrogen Generation Rates

The HGRs were calculated for the total tank waste, as well as for different waste layers. The waste layers are the convective layer (supernatant liquid) and the nonconvective layer (sludge/saltcake); a few tanks have a crust layer on top of the convective layer. The rates for each layer are presented as radiolysis rates, thermolysis rates, corrosion rates, and total generation rates in units of mole per kilogram per day and moles per cubic meter per second.

Details of the calculated rates per unit mass or per unit volume are provided in the Appendix B, Table B-3. Note that the unit rate of the corrosion rate is a function of wetted surface area, so the unit volume rate depends on the waste volume. The unit rate from corrosion is an average rate for a given tank waste volume. The total gas generation rate for a tank (in units of cubic feet per minute and liters per day) was calculated by multiplying the unit rates by the total waste volume; the results are provided in Appendix B, Table B-4. Table 4-1 lists the 10 tanks with the highest model-calculated hydrogen generation based on the current waste content.

For the water addition study, the input data are modified by adding 10 kgal of water to 100-series tanks and 1 kgal to 200-series tanks and listed in Appendix B, Table B-5. The required input data listed in Appendix B, Table B-1, are used as the starting point before water addition. It is assumed that the water is well mixed with supernatant, and that the concentration, density, and the weight percent of water of the supernatant are adjusted accordingly by a simple dilution factor. The dilution factor is the ratio between current waste volume and current waste volume plus the volume of 10 kgal and 1 kgal of water for 100- and 200-series tanks.

Table 4-1. Calculated Top Ten Hydrogen Generation Rates In Dome Space for 177 Tanks With Current Waste.

Tank	HGR from radiolysis Grad b/r (cfm)	HGR from radiolysis Grad alpha (cfm)	HGR from thermolysis Gtherm (cfm)	HGR from corrosion Gcorr (cfm)	Percent of HGR from radiolysis (Grad b/r)%	Percent of HGR from radiolysis (Grad alpha)%	Percent of HGR from thermolysis (Gtherm) %	Percent of HGR from corrosion (Gcorr)%	Total HGR from model Gmod (cfm)	Total HGR from model HGRmod (L/day)
241-AZ-102	2.88E-02	2.14E-03	1.57E-03	1.52E-04	88.2%	6.54E-02	4.8%	0.5%	3.27E-02	1332
Supernatant	1.11E-02	3.46E-06	4.22E-04	8.18E-05	95.6%	2.97E-04	3.6%	0.7%	1.17E-02	475
Solid Layer	1.77E-02	2.13E-03	1.15E-03	6.98E-05	84.0%	1.02E-01	5.5%	0.3%	2.10E-02	857
241-AY-102	2.29E-02	6.33E-04	9.74E-04	2.49E-04	92.5%	2.56E-02	3.9%	1.0%	2.48E-02	1009
Supernatant	5.27E-04	5.21E-08	8.73E-04	7.63E-05	35.7%	3.53E-05	59.1%	5.2%	1.48E-03	60
Solid Layer	2.24E-02	6.33E-04	1.01E-04	1.73E-04	96.1%	2.72E-02	0.4%	0.7%	2.33E-02	949
241-AZ-101	1.37E-02	6.45E-04	6.71E-04	1.34E-04	90.4%	4.26E-02	4.4%	0.9%	1.52E-02	618
Supernatant	7.11E-03	3.08E-07	4.02E-04	7.24E-05	93.7%	4.06E-05	5.3%	1.0%	7.59E-03	309
Solid Layer	6.59E-03	6.45E-04	2.69E-04	6.15E-05	87.1%	8.53E-02	3.6%	0.8%	7.56E-03	308
241-AN-102	3.60E-03	2.44E-05	5.17E-03	1.47E-04	40.3%	2.73E-03	57.8%	1.6%	8.95E-03	365
Supernatant	3.05E-03	1.36E-05	4.58E-03	7.92E-05	39.5%	1.76E-03	59.3%	1.0%	7.72E-03	315
Solid Layer	5.53E-04	1.09E-05	5.97E-04	6.73E-05	45.0%	8.86E-03	48.6%	5.5%	1.23E-03	50
241-AN-107	4.01E-03	9.00E-05	2.79E-03	1.49E-04	56.9%	1.28E-02	39.7%	2.1%	7.04E-03	287
Supernatant	2.86E-03	6.28E-05	2.22E-03	7.54E-05	54.8%	1.21E-02	42.5%	1.4%	5.21E-03	213
Solid Layer	1.15E-03	2.72E-05	5.76E-04	7.36E-05	63.0%	1.49E-02	31.5%	4.0%	1.83E-03	74
241-AN-106	6.12E-03	2.71E-04	1.36E-04	2.93E-04	89.7%	3.97E-02	2.0%	4.3%	6.83E-03	278
Supernatant	1.64E-04	5.55E-07	1.17E-04	1.14E-04	41.4%	1.40E-03	29.6%	28.8%	3.97E-04	16
Solid Layer	5.96E-03	2.71E-04	1.89E-05	1.79E-04	92.7%	4.21E-02	0.3%	2.8%	6.43E-03	262
241-SX-105	8.63E-04	2.46E-05	4.77E-03	3.62E-04	14.3%	4.09E-03	79.2%	6.0%	6.02E-03	246
Supernatant	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Solid Layer	8.63E-04	2.46E-05	4.77E-03	3.62E-04	14.3%	4.09E-03	79.2%	6.0%	6.02E-03	246
241-SX-103	6.94E-04	1.43E-05	4.25E-03	3.97E-04	13.0%	2.66E-03	79.3%	7.4%	5.36E-03	218
Supernatant	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA
Solid Layer	6.94E-04	1.43E-05	4.25E-03	3.97E-04	13.0%	2.66E-03	79.3%	7.4%	5.36E-03	218
241-AY-101	4.32E-03	6.53E-04	5.13E-05	2.18E-04	82.4%	1.25E-01	1.0%	4.2%	5.24E-03	214
Supernatant	1.30E-04	1.16E-06	3.18E-05	6.23E-05	57.6%	5.16E-03	14.2%	27.7%	2.25E-04	9
Solid Layer	4.19E-03	6.52E-04	1.95E-05	1.55E-04	83.5%	1.30E-01	0.4%	3.1%	5.02E-03	205
241-AN-104	1.17E-03	9.95E-07	1.61E-03	1.44E-04	40.1%	3.40E-04	55.0%	4.9%	2.92E-03	119
Supernatant	6.85E-04	1.96E-08	8.23E-04	5.24E-05	43.9%	1.26E-05	52.7%	3.4%	1.56E-03	64
Solid Layer	4.87E-04	9.75E-07	7.85E-04	9.19E-05	35.7%	7.15E-04	57.5%	6.7%	1.36E-03	56

Notes:

HGR = hydrogen generation rate.

NA = not applicable.

The generation rates of DSTs 241-AZ-102 and 241-AY-102 are 3.27 E-2 and 2.48 E-2 ft³/min, which are the two highest HGRs among 177 DSTs and SSTs because of high radionuclide concentrations. Due to the gradient in depth for the radionuclide and chemical concentrations, the generation rate of the solid layer for tank 241-AY-102 was calculated by summing the

generation rate of individual layers based on each segment's data from the recent core sampling. Generation rates from radiolysis, thermolysis, and corrosion are listed in Table 4-1 for solid and liquid layers for each tank. The contribution from thermolysis and radiolysis varied from tank to tank. Corrosion contributed 7% or less to the overall HGR for the listed tanks in Table 4-1 except tank 241-SX-103. Tanks without sample-based data use the default data from the waste grouping analysis, which have a larger uncertainty.

4.2 TANK VENTILATION RATES AND STEADY-STATE GAS CONCENTRATIONS

Tank ventilation and steady-state gas concentration data collection and data reduction are documented in RPP-5660, *Collection and Analysis of Selected Tank Headspace Parameter Data*. Ventilation rates at the tank outlet were determined by a number of methods, including tracer studies, Standard Hydrogen Monitoring System hydrogen composition decay curves, direct measurements of hydrogen, and calculations from earlier flammable gas hazard analyses. The ventilation rates were for normal ventilation conditions, either passive or active, in conjunction with steady-state gas concentration data to estimate the gas release rates.

Dome space gas composition data were based on analytical data from RPP-5660, when available. The TWINS database was queried to obtain all gas sample data. The data were reduced using mean values for single-point calculations and derived distributions for Monte Carlo analyses. Values for missing data were determined using the methodology described in SNL-000198. The ventilation rates and the steady-state gas concentrations under normal operating conditions, along with waste volumes and dome space volumes for all 177 tanks, are listed in Appendix D, Table D-1. For sludge tanks, dome space gas concentrations are very small, less than 50 ppm hydrogen, methane, and ammonia. For these tanks, the ratios between the various gases are questionable and are not an accurate analysis of gas generation rates.

4.3 STEADY-STATE GAS RELEASE RATES FOR H₂, NH₃, CH₄, AND N₂O

To evaluate the steady-state flammability levels under different ventilation conditions, the steady-state gas release rates were used to calculate the flammable gas concentrations for a given ventilation condition. For hydrogen, the steady-state release rates were calculated by subtracting the gas accumulation rate from the model calculated generation rate. In this report, the accumulation rates are assumed to be zero because no noticeable waste level increase due to gas accumulation has been reported recently. The HGRs are calculated in Section 4.1 and listed in Appendix B. For all cases, the gas release rate is equal to the model calculated gas generation rate. In the past, a few tanks had a noticeable waste level increase. The waste level increase rate can be converted to a total waste volume increase rate, which then is multiplied by the hydrogen fraction obtained from the retained gas sample analysis. The steady-state gas release rates of CH₄, NH₃, and N₂O were derived from the steady-state concentrations under normal ventilation rates using Equation 3-15. The historical data derived release may be too large compared to the calculated hydrogen generation rate because of the effect of waste transfers. Since the calculated hydrogen generation rate reflects the latest tank inventory data, the calculations of methane release were constrained to no more than 20% of the latest calculated hydrogen generation rate.

of that tank. The calculated gas release rates of H_2 , NH_3 , CH_4 , and N_2O are listed in Appendix D, Table D-1.

For ammonia, however, the method described in the previous paragraph would largely overestimate the steady-state concentrations under off-normal ventilation conditions for those tanks having relatively large release rates calculated from the steady-state concentration. For example, for DST 241-SY-101, the steady-state release rate obtained from the dome space concentration of 400 ppm under normal ventilation conditions predicts a steady-state concentration of 108% of the LFL for the off-normal ventilation condition. This value is two orders of magnitude larger than the current estimated value of 0.4% of the LFL using the liquid-vapor equilibrium mechanism. In Revision 0, similar overestimations of ammonia concentration also were reported for DSTs 241-AN-102 and 241-AN-107.

As described in Chapter 3.0, ammonia is very soluble, and the gas release rate is not a constant but is governed by the liquid-vapor equilibrium defined by Henry's Law, the mass transport coefficient, h , and the effective transport surface area, A . The ammonia release rate is driven by the gradient between the vapor and liquid phases before reaching equilibrium. Therefore, a greater difference results in a larger release rate.

For a closed system (i.e., a zero ventilation rate), the final release rate is zero when the system reaches equilibrium. An open system will never reach the equilibrium concentration, but will reach a steady-state release condition. At steady state, the concentration is lower than the equilibrium value, and the larger the ventilation rate, the lower the steady-state concentration of ammonia. For a given system, the release rate at steady state also is proportional to the ventilation rate. Therefore, if the steady-state release rate obtained at a high ventilation rate (i.e., normal active ventilation) is used as a constant to predict the steady-state concentrations for the off-normal low ventilation condition, the ammonia dome space concentration for the off-normal ventilation condition could be greatly overestimated.

Figure 4-1 demonstrates the relationship of the equilibrium value, the steady-state concentration, and the release rate of ammonia under both normal and off-normal conditions for DST 241-SY-101 after remediation. As shown in Figure 4-1 for the normal ventilation rate of $486 \text{ ft}^3/\text{min}$, the steady-state concentration of ammonia is 400 ppm, which is far below the equilibrium value of 3,895 ppm. For an off-normal ventilation rate of $0.18 \text{ ft}^3/\text{min}$, the ammonia concentration is computed to increase exponentially and took less than 8 days to reach steady state with the concentration of 3,882 ppm, which is lower than but very close to the equilibrium value. Also, note that the steady-state release rate from $0.19 \text{ ft}^3/\text{min}$ under normal ventilation conditions of $486 \text{ ft}^3/\text{min}$ is computed to drop exponentially to $7.6 \text{ E-4 ft}^3/\text{min}$ for the off-normal ventilation condition of $0.18 \text{ ft}^3/\text{min}$.

Figure 4-1. Ammonia Concentration and Release Rate for Double-Shell Tank 241-SY-101 Before and After Loss of Active Ventilation.

For many SSTs and some of the DSTs with lower concentrations of ammonia, the ammonia release rate was too small to contribute significantly to reaching 25% of the LFL even under off-normal ventilation conditions. Therefore, this method of considering ammonia release rates as constants would be a simple method for screening out tanks with small release rates. Using this method would prevent use of the liquid-vapor equilibrium method, which requires liquid and dome space ammonia concentration data and more complex calculations.

4.4 STEADY-STATE MASS TRANSPORT PROPERTIES “h” AND “A” FOR AMMONIA

As discussed in Chapter 3.0, it is difficult to estimate the effective area, A , of the mass transport in the liquid-vapor equilibrium model. The effective area is the actual waste surface area available for ammonia transport, and will be the full or partial tank cross-sectional area depending on how much true liquid surface is available. The ammonia concentration could be overestimated by two orders of magnitude in the liquid-vapor equilibrium model if 100% of the

effective area is used. In this report, the ammonia concentration analysis follows the logic in the following steps to perform the dome space ammonia calculations:

1. The ammonia concentration in all DSTs was analyzed using the liquid-vapor equilibrium model as described in Chapter 3.0. The mass transport properties, the product of h and A , were obtained from the steady-state concentration under normal conditions by applying Equation 3-17. Then, using this product of h and A , the time-dependent ammonia concentration and flammability under off-normal conditions were calculated.
2. The ammonia concentrations for the SSTs were first evaluated by assuming a constant release rate. If the ammonia concentrations computed using this conservative approach were more than 0.5% and the total flammability was above 20% of the LFL, the ammonia concentration was reanalyzed more accurately using the liquid-vapor equilibrium method as was done for the DSTs.

The input data collected included the ammonia concentrations in the liquid and in the dome space under normal ventilation conditions, the waste volume and ionic composition, and the temperatures of the waste and the dome space under both normal and off-normal conditions. Appendix C, Table C-1, gives the liquid concentrations in the DSTs and selected SSTs for the ions such as nitrate, nitrite, and aluminum used in the calculation of the HGR. The additional ion constituents required are carbonate, chloride, chromium, fluorine, hydroxide, iron, nickel, phosphate, potassium, sodium, and sulfate. Other required data include the tank waste density, temperature, and weight-percent water. These data were obtained from the BBI reports. Where tank ion concentrations or waste properties were not available in the BBI detail report, an average value from the sample analysis data contained in the TCD was used. The tank waste temperature values were the only figures not taken from the BBI or the TCD. They were obtained from RPP-5660, Table 3-2. However, the input data for ammonia calculations were not updated in Revision 3 because the required liquid ammonia data is not available. The ammonia calculations remain the same as in Revision 1 of the report; however, ammonia has a minor contribution to the flammability at steady-state.

Based on Equation 3-8, the Henry's Law constants were calculated and are listed in Appendix C, Table C-2. Table C-2 also includes the summations of ion concentrations, the Henry's Law constants in pure water, and the correction factors for the calculated Henry's Law constants, K_H , for salt solutions. The correction factors were assigned using the tank waste concentrations and temperatures according to the study results for ammonia solubility in high-concentration salt solutions (RPP-4941). The mass transport properties of the product h and A were calculated using Equation 3-17 and are listed in Appendix C, Table C-3. Based on the products of h and A , the time-dependent ammonia concentration and percent of the LFL under off-normal ventilation conditions were calculated, as discussed in Section 4.5. As discussed in Chapter 3.0, the product of h and A depends on the waste configuration and physical and chemical properties, particularly the surface area, A , which is the effective surface for gas transport from the liquid to the vapor phase. For example, if the waste was disturbed or the configuration of the waste surface changed, both the effective surface area and h could change, so the product of h and A would change. Therefore, what has been calculated as the product of h and A in this report reflects only the current ammonia transport status of storage tank waste at steady state.

As a comparison, Table 4-2 lists the products of h and A from the values derived from the field data under normal conditions using Equation 3-17 and from the calculated h using the equations in Appendix E with a 100% tank surface area, A . For most of the tanks, the values for h and A derived from field data are a few orders of magnitude smaller than the values from the calculated h and 100% area A . Two possible factors can contribute to this discrepancy. First, many tanks may not have 100% transport area A , particularly for those tanks having a large crust layer or solid waste on the surface. Second, from Equation 3-17, the field-data-derived values of h and A rely mainly on the ammonia vapor data and ventilation rate in the headspace, and the corresponding value of liquid concentration in the waste (usually the value of $K_H P \text{ v } C_g^{ss}$ is much smaller than C_l). The uncertainties of these input data and the fact that these data are not measured simultaneously can contribute to errors in the field-derived h and A values.

Next, the ammonia underneath the liquid surface could be depleted and present a large gradient throughout the tank. In this case, the measured liquid-phase ammonia data from the middle or bottom sections of the tank will be too large for the observed vapor data. Also, the equations used to calculate h in Appendix E may involve large uncertainties. In all cases, note that the values of the product of h and A determine how fast the ammonia will be released to the dome space. The bounding value for the flammability is the steady-state ammonia concentration in the dome space. The last column of Table 4-2 lists the steady-state ammonia concentrations under off-normal conditions. For all calculated values, the ammonia concentration is less than 8,300 ppm, which contributes less than 6% of the LFL to the total flammability.

Table 4-2. The Calculation of Ammonia Transport Properties. (2 sheets)

Tank	(NH ₃) ^{ss} in Dome Under Normal Vent (ppm)	Liquid [NH ₃] in Waste (µg/mL)	Normal Vent Rate in the Dome Space (ft ³ /min)	Product $h A$ (ft ³ /min) From Field Data at Normal Vent	Product $h A$ (ft ³ /min) From Calculated h and 100% A	(NH ₃) ^{ss} at Off-Normal Vent (ppm)
241-AN-101	11	40	113	2.85 E-02	1.02 E+00	55
241-AN-102	300	210	119	1.80 E-01	2.03 E+00	857
241-AN-103	7	345	100	1.33 E-03	3.50 E+00	2,034
241-AN-104	21	246	100	5.92 E-03	3.08 E+00	2,011
241-AN-105	15	210	100	5.02 E-03	2.91 E+00	1,523
241-AN-106	1	210	117	3.99 E-04	1.12 E+00	123
241-AN-107	400	210	129	3.60 E-01	1.94 E+00	759
241-AP-101	125	439	108	2.57 E-02	1.26 E+00	827
241-AP-102	75	439	135	1.83 E-02	1.15 E+00	728
241-AP-103	1	250	200	5.76 E-04	1.48 E+00	248
241-AP-104	3	133	71	1.23 E-03	1.18 E+00	136
241-AP-105	7	324	176	2.79 E-03	1.75 E+00	800
241-AP-106	5	68	111	6.54 E-03	1.11 E+00	104
241-AP-107	5	1,060	342	1.16 E-03	7.14 E-01	909
241-AP-108	27	800	129	3.14 E-03	8.82 E-01	852

Table 4-2. The Calculation of Ammonia Transport Properties. (2 sheets)

Tank	(NH ₃) ^{ss} in Dome Under Normal Vent (ppm)	Liquid [NH ₃] in Waste (µg/mL)	Normal Vent Rate in the Dome Space (ft ³ /min)	Product h A (ft ³ /min) From Field Data at Normal Vent	Product h A (ft ³ /min) From Calculated h and 100% A	(NH ₃) ^{ss} at Off-Normal Vent (ppm)
241-AW-101	5	10	100	3.92 E-02	3.05 E+00	89
241-AW-102	3	74	292	7.16 E-03	7.74 E-01	80
241-AW-103	138	512	134	3.63 E-02	7.06 E-01	437
241-AW-104	6	169	141	3.64 E-03	6.99 E-01	142
241-AW-105	43	1,010	194	5.97 E-03	5.49 E-01	625
241-AW-106	28	355	158	8.59 E-03	2.06 E+00	1,164
241-AY-101	5	113	250	7.69 E-03	1.55 E+00	286
241-AY-102	4	74	250	1.05 E-02	1.60 E+00	207
241-AZ-101	1	125	150	8.31 E-04	2.79 E+00	331
241-AZ-102	6	438	112	1.01 E-03	1.96 E+00	1,181
241-SY-101	400	1,044	486	1.42 E-01	2.09 E+00	3,870
241-SY-102	12	1,150	363	2.67 E-03	1.24 E+00	1,771
241-SY-103	59	1,290	116	3.88 E-03	3.14 E+00	5,581
241-A-101	394	531	10	5.17 E-03	3.74 E+00	8,253
241-A-103	261	531	8	2.61 E-03	3.21 E+00	2,922
241-C-103	324	1,210	10	1.94 E-03	1.88 E+00	3,159
241-S-101	765	1,210	6	2.94 E-03	2.59 E+00	5,817
241-S-102	588	1,700	2	5.47 E-04	3.01 E+00	4,312
241-SX-103	31	1,800	53	6.11 E-04	3.55 E+00	4,977
241-U-102	651	745	2	1.66 E-03	2.08 E+00	2,157
241-U-103	722	1,400	2	9.56 E-04	2.47 E+00	4,582
241-U-105	1,936	1,600	5	5.64 E-03	2.22 E+00	6,909
241-U-107	448	403	12	1.34 E-02	1.98 E+00	1,380
241-U-108	684	1,050	4	1.87 E-03	2.57 E+00	4,345

Note:

To convert cubic feet to liters, multiply the value by 28.454 L/ft³.

4.5 FLAMMABILITY EVALUATION AND RESULTS

With the collected ventilation rates and steady-state gas concentrations, the flammable gas concentrations, expressed as a percent of the LFL, in the tank dome space under normal ventilation conditions were calculated using Equation 3-18 and are listed in Appendix D, Table D-1. For all tanks, the flammable gas concentration under normal ventilation is less than 2% except SSTs 241-C-107 with 6.81% and 241-U-106 with 2.44%. This suggests that the tank dome space of all tanks under current ventilation rates, whether actively or passively ventilated, will not exceed 25% of the LFL.

For off-normal ventilation conditions, there is no guarantee that every tank will have a pathway for barometric breathing due to the sealing-off action for interim stabilization; thus the flammability calculation will be performed under both barometric breathing rate and zero ventilation rate for water addition and temperature increase condition. A study focusing on the sensitivity of waste temperature and water addition in the flammability evaluation under zero ventilation for DSTs has been done and documented in Appendix H of Revision 3 of this document. The study concluded that for the flammability evaluation under zero ventilation condition, 10 and 1 kgal of water will be added to the tank waste for 100- and 200-series DST and SSTs. Also 5 °C temperature increase will apply to all DSTs. In addition, the diffusion mechanism through concrete tank dome has been included in the flammability calculation under zero ventilation condition for 149 SSTs.

Detailed calculation results on the case of water addition and 5 °C temperature increase for DSTs are given in Appendix D. The summarized results are given in Tables 4-3 under barometric breathing condition, and Tables 4-4 and 4-5 for DSTs and SSTs, respectively under zero ventilation condition with water addition and temperature study.

4.5.1 Off-Normal Condition With Barometric Breathing

For off-normal ventilation rates, assuming only barometric breathing rate, V_{bb} , is available (discussed in Section 4.2), the steady-state concentration can be calculated using Equation 3-13 for insoluble gas and using Equation 3-16 for the soluble gas; the results are listed in Appendix D, Table D-2. In the calculation for the off-normal condition, the initial concentrations are assumed to be the steady-state concentrations under normal ventilation conditions; these concentrations are listed in Appendix D, Table D-1. As listed in Table D-2, under the off-normal condition with barometric breathing rate, 20 DSTs and 7 SSTs are computed to exceed 25% of the LFL when the system reaches steady state, and 5 DSTs and 2 SSTs are predicted to reach 100% of the LFL.

Equation 3-18 gives the formula to calculate the flammable gas concentrations at a given time with the aid of a time-dependent gas concentration equation (Equation 3-6 for insoluble gas and Equation 3-12 for soluble gas). Because the time variable cannot be expressed explicitly in an equation, a customized Excel macro was developed using Visual Basic to iterate the calculations by increasing the time until the specified LFLs in Equation 3-18 are met. The calculated times to reach 25% and 100% of the LFL (time-to 25% LFL and 100% LFL) under the off-normal ventilation condition with barometric breathing rate are listed in Appendix D, Tables D-3 and D-4. In the calculations, the flammability level of each flammable gas also is calculated for each case to understand the distribution of each gas's contribution to the total LFL.

Another needed variable is the minimum ventilation rate required to prevent the tank dome space from exceeding 25% of the LFL. Equation 3-18 gives the time-dependent flammable gas concentration in terms of percent of the LFL; however, the ventilation rate is embedded in the time-dependent concentration as given in Equations 3-6 and 3-12. No explicit solution was developed to find the minimum ventilation rate in Equation 3-18. For those tanks exceeding the specified flammability level, the minimum ventilation rate can be found by gradually increasing the ventilation rate from zero until a total flammability level of less than the specified 25% or

100% of the LFL, is obtained. A customized Excel macro was developed using Visual Basic code to iterate this equation automatically to find the minimum ventilation rate. Details of the calculated minimum ventilation rates are listed in Appendix D, Tables D-3 and D-4, for 25% and 100% of the LFL, respectively.

Table 4-3 lists all the tanks (20 DSTs and 7 SSTs) that will reach 25% of the LFL with current waste content plus water addition of 10 kgal and 1 kgal for 100- and 200-series tanks, respectively and 5 °C temperature increase under barometric breathing rate. In the off-normal condition with barometric breathing rate, DST 241-AZ-102 and SST 241-B-203 give the shortest time to 25% of the LFL as 11 and 39 days for DSTs and SSTs, respectively. Overall, under barometric breathing rate, five DSTs and two SSTs are computed to reach 100% of the LFL if the off-normal condition persists long enough. It takes 50 and 254 days to reach 100% of the LFL for DST 241-AZ-102 and SST 241-B-203, respectively. Note that the results of this calculation listed in Table 4-3 are based on the BBI information queried on September 17, 2007.

Table 4-3. Time^{a, b} to Reach 25% and 100% of the Lower Flammability Limit With Water Addition^c and 5 °C Temperature Increase^d Under Barometric Breathing Condition. (2 sheets)

DSTs	Time to reach 25% LFL t _{25%} (day)	Time to reach 100% LFL t _{100%} (day)
Double-shell Tanks		
241-AZ-102	11	50
241-AY-102	13	62
241-AN-102	21	107
241-AN-107	25	132
241-AZ-101	31	173
241-AW-101	78	not occur
241-AN-104	80	not occur
241-AN-106	104	not occur
241-AP-108	106	not occur
241-AN-105	110	not occur
241-AN-101	110	not occur
241-AY-101	120	not occur
241-SY-103	141	not occur
241-AN-103	149	not occur
241-AW-104	191	not occur
241-AP-106	228	not occur
241-AW-106	241	not occur
241-AP-104	250	not occur
241-AP-102	263	not occur
241-AP-105	646	not occur

Table 4-3. Time^{a, b} to Reach 25% and 100% of the Lower Flammability Limit With Water Addition^c and 5 °C Temperature Increase^d Under Barometric Breathing Condition. (2 sheets)

DSTs	Time to reach 25% LFL t25% (day)	Time to reach 100% LFL t100% (day)
Single-shell Tanks		
241-B-203*	39	254
241-B-204*	42	296
241-SX-103*	169	not occur
241-SX-105*	192	not occur
241-T-201	270	not occur
241-C-107	332	not occur
241-C-104	728	not occur

Notes:

^aTanks not listed here will not reach 25% of the LFL under barometric breathing conditions.

^bCalculation based on the BBI data of September 17, 2007, and the PCSACS data from April 1, 2006 to April 1, 2007.

^cWater addition of 10 kgal for DSTs and 100-series SSTs and 1 kgal for 200- series SSTs.

^dTemperature increase only applies to DSTs.

BBI = best basis inventory.

DST = double-shell tank.

LFL = lower flammability limit.

4.5.2 Off-Normal Condition with Zero Ventilation

A zero ventilation condition means a closed system. Without considering or including other possible mechanisms for gas leaving the system, such as diffusion through the dome space concrete wall, it is expected that every tank will reach 100% of the LFL under zero ventilation given adequate time. A complete set of equations for flammability evaluation under zero ventilation is given in Section 3-7 for both soluble and insoluble gases. In this model calculation, it is reasonable to assume that the tank will not be pressurized, thus, the newly generated gas will slowly push the old gas composition out and form a new concentration of flammable gas without increasing the pressure.

For SSTs, if gas diffusion is considered as the only mechanism for ventilation, then the gas concentration such as hydrogen methane can be calculated using Equation 3-6b. The required gas diffusivity, thickness of the coating on the dome, the dome area, and the calculated effective diffusion rate are given in Table F-1 and F-2 of Appendix F. For ammonia, the diffusion mechanism is too small to impact its equilibrium concentration. So the ammonia concentrations remain unchanged during the calculation.

For DSTs, the temperature effect under zero ventilation condition is considered. Other than 5 °C temperature increase on top of current tank temperature, it also considers the temperature's continued rising in the closed system. The temperature increase rates are calculated using

Equation 3-28 for the case when temperatures of the convective and non-convective layers are the same and using Equations 3-29 to 3-31 when the temperatures are different. The required input data for the calculation for each layer of each tank includes density, volume, heat load, and waste temperature. Other input parameters commonly used in the calculations for all tanks are the following (values are taken from RPP-6213):

- Heat capacity: 3,300 J/kg
- Air temperature: 285 K
- Soil temperature: 287 K
- Heat exchange area: 411 m²
- Soil thermal conductivity: 1 W/m-K
- Soil overburden thickness: 4 m
- Tank radius: 11 m.

For tanks treated as a whole, the temperature increase rate is the net heat rate, which is the tank heat load minus upward and downward heat lost, divided by the product of mass and heat capacity. For tanks with distinct temperatures between layers, the heat transfer coefficients are adjusted and determined until the calculated temperature increase rates are equal for convective and nonconvective layers. Once the heat transfer coefficients are determined, the heat-up rates are finalized.

At the given initial temperature along with the temperature increase rate, the gas concentrations for hydrogen and methane are calculated as the temperature changes in the time step of 1 day. The accumulated gas concentrations are calculated daily using Equation 3-23, since the first day of losing the normal ventilation condition. The initial concentration condition in Equation 3-23 is a steady-state concentration at the normal ventilation condition. The hydrogen release rate, which is assumed to be the same as the HGR, is calculated daily using the rate equation model documented in RPP-3851, or summarized in Chapter 2.0, based on the calculated temperature of each day.

Because methane does not have a rate equation model available, its daily gas release rate is calculated with the initial release rate at the given initial tank waste temperature, plus the daily increase rate due to tank waste heat-up under the zero ventilation condition. The daily increase rate of methane uses the same daily increase HGR, which is the ratio between the HGRs of the current and previous days. The initial methane rates at baseline temperature are taken from Appendix D, Table D-1. The initial methane release rate at baseline temperature plus 5 °C is calculated in the same ratio as the hydrogen release rate increases as shown in Equation 4-3:

$$MGR_{baseline+T}^i = MGR_{baseline}^i \cdot \frac{HGR_{baseline+T}^i}{HGR_{baseline}^i} \quad (4-3)$$

where:

$$\begin{aligned} MGR_{baseline+T}^i &= \text{methane initial release rate at baseline temperature plus } T \\ &\quad (\text{ft}^3/\text{min}) \\ MGR_{baseline}^i &= \text{Methane initial release rate at baseline temperature (ft}^3/\text{min)} \end{aligned}$$

$$\begin{aligned}
 HGR^i_{baseline+T} &= \text{hydrogen initial release rate at baseline temperature plus } T \\
 &\quad (\text{ft}^3/\text{min}) \\
 HGR^i_{baseline} &= \text{hydrogen initial release rate at baseline temperature (ft}^3/\text{min)}.
 \end{aligned}$$

Ammonia concentrations are calculated using Equation 3-25. Although ammonia concentration is also a function of temperature, to simplify the flammability evaluation the intention was to obtain one set of ammonia transport properties at the highest temperature for each tank and use it throughout the whole calculation. Calculations (Appendix H of Revision 3 of this document) show that the equilibrium ammonia vapor concentration at its highest temperatures due to temperature increase contributes to flammability is not too far from the contributions calculated at baseline temperature. In this calculation, the ammonia transport coefficients g_1 and g_2 derived at the initial temperature are used for the flammability calculations.

In the flammability calculations, there are several tanks that the N_2O concentration has increased to the model limit of 8% before the total flammability reached 100% of the LFL due to zero ventilation assumption. As mentioned in Section 3.2, the flammability level for individual flammable gas is 4%, 15%, and 5% for hydrogen, ammonia, and methane, respectively, if the N_2O is less than 8%. When the mixture has more than 8% N_2O , the required individual LFL gas concentrations are lower than listed above. For those tanks having a high N_2O concentration, the calculations of “the time to reach 100% of the LFL” simply represents the time for the N_2O to reach 8% while the total flammability is still less than 100% of the LFL, and this approach is conservative. For flammable gas control, the time to 25% of the LFL is used to determine the surveillance interval, and usually the N_2O will not build up to 8% at the time to reach 25% of the LFL. It is possible to establish the LFL for each individual flammable gas as function of higher N_2O concentration by further investigating the flammability studies on gas mixtures by Pfahl and Shepherd (1997). In any case, this will complicate the calculation of time-dependent gas concentrations, and make automation of the calculations more difficult.

Table 4-4 summarizes the flammability calculation for DSTs under off-normal ventilation condition at zero ventilation scenarios with 10 kgal water addition and 5 °C temperature increase. Under the zero ventilation condition the ratio of time to 100% of the LFL to 25% of the LFL should be roughly four (some that are higher than four means the ammonia contribution is more significant and the ammonia concentration is not linearly increasing by time but is governed by the liquid-vapor equilibrium mechanism). Those tanks with a ratio less than four means the “time to reach 100% of the LFL” is the time to reach the 8% N_2O model limit, but the flammability has not reached 100% of the LFL. As shown in Table 4-4, the five tanks with the shortest time to 25% of the LFL are 10, 13, 17, 23, and 26 days for tanks 241-AZ-102, 241-AY-102, 241-AN-102, 241-AN-107, and 241-AZ-101, respectively. The minimum vent rates to keep the dome space below 100% of the LFL ranges between 0.91 to 0.02 ft³/min.

Table 4-4. The Hydrogen Generation Rates, Time To 25% and 100% of the Lower Flammability Limit and Minimum Vent Rate With 10 kgal Water Addition and 5 °C Temperature Increase Under Zero Ventilation for Double-Shell Tanks.

Tank	Hydrogen generation rate Rr(H ₂) (cfm)	Time* to Reach 25% of the LFL (Days)	Time* to Reach 100% of the LFL (Days)	Minimum Vent Rate to Keep below 25% LFL (cfm)	Minimum Vent Rate to Keep below 100% LFL (cfm)
241-AN-101	2.55E-03	83	300	0.27	0.07
241-AN-102	1.41E-02	17	50	1.46	0.36
241-AN-103	3.58E-03	97	328	0.39	0.10
241-AN-104	4.34E-03	63	221	0.47	0.11
241-AN-105	2.68E-03	80	293	0.30	0.07
241-AN-106	7.06E-03	82	294	0.76	0.19
241-AN-107	1.05E-02	23	90	1.12	0.28
241-AP-101	5.77E-04	317	270	0.07	0.02
241-AP-102	1.55E-03	147	347	0.18	0.05
241-AP-103	2.26E-03	249	963	0.23	0.06
241-AP-104	1.84E-03	139	451	0.19	0.05
241-AP-105	9.71E-04	206	425	0.12	0.03
241-AP-106	1.67E-03	135	465	0.17	0.04
241-AP-107	6.59E-04	301	342	0.08	0.02
241-AP-108	1.56E-03	84	322	0.16	0.04
241-AW-101	3.63E-03	63	228	0.38	0.09
241-AW-102	1.15E-03	251	1,006	0.12	0.03
241-AW-103	9.85E-04	241	977	0.12	0.03
241-AW-104	2.39E-03	105	387	0.28	0.07
241-AW-105	7.03E-04	1,312	1,500	0.08	0.02
241-AW-106	1.50E-03	142	532	0.17	0.04
241-AY-101	5.49E-03	90	309	0.57	0.14
241-AY-102	2.66E-02	13	47	2.70	0.67
241-AZ-101	1.65E-02	26	79	1.71	0.43
241-AZ-102	3.56E-02	10	40	3.65	0.91
241-SY-101	7.37E-04	285	884	0.10	0.02
241-SY-102	1.15E-03	611	1,500	0.14	0.03
241-SY-103	3.81E-03	120	447	0.47	0.11

Note:

*1,500 in the Time to 25% and 100% of the LFL column means equal or longer than 1,500 days.

LFL = lower flammability limit.

Table 4-5 summarizes the flammability calculation for SSTs under off-normal ventilation condition at zero ventilation scenarios with 10 kgal and 1 kgal water addition for 100- and 200-series tanks. The gas diffusion mechanism through the concrete dome are included in the calculations. Due to the gas diffusion effect, there are 20 tanks will not reach 100% of the LFL including tank 241-A-104, 4 241-AX Tank Farm tanks and 15 241-SX Tank Farm tanks. The diffusion rates of these tanks are two orders of magnitude larger than the rest of tanks because their concrete tank domes are not coated with a coating such as Asphaltic or Gunitite. These coating materials increase the gas diffusion resistance. Asphaltic coating is particularly hard for gas to pass through because its diffusivity is four orders of magnitude smaller than concrete's diffusivity. For the remaining tanks, the shortest time to 25% of the LFL are 35, 38, and 135 days from tanks 241-B-203, 241-B-204, and 241-C-107, respectively. There are 12 tanks which have the time to 25% of the LFL shorter than 365 days.

Table 4-5. The Hydrogen Generation Rates, Time To 25% and 100% of the Lower Flammability Limit and Minimum Vent Rate with Water Addition^a Under Zero Ventilation (Except Gas Diffusion Mechanism Through The Dome) for Single-Shell Tanks. (5 sheets)

Tank	Hydrogen generation rate $R_r(H_2)$ (cfm)	Time ^{b,c} to Reach 25% of the LFL (Days)	Time ^{b,c} to Reach 100% of the LFL (Days)	Minimum Vent Rate to Keep below 25% LFL (cfm)	Minimum Vent Rate to Keep below 100% LFL (cfm)
241-A-101	1.39E-03	496	1,500	0.16	0.04
241-A-102	3.76E-04	1,500	1,500	0.09	0.02
241-A-103	1.42E-03	551	1,500	0.16	0.04
241-A-104	2.32E-04	1,500	not occur	0.03	0.01
241-A-105	NA	NA	NA	NA	NA
241-A-106	1.98E-03	400	1,500	0.28	0.07
241-AX-101	1.03E-03	not occur	not occur	0.11	0.03
241-AX-102	6.68E-04	not occur	not occur	0.08	0.02
241-AX-103	8.96E-04	not occur	not occur	0.12	0.03
241-AX-104	5.12E-03	not occur	not occur	0.51	0.13
241-B-101	4.14E-04	1,500	1,500	0.05	0.01
241-B-102	2.41E-04	1,500	1,500	0.03	0.01
241-B-103	2.40E-04	1,500	1,500	0.03	0.01
241-B-104	3.60E-04	1,067	1,500	0.04	0.01
241-B-105	3.19E-04	1,486	1,500	0.04	0.01
241-B-106	3.08E-04	1,500	1,500	0.04	0.01
241-B-107	2.85E-04	1,500	1,500	0.04	0.01
241-B-108	2.55E-04	1,500	1,500	0.03	0.01
241-B-109	2.63E-04	1,500	1,500	0.04	0.01
241-B-110	5.39E-04	786	1,500	0.07	0.02
241-B-111	9.12E-04	510	1,500	0.11	0.03
241-B-112	2.83E-04	1,500	1,500	0.04	0.01
241-B-201	5.92E-05	349	1,500	0.01	0.00
241-B-202	5.60E-05	400	1,500	0.01	0.00
241-B-203	1.98E-04	35	154	0.02	0.00

Table 4-5. The Hydrogen Generation Rates, Time To 25% and 100% of the Lower Flammability Limit and Minimum Vent Rate with Water Addition^a Under Zero Ventilation (Except Gas Diffusion Mechanism Through The Dome) for Single-Shell Tanks. (5 sheets)

Tank	Hydrogen generation rate $R_r(H_2)$ (cfm)	Time ^{b,c} to Reach 25% of the LFL (Days)	Time ^{b,c} to Reach 100% of the LFL (Days)	Minimum Vent Rate to Keep below 25% LFL (cfm)	Minimum Vent Rate to Keep below 100% LFL (cfm)
241-B-204	2.02E-04	38	166	0.02	0.01
241-BX-101	2.92E-04	1,500	1,500	0.04	0.01
241-BX-102	3.93E-04	1,500	1,500	0.05	0.01
241-BX-103	7.88E-04	712	1,500	0.10	0.03
241-BX-104	3.71E-04	1,211	1,500	0.09	0.02
241-BX-105	2.93E-04	1,500	1,500	0.07	0.02
241-BX-106	3.71E-04	1,500	1,500	0.05	0.01
241-BX-107	4.05E-04	817	1,500	0.06	0.01
241-BX-108	2.61E-04	1,500	1,500	0.03	0.01
241-BX-109	5.27E-04	952	1,500	0.06	0.02
241-BX-110	3.93E-04	1,086	1,500	0.06	0.01
241-BX-111	2.91E-04	1,500	1,500	0.04	0.01
241-BX-112	3.37E-04	1,223	1,500	0.06	0.02
241-BY-101	6.25E-04	803	1,500	0.08	0.02
241-BY-102	3.50E-04	1,452	1,500	0.07	0.02
241-BY-103	4.32E-04	1,072	1,500	0.06	0.01
241-BY-104	6.98E-04	589	1,500	0.13	0.03
241-BY-105	5.44E-04	650	1,500	0.10	0.02
241-BY-106	8.28E-04	643	1,500	0.09	0.02
241-BY-107	5.27E-04	934	1,500	0.19	0.05
241-BY-108	5.15E-04	1,021	1,500	0.21	0.05
241-BY-109	3.45E-04	1,452	1,500	0.05	0.01
241-BY-110	1.39E-03	322	1,500	0.28	0.07
241-BY-111	3.82E-04	1,264	1,500	0.05	0.01
241-BY-112	3.51E-04	1,472	1,500	0.06	0.01
241-C-101	3.38E-04	1,500	1,500	0.05	0.01
241-C-102	4.84E-04	652	1,500	0.11	0.03
241-C-103	5.75E-04	859	859	0.07	0.02
241-C-104	1.63E-03	215	1,068	0.26	0.07
241-C-105	9.06E-04	495	1,500	0.14	0.03
241-C-106	9.93E-04	667	1,500	0.12	0.03
241-C-107	2.97E-03	135	709	0.30	0.07
241-C-108	2.80E-04	1,500	1,500	0.03	0.01
241-C-109	7.95E-04	880	1,259	0.08	0.02
241-C-110	7.32E-04	559	1,500	0.11	0.03
241-C-111	1.53E-03	469	1,500	0.15	0.04
241-C-112	1.48E-03	441	934	0.16	0.04
241-C-201	4.48E-05	1,161	1,500	0.00	0.00
241-C-202	4.54E-05	1,174	1,500	0.00	0.00
241-C-203	4.26E-05	1,000	1,500	0.01	0.00

Table 4-5. The Hydrogen Generation Rates, Time To 25% and 100% of the Lower Flammability Limit and Minimum Vent Rate with Water Addition^a Under Zero Ventilation (Except Gas Diffusion Mechanism Through The Dome) for Single-Shell Tanks. (5 sheets)

Tank	Hydrogen generation rate $R_r(H_2)$ (cfm)	Time ^{b,c} to Reach 25% of the LFL (Days)	Time ^{b,c} to Reach 100% of the LFL (Days)	Minimum Vent Rate to Keep below 25% LFL (cfm)	Minimum Vent Rate to Keep below 100% LFL (cfm)
241-C-204	4.29E-05	1,204	1,500	0.00	0.00
241-S-101	9.98E-04	523	1,500	0.13	0.03
241-S-102	3.07E-04	1,500	1,500	0.04	0.01
241-S-103	4.90E-04	1,296	1,500	0.05	0.01
241-S-104	6.13E-04	951	1,500	0.07	0.02
241-S-105	3.73E-04	1,115	1,500	0.06	0.01
241-S-106	5.24E-04	916	1,500	0.06	0.02
241-S-107	7.16E-04	660	1,500	0.10	0.02
241-S-108	4.30E-04	984	1,500	0.05	0.01
241-S-109	4.28E-04	889	1,500	0.05	0.01
241-S-110	5.89E-04	718	1,500	0.10	0.03
241-S-111	6.41E-04	880	1,500	0.07	0.02
241-S-112	6.58E-04	1,285	1,500	0.08	0.02
241-SX-101	6.78E-04	not occur	not occur	0.07	0.02
241-SX-102	1.45E-03	not occur	not occur	0.15	0.04
241-SX-103	5.39E-03	not occur	not occur	0.58	0.14
241-SX-104	1.71E-03	not occur	not occur	0.18	0.04
241-SX-105	6.09E-03	not occur	not occur	0.61	0.15
241-SX-106	7.48E-04	not occur	not occur	0.08	0.02
241-SX-107	1.49E-03	not occur	not occur	0.17	0.04
241-SX-108	1.06E-03	not occur	not occur	0.11	0.03
241-SX-109	2.58E-03	not occur	not occur	0.27	0.07
241-SX-110	3.05E-03	not occur	not occur	0.32	0.08
241-SX-111	2.62E-03	not occur	not occur	0.29	0.07
241-SX-112	1.15E-03	not occur	not occur	0.14	0.04
241-SX-113	2.48E-04	not occur	not occur	0.03	0.01
241-SX-114	2.54E-03	not occur	not occur	0.30	0.07
241-SX-115	1.77E-03	not occur	not occur	0.18	0.04
241-T-101	2.97E-04	1,500	1,500	0.04	0.01
241-T-102	5.91E-04	1,241	1,500	0.06	0.02
241-T-103	2.33E-04	1,500	1,500	0.03	0.01
241-T-104	3.60E-04	973	1,500	0.06	0.01
241-T-105	3.18E-04	1,429	1,500	0.05	0.01
241-T-106	2.31E-04	1,500	1,500	0.04	0.01
241-T-107	4.32E-04	929	1,500	0.07	0.02
241-T-108	2.27E-04	1,500	1,500	0.03	0.01
241-T-109	2.41E-04	1,500	1,500	0.03	0.01
241-T-110	8.72E-04	484	1,500	0.09	0.02
241-T-111	4.22E-04	559	1,500	0.08	0.02
241-T-112	2.47E-04	1,500	1,500	0.03	0.01

Table 4-5. The Hydrogen Generation Rates, Time To 25% and 100% of the Lower Flammability Limit and Minimum Vent Rate with Water Addition^a Under Zero Ventilation (Except Gas Diffusion Mechanism Through The Dome) for Single-Shell Tanks. (5 sheets)

Tank	Hydrogen generation rate $R_r(H_2)$ (cfm)	Time ^{b,c} to Reach 25% of the LFL (Days)	Time ^{b,c} to Reach 100% of the LFL (Days)	Minimum Vent Rate to Keep below 25% LFL (cfm)	Minimum Vent Rate to Keep below 100% LFL (cfm)
241-T-201	1.43E-04	157	508	0.02	0.00
241-T-202	4.44E-05	642	958	0.01	0.00
241-T-203	6.53E-05	270	331	0.01	0.00
241-T-204	6.54E-05	269	309	0.01	0.00
241-TX-101	3.88E-04	1,500	1,500	0.05	0.01
241-TX-102	3.39E-04	1,500	1,500	0.09	0.02
241-TX-103	3.00E-04	1,500	1,500	0.05	0.01
241-TX-104	3.11E-04	1,500	1,500	0.04	0.01
241-TX-105	4.75E-04	790	1,500	0.06	0.01
241-TX-106	4.18E-04	1,065	1,500	0.09	0.02
241-TX-107	2.46E-04	1,500	1,500	0.06	0.02
241-TX-108	2.78E-04	1,500	1,500	0.03	0.01
241-TX-109	5.43E-04	741	1,111	0.14	0.03
241-TX-110	4.17E-04	929	1,500	0.23	0.06
241-TX-111	3.77E-04	1,220	1,500	0.20	0.05
241-TX-112	4.75E-04	554	1,500	0.07	0.02
241-TX-113	4.50E-04	731	1,500	0.05	0.01
241-TX-114	4.12E-04	831	1,500	0.09	0.02
241-TX-115	4.36E-04	963	1,500	0.05	0.01
241-TX-116	4.28E-04	908	1,500	0.05	0.01
241-TX-117	3.88E-04	1,284	1,500	0.04	0.01
241-TX-118	4.75E-04	1,174	1,500	0.06	0.02
241-TY-101	2.62E-04	1,500	1,500	0.03	0.01
241-TY-102	2.51E-04	1,500	1,500	0.03	0.01
241-TY-103	3.82E-04	1,500	1,500	0.05	0.01
241-TY-104	2.80E-04	1,500	1,500	0.05	0.01
241-TY-105	5.11E-04	1,299	1,500	0.06	0.01
241-TY-106	2.57E-04	1,500	1,500	0.03	0.01
241-U-101	3.26E-04	1,500	1,500	0.05	0.01
241-U-102	8.87E-04	485	1,500	0.10	0.02
241-U-103	1.10E-03	296	1,457	0.13	0.03
241-U-104	3.07E-04	1,500	1,500	0.03	0.01
241-U-105	9.14E-04	345	554	0.13	0.03
241-U-106	8.88E-04	591	1,500	0.09	0.02
241-U-107	4.97E-04	801	801	0.06	0.01
241-U-108	9.11E-04	351	1,500	0.11	0.02
241-U-109	6.59E-04	597	1,500	0.07	0.02
241-U-110	5.01E-04	885	1,500	0.07	0.02
241-U-111	4.65E-04	875	1,500	0.08	0.02
241-U-112	3.10E-04	1,500	1,500	0.04	0.01

Table 4-5. The Hydrogen Generation Rates, Time To 25% and 100% of the Lower Flammability Limit and Minimum Vent Rate with Water Addition^a Under Zero Ventilation (Except Gas Diffusion Mechanism Through The Dome) for Single-Shell Tanks. (5 sheets)

Tank	Hydrogen generation rate $R_r(H_2)$ (cfm)	Time ^{b,c} to Reach 25% of the LFL (Days)	Time ^{b,c} to Reach 100% of the LFL (Days)	Minimum Vent Rate to Keep below 25% LFL (cfm)	Minimum Vent Rate to Keep below 100% LFL (cfm)
241-U-201	2.57E-05	1,357	1,500	0.00	0.00
241-U-202	2.16E-05	1,500	1,500	0.00	0.00
241-U-203	2.52E-05	1,500	1,500	0.003	0.001
241-U-204	5.13E-05	971	1,500	0.005	0.001

Notes:

^aWater addition of 10 kgal and 1 kgal for 100 and 200 series, respectively.

^b1,500 in the column of Time to 25% and 100% of the LFL means equal or longer than 1,500 days

^cFor those tanks labeled as "not occur" means the gas generation rate is so low such that the tank will not reach 25% or 100% of the LFL through the gas diffusion mechanism.

LFL = lower flammability limit.

NA = not applicable.

4.6 DISCUSSION

In Revision 4-A of this report, the flammability calculations show that the time to 25% of the LFL has become shorter for several tanks compared to the calculations in Revision 3. One of the dramatic changes is from tank 241-C-103, where the time to 25% of the LFL drops from 239 days (in Revision 3) to 63 days. The decrease in time to 25% of the LFL is because the HGR is increased by a factor of four due to large value of G_{H_2O} . Using the newly developed water radiolysis equation (Equation 2-1) the low concentration of NO_3 and NO_2 in tank 241-C-103 results in the value of 0.224 for G_{H_2O} in Revision 4-A rather than the default value of 0.005 used in Revision 3, which is based on the old HGR model. Similarly, in tank 241-C-107 the G_{H_2O} value used is 0.069 versus the default value of 0.005. Apparently the water radiolysis term has been underestimated for given intermediate salt condition in Revision 3 of this document.

This newly developed water radiolysis equation is more sensitive to the salt concentrations in wide range. The development of water radiolysis equation is based on a large set of laboratory data with a wide range of salt condition (0-12 moles of salts). Thus, it calculates the value of G_{H_2O} more accurately for intermediate and dilute NO_3 and NO_2 conditions. Most of the values of G_{H_2O} have gone up from the default value of 0.005 for given intermediate or low NO_3 and NO_2 conditions. The G_{H_2O} value used for tanks 241-B-203, 241-B-204 and 241-T-201 are 0.099, 0.131, and 0.114, respectively, rather than the default value of 0.005 in Revision 3. However, the water radiolysis change effect dramatically impacts the final HGR only when the radiation dose or heat load is also large. The total radiation dose for beta/gamma is about 10 Kw and 14 Kw for 241-C-103 and 241-C-107, respectively, which are enormously large for SSTs, while the total radiation dose for tank 241-B-203, 241-B-204, and 241-T-201 are only one tenth watt or less. In other words, the change of G_{H_2O} in 241-C-103 and 241-C-107 are amplified by their huge radiation dose. This is not the case for 241-B-203, 241-B-204 and 241-T-201.

In Revision 1, the dome space ammonia concentration in DST 241-SY-101 increased from 4 ppm (before-transfer data) to 400 ppm (January 2001 data), even though the liquid concentration decreased by a factor of 4 comparing data from before and after the waste was transferred out of the tank. The concentration increased because the thick crust had greatly reduced the ammonia transport from the waste to the dome space. After the waste had been transferred from DST 241-SY-101, most of the crust layer was removed and the effective area, A , for mass transport increased; therefore, the concentration in the dome space increased even though the concentration of the ammonia in the liquid decreased. Some thin crust has formed in DST 241-SY-101. Breaks in this crust appear periodically.

Following the transfer of waste from DST 241-SY-101, the dome space ammonia concentration increased from 50 to 400 ppm from July 2000 to January 2001, while the hydrogen concentration remained constant. This may be explained by changes in the effective surface area of mass transport. For example, calculations show that an effective surface area increase from 1.5% to 7% of the total tank waste surface area would account for the dome space concentration increase from 100 to 400 ppm. This effective area of 1.5% and 7% is roughly 70 and 300 ft², respectively, and is consistent with the estimated liquid pool of 10 ft (RPP-6517) and 20 ft or more in diameter, respectively, observed on the surface in the corresponding time period. Calculations also indicated that most of the SSTs for which calculations were done had effective surface areas as small as several tenths of 1% of the total tank waste surface. Caution should be taken in using the results of the calculated product of h and A from Appendix C, Table C-3 because the accuracy is limited by the accuracy of the input data. Whether these data, such as dome space ammonia concentration, ventilation rate, and liquid concentration, were collected at the same time also introduces uncertainty. DST 241-SY-101 is an example that shows that the model calculations agree reasonably with field observations when the input data are accurate and are taken in the same time frame.

Another observation is that the area of liquid surface in DST 241-SY-101 seems to be changing continuously and, therefore, the ammonia transport rate will change accordingly. Calculations show that the steady-state dome space ammonia concentration under normal ventilation conditions would reach 2,573 ppm if the effective area were 100% for a given liquid ammonia concentration of 1,040 µg/mL. Using this concentration, the equilibrium vapor concentration of 3,895 ppm is calculated. For the scenario of the waste surface being fully open with a 100% effective mass transport area, the total flammable gas concentration is calculated to be 1.73% under normal ventilation conditions, and the total mass transport product of h and A is 2.09 ft³/min. Therefore the calculated time to reach 25% of the LFL under the off-normal ventilation condition would become 145 days rather than the 146 days predicted by the previous methods. Monitoring data from July 2001 show that the ammonia concentration in the dome space went up to 1,700 ppm. This is a factor of four increase compared to the January 2001 data. The increase of ammonia concentration could result from the increase of open surface area as discussed earlier. It also is possible that the results are from the reduced ventilation flow rate because a similar increase also was observed for both hydrogen and nitrous oxide. In any case, the ammonia concentration of 1,700 ppm is still within the range of the ammonia calculation, which shows that the time to 25% would be around 146 days whether the ammonia concentration is 400 ppm or 2,573 ppm under the off-normal ventilation condition.

These HGR models assume that hydrogen generation occurs in the liquid phase. For the supernatant layer, this model uses the supernatant composition data when calculating generation rates. For the solid layer, the interstitial liquid composition data and the liquid fraction are used to estimate the gas generation rate. The liquid fraction of the solid layer is estimated based on weight-percent-water data of interstitial liquid and bulk of the solid layer. If new data is not available, historical data from previous versions are used for each waste layer. The historical data from previous versions come from either BBI data or are statistically determined from the other tanks in the same waste group.

This page intentionally left blank.

5.0 SUMMARY AND CONCLUSIONS

The results of this report may be used to establish technical safety requirements for ventilation in tanks, establish maximum permissible down times for active ventilation systems, develop procedures for operations that require closing vent valves to HEPA filters on passively ventilated tanks, and support the technical basis for flammable gas control strategies. Revision 6 is mainly an update of the input data for HGR calculations using latest BBI data for physical and chemical properties of the waste and PCSACs data for waste temperatures.

The methodology for the HGR calculation was updated in Revision 4 with the newly upgraded HGR model (HNF-3851) as summarized in Chapter 2.0. The main thrust of applying the new model to current HGR calculations is to correctly calculate the water radiolysis term for the tanks having intermediate/dilute salt conditions. HGRs were calculated for the 177 SSTs and DSTs using this updated rate equation model and latest tank waste data. For tanks that do not have complete information, missing values were defaulted to the values used in Revision 4.

Flammable gas concentrations, in terms of percent of the LFL in the tank dome space, were evaluated under both normal and off-normal conditions for all 177 tanks. For normal ventilation conditions, all tanks are computed to remain well below 25% of the LFL with the highest flammable gas concentration level at 6.81% of the LFL in SST 241-C-107. With a barometric breathing rate, the shortest time to reach 25% of the LFL for current tank waste is 39 days for SST 241-B-203 and 11 days for DST 241-AZ-102; with zero ventilation scenario, the shortest time to reach 25% of the LFL for water addition is 35 days for SST 241-B-203 and 10 days for DST 241-AZ-102.

Calculated HGRs of current raw waste for DSTs ranged from $3.3 \text{ E-}2$ to $5.2 \text{ E-}4 \text{ ft}^3/\text{min}$ with the highest rate found in DST 241-AZ-102. For SSTs, the rate ranged from $6.0 \text{ E-}3$ to $2.0 \text{ E-}5 \text{ ft}^3/\text{min}$, with SST 241-SX-103 having the highest rate. For most DSTs, the tank data are sample based. For quite a few SSTs, the tanks were stabilized and no liquid samples were available.

The steady-state flammability level in the tank dome space was evaluated based on the steady-state gas concentrations of hydrogen, ammonia, and methane using Le Chatelier's rule. Overall, the calculations under off-normal conditions show that 20 DSTs and 7 SSTs will reach 25% of the LFL and 5 DSTs and 2 SSTs will reach 100% of the LFL if allowed to reach steady state with the off-normal ventilation rates of barometric breathing.

This page intentionally left blank.

6.0 REFERENCES

- 24590-WTP-RPT-RT-04-0002, 2004, *Modifying the Hu Correlation to Predict Hydrogen Formation in the Hanford Waste Treatment and Immobilization Plant*, Bechtel National, Richland, Washington.
- Coward, H. F., and G. W. Jones, 1952, *Limits of Flammability of Gases and Vapors*, Bumines B. 503, 155 pp.
- HNF-3294, 1998, *Adequacy of Ventilation Rates to Remediate Flammable Gas Levels in Headspace of Hanford Tanks – Status Report*, Rev. 0, Lockheed Martin Hanford Corporation, Richland, Washington.
- HNF-3851, 2004, *Empirical Rate Equation Model and Rate Calculations of Hydrogen Generation for Hanford Tank Waste*, Rev.1, CH2M HILL Hanford Group, Inc., Richland, Washington.
- HNF-SD-WM-CN-116, 1997, *Calculation Note Hydrogen Generation Rates At Steady State Flammable Gas Concentrations For Single-Shell Tanks*, Rev. 0A, Lockheed Martin Hanford Corporation, Richland, Washington.
- HNF-SD-WM-CN-117, 1997, *Calculations of Hydrogen Release Rate at Steady State for Double-Shell Tanks*, Rev. 0A, Lockheed Martin Hanford Corporation, Richland, Washington.
- HNF-SP-1193, 1997, *Flammable Gas Project Topical Report*, Rev. 2, Lockheed Martin Hanford Corporation, Richland, Washington.
- Pfahl, U., and J. Shepherd, 1997, *Flammability and Flame Propagation in H_2 - N_2 O- CH_4 - NH_3 - O_2 - N_2 Mixtures*, Explosion Dynamics Laboratory Report FM97-4, Graduate Aeronautical Laboratories, California Institute of Technology, Pasadena, California.
- PNNL-11297, 1996, *Status and Integration of Studies of Gas Generation in Hanford Wastes*, Rev. 0, Pacific Northwest National Laboratory, Richland, Washington.
- PNNL-11450, 1997, *Composition and Quantities of Retained Gas Measured in Hanford Waste Tanks 241-AW-101, A-101, AN-105, AN-104, and AN-103*, Rev. 1, Pacific Northwest National Laboratory, Richland, Washington.
- PNNL-11925, 1998, *Waste Tank Ventilation Rates Measured with A Tracer Gas Method, Fiscal Year 1998 Summary*, Pacific Northwest National Laboratory, Richland, Washington.
- PNNL-12181, 1999, *Thermal and Radiolytic Gas Generation on Material from Tanks 241-U-103, 241-AW-101, 241-S-106, and 241-S-102: Status Report*, Pacific Northwest National Laboratory, Richland, Washington.

- PNNL-13000, 1999, *Retained Gas Sampling Results for the Flammable Gas Program*, Rev. 0, Pacific Northwest National Laboratory, Richland, Washington.
- RPP-4941, 2000, *Methodology for Predicting Flammable Gas Mixtures in Double-Contained Receiver Tanks*, Rev. 0B, CH2M HILL Hanford Group, Inc., Richland, Washington.
- RPP-5660, 2000, *Collection And Analysis Of Selected Tank Headspace Parameter Data*, Rev. 0, CH2M HILL Hanford Group, Inc., Richland, Washington.
- RPP-6069, 2000, *Input Data for Hydrogen Generation Rate Model Calculation*, Rev. 0, CH2M HILL Hanford Group, Inc., Richland, Washington.
- RPP-6213, 2005, *Hanford Waste Tank Bump Accident and Consequence Analysis*, Rev. 4, CH2M HILL Hanford Group, Inc., Richland, Washington.
- RPP-6517, 2000, *Evaluation of Hanford High-Level Waste Tank 241-SY-101*, Rev. 0, CH2M HILL Hanford Group, Inc., Richland, Washington.
- RPP-18491, 2003, *Flammable Gas Diffusion Through Single-Shell Tank Domes*, Rev. 0, CH2M HILL Hanford Group, Inc., Richland, Washington.
- SACS, 2007, Surveillance Analysis Computer System, Queried September 2007, [Tank temperature data April 2006 through April 2007], HISI ID No. 242, CH2M HILL Hanford Group, Inc., Richland, Washington.
- SNL-000198, 1999, *Flammable Gas Safety Analysis Data Review*, Sandia National Laboratory, Albuquerque, New Mexico.
- TFC-ENG-CHEM-D-33, 2003, *Spreadsheet Verification*, Rev. B, CH2M HILL Hanford Group, Inc., Richland, Washington.
- TFC-ENG-DESIGN-C-10, 2006, *Engineering Calculations*, Rev. A-16, CH2M HILL Hanford Group, Inc., Richland, Washington.
- TFC-ENG-DESIGN-C-32, 2006, *Spreadsheet Development and Verification*, Rev. B-4, CH2M HILL Hanford Group, Inc., Richland, Washington.
- TWINS, 2007, *Tank Waste Information Network System*, [Best Basis Inventory data], internet address: <http://twins.pnl.gov/twins.htm>.
- Weisenberger, S., and A. Schumpe, 1996, "The Estimation of Gas Solubility in Salt Solutions at Temperature from 273 K to 363 K," *AIChE Journal*, Vol. 42, 299.
- WHC-EP-0651, 1993, *Barometric Pressure Variations*, Westinghouse Hanford Company, Richland, Washington.
- WHC-EP-0702, 1994, *Criteria for Flammable Gas Watch List Tanks*, Rev. 0, Westinghouse Hanford Company, Richland, Washington.

WHC-SD-WM-ES-219, 1992, *Laboratory Flammability Studies of Mixtures of Hydrogen, Nitrous Oxide, and Air*, Rev. 0, Westinghouse Hanford Company, Richland, Washington.

WHC-SD-WM-SARR-015, 1994, *Topical Report on Flammable Gases in Non-Burping Waste Tanks*, Westinghouse Hanford Company, Richland, Washington.

WHC-SD-WM-TI-724, 1996, *Methodology for Flammable Gas Evaluations*, Rev. 1, Westinghouse Hanford Company, Richland, Washington.

This page intentionally left blank.

APPENDIX A

**INPUT DATA FOR HYDROGEN GENERATION RATE CALCULATIONS FROM
BEST BASIS INVENTORY DETAIL CALCULATION REPORT AND DERIVATION
DOCUMENT (QUERIED ON SEPTEMBER 27, 2006)**

This page intentionally left blank.

CONTENTS

Table A-1. Best Basis Inventory - Density and Weight Percent Water by Tank, Waste Phase, and Waste Type Queried on September 17, 2007	A-1
Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for Hydrogen Generation Rate Calculations	A-13
Table A-3. Retained Gas Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for Hydrogen Generation Rate Calculations	A-36

This page intentionally left blank.

Table A-1. Best Basis Inventory - Density and Weight Percent Water By Tank, Waste Phase, and Waste Type Queried on September 17, 2007. (12 sheets)

Tank Name	Waste Phase	Waste Type	Volume (kL)	Density (g/mL)	Wt% Water
241-A-101	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	148	1.49	46.9
241-A-101	Saltcake Solid	A1-SltCk (Solid)	878	1.74	29.2
241-A-101	Sludge (Liquid & Solid)	P2 (Solid)	11	1.61	44.2
241-A-101	Retained Gas (Saltcake)	NA	174	NA	NA
241-A-102	Saltcake Solid	A1-SltCk (Solid)	106	1.7	34.3
241-A-102	Supernatant	A1-SltCk (Liquid)	12	1.57	46.2
241-A-102	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	33	1.57	46.2
241-A-103	Sludge (Liquid & Solid)	AR (Solid)	8	1.34	68.6
241-A-103	Saltcake Solid	A1-SltCk (Solid)	1071	1.32	37.8
241-A-103	Supernatant	A1-SltCk (Liquid)	17	1.51	50.3
241-A-103	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	338	1.51	50.3
241-A-104	Sludge Solid	AR (Solid)	102	0.946	0
241-A-104	Sludge Solid	P1 (Solid)	4	0.946	0
241-A-105	Sludge Solid	P2 (Solid)	139	1.54	0
241-A-106	Sludge (Liquid & Solid)	SRR (Solid)	110	1.7	34.3
241-A-106	Saltcake Solid	A1-SltCk (Solid)	110	1.7	34.3
241-A-106	Sludge (Liquid & Solid)	AR (Solid)	79	1.7	34.3
241-AN-101	Supernatant	NA (Liquid)	4208	1.4	52.1
241-AN-101	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	28	1.45	49.1
241-AN-101	Saltcake Solid	A1-SltCk (Solid)	90	1.58	37.8
241-AN-102	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	584	1.53	39.9
241-AN-102	Supernatant	NA (Liquid)	3446	1.41	48.9
241-AN-103	Supernatant	A2-SltSlr (Liquid)	1769	1.48	46.7
241-AN-103	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	1638	1.72	34.9
241-AN-103	Retained Gas (Saltcake)	NA	220	NA	NA
241-AN-104	Supernatant	A2-SltSlr (Liquid)	2298	1.4	51.1
241-AN-104	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	1566	1.59	45.7
241-AN-104	Retained Gas (Saltcake)	NA	119	NA	NA
241-AN-105	Supernatant	A2-SltSlr (Liquid)	2227	1.42	49.9
241-AN-105	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	1925	1.57	44.4
241-AN-105	Retained Gas (Saltcake)	NA	109	NA	NA
241-AN-106	Saltcake (Liquid & Solid)	NA (SltCk)	65	1.58	37.8
241-AN-106	Supernatant	NA (Liquid)	1958	1.11	83.5
241-AN-106	Sludge (Liquid & Solid)	NA (Sludge)	553	1.54	40.4
241-AN-106	Sludge Interstitial Liquid	NA (Liquid)	99	1.11	83.5
241-AN-107	Supernatant	A2-SltSlr (Liquid)	3297	1.43	51.5
241-AN-107	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	872	1.48	44.3
241-AP-101	Supernatant	A2-SltSlr (Liquid)	4374	1.22	68.5
241-AP-102	Supernatant	Waste Transfer	4049	1.39	58.7
241-AP-102	Sludge (Liquid & Solid)	NA (Sludge)	88	1.75	31.1
241-AP-103	Supernatant	NA (Liquid)	2806	1.37	55.2
241-AP-103	Sludge (Liquid & Solid)	NA (Sludge)	70	1.68	40.9
241-AP-104	Supernatant	NA (Liquid)	4155	1.28	66.4
241-AP-105	Supernatant	Waste Transfer	3965	1.27	71.4
241-AP-105	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	337	1.61	47.7
241-AP-106	Supernatant	NA (Liquid)	4301	1.21	72.4

Table A-1. Best Basis Inventory - Density and Weight Percent Water By Tank, Waste Phase, and Waste Type Queried on September 17, 2007. (12 sheets)

Tank Name	Waste Phase	Waste Type	Volume (kL)	Density (g/mL)	Wt% Water
241-AP-107	Supernatant	NA (Liquid)	4274	1.28	67.6
241-AP-108	Supernatant	NA (Liquid)	4337	1.41	50.8
241-AP-108	Saltcake (Liquid & Solid)	NA (SlrCk)	383	1.55	45
241-AW-101	Retained Gas (Saltcake)	NA	95	NA	NA
241-AW-101	Supernatant	A2-SltSlr (Liquid)	2770	1.47	43.8
241-AW-101	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	1403	1.59	43.9
241-AW-102	Sludge (Liquid & Solid)	NA (Sludge)	116	1.6	33.4
241-AW-102	Supernatant	NA (Liquid)	3973	1.07	88.2
241-AW-103	Supernatant	NA (Liquid)	2893	1.24	69.2
241-AW-103	Sludge (Liquid & Solid)	CWZr2 (Solid)	1105	1.47	55.8
241-AW-103	Saltcake Solid	A1-SltCk (Solid)	115	1.69	45.2
241-AW-103	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	36	1.42	50.5
241-AW-104	Saltcake Interstitial Liquid	A2-SltSlr (Liquid)	136	1.45	52
241-AW-104	Saltcake Solid	A2-SltSlr (Solid)	457	1.6	42
241-AW-104	Supernatant	NA (Liquid)	3205	1.35	66.4
241-AW-104	Sludge Solid	PL2 (Solid)	188	1.28	65.8
241-AW-104	Sludge Interstitial Liquid	PL2 (Liquid)	62	1.33	63.8
241-AW-105	Sludge (Liquid & Solid)	CWZr2 (Solid)	841	1.33	63.8
241-AW-105	Supernatant	NA (Liquid)	638	1.04	90.3
241-AW-105	Sludge (Liquid & Solid)	PL2 (Solid)	99	1.35	58.7
241-AW-106	Supernatant	NA (Liquid)	3225	1.22	70.7
241-AW-106	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	1062	1.77	29.7
241-AX-101	Saltcake Solid	A1-SltCk (Solid)	1164	1.73	32.5
241-AX-101	Sludge (Liquid & Solid)	SRR (Solid)	11	1.51	62.2
241-AX-101	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	178	1.53	43.1
241-AX-102	Saltcake (Liquid & Solid)	A1-SltCk (Solid)	90	1.58	33.9
241-AX-102	Sludge (Liquid & Solid)	B (Solid)	23	1.57	42.5
241-AX-103	Saltcake Solid	A1-SltCk (Solid)	298	1.61	43.2
241-AX-103	Sludge (Liquid & Solid)	P2 (Solid)	30	1.61	44.2
241-AX-103	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	75	1.45	49.1
241-AX-104	Sludge Solid	P2 (Solid)	28	1.8	8.23
241-AY-101	Supernatant	NA (Liquid)	2750	1.13	81.5
241-AY-101	Sludge Solid	NA (Sludge)	339	1.78	35.1
241-AY-101	Sludge Interstitial Liquid	NA (Liquid)	60	1.14	81.4
241-AY-102	Sludge Solid	BL (Solid)	75	1.71	31.6
241-AY-102	Supernatant	NA (Liquid)	3212	1.29	64.8
241-AY-102	Sludge Interstitial Liquid	BL (Liquid)	120	1.15	82
241-AY-102	Sludge Solid	NA (Sludge)	376	1.71	31.6
241-AZ-101	Supernatant	P3AZ1 (Liquid)	2991	1.24	72.1
241-AZ-101	Sludge (Liquid & Solid)	P3AZ1 (Solid)	167	1.61	34.3
241-AZ-101	Sludge (Liquid & Solid)	NA (Sludge)	30	1.61	34.3
241-AZ-102	Supernatant	P3AZ2 (Liquid)	3212	1.13	83.6
241-AZ-102	Sludge (Liquid & Solid)	P3AZ2 (Solid)	275	1.41	54.8
241-AZ-102	Sludge (Liquid & Solid)	PL2 (Solid)	15	1.41	54.8
241-AZ-102	Sludge (Liquid & Solid)	SRR (Solid)	98	1.41	54.8
241-AZ-102	Sludge (Liquid & Solid)	NA (Sludge)	8	1.41	54.8

Table A-1. Best Basis Inventory - Density and Weight Percent Water By Tank, Waste Phase, and Waste Type Queried on September 17, 2007. (12 sheets)

Tank Name	Waste Phase	Waste Type	Volume (kL)	Density (g/mL)	Wt% Water
241-B-101	Sludge (Liquid & Solid)	MW1 (Solid)	11	1.8	43.8
241-B-101	Sludge (Liquid & Solid)	B (Solid)	19	1.74	52.7
241-B-101	Sludge (Liquid & Solid)	BL (Solid)	76	1.5	52.4
241-B-101	Saltcake Interstitial Liquid	B-SltCk (Liquid)	73	1.53	50
241-B-101	Saltcake Solid	B-SltCk (Solid)	232	1.48	32
241-B-102	Saltcake Solid	B-SltCk (Solid)	81	1.72	39.7
241-B-102	Saltcake Interstitial Liquid	B-SltCk (Liquid)	25	1.26	69.6
241-B-102	Supernatant	B-SltCk (Liquid)	15	1.26	69.6
241-B-103	Saltcake Solid	B-SltCk (Solid)	157	1.72	44.9
241-B-103	Saltcake Interstitial Liquid	B-SltCk (Liquid)	50	1.26	69.6
241-B-103	Sludge (Liquid & Solid)	MW1 (Solid)	4	1.8	43.8
241-B-104	Sludge (Liquid & Solid)	1C (Solid)	473	1.39	46.7
241-B-104	Saltcake Interstitial Liquid	B-SltCk (Liquid)	55	1.26	69.6
241-B-104	Saltcake Solid	B-SltCk (Solid)	192	1.39	46.7
241-B-104	Sludge (Liquid & Solid)	2C (Solid)	697	1.39	46.7
241-B-105	Saltcake Solid	B-SltCk (Solid)	919	1.72	40.2
241-B-105	Saltcake Interstitial Liquid	B-SltCk (Liquid)	73	1.26	69.6
241-B-105	Sludge (Liquid & Solid)	2C (Solid)	61	1.28	66.6
241-B-105	Sludge (Liquid & Solid)	1C (Solid)	45	1.43	54.1
241-B-106	Sludge (Liquid & Solid)	TBP (Solid)	297	1.36	61.6
241-B-106	Supernatant	B-SltCk (Liquid)	4	1.26	67.2
241-B-106	Sludge (Liquid & Solid)	1C (Solid)	163	1.42	56.8
241-B-107	Saltcake Interstitial Liquid	B-SltCk (Liquid)	68	1.34	57.5
241-B-107	Sludge (Liquid & Solid)	1C (Solid)	285	1.63	42.1
241-B-107	Saltcake Solid	B-SltCk (Solid)	216	1.7	33.1
241-B-107	Sludge (Liquid & Solid)	CWP2 (Solid)	42	1.68	40.9
241-B-108	Saltcake Solid	B-SltCk (Solid)	204	1.72	33.3
241-B-108	Sludge (Liquid & Solid)	CWP2 (Solid)	104	1.8	25.9
241-B-108	Saltcake Interstitial Liquid	B-SltCk (Liquid)	42	1.38	69.6
241-B-109	Sludge (Liquid & Solid)	CWP2 (Solid)	189	1.85	36.2
241-B-109	Saltcake Solid	B-SltCk (Solid)	245	1.89	38.4
241-B-109	Saltcake Interstitial Liquid	B-SltCk (Liquid)	41	1.26	69.6
241-B-110	Sludge (Liquid & Solid)	B (Solid)	11	1.36	58.3
241-B-110	Sludge (Liquid & Solid)	2C (Solid)	914	1.36	58.3
241-B-110	Supernatant	CSR (Liquid)	4	1.19	76.2
241-B-111	Sludge (Liquid & Solid)	2C (Solid)	809	1.27	63.1
241-B-111	Sludge (Liquid & Solid)	B (Solid)	101	1.27	63.1
241-B-111	Supernatant	CSR (Liquid)	4	1.19	76.2
241-B-112	Supernatant	BY-SltCk (Liquid)	11	1.51	46.2
241-B-112	Sludge (Liquid & Solid)	2C (Solid)	56	1.49	40.2
241-B-112	Saltcake Solid	BY-SltCk (Solid)	49	1.49	40.2
241-B-112	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	16	1.51	46.2
241-B-201	Sludge (Liquid & Solid)	224-1 (Solid)	111	1.26	64.2
241-B-202	Sludge (Liquid & Solid)	224-2 (Solid)	108	1.22	75.9
241-B-203	Sludge (Liquid & Solid)	224-2 (Solid)	188	1.19	75.7
241-B-203	Supernatant	NA (Liquid)	2	1.05	89.4

Table A-1. Best Basis Inventory - Density and Weight Percent Water By Tank, Waste Phase, and Waste Type Queried on September 17, 2007. (12 sheets)

Tank Name	Waste Phase	Waste Type	Volume (kL)	Density (g/mL)	Wt% Water
241-B-204	Sludge (Liquid & Solid)	224-2 (Solid)	184	1.19	77.3
241-B-204	Supernatant	NA (Liquid)	3	1.05	91.4
241-BX-101	Sludge (Liquid & Solid)	TBP (Solid)	59	1.68	15.5
241-BX-101	Sludge (Liquid & Solid)	CWP2 (Solid)	47	1.68	15.5
241-BX-101	Sludge (Liquid & Solid)	BL (Solid)	74	1.68	15.5
241-BX-102	Sludge Solid	CWP2 (Solid)	81	1.68	40.9
241-BX-102	Sludge Solid	DE (Solid)	147	0.648	0
241-BX-102	Sludge Solid	TBP (Solid)	70	1.47	50.5
241-BX-103	Supernatant	CWP2 (Liquid)	50	1.07	77.8
241-BX-103	Sludge (Liquid & Solid)	TBP (Solid)	21	1.47	49.6
241-BX-103	Sludge (Liquid & Solid)	CWP2 (Solid)	214	1.68	49.6
241-BX-104	Supernatant	CWR1 (Liquid)	11	1.28	59.1
241-BX-104	Sludge (Liquid & Solid)	CWP2 (Solid)	51	1.68	26.9
241-BX-104	Sludge (Liquid & Solid)	MW1 (Solid)	155	1.68	26.9
241-BX-104	Sludge (Liquid & Solid)	CWR1 (Solid)	110	1.68	26.9
241-BX-104	Sludge (Liquid & Solid)	TBP (Solid)	53	1.68	26.9
241-BX-105	Supernatant	CWP2 (Liquid)	18	1.29	68.7
241-BX-105	Sludge (Liquid & Solid)	TBP (Solid)	55	1.69	12.6
241-BX-105	Sludge (Liquid & Solid)	MW1 (Solid)	9	1.8	43.8
241-BX-105	Sludge (Liquid & Solid)	CWP2 (Solid)	96	1.69	12.6
241-BX-105	Saltcake (Liquid & Solid)	BY-SltCk (Solid)	94	1.69	12.6
241-BX-106	Saltcake Solid	BY-SltCk (Solid)	80	1.64	38.7
241-BX-106	Sludge (Liquid & Solid)	TBP (Solid)	20	1.64	38.7
241-BX-106	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	25	1.51	46.2
241-BX-106	Sludge (Liquid & Solid)	CWP2 (Solid)	18	1.64	38.7
241-BX-107	Sludge (Liquid & Solid)	1C (Solid)	1313	1.44	50.5
241-BX-108	Sludge (Liquid & Solid)	1C (Solid)	38	1.43	17.2
241-BX-108	Sludge (Liquid & Solid)	TBP (Solid)	81	1.47	17.2
241-BX-109	Sludge (Liquid & Solid)	TBP (Solid)	730	1.52	50.6
241-BX-110	Saltcake Solid	BY-SltCk (Solid)	433	1.79	36.6
241-BX-110	Supernatant	BY-SltCk (Liquid)	5	1.44	53.1
241-BX-110	Sludge (Liquid & Solid)	NA (Sludge)	94	1.79	36.6
241-BX-110	Sludge (Liquid & Solid)	1C (Solid)	151	1.43	54.1
241-BX-110	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	129	1.44	53.1
241-BX-111	Saltcake Solid	BY-SltCk (Solid)	538	1.45	15.6
241-BX-111	Sludge (Liquid & Solid)	1C (Solid)	121	1.43	54.1
241-BX-111	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	54	1.45	51.2
241-BX-112	Supernatant	1C2 (Liquid)	5	1.18	67.6
241-BX-112	Sludge (Liquid & Solid)	1C (Solid)	617	1.31	63.3
241-BY-101	Saltcake Solid	BY-SltCk (Solid)	1208	1.87	20.4
241-BY-101	Sludge (Liquid & Solid)	PFeCN (Solid)	140	1.68	32.4
241-BY-101	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	52	1.51	46.2
241-BY-102	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	157	1.46	50.8
241-BY-102	Saltcake Solid	BY-SltCk (Solid)	897	1.59	27.9
241-BY-103	Sludge (Liquid & Solid)	CWP2 (Solid)	34	1.68	40.9
241-BY-103	Saltcake Solid	BY-SltCk (Solid)	1316	1.72	23.7

Table A-1. Best Basis Inventory - Density and Weight Percent Water By Tank, Waste Phase, and Waste Type Queried on September 17, 2007. (12 sheets)

Tank Name	Waste Phase	Waste Type	Volume (kL)	Density (g/mL)	Wt% Water
241-BY-103	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	214	1.29	59
241-BY-104	Saltcake Solid	BY-SltCk (Solid)	1208	1.75	23
241-BY-104	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	153	1.51	48.9
241-BY-104	Sludge (Liquid & Solid)	PFeCN (Solid)	172	1.64	29
241-BY-105	Saltcake Solid	BY-SltCk (Solid)	1481	1.85	14.6
241-BY-105	Sludge (Liquid & Solid)	PFeCN (Solid)	151	1.68	25.5
241-BY-105	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	159	1.44	51.3
241-BY-105	Sludge (Liquid & Solid)	Portland Cement (Solid)	30	1.9	8
241-BY-106	Sludge (Liquid & Solid)	PFeCN (Solid)	120	1.68	37.3
241-BY-106	Saltcake Solid	BY-SltCk (Solid)	1365	1.68	23.3
241-BY-106	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	138	1.31	59.4
241-BY-107	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	135	1.46	48.6
241-BY-107	Saltcake Solid	BY-SltCk (Solid)	835	1.72	36.3
241-BY-107	Sludge (Liquid & Solid)	PFeCN (Solid)	58	1.78	37.6
241-BY-108	Saltcake Solid	BY-SltCk (Solid)	587	1.5	25.5
241-BY-108	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	103	1.33	32.7
241-BY-108	Sludge (Liquid & Solid)	PFeCN (Solid)	151	1.53	31
241-BY-109	Saltcake Solid	BY-SltCk (Solid)	851	1.71	42
241-BY-109	Sludge (Liquid & Solid)	CWP2 (Solid)	89	2	28.4
241-BY-109	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	146	1.5	53
241-BY-110	Saltcake Solid	BY-SltCk (Solid)	1123	1.54	27.3
241-BY-110	Sludge (Liquid & Solid)	PFeCN (Solid)	162	1.82	28.7
241-BY-110	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	99	1.44	39.9
241-BY-111	Saltcake Solid	BY-SltCk (Solid)	1378	1.7	33.6
241-BY-111	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	145	1.42	53.8
241-BY-112	Saltcake Solid	BY-SltCk (Solid)	996	1.76	28.3
241-BY-112	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	79	1.47	48.5
241-BY-112	Sludge (Liquid & Solid)	MW2 (Solid)	8	1.85	41.4
241-C-101	Sludge (Liquid & Solid)	TBP (Solid)	125	1.78	23.4
241-C-101	Sludge (Liquid & Solid)	CWP1 (Solid)	208	1.78	23.4
241-C-102	Sludge (Liquid & Solid)	MW1 (Solid)	19	1.8	43.8
241-C-102	Sludge (Liquid & Solid)	TBP (Solid)	61	1.47	50.5
241-C-102	Sludge (Liquid & Solid)	CWP1 (Solid)	125	1.63	33.4
241-C-102	Sludge (Liquid & Solid)	TH1 (Solid)	98	1.32	63.5
241-C-102	Sludge (Liquid & Solid)	CWZr1 (Solid)	38	1.74	65.3
241-C-102	Sludge (Liquid & Solid)	CWP2 (Solid)	855	1.74	40.9
241-C-103	Sludge (Liquid & Solid)	NA (Sludge)	8.64	1.61	9
241-C-103	Supernatant	NA (Liquid)	0.93	0.98	98
241-C-104	Sludge (Liquid & Solid)	CWZr1 (Solid)	90	1.68	47.9
241-C-104	Sludge (Liquid & Solid)	OWW3 (Solid)	103	1.68	47.9
241-C-104	Sludge (Liquid & Solid)	CWP2 (Solid)	229	1.68	47.9
241-C-104	Sludge (Liquid & Solid)	TH2 (Solid)	80	1.68	47.9
241-C-104	Sludge (Liquid & Solid)	CWP1 (Solid)	326	1.68	47.9
241-C-104	Sludge (Liquid & Solid)	NA (Sludge)	152	1.68	47.9
241-C-105	Sludge (Liquid & Solid)	CWP1 (Solid)	450	1.55	25.8
241-C-105	Sludge (Liquid & Solid)	TBP (Solid)	50	1.55	50.5

Table A-1. Best Basis Inventory - Density and Weight Percent Water By Tank, Waste Phase, and Waste Type Queried on September 17, 2007. (12 sheets)

Tank Name	Waste Phase	Waste Type	Volume (kL)	Density (g/mL)	Wt% Water
241-C-106	Sludge (Liquid & Solid)	NA (Sludge)	10.166	1.56	41.9
241-C-106	Supernatant	NA (Liquid)	0.322	1.02	97.8
241-C-107	Sludge (Liquid & Solid)	1C (Solid)	507	1.55	47.5
241-C-107	Sludge (Liquid & Solid)	SRR (Solid)	339	1.55	47.5
241-C-107	Sludge (Liquid & Solid)	CWP2 (Solid)	89	1.55	47.5
241-C-108	Sludge (Liquid & Solid)	1C (Solid)	95	1.48	38.2
241-C-109	Sludge (Liquid & Solid)	CWP1 (Solid)	55	1.57	36.1
241-C-109	Sludge (Liquid & Solid)	HS (Solid)	26	1.57	36.1
241-C-109	Sludge (Liquid & Solid)	TFeCN (Solid)	121	1.57	36.1
241-C-109	Sludge (Liquid & Solid)	1C (Solid)	38	1.43	54.1
241-C-110	Sludge (Liquid & Solid)	1C (Solid)	670	1.34	60.2
241-C-110	Supernatant	1C1 (Liquid)	4	1.1	82.9
241-C-111	Sludge (Liquid & Solid)	CWP1 (Solid)	60	1.58	31.4
241-C-111	Sludge (Liquid & Solid)	HS (Solid)	17	1.58	31.4
241-C-111	Sludge (Liquid & Solid)	TFeCN (Solid)	91	1.58	31.4
241-C-111	Sludge (Liquid & Solid)	1C (Solid)	49	1.43	54.1
241-C-112	Sludge (Liquid & Solid)	CWP1 (Solid)	49	1.6	51.5
241-C-112	Sludge (Liquid & Solid)	TFeCN (Solid)	272	1.6	51.5
241-C-112	Sludge (Liquid & Solid)	1C (Solid)	57	1.43	54.1
241-C-112	Sludge (Liquid & Solid)	HS (Solid)	4	1.6	51.5
241-C-112	Sludge (Liquid & Solid)	CWP2 (Solid)	11	1.6	51.5
241-C-201	Sludge Solid	HS (Solid)	0.537	1.75	24.4
241-C-201	Supernatant	NA (Liquid)	0.007	1	100
241-C-202	Sludge (Liquid & Solid)	HS (Solid)	0.548	1.75	24.4
241-C-202	Supernatant	NA (Liquid)	0.009	1	100
241-C-203	Sludge (Liquid & Solid)	HS (Solid)	0.476	1.93	35.5
241-C-203	Supernatant	NA (Liquid)	0.048	1	100
241-C-204	Sludge (Liquid & Solid)	HS (Solid)	0.507	1.77	38.2
241-C-204	Supernatant	NA (Liquid)	0.011	1	100
241-S-101	Sludge (Liquid & Solid)	NA (Sludge)	890	1.7	37.5
241-S-101	Saltcake Solid	S1-SltCk (Solid)	246	1.56	42.4
241-S-101	Saltcake Solid	S2-SltSlr (Solid)	169	1.56	42.4
241-S-101	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	16	1.47	50.7
241-S-101	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	11	1.47	50.7
241-S-102	Sludge (Liquid & Solid)	R1 (Solid)	71	1.88	22.2
241-S-102	Retained Gas (Saltcake)	NA	9	NA	NA
241-S-102	Retained Gas (Sludge)	NA	13	NA	NA
241-S-102	Saltcake Solid	NA (SltCk)	55	1.69	36.2
241-S-103	Sludge (Liquid & Solid)	R1 (Solid)	34	1.77	22.7
241-S-103	Saltcake Solid	S1-SltCk (Solid)	347	1.68	30.2
241-S-103	Saltcake Solid	S2-SltSlr (Solid)	300	1.63	34.9
241-S-103	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	95	1.45	49.8
241-S-103	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	116	1.45	49.8
241-S-103	Supernatant	S2-SltSlr (Liquid)	4	1.45	49.8
241-S-104	Sludge (Liquid & Solid)	R1 (Solid)	409	1.77	33.5
241-S-104	Saltcake Interstitial Liquid	R-SltCk (Liquid)	139	1.37	55.1

Table A-1. Best Basis Inventory - Density and Weight Percent Water By Tank, Waste Phase, and Waste Type Queried on September 17, 2007. (12 sheets)

Tank Name	Waste Phase	Waste Type	Volume (kL)	Density (g/mL)	Wt% Water
241-S-104	Saltcake Solid	R-SltCk (Solid)	451	1.64	41
241-S-104	Sludge (Liquid & Solid)	CWR1 (Solid)	91	1.8	33.5
241-S-105	Saltcake Solid	S1-SltCk (Solid)	1371	1.68	3.57
241-S-105	Sludge (Liquid & Solid)	R1 (Solid)	8	1.77	22.7
241-S-105	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	157	1.45	49.1
241-S-106	Saltcake Solid	S1-SltCk (Solid)	1624	1.74	33.5
241-S-106	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	99	1.43	54.2
241-S-107	Saltcake Solid	T2-SltCk (Solid)	52	1.57	44.895
241-S-107	Sludge (Liquid & Solid)	CWR1 (Solid)	447	1.8	33
241-S-107	Sludge (Liquid & Solid)	CWZr1 (Solid)	91	1.8	33
241-S-107	Sludge (Liquid & Solid)	CWR2 (Solid)	211	1.8	33
241-S-107	Saltcake Solid	S1-SltCk (Solid)	63	1.57	44.895
241-S-107	Saltcake Solid	S2-SltSlr (Solid)	30	1.57	44.895
241-S-107	Sludge (Liquid & Solid)	R1 (Solid)	462	1.8	33
241-S-108	Sludge (Liquid & Solid)	R1 (Solid)	19	1.77	22.7
241-S-108	Saltcake Solid	S1-SltCk (Solid)	2032	1.68	30.2
241-S-108	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	31	1.45	49.1
241-S-109	Saltcake Solid	S1-SltCk (Solid)	1905	1.66	9.1
241-S-109	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	63	1.49	53.1
241-S-109	Sludge (Liquid & Solid)	R1 (Solid)	49	1.77	22.7
241-S-110	Saltcake Interstitial Liquid	S1-Sltck (Liquid)	115	1.43	49.3
241-S-110	Saltcake Solid	S1-Sltck (Solid)	994	1.65	12.5
241-S-110	Sludge (Liquid & Solid)	R1 (Solid)	288	1.77	31.5
241-S-110	Sludge (Liquid & Solid)	CWR1 (Solid)	76	1.77	31.5
241-S-111	Sludge (Liquid & Solid)	R1 (Solid)	207	1.67	19.4
241-S-111	Sludge (Liquid & Solid)	CWR1 (Solid)	38	1.67	19.4
241-S-111	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	124	1.45	51
241-S-111	Saltcake Solid	S1-SltCk (Solid)	1028	1.53	29
241-S-111	Retained Gas (Saltcake)	NA	77	NA	NA
241-S-111	Retained Gas (Sludge)	NA	43	NA	NA
241-S-112	Saltcake Solid	S1-SltCk (Solid)	6.358	1.69	41.3
241-S-112	Sludge (Liquid & Solid)	R1 (Solid)	2.216	1.77	22.7
241-S-112	Supernatant	NA (liquid)	0.469	1	100
241-SX-101	Saltcake Solid	R-SltCk (Solid)	497	1.69	25.5521
241-SX-101	Saltcake Interstitial Liquid	R-SltCk (Liquid)	41	1.48	49.1015
241-SX-101	Saltcake Solid	S1-SltCk (Solid)	296	1.69	25.5521
241-SX-101	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	25	1.48	49.1015
241-SX-101	Saltcake Solid	S2-SltSlr (Solid)	166	1.69	25.5521
241-SX-101	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	14	1.48	49.1015
241-SX-101	Sludge (Liquid & Solid)	R1 (Solid)	545	1.69	25.5521
241-SX-102	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	105	1.46	48.1
241-SX-102	Saltcake Solid	S1-SltCk (Solid)	875	1.72	38.52
241-SX-102	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	11	1.46	48.1
241-SX-102	Saltcake Solid	S2-SltSlr (Solid)	92	1.72	38.52
241-SX-102	Sludge (Liquid & Solid)	R1 (Solid)	209	1.72	38.52
241-SX-103	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	94	1.47	46.6

Table A-1. Best Basis Inventory - Density and Weight Percent Water By Tank, Waste Phase, and Waste Type Queried on September 17, 2007. (12 sheets)

Tank Name	Waste Phase	Waste Type	Volume (kL)	Density (g/mL)	Wt% Water
241-SX-103	Sludge (Liquid & Solid)	R1 (Solid)	294	1.88	21.9
241-SX-103	Saltcake Solid	S1-Sltck (Solid)	1439	1.72	30.9
241-SX-103	Saltcake Solid	R-SltCk (Solid)	77	1.72	37.3
241-SX-103	Saltcake Interstitial Liquid	R-SltCk (Liquid)	22	1.47	46.6
241-SX-104	Saltcake Solid	S1-SltCk (Solid)	903	1.68	30.2
241-SX-104	Sludge (Liquid & Solid)	R1 (Solid)	515	1.77	22.7
241-SX-104	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	111	1.47	45.3291
241-SX-104	Saltcake Solid	R-SltCk (Solid)	142	1.72	23.4
241-SX-104	Saltcake Interstitial Liquid	R-SltCk (Liquid)	17	1.47	45.3291
241-SX-105	Saltcake Solid	S1-SltCk (Solid)	1061	1.64	37.1
241-SX-105	Sludge (Liquid & Solid)	R1 (Solid)	189	1.67	22.7
241-SX-105	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	123	1.47	42.9
241-SX-105	Sludge (Liquid & Solid)	R2 (Solid)	49	1.67	22.7
241-SX-106	Saltcake Solid	S2-SltSlr (Solid)	1107	1.61	39
241-SX-106	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	122	1.29	49.4
241-SX-106	Saltcake Solid	S1-SltCk (Solid)	245	1.61	39
241-SX-106	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	27	1.29	49.4
241-SX-107	Sludge (Liquid & Solid)	R1 (Solid)	239	1.77	22.7
241-SX-107	Sludge (Liquid & Solid)	R2 (Solid)	117	1.77	22.7
241-SX-108	Sludge Solid	R1 (Solid)	186	1.77	2.03
241-SX-108	Sludge Solid	R2 (Solid)	94	1.77	2.03
241-SX-109	Sludge Solid	R1 (Solid)	170	1.77	22.7
241-SX-109	Saltcake Solid	R-SltCk (Solid)	662	1.72	23.4
241-SX-109	Sludge Solid	R2 (Solid)	81	1.77	22.7
241-SX-110	Sludge Solid	R2 (Solid)	184	1.77	22.7
241-SX-110	Saltcake Solid	R-SltCk (Solid)	28	1.72	23.4
241-SX-111	Sludge (Liquid & Solid)	R1 (Solid)	164	1.77	22.7
241-SX-111	Saltcake Solid	R-SltCk (Solid)	67	1.72	23.4
241-SX-111	Sludge (Liquid & Solid)	R2 (Solid)	205	1.77	22.7
241-SX-112	Sludge (Liquid & Solid)	R1 (Solid)	144	1.77	22.7
241-SX-112	Sludge (Liquid & Solid)	R2 (Solid)	139	1.77	22.7
241-SX-113	Sludge Solid	R1 (Solid)	8	1.43	46
241-SX-113	Sludge Solid	DE (Solid)	64	1.43	46
241-SX-114	Sludge (Liquid & Solid)	R1 (Solid)	298	1.77	22.7
241-SX-114	Saltcake Solid	R-SltCk (Solid)	84	1.72	23.4
241-SX-114	Saltcake Interstitial Liquid	R-SltCk (Liquid)	26	1.5	51.9
241-SX-114	Sludge (Liquid & Solid)	R2 (Solid)	180	1.77	22.7
241-SX-115	Sludge Solid	R2 (Solid)	16	1.77	10.1
241-SY-101	Supernatant	NA (Liquid)	3200	1.13	79.3
241-SY-101	Retained Gas (Saltcake)	NA	87	NA	NA
241-SY-101	Saltcake (Liquid & Solid)	S2-SltSlr (Solid)	893	1.52	50.4
241-SY-102	Sludge Solid	Z (Solid)	183	1.65	41.3
241-SY-102	Sludge Solid	NA (Sludge)	336	1.65	41.3
241-SY-102	Sludge Interstitial Liquid	Z (Liquid)	82	1.36	63.2
241-SY-102	Sludge Interstitial Liquid	NA (Liquid)	151	1.28	67.7
241-SY-102	Supernatant	NA (Liquid)	1039	1.13	80.1

Table A-1. Best Basis Inventory - Density and Weight Percent Water By Tank, Waste Phase, and Waste Type Queried on September 17, 2007. (12 sheets)

Tank Name	Waste Phase	Waste Type	Volume (kL)	Density (g/mL)	Wt% Water
241-SY-103	Supernatant	S2-SltSlr (Liquid)	1503	1.47	43.1
241-SY-103	Retained Gas (Saltcake)	NA	91	NA	NA
241-SY-103	Saltcake (Liquid & Solid)	S2-SltSlr (Solid)	1203	1.61	36.5
241-T-101	Sludge (Liquid & Solid)	CWR2 (Solid)	140	1.46	51.7
241-T-101	Saltcake Solid	T2-SltCk (Solid)	179	1.64	28.3
241-T-101	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	57	1.45	49.1
241-T-102	Sludge (Liquid & Solid)	CWP2 (Solid)	64	1.79	28.075
241-T-102	Supernatant	CSR (Liquid)	48	1.14	79.77
241-T-102	Sludge (Liquid & Solid)	MW2 (Solid)	8	1.85	41.4
241-T-103	Supernatant	CSR (Liquid)	15	1.19	71.6
241-T-103	Sludge (Liquid & Solid)	CWR1 (Solid)	19	1.8	24.5
241-T-103	Sludge (Liquid & Solid)	CWP2 (Solid)	64	1.68	40.9
241-T-103	Sludge (Liquid & Solid)	MW2 (Solid)	4	1.85	41.4
241-T-104	Sludge (Liquid & Solid)	1C (Solid)	1199	1.29	70.525
241-T-105	Sludge (Liquid & Solid)	2C (Solid)	273	1.51	53.5
241-T-105	Sludge (Liquid & Solid)	1C (Solid)	6	1.32	51.4
241-T-105	Sludge (Liquid & Solid)	CWR1 (Solid)	92	1.32	51.4
241-T-106	Sludge (Liquid & Solid)	1C (Solid)	38	1.43	16.7
241-T-106	Sludge (Liquid & Solid)	CWR1 (Solid)	34	1.8	16.7
241-T-106	Sludge (Liquid & Solid)	CWR2 (Solid)	10	1.46	16.7
241-T-107	Sludge (Liquid & Solid)	CWP2 (Solid)	32	1.56	45.7
241-T-107	Sludge (Liquid & Solid)	1C (Solid)	559	1.56	45.7
241-T-107	Sludge (Liquid & Solid)	TBP (Solid)	64	1.56	45.7
241-T-108	Sludge (Liquid & Solid)	1C (Solid)	20	1.43	54.1
241-T-108	Saltcake Solid	T1-SltCk (Solid)	30	1.72	15.1
241-T-108	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	10	1.26	69.6
241-T-109	Saltcake Solid	T1-SltCk (Solid)	197	1.72	47.9083
241-T-109	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	38	1.26	69.6
241-T-110	Sludge (Liquid & Solid)	224-2 (Solid)	37	1.25	75.5
241-T-110	Sludge (Liquid & Solid)	2C (Solid)	1360	1.25	75.5
241-T-110	Supernatant	2C1 (Liquid)	3	1.05	86.8
241-T-111	Sludge (Liquid & Solid)	2C (Solid)	787	1.24	75.3
241-T-111	Sludge (Liquid & Solid)	224-2 (Solid)	904	1.24	75.3
241-T-112	Sludge (Liquid & Solid)	2C (Solid)	135	1.28	73.9
241-T-112	Supernatant	DW (Liquid)	13	1.1	85.05
241-T-112	Sludge (Liquid & Solid)	224-2 (Solid)	91	1.28	73.9
241-T-112	Supernatant	CSR (Liquid)	13	1.1	85.05
241-T-201	Sludge (Liquid & Solid)	224-1 (Solid)	107	1.31	67.5
241-T-201	Supernatant	224-1 (Liquid)	8	1.06	91.2
241-T-202	Sludge (Liquid & Solid)	224-2 (Solid)	77	1.18	75.8
241-T-203	Sludge (Liquid & Solid)	224-2 (Solid)	136	1.22	76.2
241-T-204	Sludge (Liquid & Solid)	224-2 (Solid)	136	1.18	75
241-TX-101	Sludge (Liquid & Solid)	R1 (Solid)	265	1.77	22.7
241-TX-101	Saltcake Solid	T2-SltCk (Solid)	49	1.64	28.3
241-TX-101	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	15	1.45	49.1
241-TX-101	Sludge (Liquid & Solid)	MW2 (Solid)	11	1.85	41.4

Table A-1. Best Basis Inventory - Density and Weight Percent Water By Tank, Waste Phase, and Waste Type Queried on September 17, 2007. (12 sheets)

Tank Name	Waste Phase	Waste Type	Volume (kL)	Density (g/mL)	Wt% Water
241-TX-101	Sludge (Liquid & Solid)	Z (Solid)	4	1.76	29.1
241-TX-102	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	121	1.45	49.1
241-TX-102	Saltcake Solid	T2-SltCk (Solid)	692	1.64	28.3
241-TX-102	Sludge (Liquid & Solid)	MW2 (Solid)	8	1.85	41.4
241-TX-103	Saltcake Solid	T1-SltCk (Solid)	9	1.72	23.5
241-TX-103	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	82	1.45	49.1
241-TX-103	Saltcake Solid	T2-SltCk (Solid)	454	1.64	28.3
241-TX-103	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	3	1.26	69.6
241-TX-104	Sludge (Liquid & Solid)	R1 (Solid)	130	1.89	44.6
241-TX-104	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	30	1.44	51.9
241-TX-104	Supernatant	T2-SltCk (Liquid)	9	1.44	51.9
241-TX-104	Saltcake Solid	T2-SltCk (Solid)	93	1.62	45.2
241-TX-105	Saltcake Solid	T2-SltCk (Solid)	2044	1.64	28.3
241-TX-105	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	106	1.45	49.1
241-TX-105	Sludge (Liquid & Solid)	MW2 (Solid)	31	1.85	41.4
241-TX-106	Saltcake Solid	T2-SltCk (Solid)	1147	1.64	28.3
241-TX-106	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	152	1.45	49.1
241-TX-106	Sludge (Liquid & Solid)	MW2 (Solid)	4	1.85	41.4
241-TX-106	Sludge (Liquid & Solid)	R1 (Solid)	15	1.77	22.7
241-TX-107	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	19	1.45	49.1
241-TX-107	Saltcake Interstitial Liquid	R-SltCk (Liquid)	7	1.5	51.9
241-TX-107	Saltcake Solid	T2-SltCk (Solid)	62	1.94	22.2
241-TX-107	Saltcake Solid	R-SltCk (Solid)	24	1.72	23.4
241-TX-108	Sludge (Liquid & Solid)	MW2 (Solid)	8	1.85	41.4
241-TX-108	Saltcake Solid	T2-SltCk (Solid)	415	1.64	28.3
241-TX-108	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	40	1.45	49.1
241-TX-108	Sludge (Liquid & Solid)	TBP (Solid)	15	1.47	50.5
241-TX-109	Sludge (Liquid & Solid)	1C (Solid)	1375	1.43	54.1
241-TX-110	Sludge (Liquid & Solid)	1C (Solid)	140	1.43	54.1
241-TX-110	Saltcake Solid	T2-SltCk (Solid)	1580	1.64	28.3
241-TX-110	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	49	1.45	49.1
241-TX-111	Sludge (Liquid & Solid)	1C (Solid)	163	1.43	54.1
241-TX-111	Saltcake Solid	T2-SltCk (Solid)	1194	1.64	28.3
241-TX-111	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	24	1.45	49.1
241-TX-112	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	15	1.26	69.6
241-TX-112	Saltcake Solid	T2-SltCk (Solid)	2215	1.64	28.3
241-TX-112	Saltcake Solid	T1-SltCk (Solid)	75	1.72	23.5
241-TX-112	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	93	1.45	49.1
241-TX-113	Saltcake Solid	T2-SltCk (Solid)	2045	1.64	9.43
241-TX-113	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	20	1.45	49.1
241-TX-113	Sludge (Liquid & Solid)	1C (Solid)	351	1.43	54.1
241-TX-114	Saltcake Solid	T2-SltCk (Solid)	1750	1.64	28.3
241-TX-114	Sludge (Liquid & Solid)	1C (Solid)	15	1.43	54.1
241-TX-114	Saltcake Solid	T1-SltCk (Solid)	173	1.72	23.5
241-TX-114	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	46	1.26	69.6
241-TX-114	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	28	1.45	49.1

Table A-1. Best Basis Inventory - Density and Weight Percent Water By Tank, Waste Phase, and Waste Type Queried on September 17, 2007. (12 sheets)

Tank Name	Waste Phase	Waste Type	Volume (kL)	Density (g/mL)	Wt% Water
241-TX-115	Sludge (Liquid & Solid)	TBP (Solid)	30	1.47	50.5
241-TX-115	Saltcake Solid	T2-SltCk (Solid)	1960	1.64	28.3
241-TX-115	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	103	1.45	49.1
241-TX-116	Saltcake Solid	T2-SltCk (Solid)	926	1.64	28.5
241-TX-116	Saltcake Solid	T1-SltCk (Solid)	977	1.72	7.5
241-TX-116	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	113	1.39	53
241-TX-116	Sludge (Liquid & Solid)	DE (Solid)	248	1.6	38.8
241-TX-117	Saltcake Solid	T1-SltCk (Solid)	626	1.72	23.5
241-TX-117	Saltcake Solid	T2-SltCk (Solid)	1033	1.64	28.3
241-TX-117	Sludge Solid	DE (Solid)	110	0.384	0
241-TX-117	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	48	1.26	69.6
241-TX-118	Saltcake Solid	T2-SltCk (Solid)	671	1.77	43.6
241-TX-118	Saltcake Solid	NA (SltCk)	125	1.54	46.8
241-TX-118	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	139	1.45	49.1
241-TY-101	Sludge (Liquid & Solid)	1CFeCN (Solid)	273	1.64	43.5
241-TY-101	Saltcake Solid	T1-SltCk (Solid)	159	1.64	43.5
241-TY-101	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	15	1.26	69.6
241-TY-102	Saltcake Solid	T1-SltCk (Solid)	90	1.88	23.5
241-TY-102	Saltcake Solid	T2-SltCk (Solid)	109	1.88	28.3
241-TY-102	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	29	1.26	69.6
241-TY-102	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	34	1.45	49.1
241-TY-103	Sludge (Liquid & Solid)	TBP (Solid)	220	1.7	51.9
241-TY-103	Saltcake Solid	T2-SltCk (Solid)	150	1.7	51.9
241-TY-103	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	45	1.45	49.1
241-TY-103	Sludge (Liquid & Solid)	1CFeCN (Solid)	170	1.7	51.9
241-TY-104	Sludge (Liquid & Solid)	1CFeCN (Solid)	114	1.65	51.9
241-TY-104	Sludge (Liquid & Solid)	TBP (Solid)	49	1.65	51.9
241-TY-104	Supernatant	DW (Liquid)	5	1.18	77.5
241-TY-105	Sludge (Liquid & Solid)	TBP (Solid)	874	1.53	39.4
241-TY-106	Sludge (Liquid & Solid)	DE (Solid)	47	1.4	38.1
241-TY-106	Sludge (Liquid & Solid)	TBP (Solid)	15	1.4	38.1
241-U-101	Sludge (Liquid & Solid)	R1 (Solid)	87	1.77	29.8
241-U-102	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	117	1.48	47.5
241-U-102	Saltcake Solid	T2-SltCk (Solid)	647	1.68	34.7
241-U-102	Saltcake Solid	S2-SltSlr (Solid)	307	1.68	34.7
241-U-102	Sludge (Liquid & Solid)	R1 (Solid)	163	1.77	22.7
241-U-102	Supernatant	T2-SltCk (Liquid)	4	1.48	47.5
241-U-103	Retained Gas (Saltcake)	NA	163	NA	NA
241-U-103	Saltcake Solid	S2-SltSlr (Solid)	356	1.72	38.4
241-U-103	Saltcake Solid	S1-SltCk (Solid)	891	1.72	38.4
241-U-103	Sludge (Liquid & Solid)	R1 (Solid)	42	1.9	47.4
241-U-103	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	119	1.44	49.9
241-U-103	Supernatant	S1-SltCk (Liquid)	2	1.44	49.9
241-U-103	Retained Gas (Sludge)	NA	5	NA	NA
241-U-104	Sludge (Liquid & Solid)	MW2 (Solid)	4	1.85	41.4
241-U-104	Sludge (Liquid & Solid)	DE (Solid)	201	1.11	72.4

Table A-1. Best Basis Inventory - Density and Weight Percent Water By Tank, Waste Phase, and Waste Type Queried on September 17, 2007. (12 sheets)

Tank Name	Waste Phase	Waste Type	Volume (kL)	Density (g/mL)	Wt% Water
241-U-105	Saltcake Solid	S2-SltSlr (Solid)	827	1.7	28.4
241-U-105	Saltcake Solid	T2-SltCk (Solid)	223	1.7	28.4
241-U-105	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	35	1.46	51.6
241-U-105	Sludge (Liquid & Solid)	CWR1 (Solid)	121	1.7	22.4
241-U-105	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	130	1.46	51.6
241-U-106	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	154	1.34	48.6
241-U-106	Saltcake Solid	S1-SltCk (Solid)	484	1.62	39.8
241-U-106	Supernatant	S1-SltCk (Liquid)	6	1.34	48.6
241-U-107	Sludge (Liquid & Solid)	CWR1 (Solid)	57	1.8	24.5
241-U-107	Saltcake Solid	S2-SltSlr (Solid)	902	1.77	31.5
241-U-107	Saltcake Solid	T2-SltCk (Solid)	44	1.77	31.5
241-U-107	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	105	1.43	49.6
241-U-107	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	5	1.43	49.6
241-U-108	Saltcake Solid	S1-SltCk (Solid)	766	1.73	34.7
241-U-108	Saltcake Solid	S2-SltSlr (Solid)	610	1.73	34.7
241-U-108	Sludge (Liquid & Solid)	CWR2 (Solid)	110	1.46	51.7
241-U-108	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	69	1.4	49.9
241-U-108	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	86	1.4	49.9
241-U-109	Saltcake Solid	S1-SltCk (Solid)	600	1.67	27
241-U-109	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	137	1.47	50.7
241-U-109	Sludge (Liquid & Solid)	CWR1 (Solid)	103	1.71	22.7
241-U-109	Retained Gas (Saltcake)	NA	137	NA	NA
241-U-109	Saltcake Solid	S2-SltSlr (Solid)	512	1.67	27
241-U-109	Retained Gas (Sludge)	NA	29	NA	NA
241-U-110	Sludge (Liquid & Solid)	CWR1 (Solid)	149	1.8	3.08
241-U-110	Sludge (Liquid & Solid)	R1 (Solid)	396	1.77	38.8
241-U-110	Sludge (Liquid & Solid)	1C (Solid)	120	1.43	39.7
241-U-111	Saltcake Solid	S1-SltCk (Solid)	228	1.68	30.2
241-U-111	Saltcake Solid	S2-SltSlr (Solid)	401	1.63	34.9
241-U-111	Sludge (Liquid & Solid)	R1 (Solid)	49	1.77	22.7
241-U-111	Sludge (Liquid & Solid)	1C (Solid)	49	1.43	54.1
241-U-111	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	41	1.4	52.6
241-U-111	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	72	1.4	52.6
241-U-112	Sludge (Liquid & Solid)	CWR1 (Solid)	58	1.86	26
241-U-112	Sludge (Liquid & Solid)	1C (Solid)	47	1.43	54.1
241-U-112	Sludge (Liquid & Solid)	R1 (Solid)	67	1.86	26
241-U-201	Sludge (Liquid & Solid)	CWR1 (Solid)	11	1.63	27.1
241-U-201	Supernatant	CWR1 (Liquid)	4	1.26	69.3
241-U-202	Sludge (Liquid & Solid)	CWR1 (Solid)	10	1.51	27.8
241-U-202	Supernatant	CWR1 (Liquid)	4	1.28	69.1
241-U-203	Sludge (Liquid & Solid)	CWR1 (Solid)	9	1.59	40.2
241-U-203	Supernatant	CWR1 (Liquid)	4	1.28	68.7
241-U-204	Sludge (Liquid & Solid)	CWR1 (Solid)	7	1.47	26.2
241-U-204	Supernatant	CWR1 (Liquid)	4	1.11	87

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-A-101	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	148	5.54E+02	3.45E+04	2.44E+04	4.11E+04	7.66E+03	1.03E+01	2.26E+00	2.26E-02	9.71E-02	3.98E-03	5.16E+04	6.32E+03
241-A-101	Saltcake Solid	A1-SltCk (Solid)	878	1.21E+04	2.09E+05	1.08E+05	3.44E+05	3.52E+04	6.18E+04	1.17E+02	7.67E+00	3.31E+01	1.36E+00	2.50E+05	NA
241-A-101	Sludge (Liquid & Solid)	P2 (Solid)	11	0.00E+00	7.88E+02	3.08E+01	9.14E+02	2.15E+03	5.91E+04	2.60E+02	1.15E+01	4.68E+01	2.20E+00	1.14E+03	NA
241-A-101	Total			1.26E+04	2.44E+05	1.33E+05	3.86E+05	4.50E+04	1.21E+05	3.78E+02	1.92E+01	7.99E+01	3.56E+00	3.03E+05	6.32E+03
241-A-102	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	33	1.46E+02	6.24E+03	5.69E+03	6.60E+03	1.35E+03	3.66E+01	3.54E-02	2.82E-02	1.21E-01	4.97E-03	1.64E+04	5.71E+02
241-A-102	Saltcake Solid	A1-SltCk (Solid)	106	2.56E+03	1.63E+04	1.50E+04	2.32E+04	5.71E+03	7.75E+04	2.48E+02	7.24E+01	3.12E+02	1.28E+01	1.83E+04	NA
241-A-102	Supernatant	A1-SltCk (Liquid)	12	5.30E+01	2.27E+03	2.07E+03	2.40E+03	4.92E+02	1.33E+01	1.29E-02	1.02E-02	4.41E-02	1.81E-03	5.95E+03	2.08E+02
241-A-102	Total			2.76E+03	2.48E+04	2.27E+04	3.22E+04	7.56E+03	7.76E+04	2.48E+02	7.25E+01	3.12E+02	1.28E+01	4.06E+04	7.79E+02
241-A-103	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	338	2.81E+03	8.18E+04	4.19E+04	7.95E+04	1.20E+04	6.54E+02	1.06E+00	1.71E+00	7.36E+00	3.02E-01	9.12E+04	1.65E+04
241-A-103	Saltcake Solid	A1-SltCk (Solid)	1071	1.18E+04	1.40E+05	1.17E+05	3.07E+05	2.12E+04	5.51E+04	2.09E+02	4.09E+01	1.76E+02	7.25E+00	1.80E+05	NA
241-A-103	Sludge (Liquid & Solid)	AR (Solid)	8	0.00E+00	5.11E-07	2.35E+02	1.11E+03	1.53E+01	6.78E+04	2.47E+01	7.91E+00	3.64E+01	1.19E+00	5.32E+03	NA
241-A-103	Supernatant	A1-SltCk (Liquid)	17	1.41E+02	4.11E+03	2.11E+03	4.00E+03	6.04E+02	3.29E+01	5.31E-02	8.59E-02	3.70E-01	1.52E-02	4.59E+03	8.32E+02
241-A-103	Total			1.48E+04	2.26E+05	1.62E+05	3.92E+05	3.39E+04	1.24E+05	2.35E+02	5.06E+01	2.20E+02	8.75E+00	2.81E+05	1.74E+04
241-A-104	Sludge Solid	AR (Solid)	102	0.00E+00	1.46E-05	6.73E+03	3.19E+04	7.76E+03	2.21E+06	7.07E+02	1.43E+02	6.56E+02	2.14E+01	5.96E+04	NA
241-A-104	Sludge Solid	P1 (Solid)	4	0.00E+00	3.02E+02	1.18E+01	3.50E+02	3.04E+02	8.66E+04	9.95E+01	6.17E+00	2.51E+01	1.18E+00	2.34E+03	NA
241-A-104	Total			0.00E+00	3.02E+02	6.74E+03	3.23E+04	8.06E+03	2.29E+06	8.07E+02	1.49E+02	6.81E+02	2.26E+01	6.19E+04	NA
241-A-105	Sludge Solid	P2 (Solid)	139	0.00E+00	1.71E+04	6.67E+02	5.50E+04	8.28E+03	2.88E+06	5.62E+03	1.36E+02	5.56E+02	2.61E+01	1.07E+05	NA
241-A-105	Total			0.00E+00	1.71E+04	6.67E+02	5.50E+04	8.28E+03	2.88E+06	5.62E+03	1.36E+02	5.56E+02	2.61E+01	1.07E+05	NA
241-A-106	Saltcake Solid	A1-SltCk (Solid)	110	1.59E+03	1.85E+04	1.68E+04	2.89E+04	5.40E+03	1.80E+05	2.17E+02	8.79E+01	3.79E+02	1.56E+01	2.36E+04	NA
241-A-106	Sludge (Liquid & Solid)	AR (Solid)	79	1.14E+03	1.33E+04	1.21E+04	2.08E+04	3.87E+03	1.29E+05	1.49E+02	5.99E+01	2.75E+02	8.99E+00	1.70E+04	NA
241-A-106	Sludge (Liquid & Solid)	SRR (Solid)	110	1.59E+03	1.85E+04	1.68E+04	2.89E+04	5.40E+03	1.80E+05	2.15E+02	8.79E+01	3.79E+02	1.57E+01	2.36E+04	NA
241-A-106	Total			4.31E+03	5.03E+04	4.57E+04	7.86E+04	1.47E+04	4.90E+05	5.81E+02	2.36E+02	1.03E+03	4.03E+01	6.43E+04	NA
241-AN-101	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	28	1.13E+02	5.32E+03	3.42E+03	6.61E+03	1.06E+03	2.79E+01	7.89E-02	7.87E-04	3.39E-03	1.39E-04	9.96E+03	1.35E+03
241-AN-101	Saltcake Solid	A1-SltCk (Solid)	90	8.52E+02	1.82E+04	1.18E+04	2.96E+04	3.20E+03	4.46E+03	6.41E+00	4.22E-01	1.82E+00	7.48E-02	2.36E+04	NA
241-AN-101	Supernatant	NA (Liquid)	4208	2.26E+04	6.81E+05	4.65E+05	8.82E+05	8.02E+04	7.87E+03	9.59E+00	1.40E-01	8.38E-01	2.61E-02	1.14E+06	1.38E+05
241-AN-101	Total			2.36E+04	7.05E+05	4.80E+05	9.18E+05	8.45E+04	1.24E+04	1.61E+01	5.63E-01	2.66E+00	1.01E-01	1.18E+06	1.39E+05
241-AN-102	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	584	2.07E+04	1.98E+05	8.35E+04	1.47E+05	1.08E+04	1.22E+05	5.35E+02	9.40E+00	3.61E+01	2.62E+00	2.36E+05	3.48E+04
241-AN-102	Supernatant	NA (Liquid)	3446	8.32E+04	6.78E+05	3.00E+05	7.30E+05	4.55E+04	2.75E+05	5.62E+02	4.28E+00	1.65E+01	1.20E+00	1.36E+06	2.82E+04
241-AN-102	Total			1.04E+05	8.77E+05	3.84E+05	8.77E+05	5.63E+04	3.97E+05	1.10E+03	1.37E+01	5.26E+01	3.82E+00	1.59E+06	6.30E+04
241-AN-103	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	1638	5.10E+03	4.36E+05	1.97E+05	5.88E+05	1.73E+05	6.26E+03	9.89E+00	1.01E+00	3.89E+00	2.82E-01	5.79E+05	9.39E+04
241-AN-103	Supernatant	A2-SltSlr (Liquid)	1769	5.39E+03	2.27E+05	2.30E+05	4.78E+05	5.30E+04	3.13E+01	1.08E+01	1.17E-01	4.51E-01	3.28E-02	1.12E+06	1.19E+05
241-AN-103	Total			1.05E+04	6.63E+05	4.27E+05	1.07E+06	2.26E+05	6.29E+03	2.07E+01	1.13E+00	4.34E+00	3.15E-01	1.70E+06	2.13E+05

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-AN-104	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	1566	1.20E+04	2.96E+05	1.58E+05	4.81E+05	5.13E+04	7.16E+04	4.71E+01	1.85E+00	7.12E+00	5.16E-01	7.48E+05	9.15E+04
241-AN-104	Supernatant	A2-SltSlr (Liquid)	2298	7.22E+03	4.35E+05	2.74E+05	5.94E+05	8.96E+04	1.88E+02	8.06E-01	4.32E-02	1.66E-01	1.20E-02	1.13E+06	1.50E+05
241-AN-104	Total			1.93E+04	7.32E+05	4.32E+05	1.07E+06	1.41E+05	7.18E+04	4.79E+01	1.90E+00	7.28E+00	5.29E-01	1.88E+06	2.41E+05
241-AN-105	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	1925	1.62E+04	3.43E+05	1.94E+05	5.52E+05	6.76E+04	2.87E+04	2.09E+01	1.41E+00	5.41E+00	3.92E-01	7.56E+05	7.22E+04
241-AN-105	Supernatant	A2-SltSlr (Liquid)	2227	6.15E+03	3.48E+05	2.64E+05	5.50E+05	9.28E+04	7.73E+01	3.20E+01	3.48E-01	1.34E+00	9.72E-02	6.52E+05	1.33E+05
241-AN-105	Total			2.23E+04	6.91E+05	4.59E+05	1.10E+06	1.60E+05	2.88E+04	5.29E+01	1.76E+00	6.75E+00	4.89E-01	1.41E+06	2.05E+05
241-AN-106	Saltcake (Liquid & Solid)	NA (SltCk)	65	6.15E+02	1.31E+04	8.53E+03	2.14E+04	2.31E+03	3.22E+03	4.63E+00	3.05E-01	1.31E+00	5.41E-02	1.71E+04	NA
241-AN-106	Sludge (Liquid & Solid)	NA (Sludge)	553	1.52E+04	1.37E+04	1.13E+04	6.72E+04	5.30E+04	1.97E+06	2.37E+03	2.71E+02	1.26E+03	4.08E+01	1.05E+05	NA
241-AN-106	Sludge Interstitial Liquid	NA (Liquid)	99	8.81E+01	1.84E+02	2.76E+03	5.21E+03	1.21E+02	9.95E+01	1.85E-02	3.22E-02	1.53E-01	2.24E-02	2.02E+03	6.61E+02
241-AN-106	Supernatant	NA (Liquid)	1958	1.74E+03	3.65E+03	5.47E+04	1.03E+05	2.40E+03	1.97E+03	3.65E-01	6.37E-01	3.02E+00	4.43E-01	3.99E+04	1.31E+04
241-AN-106	Total			1.77E+04	3.07E+04	7.72E+04	1.97E+05	5.78E+04	1.98E+06	2.37E+03	2.72E+02	1.27E+03	4.13E+01	1.64E+05	1.37E+04
241-AN-107	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	872	4.03E+04	1.47E+05	5.38E+04	1.88E+05	2.23E+04	2.14E+05	1.20E+03	1.84E+01	7.08E+01	5.14E+00	3.01E+05	2.48E+02
241-AN-107	Supernatant	A2-SltSlr (Liquid)	3297	1.07E+05	6.89E+05	2.20E+05	6.85E+05	3.70E+03	2.53E+05	2.41E+03	3.87E+01	1.49E+02	1.08E+01	9.85E+05	5.93E+04
241-AN-107	Total			1.47E+05	8.37E+05	2.74E+05	8.72E+05	2.60E+04	4.67E+05	3.62E+03	5.71E+01	2.20E+02	1.59E+01	1.29E+06	5.96E+04
241-AP-101	Supernatant	A2-SltSlr (Liquid)	4374	4.57E+03	5.96E+05	9.26E+04	4.64E+05	2.14E+04	4.17E+03	5.66E+00	6.12E-01	3.12E+00	9.87E-02	2.92E+05	9.61E+04
241-AP-101	Total			4.57E+03	5.96E+05	9.26E+04	4.64E+05	2.14E+04	4.17E+03	5.66E+00	6.12E-01	3.12E+00	9.87E-02	2.92E+05	9.61E+04
241-AP-102	Sludge (Liquid & Solid)	NA (Sludge)	88	2.16E+02	7.58E+03	4.67E+03	9.18E+03	1.57E+04	5.66E+01	1.07E-01	1.22E-02	7.21E-02	1.85E-03	1.25E+04	1.20E+03
241-AP-102	Supernatant	Waste Transfer	4049	1.22E+04	6.78E+05	3.98E+05	7.89E+05	1.25E+05	1.56E+03	7.00E+00	2.11E-01	1.25E+00	3.24E-02	9.67E+05	1.30E+05
241-AP-102	Total			1.24E+04	6.86E+05	4.03E+05	7.98E+05	1.41E+05	1.62E+03	7.11E+00	2.23E-01	1.32E+00	3.43E-02	9.80E+05	1.31E+05
241-AP-103	Sludge (Liquid & Solid)	NA (Sludge)	70	2.23E+02	5.92E+03	5.01E+03	9.60E+03	1.95E+04	2.87E+01	2.93E-02	1.90E-02	1.13E-01	3.72E-03	1.31E+04	4.79E+02
241-AP-103	Supernatant	NA (Liquid)	2806	1.85E+04	4.51E+05	2.31E+05	5.24E+05	5.58E+04	6.29E+03	2.48E+01	3.51E-01	2.09E+00	7.38E-02	6.43E+05	5.89E+04
241-AP-103	Total			1.87E+04	4.57E+05	2.36E+05	5.34E+05	7.54E+04	6.32E+03	2.49E+01	3.70E-01	2.21E+00	7.75E-02	6.56E+05	5.93E+04
241-AP-104	Supernatant	NA (Liquid)	4155	1.73E+04	4.19E+05	2.66E+05	5.34E+05	6.98E+04	6.94E+03	1.17E+01	1.25E-01	7.33E-01	1.65E-01	7.71E+05	8.18E+04
241-AP-104	Total			1.73E+04	4.19E+05	2.66E+05	5.34E+05	6.98E+04	6.94E+03	1.17E+01	1.25E-01	7.33E-01	1.65E-01	7.71E+05	8.18E+04
241-AP-105	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	337	2.94E+03	6.31E+04	1.62E+04	1.04E+05	4.73E+03	9.69E+03	2.83E+00	4.83E-01	1.86E+00	1.35E-01	1.22E+05	1.84E+04
241-AP-105	Supernatant	Waste Transfer	3965	5.94E+03	4.21E+05	1.88E+05	5.31E+05	7.63E+04	1.08E+03	2.75E+00	1.84E-01	1.12E+00	6.38E-02	5.39E+05	1.03E+05
241-AP-105	Total			8.88E+03	4.84E+05	2.04E+05	6.35E+05	8.11E+04	1.08E+04	5.57E+00	6.67E-01	2.98E+00	1.98E-01	6.61E+05	1.22E+05
241-AP-106	Supernatant	NA (Liquid)	4301	1.49E+04	3.04E+05	1.78E+05	4.45E+05	5.81E+04	5.12E+03	2.61E+00	5.47E-02	3.18E-01	8.93E-03	7.54E+05	3.17E+04
241-AP-106	Total			1.49E+04	3.04E+05	1.78E+05	4.45E+05	5.81E+04	5.12E+03	2.61E+00	5.47E-02	3.18E-01	8.93E-03	7.54E+05	3.17E+04
241-AP-107	Supernatant	NA (Liquid)	4274	6.86E+03	6.52E+05	1.38E+05	5.36E+05	3.89E+04	2.45E+03	1.26E+00	8.97E-02	4.41E-01	2.00E-02	3.76E+05	8.03E+04
241-AP-107	Total			6.86E+03	6.52E+05	1.38E+05	5.36E+05	3.89E+04	2.45E+03	1.26E+00	8.97E-02	4.41E-01	2.00E-02	3.76E+05	8.03E+04
241-AP-108	Saltcake (Liquid & Solid)	NA (SltCk)	383	1.26E+03	6.23E+04	2.74E+04	1.13E+05	8.86E+03	2.77E+02	1.30E-01	2.57E-02	1.27E-01	9.51E-03	7.75E+04	5.18E+03

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-AP-108	Supernatant	NA (Liquid)	4337	1.52E+04	7.58E+05	3.46E+05	8.99E+05	1.00E+05	4.43E+03	8.22E+00	3.31E-01	1.74E+00	1.08E-01	8.99E+05	1.59E+05
241-AP-108	Total			1.65E+04	8.20E+05	3.73E+05	1.01E+06	1.09E+05	4.70E+03	8.35E+00	3.57E-01	1.87E+00	1.17E-01	9.77E+05	1.64E+05
241-AW-101	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	1403	1.32E+04	3.46E+05	1.30E+05	3.77E+05	3.34E+04	8.20E+04	1.04E+02	2.58E+01	9.93E+01	7.20E+00	4.75E+05	1.17E+05
241-AW-101	Supernatant	A2-SltSlr (Liquid)	2770	7.24E+03	4.74E+05	2.92E+05	6.45E+05	8.17E+04	1.04E+03	7.21E-01	2.96E-01	1.14E+00	8.25E-02	1.05E+06	2.76E+05
241-AW-101	Total			2.04E+04	8.19E+05	4.22E+05	1.02E+06	1.15E+05	8.30E+04	1.05E+02	2.61E+01	1.00E+02	7.29E+00	1.52E+06	3.93E+05
241-AW-102	Sludge (Liquid & Solid)	NA (Sludge)	116	1.06E+03	1.02E+03	1.40E+03	7.75E+03	3.50E+04	1.01E+05	3.40E+02	1.72E+01	8.25E+01	1.42E+00	1.32E+04	NA
241-AW-102	Supernatant	NA (Liquid)	3973	7.62E+03	6.37E+04	6.02E+04	1.51E+05	7.80E+03	3.62E+02	5.07E-02	9.37E-01	5.58E+00	1.06E+00	1.24E+05	1.18E+04
241-AW-102	Total			8.68E+03	6.47E+04	6.16E+04	1.58E+05	4.28E+04	1.01E+05	3.40E+02	1.81E+01	8.81E+01	2.48E+00	1.37E+05	1.18E+04
241-AW-103	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	36	2.20E+02	8.88E+03	3.35E+03	7.23E+03	2.91E+02	3.41E+01	9.65E-02	9.62E-04	4.14E-03	1.70E-04	1.22E+04	9.79E+02
241-AW-103	Saltcake Solid	A1-SltCk (Solid)	115	1.76E+03	2.95E+04	1.41E+04	3.04E+04	7.05E+03	1.20E+03	1.01E+01	6.62E-01	2.85E+00	1.17E-01	3.69E+03	1.24E+03
241-AW-103	Sludge (Liquid & Solid)	CWZr2 (Solid)	1105	2.02E+03	4.51E+04	2.14E+04	1.88E+05	3.84E+03	1.15E+04	1.57E+02	1.14E+02	4.06E+02	4.03E+01	3.55E+04	1.19E+04
241-AW-103	Supernatant	NA (Liquid)	2893	5.42E+03	2.79E+05	9.69E+04	2.92E+05	2.34E+04	6.38E+02	1.48E-01	7.34E-02	3.45E-01	3.12E-02	3.25E+05	3.77E+04
241-AW-103	Total			9.41E+03	3.62E+05	1.36E+05	5.17E+05	3.46E+04	1.34E+04	1.67E+02	1.15E+02	4.09E+02	4.04E+01	3.76E+05	5.18E+04
241-AW-104	Saltcake Interstitial Liquid	A2-SltSlr (Liquid)	136	5.14E+02	1.89E+04	1.32E+04	3.50E+04	5.67E+03	1.28E+02	1.38E+00	1.51E-02	5.80E-02	4.21E-03	4.56E+04	6.67E+03
241-AW-104	Saltcake Solid	A2-SltSlr (Solid)	457	4.51E+03	5.97E+04	4.17E+04	1.65E+05	1.46E+04	5.56E+02	4.29E+01	7.32E+00	2.81E+01	2.04E+00	1.52E+05	NA
241-AW-104	Sludge Interstitial Liquid	PL2 (Liquid)	62	1.63E+02	4.38E+03	2.72E+03	1.17E+04	8.37E+02	4.02E+01	2.57E-01	2.80E-03	1.08E-02	7.81E-04	1.44E+04	1.27E+03
241-AW-104	Sludge Solid	PL2 (Solid)	188	2.84E+03	1.02E+04	5.82E+03	2.31E+04	2.57E+03	1.20E+01	1.83E+01	1.38E+02	4.90E+02	4.95E+01	1.37E+01	NA
241-AW-104	Supernatant	NA (Liquid)	3205	1.39E+04	3.62E+05	2.40E+05	5.47E+05	8.19E+04	5.24E+03	5.05E+00	8.17E-02	4.58E-01	1.46E-02	7.69E+05	8.15E+04
241-AW-104	Total			2.19E+04	4.56E+05	3.03E+05	7.82E+05	1.06E+05	5.98E+03	6.78E+01	1.46E+02	5.18E+02	5.16E+01	9.81E+05	8.95E+04
241-AW-105	Sludge (Liquid & Solid)	CWZr2 (Solid)	841	3.40E+03	2.74E+04	7.77E+03	1.20E+05	1.98E+03	2.36E+04	4.32E+02	1.73E+02	6.16E+02	6.12E+01	2.82E+04	6.35E+03
241-AW-105	Sludge (Liquid & Solid)	PL2 (Solid)	99	3.60E+03	4.68E+03	1.79E+03	1.48E+04	1.62E+03	3.68E+04	2.38E+02	3.13E+01	1.11E+02	1.12E+01	8.28E+03	6.81E+02
241-AW-105	Supernatant	NA (Liquid)	638	3.69E+02	1.75E+04	1.89E+03	1.60E+04	1.12E+02	1.43E+01	4.12E-02	4.17E-02	1.48E-01	1.47E-02	6.45E+03	2.87E+03
241-AW-105	Total			7.37E+03	4.97E+04	1.14E+04	1.51E+05	3.72E+03	6.04E+04	6.70E+02	2.05E+02	7.27E+02	7.24E+01	4.29E+04	9.89E+03
241-AW-106	Saltcake (Liquid & Solid)	A2-SltSlr (Solid)	1062	2.86E+04	9.26E+04	6.07E+04	5.34E+05	1.15E+04	4.50E+04	4.91E+01	4.70E+01	1.80E+02	1.31E+01	5.66E+05	1.87E+04
241-AW-106	Supernatant	NA (Liquid)	3225	7.50E+03	4.10E+05	1.05E+05	3.84E+05	3.15E+04	1.62E+03	2.15E+00	5.33E-01	3.42E+00	5.73E-02	4.05E+05	3.77E+04
241-AW-106	Total			3.61E+04	5.02E+05	1.66E+05	9.19E+05	4.29E+04	4.67E+04	5.12E+01	4.75E+01	1.84E+02	1.31E+01	9.71E+05	5.64E+04
241-AX-101	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	178	7.08E+02	4.84E+04	3.08E+04	5.02E+04	8.95E+03	4.06E+01	7.02E-02	5.90E-03	2.54E-02	1.04E-03	6.09E+04	6.94E+03
241-AX-101	Saltcake Solid	A1-SltCk (Solid)	1164	1.06E+04	2.87E+05	1.34E+05	4.38E+05	4.23E+04	7.59E+04	1.15E+02	7.54E+00	3.25E+01	1.34E+00	3.44E+05	NA
241-AX-101	Sludge (Liquid & Solid)	SRR (Solid)	11	3.79E-02	1.23E-08	2.57E+02	2.03E+03	0.00E+00	1.45E+05	2.78E+02	1.93E+01	8.30E+01	3.44E+00	1.51E+03	NA
241-AX-101	Total			1.13E+04	3.35E+05	1.65E+05	4.90E+05	5.12E+04	2.21E+05	3.93E+02	2.68E+01	1.16E+02	4.78E+00	4.07E+05	6.94E+03
241-AX-102	Saltcake (Liquid & Solid)	A1-SltCk (Solid)	90	6.04E+03	2.58E+04	4.91E+03	1.73E+04	1.56E+03	2.87E+04	2.76E+02	8.90E+00	3.84E+01	1.58E+00	1.64E+04	NA
241-AX-102	Sludge (Liquid & Solid)	B (Solid)	23	8.71E+00	5.08E-08	1.57E+02	6.96E+03	8.10E+02	2.02E+05	1.87E+03	3.98E+01	1.14E+02	1.25E+01	8.12E+03	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-AX-102	Total			6.05E+03	2.58E+04	5.07E+03	2.43E+04	2.37E+03	2.30E+05	2.14E+03	4.87E+01	1.52E+02	1.41E+01	2.45E+04	NA
241-AX-103	Saltcake Interstitial Liquid	A1-SltCk (Liquid)	75	3.02E+02	1.43E+04	9.15E+03	1.77E+04	2.84E+03	7.47E+01	2.11E-01	2.11E-03	9.07E-03	3.72E-04	2.67E+04	NA
241-AX-103	Saltcake Solid	A1-SltCk (Solid)	298	2.23E+03	5.18E+04	4.47E+04	8.72E+04	1.07E+04	1.37E+04	2.00E+01	1.52E+00	3.60E+00	1.48E-01	7.28E+04	NA
241-AX-103	Sludge (Liquid & Solid)	P2 (Solid)	30	0.00E+00	2.25E+03	8.40E+01	1.74E+03	1.53E+03	4.31E+05	7.07E+02	2.18E+01	8.90E+01	4.18E+00	1.60E+04	NA
241-AX-103	Total			2.54E+03	6.83E+04	5.39E+04	1.07E+05	1.51E+04	4.45E+05	7.28E+02	2.34E+01	9.26E+01	4.33E+00	1.16E+05	NA
241-AX-104	Sludge Solid	P2 (Solid)	28	1.46E+01	2.30E+03	1.13E+02	2.17E+03	2.67E+03	2.05E+06	9.48E+02	6.61E+01	2.69E+02	1.27E+01	4.97E+04	NA
241-AX-104	Total			1.46E+01	2.30E+03	1.13E+02	2.17E+03	2.67E+03	2.05E+06	9.48E+02	6.61E+01	2.69E+02	1.27E+01	4.97E+04	NA
241-AY-101	Sludge Interstitial Liquid	NA (Liquid)	60	1.77E+02	4.05E+02	3.92E+03	4.68E+03	3.18E+01	4.62E+01	3.08E+00	5.22E+00	2.23E+01	9.54E-01	5.26E+03	3.00E+01
241-AY-101	Sludge Solid	NA (Sludge)	339	7.97E+03	1.87E+03	1.36E+04	6.79E+04	3.83E+04	2.13E+06	1.44E+04	2.28E+02	7.37E+02	6.40E+01	6.60E+04	NA
241-AY-101	Supernatant	NA (Liquid)	2750	1.70E+03	1.87E+05	2.70E+04	1.73E+05	7.27E+03	2.48E+03	1.13E+01	2.33E+00	1.04E+01	4.04E-01	6.47E+04	3.43E+04
241-AY-101	Total			9.84E+03	1.89E+05	4.45E+04	2.46E+05	4.56E+04	2.13E+06	1.44E+04	2.36E+02	7.70E+02	6.53E+01	1.36E+05	3.43E+04
241-AY-102	Sludge Interstitial Liquid	BL (Liquid)	120	1.83E+02	4.65E+01	8.70E+02	8.44E+03	4.09E+01	2.05E+02	3.81E-02	7.20E-02	2.82E-01	1.54E-02	3.70E+03	6.62E+01
241-AY-102	Sludge Solid	BL (Solid)	75	6.86E+02	2.82E+01	4.25E+02	8.75E+03	8.58E+03	7.71E+05	8.28E+02	6.64E+01	2.60E+02	1.43E+01	4.09E+04	NA
241-AY-102	Sludge Solid	NA (Sludge)	376	3.44E+03	1.41E+02	2.13E+03	4.39E+04	4.30E+04	3.86E+06	4.14E+03	3.02E+02	1.34E+03	4.70E+01	2.05E+05	NA
241-AY-102	Supernatant	NA (Liquid)	3212	5.86E+03	3.51E+05	1.29E+05	3.98E+05	2.20E+04	5.73E+02	6.26E-01	1.66E-01	7.04E-01	8.57E-02	4.18E+05	1.20E+05
241-AY-102	Total			1.02E+04	3.51E+05	1.32E+05	4.59E+05	7.36E+04	4.63E+06	4.97E+03	3.69E+02	1.60E+03	6.14E+01	6.68E+05	1.20E+05
241-AZ-101	Sludge (Liquid & Solid)	NA (Sludge)	30	3.95E+01	1.19E+03	1.42E+03	3.48E+03	5.99E+03	8.40E+05	3.89E+03	4.72E+01	1.81E+02	1.32E+01	3.70E+04	4.10E+01
241-AZ-101	Sludge (Liquid & Solid)	P3AZ1 (Solid)	167	2.20E+02	6.65E+03	7.92E+03	1.94E+04	3.34E+04	4.68E+06	2.17E+04	2.84E+02	9.89E+02	1.02E+02	2.06E+05	2.28E+02
241-AZ-101	Supernatant	P3AZ1 (Liquid)	2991	1.66E+03	1.71E+05	1.99E+05	3.60E+05	1.96E+04	2.81E+03	4.67E-01	1.30E+00	4.55E+00	4.70E-01	5.06E+06	3.69E+04
241-AZ-101	Total			1.91E+03	1.78E+05	2.08E+05	3.83E+05	5.90E+04	5.52E+06	2.56E+04	3.32E+02	1.18E+03	1.15E+02	5.31E+06	3.72E+04
241-AZ-102	Sludge (Liquid & Solid)	NA (Sludge)	8	5.73E+00	8.61E+01	3.34E+02	5.39E+02	5.97E+02	7.90E+04	5.72E+02	6.29E+00	2.71E+01	3.93E+00	7.47E+03	3.80E-01
241-AZ-102	Sludge (Liquid & Solid)	P3AZ2 (Solid)	275	1.97E+02	2.96E+03	1.15E+04	1.85E+04	2.05E+04	2.71E+06	1.97E+04	2.47E+02	9.01E+02	1.35E+02	2.57E+05	1.31E+01
241-AZ-102	Sludge (Liquid & Solid)	PL2 (Solid)	15	1.07E+01	1.61E+02	6.26E+02	1.01E+03	1.12E+03	1.48E+05	1.07E+03	1.38E+01	4.88E+01	7.36E+00	1.40E+04	7.12E-01
241-AZ-102	Sludge (Liquid & Solid)	SRR (Solid)	98	7.02E+01	1.05E+03	4.09E+03	6.60E+03	7.31E+03	9.67E+05	7.01E+03	7.70E+01	3.32E+02	4.81E+01	9.15E+04	4.65E+00
241-AZ-102	Supernatant	P3AZ2 (Liquid)	3212	3.44E+03	4.40E+04	1.11E+05	1.89E+05	1.83E+03	6.51E+03	2.07E+00	6.61E+00	2.42E+01	2.34E+00	3.13E+06	6.61E+03
241-AZ-102	Total			3.72E+03	4.83E+04	1.28E+05	2.16E+05	3.14E+04	3.92E+06	2.84E+04	3.51E+02	1.33E+03	1.97E+02	3.50E+06	6.63E+03
241-B-101	Saltcake Interstitial Liquid	B-SltCk (Liquid)	73	4.94E-01	2.60E+04	9.60E+03	1.65E+04	5.28E+01	3.10E+02	2.26E-01	8.64E-02	7.64E-01	5.67E-03	1.31E+03	NA
241-B-101	Saltcake Solid	B-SltCk (Solid)	232	6.50E+02	6.28E+04	1.60E+04	7.92E+04	1.01E+04	1.34E+02	9.12E-02	1.54E+00	1.37E+01	1.01E-01	6.37E+02	NA
241-B-101	Sludge (Liquid & Solid)	B (Solid)	19	6.58E+00	3.83E-08	1.18E+02	5.26E+03	6.12E+02	1.98E+05	1.41E+03	6.87E+01	1.96E+02	2.16E+01	1.76E+02	NA
241-B-101	Sludge (Liquid & Solid)	BL (Solid)	76	3.31E+03	2.31E+03	4.46E+02	2.09E+04	4.38E+03	3.63E+03	5.37E+00	2.61E+01	1.02E+02	5.61E+00	0.00E+00	NA
241-B-101	Sludge (Liquid & Solid)	MW1 (Solid)	11	0.00E+00	2.28E+01	1.08E+01	1.33E+03	0.00E+00	7.63E+02	2.49E-03	8.08E-04	1.20E-02	4.04E-05	3.88E+01	NA
241-B-101	Total			3.96E+03	9.12E+04	2.62E+04	1.23E+05	1.52E+04	2.03E+05	1.42E+03	9.65E+01	3.13E+02	2.73E+01	2.16E+03	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-B-102	Saltcake Interstitial Liquid	B-SltCk (Liquid)	25	8.45E-02	5.43E+03	2.13E+02	2.82E+03	9.03E+00	5.30E+01	3.87E-02	1.48E-02	1.30E-01	9.69E-04	2.23E+02	NA
241-B-102	Saltcake Solid	B-SltCk (Solid)	81	8.12E+02	1.36E+04	1.01E+03	2.83E+04	3.62E+03	4.80E+01	3.25E-02	5.52E-01	4.88E+00	3.62E-02	2.28E+02	NA
241-B-102	Supernatant	B-SltCk (Liquid)	15	5.07E-02	3.25E+03	1.27E+02	1.69E+03	5.42E+00	3.18E+01	2.32E-02	8.86E-03	7.83E-02	5.82E-04	1.34E+02	NA
241-B-102	Total			8.12E+02	2.22E+04	1.35E+03	3.28E+04	3.64E+03	1.33E+02	9.45E-02	5.75E-01	5.08E+00	3.77E-02	5.84E+02	NA
241-B-103	Saltcake Interstitial Liquid	B-SltCk (Liquid)	50	1.69E-01	1.09E+04	4.25E+02	5.65E+03	1.81E+01	1.06E+02	7.74E-02	2.95E-02	2.61E-01	1.94E-03	4.46E+02	NA
241-B-103	Saltcake Solid	B-SltCk (Solid)	157	1.83E+02	2.63E+04	1.96E+03	5.48E+04	7.02E+03	9.30E+01	3.40E-01	5.76E+00	5.09E+01	3.78E-01	4.41E+02	NA
241-B-103	Sludge (Liquid & Solid)	MW1 (Solid)	4	0.00E+00	8.28E+00	3.92E+00	4.85E+02	0.00E+00	2.77E+02	9.04E-04	2.94E-04	4.36E-03	1.47E-05	1.41E+01	NA
241-B-103	Total			1.83E+02	3.71E+04	2.38E+03	6.10E+04	7.04E+03	4.76E+02	4.18E-01	5.79E+00	5.12E+01	3.80E-01	9.01E+02	NA
241-B-104	Saltcake Interstitial Liquid	B-SltCk (Liquid)	55	1.86E-01	1.19E+04	4.67E+02	6.21E+03	1.99E+01	1.17E+02	8.51E-02	3.25E-02	2.87E-01	2.13E-03	4.91E+02	NA
241-B-104	Saltcake Solid	B-SltCk (Solid)	192	2.40E+02	7.72E+04	6.62E+02	3.12E+04	4.91E+02	8.18E+01	8.43E-02	1.43E+00	1.26E+01	9.38E-02	3.88E+02	NA
241-B-104	Sludge (Liquid & Solid)	1C (Solid)	473	4.02E+02	1.90E+05	1.63E+03	7.69E+04	1.21E+03	3.68E+03	4.53E+00	2.97E+00	2.73E+01	1.92E-01	1.21E+04	NA
241-B-104	Sludge (Liquid & Solid)	2C (Solid)	697	1.91E+03	2.80E+05	2.40E+03	1.13E+05	1.78E+03	2.61E+00	9.43E-02	4.82E+00	4.62E+01	3.07E-01	3.04E+00	NA
241-B-104	Total			2.55E+03	5.59E+05	5.16E+03	2.28E+05	3.50E+03	3.88E+03	4.79E+00	9.26E+00	8.65E+01	5.95E-01	1.30E+04	NA
241-B-105	Saltcake Interstitial Liquid	B-SltCk (Liquid)	73	2.47E-01	1.58E+04	6.21E+02	8.25E+03	2.64E+01	1.55E+02	1.13E-01	4.31E-02	3.81E-01	2.83E-03	6.51E+02	NA
241-B-105	Saltcake Solid	B-SltCk (Solid)	919	1.60E+03	1.54E+05	1.14E+04	3.21E+05	4.11E+04	5.44E+02	3.69E-01	6.26E+00	5.53E+01	4.11E-01	2.58E+03	NA
241-B-105	Sludge (Liquid & Solid)	1C (Solid)	45	3.38E+01	8.11E+03	6.25E+02	6.39E+03	9.59E+02	3.10E+02	8.89E-01	5.83E-01	5.36E+00	3.77E-02	1.02E+03	NA
241-B-105	Sludge (Liquid & Solid)	2C (Solid)	61	9.68E+01	6.39E+03	1.64E+03	5.72E+03	1.55E+02	1.32E-01	2.58E-03	1.32E-01	1.26E+00	8.39E-03	1.54E-01	NA
241-B-105	Total			1.73E+03	1.84E+05	1.43E+04	3.41E+05	4.22E+04	1.01E+03	1.37E+00	7.02E+00	6.23E+01	4.60E-01	4.25E+03	NA
241-B-106	Sludge (Liquid & Solid)	1C (Solid)	163	4.81E+01	3.94E+04	1.54E+03	2.81E+04	3.18E+03	1.14E+03	1.67E+00	1.09E+00	1.01E+01	7.07E-02	2.35E+03	NA
241-B-106	Sludge (Liquid & Solid)	TBP (Solid)	297	2.18E+02	7.48E+04	3.06E+03	4.22E+04	6.11E+02	3.01E+04	4.65E+00	9.06E-01	8.46E+00	5.89E-02	7.52E+03	NA
241-B-106	Supernatant	B-SltCk (Liquid)	4	1.35E-02	8.68E+02	3.40E+01	4.52E+02	1.44E+00	8.48E+00	6.19E-03	2.36E-03	2.09E-02	1.55E-04	3.57E+01	NA
241-B-106	Total			2.67E+02	1.15E+05	4.63E+03	7.07E+04	3.79E+03	3.12E+04	6.33E+00	2.00E+00	1.85E+01	1.30E-01	9.90E+03	NA
241-B-107	Saltcake Interstitial Liquid	B-SltCk (Liquid)	68	3.43E-01	2.25E+04	4.43E+02	9.96E+03	1.37E+00	2.15E+02	2.44E-03	9.32E-04	8.23E-03	6.11E-05	9.05E+02	NA
241-B-107	Saltcake Solid	B-SltCk (Solid)	216	4.15E+02	3.56E+04	8.62E+02	7.22E+04	5.26E+03	1.41E+02	8.27E-02	1.40E+00	1.24E+01	9.20E-02	6.71E+02	NA
241-B-107	Sludge (Liquid & Solid)	1C (Solid)	285	3.08E+02	9.65E+04	2.10E+03	6.63E+04	9.77E+03	2.82E+03	4.20E+00	2.76E+00	2.53E+01	1.78E-01	9.30E+03	NA
241-B-107	Sludge (Liquid & Solid)	CWP2 (Solid)	42	3.37E+01	1.73E+03	5.45E+01	1.19E+03	1.09E+04	2.32E+01	2.74E-01	5.43E-01	2.30E+00	5.43E-02	2.73E+01	NA
241-B-107	Total			7.57E+02	1.56E+05	3.46E+03	1.50E+05	2.59E+04	3.20E+03	4.56E+00	4.70E+00	4.00E+01	3.24E-01	1.09E+04	NA
241-B-108	Saltcake Interstitial Liquid	B-SltCk (Liquid)	42	1.56E-01	1.58E+04	2.26E+03	7.31E+03	3.77E+01	9.79E+01	3.44E-02	1.31E-02	1.16E-01	8.62E-04	4.12E+02	NA
241-B-108	Saltcake Solid	B-SltCk (Solid)	204	3.95E+02	1.63E+04	2.64E+03	8.60E+04	8.33E+03	1.35E+02	8.66E-03	1.47E-01	1.30E+00	9.64E-03	3.95E+03	NA
241-B-108	Sludge (Liquid & Solid)	CWP2 (Solid)	104	1.54E+02	9.09E+03	2.42E+03	2.35E+04	2.55E+04	6.96E+02	6.45E-02	1.28E-01	5.42E-01	1.28E-02	3.17E+03	NA
241-B-108	Total			5.50E+02	4.12E+04	7.31E+03	1.17E+05	3.38E+04	9.29E+02	1.08E-01	2.88E-01	1.96E+00	2.33E-02	7.54E+03	NA
241-B-109	Saltcake Interstitial Liquid	B-SltCk (Liquid)	41	1.39E-01	8.90E+03	3.49E+02	4.63E+03	1.48E+01	8.70E+01	6.35E-02	2.42E-02	2.14E-01	1.59E-03	3.66E+02	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-B-109	Saltcake Solid	B-SltCk (Solid)	245	1.74E+02	7.28E+04	2.56E+03	1.09E+05	6.59E+03	1.64E+02	1.16E-01	1.97E+00	1.74E+01	1.29E-01	7.79E+02	NA
241-B-109	Sludge (Liquid & Solid)	CWP2 (Solid)	189	9.18E+02	1.21E+04	2.13E+03	5.50E+04	3.63E+04	1.24E+02	4.47E-01	8.87E-01	3.76E+00	8.87E-02	1.46E+02	NA
241-B-109	Total			1.09E+03	9.38E+04	5.04E+03	1.68E+05	4.29E+04	3.75E+02	6.27E-01	2.89E+00	2.14E+01	2.20E-01	1.29E+03	NA
241-B-110	Sludge (Liquid & Solid)	2C (Solid)	914	4.74E+02	2.32E+05	1.28E+04	1.21E+05	1.40E+03	9.66E+04	8.98E+01	1.31E+01	1.26E+02	3.90E+00	1.35E+04	NA
241-B-110	Sludge (Liquid & Solid)	B (Solid)	11	5.70E+00	2.80E+03	1.54E+02	1.46E+03	1.69E+01	1.16E+03	1.28E+00	4.35E-01	1.24E+00	4.31E-02	1.63E+02	NA
241-B-110	Supernatant	CSR (Liquid)	4	2.22E+01	3.11E+02	1.58E+02	3.82E+02	4.16E+01	9.23E+00	2.70E-02	4.68E-03	2.02E-02	8.44E-04	5.60E+01	NA
241-B-110	Total			5.01E+02	2.36E+05	1.31E+04	1.23E+05	1.46E+03	9.77E+04	9.11E+01	1.35E+01	1.27E+02	3.94E+00	1.37E+04	NA
241-B-111	Sludge (Liquid & Solid)	2C (Solid)	809	1.10E+03	8.42E+04	4.62E+04	9.03E+04	9.23E+02	1.97E+05	8.66E+01	9.40E+00	9.06E+01	3.06E+00	1.27E+05	NA
241-B-111	Sludge (Liquid & Solid)	B (Solid)	101	1.38E+02	1.05E+04	5.77E+03	1.13E+04	1.15E+02	2.46E+04	1.18E+01	3.24E+00	9.23E+00	3.60E-01	1.59E+04	NA
241-B-111	Supernatant	CSR (Liquid)	4	2.22E+01	3.11E+02	1.58E+02	3.82E+02	4.16E+01	9.23E+00	2.70E-02	4.68E-03	2.02E-02	8.44E-04	5.60E+01	NA
241-B-111	Total			1.26E+03	9.51E+04	5.22E+04	1.02E+05	1.08E+03	2.22E+05	9.85E+01	1.26E+01	9.98E+01	3.42E+00	1.43E+05	NA
241-B-112	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	16	2.91E+02	3.47E+03	1.87E+03	4.08E+03	7.57E+02	3.69E+01	1.08E-01	1.94E-02	8.06E-02	3.11E-03	2.45E+03	NA
241-B-112	Saltcake Solid	BY-SltCk (Solid)	49	2.54E+02	1.54E+04	1.61E+03	1.40E+04	1.53E+03	7.26E+02	1.01E-01	1.03E-02	4.31E-02	1.66E-03	3.77E+03	NA
241-B-112	Sludge (Liquid & Solid)	2C (Solid)	56	1.85E+02	1.22E+04	3.13E+03	1.09E+04	2.96E+02	2.52E-01	6.78E-04	3.46E-02	3.32E-01	2.20E-03	2.93E-01	NA
241-B-112	Supernatant	BY-SltCk (Liquid)	11	2.00E+02	2.39E+03	1.29E+03	2.80E+03	5.20E+02	2.54E+01	7.42E-02	1.33E-02	5.54E-02	2.14E-03	1.68E+03	NA
241-B-112	Total			9.30E+02	3.34E+04	7.90E+03	3.17E+04	3.10E+03	7.88E+02	2.84E-01	7.76E-02	5.11E-01	9.11E-03	7.90E+03	NA
241-B-201	Sludge (Liquid & Solid)	224-1 (Solid)	111	3.31E+02	7.06E+03	1.23E+02	4.79E+03	1.52E+02	2.39E+02	3.97E+00	6.05E+00	1.05E+02	8.79E-01	1.90E+01	NA
241-B-201	Total			3.31E+02	7.06E+03	1.23E+02	4.79E+03	1.52E+02	2.39E+02	3.97E+00	6.05E+00	1.05E+02	8.79E-01	1.90E+01	NA
241-B-202	Sludge (Liquid & Solid)	224-2 (Solid)	108	3.89E+02	8.10E+03	1.44E+02	5.17E+03	2.25E+02	3.95E+02	8.79E+00	2.86E+00	1.69E+01	2.67E-01	1.01E+01	NA
241-B-202	Total			3.89E+02	8.10E+03	1.44E+02	5.17E+03	2.25E+02	3.95E+02	8.79E+00	2.86E+00	1.69E+01	2.67E-01	1.01E+01	NA
241-B-203	Sludge (Liquid & Solid)	224-2 (Solid)	188	1.21E+02	1.39E+04	1.58E+02	6.47E+03	1.16E+01	1.55E+01	7.73E+00	6.59E+00	5.22E+01	4.52E-01	1.48E+00	NA
241-B-203	Supernatant	NA (Liquid)	2	1.92E-01	1.13E+02	3.14E+00	6.23E+01	0.00E+00	1.63E-04	8.54E-05	1.02E-03	8.04E-03	6.96E-05	1.89E-04	NA
241-B-203	Total			1.21E+02	1.40E+04	1.61E+02	6.53E+03	1.16E+01	1.55E+01	7.73E+00	6.59E+00	5.23E+01	4.52E-01	1.48E+00	NA
241-B-204	Sludge (Liquid & Solid)	224-2 (Solid)	184	1.00E+02	1.08E+04	1.26E+02	5.75E+03	1.28E+01	5.73E-01	8.41E+00	5.50E+00	4.36E+01	3.77E-01	5.73E+00	NA
241-B-204	Supernatant	NA (Liquid)	3	2.26E-01	1.04E+02	4.09E+00	8.35E+01	0.00E+00	1.09E-04	4.92E-07	1.48E-05	2.20E-04	7.43E-07	1.25E-04	NA
241-B-204	Total			1.01E+02	1.09E+04	1.30E+02	5.84E+03	1.28E+01	5.73E-01	8.41E+00	5.50E+00	4.36E+01	3.77E-01	5.73E+00	NA
241-BX-101	Sludge (Liquid & Solid)	BL (Solid)	74	6.38E+03	4.68E+03	2.87E+03	9.43E+03	1.70E+04	7.00E+03	4.62E+00	2.24E+01	8.78E+01	4.82E+00	1.13E+04	NA
241-BX-101	Sludge (Liquid & Solid)	CWP2 (Solid)	47	5.39E+01	2.97E+03	1.82E+03	5.99E+03	1.08E+04	5.16E+04	5.86E+00	1.16E+01	4.92E+01	1.16E+00	7.17E+03	NA
241-BX-101	Sludge (Liquid & Solid)	TBP (Solid)	59	1.15E+02	3.73E+03	2.28E+03	7.52E+03	1.35E+04	1.86E+04	3.10E+01	6.03E+00	5.63E+01	3.92E-01	9.00E+03	NA
241-BX-101	Total			6.55E+03	1.14E+04	6.97E+03	2.29E+04	4.13E+04	7.72E+04	4.15E+01	4.01E+01	1.93E+02	6.37E+00	2.75E+04	NA
241-BX-102	Sludge Solid	CWP2 (Solid)	81	6.49E+01	3.13E+03	9.93E+02	3.82E+03	2.26E+04	4.47E+01	5.28E-01	1.05E+00	4.44E+00	1.05E-01	5.26E+01	NA
241-BX-102	Sludge Solid	DE (Solid)	147	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.54E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-BX-102	Sludge Solid	TBP (Solid)	70	7.00E+01	1.91E+04	1.32E+03	1.12E+04	1.85E+02	1.05E+05	6.34E-01	1.23E-01	1.15E+00	8.02E-03	1.13E+04	NA
241-BX-102	Total			1.35E+02	2.23E+04	2.31E+03	1.50E+04	2.33E+04	1.05E+05	1.16E+00	1.17E+00	5.59E+00	1.13E-01	1.14E+04	NA
241-BX-103	Sludge (Liquid & Solid)	CWP2 (Solid)	214	3.11E+03	7.05E+03	2.24E+03	8.62E+03	5.09E+04	1.01E+02	9.37E+01	1.86E+02	7.87E+02	1.86E+01	1.18E+02	NA
241-BX-103	Sludge (Liquid & Solid)	TBP (Solid)	21	3.05E+02	5.85E+03	4.02E+02	3.43E+03	5.66E+01	1.82E+05	3.46E+01	6.73E+00	6.29E+01	4.37E-01	1.96E+04	NA
241-BX-103	Supernatant	CWP2 (Liquid)	50	1.82E+02	2.22E+03	6.83E+02	1.94E+03	8.86E+02	2.61E+01	2.90E-01	6.20E-02	2.63E-01	6.21E-03	3.07E+01	NA
241-BX-103	Total			3.60E+03	1.51E+04	3.32E+03	1.40E+04	5.18E+04	1.82E+05	1.29E+02	1.93E+02	8.50E+02	1.90E+01	1.97E+04	NA
241-BX-104	Sludge (Liquid & Solid)	CWP2 (Solid)	51	3.72E+02	3.94E+03	1.94E+03	5.68E+03	1.15E+04	1.66E+04	3.39E+01	6.45E+00	2.73E+01	6.45E-01	5.21E+03	NA
241-BX-104	Sludge (Liquid & Solid)	CWR1 (Solid)	110	8.01E+02	8.49E+03	4.19E+03	1.23E+04	2.48E+04	3.58E+04	1.03E+02	1.16E+01	6.12E+01	9.53E-01	1.12E+04	NA
241-BX-104	Sludge (Liquid & Solid)	MW1 (Solid)	155	1.13E+03	1.20E+04	5.91E+03	1.73E+04	3.50E+04	5.05E+04	1.46E+02	6.48E+00	9.61E+01	3.24E-01	1.58E+04	NA
241-BX-104	Sludge (Liquid & Solid)	TBP (Solid)	53	3.86E+02	4.09E+03	2.02E+03	5.91E+03	1.20E+04	1.73E+04	4.97E+01	3.40E+00	3.17E+01	2.21E-01	5.41E+03	NA
241-BX-104	Supernatant	CWR1 (Liquid)	11	3.51E+01	1.47E+03	7.01E+02	1.54E+03	3.12E+01	1.86E+01	2.96E-03	4.49E-04	2.36E-03	3.67E-05	1.36E+03	NA
241-BX-104	Total			2.72E+03	3.00E+04	1.48E+04	4.27E+04	8.33E+04	1.20E+05	3.32E+02	2.80E+01	2.16E+02	2.14E+00	3.90E+04	NA
241-BX-105	Saltcake (Liquid & Solid)	BY-SltCk (Solid)	94	2.64E+02	1.07E+04	5.13E+03	3.55E+04	1.09E+04	3.00E+04	1.61E+01	1.64E+00	6.87E+00	2.64E-01	1.21E+04	NA
241-BX-105	Sludge (Liquid & Solid)	CWP2 (Solid)	96	2.70E+02	1.10E+04	1.75E+03	3.62E+04	1.12E+04	3.06E+04	2.70E+00	5.36E+00	2.27E+01	5.36E-01	1.23E+04	NA
241-BX-105	Sludge (Liquid & Solid)	MW1 (Solid)	9	0.00E+00	1.86E+01	8.81E+00	1.09E+03	0.00E+00	6.24E+02	2.03E-03	6.61E-04	9.80E-03	3.31E-05	3.17E+01	NA
241-BX-105	Sludge (Liquid & Solid)	TBP (Solid)	55	1.54E+02	6.28E+03	2.10E+03	2.08E+04	6.40E+03	1.75E+04	6.57E+00	1.28E+00	1.19E+01	8.31E-02	7.07E+03	NA
241-BX-105	Supernatant	CWP2 (Liquid)	18	1.70E+02	2.11E+03	7.20E+02	2.23E+03	1.07E+02	1.35E+02	4.44E-01	5.88E-02	2.50E-01	5.89E-03	2.14E+03	NA
241-BX-105	Total			8.58E+02	3.01E+04	9.71E+03	9.58E+04	2.86E+04	7.89E+04	2.58E+01	8.34E+00	4.18E+01	8.89E-01	3.37E+04	NA
241-BX-106	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	25	4.55E+02	5.42E+03	2.93E+03	6.37E+03	1.18E+03	5.77E+01	1.69E-01	3.02E-02	1.26E-01	4.86E-03	3.83E+03	NA
241-BX-106	Saltcake Solid	BY-SltCk (Solid)	80	4.68E+02	2.83E+04	2.97E+03	2.57E+04	2.81E+03	1.34E+03	4.98E+01	5.07E+00	2.12E+01	8.17E-01	6.94E+03	NA
241-BX-106	Sludge (Liquid & Solid)	CWP2 (Solid)	18	1.46E+01	7.05E+02	2.24E+02	8.61E+02	5.09E+03	1.01E+01	1.49E+00	2.96E+00	1.25E+01	2.96E-01	1.18E+01	NA
241-BX-106	Sludge (Liquid & Solid)	TBP (Solid)	20	2.76E+01	7.56E+03	5.20E+02	4.43E+03	7.31E+01	7.10E+04	6.26E+00	1.22E+00	1.14E+01	7.92E-02	7.68E+03	NA
241-BX-106	Total			9.65E+02	4.19E+04	6.64E+03	3.73E+04	9.16E+03	7.24E+04	5.77E+01	9.27E+00	4.52E+01	1.20E+00	1.85E+04	NA
241-BX-107	Sludge (Liquid & Solid)	1C (Solid)	1313	1.13E+03	2.59E+05	1.54E+04	1.92E+05	2.70E+04	1.42E+04	2.45E+01	1.06E+01	9.75E+01	6.86E-01	2.54E+04	NA
241-BX-107	Total			1.13E+03	2.59E+05	1.54E+04	1.92E+05	2.70E+04	1.42E+04	2.45E+01	1.06E+01	9.75E+01	6.86E-01	2.54E+04	NA
241-BX-108	Sludge (Liquid & Solid)	1C (Solid)	38	5.16E+01	1.24E+04	9.52E+02	9.73E+03	1.46E+03	4.72E+02	5.69E-01	3.74E-01	3.43E+00	2.41E-02	1.56E+03	NA
241-BX-108	Sludge (Liquid & Solid)	TBP (Solid)	81	1.35E+02	3.71E+04	2.55E+03	2.17E+04	3.59E+02	2.19E+04	2.68E+00	5.21E-01	4.87E+00	3.39E-02	2.36E+03	NA
241-BX-108	Total			1.87E+02	4.94E+04	3.50E+03	3.14E+04	1.82E+03	2.23E+04	3.25E+00	8.95E-01	8.30E+00	5.80E-02	3.92E+03	NA
241-BX-109	Sludge (Liquid & Solid)	TBP (Solid)	730	7.83E+02	2.17E+05	2.00E+04	1.17E+05	2.21E+03	1.19E+05	5.95E+00	1.16E+00	1.08E+01	7.53E-02	1.20E+04	NA
241-BX-109	Total			7.83E+02	2.17E+05	2.00E+04	1.17E+05	2.21E+03	1.19E+05	5.95E+00	1.16E+00	1.08E+01	7.53E-02	1.20E+04	NA
241-BX-110	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	129	1.96E+03	5.32E+04	6.72E+03	2.88E+04	5.67E+02	2.48E+02	7.25E-01	1.30E-01	5.42E-01	2.09E-02	1.64E+04	NA
241-BX-110	Saltcake Solid	BY-SltCk (Solid)	433	1.42E+03	2.97E+05	8.00E+03	1.81E+05	1.82E+04	8.16E+03	2.53E+00	2.57E-01	1.08E+00	4.15E-02	4.24E+04	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-BX-110	Sludge (Liquid & Solid)	1C (Solid)	151	1.14E+02	2.72E+04	2.10E+03	2.14E+04	3.22E+03	1.04E+03	2.98E+00	1.96E+00	1.80E+01	1.27E-01	3.43E+03	NA
241-BX-110	Sludge (Liquid & Solid)	NA (Sludge)	94	3.08E+02	6.45E+04	1.74E+03	3.93E+04	3.96E+03	1.12E+03	1.31E-01	8.63E-02	7.93E-01	5.58E-03	3.69E+03	NA
241-BX-110	Supernatant	BY-SltCk (Liquid)	5	7.58E+01	2.06E+03	2.61E+02	1.12E+03	2.20E+01	9.61E+00	2.81E-02	5.04E-03	2.10E-02	8.09E-04	6.37E+02	NA
241-BX-110	Total			3.87E+03	4.44E+05	1.88E+04	2.71E+05	2.60E+04	1.06E+04	6.40E+00	2.44E+00	2.04E+01	1.95E-01	6.66E+04	NA
241-BX-111	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	54	9.18E+01	1.00E+04	5.73E+03	1.22E+04	2.63E+03	1.09E+02	9.94E-02	1.78E-02	7.42E-02	2.86E-03	7.21E+03	NA
241-BX-111	Saltcake Solid	BY-SltCk (Solid)	538	9.52E+02	3.75E+05	1.01E+04	2.20E+05	1.10E+04	1.09E+04	1.05E+00	1.07E-01	4.49E-01	1.73E-02	5.68E+04	NA
241-BX-111	Sludge (Liquid & Solid)	1C (Solid)	121	9.10E+01	2.18E+04	1.68E+03	1.72E+04	2.58E+03	8.34E+02	2.39E+00	1.57E+00	1.44E+01	1.01E-01	2.74E+03	NA
241-BX-111	Total			1.13E+03	4.06E+05	1.75E+04	2.49E+05	1.62E+04	1.19E+04	3.54E+00	1.69E+00	1.49E+01	1.22E-01	6.67E+04	NA
241-BX-112	Sludge (Liquid & Solid)	1C (Solid)	617	4.70E+02	6.14E+04	2.22E+04	6.73E+04	1.00E+04	4.70E+03	1.95E+01	1.28E+01	1.17E+02	8.26E-01	3.28E+04	NA
241-BX-112	Supernatant	1C2 (Liquid)	5	0.00E+00	4.93E+02	1.76E+02	3.89E+02	2.39E-01	3.67E+00	8.06E-04	1.13E-03	7.96E-03	7.90E-05	4.31E+00	NA
241-BX-112	Total			4.70E+02	6.19E+04	2.24E+04	6.77E+04	1.00E+04	4.70E+03	1.95E+01	1.28E+01	1.17E+02	8.26E-01	3.28E+04	NA
241-BY-101	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	52	9.46E+02	1.13E+04	6.08E+03	1.33E+04	2.46E+03	1.20E+02	3.51E-01	6.29E-02	2.62E-01	1.01E-02	7.96E+03	NA
241-BY-101	Saltcake Solid	BY-SltCk (Solid)	1208	5.27E+03	8.54E+05	2.48E+03	5.75E+05	4.59E+04	2.99E+04	3.10E+00	3.15E-01	1.32E+00	5.08E-02	1.55E+05	NA
241-BY-101	Sludge (Liquid & Solid)	PFeCN (Solid)	140	2.92E+03	3.20E+04	7.93E+03	3.67E+04	7.20E+03	1.17E+05	2.22E+01	2.82E+00	2.61E+01	1.82E-01	6.98E+04	NA
241-BY-101	Total			9.13E+03	8.97E+05	1.65E+04	6.25E+05	5.55E+04	1.47E+05	2.56E+01	3.20E+00	2.77E+01	2.43E-01	2.33E+05	NA
241-BY-102	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	157	2.43E+02	2.32E+04	1.32E+04	3.68E+04	8.88E+03	3.21E+02	2.74E-01	4.92E-02	2.05E-01	7.90E-03	2.13E+04	NA
241-BY-102	Saltcake Solid	BY-SltCk (Solid)	897	8.99E+03	1.59E+05	2.31E+04	3.94E+05	4.14E+04	1.71E+04	8.34E+01	8.48E+00	3.55E+01	1.37E+00	8.88E+04	NA
241-BY-102	Total			9.23E+03	1.82E+05	3.62E+04	4.30E+05	5.03E+04	1.74E+04	8.36E+01	8.53E+00	3.57E+01	1.37E+00	1.10E+05	NA
241-BY-103	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	214	3.41E+02	3.02E+04	9.61E+03	3.85E+04	7.41E+03	1.62E+01	1.22E-01	3.63E-03	1.51E-02	5.84E-04	2.06E+04	6.74E+03
241-BY-103	Saltcake Solid	BY-SltCk (Solid)	1316	3.28E+04	5.41E+05	1.61E+04	5.66E+05	6.20E+04	2.94E+04	2.98E+01	3.03E+00	1.27E+01	4.89E-01	1.53E+05	NA
241-BY-103	Sludge (Liquid & Solid)	CWP2 (Solid)	34	2.72E+01	1.31E+03	4.17E+02	1.61E+03	9.48E+03	1.88E+01	2.22E-01	4.40E-01	1.86E+00	4.40E-02	2.21E+01	NA
241-BY-103	Total			3.32E+04	5.72E+05	2.62E+04	6.06E+05	7.89E+04	2.95E+04	3.02E+01	3.47E+00	1.46E+01	5.33E-01	1.74E+05	6.74E+03
241-BY-104	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	153	3.63E+02	3.16E+04	1.70E+04	3.79E+04	1.10E+04	3.36E+02	9.82E-01	1.76E-01	7.33E-01	2.83E-02	2.23E+04	NA
241-BY-104	Saltcake Solid	BY-SltCk (Solid)	1208	1.42E+04	5.18E+05	7.66E+04	4.56E+05	4.34E+04	2.04E+05	1.24E+02	1.26E+01	5.28E+01	2.03E+00	1.89E+05	NA
241-BY-104	Sludge (Liquid & Solid)	PFeCN (Solid)	172	3.23E+03	3.58E+04	1.20E+04	4.35E+04	1.70E+04	1.59E+05	2.01E+01	2.55E+00	2.36E+01	1.65E-01	1.59E+04	NA
241-BY-104	Total			1.78E+04	5.85E+05	1.06E+05	5.38E+05	7.14E+04	3.63E+05	1.45E+02	1.53E+01	7.72E+01	2.23E+00	2.28E+05	NA
241-BY-105	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	159	3.86E+02	3.17E+04	1.09E+04	3.30E+04	6.23E+03	1.53E+01	1.63E+00	7.32E-03	3.05E-02	1.18E-03	2.99E+04	6.08E+03
241-BY-105	Saltcake Solid	BY-SltCk (Solid)	1481	4.96E+03	1.33E+06	2.39E+04	6.22E+05	5.80E+04	1.48E+04	7.89E+01	8.02E+00	3.36E+01	1.29E+00	8.21E+04	NA
241-BY-105	Sludge (Liquid & Solid)	PFeCN (Solid)	151	3.90E+03	4.11E+04	6.75E+03	3.99E+04	5.61E+03	1.25E+05	3.77E+01	4.79E+00	4.43E+01	3.09E-01	4.06E+04	NA
241-BY-105	Sludge (Liquid & Solid)	Portland Cement (Sol)	30	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.57E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	NA
241-BY-105	Total			9.24E+03	1.40E+06	4.16E+04	6.95E+05	7.14E+04	1.40E+05	1.18E+02	1.28E+01	7.80E+01	1.60E+00	1.53E+05	6.08E+03
241-BY-106	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	138	3.69E+02	1.52E+04	1.08E+04	2.27E+04	5.49E+03	4.32E+00	6.40E-03	2.15E-04	8.95E-04	3.45E-05	2.40E+04	4.93E+03

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-BY-106	Saltcake Solid	BY-SltCk (Solid)	1365	5.79E+03	7.69E+05	6.19E+04	4.68E+05	4.26E+04	8.25E+03	1.23E+01	1.25E+00	5.24E+00	2.02E-01	1.91E+05	NA
241-BY-106	Sludge (Liquid & Solid)	PFeCN (Solid)	120	4.11E+03	2.54E+04	6.30E+03	2.61E+04	6.21E+03	1.28E+05	2.62E+01	1.96E+00	1.81E+01	1.26E-01	8.56E+04	NA
241-BY-106	Total			1.03E+04	8.10E+05	7.90E+04	5.17E+05	5.43E+04	1.36E+05	3.85E+01	3.21E+00	2.34E+01	3.28E-01	3.01E+05	4.93E+03
241-BY-107	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	135	3.24E+02	1.77E+04	1.58E+04	3.28E+04	6.91E+03	2.88E+02	6.16E-01	1.10E-01	4.60E-01	1.77E-02	1.91E+04	NA
241-BY-107	Saltcake Solid	BY-SltCk (Solid)	835	5.60E+03	2.97E+05	5.48E+04	3.70E+05	4.91E+04	2.67E+04	1.31E+01	1.33E+00	5.58E+00	2.15E-01	1.52E+05	NA
241-BY-107	Sludge (Liquid & Solid)	PFeCN (Solid)	58	8.54E+02	9.85E+03	4.21E+03	2.29E+04	4.83E+03	4.75E+04	6.82E+00	8.67E-01	8.02E+00	5.59E-02	2.83E+04	NA
241-BY-107	Total			6.78E+03	3.25E+05	7.49E+04	4.25E+05	6.08E+04	7.45E+04	2.06E+01	2.31E+00	1.41E+01	2.89E-01	1.99E+05	NA
241-BY-108	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	103	2.44E+02	3.03E+04	8.09E+03	2.90E+04	3.74E+03	2.62E+02	1.19E-01	2.14E-02	8.90E-02	3.43E-03	1.74E+04	NA
241-BY-108	Saltcake Solid	BY-SltCk (Solid)	587	3.01E+03	1.79E+05	2.01E+04	1.70E+05	7.57E+04	1.09E+04	2.19E+01	2.23E+00	9.34E+00	3.60E-01	1.51E+04	NA
241-BY-108	Sludge (Liquid & Solid)	PFeCN (Solid)	151	2.32E+03	1.94E+04	9.87E+03	3.39E+04	5.41E+03	1.18E+05	1.60E+01	2.03E+00	1.88E+01	1.31E-01	2.01E+04	NA
241-BY-108	Total			5.58E+03	2.29E+05	3.81E+04	2.32E+05	8.49E+04	1.29E+05	3.81E+01	4.29E+00	2.82E+01	4.94E-01	5.26E+04	NA
241-BY-109	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	146	2.75E+02	2.78E+04	1.21E+04	3.06E+04	5.66E+03	2.93E+02	8.56E-01	1.53E-01	6.39E-01	2.47E-02	1.94E+04	NA
241-BY-109	Saltcake Solid	BY-SltCk (Solid)	851	9.72E+03	9.64E+04	3.69E+04	2.96E+05	3.29E+04	1.40E+04	6.70E+01	6.81E+00	2.85E+01	1.10E+00	7.28E+04	NA
241-BY-109	Sludge (Liquid & Solid)	CWP2 (Solid)	89	1.03E+02	9.08E+03	3.03E+03	1.16E+04	3.52E+04	7.08E+01	5.54E-01	1.10E+00	4.66E+00	1.10E-01	8.33E+01	NA
241-BY-109	Total			1.01E+04	1.33E+05	5.20E+04	3.38E+05	7.37E+04	1.44E+04	6.84E+01	8.07E+00	3.38E+01	1.23E+00	9.23E+04	NA
241-BY-110	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	99	1.92E+03	1.23E+04	1.23E+04	2.51E+04	6.51E+03	2.44E+02	6.60E-02	1.18E-02	4.93E-02	1.90E-03	1.62E+04	NA
241-BY-110	Saltcake Solid	BY-SltCk (Solid)	1123	9.54E+03	1.98E+05	5.85E+04	3.93E+05	3.29E+04	4.86E+04	4.13E+01	5.60E+00	2.34E+01	9.03E-01	1.39E+05	NA
241-BY-110	Sludge (Liquid & Solid)	PFeCN (Solid)	162	2.64E+03	3.04E+04	1.19E+04	4.42E+04	8.81E+03	1.09E+05	1.84E+01	2.66E+00	2.46E+01	1.71E-01	3.43E+04	NA
241-BY-110	Total			1.41E+04	2.41E+05	8.27E+04	4.63E+05	4.82E+04	1.58E+05	5.98E+01	8.27E+00	4.81E+01	1.08E+00	1.90E+05	NA
241-BY-111	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	145	1.85E+02	2.91E+04	7.92E+03	3.14E+04	6.23E+03	2.71E+02	5.29E-01	9.48E-02	3.95E-01	1.52E-02	1.80E+04	NA
241-BY-111	Saltcake Solid	BY-SltCk (Solid)	1378	1.42E+04	3.39E+05	3.66E+04	5.75E+05	5.85E+04	2.58E+04	1.56E+02	1.59E+01	6.66E+01	2.56E+00	1.34E+05	NA
241-BY-111	Total			1.44E+04	3.68E+05	4.46E+04	6.07E+05	6.48E+04	2.61E+04	1.57E+02	1.60E+01	6.70E+01	2.58E+00	1.52E+05	NA
241-BY-112	Saltcake Interstitial Liquid	BY-SltCk (Liquid)	79	1.36E+02	1.50E+04	1.11E+04	1.93E+04	4.38E+03	1.70E+02	4.97E-01	8.92E-02	3.71E-01	1.43E-02	1.13E+04	NA
241-BY-112	Saltcake Solid	BY-SltCk (Solid)	996	1.49E+04	1.29E+05	4.13E+04	5.71E+05	3.48E+04	2.09E+04	8.06E+01	8.19E+00	3.43E+01	1.32E+00	1.08E+05	NA
241-BY-112	Sludge (Liquid & Solid)	MW2 (Solid)	8	0.00E+00	6.99E+00	5.82E+00	1.21E+03	0.00E+00	1.12E+03	5.47E-03	1.06E-02	8.38E-02	7.26E-04	2.86E+01	NA
241-BY-112	Total			1.50E+04	1.44E+05	5.23E+04	5.92E+05	3.92E+04	2.22E+04	8.11E+01	8.29E+00	3.48E+01	1.34E+00	1.20E+05	NA
241-C-101	Sludge (Liquid & Solid)	CWP1 (Solid)	208	1.43E+03	2.30E+03	3.15E+03	1.75E+04	7.88E+04	2.40E+02	6.11E+00	6.73E+01	3.23E+02	5.58E+00	2.59E+04	NA
241-C-101	Sludge (Liquid & Solid)	TBP (Solid)	125	2.34E+02	6.40E+04	4.41E+03	3.75E+04	6.20E+02	3.78E+04	7.89E+01	1.54E+01	1.43E+02	9.98E-01	4.08E+03	NA
241-C-101	Total			1.66E+03	6.63E+04	7.55E+03	5.50E+04	7.94E+04	3.80E+04	8.50E+01	8.26E+01	4.67E+02	6.57E+00	3.00E+04	NA
241-C-102	Sludge (Liquid & Solid)	CWP1 (Solid)	125	6.83E+02	1.10E+03	1.51E+03	8.35E+03	3.77E+04	1.15E+02	4.28E+00	4.71E+01	2.26E+02	3.90E+00	1.24E+04	NA
241-C-102	Sludge (Liquid & Solid)	CWP2 (Solid)	855	1.02E+03	3.66E+04	1.20E+04	7.35E+04	2.38E+05	4.72E+02	9.50E+02	7.21E+02	3.05E+03	7.21E+01	1.11E+04	NA
241-C-102	Sludge (Liquid & Solid)	CWZr1 (Solid)	38	4.54E+01	1.63E+03	5.31E+02	3.27E+03	0.00E+00	9.74E+02	6.73E+01	4.68E+01	1.21E+02	1.20E+01	4.92E+02	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-C-102	Sludge (Liquid & Solid)	MW1 (Solid)	19	0.00E+00	3.93E+01	1.86E+01	2.30E+03	0.00E+00	1.32E+03	4.29E-03	1.39E-03	2.07E-02	6.98E-05	6.70E+01	NA
241-C-102	Sludge (Liquid & Solid)	TBP (Solid)	61	6.10E+01	1.67E+04	1.15E+03	9.77E+03	1.61E+02	9.84E+03	5.52E-01	1.08E-01	1.00E+00	6.99E-03	1.06E+03	NA
241-C-102	Sludge (Liquid & Solid)	TH1 (Solid)	98	4.73E+01	9.18E+03	3.83E+03	9.16E+03	1.80E+03	1.53E+04	6.81E-12	1.19E-11	1.73E-10	3.34E-06	8.05E+02	NA
241-C-102	Total			1.86E+03	6.52E+04	1.90E+04	1.06E+05	2.78E+05	2.80E+04	1.02E+03	8.15E+02	3.40E+03	8.80E+01	2.59E+04	NA
241-C-103	Sludge (Liquid & Solid)	NA (Sludge)	8.64	5.81E-01	8.23E-01	4.46E-01	9.59E+01	3.63E+03	9.96E+03	4.93E+00	1.04E+00	4.99E+00	1.48E+00	8.78E+02	NA
241-C-103	Supernatant	NA (Liquid)	0.93	4.93E-04	4.77E-02	3.58E-02	1.17E-01	1.12E-03	6.65E-02	4.63E-06	1.46E-06	9.40E-06	2.64E-06	9.79E-02	9.36E-05
241-C-103	Total			5.82E-01	8.71E-01	4.82E-01	9.60E+01	3.63E+03	9.96E+03	4.93E+00	1.04E+00	4.99E+00	1.48E+00	8.78E+02	9.36E-05
241-C-104	Sludge (Liquid & Solid)	CWP1 (Solid)	326	4.68E+03	6.47E+03	1.21E+04	5.89E+04	2.98E+04	1.49E+05	2.07E+03	3.73E+02	1.79E+03	3.09E+01	2.95E+04	NA
241-C-104	Sludge (Liquid & Solid)	CWP2 (Solid)	229	3.29E+03	4.55E+03	8.48E+03	4.14E+04	2.09E+04	1.04E+05	1.47E+03	2.91E+02	1.23E+03	2.90E+01	2.07E+04	NA
241-C-104	Sludge (Liquid & Solid)	CWZr1 (Solid)	90	1.29E+03	1.79E+03	3.33E+03	1.63E+04	8.23E+03	4.11E+04	6.07E+02	1.67E+02	4.31E+02	4.28E+01	8.14E+03	NA
241-C-104	Sludge (Liquid & Solid)	NA (Sludge)	152	2.18E+03	3.02E+03	5.63E+03	2.75E+04	1.39E+04	6.93E+04	1.00E+03	2.34E+02	7.76E+02	6.28E+01	1.37E+04	NA
241-C-104	Sludge (Liquid & Solid)	OWW3 (Solid)	103	1.48E+03	2.04E+03	3.81E+03	1.86E+04	9.42E+03	4.70E+04	6.88E+02	1.77E+02	5.07E+02	5.59E+01	9.31E+03	NA
241-C-104	Sludge (Liquid & Solid)	TH2 (Solid)	80	1.15E+03	1.59E+03	2.96E+03	1.44E+04	7.31E+03	3.65E+04	5.09E+02	9.15E+01	4.40E+02	7.59E+00	7.23E+03	NA
241-C-104	Total			1.41E+04	1.95E+04	3.63E+04	1.77E+05	8.96E+04	4.47E+05	6.34E+03	1.33E+03	5.18E+03	2.29E+02	8.86E+04	NA
241-C-105	Sludge (Liquid & Solid)	CWP1 (Solid)	450	4.26E+03	7.32E+03	5.74E+03	2.97E+04	1.55E+05	3.97E+05	1.08E+03	3.67E+02	1.77E+03	3.04E+01	6.87E+04	NA
241-C-105	Sludge (Liquid & Solid)	TBP (Solid)	50	5.27E+01	8.14E+02	9.92E+02	8.44E+03	1.39E+02	4.41E+04	1.15E+02	2.29E+01	2.14E+02	1.49E+00	7.64E+03	NA
241-C-105	Total			4.31E+03	8.14E+03	6.73E+03	3.81E+04	1.55E+05	4.41E+05	1.19E+03	3.90E+02	1.98E+03	3.19E+01	7.64E+04	NA
241-C-106	Sludge (Liquid & Solid)	NA (Sludge)	10.166	9.06E+01	3.48E+01	4.14E+01	1.85E+02	3.82E+02	6.61E+04	6.52E+01	3.57E+00	1.67E+01	2.70E+00	1.45E+03	NA
241-C-106	Supernatant	NA (Liquid)	0.322	1.07E-01	1.94E-02	1.75E-02	3.15E+00	3.02E-02	1.42E-02	1.35E-06	2.79E-07	1.31E-06	2.10E-07	1.40E-01	2.26E+00
241-C-106	Total			9.07E+01	3.48E+01	4.14E+01	1.88E+02	3.82E+02	6.61E+04	6.52E+01	3.57E+00	1.67E+01	2.70E+00	1.45E+03	2.26E+00
241-C-107	Sludge (Liquid & Solid)	1C (Solid)	507	3.97E+02	3.43E+04	2.05E+04	5.85E+04	1.89E+04	3.40E+05	3.63E+03	1.35E+02	1.24E+03	8.73E+00	3.20E+04	NA
241-C-107	Sludge (Liquid & Solid)	CWP2 (Solid)	89	6.97E+01	3.21E+03	2.58E+03	7.88E+03	1.64E+04	5.97E+04	6.37E+02	4.62E+01	1.95E+02	4.61E+00	5.61E+03	NA
241-C-107	Sludge (Liquid & Solid)	SRR (Solid)	339	2.66E+02	1.00E+04	1.21E+04	2.83E+04	2.29E+04	1.68E+06	2.43E+03	1.73E+02	7.47E+02	3.09E+01	2.14E+04	NA
241-C-107	Total			7.32E+02	4.75E+04	3.51E+04	9.47E+04	5.83E+04	2.08E+06	6.69E+03	3.55E+02	2.18E+03	4.43E+01	5.89E+04	NA
241-C-108	Sludge (Liquid & Solid)	1C (Solid)	95	1.33E+02	6.10E+03	3.39E+03	1.32E+04	7.32E+03	3.04E+03	4.08E+00	1.29E-01	1.19E+00	8.34E-03	2.95E+04	NA
241-C-108	Total			1.33E+02	6.10E+03	3.39E+03	1.32E+04	7.32E+03	3.04E+03	4.08E+00	1.29E-01	1.19E+00	8.34E-03	2.95E+04	NA
241-C-109	Sludge (Liquid & Solid)	1C (Solid)	38	2.86E+01	6.85E+03	5.28E+02	5.40E+03	8.10E+02	2.62E+02	7.51E-01	4.93E-01	4.53E+00	3.18E-02	8.62E+02	NA
241-C-109	Sludge (Liquid & Solid)	CWP1 (Solid)	55	2.14E+02	3.48E+03	3.45E+03	8.78E+03	6.65E+03	6.87E+04	1.34E+01	2.92E+00	1.66E+01	4.40E-01	4.67E+04	NA
241-C-109	Sludge (Liquid & Solid)	HS (Solid)	26	1.01E+02	1.64E+03	1.63E+03	4.15E+03	3.14E+03	3.25E+04	6.36E+00	1.38E+00	7.83E+00	2.08E-01	2.21E+04	NA
241-C-109	Sludge (Liquid & Solid)	TFcCN (Solid)	121	4.71E+02	7.65E+03	7.60E+03	1.93E+04	1.46E+04	1.51E+05	2.96E+01	6.43E+00	3.65E+01	9.68E-01	1.03E+05	NA
241-C-109	Total			8.15E+02	1.96E+04	1.32E+04	3.76E+04	2.52E+04	2.53E+05	5.01E+01	1.12E+01	6.54E+01	1.65E+00	1.73E+05	NA
241-C-110	Sludge (Liquid & Solid)	1C (Solid)	670	4.10E+02	9.77E+04	6.51E+03	7.51E+04	1.31E+04	3.45E+03	3.86E+01	7.05E+00	6.48E+01	4.56E-01	1.35E+04	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-C-110	Supernatant	1C1 (Liquid)	4	2.32E+00	2.41E+02	1.84E+01	1.22E+02	8.34E-01	8.46E-02	7.58E-05	4.44E-04	6.59E-03	2.23E-05	1.50E+01	NA
241-C-110	Total			4.12E+02	9.80E+04	6.53E+03	7.53E+04	1.31E+04	3.45E+03	3.86E+01	7.05E+00	6.48E+01	4.56E-01	1.35E+04	NA
241-C-111	Sludge (Liquid & Solid)	1C (Solid)	49	3.69E+01	8.83E+03	6.80E+02	6.96E+03	1.04E+03	3.38E+02	9.68E-01	6.35E-01	5.84E+00	4.11E-02	1.11E+03	NA
241-C-111	Sludge (Liquid & Solid)	CWP1 (Solid)	60	7.91E+01	5.14E+02	7.03E+02	2.43E+03	1.08E+04	3.24E+05	2.14E+00	2.35E+01	1.13E+02	1.95E+00	6.66E+03	NA
241-C-111	Sludge (Liquid & Solid)	HS (Solid)	17	2.24E+01	1.32E+03	7.95E+02	6.88E+02	3.06E+03	9.17E+04	1.24E+00	6.68E+00	3.09E+01	9.83E-01	1.89E+03	NA
241-C-111	Sludge (Liquid & Solid)	TFeCN (Solid)	91	1.20E+02	9.87E+03	8.46E+03	3.68E+03	1.64E+04	4.91E+05	1.86E+02	2.24E+00	2.01E+01	1.47E-01	1.01E+04	NA
241-C-111	Total			2.58E+02	2.05E+04	1.06E+04	1.38E+04	3.13E+04	9.07E+05	1.90E+02	3.30E+01	1.70E+02	3.12E+00	1.98E+04	NA
241-C-112	Sludge (Liquid & Solid)	1C (Solid)	57	4.29E+01	1.03E+04	7.91E+02	8.09E+03	1.21E+03	3.93E+02	1.13E+00	7.39E-01	6.79E+00	4.78E-02	1.29E+03	NA
241-C-112	Sludge (Liquid & Solid)	CWP1 (Solid)	49	3.01E+02	4.63E+03	3.47E+03	6.25E+03	1.54E+03	7.50E+04	5.89E+01	2.04E+00	9.79E+00	9.77E-01	3.31E+04	NA
241-C-112	Sludge (Liquid & Solid)	CWP2 (Solid)	11	6.77E+01	1.04E+03	7.78E+02	1.40E+03	3.46E+02	1.68E+04	1.33E+01	5.07E-01	2.15E+00	2.19E-01	7.44E+03	NA
241-C-112	Sludge (Liquid & Solid)	HS (Solid)	4	2.46E+01	3.78E+02	2.83E+02	5.10E+02	1.26E+02	6.12E+03	4.81E+00	1.72E-01	7.94E-01	7.98E-02	2.71E+03	NA
241-C-112	Sludge (Liquid & Solid)	TFeCN (Solid)	272	1.67E+03	2.57E+04	1.92E+04	3.47E+04	8.55E+03	4.16E+05	3.26E+02	6.59E+00	5.91E+01	5.42E+00	1.84E+05	NA
241-C-112	Total			2.11E+03	4.20E+04	2.46E+04	5.09E+04	1.18E+04	5.15E+05	4.04E+02	1.00E+01	7.86E+01	6.75E+00	2.29E+05	NA
241-C-201	Sludge Solid	HS (Solid)	0.537	3.46E+01	1.35E+00	5.27E-01	4.91E+01	4.11E+00	2.52E+02	2.42E+00	3.40E+00	1.58E+01	5.01E-01	1.01E+01	NA
241-C-201	Supernatant	NA (Liquid)	0.007	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	NA
241-C-201	Total			3.46E+01	1.35E+00	5.27E-01	4.91E+01	4.11E+00	2.52E+02	2.42E+00	3.40E+00	1.58E+01	5.01E-01	1.01E+01	NA
241-C-202	Sludge (Liquid & Solid)	HS (Solid)	0.548	3.53E+01	1.25E+00	4.52E-01	4.58E+01	8.48E+00	4.87E+02	1.15E+00	3.08E+00	1.43E+01	4.54E-01	8.93E+00	NA
241-C-202	Supernatant	NA (Liquid)	0.009	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	NA
241-C-202	Total			3.53E+01	1.25E+00	4.52E-01	4.58E+01	8.48E+00	4.87E+02	1.15E+00	3.08E+00	1.43E+01	4.54E-01	8.93E+00	NA
241-C-203	Sludge (Liquid & Solid)	HS (Solid)	0.476	4.97E+00	3.76E+00	9.94E-01	5.59E+01	0.00E+00	2.36E+00	2.91E-02	1.05E-01	4.86E-01	1.55E-02	1.31E+01	NA
241-C-203	Supernatant	NA (Liquid)	0.048	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	NA
241-C-203	Total			4.97E+00	3.76E+00	9.94E-01	5.59E+01	0.00E+00	2.36E+00	2.91E-02	1.05E-01	4.86E-01	1.55E-02	1.31E+01	NA
241-C-204	Sludge (Liquid & Solid)	HS (Solid)	0.507	3.54E+01	2.22E-02	3.13E-02	3.33E+01	5.88E+00	1.52E+02	3.17E-03	2.12E-03	9.84E-03	3.13E-04	5.96E+00	NA
241-C-204	Supernatant	NA (Liquid)	0.011	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	NA
241-C-204	Total			3.54E+01	2.22E-02	3.13E-02	3.33E+01	5.88E+00	1.52E+02	3.17E-03	2.12E-03	9.84E-03	3.13E-04	5.96E+00	NA
241-S-101	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	16	2.86E+01	3.42E+03	1.80E+03	3.55E+03	4.79E+02	6.07E-01	1.33E-03	8.12E-05	3.73E-04	1.31E-05	4.36E+03	7.62E+02
241-S-101	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	11	1.97E+01	2.35E+03	1.24E+03	2.44E+03	3.29E+02	4.17E-01	9.16E-04	5.51E-05	2.57E-04	8.98E-06	3.00E+03	5.24E+02
241-S-101	Saltcake Solid	S1-SltCk (Solid)	246	1.52E+03	4.19E+04	2.28E+04	7.29E+04	8.85E+03	8.53E+04	3.49E+01	2.36E+00	1.08E+01	3.81E-01	5.71E+04	5.57E+03
241-S-101	Saltcake Solid	S2-SltSlr (Solid)	169	1.04E+03	2.88E+04	1.57E+04	5.00E+04	6.08E+03	5.86E+04	1.82E+01	2.61E+00	1.22E+01	4.24E-01	3.93E+04	NA
241-S-101	Sludge (Liquid & Solid)	NA (Sludge)	890	2.93E+03	2.35E+05	6.61E+04	1.99E+05	1.70E+05	3.09E+05	1.68E+02	5.82E+01	2.98E+02	5.91E+00	1.42E+05	NA
241-S-101	Total			5.54E+03	3.11E+05	1.08E+05	3.27E+05	1.86E+05	4.53E+05	2.21E+02	6.32E+01	3.21E+02	6.71E+00	2.45E+05	6.86E+03
241-S-102	Saltcake Solid	NA (SltCk)	55	3.63E+02	2.94E+04	3.16E+03	1.80E+04	1.13E+03	1.82E+03	1.00E+01	1.11E+00	5.12E+00	1.79E-01	9.29E+03	6.01E+02

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-S-102	Sludge (Liquid & Solid)	R1 (Solid)	71	1.06E+03	6.47E+03	4.76E+03	1.41E+04	2.51E+04	5.50E+04	4.17E+00	1.60E+00	8.25E+00	1.53E-01	8.47E+03	NA
241-S-102	Total			1.42E+03	3.59E+04	7.93E+03	3.22E+04	2.63E+04	5.68E+04	1.42E+01	2.71E+00	1.34E+01	3.32E-01	1.78E+04	6.01E+02
241-S-103	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	116	5.43E+02	2.51E+04	1.70E+04	2.64E+04	3.72E+03	4.29E+01	1.37E-01	1.44E-03	6.61E-03	2.33E-04	3.75E+04	4.23E+03
241-S-103	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	95	4.44E+02	2.05E+04	1.40E+04	2.17E+04	3.04E+03	3.51E+01	1.12E-01	1.16E-03	5.43E-03	1.90E-04	3.07E+04	3.46E+03
241-S-103	Saltcake Solid	S1-SltCk (Solid)	347	2.09E+03	1.79E+05	2.48E+04	1.25E+05	9.21E+03	1.01E+04	4.45E+01	3.01E+00	1.38E+01	4.86E-01	5.49E+04	1.03E+04
241-S-103	Saltcake Solid	S2-SltSlr (Solid)	300	2.58E+03	1.32E+05	2.47E+04	9.49E+04	9.29E+03	6.64E+03	7.53E+01	1.08E+01	5.04E+01	1.76E+00	6.71E+04	NA
241-S-103	Sludge (Liquid & Solid)	R1 (Solid)	34	6.32E+01	6.74E+03	1.90E+03	6.08E+03	1.13E+04	2.46E+04	1.51E+01	5.78E+00	2.98E+01	5.52E-01	3.80E+03	NA
241-S-103	Supernatant	S2-SltSlr (Liquid)	4	1.87E+01	8.64E+02	5.88E+02	9.12E+02	1.28E+02	1.48E+00	4.72E-03	4.90E-05	2.29E-04	7.98E-06	1.29E+03	1.46E+02
241-S-103	Total			5.74E+03	3.64E+05	8.30E+04	2.75E+05	3.66E+04	4.15E+04	1.35E+02	1.96E+01	9.40E+01	2.80E+00	1.95E+05	1.81E+04
241-S-104	Saltcake Interstitial Liquid	R-SltCk (Liquid)	139	5.51E+01	3.73E+04	5.31E+03	2.75E+04	1.66E+03	5.57E-01	1.04E-02	2.19E-03	1.03E-02	3.92E-04	8.77E+03	7.09E+02
241-S-104	Saltcake Solid	R-SltCk (Solid)	451	1.17E+03	1.47E+05	1.60E+04	8.80E+04	9.02E+04	1.84E+05	9.35E+01	3.81E+01	1.79E+02	6.83E+00	3.08E+04	NA
241-S-104	Sludge (Liquid & Solid)	CWR1 (Solid)	91	2.37E+02	3.74E+04	3.72E+03	2.01E+04	1.82E+04	3.72E+04	1.84E+01	5.66E+00	2.98E+01	4.64E-01	6.94E+03	NA
241-S-104	Sludge (Liquid & Solid)	R1 (Solid)	409	1.06E+03	1.68E+05	1.67E+04	9.05E+04	8.18E+04	1.67E+05	8.27E+01	2.59E+01	1.33E+02	2.48E+00	3.12E+04	NA
241-S-104	Total			2.53E+03	3.90E+05	4.18E+04	2.26E+05	1.92E+05	3.89E+05	1.95E+02	6.97E+01	3.43E+02	9.77E+00	7.77E+04	7.09E+02
241-S-105	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	157	6.33E+02	2.98E+04	1.92E+04	3.71E+04	5.93E+03	1.56E+02	4.42E-01	4.17E-03	1.92E-02	6.75E-04	5.58E+04	NA
241-S-105	Saltcake Solid	S1-SltCk (Solid)	1371	1.43E+03	1.35E+06	9.61E+03	5.94E+05	8.55E+03	5.59E+02	3.78E+00	4.82E-01	2.21E+00	7.78E-02	3.03E+04	NA
241-S-105	Sludge (Liquid & Solid)	R1 (Solid)	8	1.49E+01	1.59E+03	4.47E+02	1.43E+03	2.65E+03	5.80E+03	3.54E+00	1.36E+00	7.01E+00	1.30E-01	8.93E+02	NA
241-S-105	Total			2.08E+03	1.38E+06	2.92E+04	6.32E+05	1.71E+04	6.51E+03	7.77E+00	1.85E+00	9.24E+00	2.08E-01	8.70E+04	NA
241-S-106	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	99	1.96E+02	2.34E+04	1.03E+04	2.42E+04	3.76E+03	4.85E+00	5.42E-01	5.11E-03	2.34E-02	8.26E-04	2.30E+04	5.49E+03
241-S-106	Saltcake Solid	S1-SltCk (Solid)	1624	6.13E+03	9.61E+05	6.73E+04	5.76E+05	4.78E+04	3.64E+04	5.77E+01	3.90E+00	1.79E+01	6.30E-01	2.48E+05	NA
241-S-106	Total			6.33E+03	9.84E+05	7.75E+04	6.01E+05	5.15E+04	3.64E+04	5.82E+01	3.91E+00	1.79E+01	6.30E-01	2.71E+05	5.49E+03
241-S-107	Saltcake Solid	S1-SltCk (Solid)	63	5.97E+02	4.17E+03	1.94E+03	1.36E+04	2.04E+03	7.31E+03	9.72E+01	6.57E+00	3.01E+01	1.06E+00	4.27E+03	1.37E+03
241-S-107	Saltcake Solid	S2-SltSlr (Solid)	30	2.84E+02	1.99E+03	9.22E+02	6.47E+03	9.73E+02	3.48E+03	3.51E+01	5.04E+00	2.35E+01	8.20E-01	2.03E+03	NA
241-S-107	Saltcake Solid	T2-SltCk (Solid)	52	4.93E+02	3.44E+03	1.60E+03	1.12E+04	1.69E+03	6.04E+03	6.91E+01	7.19E+00	3.43E+01	1.21E+00	3.53E+03	NA
241-S-107	Sludge (Liquid & Solid)	CWR1 (Solid)	447	1.13E+03	4.83E+04	2.57E+04	7.05E+04	1.65E+05	1.09E+05	2.47E+02	7.29E+01	3.84E+02	5.97E+00	5.65E+04	NA
241-S-107	Sludge (Liquid & Solid)	CWR2 (Solid)	211	5.33E+02	2.28E+04	1.21E+04	3.33E+04	5.70E+04	5.14E+04	2.29E+01	5.57E+01	2.54E+02	6.33E+00	2.67E+04	NA
241-S-107	Sludge (Liquid & Solid)	CWZr1 (Solid)	91	2.30E+02	9.84E+03	5.23E+03	1.43E+04	0.00E+00	2.22E+04	5.87E+01	2.37E+01	6.12E+01	6.08E+00	1.15E+04	NA
241-S-107	Sludge (Liquid & Solid)	R1 (Solid)	462	1.17E+03	5.00E+04	2.65E+04	7.29E+04	1.35E+05	1.13E+05	2.16E+02	8.29E+01	4.27E+02	7.92E+00	5.84E+04	NA
241-S-107	Total			4.43E+03	1.41E+05	7.40E+04	2.22E+05	3.61E+05	3.12E+05	7.46E+02	2.54E+02	1.21E+03	2.94E+01	1.63E+05	1.37E+03
241-S-108	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	31	1.25E+02	5.89E+03	3.78E+03	7.32E+03	1.17E+03	3.09E+01	8.73E-02	8.24E-04	3.78E-03	1.33E-04	1.10E+04	1.49E+03
241-S-108	Saltcake Solid	S1-SltCk (Solid)	2032	1.23E+04	1.05E+06	1.45E+05	7.34E+05	5.39E+04	5.94E+04	2.61E+02	1.76E+01	8.09E+01	2.85E+00	3.22E+05	6.01E+04
241-S-108	Sludge (Liquid & Solid)	R1 (Solid)	19	3.53E+01	3.77E+03	1.06E+03	3.40E+03	6.29E+03	1.38E+04	8.42E+00	3.23E+00	1.66E+01	3.09E-01	2.12E+03	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-S-108	Total			1.24E+04	1.06E+06	1.50E+05	7.45E+05	6.14E+04	7.32E+04	2.69E+02	2.09E+01	9.75E+01	3.16E+00	3.35E+05	6.16E+04
241-S-109	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	63	7.02E+01	8.29E+03	5.35E+03	1.38E+04	2.89E+03	1.53E+01	1.69E-02	6.04E-04	2.77E-03	9.77E-05	1.79E+04	5.16E+03
241-S-109	Saltcake Solid	S1-SltCk (Solid)	1905	2.16E+03	1.70E+06	1.46E+04	7.48E+05	5.44E+03	1.40E+04	1.66E+01	1.12E+00	5.14E+00	1.81E-01	2.02E+04	2.99E+04
241-S-109	Sludge (Liquid & Solid)	R1 (Solid)	49	9.11E+01	9.71E+03	2.74E+03	8.76E+03	1.62E+04	3.55E+04	2.17E+01	8.33E+00	4.29E+01	7.96E-01	5.47E+03	NA
241-S-109	Total			2.32E+03	1.72E+06	2.27E+04	7.70E+05	2.45E+04	4.96E+04	3.83E+01	9.45E+00	4.81E+01	9.77E-01	4.36E+04	3.50E+04
241-S-110	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	115	2.62E+02	2.50E+04	9.87E+03	2.43E+04	3.56E+03	1.12E+02	8.28E-01	7.81E-03	3.58E-02	1.26E-03	4.02E+04	NA
241-S-110	Saltcake Solid	S1-SltCk (Solid)	994	4.99E+03	8.15E+05	2.65E+04	3.98E+05	1.28E+04	4.32E+04	1.63E+02	1.11E+01	5.07E+01	1.78E+00	8.91E+04	NA
241-S-110	Sludge (Liquid & Solid)	CWR1 (Solid)	76	4.92E+01	1.35E+04	3.71E+03	1.25E+04	2.26E+04	3.90E+04	3.28E+01	9.69E+00	5.10E+01	7.93E-01	1.02E+04	NA
241-S-110	Sludge (Liquid & Solid)	R1 (Solid)	288	1.86E+02	5.10E+04	1.40E+04	4.73E+04	8.57E+04	1.48E+05	1.05E+02	4.04E+01	2.08E+02	3.86E+00	3.86E+04	NA
241-S-110	Total			5.49E+03	9.05E+05	5.41E+04	4.82E+05	1.25E+05	2.30E+05	3.02E+02	6.11E+01	3.10E+02	6.43E+00	1.78E+05	NA
241-S-111	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	124	1.85E+02	2.39E+04	1.04E+04	2.76E+04	4.51E+03	1.40E+01	1.91E-02	3.18E-03	1.46E-02	5.13E-04	3.72E+04	6.32E+03
241-S-111	Saltcake Solid	S1-SltCk (Solid)	1028	3.51E+03	4.62E+05	4.60E+04	3.32E+05	3.04E+04	2.48E+05	2.89E+01	1.96E+00	8.97E+00	3.16E-01	1.54E+05	3.86E+04
241-S-111	Sludge (Liquid & Solid)	CWR1 (Solid)	38	5.81E+01	2.53E+03	1.56E+03	3.76E+03	1.37E+04	1.26E+02	5.55E-01	1.64E-01	8.62E-01	1.34E-02	4.72E+03	NA
241-S-111	Sludge (Liquid & Solid)	R1 (Solid)	207	3.17E+02	1.38E+04	8.48E+03	2.05E+04	7.45E+04	1.48E+05	2.56E+00	9.82E-01	5.06E+00	9.38E-02	2.57E+04	NA
241-S-111	Total			4.07E+03	5.03E+05	6.64E+04	3.84E+05	1.23E+05	3.95E+05	3.20E+01	3.10E+00	1.49E+01	4.23E-01	2.22E+05	4.50E+04
241-S-112	Saltcake Solid	S1-SltCk (Solid)	6.358	2.57E+02	0.00E+00	0.00E+00	8.23E+02	0.00E+00	7.63E+03	6.71E+00	4.53E-01	2.74E+00	6.98E-02	0.00E+00	0.00E+00
241-S-112	Sludge (Liquid & Solid)	R1 (Solid)	2.216	4.12E+00	4.39E+02	1.24E+02	3.96E+02	7.33E+02	1.61E+03	9.82E-01	3.77E-01	1.94E+00	3.60E-02	2.47E+02	NA
241-S-112	Supernatant	NA (liquid)	0.469	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	NA
241-S-112	Total			2.61E+02	4.39E+02	1.24E+02	1.22E+03	7.33E+02	9.24E+03	7.69E+00	8.30E-01	4.68E+00	1.06E-01	2.47E+02	0.00E+00
241-SX-101	Saltcake Interstitial Liquid	R-SltCk (Liquid)	41	1.37E+01	4.42E+03	3.07E+03	9.93E+03	3.28E+03	2.87E+00	2.24E-02	8.38E-04	3.94E-03	1.50E-04	1.45E+04	2.00E+03
241-SX-101	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	25	8.37E+00	2.70E+03	1.87E+03	6.06E+03	2.00E+03	1.75E+00	1.37E-02	5.21E-04	2.39E-03	8.43E-05	8.85E+03	1.22E+03
241-SX-101	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	14	4.69E+00	1.51E+03	1.05E+03	3.39E+03	1.12E+03	9.81E-01	7.67E-03	2.88E-04	1.34E-03	4.69E-05	4.96E+03	6.81E+02
241-SX-101	Saltcake Solid	R-SltCk (Solid)	497	1.69E+03	2.54E+05	1.95E+04	1.68E+05	5.13E+04	9.98E+04	1.84E+02	2.78E+01	1.31E+02	4.99E+00	7.89E+04	NA
241-SX-101	Saltcake Solid	S1-SltCk (Solid)	296	1.00E+03	1.51E+05	1.16E+04	1.00E+05	3.06E+04	5.94E+04	1.49E+02	1.00E+01	4.61E+01	1.62E+00	4.70E+04	NA
241-SX-101	Saltcake Solid	S2-SltSlr (Solid)	166	5.63E+02	8.47E+04	6.51E+03	5.61E+04	1.71E+04	3.33E+04	6.31E+01	9.05E+00	4.22E+01	1.47E+00	2.64E+04	NA
241-SX-101	Sludge (Liquid & Solid)	R1 (Solid)	545	1.85E+03	2.78E+05	2.14E+04	1.84E+05	5.63E+04	1.09E+05	1.13E+02	4.32E+01	2.23E+02	4.13E+00	8.66E+04	NA
241-SX-101	Total			5.13E+03	7.76E+05	6.50E+04	5.28E+05	1.62E+05	3.02E+05	5.08E+02	9.02E+01	4.42E+02	1.22E+01	2.67E+05	3.89E+03
241-SX-102	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	105	1.59E+02	1.65E+04	1.59E+04	2.47E+04	4.79E+03	2.18E+00	8.77E-01	8.28E-03	3.80E-02	1.34E-03	4.10E+04	5.26E+03
241-SX-102	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	11	1.66E+01	1.73E+03	1.66E+03	2.59E+03	5.02E+02	2.28E-01	9.18E-02	8.60E-04	4.01E-03	1.40E-04	4.29E+03	5.51E+02
241-SX-102	Saltcake Solid	S1-SltCk (Solid)	875	6.18E+03	3.50E+05	1.06E+05	2.81E+05	3.85E+04	1.34E+05	2.27E+02	1.53E+01	7.03E+01	2.47E+00	1.95E+05	2.84E+04
241-SX-102	Saltcake Solid	S2-SltSlr (Solid)	92	6.50E+02	3.68E+04	1.11E+04	2.95E+04	4.05E+03	1.41E+04	1.81E+01	2.59E+00	1.21E+01	4.21E-01	2.05E+04	2.99E+03
241-SX-102	Sludge (Liquid & Solid)	R1 (Solid)	209	1.48E+03	8.35E+04	2.53E+04	6.71E+04	9.19E+03	3.19E+04	2.23E+01	8.55E+00	4.41E+01	8.17E-01	4.65E+04	6.79E+03

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-SX-102	Total			8.48E+03	4.88E+05	1.60E+05	4.05E+05	5.70E+04	1.80E+05	2.68E+02	2.65E+01	1.27E+02	3.71E+00	3.07E+05	4.40E+04
241-SX-103	Saltcake Interstitial Liquid	R-SltCk (Liquid)	22	7.44E+01	3.45E+03	3.46E+03	5.28E+03	9.77E+02	1.81E+00	1.02E-02	3.79E-04	1.78E-03	6.78E-05	8.92E+03	9.94E+02
241-SX-103	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	94	3.18E+02	1.47E+04	1.48E+04	2.26E+04	4.17E+03	7.75E+00	4.37E-02	1.65E-03	7.58E-03	2.67E-04	3.81E+04	4.25E+03
241-SX-103	Saltcake Solid	R-SltCk (Solid)	77	7.26E+02	2.22E+04	9.34E+03	2.40E+04	5.57E+03	6.29E+04	5.42E+01	8.20E+00	3.86E+01	1.47E+00	2.07E+04	NA
241-SX-103	Saltcake Solid	S1-SltCk (Solid)	1439	9.91E+03	8.60E+05	1.30E+05	5.34E+05	3.96E+04	1.00E+05	5.98E+02	1.78E+01	8.18E+01	2.88E+00	2.99E+05	3.78E+04
241-SX-103	Sludge (Liquid & Solid)	R1 (Solid)	294	1.83E+03	8.90E+04	2.26E+04	5.67E+04	1.02E+05	3.50E+05	6.75E+01	2.59E+01	1.33E+02	2.48E+00	4.45E+04	NA
241-SX-103	Total			1.29E+04	9.89E+05	1.80E+05	6.42E+05	1.52E+05	5.13E+05	7.20E+02	5.20E+01	2.54E+02	6.82E+00	4.12E+05	4.30E+04
241-SX-104	Saltcake Interstitial Liquid	R-SltCk (Liquid)	17	3.61E+01	4.93E+03	1.99E+03	4.26E+03	6.04E+02	1.35E+00	4.82E-03	4.68E-04	2.20E-03	8.38E-05	3.90E+03	5.18E+02
241-SX-104	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	111	2.36E+02	3.22E+04	1.30E+04	2.78E+04	3.95E+03	8.79E+00	3.15E-02	3.12E-03	1.43E-02	5.04E-04	2.55E+04	3.38E+03
241-SX-104	Saltcake Solid	R-SltCk (Solid)	142	3.66E+02	1.08E+05	4.49E+03	5.47E+04	1.10E+04	5.68E+03	1.59E+01	2.41E+00	1.13E+01	4.32E-01	1.91E+04	NA
241-SX-104	Saltcake Solid	S1-SltCk (Solid)	903	5.45E+03	4.66E+05	6.45E+04	3.26E+05	2.40E+04	2.64E+04	1.16E+02	7.84E+00	3.60E+01	1.27E+00	1.43E+05	NA
241-SX-104	Sludge (Liquid & Solid)	R1 (Solid)	515	9.57E+02	1.02E+05	2.88E+04	9.21E+04	1.70E+05	3.73E+05	2.28E+02	8.76E+01	4.51E+02	8.37E+00	5.75E+04	NA
241-SX-104	Total			7.04E+03	7.13E+05	1.13E+05	5.05E+05	2.10E+05	4.05E+05	3.60E+02	9.78E+01	4.98E+02	1.01E+01	2.49E+05	3.90E+03
241-SX-105	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	123	4.01E+02	2.02E+04	1.76E+04	2.90E+04	5.42E+03	1.73E+01	6.12E-01	3.50E-03	1.61E-02	5.66E-04	4.17E+04	5.04E+03
241-SX-105	Saltcake Solid	S1-SltCk (Solid)	1061	5.57E+03	4.07E+05	1.21E+05	3.46E+05	3.88E+04	2.73E+04	1.06E+02	7.19E+00	3.30E+01	1.16E+00	1.48E+05	2.76E+04
241-SX-105	Sludge (Liquid & Solid)	R1 (Solid)	189	5.30E+02	4.48E+04	1.73E+04	4.20E+04	4.48E+04	1.29E+05	2.96E+02	1.14E+02	5.86E+02	1.09E+01	1.99E+04	NA
241-SX-105	Sludge (Liquid & Solid)	R2 (Solid)	49	1.37E+02	1.16E+04	4.48E+03	1.09E+04	1.16E+04	4.29E+05	1.93E+02	1.18E+01	5.04E+01	3.37E+00	9.87E+03	NA
241-SX-105	Total			6.64E+03	4.84E+05	1.60E+05	4.28E+05	1.01E+05	5.86E+05	5.96E+02	1.33E+02	6.69E+02	1.54E+01	2.19E+05	3.26E+04
241-SX-106	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	27	8.48E+01	6.61E+03	4.02E+03	5.87E+03	6.12E+02	8.06E+00	8.47E-03	2.44E-04	1.12E-03	3.94E-05	8.99E+03	8.63E+02
241-SX-106	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	122	3.83E+02	2.99E+04	1.82E+04	2.65E+04	2.76E+03	3.64E+01	3.83E-02	1.09E-03	5.07E-03	1.77E-04	4.06E+04	3.90E+03
241-SX-106	Saltcake Solid	S1-SltCk (Solid)	245	1.41E+03	9.35E+04	2.67E+04	7.46E+04	8.32E+03	6.00E+03	7.89E+01	5.34E+00	2.45E+01	8.62E-01	3.25E+04	6.07E+03
241-SX-106	Saltcake Solid	S2-SltSlr (Solid)	1107	6.36E+03	4.22E+05	1.20E+05	3.37E+05	3.76E+04	2.27E+04	2.70E+02	3.88E+01	1.81E+02	6.31E+00	2.29E+05	NA
241-SX-106	Total			8.24E+03	5.52E+05	1.69E+05	4.44E+05	4.93E+04	2.87E+04	3.49E+02	4.41E+01	2.05E+02	7.17E+00	3.11E+05	1.08E+04
241-SX-107	Sludge (Liquid & Solid)	R1 (Solid)	239	4.44E+02	4.74E+04	1.34E+04	4.27E+04	7.91E+04	1.73E+05	1.06E+02	4.06E+01	2.09E+02	3.88E+00	2.67E+04	NA
241-SX-107	Sludge (Liquid & Solid)	R2 (Solid)	117	2.17E+02	2.32E+04	6.54E+03	2.09E+04	3.87E+04	1.09E+06	4.53E+02	2.77E+01	1.18E+02	7.89E+00	2.50E+04	NA
241-SX-107	Total			6.62E+02	7.06E+04	1.99E+04	6.36E+04	1.18E+05	1.26E+06	5.59E+02	6.83E+01	3.27E+02	1.18E+01	5.17E+04	NA
241-SX-108	Sludge Solid	R1 (Solid)	186	2.10E+02	1.22E+05	5.15E+03	6.07E+04	4.67E+04	8.47E+05	3.19E+02	1.22E+02	6.30E+02	1.17E+01	5.43E+04	NA
241-SX-108	Sludge Solid	R2 (Solid)	94	1.06E+02	6.19E+04	2.60E+03	3.07E+04	2.36E+04	4.28E+05	4.05E+02	2.47E+01	1.06E+02	7.05E+00	2.74E+04	NA
241-SX-108	Total			3.16E+02	1.84E+05	7.76E+03	9.14E+04	7.04E+04	1.27E+06	7.23E+02	1.47E+02	7.36E+02	1.87E+01	8.17E+04	NA
241-SX-109	Saltcake Solid	R-SltCk (Solid)	662	1.71E+03	5.02E+05	2.10E+04	2.55E+05	5.14E+04	2.65E+04	7.43E+01	1.12E+01	5.28E+01	2.01E+00	8.89E+04	NA
241-SX-109	Sludge Solid	R1 (Solid)	170	3.16E+02	3.37E+04	9.51E+03	3.04E+04	5.63E+04	1.23E+05	7.53E+01	2.89E+01	1.49E+02	2.76E+00	1.90E+04	NA
241-SX-109	Sludge Solid	R2 (Solid)	81	1.51E+02	1.61E+04	4.53E+03	1.45E+04	2.68E+04	7.52E+05	3.13E+02	1.92E+01	8.18E+01	5.46E+00	1.73E+04	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-SX-109	Total			2.17E+03	5.52E+05	3.50E+04	3.00E+05	1.34E+05	9.01E+05	4.63E+02	5.93E+01	2.84E+02	1.02E+01	1.25E+05	NA
241-SX-110	Saltcake Solid	R-SltCk (Solid)	28	7.22E+01	2.12E+04	8.86E+02	1.08E+04	2.17E+03	1.12E+03	3.14E+00	4.75E-01	2.23E+00	8.51E-02	3.76E+03	NA
241-SX-110	Sludge Solid	R2 (Solid)	184	3.42E+02	3.65E+04	1.03E+04	3.29E+04	6.09E+04	1.71E+06	7.12E+02	4.35E+01	1.86E+02	1.24E+01	3.93E+04	NA
241-SX-110	Total			4.14E+02	5.77E+04	1.12E+04	4.37E+04	6.31E+04	1.71E+06	7.15E+02	4.40E+01	1.88E+02	1.25E+01	4.30E+04	NA
241-SX-111	Saltcake Solid	R-SltCk (Solid)	67	1.73E+02	5.08E+04	2.12E+03	2.58E+04	5.20E+03	2.68E+03	7.52E+00	1.14E+00	5.35E+00	2.04E-01	9.00E+03	NA
241-SX-111	Sludge (Liquid & Solid)	R1 (Solid)	164	3.05E+02	3.25E+04	9.17E+03	2.93E+04	5.43E+04	1.19E+05	7.27E+01	2.79E+01	1.44E+02	2.66E+00	1.83E+04	NA
241-SX-111	Sludge (Liquid & Solid)	R2 (Solid)	205	3.81E+02	4.06E+04	1.15E+04	3.66E+04	6.79E+04	1.90E+06	7.93E+02	4.85E+01	2.07E+02	1.38E+01	4.38E+04	NA
241-SX-111	Total			8.59E+02	1.24E+05	2.28E+04	9.18E+04	1.27E+05	2.02E+06	8.74E+02	7.75E+01	3.56E+02	1.67E+01	7.11E+04	NA
241-SX-112	Sludge (Liquid & Solid)	R1 (Solid)	144	2.68E+02	2.85E+04	8.05E+03	2.57E+04	4.77E+04	1.04E+05	6.38E+01	2.45E+01	1.26E+02	2.34E+00	1.61E+04	NA
241-SX-112	Sludge (Liquid & Solid)	R2 (Solid)	139	2.58E+02	2.76E+04	7.77E+03	2.48E+04	4.60E+04	1.29E+06	5.38E+02	3.29E+01	1.40E+02	9.37E+00	2.97E+04	NA
241-SX-112	Total			5.26E+02	5.61E+04	1.58E+04	5.06E+04	9.37E+04	1.39E+06	6.02E+02	5.74E+01	2.66E+02	1.17E+01	4.58E+04	NA
241-SX-113	Sludge Solid	DE (Solid)	64	0.00E+00	7.17E+03	1.81E+03	8.45E+01	1.05E+03	2.52E+03	9.98E+00	8.67E-01	4.47E+00	8.29E-02	1.85E+03	NA
241-SX-113	Sludge Solid	R1 (Solid)	8	1.49E+01	1.59E+03	4.47E+02	1.06E+01	1.31E+02	3.15E+02	1.25E+00	1.08E-01	5.59E-01	1.04E-02	2.31E+02	NA
241-SX-113	Total			1.49E+01	8.75E+03	2.26E+03	9.51E+01	1.18E+03	2.84E+03	1.12E+01	9.76E-01	5.03E+00	9.32E-02	2.08E+03	NA
241-SX-114	Saltcake Interstitial Liquid	R-SltCk (Liquid)	26	2.63E+01	5.64E+03	2.57E+03	6.53E+03	1.23E+03	6.00E+01	1.75E-01	2.81E-02	1.32E-01	5.03E-03	7.25E+03	NA
241-SX-114	Saltcake Solid	R-SltCk (Solid)	84	2.17E+02	6.37E+04	2.66E+03	3.24E+04	6.52E+03	3.36E+03	9.43E+00	1.43E+00	6.70E+00	2.55E-01	1.13E+04	NA
241-SX-114	Sludge (Liquid & Solid)	R1 (Solid)	298	5.54E+02	5.91E+04	1.67E+04	5.33E+04	9.86E+04	2.16E+05	1.32E+02	5.07E+01	2.61E+02	4.84E+00	3.33E+04	NA
241-SX-114	Sludge (Liquid & Solid)	R2 (Solid)	180	3.35E+02	3.57E+04	1.01E+04	3.22E+04	5.96E+04	1.67E+06	6.97E+02	4.26E+01	1.82E+02	1.21E+01	3.84E+04	NA
241-SX-114	Total			1.13E+03	1.64E+05	3.20E+04	1.24E+05	1.66E+05	1.89E+06	8.38E+02	9.47E+01	4.50E+02	1.72E+01	9.02E+04	NA
241-SX-115	Sludge Solid	R2 (Solid)	16	3.17E+01	3.69E+03	5.89E+01	7.06E+02	6.16E+03	3.83E+05	4.02E+02	1.07E+02	4.55E+02	3.04E+01	5.81E+02	NA
241-SX-115	Total			3.17E+01	3.69E+03	5.89E+01	7.06E+02	6.16E+03	3.83E+05	4.02E+02	1.07E+02	4.55E+02	3.04E+01	5.81E+02	NA
241-SY-101	Saltcake (Liquid & Solid)	S2-SltSlr (Solid)	893	2.50E+04	9.76E+04	6.73E+04	1.97E+05	7.26E+04	5.22E+04	4.13E+02	7.74E+00	3.61E+01	1.26E+00	1.80E+05	NA
241-SY-101	Supernatant	NA (Liquid)	3200	2.94E+03	2.05E+05	3.04E+04	1.88E+05	1.16E+04	3.51E+03	1.54E+01	1.71E+00	7.99E+00	2.84E-01	8.49E+04	3.89E+04
241-SY-101	Total			2.79E+04	3.02E+05	9.77E+04	3.85E+05	8.42E+04	5.57E+04	4.29E+02	9.45E+00	4.41E+01	1.54E+00	2.65E+05	3.89E+04
241-SY-102	Sludge Interstitial Liquid	NA (Liquid)	151	4.59E+02	1.86E+04	7.08E+03	1.87E+04	1.15E+03	2.26E+02	1.98E+00	2.86E-02	1.34E-01	4.67E-03	1.82E+04	3.06E+03
241-SY-102	Sludge Interstitial Liquid	Z (Liquid)	82	3.81E+02	1.10E+04	5.99E+03	1.25E+04	6.22E+02	1.22E+02	1.08E+00	1.56E-02	7.25E-02	2.53E-03	1.53E+04	1.75E+03
241-SY-102	Sludge Solid	NA (Sludge)	336	1.38E+04	3.29E+04	2.16E+04	7.03E+04	3.77E+04	1.73E+05	1.09E+04	5.67E+02	2.65E+03	9.18E+01	5.78E+04	7.12E+03
241-SY-102	Sludge Solid	Z (Solid)	183	6.69E+03	2.33E+04	1.04E+04	3.34E+04	8.73E+03	3.00E+04	9.78E+03	5.58E+02	2.23E+03	1.39E+02	3.15E+04	NA
241-SY-102	Supernatant	NA (Liquid)	1039	1.01E+03	5.67E+04	9.93E+03	5.67E+04	3.78E+03	2.04E+01	2.81E-02	6.17E-03	2.88E-02	4.89E-03	2.86E+04	1.21E+04
241-SY-102	Total			2.24E+04	1.42E+05	5.51E+04	1.92E+05	5.20E+04	2.03E+05	2.07E+04	1.12E+03	4.89E+03	2.31E+02	1.51E+05	2.40E+04
241-SY-103	Saltcake (Liquid & Solid)	S2-SltSlr (Solid)	1203	1.71E+04	2.48E+05	1.63E+05	3.76E+05	7.09E+04	6.36E+04	1.23E+03	2.44E+01	1.14E+02	3.97E+00	4.26E+05	2.96E+04
241-SY-103	Supernatant	S2-SltSlr (Liquid)	1503	9.35E+03	2.52E+05	2.29E+05	3.23E+05	5.65E+04	4.53E+03	1.53E+01	1.76E-02	8.20E-02	2.87E-03	6.45E+05	4.49E+04

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-SY-103	Total			2.64E+04	5.00E+05	3.92E+05	6.98E+05	1.27E+05	6.81E+04	1.25E+03	2.44E+01	1.14E+02	3.97E+00	1.07E+06	7.45E+04
241-T-101	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	57	2.30E+02	1.08E+04	6.95E+03	1.35E+04	2.15E+03	5.67E+01	1.61E-01	1.47E-03	7.01E-03	2.48E-04	2.03E+04	2.74E+03
241-T-101	Saltcake Solid	T2-SltCk (Solid)	179	1.08E+03	1.04E+05	7.22E+03	5.75E+04	5.55E+03	2.18E+02	4.99E+01	5.19E+00	2.47E+01	8.72E-01	1.88E+04	NA
241-T-101	Sludge (Liquid & Solid)	CWR2 (Solid)	140	0.00E+00	5.74E+03	1.41E+03	4.42E+03	2.21E+04	1.10E+02	1.65E+01	4.03E+01	1.83E+02	4.57E+00	1.28E+02	NA
241-T-101	Total			1.31E+03	1.20E+05	1.56E+04	7.54E+04	2.98E+04	3.85E+02	6.65E+01	4.54E+01	2.08E+02	5.44E+00	3.92E+04	2.74E+03
241-T-102	Sludge (Liquid & Solid)	CWP2 (Solid)	64	5.46E+01	2.92E+03	6.67E+02	2.52E+03	2.39E+04	1.55E+04	2.12E+01	8.81E-01	3.73E+00	8.80E-02	2.09E+03	NA
241-T-102	Sludge (Liquid & Solid)	MW2 (Solid)	8	0.00E+00	6.99E+00	5.82E+00	1.21E+03	0.00E+00	1.12E+03	5.47E-03	1.06E-02	8.38E-02	7.26E-04	2.86E+01	NA
241-T-102	Supernatant	CSR (Liquid)	48	2.16E+01	5.23E+03	1.10E+03	3.10E+03	4.06E+02	4.68E+01	2.05E-01	5.68E-02	2.45E-01	1.03E-02	2.47E+03	3.00E+00
241-T-102	Total			7.62E+01	8.16E+03	1.78E+03	6.83E+03	2.44E+04	1.66E+04	2.14E+01	9.48E-01	4.06E+00	9.90E-02	4.59E+03	3.00E+00
241-T-103	Sludge (Liquid & Solid)	CWP2 (Solid)	64	5.13E+01	2.47E+03	7.85E+02	3.02E+03	1.78E+04	3.53E+01	4.17E-01	8.28E-01	3.50E+00	8.27E-02	4.15E+01	NA
241-T-103	Sludge (Liquid & Solid)	CWR1 (Solid)	19	2.18E+01	8.38E+02	3.66E+02	1.32E+03	7.90E+03	6.36E+01	6.67E-02	1.97E-02	1.04E-01	1.61E-03	1.34E+02	NA
241-T-103	Sludge (Liquid & Solid)	MW2 (Solid)	4	0.00E+00	3.49E+00	2.91E+00	6.06E+02	0.00E+00	5.62E+02	2.73E-03	5.31E-03	4.19E-02	3.63E-04	1.43E+01	NA
241-T-103	Supernatant	CSR (Liquid)	15	8.33E+01	1.17E+03	5.94E+02	1.43E+03	1.56E+02	3.46E+01	1.53E-01	2.65E-02	1.14E-01	4.78E-03	2.10E+02	NA
241-T-103	Total			1.56E+02	4.48E+03	1.75E+03	6.38E+03	2.59E+04	6.95E+02	6.39E-01	8.79E-01	3.76E+00	8.95E-02	4.00E+02	NA
241-T-104	Sludge (Liquid & Solid)	1C (Solid)	1199	5.23E+02	8.97E+04	6.55E+03	9.98E+04	2.51E+04	3.14E+03	2.80E+01	2.33E+01	1.93E+02	2.51E+00	2.40E+02	NA
241-T-104	Total			5.23E+02	8.97E+04	6.55E+03	9.98E+04	2.51E+04	3.14E+03	2.80E+01	2.33E+01	1.93E+02	2.51E+00	2.40E+02	NA
241-T-105	Sludge (Liquid & Solid)	1C (Solid)	6	3.64E+01	1.80E+02	2.56E+02	4.16E+02	9.29E+02	1.72E+03	1.91E+00	1.20E-01	9.74E-01	6.85E-03	3.06E+02	NA
241-T-105	Sludge (Liquid & Solid)	2C (Solid)	273	7.09E+02	9.52E+03	1.34E+04	3.27E+04	9.17E+03	9.69E-01	2.73E-01	1.39E+01	1.34E+02	8.87E-01	1.13E+00	NA
241-T-105	Sludge (Liquid & Solid)	CWR1 (Solid)	92	5.58E+02	2.76E+03	3.92E+03	6.38E+03	1.42E+04	2.64E+04	2.93E+01	1.84E+00	1.49E+01	2.32E-01	4.69E+03	NA
241-T-105	Total			1.30E+03	1.25E+04	1.76E+04	3.95E+04	2.43E+04	2.81E+04	3.15E+01	1.59E+01	1.50E+02	1.13E+00	5.00E+03	NA
241-T-106	Sludge (Liquid & Solid)	1C (Solid)	38	5.77E+01	1.38E+04	1.06E+03	1.09E+04	1.63E+03	5.28E+02	1.57E+00	1.03E+00	9.45E+00	6.65E-02	1.74E+03	NA
241-T-106	Sludge (Liquid & Solid)	CWR1 (Solid)	34	3.81E+01	1.46E+03	6.38E+02	2.30E+03	1.38E+04	1.11E+02	3.80E+00	1.12E+00	5.90E+00	9.19E-02	2.34E+02	NA
241-T-106	Sludge (Liquid & Solid)	CWR2 (Solid)	10	0.00E+00	7.72E+02	1.90E+02	5.94E+02	2.97E+03	1.47E+01	1.86E-01	4.54E-01	2.07E+00	5.16E-02	1.72E+01	NA
241-T-106	Total			9.57E+01	1.61E+04	1.89E+03	1.38E+04	1.84E+04	6.54E+02	5.55E+00	2.60E+00	1.74E+01	2.10E-01	1.99E+03	NA
241-T-107	Sludge (Liquid & Solid)	1C (Solid)	559	7.53E+02	6.15E+04	9.65E+03	8.06E+04	3.27E+04	8.77E+04	4.53E+01	2.97E+01	2.73E+02	1.92E+00	1.28E+04	NA
241-T-107	Sludge (Liquid & Solid)	CWP2 (Solid)	32	4.31E+01	3.52E+03	5.52E+02	4.61E+03	1.87E+03	5.02E+03	1.68E+00	3.33E+00	1.41E+01	3.33E-01	7.35E+02	NA
241-T-107	Sludge (Liquid & Solid)	TBP (Solid)	64	8.62E+01	7.04E+03	1.10E+03	9.23E+03	3.74E+03	1.00E+04	1.32E+01	2.57E+00	2.40E+01	1.67E-01	1.47E+03	NA
241-T-107	Total			8.82E+02	7.21E+04	1.13E+04	9.45E+04	3.83E+04	1.03E+05	6.01E+01	3.56E+01	3.11E+02	2.42E+00	1.51E+04	NA
241-T-108	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	10	3.38E-02	2.17E+03	8.50E+01	1.13E+03	3.61E+00	2.12E+01	1.55E-02	5.91E-03	5.22E-02	3.88E-04	8.92E+01	NA
241-T-108	Saltcake Solid	T1-SltCk (Solid)	30	4.54E-02	2.02E+04	3.19E+02	1.15E+04	1.18E+02	5.15E+00	2.13E-02	3.61E-01	3.18E+00	2.37E-02	8.50E+01	NA
241-T-108	Sludge (Liquid & Solid)	1C (Solid)	20	1.50E+01	3.60E+03	2.78E+02	2.84E+03	4.26E+02	1.38E+02	3.95E-01	2.59E-01	2.38E+00	1.68E-02	4.54E+02	NA
241-T-108	Total			1.51E+01	2.60E+04	6.82E+02	1.55E+04	5.48E+02	1.64E+02	4.32E-01	6.26E-01	5.62E+00	4.08E-02	6.28E+02	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-T-109	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	38	1.28E-01	8.25E+03	3.23E+02	4.29E+03	1.37E+01	8.06E+01	5.88E-02	2.25E-02	1.98E-01	1.47E-03	3.39E+02	NA
241-T-109	Saltcake Solid	T1-SltCk (Solid)	197	1.83E-01	5.08E+03	1.67E+02	6.31E+04	4.06E+02	2.07E+01	2.23E-02	3.78E-01	3.33E+00	2.48E-02	4.84E+02	NA
241-T-109	Total			3.11E-01	1.33E+04	4.90E+02	6.74E+04	4.20E+02	1.01E+02	8.11E-02	4.00E-01	3.53E+00	2.63E-02	8.24E+02	NA
241-T-110	Sludge (Liquid & Solid)	224-2 (Solid)	37	1.37E+01	2.72E+03	2.41E+01	1.53E+03	2.89E+00	1.26E+00	2.29E-01	3.21E-01	2.55E+00	2.20E-02	6.88E-01	NA
241-T-110	Sludge (Liquid & Solid)	2C (Solid)	1360	1.54E+03	1.02E+05	2.61E+04	9.10E+04	2.47E+03	4.64E+01	8.40E+00	9.95E+00	9.54E+01	6.33E-01	2.53E+01	NA
241-T-110	Supernatant	2C1 (Liquid)	3	1.35E-01	5.49E+01	1.77E-01	1.11E+02	0.00E+00	1.35E-03	9.00E-06	3.14E-05	4.66E-04	5.97E-06	8.79E-03	NA
241-T-110	Total			1.56E+03	1.05E+05	2.61E+04	9.26E+04	2.48E+03	4.76E+01	8.63E+00	1.03E+01	9.79E+01	6.55E-01	2.60E+01	NA
241-T-111	Sludge (Liquid & Solid)	224-2 (Solid)	904	3.88E+03	6.50E+04	8.40E+02	3.61E+04	3.93E+02	4.57E+03	5.28E+01	1.74E+01	1.38E+02	1.19E+00	1.14E+02	NA
241-T-111	Sludge (Liquid & Solid)	2C (Solid)	787	3.38E+03	5.66E+04	7.31E+02	3.15E+04	3.42E+02	3.98E+03	4.57E+01	1.28E+01	1.23E+02	1.08E-01	9.93E+01	NA
241-T-111	Total			7.26E+03	1.22E+05	1.57E+03	6.76E+04	7.36E+02	8.56E+03	9.85E+01	3.02E+01	2.61E+02	1.30E+00	2.13E+02	NA
241-T-112	Sludge (Liquid & Solid)	224-2 (Solid)	91	3.66E+01	2.02E+03	3.27E+03	7.83E+03	5.96E+02	3.50E-01	4.32E+00	2.83E+00	2.24E+01	1.94E-01	8.50E-01	NA
241-T-112	Sludge (Liquid & Solid)	2C (Solid)	135	1.67E+02	3.00E+03	4.85E+03	1.16E+04	8.84E+02	2.28E-01	8.08E-02	4.13E+00	3.96E+01	2.63E-01	2.65E-01	NA
241-T-112	Supernatant	CSR (Liquid)	13	4.19E+01	3.03E+02	5.05E+02	7.44E+02	1.31E-01	1.74E+01	1.47E-01	2.55E-02	1.10E-01	4.60E-03	1.06E+02	NA
241-T-112	Supernatant	DW (Liquid)	13	0.00E+00	3.03E+02	5.05E+02	7.44E+02	0.00E+00	0.00E+00	1.47E-01	2.55E-02	1.10E-01	4.60E-03	0.00E+00	NA
241-T-112	Total			2.45E+02	5.62E+03	9.13E+03	2.09E+04	1.48E+03	1.80E+01	4.70E+00	7.01E+00	6.23E+01	4.66E-01	1.07E+02	NA
241-T-201	Sludge (Liquid & Solid)	224-1 (Solid)	107	3.95E+01	6.13E+03	5.63E+01	3.88E+03	1.15E+01	9.44E+00	5.56E+00	6.34E+00	9.40E+01	3.18E-01	3.10E+00	NA
241-T-201	Supernatant	224-1 (Liquid)	8	6.22E-01	3.69E+02	2.68E+00	2.01E+02	0.00E+00	3.00E-04	4.72E-07	1.42E-05	2.11E-04	7.13E-07	3.45E-04	NA
241-T-201	Total			4.01E+01	6.50E+03	5.90E+01	4.08E+03	1.15E+01	9.44E+00	5.56E+00	6.34E+00	9.40E+01	3.18E-01	3.10E+00	NA
241-T-202	Sludge (Liquid & Solid)	224-2 (Solid)	77	3.31E+01	5.60E+03	5.81E+01	3.14E+03	6.67E+00	2.03E-01	2.93E+00	1.92E+00	1.52E+01	1.32E-01	6.15E-01	NA
241-T-202	Total			3.31E+01	5.60E+03	5.81E+01	3.14E+03	6.67E+00	2.03E-01	2.93E+00	1.92E+00	1.52E+01	1.32E-01	6.15E-01	NA
241-T-203	Sludge (Liquid & Solid)	224-2 (Solid)	136	7.03E+01	9.73E+03	5.54E+01	5.73E+03	9.41E+00	3.67E-01	6.22E+00	4.67E+00	3.71E+01	3.20E-01	1.10E+00	NA
241-T-203	Total			7.03E+01	9.73E+03	5.54E+01	5.73E+03	9.41E+00	3.67E-01	6.22E+00	4.67E+00	3.71E+01	3.20E-01	1.10E+00	NA
241-T-204	Sludge (Liquid & Solid)	224-2 (Solid)	136	5.97E+01	9.08E+03	4.67E+01	5.23E+03	8.82E+00	6.47E-01	3.64E+00	3.84E+00	3.05E+01	2.63E-01	1.10E+00	NA
241-T-204	Total			5.97E+01	9.08E+03	4.67E+01	5.23E+03	8.82E+00	6.47E-01	3.64E+00	3.84E+00	3.05E+01	2.63E-01	1.10E+00	NA
241-TX-101	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	15	6.05E+01	2.85E+03	1.83E+03	3.54E+03	5.67E+02	1.49E+01	4.23E-02	3.87E-04	1.84E-03	6.52E-05	5.33E+03	NA
241-TX-101	Saltcake Solid	T2-SltCk (Solid)	49	2.97E+02	2.84E+04	1.98E+03	1.58E+04	1.52E+03	5.98E+01	1.36E+01	1.42E+00	6.77E+00	2.39E-01	5.16E+03	NA
241-TX-101	Sludge (Liquid & Solid)	MW2 (Solid)	11	0.00E+00	9.61E+00	8.00E+00	1.67E+03	0.00E+00	1.54E+03	7.52E-03	1.46E-02	1.15E-01	9.98E-04	3.93E+01	NA
241-TX-101	Sludge (Liquid & Solid)	R1 (Solid)	265	4.93E+02	5.25E+04	1.48E+04	4.74E+04	8.77E+04	1.92E+05	1.17E+02	4.51E+01	2.32E+02	4.31E+00	2.96E+04	NA
241-TX-101	Sludge (Liquid & Solid)	Z (Solid)	4	0.00E+00	3.38E+02	1.37E+00	1.72E+02	1.19E+03	0.00E+00	1.21E+02	2.86E+01	1.14E+02	7.15E+00	0.00E+00	NA
241-TX-101	Total			8.49E+02	8.41E+04	1.86E+04	6.85E+04	9.10E+04	1.94E+05	2.52E+02	7.51E+01	3.53E+02	1.17E+01	4.01E+04	NA
241-TX-102	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	121	4.88E+02	2.30E+04	1.48E+04	2.86E+04	4.57E+03	1.20E+02	3.41E-01	3.12E-03	1.49E-02	5.26E-04	4.30E+04	NA
241-TX-102	Saltcake Solid	T2-SltCk (Solid)	692	4.19E+03	4.01E+05	2.79E+04	2.22E+05	2.14E+04	8.45E+02	1.92E+02	2.01E+01	9.57E+01	3.37E+00	7.29E+04	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-TX-102	Sludge (Liquid & Solid)	MW2 (Solid)	8	0.00E+00	6.99E+00	5.82E+00	1.21E+03	0.00E+00	1.12E+03	5.36E-03	1.06E-02	8.38E-02	7.26E-04	2.86E+01	NA
241-TX-102	Total			4.68E+03	4.24E+05	4.27E+04	2.52E+05	2.60E+04	2.09E+03	1.92E+02	2.01E+01	9.58E+01	3.37E+00	1.16E+05	NA
241-TX-103	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	3	1.01E-02	6.51E+02	2.55E+01	3.39E+02	1.08E+00	6.36E+00	4.64E-03	1.77E-03	1.57E-02	1.16E-04	2.68E+01	NA
241-TX-103	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	82	3.30E+02	1.56E+04	1.00E+04	1.94E+04	3.10E+03	8.16E+01	2.31E-01	2.11E-03	1.01E-02	3.56E-04	2.92E+04	NA
241-TX-103	Saltcake Solid	T1-SltCk (Solid)	9	1.23E-02	5.02E+03	3.08E+01	3.39E+03	2.83E+01	1.39E+00	3.70E-03	6.27E-02	5.53E-01	4.11E-03	3.25E+01	NA
241-TX-103	Saltcake Solid	T2-SltCk (Solid)	454	2.75E+03	2.63E+05	1.83E+04	1.46E+05	1.41E+04	5.54E+02	1.26E+02	1.32E+01	6.28E+01	2.21E+00	4.78E+04	NA
241-TX-103	Total			3.08E+03	2.84E+05	2.84E+04	1.69E+05	1.72E+04	6.44E+02	1.27E+02	1.32E+01	6.33E+01	2.22E+00	7.70E+04	NA
241-TX-104	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	30	4.07E+01	1.06E+04	2.83E+03	6.15E+03	9.57E+01	2.80E+01	3.82E-01	3.50E-03	1.67E-02	5.89E-04	1.00E+04	NA
241-TX-104	Saltcake Solid	T2-SltCk (Solid)	93	3.38E+02	4.42E+04	4.80E+03	2.36E+04	2.92E+03	8.57E+01	6.18E+01	6.43E+00	3.07E+01	1.08E+00	7.39E+03	NA
241-TX-104	Sludge (Liquid & Solid)	R1 (Solid)	130	1.77E+02	4.92E+04	3.05E+03	2.07E+04	3.84E+04	7.21E+04	8.11E+00	3.11E+00	1.60E+01	2.97E-01	1.11E+04	NA
241-TX-104	Supernatant	T2-SltCk (Liquid)	9	1.22E+01	3.19E+03	8.48E+02	1.85E+03	2.87E+01	8.40E+00	1.15E-01	1.05E-03	5.00E-03	1.77E-04	3.00E+03	NA
241-TX-104	Total			5.68E+02	1.07E+05	1.15E+04	5.22E+04	4.15E+04	7.22E+04	7.04E+01	9.55E+00	4.67E+01	1.38E+00	3.15E+04	NA
241-TX-105	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	106	4.27E+02	2.01E+04	1.29E+04	2.50E+04	4.01E+03	1.06E+02	2.99E-01	2.73E-03	1.30E-02	4.61E-04	3.77E+04	NA
241-TX-105	Saltcake Solid	T2-SltCk (Solid)	2044	1.24E+04	1.18E+06	8.25E+04	6.57E+05	6.34E+04	2.49E+03	5.69E+02	5.93E+01	2.83E+02	9.95E+00	2.15E+05	NA
241-TX-105	Sludge (Liquid & Solid)	MW2 (Solid)	31	0.00E+00	2.71E+01	2.25E+01	4.70E+03	0.00E+00	4.35E+03	2.12E-02	4.12E-02	3.25E-01	2.81E-03	1.11E+02	NA
241-TX-105	Total			1.28E+04	1.20E+06	9.54E+04	6.87E+05	6.74E+04	6.95E+03	5.70E+02	5.94E+01	2.83E+02	9.96E+00	2.53E+05	NA
241-TX-106	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	152	6.13E+02	2.89E+04	1.85E+04	3.59E+04	5.75E+03	1.51E+02	4.28E-01	3.92E-03	1.87E-02	6.61E-04	5.40E+04	NA
241-TX-106	Saltcake Solid	T2-SltCk (Solid)	1147	6.94E+03	6.64E+05	4.63E+04	3.69E+05	3.56E+04	1.40E+03	3.19E+02	3.33E+01	1.59E+02	5.58E+00	1.21E+05	NA
241-TX-106	Sludge (Liquid & Solid)	MW2 (Solid)	4	0.00E+00	3.49E+00	2.91E+00	6.06E+02	0.00E+00	5.62E+02	2.73E-03	5.31E-03	4.19E-02	3.63E-04	1.43E+01	NA
241-TX-106	Sludge (Liquid & Solid)	R1 (Solid)	15	2.79E+01	2.97E+03	8.39E+02	2.68E+03	4.96E+03	1.09E+04	6.65E+00	2.55E+00	1.31E+01	2.44E-01	1.67E+03	NA
241-TX-106	Total			7.58E+03	6.96E+05	6.57E+04	4.08E+05	4.63E+04	1.30E+04	3.27E+02	3.58E+01	1.72E+02	5.83E+00	1.77E+05	NA
241-TX-107	Saltcake Interstitial Liquid	R-SltCk (Liquid)	7	7.07E+00	1.52E+03	6.92E+02	1.76E+03	3.30E+02	1.61E+01	4.71E-02	7.56E-03	3.56E-02	1.35E-03	1.95E+03	NA
241-TX-107	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	19	7.66E+01	3.61E+03	2.32E+03	4.48E+03	7.18E+02	1.89E+01	5.35E-02	4.90E-04	2.34E-03	8.26E-05	6.76E+03	NA
241-TX-107	Saltcake Solid	R-SltCk (Solid)	24	6.19E+01	1.82E+04	7.60E+02	9.25E+03	1.86E+03	9.60E+02	2.69E+00	4.07E-01	1.92E+00	7.30E-02	3.22E+03	NA
241-TX-107	Saltcake Solid	T2-SltCk (Solid)	62	4.82E+02	4.61E+04	3.21E+03	2.56E+04	2.47E+03	9.72E+01	3.35E+02	3.49E+01	1.66E+02	5.85E+00	8.38E+03	NA
241-TX-107	Total			6.27E+02	6.94E+04	6.98E+03	4.11E+04	5.38E+03	1.09E+03	3.38E+02	3.53E+01	1.68E+02	5.93E+00	2.03E+04	NA
241-TX-108	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	40	1.61E+02	7.60E+03	4.88E+03	9.44E+03	1.51E+03	3.98E+01	1.13E-01	1.03E-03	4.92E-03	1.74E-04	1.42E+04	NA
241-TX-108	Saltcake Solid	T2-SltCk (Solid)	415	2.51E+03	2.40E+05	1.67E+04	1.33E+05	1.29E+04	5.07E+02	1.16E+02	1.20E+01	5.74E+01	2.02E+00	4.37E+04	NA
241-TX-108	Sludge (Liquid & Solid)	MW2 (Solid)	8	0.00E+00	6.99E+00	5.82E+00	1.21E+03	0.00E+00	1.12E+03	5.47E-03	1.06E-02	8.38E-02	7.26E-04	2.86E+01	NA
241-TX-108	Sludge (Liquid & Solid)	TBP (Solid)	15	1.50E+01	4.10E+03	2.82E+02	2.40E+03	3.97E+01	2.42E+03	1.36E-01	2.65E-02	2.47E-01	1.72E-03	2.61E+02	NA
241-TX-108	Total			2.69E+03	2.52E+05	2.19E+04	1.46E+05	1.44E+04	4.09E+03	1.16E+02	1.21E+01	5.77E+01	2.02E+00	5.82E+04	NA
241-TX-109	Sludge (Liquid & Solid)	1C (Solid)	1375	1.03E+03	2.48E+05	1.91E+04	1.95E+05	2.93E+04	9.48E+03	2.72E+01	1.78E+01	1.64E+02	1.15E+00	3.12E+04	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-TX-109	Total			1.03E+03	2.48E+05	1.91E+04	1.95E+05	2.93E+04	9.48E+03	2.72E+01	1.78E+01	1.64E+02	1.15E+00	3.12E+04	NA
241-TX-110	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	49	1.97E+02	9.31E+03	5.98E+03	1.16E+04	1.85E+03	4.88E+01	1.38E-01	1.26E-03	6.03E-03	2.13E-04	1.74E+04	NA
241-TX-110	Saltcake Solid	T2-SltCk (Solid)	1580	9.56E+03	9.15E+05	6.37E+04	5.08E+05	4.90E+04	1.93E+03	4.40E+02	4.58E+01	2.18E+02	7.69E+00	1.66E+05	NA
241-TX-110	Sludge (Liquid & Solid)	1C (Solid)	140	1.05E+02	2.52E+04	1.94E+03	1.99E+04	2.98E+03	9.65E+02	2.77E+00	1.82E+00	1.67E+01	1.17E-01	3.18E+03	NA
241-TX-110	Total			9.86E+03	9.49E+05	7.17E+04	5.39E+05	5.38E+04	2.94E+03	4.43E+02	4.77E+01	2.35E+02	7.81E+00	1.87E+05	NA
241-TX-111	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	24	9.67E+01	4.56E+03	2.93E+03	5.66E+03	9.07E+02	2.39E+01	6.76E-02	6.19E-04	2.95E-03	1.04E-04	8.53E+03	NA
241-TX-111	Saltcake Solid	T2-SltCk (Solid)	1194	7.23E+03	6.91E+05	4.82E+04	3.84E+05	3.70E+04	1.46E+03	3.33E+02	3.46E+01	1.65E+02	5.81E+00	1.26E+05	NA
241-TX-111	Sludge (Liquid & Solid)	1C (Solid)	163	1.23E+02	2.94E+04	2.26E+03	2.31E+04	3.47E+03	1.12E+03	3.22E+00	2.11E+00	1.94E+01	1.37E-01	3.70E+03	NA
241-TX-111	Total			7.44E+03	7.25E+05	5.34E+04	4.13E+05	4.14E+04	2.60E+03	3.36E+02	3.68E+01	1.84E+02	5.95E+00	1.38E+05	NA
241-TX-112	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	15	5.07E-02	3.25E+03	1.27E+02	1.69E+03	5.42E+00	3.18E+01	2.32E-02	8.86E-03	7.83E-02	5.82E-04	1.34E+02	NA
241-TX-112	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	93	3.75E+02	1.77E+04	1.13E+04	2.19E+04	3.52E+03	9.26E+01	2.62E-01	2.40E-03	1.14E-02	4.04E-04	3.31E+04	4.47E+03
241-TX-112	Saltcake Solid	T1-SltCk (Solid)	75	1.02E-01	4.18E+04	2.57E+02	2.83E+04	2.36E+02	1.16E+01	3.09E-02	5.22E-01	4.60E+00	3.43E-02	2.71E+02	NA
241-TX-112	Saltcake Solid	T2-SltCk (Solid)	2215	1.34E+04	1.28E+06	8.94E+04	7.12E+05	6.87E+04	2.70E+03	6.17E+02	6.43E+01	3.06E+02	1.08E+01	2.33E+05	NA
241-TX-112	Total			1.38E+04	1.35E+06	1.01E+05	7.64E+05	7.24E+04	2.84E+03	6.17E+02	6.48E+01	3.11E+02	1.08E+01	2.67E+05	4.47E+03
241-TX-113	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	20	8.06E+01	3.80E+03	2.44E+03	4.72E+03	7.56E+02	1.99E+01	5.63E-02	5.16E-04	2.46E-03	8.69E-05	7.11E+03	9.62E+02
241-TX-113	Saltcake Solid	T2-SltCk (Solid)	2045	1.73E+03	1.59E+06	8.21E+03	8.51E+05	8.41E+03	2.98E+03	1.91E+01	1.99E+00	9.49E+00	3.34E-01	1.67E+04	NA
241-TX-113	Sludge (Liquid & Solid)	1C (Solid)	351	2.64E+02	6.32E+04	4.87E+03	4.98E+04	7.48E+03	2.42E+03	6.93E+00	4.55E+00	4.18E+01	2.94E-01	7.96E+03	NA
241-TX-113	Total			2.07E+03	1.66E+06	1.55E+04	9.06E+05	1.66E+04	5.42E+03	2.61E+01	6.54E+00	5.13E+01	6.28E-01	3.18E+04	9.62E+02
241-TX-114	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	46	1.55E-01	9.98E+03	3.91E+02	5.20E+03	1.66E+01	9.76E+01	7.12E-02	2.72E-02	2.40E-01	1.78E-03	4.10E+02	NA
241-TX-114	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	28	1.13E+02	5.32E+03	3.42E+03	6.61E+03	1.06E+03	2.79E+01	7.89E-02	7.22E-04	3.44E-03	1.22E-04	9.96E+03	NA
241-TX-114	Saltcake Solid	T1-SltCk (Solid)	173	2.36E-01	9.64E+04	5.92E+02	6.52E+04	5.45E+02	2.67E+01	7.12E-02	1.20E+00	1.06E+01	7.90E-02	6.25E+02	NA
241-TX-114	Saltcake Solid	T2-SltCk (Solid)	1750	1.06E+04	1.01E+06	7.06E+04	5.63E+05	5.42E+04	2.14E+03	4.87E+02	5.08E+01	2.42E+02	8.52E+00	1.84E+05	NA
241-TX-114	Sludge (Liquid & Solid)	1C (Solid)	15	1.13E+01	2.70E+03	2.08E+02	2.13E+03	3.20E+02	1.03E+02	2.96E-01	1.94E-01	1.79E+00	1.26E-02	3.40E+02	NA
241-TX-114	Total			1.07E+04	1.13E+06	7.52E+04	6.42E+05	5.62E+04	2.39E+03	4.88E+02	5.22E+01	2.55E+02	8.61E+00	1.96E+05	NA
241-TX-115	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	103	4.15E+02	1.96E+04	1.26E+04	2.43E+04	3.89E+03	1.03E+02	2.90E-01	2.66E-03	1.27E-02	4.48E-04	3.66E+04	4.95E+03
241-TX-115	Saltcake Solid	T2-SltCk (Solid)	1960	1.19E+04	1.13E+06	7.91E+04	6.30E+05	6.08E+04	2.39E+03	5.46E+02	5.69E+01	2.71E+02	9.54E+00	2.06E+05	NA
241-TX-115	Sludge (Liquid & Solid)	TBP (Solid)	30	3.00E+01	8.20E+03	5.64E+02	4.81E+03	7.94E+01	4.84E+03	2.72E-01	5.29E-02	4.94E-01	3.44E-03	5.23E+02	NA
241-TX-115	Total			1.23E+04	1.16E+06	9.22E+04	6.59E+05	6.47E+04	7.34E+03	5.46E+02	5.69E+01	2.71E+02	9.55E+00	2.44E+05	4.95E+03
241-TX-116	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	113	3.60E+01	4.28E+04	1.19E+03	1.71E+04	9.93E-01	2.14E-01	5.50E-02	1.62E-04	1.43E-03	1.06E-05	2.33E+03	2.87E+02
241-TX-116	Saltcake Solid	T1-SltCk (Solid)	977	1.61E+00	9.48E+05	4.04E+03	4.15E+05	3.34E+03	1.51E+02	4.86E-01	8.22E+00	7.25E+01	5.39E-01	4.27E+03	NA
241-TX-116	Saltcake Solid	T2-SltCk (Solid)	926	5.59E+03	5.30E+05	1.30E+04	2.84E+05	5.86E+04	9.27E+02	2.57E+02	2.68E+01	1.28E+02	4.49E+00	5.25E+04	NA
241-TX-116	Sludge (Liquid & Solid)	DE (Solid)	248	8.25E+02	3.89E+04	2.50E+04	4.83E+04	5.54E+02	2.04E+02	5.76E-01	5.28E-03	2.52E-02	8.89E-04	7.27E+04	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-TX-116	Total			6.45E+03	1.56E+06	4.31E+04	7.64E+05	6.25E+04	1.28E+03	2.58E+02	3.50E+01	2.00E+02	5.04E+00	1.32E+05	2.87E+02
241-TX-117	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	48	1.62E-01	1.04E+04	4.08E+02	5.42E+03	1.73E+01	1.02E+02	7.43E-02	2.84E-02	2.51E-01	1.86E-03	4.28E+02	NA
241-TX-117	Saltcake Solid	T1-SltCk (Solid)	626	8.54E-01	3.49E+05	2.14E+03	2.36E+05	1.97E+03	9.68E+01	2.58E-01	4.36E+00	3.84E+01	2.86E-01	2.26E+03	NA
241-TX-117	Saltcake Solid	T2-SltCk (Solid)	1033	6.25E+03	5.98E+05	4.17E+04	3.32E+05	3.20E+04	1.26E+03	2.88E+02	3.00E+01	1.43E+02	5.03E+00	1.09E+05	NA
241-TX-117	Sludge Solid	DE (Solid)	110	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.46E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	NA
241-TX-117	Total			6.25E+03	9.57E+05	4.42E+04	5.73E+05	3.43E+04	1.46E+03	2.88E+02	3.44E+01	1.81E+02	5.32E+00	1.11E+05	NA
241-TX-118	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	139	5.60E+02	2.64E+04	1.70E+04	3.28E+04	5.25E+03	1.38E+02	3.92E-01	3.59E-03	1.71E-02	6.04E-04	4.94E+04	6.69E+03
241-TX-118	Saltcake Solid	NA (SltCk)	125	4.04E+03	1.59E+03	3.51E+03	3.27E+04	1.84E+03	5.24E+04	4.71E+03	6.74E+02	3.21E+03	1.13E+02	1.31E+03	NA
241-TX-118	Saltcake Solid	T2-SltCk (Solid)	671	3.79E+03	9.33E+04	1.52E+04	2.42E+05	5.70E+03	1.39E+05	1.01E+03	1.05E+02	4.99E+02	1.76E+01	3.45E+04	NA
241-TX-118	Total			8.40E+03	1.21E+05	3.57E+04	3.08E+05	1.28E+04	1.92E+05	5.71E+03	7.79E+02	3.71E+03	1.31E+02	8.52E+04	6.69E+03
241-TY-101	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	15	5.07E-02	3.25E+03	1.27E+02	1.69E+03	5.42E+00	3.18E+01	2.32E-02	8.86E-03	7.83E-02	5.82E-04	1.34E+02	NA
241-TY-101	Saltcake Solid	T1-SltCk (Solid)	159	1.73E+02	3.78E+04	3.83E+02	3.16E+04	7.59E+03	2.54E+03	3.44E+00	5.07E+00	4.47E+01	3.33E-01	5.88E+01	NA
241-TY-101	Sludge (Liquid & Solid)	1CFeCN (Solid)	273	2.97E+02	6.49E+04	7.84E+03	5.43E+04	1.30E+04	4.36E+03	5.72E+00	5.43E+00	8.01E+01	2.83E-01	1.01E+02	NA
241-TY-101	Total			4.70E+02	1.06E+05	8.35E+03	8.76E+04	2.06E+04	6.94E+03	9.18E+00	1.05E+01	1.25E+02	6.16E-01	2.94E+02	NA
241-TY-102	Saltcake Interstitial Liquid	T1-SltCk (Liquid)	29	9.80E-02	6.29E+03	2.46E+02	3.28E+03	1.05E+01	6.15E+01	4.49E-02	1.71E-02	1.51E-01	1.12E-03	2.59E+02	NA
241-TY-102	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	34	1.37E+02	6.46E+03	4.15E+03	8.02E+03	1.29E+03	3.38E+01	9.58E-02	8.77E-04	4.18E-03	1.48E-04	1.21E+04	1.64E+03
241-TY-102	Saltcake Solid	T1-SltCk (Solid)	90	5.53E+01	5.48E+04	3.37E+02	3.49E+04	6.94E+01	5.02E+02	3.46E-02	2.45E-02	2.16E-01	1.60E-03	3.73E+02	8.63E-02
241-TY-102	Saltcake Solid	T2-SltCk (Solid)	109	6.70E+01	7.23E+04	5.04E+03	4.22E+04	8.40E+01	6.08E+02	9.74E-01	5.04E-02	2.40E-01	8.46E-03	4.51E+02	1.05E-01
241-TY-102	Total			2.59E+02	1.40E+05	9.77E+03	8.84E+04	1.45E+03	1.21E+03	1.15E+00	9.29E-02	6.12E-01	1.13E-02	1.32E+04	1.64E+03
241-TY-103	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	45	1.81E+02	8.55E+03	5.49E+03	1.06E+04	1.70E+03	4.48E+01	1.27E-01	1.16E-03	5.53E-03	1.96E-04	1.60E+04	2.16E+03
241-TY-103	Saltcake Solid	T2-SltCk (Solid)	150	2.95E+02	3.90E+04	2.09E+03	2.96E+04	7.63E+02	1.91E+04	1.13E+01	8.52E+00	4.06E+01	1.43E+00	3.14E+03	3.41E+01
241-TY-103	Sludge (Liquid & Solid)	1CFeCN (Solid)	170	3.35E+02	4.42E+04	2.37E+03	3.35E+04	8.65E+02	2.17E+04	9.95E+00	3.53E+00	5.21E+01	1.84E-01	3.56E+03	3.87E+01
241-TY-103	Sludge (Liquid & Solid)	TBP (Solid)	220	4.33E+02	5.71E+04	3.07E+03	4.34E+04	1.12E+03	2.80E+04	2.41E+00	6.97E+00	6.50E+01	4.53E-01	4.61E+03	5.00E+01
241-TY-103	Total			1.24E+03	1.49E+05	1.30E+04	1.17E+05	4.45E+03	6.89E+04	2.38E+01	1.90E+01	1.58E+02	2.07E+00	2.73E+04	2.29E+03
241-TY-104	Sludge (Liquid & Solid)	1CFeCN (Solid)	114	1.63E+02	9.46E+03	2.46E+03	2.03E+04	1.67E+03	1.63E+04	1.50E+01	2.22E+00	3.27E+01	1.16E-01	6.61E+03	NA
241-TY-104	Sludge (Liquid & Solid)	TBP (Solid)	49	7.00E+01	4.07E+03	1.06E+03	8.73E+03	7.18E+02	7.02E+03	6.45E+00	1.45E+00	1.36E+01	9.45E-02	2.84E+03	NA
241-TY-104	Supernatant	DW (Liquid)	5	1.06E+01	4.95E+02	5.65E+01	4.17E+02	2.85E+00	3.02E-01	2.16E-03	1.56E-03	6.53E-03	3.70E-04	5.73E+01	NA
241-TY-104	Total			2.43E+02	1.40E+04	3.58E+03	2.95E+04	2.39E+03	2.33E+04	2.14E+01	3.68E+00	4.63E+01	2.11E-01	9.50E+03	NA
241-TY-105	Sludge (Liquid & Solid)	TBP (Solid)	874	1.08E+03	2.38E+05	2.10E+04	1.54E+05	2.55E+03	1.98E+05	1.01E+01	3.04E+00	2.84E+01	1.97E-01	8.35E+03	7.13E-01
241-TY-105	Total			1.08E+03	2.38E+05	2.10E+04	1.54E+05	2.55E+03	1.98E+05	1.01E+01	3.04E+00	2.84E+01	1.97E-01	8.35E+03	7.13E-01
241-TY-106	Sludge (Liquid & Solid)	DE (Solid)	47	1.88E+02	1.09E+04	5.48E+02	5.23E+03	1.45E+02	7.97E+03	1.09E+00	1.34E-01	1.25E+00	8.70E-03	3.72E+03	NA
241-TY-106	Sludge (Liquid & Solid)	TBP (Solid)	15	5.99E+01	3.46E+03	1.75E+02	1.67E+03	4.62E+01	2.54E+03	3.49E-01	4.27E-02	3.99E-01	2.78E-03	1.19E+03	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-TY-106	Total			2.48E+02	1.43E+04	7.24E+02	6.90E+03	1.91E+02	1.05E+04	1.44E+00	1.77E-01	1.65E+00	1.15E-02	4.90E+03	NA
241-U-101	Sludge (Liquid & Solid)	R1 (Solid)	87	1.47E+02	1.57E+04	4.42E+03	1.41E+04	2.61E+04	5.72E+04	3.16E+00	1.21E+00	6.25E+00	1.16E-01	8.82E+03	NA
241-U-101	Total			1.47E+02	1.57E+04	4.42E+03	1.41E+04	2.61E+04	5.72E+04	3.16E+00	1.21E+00	6.25E+00	1.16E-01	8.82E+03	NA
241-U-102	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	117	1.31E+03	2.32E+04	1.71E+04	2.61E+04	3.88E+03	7.88E+02	1.36E+00	1.14E-02	5.44E-02	1.92E-03	5.27E+04	3.43E+03
241-U-102	Saltcake Solid	S2-SltSlr (Solid)	307	3.97E+03	1.52E+05	2.34E+04	9.59E+04	7.84E+03	1.79E+04	5.03E+01	7.21E+00	3.36E+01	1.17E+00	7.02E+04	NA
241-U-102	Saltcake Solid	T2-SltCk (Solid)	647	8.37E+03	3.21E+05	4.92E+04	2.02E+05	1.65E+04	3.78E+04	1.20E+02	1.25E+01	5.96E+01	2.10E+00	1.48E+05	NA
241-U-102	Sludge (Liquid & Solid)	R1 (Solid)	163	3.03E+02	3.23E+04	9.12E+03	2.91E+04	5.40E+04	1.18E+05	7.22E+01	2.77E+01	1.43E+02	2.65E+00	1.82E+04	NA
241-U-102	Supernatant	T2-SltCk (Liquid)	4	4.48E+01	7.92E+02	5.84E+02	8.92E+02	1.33E+02	2.69E+01	4.65E-02	3.90E-04	1.86E-03	6.58E-05	1.80E+03	1.17E+02
241-U-102	Total			1.40E+04	5.29E+05	9.94E+04	3.54E+05	8.23E+04	1.75E+05	2.44E+02	4.75E+01	2.36E+02	5.92E+00	2.91E+05	3.55E+03
241-U-103	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	119	1.48E+03	1.81E+04	1.63E+04	2.74E+04	4.87E+03	1.12E+03	2.20E+00	1.02E-02	4.69E-02	1.65E-03	5.30E+04	3.67E+03
241-U-103	Saltcake Solid	S1-SltCk (Solid)	891	1.21E+04	3.42E+05	7.45E+04	3.11E+05	2.52E+04	2.35E+04	1.44E+02	9.71E+00	4.45E+01	1.57E+00	1.28E+05	2.38E+04
241-U-103	Saltcake Solid	S2-SltSlr (Solid)	356	4.84E+03	1.37E+05	2.98E+04	1.24E+05	1.01E+04	7.87E+03	4.35E+01	6.24E+00	2.91E+01	1.02E+00	7.94E+04	NA
241-U-103	Sludge (Liquid & Solid)	R1 (Solid)	42	6.66E+02	6.21E+03	3.17E+03	9.10E+03	8.46E+03	2.22E+04	1.50E+01	5.76E+00	2.97E+01	5.50E-01	3.42E+03	NA
241-U-103	Supernatant	S1-SltCk (Liquid)	2	2.48E+01	3.04E+02	2.74E+02	4.61E+02	8.18E+01	1.87E+01	3.70E-02	1.72E-04	7.88E-04	2.78E-05	8.91E+02	6.16E+01
241-U-103	Total			1.91E+04	5.04E+05	1.24E+05	4.72E+05	4.86E+04	5.48E+04	2.04E+02	2.17E+01	1.03E+02	3.13E+00	2.64E+05	2.75E+04
241-U-104	Sludge (Liquid & Solid)	DE (Solid)	201	0.00E+00	7.09E+02	6.65E+01	2.76E+03	3.16E+02	1.97E+01	2.90E-01	1.33E-01	1.05E+00	9.09E-03	3.66E+01	NA
241-U-104	Sludge (Liquid & Solid)	MW2 (Solid)	4	0.00E+00	3.49E+00	2.91E+00	6.06E+02	0.00E+00	5.62E+02	2.73E-03	5.31E-03	4.19E-02	3.63E-04	1.43E+01	NA
241-U-104	Total			0.00E+00	7.12E+02	6.94E+01	3.37E+03	3.16E+02	5.81E+02	2.93E-01	1.38E-01	1.09E+00	9.46E-03	5.09E+01	NA
241-U-105	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	130	2.13E+03	2.35E+04	1.40E+04	2.95E+04	3.87E+03	2.93E+03	7.67E+00	4.13E-02	1.93E-01	6.73E-03	4.53E+04	2.72E+03
241-U-105	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	35	5.74E+02	6.34E+03	3.78E+03	7.95E+03	1.04E+03	7.89E+02	2.06E+00	1.09E-02	5.21E-02	1.84E-03	1.22E+04	7.33E+02
241-U-105	Saltcake Solid	S2-SltSlr (Solid)	827	2.80E+04	4.56E+05	6.24E+04	2.79E+05	2.04E+04	2.10E+04	5.50E+02	7.89E+01	3.68E+02	1.28E+01	1.84E+05	NA
241-U-105	Saltcake Solid	T2-SltCk (Solid)	223	7.54E+03	1.23E+05	1.68E+04	7.53E+04	5.50E+03	2.82E+02	1.68E+02	1.75E+01	8.35E+01	2.94E+00	4.95E+04	NA
241-U-105	Sludge (Liquid & Solid)	CWR1 (Solid)	121	2.02E+03	3.33E+04	4.09E+03	2.05E+04	3.17E+04	3.93E+02	8.20E+01	2.42E+01	1.27E+02	1.98E+00	1.45E+04	NA
241-U-105	Total			4.03E+04	6.42E+05	1.01E+05	4.12E+05	6.25E+04	2.54E+04	8.10E+02	1.21E+02	5.79E+02	1.78E+01	3.05E+05	3.45E+03
241-U-106	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	154	5.21E+03	3.83E+04	1.52E+04	3.43E+04	1.85E+03	8.47E+03	4.45E+01	1.90E-01	8.71E-01	3.07E-02	4.35E+04	7.87E+02
241-U-106	Saltcake Solid	S1-SltCk (Solid)	484	1.65E+04	1.64E+05	3.68E+04	1.41E+05	9.22E+03	5.04E+04	6.34E+02	4.29E+01	1.97E+02	6.93E+00	9.98E+04	NA
241-U-106	Supernatant	S1-SltCk (Liquid)	6	2.03E+02	1.49E+03	5.94E+02	1.34E+03	7.22E+01	3.30E+02	1.74E+00	7.39E-03	3.39E-02	1.19E-03	1.69E+03	3.07E+01
241-U-106	Total			2.20E+04	2.04E+05	5.26E+04	1.77E+05	1.11E+04	5.92E+04	6.81E+02	4.31E+01	1.98E+02	6.96E+00	1.45E+05	8.18E+02
241-U-107	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	105	6.59E+02	1.49E+04	1.34E+04	2.15E+04	4.30E+03	4.67E+01	2.89E-01	9.03E-04	4.21E-03	1.47E-04	3.59E+04	3.28E+03
241-U-107	Saltcake Interstitial Liquid	T2-SltCk (Liquid)	5	3.14E+01	7.11E+02	6.37E+02	1.02E+03	2.05E+02	2.22E+00	1.38E-02	4.22E-05	2.01E-04	7.11E-06	1.71E+03	1.56E+02
241-U-107	Saltcake Solid	S2-SltSlr (Solid)	902	2.30E+03	5.90E+05	5.38E+04	3.25E+05	2.20E+04	3.63E+03	3.94E+02	5.65E+01	2.64E+02	9.20E+00	1.03E+05	NA
241-U-107	Saltcake Solid	T2-SltCk (Solid)	44	1.12E+02	2.88E+04	2.62E+03	1.58E+04	1.07E+03	1.77E+02	2.18E+01	2.27E+00	1.08E+01	3.81E-01	5.04E+03	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-U-107	Sludge (Liquid & Solid)	CWR1 (Solid)	57	6.55E+01	2.51E+03	1.10E+03	3.96E+03	2.37E+04	1.91E+02	2.00E-01	5.91E-02	3.11E-01	4.84E-03	4.03E+02	NA
241-U-107	Total			3.17E+03	6.37E+05	7.15E+04	3.67E+05	5.13E+04	4.05E+03	4.16E+02	5.89E+01	2.75E+02	9.58E+00	1.46E+05	3.44E+03
241-U-108	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	86	6.08E+02	1.58E+04	1.15E+04	1.96E+04	2.62E+03	2.41E+01	2.03E-01	1.24E-03	5.71E-03	2.01E-04	2.94E+04	4.23E+03
241-U-108	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	69	4.88E+02	1.27E+04	9.25E+03	1.57E+04	2.10E+03	1.93E+01	1.63E-01	9.85E-04	4.59E-03	1.60E-04	2.36E+04	3.39E+03
241-U-108	Saltcake Solid	S1-SltCk (Solid)	766	6.72E+03	3.86E+05	6.75E+04	3.22E+05	2.11E+04	1.15E+04	5.06E+01	3.42E+00	1.57E+01	5.52E-01	1.59E+05	NA
241-U-108	Saltcake Solid	S2-SltSlr (Solid)	610	5.35E+03	3.07E+05	5.37E+04	2.56E+05	1.68E+04	9.17E+03	3.06E+01	4.38E+00	2.04E+01	7.13E-01	1.27E+05	NA
241-U-108	Sludge (Liquid & Solid)	CWR2 (Solid)	110	0.00E+00	4.51E+03	1.11E+03	3.47E+03	1.73E+04	8.62E+01	1.30E+01	3.16E+01	1.44E+02	3.59E+00	1.01E+02	NA
241-U-108	Total			1.32E+04	7.26E+05	1.43E+05	6.17E+05	5.99E+04	2.08E+04	9.45E+01	3.94E+01	1.80E+02	4.86E+00	3.39E+05	7.63E+03
241-U-109	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	137	8.95E+02	2.53E+04	1.75E+04	3.12E+04	4.00E+03	1.13E+02	1.79E+00	1.69E-02	7.77E-02	2.74E-03	4.45E+04	6.06E+03
241-U-109	Saltcake Solid	S1-SltCk (Solid)	600	4.01E+03	3.05E+05	4.57E+04	2.07E+05	1.28E+04	7.40E+03	2.99E+01	2.02E+00	9.27E+00	3.26E-01	1.06E+05	1.85E+04
241-U-109	Saltcake Solid	S2-SltSlr (Solid)	512	3.42E+03	2.60E+05	3.90E+04	1.77E+05	1.09E+04	6.31E+03	1.93E+01	2.77E+00	1.29E+01	4.51E-01	9.04E+04	NA
241-U-109	Sludge (Liquid & Solid)	CWR1 (Solid)	103	4.84E+02	7.78E+03	5.20E+03	1.55E+04	2.99E+04	1.70E+03	1.68E+00	4.95E-01	2.61E+00	4.06E-02	1.14E+04	1.56E+03
241-U-109	Total			8.81E+03	5.98E+05	1.07E+05	4.31E+05	5.77E+04	1.55E+04	5.27E+01	5.30E+00	2.49E+01	8.20E-01	2.52E+05	2.61E+04
241-U-110	Sludge (Liquid & Solid)	1C (Solid)	120	1.43E+02	7.13E+03	1.27E+03	2.22E+04	1.35E+04	1.09E+03	9.21E+00	6.05E+00	5.55E+01	3.91E-01	5.68E+03	NA
241-U-110	Sludge (Liquid & Solid)	CWR1 (Solid)	149	1.45E+02	2.76E+01	1.24E+01	2.88E+02	8.29E+04	1.63E+02	5.24E+00	1.55E+00	8.14E+00	1.27E-01	7.68E+01	NA
241-U-110	Sludge (Liquid & Solid)	R1 (Solid)	396	9.93E+02	3.38E+04	1.05E+04	4.90E+04	1.09E+05	1.84E+05	6.94E+01	2.84E+01	1.46E+02	2.72E+00	1.49E+04	NA
241-U-110	Total			1.28E+03	4.10E+04	1.18E+04	7.15E+04	2.06E+05	1.85E+05	8.39E+01	3.60E+01	2.10E+02	3.23E+00	2.07E+04	NA
241-U-111	Saltcake Interstitial Liquid	S1-SltCk (Liquid)	41	2.22E+02	6.82E+03	4.92E+03	9.78E+03	1.50E+03	6.90E+01	1.70E-01	2.15E-03	9.86E-03	3.47E-04	1.41E+04	1.39E+03
241-U-111	Saltcake Interstitial Liquid	S2-SltSlr (Liquid)	72	3.89E+02	1.20E+04	8.64E+03	1.72E+04	2.64E+03	1.21E+02	2.98E-01	3.73E-03	1.74E-02	6.07E-04	2.48E+04	2.44E+03
241-U-111	Saltcake Solid	S1-SltCk (Solid)	228	1.38E+03	1.18E+05	1.63E+04	8.24E+04	6.05E+03	6.66E+03	2.93E+01	1.98E+00	9.08E+00	3.19E-01	3.61E+04	6.74E+03
241-U-111	Saltcake Solid	S2-SltSlr (Solid)	401	3.45E+03	1.76E+05	3.31E+04	1.27E+05	1.24E+04	8.88E+03	1.01E+02	1.44E+01	6.73E+01	2.35E+00	8.97E+04	NA
241-U-111	Sludge (Liquid & Solid)	1C (Solid)	49	3.69E+01	8.83E+03	6.80E+02	6.96E+03	1.04E+03	3.38E+02	9.68E-01	6.35E-01	5.84E+00	4.11E-02	1.11E+03	NA
241-U-111	Sludge (Liquid & Solid)	R1 (Solid)	49	9.11E+01	9.71E+03	2.74E+03	8.76E+03	1.62E+04	3.55E+04	2.17E+01	8.33E+00	4.29E+01	7.96E-01	5.47E+03	NA
241-U-111	Total			5.57E+03	3.31E+05	6.63E+04	2.52E+05	3.99E+04	5.16E+04	1.53E+02	2.54E+01	1.25E+02	3.51E+00	1.71E+05	1.06E+04
241-U-112	Sludge (Liquid & Solid)	1C (Solid)	47	3.54E+01	8.47E+03	6.53E+02	6.67E+03	1.00E+03	3.24E+02	9.28E-01	6.09E-01	5.60E+00	3.94E-02	1.07E+03	NA
241-U-112	Sludge (Liquid & Solid)	CWR1 (Solid)	58	6.75E+01	4.86E+03	1.58E+02	7.53E+03	1.86E+04	1.97E+02	7.94E-02	2.35E-02	1.23E-01	1.92E-03	4.15E+02	NA
241-U-112	Sludge (Liquid & Solid)	R1 (Solid)	67	1.25E+02	5.61E+03	1.82E+02	8.70E+03	2.15E+04	4.88E+04	2.96E-04	1.14E-04	5.85E-04	1.08E-05	7.53E+03	NA
241-U-112	Total			2.28E+02	1.89E+04	9.92E+02	2.29E+04	4.12E+04	4.94E+04	1.01E+00	6.33E-01	5.72E+00	4.13E-02	9.01E+03	NA
241-U-201	Sludge (Liquid & Solid)	CWR1 (Solid)	11	2.26E+00	3.08E+02	4.64E+01	1.14E+03	3.52E+03	2.59E+00	2.75E-02	6.32E-03	3.33E-02	5.18E-04	8.47E+01	NA
241-U-201	Supernatant	CWR1 (Liquid)	4	0.00E+00	5.71E+02	8.28E+01	4.63E+02	5.65E-01	5.10E-02	2.18E-03	1.74E-04	9.16E-04	1.42E-05	1.09E+02	5.06E+01
241-U-201	Total			2.26E+00	8.79E+02	1.29E+02	1.61E+03	3.52E+03	2.64E+00	2.97E-02	6.50E-03	3.42E-02	5.32E-04	1.93E+02	5.06E+01
241-U-202	Sludge (Liquid & Solid)	CWR1 (Solid)	10	1.52E+00	2.36E+02	3.89E+01	9.38E+02	3.03E+03	9.32E-01	2.87E-02	7.44E-03	3.92E-02	6.10E-04	6.24E+01	NA

Table A-2. Tank Waste Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for
Hydrogen Generation Rate Calculations. (23 sheets)

Tank Name	Waste Phase	Waste Type	Vol (kL)	TOC (kg)	NO ₃ (kg)	NO ₂ (kg)	Na (kg)	Al (kg)	⁹⁰ Sr (Ci)	²⁴¹ Am (Ci)	²⁴⁰ Pu (Ci)	²³⁹ Pu (Ci)	²³⁸ Pu (Ci)	¹³⁷ Cs (Ci)	Free OH (kg)
241-U-202	Supernatant	CWR1 (Liquid)	4	5.64E-01	6.07E+02	9.81E+01	4.78E+02	9.54E-01	2.47E-03	3.70E-05	4.47E-06	2.35E-05	3.66E-07	7.83E+01	7.14E+01
241-U-202	Total			2.09E+00	8.43E+02	1.37E+02	1.42E+03	3.04E+03	9.34E-01	2.87E-02	7.45E-03	3.92E-02	6.10E-04	1.41E+02	7.14E+01
241-U-203	Sludge (Liquid & Solid)	CWR1 (Solid)	9	1.14E+00	2.32E+02	3.49E+01	1.68E+03	1.37E+03	1.80E+00	2.21E-02	4.12E-03	2.17E-02	3.37E-04	5.57E+01	NA
241-U-203	Supernatant	CWR1 (Liquid)	4	0.00E+00	5.76E+02	7.74E+01	4.01E+02	7.50E-01	2.17E-03	3.55E-05	1.90E-05	9.98E-05	1.55E-06	7.34E+01	1.90E+01
241-U-203	Total			1.14E+00	8.08E+02	1.12E+02	2.08E+03	1.37E+03	1.80E+00	2.21E-02	4.14E-03	2.18E-02	3.39E-04	1.29E+02	1.90E+01
241-U-204	Sludge (Liquid & Solid)	CWR1 (Solid)	7	6.02E+00	1.34E+02	1.93E+01	1.34E+02	2.27E+03	3.92E+01	2.27E-01	1.24E-01	6.53E-01	1.02E-02	5.12E+01	NA
241-U-204	Supernatant	CWR1 (Liquid)	4	3.24E-01	2.21E+02	2.81E+01	1.57E+02	5.85E-02	7.86E-04	3.77E-05	2.98E-06	1.57E-05	2.43E-07	2.72E+01	6.44E+00
241-U-204	Total			6.35E+00	3.54E+02	4.74E+01	2.91E+02	2.27E+03	3.92E+01	2.27E-01	1.24E-01	6.53E-01	1.02E-02	7.85E+01	6.44E+00

NOTE: The water concentration is applicable to the time of sampling and may change with time; no water inventory is calculated.

Table A-3. Retained Gas Inventory from Best Basis Inventory Detail Report (Queried on September 17, 2007) for Hydrogen Generation Rate Calculations.

Tank Name	Waste Phase	Waste Type	Volume (kL)
241-A-101	Retained Gas (Saltcake)	NA	174
241-AN-103	Retained Gas (Saltcake)	NA	220
241-AN-104	Retained Gas (Saltcake)	NA	119
241-AN-105	Retained Gas (Saltcake)	NA	109
241-AW-101	Retained Gas (Saltcake)	NA	95
241-S-102	Retained Gas (Saltcake)	NA	9
241-S-102	Retained Gas (Sludge)	NA	13
241-S-111	Retained Gas (Saltcake)	NA	77
241-S-111	Retained Gas (Sludge)	NA	43
241-SY-101	Retained Gas (Saltcake)	NA	87
241-SY-103	Retained Gas (Saltcake)	NA	91
241-U-103	Retained Gas (Saltcake)	NA	163
241-U-103	Retained Gas (Sludge)	NA	5
241-U-109	Retained Gas (Saltcake)	NA	137
241-U-109	Retained Gas (Sludge)	NA	29

Note: Data from Wt%H₂O&Density Report 09172007

APPENDIX B

**HYDROGEN GENERATION RATE CALCULATIONS FROM EMPIRICAL RATE
EQUATION MODEL FOR 177 HANFORD TANKS**

This page intentionally left blank.

CONTENTS

Table B-1	Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks	B-1
Table B-2	Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks	B-15
Table B-3	Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks	B-29
Table B-4	Calculated Total Hydrogen Generation Rate in Dome Space for 177 Tanks	B-43
Table B-5	Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks	B-57

This page intentionally left blank.

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (μg/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-AN-101	3.32E+04	5.33E+03	1.11E+05	1.63E+05	2.10E+05	1.96E+04	1.97E+00	2.55E-03	8.62E-05	4.10E-04	1.55E-05	1.93E+02	1.40	1.40	4326	52%	52%	25	23
Supernatant	3.28E+04	5.37E+03	1.11E+05	1.62E+05	2.10E+05	1.91E+04	1.34E+00	1.63E-03	2.38E-05	1.42E-04	4.43E-06	1.94E+02	1.40	1.40	4208	52%	52%	25	23
Solid Layer	4.82E+04	4.04E+03	1.22E+05	1.90E+05	2.36E+05	3.79E+04	2.46E+01	3.55E-02	2.31E-03	9.97E-03	4.10E-04	1.84E+02	1.55	1.45	118	40%	49%	22	23
241-AN-102	8.28E+03	2.41E+04	8.71E+04	1.97E+05	2.12E+05	1.32E+04	6.82E+01	1.86E-01	2.28E-03	8.76E-03	6.36E-04	2.78E+02	1.43	1.41	4030	48%	49%	31	30
Supernatant	8.18E+03	2.41E+04	8.71E+04	1.97E+05	2.12E+05	1.32E+04	5.66E+01	1.16E-01	8.81E-04	3.40E-03	2.47E-04	2.80E+02	1.41	1.41	3446	49%	49%	31	30
Solid Layer	8.85E+03	2.41E+04	8.71E+04	1.97E+05	2.12E+05	1.32E+04	1.37E+02	5.99E-01	1.05E-02	4.04E-02	2.93E-03	2.64E+02	1.53	1.41	584	40%	49%	30	30
241-AN-103	6.72E+04	3.05E+03	1.30E+05	1.28E+05	2.70E+05	3.00E+04	1.07E+00	3.83E-03	1.96E-04	7.53E-04	5.46E-05	3.21E+02	1.60	1.48	3407	41%	47%	36	29
Supernatant	6.73E+04	3.05E+03	1.30E+05	1.28E+05	2.70E+05	3.00E+04	1.20E-02	4.13E-03	4.47E-05	1.72E-04	1.25E-05	4.28E+02	1.48	1.48	1769	47%	47%	36	29
Solid Layer	6.72E+04	3.05E+03	1.30E+05	1.28E+05	2.70E+05	3.00E+04	2.22E+00	3.51E-03	3.58E-04	1.38E-03	1.00E-04	2.06E+02	1.72	1.48	1638	35%	47%	36	29
241-AN-104	6.53E+04	3.14E+03	1.19E+05	1.89E+05	2.58E+05	3.90E+04	1.17E+01	7.82E-03	3.09E-04	1.19E-03	8.62E-05	3.31E+02	1.48	1.40	3864	49%	51%	35	27
Supernatant	6.53E+04	3.14E+03	1.19E+05	1.89E+05	2.58E+05	3.90E+04	5.84E-02	2.51E-04	1.34E-05	5.16E-05	3.73E-06	3.51E+02	1.40	1.40	2298	51%	51%	33	27
Solid Layer	6.53E+04	3.14E+03	1.19E+05	1.89E+05	2.58E+05	3.90E+04	2.88E+01	1.89E-02	7.43E-04	2.86E-03	2.07E-04	3.00E+02	1.59	1.40	1566	46%	51%	36	27
241-AN-105	5.97E+04	2.76E+03	1.19E+05	1.56E+05	2.47E+05	4.17E+04	4.42E+00	8.63E-03	2.75E-04	1.06E-03	7.66E-05	2.27E+02	1.49	1.42	4152	47%	50%	30	23
Supernatant	5.97E+04	2.76E+03	1.19E+05	1.56E+05	2.47E+05	4.17E+04	2.44E-02	1.01E-02	1.10E-04	4.24E-04	3.07E-05	2.06E+02	1.42	1.42	2227	50%	50%	29	23
Solid Layer	5.97E+04	2.76E+03	1.19E+05	1.56E+05	2.47E+05	4.17E+04	9.50E+00	6.92E-03	4.67E-04	1.79E-03	1.30E-04	2.50E+02	1.57	1.42	1925	44%	50%	31	23
241-AN-106	6.69E+03	8.89E+02	2.79E+04	1.86E+03	5.26E+04	1.22E+03	4.98E+02	5.98E-01	6.86E-02	3.19E-01	1.04E-02	4.47E+01	1.21	1.11	2675	71%	84%	39	35
Supernatant	6.69E+03	8.89E+02	2.79E+04	1.86E+03	5.26E+04	1.23E+03	9.06E-01	1.68E-04	2.93E-04	1.39E-03	2.04E-04	1.84E+01	1.11	1.11	1958	84%	84%	40	35
Solid Layer	6.68E+03	8.90E+02	2.79E+04	1.86E+03	5.26E+04	1.22E+03	1.85E+03	2.23E+00	2.55E-01	1.19E+00	3.84E-02	1.17E+02	1.48	1.11	717	45%	84%	36	35
241-AN-107	1.80E+04	3.25E+04	6.67E+04	2.09E+05	2.08E+05	1.12E+03	7.71E+01	5.99E-01	9.47E-03	3.65E-02	2.64E-03	2.14E+02	1.44	1.43	4169	50%	52%	31	28
Supernatant	1.80E+04	3.25E+04	6.67E+04	2.09E+05	2.08E+05	1.12E+03	5.37E+01	5.11E-01	8.21E-03	3.16E-02	2.29E-03	2.09E+02	1.43	1.43	3297	52%	52%	31	28
Solid Layer	1.80E+04	3.25E+04	6.67E+04	2.09E+05	2.08E+05	1.12E+03	1.66E+02	9.30E-01	1.43E-02	5.49E-02	3.98E-03	2.33E+02	1.48	1.43	872	44%	52%	32	28
241-AP-101	2.20E+04	1.04E+03	2.12E+04	1.36E+05	1.06E+05	4.89E+03	7.81E-01	1.06E-03	1.15E-04	5.85E-04	1.85E-05	5.47E+01	1.22	1.22	4374	69%	69%	20	22
Supernatant	2.20E+04	1.04E+03	2.12E+04	1.36E+05	1.06E+05	4.89E+03	7.81E-01	1.06E-03	1.15E-04	5.85E-04	1.85E-05	5.47E+01	1.22	1.22	4374	69%	69%	20	22
Solid Layer	0.00E+00	0.0	0.0	0.0	0.0	0.0	0.0	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.0	0.00	0.00	0	0%	0%	0	0
241-AP-102	3.21E+04	3.01E+03	9.83E+04	1.67E+05	1.95E+05	3.09E+04	2.79E-01	1.23E-03	3.84E-05	2.27E-04	5.89E-06	1.70E+02	1.40	1.39	4137	58%	59%	22	31
Supernatant	3.21E+04	3.01E+03	9.83E+04	1.67E+05	1.95E+05	3.09E+04	2.77E-01	1.24E-03	3.75E-05	2.22E-04	5.76E-06	1.72E+02	1.39	1.39	4049	59%	59%	22	31
Solid Layer	3.21E+04	3013.1	98295.9	167448.8	194862.9	30871.8	0.4	6.95E-04	7.92E-05	4.68E-04	1.20E-05	81.2	1.75	1.39	88	31%	59%	24	31
241-AP-103	2.09E+04	6.59E+03	8.23E+04	1.61E+05	1.87E+05	1.99E+04	1.60E+00	6.30E-03	9.30E-05	5.54E-04	1.95E-05	1.66E+02	1.38	1.37	2876	55%	55%	27	22
Supernatant	2.10E+04	6.59E+03	8.23E+04	1.61E+05	1.87E+05	1.99E+04	1.64E+00	6.45E-03	9.13E-05	5.44E-04	1.92E-05	1.67E+02	1.37	1.37	2806	55%	55%	27	22
Solid Layer	1.67E+04	6593.0	82323.6	160727.0	186742.7	19886.0	0.2	2.49E-04	1.62E-04	9.61E-04	3.16E-05	111.4	1.68	1.35	70	41%	55%	24	22
241-AP-104	1.97E+04	4.16E+03	6.40E+04	1.01E+05	1.29E+05	1.68E+04	1.30E+00	2.20E-03	2.35E-05	1.38E-04	3.10E-05	1.45E+02	1.28	1.28	4155	66%	66%	22	22
Supernatant	1.97E+04	4.16E+03	6.40E+04	1.01E+05	1.29E+05	1.68E+04	1.30E+00	2.20E-03	2.35E-05	1.38E-04	3.10E-05	1.45E+02	1.28	1.28	4155	66%	66%	22	22
Solid Layer	0.00E+00	0.0	0.0	0.0	0.0	0.0	0.0	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.0	0.00	0.00	0	0%	0%	0	0
241-AP-105	2.60E+04	1.50E+03	4.74E+04	1.06E+05	1.34E+05	1.92E+04	1.60E+00	9.12E-04	1.03E-04	4.74E-04	3.12E-05	1.16E+02	1.30	1.27	4302	69%	71%	19	20
Supernatant	2.60E+04	1.50E+03	4.74E+04	1.06E+05	1.34E+05	1.92E+04	2.14E-01	5.46E-04	3.65E-05	2.22E-04	1.27E-05	1.07E+02	1.27	1.27	3965	71%	71%	19	20
Solid Layer	2.59E+04	1.50E+03	4.74E+04	1.06E+05	1.34E+05	1.92E+04	1.79E+01	5.22E-03	8.90E-04	3.43E-03	2.49E-04	2.25E+02	1.61	1.27	337	48%	71%	19	20
241-AP-106	7.37E+03	3.46E+03	4.14E+04	7.07E+04	1.03E+05	1.35E+04	9.84E-01	5.02E-04	1.05E-05	6.11E-05	1.72E-06	1.45E+02	1.21	1.21	4301	72%	72%	19	19
Supernatant	7.37E+03	3.46E+03	4.14E+04	7.07E+04	1.03E+05	1.35E+04	9.84E-01	5.02E-04	1.05E-05	6.11E-05	1.72E-06	1.45E+02	1.21	1.21	4301	72%	72%	19	19
Solid Layer	0.00E+00	0.0	0.0	0.0	0.0	0.0	0.0	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.0	0.00	0.00	0	0%	0%	0	0

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (μg/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-AP-107	1.88E+04	1.61E+03	3.23E+04	1.53E+05	1.25E+05	9.10E+03	4.48E-01	2.30E-04	1.64E-05	8.06E-05	3.66E-06	6.87E+01	1.28	1.28	4274	68%	68%	19	14
Supernatant	1.88E+04	1.61E+03	3.23E+04	1.53E+05	1.25E+05	9.10E+03	4.48E-01	2.30E-04	1.64E-05	8.06E-05	3.66E-06	6.87E+01	1.28	1.28	4274	68%	68%	19	14
Solid Layer	0.00E+00	0.0	0.0	0.0	0.0	0.0	0.0	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.0	0.00	0.00	0	0%	0%	0	0
241-AP-108	4.91E+04	3.50E+03	7.98E+04	1.75E+05	2.07E+05	2.31E+04	7.04E-01	1.25E-03	5.32E-05	2.79E-04	1.75E-05	1.46E+02	1.42	1.41	4720	50%	51%	22	22
Supernatant	3.67E+04	3.50E+03	7.98E+04	1.75E+05	2.07E+05	2.31E+04	7.24E-01	1.34E-03	5.41E-05	2.85E-04	1.77E-05	1.47E+02	1.41	1.41	4337	51%	51%	22	22
Solid Layer	3.95E+04	3504.7	79778.6	174775.2	207286.1	23057.4	0.5	2.19E-04	4.33E-05	2.14E-04	1.60E-05	130.5	1.55	1.42	383	45%	51%	23	22
241-AW-101	9.96E+04	2.61E+03	1.05E+05	1.71E+05	2.33E+05	2.95E+04	1.25E+01	1.58E-02	3.94E-03	1.52E-02	1.10E-03	2.43E+02	1.51	1.47	4173	44%	44%	35	24
Supernatant	9.96E+04	2.61E+03	1.05E+05	1.71E+05	2.33E+05	2.95E+04	2.55E-01	1.77E-04	7.27E-05	2.80E-04	2.03E-05	2.58E+02	1.47	1.47	2770	44%	44%	35	24
Solid Layer	9.96E+04	2.61E+03	1.05E+05	1.71E+05	2.33E+05	2.95E+04	3.68E+01	4.66E-02	1.16E-02	4.45E-02	3.23E-03	2.13E+02	1.59	1.47	1403	44%	44%	35	24
241-AW-102	3.41E+03	1.92E+03	1.52E+04	1.60E+04	3.80E+04	1.96E+03	1.55E+01	5.20E-02	2.84E-03	1.39E-02	4.59E-04	3.04E+01	1.09	1.07	4089	86%	88%	27	25
Supernatant	2.97E+03	1.92E+03	1.52E+04	1.60E+04	3.80E+04	1.96E+03	8.52E-02	1.19E-05	2.20E-04	1.31E-03	2.49E-04	2.92E+01	1.07	1.07	3973	88%	88%	27	25
Solid Layer	1.85E+04	1.92E+03	1.52E+04	1.60E+04	3.80E+04	1.96E+03	5.44E+02	1.83E+00	9.27E-02	4.45E-01	7.65E-03	7.11E+01	1.60	1.22	116	33%	88%	28	25
241-AW-103	1.73E+04	3.16E+03	5.15E+04	1.42E+05	1.31E+05	8.09E+03	2.19E+00	2.71E-02	1.86E-02	6.63E-02	6.55E-03	7.15E+01	1.32	1.24	4149	64%	63%	20	22
Supernatant	1.30E+04	1.87E+03	3.35E+04	9.64E+04	1.01E+05	8.09E+03	1.78E-01	4.13E-05	2.05E-05	9.62E-05	8.70E-06	9.06E+01	1.24	1.24	2893	69%	69%	20	22
Solid Layer	2.72E+04	6.11E+03	9.31E+04	2.47E+05	2.01E+05	8.08E+03	6.81E+00	8.94E-02	6.13E-02	2.19E-01	2.16E-02	2.75E+01	1.49	1.42	1256	55%	51%	20	22
241-AW-104	2.85E+04	4.15E+03	7.60E+04	1.14E+05	1.84E+05	2.71E+04	1.08E+00	1.14E-02	2.42E-02	8.63E-02	8.58E-03	1.76E+02	1.38	1.35	4048	54%	64%	27	25
Supernatant	2.54E+04	4.34E+03	7.49E+04	1.13E+05	1.71E+05	2.56E+04	1.21E+00	1.17E-03	1.89E-05	1.06E-04	3.37E-06	1.78E+02	1.35	1.35	3205	55%	66%	26	25
Solid Layer	4.01E+04	3.42E+03	8.04E+04	1.18E+05	2.36E+05	3.29E+04	5.88E-01	5.02E-02	1.16E-01	4.14E-01	4.12E-02	1.69E+02	1.48	1.41	843	50%	55%	28	25
241-AW-105	7.00E+03	5.78E+02	2.96E+03	2.74E+04	2.51E+04	1.76E+02	2.87E+01	3.19E-01	9.72E-02	3.46E-01	3.45E-02	2.13E+01	1.21	1.04	1578	73%	86%	17	19
Supernatant	4.50E+03	5.78E+02	2.96E+03	2.74E+04	2.51E+04	1.76E+02	2.16E-02	6.21E-05	6.28E-05	2.23E-04	2.22E-05	9.72E+00	1.04	1.04	638	90%	90%	18	19
Solid Layer	8.70E+03	5.78E+02	2.96E+03	2.74E+04	2.51E+04	1.76E+02	4.82E+01	5.35E-01	1.63E-01	5.81E-01	5.78E-02	2.91E+01	1.33	1.10	940	63%	84%	17	19
241-AW-106	1.55E+04	2.33E+03	3.26E+04	1.27E+05	1.19E+05	9.77E+03	6.24E+00	6.88E-03	6.30E-03	2.44E-02	1.74E-03	1.52E+02	1.36	1.22	4287	57%	71%	28	21
Supernatant	1.17E+04	2.33E+03	3.26E+04	1.27E+05	1.19E+05	9.77E+03	4.12E-01	5.46E-04	1.35E-04	8.69E-04	1.46E-05	1.03E+02	1.22	1.22	3225	71%	71%	25	21
Solid Layer	2.72E+04	2.33E+03	3.26E+04	1.27E+05	1.19E+05	9.77E+03	2.39E+01	2.61E-02	2.50E-02	9.58E-02	6.97E-03	3.01E+02	1.77	1.25	1062	30%	71%	35	21
241-AY-101	1.10E+04	9.14E+02	1.69E+04	6.02E+04	6.48E+04	2.38E+03	4.02E+02	2.72E+00	4.46E-02	1.46E-01	1.24E-02	3.16E+01	1.20	1.13	3149	74%	81%	28	25
Supernatant	1.25E+04	6.18E+02	9.82E+03	6.80E+04	6.29E+04	2.64E+03	7.98E-01	3.64E-03	7.50E-04	3.35E-03	1.30E-04	2.08E+01	1.13	1.13	2750	82%	82%	27	25
Solid Layer	5.00E+02	2.95E+03	6.53E+04	6.75E+03	7.80E+04	5.30E+02	3.17E+03	2.14E+01	3.47E-01	1.13E+00	9.67E-02	1.06E+02	1.68	1.14	399	40%	81%	34	25
241-AY-102	3.18E+04	1.78E+03	3.52E+04	9.28E+04	1.16E+05	5.87E+03	7.69E+02	8.25E-01	6.12E-02	2.66E-01	1.02E-02	1.27E+02	1.34	1.29	3783	60%	68%	44	40
Supernatant	3.74E+04	1.82E+03	4.02E+04	1.09E+05	1.24E+05	6.85E+03	1.38E-01	1.51E-04	4.01E-05	1.70E-04	2.07E-05	1.01E+02	1.29	1.29	3212	65%	65%	41	40
Solid Layer*	5.52E+02	1.53E+03	7.25E+02	3.88E+02	7.03E+04	3.41E+02	9.26E+03	5.46E+00	4.05E-01	1.76E+00	6.74E-02	2.75E+02	1.59	1.15	571	39%	82%	54	40
241-AZ-101	1.23E+04	5.55E+02	6.65E+04	5.72E+04	1.20E+05	6.55E+03	1.08E+03	4.99E+00	6.49E-02	2.29E-01	2.26E-02	1.33E+03	1.26	1.24	3188	69%	72%	48	46
Supernatant	1.23E+04	5.55E+02	6.65E+04	5.72E+04	1.20E+05	6.55E+03	7.58E-01	1.26E-04	3.51E-04	1.23E-03	1.27E-04	1.36E+03	1.24	1.24	2991	72%	72%	46	46
Solid Layer	1.15E+04	5.55E+02	6.65E+04	5.72E+04	1.20E+05	6.55E+03	1.74E+04	8.07E+01	1.04E+00	3.69E+00	3.63E-01	7.66E+02	1.61	1.22	197	34%	71%	74	46
241-AZ-102	2.10E+03	1.07E+03	3.46E+04	1.37E+04	5.88E+04	5.70E+02	7.69E+02	5.57E+00	6.93E-02	2.63E-01	3.88E-02	8.40E+02	1.16	1.13	3608	80%	84%	52	62
Supernatant	2.06E+03	1.07E+03	3.46E+04	1.37E+04	5.88E+04	5.70E+02	1.79E+00	5.70E-04	1.82E-03	6.67E-03	6.45E-04	8.62E+02	1.13	1.13	3212	84%	84%	48	62
Solid Layer	2.45E+03	1.07E+03	3.46E+04	1.37E+04	5.88E+04	5.70E+02	6.99E+03	5.08E+01	6.16E-01	2.34E+00	3.48E-01	6.63E+02	1.41	1.11	396	55%	84%	82	62
241-SY-101	1.77E+04	9.19E+02	9.50E+03	6.41E+04	5.88E+04	3.63E+03	9.15E+00	6.97E-02	1.61E-03	7.53E-03	2.64E-04	4.73E+01	1.22	1.13	4093	71%	79%	21	18
Supernatant	1.22E+04	9.19E+02	9.50E+03	6.41E+04	5.88E+04	3.63E+03	9.71E-01	4.26E-03	4.73E-04	2.21E-03	7.85E-05	2.35E+01	1.13	1.13	3200	79%	79%	19	18
Solid Layer	3.74E+04	9.19E+02	9.50E+03	6.41E+04	5.88E+04	3.63E+03	3.85E+01	3.04E-01	5.70E-03	2.66E-02	9.28E-04	1.33E+02	1.52	1.28	893	50%	79%	25	18

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (µg/mL)	TOC in liquid [TOC] (µg/mL)	NO ₂ in liquid [NO ₂] (µg/mL)	NO ₃ in liquid [NO ₃] (µg/mL)	Na in liquid [Na] (ug/mL)	Al in liquid [Al] (µg/mL)	⁹⁰ Sr in waste [Sr] (µCi/g)	²⁴¹ Am in waste [Am241] (µCi/g)	²⁴⁰ Pu in waste [Pu240] (µCi/g)	²³⁹ Pu in waste [Pu240] (µCi/g)	²³⁸ Pu in waste [Pu238] (µCi/g)	¹³⁷ Cs in waste [Cs] (µCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-SY-102	1.54E+04	2.08E+03	2.91E+04	8.50E+04	8.79E+04	5.30E+03	7.35E+01	7.48E+00	4.07E-01	1.76E+00	8.35E-02	5.85E+01	1.30	1.13	1791	64%	73%	24	22
Supernatant	1.16E+04	9.72E+02	9.56E+03	5.46E+04	5.46E+04	3.64E+03	1.74E-02	2.39E-05	5.26E-06	2.45E-05	4.16E-06	2.44E+01	1.13	1.13	1039	80%	80%	24	22
Solid Layer	2.06E+04	3.61E+03	5.61E+04	1.27E+05	1.34E+05	7.61E+03	1.75E+02	1.78E+01	9.69E-01	4.20E+00	1.99E-01	1.06E+02	1.54	1.31	752	48%	66%	24	22
241-SY-103	2.99E+04	6.22E+03	1.52E+05	1.68E+05	2.15E+05	3.76E+04	1.57E+01	2.86E-01	5.61E-03	2.62E-02	9.12E-04	2.60E+02	1.53	1.47	2706	40%	43%	31	23
Supernatant	2.99E+04	6.22E+03	1.52E+05	1.68E+05	2.15E+05	3.76E+04	2.05E+00	6.92E-03	7.97E-06	3.71E-05	1.30E-06	2.92E+02	1.47	1.47	1503	43%	43%	28	23
Solid Layer	2.99E+04	6.22E+03	1.52E+05	1.68E+05	2.15E+05	3.76E+04	3.28E+01	6.35E-01	1.26E-02	5.89E-02	2.05E-03	2.20E+02	1.61	1.47	1203	37%	43%	35	23
241-A-101	4.27E+04	3.74E+03	1.65E+05	2.33E+05	2.78E+05	5.18E+04	6.85E+01	2.15E-01	1.09E-02	4.53E-02	2.02E-03	1.71E+02	1.70	1.49	1037	32%	47%	44	28
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.27E+04	3.74E+03	1.65E+05	2.33E+05	2.78E+05	5.18E+04	6.85E+01	2.15E-01	1.09E-02	4.53E-02	2.02E-03	1.71E+02	1.70	1.49	1037	32%	47%	44	28
241-A-102	1.73E+04	4.42E+03	1.72E+05	1.89E+05	2.00E+05	4.09E+04	3.08E+02	9.84E-01	2.87E-01	1.24E+00	5.08E-02	1.63E+02	1.66	1.57	151	38%	46%	31	31
Supernatant	1.73E+04	4.42E+03	1.73E+05	1.89E+05	2.00E+05	4.10E+04	7.06E-01	6.85E-04	5.41E-04	2.34E-03	9.61E-05	3.16E+02	1.57	1.57	12	46%	46%	33	31
Solid Layer	1.73E+04	4.42E+03	1.72E+05	1.89E+05	2.00E+05	4.09E+04	3.34E+02	1.07E+00	3.12E-01	1.35E+00	5.52E-02	1.50E+02	1.67	1.57	139	37%	46%	31	31
241-A-103	4.88E+04	8.31E+03	1.24E+05	2.42E+05	2.35E+05	3.55E+04	6.31E+01	1.20E-01	2.58E-02	1.12E-01	4.47E-03	1.43E+02	1.37	1.51	1434	41%	50%	38	27
Supernatant	4.89E+04	8.29E+03	1.24E+05	2.42E+05	2.35E+05	3.55E+04	1.28E+00	2.07E-03	3.35E-03	1.44E-02	5.92E-04	1.79E+02	1.51	1.51	17	50%	50%	38	27
Solid Layer	4.88E+04	8.31E+03	1.24E+05	2.42E+05	2.35E+05	3.55E+04	6.39E+01	1.21E-01	2.61E-02	1.14E-01	4.52E-03	1.43E+02	1.37	1.51	1417	41%	50%	38	27
241-A-104	4.27E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.29E+04	8.04E+00	1.49E+00	6.79E+00	2.25E-01	6.18E+02	0.95	1.17	106	0%	75%	74	34
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.27E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.29E+04	8.04E+00	1.49E+00	6.79E+00	2.25E-01	6.18E+02	0.95	1.17	106	0%	75%	74	34
241-A-105	#VALUE!	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.35E+04	2.63E+01	6.35E-01	2.60E+00	1.22E-01	5.00E+02	1.54	1.17	139	0%	0%	0	0
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.27E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.35E+04	2.63E+01	6.35E-01	2.60E+00	1.22E-01	5.00E+02	1.54	1.17	139	0%	0%	0	na
241-A-106	4.27E+04	1.10E+04	3.60E+04	7.96E+04	8.32E+04	4.94E+03	9.62E+02	1.14E+00	4.64E-01	2.03E+00	7.93E-02	1.26E+02	1.70	1.17	299	34%	75%	53	39
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.27E+04	1.10E+04	3.60E+04	7.96E+04	8.32E+04	4.94E+03	9.62E+02	1.14E+00	4.64E-01	2.03E+00	7.93E-02	1.26E+02	1.70	1.17	299	34%	75%	53	39
241-AX-101	3.90E+04	3.98E+03	1.73E+05	2.72E+05	2.82E+05	5.03E+04	9.59E+01	1.71E-01	1.17E-02	5.02E-02	2.08E-03	1.76E+02	1.70	1.53	1353	34%	43%	35	28
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.90E+04	3.98E+03	1.73E+05	2.72E+05	2.82E+05	5.03E+04	9.59E+01	1.71E-01	1.17E-02	5.02E-02	2.08E-03	1.76E+02	1.70	1.53	1353	34%	43%	35	28
241-AX-102	3.89E+04	2.30E+04	1.07E+05	1.76E+05	1.98E+05	2.75E+04	1.29E+03	1.20E+01	2.73E-01	8.55E-01	7.90E-02	1.38E+02	1.58	1.39	113	36%	51%	24	24
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.89E+04	2.30E+04	1.07E+05	1.76E+05	1.98E+05	2.75E+04	1.29E+03	1.20E+01	2.73E-01	8.55E-01	7.90E-02	1.38E+02	1.58	1.39	113	36%	51%	24	24
241-AX-103	3.89E+04	4.03E+03	1.22E+05	1.91E+05	2.36E+05	3.79E+04	6.98E+02	1.14E+00	3.66E-02	1.45E-01	6.80E-03	1.81E+02	1.58	1.45	403	44%	49%	37	30
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.89E+04	4.03E+03	1.22E+05	1.91E+05	2.36E+05	3.79E+04	6.98E+02	1.14E+00	3.66E-02	1.45E-01	6.80E-03	1.81E+02	1.58	1.45	403	44%	49%	37	30
241-AX-104	3.89E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.07E+04	1.88E+01	1.31E+00	5.34E+00	2.52E-01	9.86E+02	1.80	1.17	28	8%	75%	32	30
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.89E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.07E+04	1.88E+01	1.31E+00	5.34E+00	2.52E-01	9.86E+02	1.80	1.17	28	8%	75%	32	30
241-B-101	1.70E+04	6.77E+00	1.32E+05	3.56E+05	2.26E+05	7.23E+02	3.26E+02	2.28E+00	1.55E-01	5.02E-01	4.39E-02	3.48E+00	1.51	1.53	411	40%	50%	39	32
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	6.77E+00	1.32E+05	3.56E+05	2.26E+05	7.23E+02	3.26E+02	2.28E+00	1.55E-01	5.02E-01	4.39E-02	3.48E+00	1.51	1.53	411	40%	50%	39	32

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (ug/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kl)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-B-102	1.70E+04	3.38E+00	8.51E+03	2.17E+05	1.13E+05	3.61E+02	7.27E-01	5.17E-04	2.96E-03	2.62E-02	1.94E-04	3.19E+00	1.57	1.26	121	48%	70%	18	24
Supernatant	1.70E+04	3.38E+00	8.47E+03	2.17E+05	1.13E+05	3.61E+02	1.68E+00	1.23E-03	4.69E-04	4.14E-03	3.08E-05	7.09E+00	1.26	1.26	15	70%	70%	18	24
Solid Layer	1.70E+04	3.38E+00	8.52E+03	2.17E+05	1.13E+05	3.61E+02	5.91E-01	4.17E-04	3.32E-03	2.93E-02	2.18E-04	2.64E+00	1.61	1.26	106	45%	70%	18	24
241-B-103	1.70E+04	3.38E+00	8.50E+03	2.18E+05	1.13E+05	3.62E+02	1.40E+00	1.23E-03	1.70E-02	1.50E-01	1.12E-03	2.65E+00	1.61	1.26	211	49%	70%	17	20
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	3.38E+00	8.50E+03	2.18E+05	1.13E+05	3.62E+02	1.40E+00	1.23E-03	1.70E-02	1.50E-01	1.12E-03	2.65E+00	1.61	1.26	211	49%	70%	17	20
241-B-104	1.70E+04	3.38E+00	8.49E+03	2.16E+05	1.13E+05	3.62E+02	1.98E+00	2.44E-03	4.71E-03	4.40E-02	3.03E-04	6.62E+00	1.38	1.26	1417	48%	70%	21	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	3.38E+00	8.49E+03	2.16E+05	1.13E+05	3.62E+02	1.98E+00	2.44E-03	4.71E-03	4.40E-02	3.03E-04	6.62E+00	1.38	1.26	1417	48%	70%	21	22
241-B-105	1.70E+04	3.38E+00	8.51E+03	2.16E+05	1.13E+05	3.62E+02	5.56E-01	7.57E-04	3.87E-03	3.43E-02	2.53E-04	2.34E+00	1.65	1.26	1098	43%	70%	19	18
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	3.38E+00	8.51E+03	2.16E+05	1.13E+05	3.62E+02	5.56E-01	7.57E-04	3.87E-03	3.43E-02	2.53E-04	2.34E+00	1.65	1.26	1098	43%	70%	19	18
241-B-106	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.60E+02	4.88E+01	9.87E-03	3.12E-03	2.90E-02	2.02E-04	1.55E+01	1.38	1.26	464	60%	67%	23	22
Supernatant	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.60E+02	1.68E+00	1.23E-03	4.68E-04	4.15E-03	3.08E-05	7.08E+00	1.26	1.26	4	67%	67%	18	22
Solid Layer	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.60E+02	4.92E+01	9.95E-03	3.14E-03	2.92E-02	2.04E-04	1.55E+01	1.38	1.19	460	60%	67%	23	22
241-B-107	1.70E+04	5.04E+00	6.51E+03	3.31E+05	1.46E+05	2.01E+01	3.22E+00	4.59E-03	4.74E-03	4.03E-02	3.27E-04	1.10E+01	1.63	1.34	611	40%	58%	16	25
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	5.04E+00	6.51E+03	3.31E+05	1.46E+05	2.01E+01	3.22E+00	4.59E-03	4.74E-03	4.03E-02	3.27E-04	1.10E+01	1.63	1.34	611	40%	58%	16	25
241-B-108	1.70E+04	3.71E+00	5.38E+04	3.76E+05	1.74E+05	8.98E+02	1.56E+00	1.80E-04	4.83E-04	3.29E-03	3.91E-05	1.26E+01	1.70	1.38	350	35%	70%	21	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	3.71E+00	5.38E+04	3.76E+05	1.74E+05	8.98E+02	1.56E+00	1.80E-04	4.83E-04	3.29E-03	3.91E-05	1.26E+01	1.70	1.38	350	35%	70%	21	22
241-B-109	1.70E+04	3.39E+00	8.51E+03	2.17E+05	1.13E+05	3.61E+02	4.34E-01	7.25E-04	3.33E-03	2.47E-02	2.54E-04	1.49E+00	1.82	1.26	475	39%	70%	20	20
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	3.39E+00	8.51E+03	2.17E+05	1.13E+05	3.61E+02	4.34E-01	7.25E-04	3.33E-03	2.47E-02	2.54E-04	1.49E+00	1.82	1.26	475	39%	70%	20	20
241-B-110	1.70E+04	5.55E+03	3.95E+04	7.78E+04	9.55E+04	1.04E+04	7.74E+01	7.21E-02	1.07E-02	1.01E-01	3.12E-03	1.09E+01	1.36	1.19	929	58%	76%	21	23
Supernatant	1.70E+04	5.55E+03	3.95E+04	7.78E+04	9.55E+04	1.04E+04	1.94E+00	5.67E-03	9.83E-04	4.24E-03	1.77E-04	1.18E+01	1.19	1.19	4	76%	76%	21	23
Solid Layer	1.70E+04	5.55E+03	3.95E+04	7.78E+04	9.55E+04	1.04E+04	7.77E+01	7.24E-02	1.08E-02	1.01E-01	3.13E-03	1.09E+01	1.36	1.01	925	58%	76%	21	23
241-B-111	1.70E+04	5.55E+03	3.95E+04	7.78E+04	9.55E+04	1.04E+04	1.91E+02	8.48E-02	1.09E-02	8.60E-02	2.95E-03	1.23E+02	1.27	1.19	914	63%	76%	25	24
Supernatant	1.70E+04	5.55E+03	3.95E+04	7.78E+04	9.55E+04	1.04E+04	1.94E+00	5.67E-03	9.83E-04	4.24E-03	1.77E-04	1.18E+01	1.19	1.19	4	76%	76%	24	24
Solid Layer	1.70E+04	5.55E+03	3.95E+04	7.78E+04	9.55E+04	1.04E+04	1.92E+02	8.51E-02	1.09E-02	8.64E-02	2.96E-03	1.24E+02	1.27	1.01	910	63%	76%	25	24
241-B-112	1.70E+04	1.82E+04	1.17E+05	2.17E+05	2.55E+05	4.73E+04	4.00E+00	1.44E-03	3.93E-04	2.59E-03	4.61E-05	4.00E+01	1.49	1.51	132	41%	46%	25	22
Supernatant	1.70E+04	1.82E+04	1.17E+05	2.17E+05	2.55E+05	4.73E+04	1.53E+00	4.47E-03	8.01E-04	3.34E-03	1.29E-04	1.01E+02	1.51	1.51	11	46%	46%	25	22
Solid Layer	1.70E+04	1.82E+04	1.17E+05	2.17E+05	2.55E+05	4.73E+04	4.23E+00	1.16E-03	3.56E-04	2.52E-03	3.86E-05	3.44E+01	1.49	1.51	121	41%	46%	25	22
241-B-201	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.71E+00	2.84E-02	4.33E-02	7.51E-01	6.28E-03	1.36E-01	1.26	1.17	111	64%	75%	17	19
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.71E+00	2.84E-02	4.33E-02	7.51E-01	6.28E-03	1.36E-01	1.26	1.17	111	64%	75%	17	19
241-B-202	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.00E+00	6.67E-02	2.17E-02	1.28E-01	2.03E-03	7.67E-02	1.22	1.17	108	76%	83%	18	20
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.00E+00	6.67E-02	2.17E-02	1.28E-01	2.03E-03	7.67E-02	1.22	1.17	108	76%	83%	18	20

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (µg/mL)	TOC in liquid [TOC] (µg/mL)	NO ₂ in liquid [NO ₂] (µg/mL)	NO ₃ in liquid [NO ₃] (µg/mL)	Na in liquid [Na] (ug/mL)	Al in liquid [Al] (µg/mL)	⁹⁰ Sr in waste [Sr] (µCi/g)	²⁴¹ Am in waste [Am241] (µCi/g)	²⁴⁰ Pu in waste [Pu240] (µCi/g)	²³⁹ Pu in waste [Pu240] (µCi/g)	²³⁸ Pu in waste [Pu238] (µCi/g)	¹³⁷ Cs in waste [Cs] (µCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-B-203	1.70E+04	9.60E+01	1.57E+03	5.65E+04	3.12E+04	0.00E+00	6.86E-02	3.42E-02	2.92E-02	2.31E-01	2.00E-03	6.55E-03	1.19	1.05	190	76%	89%	19	12
Supernatant	1.70E+04	9.60E+01	1.57E+03	5.65E+04	3.12E+04	0.00E+00	7.76E-05	4.07E-05	4.86E-04	3.83E-03	3.31E-05	9.00E-05	1.05	1.05	2	89%	89%	20	12
Solid Layer	1.70E+04	9.60E+01	1.57E+03	5.65E+04	3.12E+04	0.00E+00	6.93E-02	3.46E-02	2.95E-02	2.33E-01	2.02E-03	6.62E-03	1.19	1.05	188	76%	89%	19	12
241-B-204	1.70E+04	7.53E+01	1.36E+03	3.47E+04	2.78E+04	0.00E+00	2.58E-03	3.78E-02	2.47E-02	1.96E-01	1.69E-03	2.57E-02	1.19	1.05	187	77%	91%	19	20
Supernatant	1.70E+04	7.53E+01	1.36E+03	3.47E+04	2.78E+04	0.00E+00	3.46E-05	1.56E-07	4.70E-06	6.98E-05	2.36E-07	3.97E-05	1.05	1.05	3	91%	91%	19	20
Solid Layer	1.70E+04	7.53E+01	1.36E+03	3.47E+04	2.78E+04	0.00E+00	2.62E-03	3.84E-02	2.51E-02	1.99E-01	1.72E-03	2.62E-02	1.19	1.05	184	77%	91%	19	20
241-BX-101	1.70E+04	4.98E+03	6.43E+04	1.21E+05	1.42E+05	5.17E+03	2.55E+02	1.37E-01	1.32E-01	6.39E-01	2.11E-02	9.08E+01	1.68	1.28	180	16%	75%	23	23
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	4.98E+03	6.43E+04	1.21E+05	1.42E+05	5.17E+03	2.55E+02	1.37E-01	1.32E-01	6.39E-01	2.11E-02	9.08E+01	1.68	1.28	180	16%	75%	23	23
241-BX-102	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.14E+02	3.48E-03	3.51E-03	1.67E-02	3.38E-04	3.40E+01	1.12	1.17	298	32%	75%	22	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.14E+02	3.48E-03	3.51E-03	1.67E-02	3.38E-04	3.40E+01	1.12	1.17	298	32%	75%	22	22
241-BX-103	1.70E+04	3.64E+03	1.37E+04	4.44E+04	3.88E+04	1.77E+04	3.85E+02	2.72E-01	4.07E-01	1.80E+00	4.02E-02	4.17E+01	1.56	1.07	285	53%	78%	21	23
Supernatant	1.70E+04	3.64E+03	1.37E+04	4.44E+04	3.88E+04	1.77E+04	4.88E-01	5.42E-03	1.16E-03	4.92E-03	1.16E-04	5.74E-01	1.07	1.07	50	78%	78%	23	23
Solid Layer	1.70E+04	3.64E+03	1.37E+04	4.44E+04	3.88E+04	1.77E+04	4.66E+02	3.29E-01	4.94E-01	2.18E+00	4.88E-02	5.05E+01	1.66	1.11	235	50%	78%	21	23
241-BX-104	1.70E+04	3.19E+03	6.37E+04	1.34E+05	1.40E+05	2.84E+03	1.88E+02	5.21E-01	4.38E-02	3.39E-01	3.36E-03	6.17E+01	1.67	1.28	380	28%	59%	30	25
Supernatant	1.70E+04	3.19E+03	6.37E+04	1.34E+05	1.40E+05	2.84E+03	1.32E+00	2.10E-04	3.19E-05	1.68E-04	2.61E-06	9.66E+01	1.28	1.28	11	59%	59%	30	25
Solid Layer	1.70E+04	3.19E+03	6.37E+04	1.34E+05	1.40E+05	2.84E+03	1.94E+02	5.37E-01	4.51E-02	3.49E-01	3.46E-03	6.07E+01	1.68	1.28	369	27%	59%	30	25
241-BX-105	1.70E+04	9.44E+03	4.00E+04	1.17E+05	1.24E+05	5.94E+03	1.71E+02	5.63E-02	1.81E-02	9.07E-02	1.93E-03	7.45E+01	1.67	1.29	272	17%	69%	23	23
Supernatant	1.70E+04	9.44E+03	4.00E+04	1.17E+05	1.24E+05	5.94E+03	5.81E+00	1.91E-02	2.53E-03	1.08E-02	2.54E-04	9.22E+01	1.29	1.29	18	69%	69%	20	23
Solid Layer	1.70E+04	9.44E+03	4.00E+04	1.17E+05	1.24E+05	5.94E+03	1.83E+02	5.90E-02	1.92E-02	9.64E-02	2.05E-03	7.32E+01	1.69	1.29	254	14%	69%	24	23
241-BX-106	1.70E+04	1.82E+04	1.17E+05	2.17E+05	2.55E+05	4.72E+04	3.13E+02	2.50E-01	4.01E-02	1.96E-01	5.18E-03	7.98E+01	1.62	1.17	143	40%	46%	20	27
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	1.82E+04	1.17E+05	2.17E+05	2.55E+05	4.72E+04	3.13E+02	2.50E-01	4.01E-02	1.96E-01	5.18E-03	7.98E+01	1.62	1.51	143	40%	46%	20	27
241-BX-107	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	7.51E+00	1.30E-02	5.61E-03	5.16E-02	3.63E-04	1.34E+01	1.44	1.17	1313	51%	75%	19	19
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	7.51E+00	1.30E-02	5.61E-03	5.16E-02	3.63E-04	1.34E+01	1.44	1.17	1313	51%	75%	19	19
241-BX-108	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.29E+02	1.87E-02	5.16E-03	4.79E-02	3.34E-04	2.26E+01	1.46	1.17	119	17%	75%	20	23
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.29E+02	1.87E-02	5.16E-03	4.79E-02	3.34E-04	2.26E+01	1.46	1.17	119	17%	75%	20	23
241-BX-109	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.07E+02	5.36E-03	1.05E-03	9.73E-03	6.79E-05	1.08E+01	1.52	1.17	730	51%	72%	26	24
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.07E+02	5.36E-03	1.05E-03	9.73E-03	6.79E-05	1.08E+01	1.52	1.17	730	51%	72%	26	24
241-BX-110	1.70E+04	1.52E+04	5.21E+04	4.12E+05	2.23E+05	4.40E+03	7.82E+00	4.73E-03	1.80E-03	1.51E-02	1.45E-04	4.93E+01	1.67	1.44	812	42%	53%	22	18
Supernatant	1.70E+04	1.52E+04	5.22E+04	4.12E+05	2.24E+05	4.40E+03	1.33E+03	3.90E-03	7.00E-03	2.92E-02	1.12E-04	8.85E+01	1.44	1.44	5	53%	53%	20	18
Solid Layer	1.70E+04	1.52E+04	5.21E+04	4.12E+05	2.23E+05	4.40E+03	7.86E+00	4.73E-03	1.81E-03	1.52E-02	1.45E-04	4.90E+01	1.67	1.44	807	42%	53%	22	18
241-BX-111	1.70E+04	1.70E+03	1.06E+05	1.85E+05	2.26E+05	4.87E+04	1.15E+01	3.43E-03	1.64E-03	1.45E-02	1.17E-04	6.47E+01	1.45	1.45	713	25%	51%	19	19
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	1.70E+03	1.06E+05	1.85E+05	2.26E+05	4.87E+04	1.15E+01	3.43E-03	1.64E-03	1.45E-02	1.17E-04	6.47E+01	1.45	1.45	713	25%	51%	19	19

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (ug/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-BX-112	1.70E+04	0.00E+00	3.52E+04	9.86E+04	7.78E+04	4.78E+01	5.77E+00	2.39E-02	1.57E-02	1.44E-01	1.01E-03	4.03E+01	1.31	1.18	622	63%	68%	21	19
Supernatant	1.70E+04	0.00E+00	3.52E+04	9.86E+04	7.78E+04	4.78E+01	6.22E-01	1.37E-04	1.92E-04	1.35E-03	1.34E-05	7.31E-01	1.18	1.18	5	68%	68%	19	19
Solid Layer	1.70E+04	0.00E+00	3.52E+04	9.86E+04	7.78E+04	4.78E+01	5.81E+00	2.41E-02	1.58E-02	1.45E-01	1.02E-03	4.06E+01	1.31	1.18	617	63%	68%	21	19
241-BY-101	3.83E+04	1.82E+04	1.17E+05	2.17E+05	2.56E+05	4.73E+04	5.71E+01	9.97E-03	1.24E-03	1.08E-02	9.44E-05	9.05E+01	1.84	1.51	1400	22%	46%	24	24
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.83E+04	1.82E+04	1.17E+05	2.17E+05	2.56E+05	4.73E+04	5.71E+01	9.97E-03	1.24E-03	1.08E-02	9.44E-05	9.05E+01	1.84	1.51	1400	22%	46%	24	24
241-BY-102	3.83E+04	1.55E+03	8.41E+04	1.48E+05	2.34E+05	5.66E+04	1.05E+01	5.05E-02	5.15E-03	2.16E-02	8.32E-04	6.65E+01	1.57	1.44	1054	31%	51%	22	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.83E+04	1.55E+03	8.41E+04	1.48E+05	2.34E+05	5.66E+04	1.05E+01	5.05E-02	5.15E-03	2.16E-02	8.32E-04	6.65E+01	1.57	1.46	1054	31%	51%	22	22
241-BY-103	3.15E+04	1.59E+03	4.49E+04	1.41E+05	1.80E+05	3.46E+04	1.13E+01	1.16E-02	1.34E-03	5.61E-03	2.05E-04	6.69E+01	1.66	1.29	1564	28%	59%	25	21
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.15E+04	1.59E+03	4.49E+04	1.41E+05	1.80E+05	3.46E+04	1.13E+01	1.16E-02	1.34E-03	5.61E-03	2.05E-04	6.69E+01	1.66	1.29	1564	28%	59%	25	21
241-BY-104	3.83E+04	2.37E+03	1.11E+05	2.07E+05	2.48E+05	7.19E+04	1.38E+02	5.52E-02	5.83E-03	2.94E-02	8.46E-04	8.65E+01	1.71	1.51	1533	26%	49%	41	26
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.83E+04	2.37E+03	1.11E+05	2.07E+05	2.48E+05	7.19E+04	1.38E+02	5.52E-02	5.83E-03	2.94E-02	8.46E-04	8.65E+01	1.71	1.51	1533	26%	49%	41	26
241-BY-105	3.82E+04	2.43E+03	6.86E+04	1.99E+05	2.08E+05	3.92E+04	4.26E+01	3.61E-02	3.91E-03	2.38E-02	4.88E-04	4.65E+01	1.80	1.44	1821	18%	51%	31	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.82E+04	2.43E+03	6.86E+04	1.99E+05	2.08E+05	3.92E+04	4.26E+01	3.61E-02	3.91E-03	2.38E-02	4.88E-04	4.65E+01	1.80	1.44	1821	18%	51%	31	22
241-BY-106	3.57E+04	2.67E+03	7.83E+04	1.10E+05	1.64E+05	3.98E+04	5.09E+01	1.44E-02	1.20E-03	8.72E-03	1.23E-04	1.12E+02	1.65	1.31	1623	27%	59%	37	37
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.57E+04	2.67E+03	7.83E+04	1.10E+05	1.64E+05	3.98E+04	5.09E+01	1.44E-02	1.20E-03	8.72E-03	1.23E-04	1.12E+02	1.65	1.31	1623	27%	59%	37	37
241-BY-107	3.83E+04	2.40E+03	1.17E+05	1.31E+05	2.43E+05	5.12E+04	4.29E+01	1.18E-02	1.33E-03	8.10E-03	1.66E-04	1.15E+02	1.69	1.46	1028	38%	49%	36	28
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.83E+04	2.40E+03	1.17E+05	1.31E+05	2.43E+05	5.12E+04	4.29E+01	1.18E-02	1.33E-03	8.10E-03	1.66E-04	1.15E+02	1.69	1.46	1028	38%	49%	36	28
241-BY-108	3.83E+04	2.37E+03	7.85E+04	2.94E+05	2.82E+05	3.63E+04	1.03E+02	3.05E-02	3.43E-03	2.26E-02	3.96E-04	4.21E+01	1.48	1.33	841	27%	33%	40	31
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.83E+04	2.37E+03	7.85E+04	2.94E+05	2.82E+05	3.63E+04	1.03E+02	3.05E-02	3.43E-03	2.26E-02	3.96E-04	4.21E+01	1.48	1.33	841	27%	33%	40	31
241-BY-109	3.83E+04	1.88E+03	8.29E+04	1.90E+05	2.10E+05	3.88E+04	7.75E+00	3.69E-02	4.35E-03	1.82E-02	6.67E-04	4.98E+01	1.71	1.50	1086	42%	53%	18	17
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.83E+04	1.88E+03	8.29E+04	1.90E+05	2.10E+05	3.88E+04	7.75E+00	3.69E-02	4.35E-03	1.82E-02	6.67E-04	4.98E+01	1.71	1.50	1086	42%	53%	18	17
241-BY-110	3.83E+04	1.94E+04	1.24E+05	1.24E+05	2.54E+05	6.58E+04	7.28E+01	2.76E-02	3.82E-03	2.22E-02	4.97E-04	8.75E+01	1.57	1.44	1384	28%	40%	37	24
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0.000	0%	0%	0	0
Solid Layer	3.83E+04	1.94E+04	1.24E+05	1.24E+05	2.54E+05	6.58E+04	7.28E+01	2.76E-02	3.82E-03	2.22E-02	4.97E-04	8.75E+01	1.57	1.44	1384	28%	40%	37	24
241-BY-111	3.83E+04	1.28E+03	5.46E+04	2.01E+05	2.17E+05	4.30E+04	1.02E+01	6.14E-02	6.28E-03	2.63E-02	1.01E-03	5.96E+01	1.67	1.42	1523	35%	54%	30	25
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.83E+04	1.28E+03	5.46E+04	2.01E+05	2.17E+05	4.30E+04	1.02E+01	6.14E-02	6.28E-03	2.63E-02	1.01E-03	5.96E+01	1.67	1.42	1523	35%	54%	30	25
241-BY-112	3.83E+04	1.72E+03	1.41E+05	1.90E+05	2.44E+05	5.54E+04	1.18E+01	4.31E-02	4.40E-03	1.84E-02	7.09E-04	6.33E+01	1.74	1.47	1083	30%	49%	32	25
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.83E+04	1.72E+03	1.41E+05	1.90E+05	2.44E+05	5.54E+04	1.18E+01	4.31E-02	4.40E-03	1.84E-02	7.09E-04	6.33E+01	1.74	1.47	1083	30%	49%	32	25

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (μg/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/mL)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-C-101	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	6.42E+01	1.43E-01	1.40E-01	7.86E-01	1.11E-02	5.06E+01	1.78	1.17	333	23%	74%	32	32
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	6.42E+01	1.43E-01	1.40E-01	7.86E-01	1.11E-02	5.06E+01	1.78	1.17	333	23%	74%	32	32
241-C-102	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.39E+01	5.08E-01	4.05E-01	1.69E+00	4.38E-02	1.29E+01	1.68	1.17	1196	43%	75%	28	26
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.39E+01	5.08E-01	4.05E-01	1.69E+00	4.38E-02	1.29E+01	1.68	1.17	1196	43%	75%	28	26
241-C-103	1.70E+04	5.30E-01	3.85E+01	5.13E+01	1.26E+02	1.20E+00	6.46E+02	3.20E-01	6.75E-02	3.24E-01	9.61E-02	5.70E+01	1.55	0.98	10	14%	98%	43	25
Supernatant	1.01E-01	5.30E-01	3.85E+01	5.13E+01	1.26E+02	1.20E+00	7.30E-02	5.08E-06	1.60E-06	1.03E-05	2.90E-06	1.07E-01	0.98	0.98	1	98%	98%	43	25
Solid Layer	1.70E+04	5.30E-01	3.85E+01	5.13E+01	1.26E+02	1.20E+00	7.16E+02	3.54E-01	7.48E-02	3.59E-01	1.06E-01	6.31E+01	1.61	1.11	9	9%	98%	43	25
241-C-104	1.70E+04	5.60E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.71E+02	3.85E+00	8.10E-01	3.14E+00	1.39E-01	5.38E+01	1.68	1.17	980	48%	81%	36	34
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	5.60E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.71E+02	3.85E+00	8.10E-01	3.14E+00	1.39E-01	5.38E+01	1.68	1.17	980	48%	81%	36	34
241-C-105	1.70E+04	2.87E+03	3.70E+04	3.43E+04	1.14E+05	9.02E+00	5.69E+02	1.54E+00	5.03E-01	2.56E+00	4.11E-02	9.85E+01	1.55	1.23	500	28%	67%	46	41
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.87E+03	3.70E+04	3.43E+04	1.14E+05	9.02E+00	5.69E+02	1.54E+00	5.03E-01	2.56E+00	4.11E-02	9.85E+01	1.55	1.23	500	28%	67%	46	41
241-C-106	7.02E+03	3.32E+02	5.43E+01	6.02E+01	9.78E+03	9.38E+01	4.04E+03	3.99E+00	2.18E-01	1.02E+00	1.65E-01	8.86E+01	1.54	1.02	10	43%	98%	30	25
Supernatant	7.02E+03	3.32E+02	5.43E+01	6.02E+01	9.78E+03	9.38E+01	4.32E-02	4.11E-06	8.49E-07	3.99E-06	6.39E-07	4.26E-01	1.02	1.02	0.3	98%	98%	31.0	25.2
Solid Layer	7.02E+03	3.32E+02	5.43E+01	6.02E+01	9.78E+03	9.38E+01	4.17E+03	4.11E+00	2.25E-01	1.05E+00	1.70E-01	9.14E+01	1.56	1.14	10.2	42%	98%	29.6	25.2
241-C-107	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.44E+03	4.62E+00	2.44E-01	1.51E+00	3.05E-02	4.07E+01	1.55	1.17	935	48%	79%	42	40
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.44E+03	4.62E+00	2.44E-01	1.51E+00	3.05E-02	4.07E+01	1.55	1.17	935	48%	79%	42	40
241-C-108	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.16E+01	2.90E-02	9.17E-04	8.46E-03	5.93E-05	2.10E+02	1.48	1.17	95	38%	75%	25	26
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.16E+01	2.90E-02	9.17E-04	8.46E-03	5.93E-05	2.10E+02	1.48	1.17	95	38%	75%	25	26
241-C-109	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	6.80E+02	1.35E-01	3.02E-02	1.76E-01	4.44E-03	4.65E+02	1.55	1.17	240	39%	75%	25	25
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	6.80E+02	1.35E-01	3.02E-02	1.76E-01	4.44E-03	4.65E+02	1.55	1.17	240	39%	75%	25	25
241-C-110	1.70E+04	5.80E+02	4.60E+03	6.03E+04	3.05E+04	2.09E+02	3.82E+00	4.27E-02	7.81E-03	7.18E-02	5.05E-04	1.50E+01	1.34	1.10	674	60%	83%	20	22
Supernatant	1.70E+04	5.80E+02	4.60E+03	6.03E+04	3.05E+04	2.09E+02	1.92E-02	1.72E-05	1.01E-04	1.50E-03	5.07E-06	3.41E+00	1.10	1.10	4	83%	83%	21	22
Solid Layer	1.70E+04	5.80E+02	4.60E+03	6.03E+04	3.05E+04	2.09E+02	3.84E+00	4.30E-02	7.85E-03	7.22E-02	5.08E-04	1.50E+01	1.34	1.10	670	60%	83%	20	22
241-C-111	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.70E+03	5.67E-01	9.85E-02	5.06E-01	9.30E-03	5.89E+01	1.55	1.17	217	36%	75%	23	24
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.70E+03	5.67E-01	9.85E-02	5.06E-01	9.30E-03	5.89E+01	1.55	1.17	217	36%	75%	23	24
241-C-112	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	8.31E+02	6.53E-01	1.62E-02	1.27E-01	1.09E-02	3.69E+02	1.58	1.17	393	52%	75%	27	27
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	8.31E+02	6.53E-01	1.62E-02	1.27E-01	1.09E-02	3.69E+02	1.58	1.17	393	52%	75%	27	27
241-C-201	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.65E+02	2.54E+00	3.57E+00	1.66E+01	5.26E-01	1.06E+01	1.74	1.00	1	25%	100%	16	20
Supernatant	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.00	1.00	0	100%	100%	16	20
Solid Layer	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.68E+02	2.58E+00	3.62E+00	1.68E+01	5.33E-01	1.07E+01	1.75	1.00	1	24%	100%	16	20

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (μg/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-C-202	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.00E+02	1.18E+00	3.16E+00	1.47E+01	4.66E-01	9.16E+00	1.74	1.00	1	25%	100%	16	19
Supernatant	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.00	1.00	0	100%	100%	16	19
Solid Layer	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.08E+02	1.20E+00	3.21E+00	1.49E+01	4.73E-01	9.31E+00	1.75	1.00	1	24%	100%	16	19
241-C-203	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.33E+00	2.88E-02	1.04E-01	4.81E-01	1.53E-02	1.30E+01	1.84	1.00	0.5	39%	100%	15	19
Supernatant	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.00	1.00	0.05	100%	100%	19	19
Solid Layer	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.57E+00	3.17E-02	1.14E-01	5.29E-01	1.69E-02	1.43E+01	1.93	1.00	0.48	36%	100%	15	19
241-C-204	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.66E+02	3.46E-03	2.31E-03	1.07E-02	3.41E-04	6.50E+00	1.75	1.00	1	39%	100%	17	16
Supernatant	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.00	1.00	0	100%	100%	17	16
Solid Layer	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.69E+02	3.53E-03	2.36E-03	1.10E-02	3.49E-04	6.64E+00	1.77	1.17	1	38%	100%	17	16
241-S-101	4.76E+04	1.79E+03	1.13E+05	2.14E+05	2.22E+05	2.99E+04	2.06E+02	1.00E-01	2.87E-02	1.46E-01	3.05E-03	1.12E+02	1.65	1.47	1332	39%	51%	39	31
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.76E+04	1.79E+03	1.13E+05	2.14E+05	2.22E+05	2.99E+04	2.06E+02	1.00E-01	2.87E-02	1.46E-01	3.05E-03	1.12E+02	1.65	1.47	1332	39%	51%	39	31
241-S-102	3.76E+04	3.76E+03	1.27E+05	1.55E+05	2.34E+05	5.62E+04	2.51E+02	6.26E-02	1.20E-02	5.90E-02	1.47E-03	7.84E+01	1.80	1.46	126	28%	49%	28	25
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.76E+04	3.76E+03	1.27E+05	1.55E+05	2.34E+05	5.62E+04	2.51E+02	6.26E-02	1.20E-02	5.90E-02	1.47E-03	7.84E+01	1.80	1.46	126	28%	49%	28	25
241-S-103	3.64E+04	4.68E+03	1.47E+05	2.16E+05	2.28E+05	3.20E+04	2.87E+01	9.36E-02	1.36E-02	6.51E-02	1.94E-03	1.35E+02	1.61	1.45	896	36%	50%	25	25
Supernatant	3.65E+04	4.68E+03	1.47E+05	2.16E+05	2.28E+05	3.20E+04	2.55E-01	8.14E-04	8.45E-06	3.95E-05	1.38E-06	2.22E+02	1.45	1.45	4	50%	50%	25	25
Solid Layer	3.64E+04	4.68E+03	1.47E+05	2.16E+05	2.28E+05	3.20E+04	2.88E+01	9.40E-02	1.36E-02	6.54E-02	1.95E-03	1.35E+02	1.61	1.45	892	36%	50%	25	25
241-S-104	5.10E+03	3.96E+02	3.82E+04	2.68E+05	1.98E+05	1.19E+04	2.14E+02	1.07E-01	3.83E-02	1.88E-01	5.38E-03	4.27E+01	1.67	1.37	1090	39%	55%	39	31
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	5.10E+03	3.96E+02	3.82E+04	2.68E+05	1.98E+05	1.19E+04	2.14E+02	1.07E-01	3.83E-02	1.88E-01	5.38E-03	4.27E+01	1.67	1.37	1090	39%	55%	39	31
241-S-105	8.18E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	2.56E+00	3.05E-03	7.25E-04	3.63E-03	8.19E-05	3.42E+01	1.66	1.45	1536	8%	49%	26	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	8.18E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	2.56E+00	3.05E-03	7.25E-04	3.63E-03	8.19E-05	3.42E+01	1.66	1.45	1536	8%	49%	26	22
241-S-106	5.55E+04	1.98E+03	1.04E+05	2.36E+05	2.44E+05	3.80E+04	1.23E+01	1.96E-02	1.32E-03	6.04E-03	2.13E-04	9.13E+01	1.72	1.43	1723	34%	54%	23	23
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	5.55E+04	1.98E+03	1.04E+05	2.36E+05	2.44E+05	3.80E+04	1.23E+01	1.96E-02	1.32E-03	6.04E-03	2.13E-04	9.13E+01	1.72	1.43	1723	34%	54%	23	23
241-S-107	2.99E+04	1.18E+03	7.11E+04	1.14E+05	1.56E+05	1.07E+04	1.30E+02	3.10E-01	1.06E-01	5.04E-01	1.22E-02	6.77E+01	1.78	1.31	1356	34%	64%	33	28
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	2.99E+04	1.18E+03	7.11E+04	1.14E+05	1.56E+05	1.07E+04	1.30E+02	3.10E-01	1.06E-01	5.04E-01	1.22E-02	6.77E+01	1.78	1.31	1356	34%	64%	33	28
241-S-108	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.77E+04	2.10E+01	7.72E-02	5.96E-03	2.79E-02	9.05E-04	9.60E+01	1.68	1.45	2082	30%	49%	27	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.77E+04	2.10E+01	7.72E-02	5.96E-03	2.79E-02	9.05E-04	9.60E+01	1.68	1.45	2082	30%	49%	27	22
241-S-109	8.19E+04	1.11E+03	8.49E+04	1.32E+05	2.19E+05	4.59E+04	1.48E+01	1.15E-02	2.83E-03	1.44E-02	2.92E-04	1.30E+01	1.66	1.49	2017	11%	53%	26	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	8.19E+04	1.11E+03	8.49E+04	1.32E+05	2.19E+05	4.59E+04	1.48E+01	1.15E-02	2.83E-03	1.44E-02	2.92E-04	1.30E+01	1.66	1.49	2017	11%	53%	26	22
241-S-110	8.18E+04	2.28E+03	8.58E+04	2.17E+05	2.11E+05	3.10E+04	9.40E+01	1.23E-01	2.50E-02	1.26E-01	2.63E-03	7.27E+01	1.66	1.43	1473	20%	49%	42	30
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	8.18E+04	2.28E+03	8.58E+04	2.17E+05	2.11E+05	3.10E+04	9.40E+01	1.23E-01	2.50E-02	1.26E-01	2.63E-03	7.27E+01	1.66	1.43	1473	20%	49%	42	30

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (μg/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-S-111	5.10E+04	1.49E+03	8.39E+04	1.93E+05	2.23E+05	3.64E+04	1.83E+02	1.48E-02	1.44E-03	6.90E-03	1.96E-04	1.03E+02	1.55	1.45	1397	29%	51%	28	24
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	5.10E+04	1.49E+03	8.39E+04	1.93E+05	2.23E+05	3.64E+04	1.83E+02	1.48E-02	1.44E-03	6.90E-03	1.96E-04	1.03E+02	1.55	1.45	1397	29%	51%	28	24
241-S-112	4.86E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.97E+02	4.97E-01	5.37E-02	3.03E-01	6.84E-03	1.60E+01	1.67	1.45	9	38%	53%	29	21
Supernatant	4.86E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.00	1.00	0	100%	100%	29	21
Solid Layer	4.86E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.30E+02	5.24E-01	5.66E-02	3.19E-01	7.21E-03	1.68E+01	1.71	1.45	9	36%	52%	29	21
241-SX-101	4.88E+04	3.35E+02	7.49E+04	1.08E+05	2.42E+05	8.00E+04	1.13E+02	1.91E-01	3.39E-02	1.66E-01	4.59E-03	1.00E+02	1.68	1.48	1584	27%	49%	47	36
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.88E+04	3.35E+02	7.49E+04	1.08E+05	2.42E+05	8.00E+04	1.13E+02	1.91E-01	3.39E-02	1.66E-01	4.59E-03	1.00E+02	1.68	1.48	1584	27%	49%	47	36
241-SX-102	5.01E+04	1.51E+03	1.51E+05	1.57E+05	2.35E+05	4.56E+04	8.21E+01	1.22E-01	1.21E-02	5.77E-02	1.69E-03	1.40E+02	1.70	1.46	1292	39%	48%	51	31
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	5.01E+04	1.51E+03	1.51E+05	1.57E+05	2.35E+05	4.56E+04	8.21E+01	1.22E-01	1.21E-02	5.77E-02	1.69E-03	1.40E+02	1.70	1.46	1292	39%	48%	51	31
241-SX-103	4.52E+04	3.38E+03	1.57E+05	1.56E+05	2.40E+05	4.44E+04	1.54E+02	2.16E-01	1.56E-02	7.61E-02	2.05E-03	1.23E+02	1.73	1.47	1926	30%	47%	59	27
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.52E+04	3.38E+03	1.57E+05	1.56E+05	2.40E+05	4.44E+04	1.54E+02	2.16E-01	1.56E-02	7.61E-02	2.05E-03	1.23E+02	1.73	1.47	1926	30%	47%	59	27
241-SX-104	3.05E+04	2.13E+03	1.17E+05	2.90E+05	2.50E+05	3.56E+04	1.42E+02	1.26E-01	3.42E-02	1.74E-01	3.52E-03	8.70E+01	1.69	1.47	1688	28%	45%	49	60
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.05E+04	2.13E+03	1.17E+05	2.90E+05	2.50E+05	3.56E+04	1.42E+02	1.26E-01	3.42E-02	1.74E-01	3.52E-03	8.70E+01	1.69	1.47	1688	28%	45%	49	60
241-SX-105	4.10E+04	3.26E+03	1.43E+05	1.64E+05	2.36E+05	4.41E+04	2.52E+02	2.57E-01	5.74E-02	2.89E-01	6.66E-03	9.47E+01	1.63	1.47	1422	35%	43%	61	36
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.10E+04	3.26E+03	1.43E+05	1.64E+05	2.36E+05	4.41E+04	2.52E+02	2.57E-01	5.74E-02	2.89E-01	6.66E-03	9.47E+01	1.63	1.47	1422	35%	43%	61	36
241-SX-106	3.20E+04	3.14E+03	1.49E+05	2.45E+05	2.17E+05	2.26E+04	1.21E+01	1.47E-01	1.86E-02	8.68E-02	3.03E-03	1.31E+02	1.58	1.29	1501	40%	49%	32	26
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.20E+04	3.14E+03	1.49E+05	2.45E+05	2.17E+05	2.26E+04	1.21E+01	1.47E-01	1.86E-02	8.68E-02	3.03E-03	1.31E+02	1.58	1.29	1501	40%	49%	32	26
241-SX-107	6.07E+04	1.01E+03	9.86E+04	2.17E+05	2.55E+05	4.72E+04	2.00E+03	8.87E-01	1.08E-01	5.19E-01	1.87E-02	8.20E+01	1.77	1.50	356	23%	52%	70	53
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	6.07E+04	1.01E+03	9.86E+04	2.17E+05	2.55E+05	4.72E+04	2.00E+03	8.87E-01	1.08E-01	5.19E-01	1.87E-02	8.20E+01	1.77	1.50	356	23%	52%	70	53
241-SX-108	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.57E+03	1.46E+00	2.96E-01	1.49E+00	3.78E-02	1.65E+02	1.77	1.17	280	2%	75%	77	59
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.57E+03	1.46E+00	2.96E-01	1.49E+00	3.78E-02	1.65E+02	1.77	1.17	280	2%	75%	77	59
241-SX-109	6.07E+04	9.20E+03	1.07E+05	1.76E+05	1.98E+05	2.75E+04	5.70E+02	2.92E-01	3.75E-02	1.79E-01	6.46E-03	7.91E+01	1.73	1.39	913	23%	51%	54	48
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	6.07E+04	9.20E+03	1.07E+05	1.76E+05	1.98E+05	2.75E+04	5.70E+02	2.92E-01	3.75E-02	1.79E-01	6.46E-03	7.91E+01	1.73	1.39	913	23%	51%	54	48
241-SX-110	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.58E+03	1.91E+00	1.18E-01	5.04E-01	3.34E-02	1.15E+02	1.76	1.17	212	23%	75%	69	42
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.58E+03	1.91E+00	1.18E-01	5.04E-01	3.34E-02	1.15E+02	1.76	1.17	212	23%	75%	69	42
241-SX-111	6.07E+04	1.01E+03	9.89E+04	2.17E+05	2.55E+05	4.71E+04	2.63E+03	1.14E+00	1.01E-01	4.64E-01	2.17E-02	9.25E+01	1.76	1.50	436	23%	52%	76	60
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	6.07E+04	1.01E+03	9.89E+04	2.17E+05	2.55E+05	4.71E+04	2.63E+03	1.14E+00	1.01E-01	4.64E-01	2.17E-02	9.25E+01	1.76	1.50	436	23%	52%	76	60

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (μg/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/mL)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-SX-112	6.07E+04	1.01E+03	9.88E+04	2.17E+05	2.55E+05	4.72E+04	2.78E+03	1.20E+00	1.15E-01	5.31E-01	2.34E-02	9.14E+01	1.77	1.50	283	23%	52%	61	52
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	6.07E+04	1.01E+03	9.88E+04	2.17E+05	2.55E+05	4.72E+04	2.78E+03	1.20E+00	1.15E-01	5.31E-01	2.34E-02	9.14E+01	1.77	1.50	283	23%	52%	61	52
241-SX-113	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.75E+01	1.09E-01	9.47E-03	4.88E-02	9.06E-04	2.02E+01	1.43	1.17	72	46%	75%	28	28
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.75E+01	1.09E-01	9.47E-03	4.88E-02	9.06E-04	2.02E+01	1.43	1.17	72	46%	75%	28	28
241-SX-114	6.07E+04	1.01E+03	9.88E+04	2.17E+05	2.51E+05	4.73E+04	1.84E+03	8.15E-01	9.20E-02	4.37E-01	1.67E-02	8.77E+01	1.75	1.50	588	24%	52%	73	52
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	6.07E+04	1.01E+03	9.88E+04	2.17E+05	2.51E+05	4.73E+04	1.84E+03	8.15E-01	9.20E-02	4.37E-01	1.67E-02	8.77E+01	1.75	1.50	588	24%	52%	73	52
241-SX-115	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.35E+04	1.42E+01	3.78E+00	1.61E+01	1.07E+00	2.05E+01	1.77	1.17	16	10%	75%	25	25
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.35E+04	1.42E+01	3.78E+00	1.61E+01	1.07E+00	2.05E+01	1.77	1.17	16	10%	75%	25	25
241-T-101	4.81E+04	4.04E+03	1.22E+05	1.89E+05	2.37E+05	3.77E+04	6.63E-01	1.15E-01	7.84E-02	3.58E-01	9.37E-03	6.76E+01	1.54	1.45	376	39%	49%	21	21
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.81E+04	4.04E+03	1.22E+05	1.89E+05	2.37E+05	3.77E+04	6.63E-01	1.15E-01	7.84E-02	3.58E-01	9.37E-03	6.76E+01	1.54	1.45	376	39%	49%	21	21
241-T-102	6.25E+01	4.50E+02	2.29E+04	1.09E+05	6.46E+04	8.46E+03	7.74E+01	9.99E-02	4.55E-03	1.95E-02	4.87E-04	2.79E+01	1.53	1.14	120	45%	80%	18	18
Supernatant	6.25E+01	4.50E+02	2.29E+04	1.09E+05	6.46E+04	8.46E+03	8.55E-01	3.75E-03	1.04E-03	4.48E-03	1.88E-04	4.51E+01	1.14	1.14	48	80%	80%	18	18
Solid Layer	6.25E+01	4.50E+02	2.29E+04	1.09E+05	6.46E+04	8.46E+03	1.28E+02	1.64E-01	6.89E-03	2.95E-02	6.86E-04	1.64E+01	1.80	1.14	72	30%	80%	18	18
241-T-103	1.70E+04	5.55E+03	3.96E+04	7.80E+04	9.53E+04	1.04E+04	4.07E+00	4.04E-03	5.10E-03	2.18E-02	5.24E-04	2.82E+00	1.64	1.19	102	41%	72%	19	20
Supernatant	1.70E+04	5.55E+03	3.96E+04	7.80E+04	9.53E+04	1.04E+04	1.94E+00	8.57E-03	1.48E-03	6.39E-03	2.68E-04	1.18E+01	1.19	1.19	15	72%	72%	19	20
Solid Layer	1.70E+04	5.55E+03	3.96E+04	7.80E+04	9.53E+04	1.04E+04	4.43E+00	3.26E-03	5.72E-03	2.44E-02	5.68E-04	1.27E+00	1.71	1.18	87	37%	72%	19	20
241-T-104	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.03E+00	1.81E-02	1.51E-02	1.25E-01	1.62E-03	1.55E-01	1.29	1.17	1199	71%	84%	19	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.03E+00	1.81E-02	1.51E-02	1.25E-01	1.62E-03	1.55E-01	1.29	1.17	1199	71%	84%	19	22
241-T-105	1.70E+04	2.98E+03	5.42E+04	3.71E+04	8.84E+04	3.62E+02	5.19E+01	5.81E-02	2.93E-02	2.77E-01	2.08E-03	9.23E+00	1.46	1.18	371	53%	80%	17	16
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	5.42E+04	3.71E+04	8.84E+04	3.62E+02	5.19E+01	5.81E-02	2.93E-02	2.77E-01	2.08E-03	9.23E+00	1.46	1.18	371	53%	80%	17	16
241-T-106	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	5.02E+00	4.27E-02	2.00E-02	1.34E-01	1.61E-03	1.53E+01	1.59	1.17	82	17%	75%	20	21
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	5.02E+00	4.27E-02	2.00E-02	1.34E-01	1.61E-03	1.53E+01	1.59	1.17	82	17%	75%	20	21
241-T-107	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.01E+02	5.89E-02	3.48E-02	3.04E-01	2.37E-03	1.47E+01	1.56	1.17	655	46%	84%	19	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.01E+02	5.89E-02	3.48E-02	3.04E-01	2.37E-03	1.47E+01	1.56	1.17	655	46%	84%	19	22
241-T-108	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.61E+02	1.77E+00	4.65E-03	6.74E-03	6.05E-02	4.41E-04	6.77E+00	1.55	1.26	60	35%	70%	16	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.61E+02	1.77E+00	4.65E-03	6.74E-03	6.05E-02	4.41E-04	6.77E+00	1.55	1.26	60	35%	70%	16	22
241-T-109	1.70E+04	3.37E+00	8.50E+03	2.17E+05	1.13E+05	3.61E+02	2.62E-01	2.10E-04	1.04E-03	9.12E-03	6.79E-05	2.13E+00	1.65	1.26	235	51%	70%	19	20
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	3.37E+00	8.50E+03	2.17E+05	1.13E+05	3.61E+02	2.62E-01	2.10E-04	1.04E-03	9.12E-03	6.79E-05	2.13E+00	1.65	1.26	235	51%	70%	19	20

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (ug/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-T-110	1.70E+04	4.50E+01	5.90E+01	1.83E+04	3.70E+04	0.00E+00	2.72E-02	4.93E-03	5.87E-03	5.60E-02	3.74E-04	1.49E-02	1.25	1.05	1400	76%	87%	17	20
Supernatant	1.70E+04	4.50E+01	5.90E+01	1.83E+04	3.70E+04	0.00E+00	4.29E-04	2.86E-06	9.97E-06	1.48E-04	1.90E-06	2.79E-03	1.05	1.05	3	87%	87%	19	20
Solid Layer	1.70E+04	4.50E+01	5.90E+01	1.83E+04	3.70E+04	0.00E+00	2.73E-02	4.94E-03	5.88E-03	5.61E-02	3.75E-04	1.49E-02	1.25	1.05	1397	76%	87%	17	20
241-T-111	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.08E+00	4.70E-02	1.44E-02	1.24E-01	6.19E-04	1.02E-01	1.24	1.17	1691	75%	75%	18	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.08E+00	4.70E-02	1.44E-02	1.24E-01	6.19E-04	1.02E-01	1.24	1.17	1691	75%	75%	18	22
241-T-112	1.70E+04	1.61E+03	3.88E+04	2.33E+04	5.72E+04	5.04E+00	6.46E-02	1.47E-02	2.18E-02	1.93E-01	1.45E-03	3.86E-01	1.26	1.10	252	75%	85%	19	20
Supernatant	1.70E+04	1.61E+03	3.88E+04	2.33E+04	5.72E+04	5.04E+00	6.08E-01	1.03E-02	1.78E-03	7.69E-03	3.22E-04	3.71E+00	1.10	1.10	26	85%	85%	19	20
Solid Layer	1.70E+04	1.61E+03	3.88E+04	2.33E+04	5.72E+04	5.04E+00	2.00E-03	1.52E-02	2.41E-02	2.14E-01	1.58E-03	3.85E-03	1.28	1.10	226	74%	85%	19	20
241-T-201	1.70E+04	7.78E+01	3.35E+02	4.61E+04	2.51E+04	0.00E+00	6.27E-02	3.69E-02	4.21E-02	6.24E-01	2.11E-03	2.06E-02	1.29	1.06	115	69%	91%	18	20
Supernatant	1.70E+04	7.78E+01	3.35E+02	4.61E+04	2.51E+04	0.00E+00	3.54E-05	5.57E-08	1.67E-06	2.49E-05	8.41E-08	4.07E-05	1.06	1.06	8	91%	91%	19	20
Solid Layer	1.70E+04	7.78E+01	3.35E+02	4.61E+04	2.51E+04	0.00E+00	6.73E-02	3.97E-02	4.52E-02	6.71E-01	2.27E-03	2.21E-02	1.31	1.06	107	68%	91%	17	20
241-T-202	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.23E-03	3.22E-02	2.11E-02	1.67E-01	1.45E-03	6.77E-03	1.18	1.17	77	76%	75%	18	20
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.23E-03	3.22E-02	2.11E-02	1.67E-01	1.45E-03	6.77E-03	1.18	1.17	77	76%	75%	18	20
241-T-203	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.21E-03	3.75E-02	2.81E-02	2.24E-01	1.93E-03	6.63E-03	1.22	1.17	136	76%	85%	17	20
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.21E-03	3.75E-02	2.81E-02	2.24E-01	1.93E-03	6.63E-03	1.22	1.17	136	76%	85%	17	20
241-T-204	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.03E-03	2.27E-02	2.39E-02	1.90E-01	1.64E-03	6.85E-03	1.18	1.17	136	75%	75%	17	20
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.03E-03	2.27E-02	2.39E-02	1.90E-01	1.64E-03	6.85E-03	1.18	1.17	136	75%	75%	17	20
241-TX-101	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	3.23E+02	4.20E-01	1.26E-01	5.90E-01	1.95E-02	6.70E+01	1.74	1.45	344	25%	49%	25	23
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	3.23E+02	4.20E-01	1.26E-01	5.90E-01	1.95E-02	6.70E+01	1.74	1.45	344	25%	49%	25	23
241-TX-102	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.57E+00	1.45E-01	1.52E-02	7.23E-02	2.54E-03	8.75E+01	1.61	1.45	821	31%	49%	26	25
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.57E+00	1.45E-01	1.52E-02	7.23E-02	2.54E-03	8.75E+01	1.61	1.45	821	31%	49%	26	25
241-TX-103	1.70E+04	3.88E+03	1.18E+05	1.91E+05	2.32E+05	3.65E+04	7.29E-01	1.43E-01	1.50E-02	7.18E-02	2.51E-03	8.73E+01	1.61	1.44	548	31%	50%	22	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	3.88E+03	1.18E+05	1.91E+05	2.32E+05	3.65E+04	7.29E-01	1.43E-01	1.50E-02	7.18E-02	2.51E-03	8.73E+01	1.61	1.44	548	31%	50%	22	22
241-TX-104	1.70E+04	1.36E+03	9.43E+04	3.53E+05	2.05E+05	3.19E+03	1.59E+02	1.55E-01	2.10E-02	1.03E-01	3.03E-03	7.05E+01	1.73	1.44	262	46%	52%	21	21
Supernatant	1.70E+04	1.36E+03	9.42E+04	3.54E+05	2.06E+05	3.19E+03	6.48E-01	8.87E-03	8.10E-05	3.86E-04	1.37E-05	2.31E+02	1.44	1.44	9	52%	52%	21	21
Solid Layer	1.70E+04	1.36E+03	9.43E+04	3.53E+05	2.05E+05	3.19E+03	1.64E+02	1.60E-01	2.17E-02	1.06E-01	3.13E-03	6.48E+01	1.74	1.44	253	46%	52%	21	21
241-TX-105	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.95E+00	1.60E-01	1.67E-02	7.95E-02	2.79E-03	7.10E+01	1.63	1.45	2181	29%	49%	33	23
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.95E+00	1.60E-01	1.67E-02	7.95E-02	2.79E-03	7.10E+01	1.63	1.45	2181	29%	49%	33	23
241-TX-106	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	6.09E+00	1.53E-01	1.68E-02	8.06E-02	2.73E-03	8.27E+01	1.62	1.45	1318	30%	49%	25	25
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	6.09E+00	1.53E-01	1.68E-02	8.06E-02	2.73E-03	8.27E+01	1.62	1.45	1318	30%	49%	25	25

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (µg/mL)	TOC in liquid [TOC] (µg/mL)	NO ₂ in liquid [NO ₂] (µg/mL)	NO ₃ in liquid [NO ₃] (µg/mL)	Na in liquid [Na] (ug/mL)	Al in liquid [Al] (µg/mL)	⁹⁰ Sr in waste [Sr] (µCi/g)	²⁴¹ Am in waste [Am241] (µCi/g)	²⁴⁰ Pu in waste [Pu240] (µCi/g)	²³⁹ Pu in waste [Pu240] (µCi/g)	²³⁸ Pu in waste [Pu238] (µCi/g)	¹³⁷ Cs in waste [Cs] (µCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-TX-107	1.70E+04	3.22E+03	1.16E+05	1.97E+05	2.40E+05	4.03E+04	5.47E+00	1.69E+00	1.77E-01	8.41E-01	2.97E-02	1.02E+02	1.78	1.46	112	28%	50%	22	14
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	3.22E+03	1.16E+05	1.97E+05	2.40E+05	4.03E+04	5.47E+00	1.69E+00	1.77E-01	8.41E-01	2.97E-02	1.02E+02	1.78	1.46	112	28%	50%	22	14
241-TX-108	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	5.27E+00	1.50E-01	1.55E-02	7.45E-02	2.61E-03	7.50E+01	1.62	1.45	478	31%	49%	21	21
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	5.27E+00	1.50E-01	1.55E-02	7.45E-02	2.61E-03	7.50E+01	1.62	1.45	478	31%	49%	21	21
241-TX-109	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.82E+00	1.38E-02	9.05E-03	8.34E-02	5.85E-04	1.59E+01	1.43	1.17	1375	54%	75%	36	39
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.82E+00	1.38E-02	9.05E-03	8.34E-02	5.85E-04	1.59E+01	1.43	1.17	1375	54%	75%	36	39
241-TX-110	1.70E+04	4.02E+03	1.22E+05	1.90E+05	2.37E+05	3.78E+04	1.03E+00	1.55E-01	1.66E-02	8.20E-02	2.73E-03	6.52E+01	1.62	1.45	1769	31%	49%	28	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	4.02E+03	1.22E+05	1.90E+05	2.37E+05	3.78E+04	1.03E+00	1.55E-01	1.66E-02	8.20E-02	2.73E-03	6.52E+01	1.62	1.45	1769	31%	49%	28	22
241-TX-111	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.17E+00	1.51E-01	1.65E-02	8.28E-02	2.67E-03	6.21E+01	1.61	1.45	1381	31%	49%	27	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.17E+00	1.51E-01	1.65E-02	8.28E-02	2.67E-03	6.21E+01	1.61	1.45	1381	31%	49%	27	22
241-TX-112	4.81E+04	3.47E+03	1.06E+05	1.94E+05	2.18E+05	3.26E+04	7.24E-01	1.58E-01	1.66E-02	7.94E-02	2.77E-03	6.81E+01	1.63	1.42	2398	29%	52%	22	18
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.81E+04	3.47E+03	1.06E+05	1.94E+05	2.18E+05	3.26E+04	7.24E-01	1.58E-01	1.66E-02	7.94E-02	2.77E-03	6.81E+01	1.63	1.42	2398	29%	52%	22	18
241-TX-113	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.40E+00	6.72E-03	1.68E-03	1.32E-02	1.62E-04	8.18E+00	1.61	1.45	2416	15%	49%	22	22
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.40E+00	6.72E-03	1.68E-03	1.32E-02	1.62E-04	8.18E+00	1.61	1.45	2416	15%	49%	22	22
241-TX-114	1.70E+04	1.53E+03	5.15E+04	2.07E+05	1.60E+05	1.45E+04	7.29E-01	1.48E-01	1.59E-02	7.75E-02	2.62E-03	5.94E+01	1.63	1.33	2012	29%	61%	21	18
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	1.53E+03	5.15E+04	2.07E+05	1.60E+05	1.45E+04	7.29E-01	1.48E-01	1.59E-02	7.75E-02	2.62E-03	5.94E+01	1.63	1.33	2012	29%	61%	21	18
241-TX-115	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	2.15E+00	1.60E-01	1.67E-02	7.97E-02	2.80E-03	7.13E+01	1.63	1.45	2093	29%	49%	22	21
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	2.15E+00	1.60E-01	1.67E-02	7.97E-02	2.80E-03	7.13E+01	1.63	1.45	2093	29%	49%	22	21
241-TX-116	2.54E+03	3.19E+02	1.05E+04	3.79E+05	1.51E+05	8.79E+00	3.42E-01	6.88E-02	9.33E-03	5.34E-02	1.34E-03	3.51E+01	1.66	1.39	2264	21%	53%	21	20
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	2.54E+03	3.19E+02	1.05E+04	3.79E+05	1.51E+05	8.79E+00	3.42E-01	6.88E-02	9.33E-03	5.34E-02	1.34E-03	3.51E+01	1.66	1.39	2264	21%	53%	21	20
241-TX-117	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.60E+02	5.08E-01	1.00E-01	1.20E-02	6.32E-02	1.85E-03	3.89E+01	1.58	1.26	1817	27%	70%	21	20
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.60E+02	5.08E-01	1.00E-01	1.20E-02	6.32E-02	1.85E-03	3.89E+01	1.58	1.26	1817	27%	70%	21	20
241-TX-118	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.21E+02	3.62E+00	4.93E-01	2.34E+00	8.26E-02	5.39E+01	1.69	1.45	935	45%	49%	24	24
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.21E+02	3.62E+00	4.93E-01	2.34E+00	8.26E-02	5.39E+01	1.69	1.45	935	45%	49%	24	24
241-TY-101	1.70E+04	3.38E+00	8.47E+03	2.17E+05	1.13E+05	3.61E+02	9.53E+00	1.26E-02	1.44E-02	1.72E-01	8.48E-04	4.04E-01	1.63	1.26	447	44%	70%	19	20
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	3.38E+00	8.47E+03	2.17E+05	1.13E+05	3.61E+02	9.53E+00	1.26E-02	1.44E-02	1.72E-01	8.48E-04	4.04E-01	1.63	1.26	447	44%	70%	19	20

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (µg/mL)	TOC in liquid [TOC] (µg/mL)	NO ₂ in liquid [NO ₂] (µg/mL)	NO ₃ in liquid [NO ₃] (µg/mL)	Na in liquid [Na] (ug/mL)	Al in liquid [Al] (µg/mL)	⁹⁰ Sr in waste [Sr] (µCi/g)	²⁴¹ Am in waste [Am241] (µCi/g)	²⁴⁰ Pu in waste [Pu240] (µCi/g)	²³⁹ Pu in waste [Pu240] (µCi/g)	²³⁸ Pu in waste [Pu238] (µCi/g)	¹³⁷ Cs in waste [Cs] (µCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-TY-102	4.82E+04	2.18E+03	6.98E+04	2.02E+05	1.79E+05	2.06E+04	2.62E+00	2.50E-03	2.02E-04	1.33E-03	2.46E-05	2.87E+01	1.76	1.36	262	32%	58%	16	19
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.82E+04	2.18E+03	6.98E+04	2.02E+05	1.79E+05	2.06E+04	2.62E+00	2.50E-03	2.02E-04	1.33E-03	2.46E-05	2.87E+01	1.76	1.36	262	32%	58%	16	19
241-TY-103	4.80E+04	4.02E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	7.00E+01	2.42E-02	1.93E-02	1.60E-01	2.10E-03	2.78E+01	1.68	1.45	585	52%	49%	24	17
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.80E+04	4.02E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	7.00E+01	2.42E-02	1.93E-02	1.60E-01	2.10E-03	2.78E+01	1.68	1.45	585	52%	49%	24	17
241-TY-104	1.70E+04	2.12E+03	1.13E+04	9.90E+04	8.34E+04	5.70E+02	8.41E+01	7.74E-02	1.32E-02	1.67E-01	7.61E-04	3.44E+01	1.64	1.18	168	52%	78%	15	19
Supernatant	1.70E+04	2.12E+03	1.13E+04	9.90E+04	8.34E+04	5.70E+02	5.12E-02	3.66E-04	2.64E-04	1.11E-03	6.27E-05	9.71E+00	1.18	1.18	5	78%	78%	16	19
Solid Layer	1.70E+04	2.12E+03	1.13E+04	9.90E+04	8.34E+04	5.70E+02	8.67E+01	7.98E-02	1.36E-02	1.72E-01	7.83E-04	3.51E+01	1.65	1.18	163	52%	78%	15	19
241-TY-105	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.48E+02	7.55E-03	2.27E-03	2.12E-02	1.47E-04	6.24E+00	1.53	1.17	874	39%	75%	25	23
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.48E+02	7.55E-03	2.27E-03	2.12E-02	1.47E-04	6.24E+00	1.53	1.17	874	39%	75%	25	23
241-TY-106	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.21E+02	1.66E-02	2.04E-03	1.90E-02	1.32E-04	5.66E+01	1.40	1.17	62	38%	75%	16	20
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.21E+02	1.66E-02	2.04E-03	1.90E-02	1.32E-04	5.66E+01	1.40	1.17	62	38%	75%	16	20
241-U-101	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.71E+02	2.05E-02	7.86E-03	4.06E-02	7.53E-04	5.73E+01	1.77	1.17	87	30%	76%	21	21
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.71E+02	2.05E-02	7.86E-03	4.06E-02	7.53E-04	5.73E+01	1.77	1.17	87	30%	76%	21	21
241-U-102	2.93E+04	1.12E+04	1.46E+05	1.98E+05	2.23E+05	3.32E+04	8.43E+01	1.18E-01	2.29E-02	1.14E-01	2.86E-03	1.41E+02	1.67	1.48	1238	34%	48%	26	27
Supernatant	2.93E+04	1.12E+04	1.46E+05	1.98E+05	2.23E+05	3.33E+04	4.54E+00	7.85E-03	6.59E-05	3.14E-04	1.11E-05	3.04E+02	1.48	1.48	4	48%	48%	27	27
Solid Layer	2.93E+04	1.12E+04	1.46E+05	1.98E+05	2.23E+05	3.32E+04	8.45E+01	1.18E-01	2.30E-02	1.14E-01	2.87E-03	1.40E+02	1.67	1.48	1234	34%	48%	26	27
241-U-103	3.08E+04	1.24E+04	1.37E+05	1.52E+05	2.30E+05	4.09E+04	2.28E+01	8.53E-02	9.05E-03	4.31E-02	1.31E-03	1.10E+02	1.70	1.44	1410	40%	50%	28	22
Supernatant	3.08E+04	1.24E+04	1.37E+05	1.52E+05	2.31E+05	4.09E+04	6.49E+00	1.28E-02	5.97E-05	2.74E-04	9.65E-06	3.09E+02	1.44	1.44	2	50%	50%	28	22
Solid Layer	3.08E+04	1.24E+04	1.37E+05	1.52E+05	2.30E+05	4.09E+04	2.28E+01	8.54E-02	9.07E-03	4.31E-02	1.31E-03	1.10E+02	1.70	1.44	1408	40%	50%	28	22
241-U-104	4.91E+04	9.58E+03	1.05E+05	2.07E+05	2.03E+05	3.21E+04	2.52E+00	1.27E-03	6.00E-04	4.74E-03	4.10E-05	2.21E-01	1.12	1.40	205	71%	55%	28	24
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.91E+04	9.58E+03	1.05E+05	2.07E+05	2.03E+05	3.21E+04	2.52E+00	1.27E-03	6.00E-04	4.74E-03	4.10E-05	2.21E-01	1.12	1.40	205	71%	55%	28	24
241-U-105	2.09E+04	1.64E+04	1.08E+05	1.81E+05	2.27E+05	2.98E+04	1.14E+01	3.63E-01	5.41E-02	2.59E-01	7.94E-03	1.37E+02	1.67	1.46	1336	30%	52%	28	23
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	2.09E+04	1.64E+04	1.08E+05	1.81E+05	2.27E+05	2.98E+04	1.14E+01	3.63E-01	5.41E-02	2.59E-01	7.94E-03	1.37E+02	1.67	1.46	1336	30%	52%	28	23
241-U-106	5.11E+03	3.38E+04	9.87E+04	2.49E+05	2.23E+05	1.20E+04	5.93E+01	6.81E-01	4.31E-02	1.98E-01	6.96E-03	1.45E+02	1.55	1.34	644	42%	49%	27	22
Supernatant	5.12E+03	3.38E+04	9.90E+04	2.48E+05	2.23E+05	1.20E+04	4.10E+01	2.16E-01	9.19E-04	4.22E-03	1.48E-04	2.10E+02	1.34	1.34	6	49%	49%	24	22
Solid Layer	5.11E+03	3.38E+04	9.87E+04	2.49E+05	2.23E+05	1.20E+04	5.94E+01	6.85E-01	4.35E-02	2.00E-01	7.03E-03	1.45E+02	1.55	1.34	638	42%	49%	27	22
241-U-107	3.12E+04	6.28E+03	1.28E+05	1.42E+05	2.05E+05	4.10E+04	2.09E+00	2.15E-01	3.04E-02	1.42E-01	4.96E-03	7.55E+01	1.74	1.39	1113	33%	50%	22	23
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.12E+04	6.28E+03	1.28E+05	1.42E+05	2.05E+05	4.10E+04	2.09E+00	2.15E-01	3.04E-02	1.42E-01	4.96E-03	7.55E+01	1.74	1.43	1113	33%	50%	22	23
241-U-108	4.92E+04	7.07E+03	1.34E+05	1.84E+05	2.28E+05	3.05E+04	7.54E+00	3.43E-02	1.43E-02	6.53E-02	1.76E-03	1.23E+02	1.68	1.40	1641	37%	50%	29	28
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.92E+04	7.07E+03	1.34E+05	1.84E+05	2.28E+05	3.05E+04	7.54E+00	3.43E-02	1.43E-02	6.53E-02	1.76E-03	1.23E+02	1.68	1.40	1641	37%	50%	29	28

Table B-1. Input Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (μg/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-U-109	4.42E+04	6.53E+03	1.28E+05	1.85E+05	2.28E+05	2.92E+04	6.95E+00	2.36E-02	2.37E-03	1.11E-02	3.67E-04	1.13E+02	1.65	1.47	1352	29%	51%	30	26
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.42E+04	6.53E+03	1.28E+05	1.85E+05	2.28E+05	2.92E+04	6.95E+00	2.36E-02	2.37E-03	1.11E-02	3.67E-04	1.13E+02	1.65	1.47	1352	29%	51%	30	26
241-U-110	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.62E+02	7.35E-02	3.16E-02	1.84E-01	2.84E-03	1.81E+01	1.72	1.17	665	31%	75%	25	24
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.62E+02	7.35E-02	3.16E-02	1.84E-01	2.84E-03	1.81E+01	1.72	1.17	665	31%	75%	25	24
241-U-111	3.39E+04	5.41E+03	1.20E+05	1.67E+05	2.39E+05	3.66E+04	3.82E+01	1.14E-01	1.88E-02	9.26E-02	2.59E-03	1.27E+02	1.61	1.40	840	36%	53%	23	25
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	3.39E+04	5.41E+03	1.20E+05	1.67E+05	2.39E+05	3.66E+04	3.82E+01	1.14E-01	1.88E-02	9.26E-02	2.59E-03	1.27E+02	1.61	1.40	840	36%	53%	23	25
241-U-112	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.65E+02	3.36E-03	2.11E-03	1.91E-02	1.38E-04	3.01E+01	1.74	1.17	172	32%	75%	21	21
Supernatant	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0	0%	0%	0	0
Solid Layer	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.65E+02	3.36E-03	2.11E-03	1.91E-02	1.38E-04	3.01E+01	1.74	1.17	172	32%	75%	21	21
241-U-201	1.27E+04	0.00E+00	2.07E+04	1.43E+05	1.16E+05	1.41E+02	1.09E-01	1.24E-03	2.68E-04	1.41E-03	2.19E-05	9.23E+00	1.53	1.26	15	36%	69%	18	17
Supernatant	1.27E+04	0.00E+00	2.07E+04	1.43E+05	1.16E+05	1.41E+02	1.01E-02	4.33E-04	3.45E-05	1.82E-04	2.82E-06	2.16E+01	1.26	1.26	4	69%	69%	21	17
Solid Layer	1.27E+04	0.00E+00	2.07E+04	1.43E+05	1.16E+05	1.41E+02	1.44E-01	1.53E-03	3.52E-04	1.86E-03	2.89E-05	4.72E+00	1.63	1.22	11	27%	69%	17	17
241-U-202	1.79E+04	1.41E+02	2.45E+04	1.52E+05	1.20E+05	2.39E+02	4.42E-02	1.36E-03	3.52E-04	1.86E-03	2.89E-05	7.32E+00	1.44	1.28	14	38%	69%	18	19
Supernatant	1.79E+04	1.41E+02	2.45E+04	1.52E+05	1.20E+05	2.39E+02	4.82E-04	7.23E-06	8.73E-07	4.59E-06	7.15E-08	1.53E+01	1.28	1.28	4	69%	69%	18	19
Solid Layer	1.79E+04	1.41E+02	2.45E+04	1.52E+05	1.20E+05	2.39E+02	6.17E-02	1.90E-03	4.93E-04	2.60E-03	4.04E-05	4.13E+00	1.51	1.22	10	28%	69%	18	19
241-U-203	4.75E+03	0.00E+00	1.94E+04	1.44E+05	1.00E+05	1.88E+02	8.72E-02	1.07E-03	2.00E-04	1.06E-03	1.64E-05	7.11E+00	1.49	1.28	13	48%	69%	19	19
Supernatant	4.75E+03	0.00E+00	1.94E+04	1.44E+05	1.00E+05	1.88E+02	4.24E-04	6.93E-06	3.71E-06	1.95E-05	3.03E-07	1.43E+01	1.28	1.28	4	69%	69%	19	19
Solid Layer	4.75E+03	0.00E+00	1.94E+04	1.44E+05	1.00E+05	1.88E+02	1.26E-01	1.54E-03	2.88E-04	1.52E-03	2.35E-05	3.89E+00	1.59	1.28	9	40%	69%	19	19
241-U-204	1.61E+03	8.10E+01	7.03E+03	5.53E+04	3.93E+04	1.46E+01	2.42E+00	1.40E-02	7.67E-03	4.04E-02	6.31E-04	5.39E+00	1.34	1.11	11	45%	87%	18	19
Supernatant	1.61E+03	8.10E+01	7.03E+03	5.53E+04	3.93E+04	1.46E+01	1.77E-04	8.49E-06	6.71E-07	3.54E-06	5.47E-08	6.13E+00	1.11	1.11	4	87%	87%	18	19
Solid Layer	1.61E+03	8.10E+01	7.03E+03	5.53E+04	3.93E+04	1.46E+01	3.81E+00	2.21E-02	1.21E-02	6.35E-02	9.91E-04	4.98E+00	1.47	1.11	7	26%	87%	18	19
AY102-S-14U	1.50E+03	1.35E+03	1.79E+04	3.97E+02	8.63E+04	8.85E+02	6.72E+03	5.46E+00	4.05E-01	1.76E+00	6.74E-02	3.54E+02	1.61	1.10	120	35%	78%	35	29
AY102-S-14L	8.18E+02	1.39E+03	1.29E+04	3.33E+02	8.62E+04	5.84E+02	9.06E+03	5.46E+00	4.05E-01	1.76E+00	6.74E-02	3.50E+02	1.58	1.20	89	40%	79%	42	29
AY102-S-15U	2.50E+02	1.35E+03	8.52E+03	2.36E+02	7.65E+04	2.28E+02	4.07E+03	5.46E+00	4.05E-01	1.76E+00	6.74E-02	3.62E+02	1.55	1.17	36	36%	81%	46	29
AY102-S-15L	4.07E+02	1.80E+03	3.72E+03	1.82E+02	6.88E+04	2.46E+02	6.15E+03	5.46E+00	4.05E-01	1.76E+00	6.74E-02	4.03E+02	1.60	1.18	125	42%	83%	51	29
AY-102-S-16	2.51E+03	1.86E+03	4.46E+02	1.22E+02	5.42E+04	4.55E+01	7.66E+03	5.46E+00	4.05E-01	1.76E+00	6.74E-02	3.24E+02	1.40	1.15	109	43%	86%	60	29
AY102-Orig-9"	2.50E+02	1.17E+03	4.67E+01	1.22E+02	5.01E+04	5.88E+01	1.40E+04	5.46E+00	4.05E-01	1.76E+00	6.74E-02	2.01E+02	1.44	1.13	94	43%	86%	64	29

Note: *The solid layer's HGR is calculated based on the core segment data listed in the bottom of this table. The value of NO₃, Sr and Temp in the solid layer are an effective value which are adjusted+A217 such that HG

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load ^{b/r} H _L (watt)	Tank heat load ^a H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} ^{b/r} (H ₂ /100eV)	Total G values G _{TOT} ^{b/r} (H ₂ /100eV)	G values for water G _{H2O} ^{alpha} (H ₂ /100eV)	Total G values G _{TOT} ^{alpha} (H ₂ /100eV)
241-AN-101	415.0	6.07E+06	99%	12566	9.27E-04	5.63E+03	1.04E-07	2.62	2.41	4.11	1.95	0.38	1.40	0.20	0.023	0.030	0.119	0.123
Supernatant	403.6	5.89E+06	100%	7926	9.24E-04	5.44E+03	5.86E-08	2.61	2.40	4.10	1.93	0.38	1.36	0.20	0.023	0.030	0.120	0.123
Solid Layer	11.3	1.83E+05	82%	4640.1	1.03E-03	1.89E+02	1.55E-06	3.06	2.66	4.54	2.84	0.3	2.6	0.20	0.0	0.0	0.105	0.107
241-AN-102	386.6	5.75E+06	97%	12008	1.77E-03	1.02E+04	6.63E-06	3.17	1.89	4.14	0.49	1.71	0.94	0.20	0.021	0.067	0.107	0.130
Supernatant	330.6	4.86E+06	100%	6490	1.70E-03	8.27E+03	3.93E-06	3.17	1.89	4.14	0.48	1.71	0.94	0.20	0.021	0.068	0.107	0.130
Solid Layer	56.0	8.94E+05	82%	5518	2.16E-03	1.93E+03	2.13E-05	3.17	1.89	4.14	0.52	1.71	0.94	0.200	0.021	0.064	0.107	0.128
241-AN-103	347.9	5.44E+06	87%	11249	1.49E-03	8.08E+03	1.57E-07	2.07	2.83	6.85	3.95	0.21	2.02	0.20	0.015	0.022	0.136	0.139
Supernatant	169.7	2.62E+06	100%	3332	2.02E-03	5.30E+03	1.42E-07	2.07	2.83	6.85	3.96	0.21	2.02	0.20	0.015	0.023	0.136	0.140
Solid Layer	178.2	2.82E+06	75%	7917.3	9.87E-04	2.78E+03	1.71E-07	2.07	2.83	6.85	3.95	0.21	2.02	0.20	0.015	0.022	0.136	0.139
241-AN-104	382.1	5.71E+06	95%	11920	1.64E-03	9.36E+03	3.27E-07	3.05	2.59	5.59	3.84	0.22	2.79	0.20	0.017	0.024	0.105	0.109
Supernatant	220.4	3.22E+06	100%	4328	1.66E-03	5.35E+03	1.03E-08	3.05	2.59	5.59	3.84	0.22	2.79	0.20	0.017	0.024	0.105	0.109
Solid Layer	161.6	2.49E+06	89%	7591	1.61E-03	4.02E+03	7.37E-07	3.05	2.59	5.59	3.84	0.22	2.79	0.20	0.017	0.025	0.105	0.110
241-AN-105	408.7	6.18E+06	95%	12443	1.11E-03	6.85E+03	3.25E-07	2.52	2.58	5.64	3.51	0.19	2.93	0.20	0.018	0.023	0.121	0.124
Supernatant	213.6	3.16E+06	100%	4194	9.75E-04	3.08E+03	3.49E-07	2.52	2.58	5.64	3.51	0.19	2.93	0.20	0.018	0.022	0.121	0.123
Solid Layer	195.1	3.02E+06	89%	8249	1.25E-03	3.77E+03	3.00E-07	2.52	2.58	5.64	3.51	0.19	2.93	0.20	0.018	0.023	0.121	0.124
241-AN-106	256.6	3.24E+06	85%	9456	4.32E-03	1.40E+04	3.90E-05	0.03	0.61	1.65	0.39	0.08	0.11	0.50	0.143	0.146	0.723	0.725
Supernatant	187.8	2.17E+06	100%	3688	9.29E-05	2.02E+02	6.35E-08	0.03	0.61	1.65	0.39	0.08	0.11	0.50	0.143	0.147	0.723	0.725
Solid Layer	68.8	1.06E+06	53%	5768	1.30E-02	1.38E+04	1.18E-04	0.03	0.61	1.65	0.39	0.08	0.11	0.50	0.143	0.146	0.723	0.725
241-AN-107	399.9	6.01E+06	97%	12270	1.53E-03	9.21E+03	2.12E-05	3.37	1.45	4.21	1.06	2.27	0.08	0.20	0.021	0.084	0.105	0.136
Supernatant	316.3	4.71E+06	100%	6210	1.35E-03	6.35E+03	1.81E-05	3.37	1.45	4.21	1.06	2.27	0.08	0.20	0.021	0.083	0.105	0.136
Solid Layer	83.6	1.29E+06	86%	6060	2.21E-03	2.86E+03	3.27E-05	3.37	1.45	4.21	1.06	2.27	0.08	0.20	0.021	0.086	0.105	0.138
241-AP-101	419.6	5.34E+06	100%	12656	2.64E-04	1.41E+03	5.67E-08	2.20	0.46	1.95	1.29	0.09	0.40	0.20	0.042	0.043	0.160	0.161
Supernatant	419.6	5.34E+06	100%	12656	2.64E-04	1.41E+03	5.67E-08	2.20	0.46	1.95	1.29	0.09	0.40	0.20	0.042	0.043	0.160	0.161
Solid Layer	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na
241-AP-102	396.8	5.78E+06	99%	12210	8.03E-04	4.64E+03	4.87E-08	2.70	2.14	3.63	1.89	0.22	2.22	0.20	0.025	0.028	0.119	0.121
Supernatant	388.4	5.63E+06	100%	7626	8.15E-04	4.58E+03	4.89E-08	2.70	2.14	3.63	1.89	0.22	2.22	0.20	0.025	0.028	0.119	0.121
Solid Layer	8.4	1.54E+05	53%	4584	3.86E-04	5.95E+01	3.99E-08	2.70	2.14	3.63	1.89	0.22	2.22	0.20	0.025	0.029	0.119	0.121
241-AP-103	275.9	3.96E+06	99%	9835	7.94E-04	3.15E+03	2.26E-07	2.59	1.79	3.74	1.23	0.48	1.45	0.20	0.026	0.036	0.126	0.131
Supernatant	269.2	3.84E+06	100%	5285	8.02E-04	3.08E+03	2.32E-07	2.59	1.79	3.74	1.23	0.48	1.45	0.20	0.026	0.036	0.126	0.131
Solid Layer	6.7	1.18E+05	74%	4550	5.29E-04	6.22E+01	4.35E-08	2.59	1.79	3.74	0.98	0.49	1.47	0.20	0.026	0.034	0.126	0.130
241-AP-104	398.6	5.32E+06	100%	12244	6.94E-04	3.69E+03	7.81E-08	1.63	1.39	2.57	1.16	0.33	1.31	0.20	0.041	0.046	0.182	0.184
Supernatant	398.6	5.32E+06	100%	12244	6.94E-04	3.69E+03	7.81E-08	1.63	1.39	2.57	1.16	0.33	1.31	0.20	0.041	0.046	0.182	0.184
Solid Layer	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na
241-AP-105	412.7	5.58E+06	97%	12520	5.73E-04	3.20E+03	5.39E-08	1.71	1.03	3.08	1.53	0.12	1.52	0.20	0.037	0.039	0.182	0.183
Supernatant	380.3	5.04E+06	100%	7468	5.08E-04	2.56E+03	2.62E-08	1.71	1.03	3.08	1.53	0.12	1.52	0.20	0.037	0.039	0.182	0.183
Solid Layer	32.3	5.43E+05	67%	5053	1.18E-03	6.42E+02	3.11E-07	1.71	1.03	3.08	1.52	0.12	1.52	0.20	0.037	0.039	0.182	0.183
241-AP-106	412.6	5.20E+06	100%	12519	6.92E-04	3.60E+03	1.87E-08	1.14	0.90	2.46	0.43	0.29	1.12	0.20	0.053	0.056	0.244	0.246
Supernatant	412.6	5.20E+06	100%	12519	6.92E-04	3.60E+03	1.87E-08	1.14	0.90	2.46	0.43	0.29	1.12	0.20	0.053	0.056	0.244	0.246
Solid Layer	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load b/r H _L (watt)	Tank heat load ^a H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} b/r (H ₂ /100eV)	Total G values G _{TOT} b/r (H ₂ /100eV)	G values for water G _{H2O} alpha (H ₂ /100eV)	Total G values G _{TOT} alpha (H ₂ /100eV)
241-AP-107	410.0	5.47E+06	100%	12468	3.28E-04	1.79E+03	1.06E-08	2.46	0.70	2.29	1.11	0.13	0.71	0.20	0.036	0.038	0.143	0.144
Supernatant	410.0	5.47E+06	100%	12468	3.28E-04	1.79E+03	1.06E-08	2.46	0.70	2.29	1.11	0.13	0.71	0.20	0.036	0.038	0.143	0.144
Solid Layer	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na
241-AP-108	452.8	6.71E+06	99%	13308	6.93E-04	4.65E+03	5.15E-08	2.82	1.73	4.46	2.17	0.25	1.63	0.20	0.022	0.025	0.119	0.120
Supernatant	416.0	6.12E+06	100%	8169	7.00E-04	4.28E+03	5.50E-08	2.82	1.73	4.46	2.16	0.25	1.64	0.20	0.022	0.025	0.119	0.120
Solid Layer	36.7	5.94E+05	89%	5139	6.21E-04	3.68E+02	1.56E-08	2.82	1.73	4.46	2.33	0.25	1.62	0.20	0.022	0.026	0.119	0.121
241-AW-101	409.4	6.30E+06	100%	12456	1.23E-03	7.77E+03	1.20E-06	2.76	2.29	5.07	5.86	0.18	2.01	0.20	0.019	0.025	0.116	0.119
Supernatant	265.7	4.07E+06	100%	5217	1.22E-03	4.97E+03	1.72E-08	2.76	2.29	5.07	5.86	0.18	2.01	0.20	0.019	0.025	0.116	0.119
Solid Layer	143.7	2.23E+06	100%	7239	1.25E-03	2.80E+03	3.35E-06	2.76	2.29	5.07	5.86	0.18	2.01	0.20	0.019	0.025	0.116	0.119
241-AW-102	392.2	4.44E+06	97%	12119	2.99E-04	1.33E+03	3.26E-06	0.26	0.33	1.06	0.20	0.18	0.18	0.20	0.149	0.153	0.575	0.577
Supernatant	381.1	4.25E+06	100%	7483	1.39E-04	5.89E+02	5.53E-08	0.26	0.33	1.06	0.17	0.18	0.18	0.20	0.149	0.153	0.575	0.577
Solid Layer	11.1	1.86E+05	38%	4636	3.98E-03	7.38E+02	7.67E-05	0.26	0.33	1.06	1.09	0.16	0.16	0.20	0.149	0.153	0.575	0.576
241-AW-103	398.0	5.46E+06	103%	12232	3.43E-04	1.87E+03	4.18E-06	2.29	1.12	2.32	1.02	0.25	0.62	0.20	0.036	0.040	0.146	0.148
Supernatant	277.5	3.59E+06	100%	5449	4.30E-04	1.54E+03	5.20E-09	1.56	0.73	2.10	0.77	0.15	0.65	0.20	0.049	0.051	0.202	0.203
Solid Layer	120.5	1.87E+06	108%	6783	1.76E-04	3.28E+02	1.22E-05	3.98	2.02	2.73	1.60	0.43	0.57	0.20	0.023	0.029	0.089	0.092
241-AW-104	388.3	5.58E+06	98%	12042	8.39E-04	4.68E+03	4.33E-06	1.84	1.65	4.56	1.68	0.30	1.99	0.20	0.025	0.031	0.163	0.166
Supernatant	307.4	4.33E+06	100%	6036	8.49E-04	3.67E+03	4.22E-08	1.82	1.63	3.97	1.50	0.32	1.89	0.20	0.029	0.035	0.164	0.167
Solid Layer	80.9	1.25E+06	89%	6006	8.05E-04	1.01E+03	1.92E-05	1.90	1.75	6.61	2.36	0.24	2.33	0.20	0.016	0.022	0.158	0.161
241-AW-105	151.4	1.92E+06	84%	7390	3.17E-04	6.07E+02	2.75E-05	0.44	0.06	0.58	0.41	0.05	0.02	0.50	0.147	0.148	0.500	0.500
Supernatant	61.2	6.64E+05	100%	1202	4.61E-05	3.06E+01	1.15E-08	0.44	0.06	0.58	0.26	0.06	0.02	0.50	0.147	0.148	0.500	0.500
Solid Layer	90.2	1.25E+06	75%	6188	4.60E-04	5.77E+02	4.21E-05	0.44	0.06	0.58	0.51	0.05	0.02	0.50	0.147	0.148	0.500	0.500
241-AW-106	411.2	5.81E+06	81%	12492	8.44E-04	4.90E+03	1.58E-06	2.05	0.71	2.42	0.91	0.19	0.79	0.20	0.040	0.044	0.165	0.167
Supernatant	309.4	3.93E+06	100%	6074	4.90E-04	1.93E+03	4.91E-08	2.05	0.71	2.42	0.69	0.19	0.80	0.20	0.040	0.043	0.165	0.167
Solid Layer	101.9	1.88E+06	42%	6418	1.58E-03	2.98E+03	4.77E-06	2.05	0.71	2.42	1.60	0.19	0.78	0.20	0.040	0.046	0.165	0.168
241-AY-101	302.1	3.78E+06	91%	10349	3.95E-03	1.49E+04	1.34E-04	0.97	0.37	1.50	0.64	0.09	0.20	0.20	0.076	0.078	0.295	0.296
Supernatant	263.8	3.11E+06	100%	5180	1.04E-04	3.23E+02	2.49E-07	1.10	0.21	1.42	0.73	0.05	0.23	0.20	0.074	0.075	0.279	0.279
Solid Layer	38.3	6.72E+05	49%	5169	2.17E-02	1.46E+04	7.51E-04	0.11	1.42	1.86	0.03	0.26	0.05	0.50	0.101	0.109	0.487	0.492
241-AY-102	362.9	5.05E+06	91%	11543	1.18E-02	5.95E+04	4.45E-05	1.50	0.74	2.80	1.87	0.14	0.44	0.20	0.043	0.051	0.207	0.212
Supernatant	308.1	4.14E+06	100%	6050	4.78E-04	1.98E+03	1.20E-08	1.76	0.87	2.75	2.20	0.14	0.53	0.20	0.040	0.047	0.182	0.185
Solid Layer	54.8	9.09E+05	48%	5493	6.32E-02	5.75E+04	2.48E-04	0.01	0.02	3.04	0.03	0.13	0.03	0.50	0.130	0.144	1.036	1.043
241-AZ-101	305.8	4.03E+06	96%	10422	1.54E-02	6.20E+04	2.21E-04	0.92	1.45	2.86	0.72	0.04	0.53	0.20	0.049	0.052	0.255	0.256
Supernatant	286.9	3.71E+06	100%	5633	6.46E-03	2.40E+04	5.64E-08	0.92	1.45	2.86	0.73	0.04	0.53	0.20	0.049	0.052	0.255	0.256
Solid Layer	18.9	3.17E+05	48%	4789	1.20E-01	3.81E+04	2.80E-03	0.92	1.45	2.86	0.68	0.05	0.54	0.20	0.049	0.062	0.255	0.261
241-AZ-102	346.1	4.19E+06	95%	11213	1.02E-02	4.27E+04	2.36E-04	0.22	0.75	1.59	0.12	0.10	0.05	0.20	0.117	0.126	0.524	0.529
Supernatant	308.1	3.63E+06	100%	6050	4.09E-03	1.48E+04	2.99E-07	0.22	0.75	1.59	0.12	0.09	0.05	0.20	0.117	0.124	0.524	0.528
Solid Layer	38.0	5.58E+05	66%	5164	4.99E-02	2.79E+04	1.77E-03	0.22	0.75	1.59	0.14	0.10	0.05	0.20	0.117	0.160	0.524	0.546
241-SY-101	401.0	4.97E+06	90%	12291	3.27E-04	1.63E+03	3.16E-06	1.03	0.21	1.31	1.04	0.08	0.31	0.20	0.078	0.079	0.291	0.291
Supernatant	307.0	3.62E+06	100%	6027	1.18E-04	4.25E+02	2.24E-07	1.03	0.21	1.31	0.72	0.08	0.32	0.20	0.078	0.079	0.291	0.291
Solid Layer	94.0	1.36E+06	64%	6264	8.85E-04	1.20E+03	1.10E-05	1.03	0.21	1.31	2.20	0.07	0.28	0.20	0.078	0.079	0.291	0.292

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load ^{b/r} H _L (watt)	Tank heat load ^a H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} ^{b/r} (H ₂ /100eV)	Total G values G _{TOT} ^{b/r} (H ₂ /100eV)	G values for water G _{H2O} ^{alpha} (H ₂ /100eV)	Total G values G _{TOT} ^{alpha} (H ₂ /100eV)
241-SY-102	171.8	2.34E+06	86%	7791	8.89E-04	2.08E+03	3.72E-04	1.37	0.63	1.92	0.91	0.18	0.45	0.20	0.056	0.059	0.224	0.226
Supernatant	99.7	1.17E+06	100%	1957	1.15E-04	1.35E+02	1.83E-09	0.88	0.21	1.28	0.69	0.09	0.32	0.20	0.086	0.088	0.324	0.325
Solid Layer	72.1	1.16E+06	72%	5834	1.67E-03	1.94E+03	7.49E-04	2.05	1.22	2.55	1.21	0.28	0.58	0.20	0.037	0.042	0.157	0.159
241-SY-103	268.3	4.15E+06	93%	9686	1.33E-03	5.52E+03	1.09E-05	2.70	3.31	3.33	1.76	0.42	2.56	0.20	0.025	0.037	0.110	0.115
Supernatant	144.2	2.21E+06	100%	2831	1.39E-03	3.08E+03	2.29E-07	2.70	3.31	3.33	1.76	0.42	2.56	0.20	0.025	0.035	0.110	0.114
Solid Layer	124.1	1.94E+06	85%	6855	1.26E-03	2.44E+03	2.31E-05	2.70	3.31	3.33	1.76	0.42	2.56	0.20	0.025	0.039	0.110	0.117
241-A-101	116.2	1.77E+06	67%	6699	1.27E-03	2.24E+03	8.82E-06	3.76	3.58	4.73	2.51	0.25	3.47	0.20	0.017	0.025	0.086	0.089
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	116.2	1.77E+06	67%	6699	1.27E-03	2.24E+03	8.82E-06	3.76	3.58	4.73	2.51	0.25	3.47	0.20	0.017	0.025	0.086	0.089
241-A-102	14.5	2.51E+05	81%	4702	2.83E-03	7.11E+02	8.09E-05	3.05	3.75	1.90	1.02	0.28	2.61	0.20	0.027	0.031	0.098	0.100
Supernatant	1.2	1.88E+04	100%	23	1.50E-03	2.82E+01	1.14E-07	3.05	3.75	1.89	1.02	0.28	2.61	0.20	0.027	0.032	0.098	0.101
Solid Layer	13.3	2.32E+05	80%	4680	2.94E-03	6.83E+02	8.74E-05	3.05	3.75	1.90	1.02	0.28	2.61	0.20	0.027	0.031	0.098	0.100
241-A-103	137.6	1.96E+06	82%	7119	1.10E-03	2.16E+03	8.29E-06	3.90	2.69	3.63	2.87	0.55	2.35	0.20	0.020	0.031	0.087	0.093
Supernatant	1.6	2.57E+04	100%	32	8.54E-04	2.19E+01	6.29E-07	3.90	2.70	3.63	2.88	0.55	2.35	0.20	0.020	0.031	0.087	0.093
Solid Layer	135.9	1.93E+06	82%	7087	1.10E-03	2.13E+03	8.39E-06	3.90	2.69	3.63	2.87	0.55	2.35	0.20	0.020	0.031	0.087	0.093
241-A-104	10.2	1.00E+05	0%	4618	1.56E-01	1.57E+04	5.24E-04	1.28	0.78	1.55	2.51	0.26	0.42	0.20	0.061	0.099	0.230	0.249
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	10.2	1.00E+05	0%	4618	1.56E-01	1.57E+04	5.24E-04	1.28	0.78	1.55	2.51	0.26	0.42	0.20	0.061	0.099	0.230	0.249
241-A-105	13.3	2.14E+05	0	4680	9.24E-02	1.98E+04	9.64E-04	1.28	0.78	1.55	na	0.26	0.42	0.20	0.422	0.422	0.422	0.422
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na	na
Solid Layer	13.3	2.14E+05	0%	4680	9.24E-02	1.98E+04	9.64E-04	1.28	0.78	1.55	na	0.26	0.42	0.20	0.061	0.061	0.230	0.230
241-A-106	28.7	5.08E+05	46%	4981	7.03E-03	3.58E+03	1.16E-04	1.28	0.78	1.55	2.51	0.94	0.42	0.20	0.061	0.107	0.230	0.253
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	28.7	5.08E+05	46%	4981	7.03E-03	3.58E+03	1.16E-04	1.28	0.78	1.55	2.51	0.94	0.42	0.20	0.061	0.107	0.230	0.253
241-AX-101	129.8	2.30E+06	79%	6966	1.48E-03	3.40E+03	7.55E-06	4.39	3.76	4.11	2.29	0.26	3.29	0.20	0.017	0.022	0.076	0.078
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	129.8	2.30E+06	79%	6966	1.48E-03	3.40E+03	7.55E-06	4.39	3.76	4.11	2.29	0.26	3.29	0.20	0.017	0.022	0.076	0.078
241-AX-102	10.8	1.78E+05	70%	4631	9.31E-03	1.66E+03	4.32E-04	2.83	2.33	3.43	2.29	1.65	1.98	0.20	0.025	0.039	0.113	0.120
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	10.8	1.78E+05	70%	4631	9.31E-03	1.66E+03	4.32E-04	2.83	2.33	3.43	2.29	1.65	1.98	0.20	0.025	0.039	0.113	0.120
241-AX-103	38.7	6.37E+05	90%	5177	5.53E-03	3.52E+03	4.32E-05	3.08	2.65	4.53	2.29	0.28	2.61	0.20	0.020	0.025	0.104	0.107
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	38.7	6.37E+05	90%	5177	5.53E-03	3.52E+03	4.32E-05	3.08	2.65	4.53	2.29	0.28	2.61	0.20	0.020	0.025	0.104	0.107
241-AX-104	2.7	5.04E+04	11%	4471	2.77E-01	1.39E+04	8.28E-04	1.28	0.78	1.55	2.29	0.26	0.42	0.20	0.061	0.064	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	2.7	5.04E+04	11%	4471	2.77E-01	1.39E+04	8.28E-04	1.28	0.78	1.55	2.29	0.26	0.42	0.20	0.061	0.064	0.230	0.231
241-B-101	46.9	6.22E+05	81%	5339	2.20E-03	1.37E+03	9.62E-05	5.74	2.86	1.22	1.00	0.00	0.05	0.20	0.019	0.019	0.063	0.063
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	46.9	6.22E+05	81%	5339	2.20E-03	1.37E+03	9.62E-05	5.74	2.86	1.22	1.00	0.00	0.05	0.20	0.019	0.019	0.063	0.063

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load ^{b/r} H _L (watt)	Tank heat load ^a H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} ^{b/r} (H ₂ /100eV)	Total G values G _{TOT} ^{b/r} (H ₂ /100eV)	G values for water G _{H2O} ^{alpha} (H ₂ /100eV)	Total G values G _{TOT} ^{alpha} (H ₂ /100eV)
241-B-102	19.1	1.90E+05	68%	4792	1.93E-05	3.66E+00	9.34E-07	3.50	0.19	1.22	1.00	0.00	0.03	0.20	0.032	0.032	0.110	0.110
Supernatant	1.4	1.89E+04	100%	28	4.48E-05	8.47E-01	1.82E-07	3.49	0.18	1.22	1.00	0.00	0.03	0.20	0.032	0.032	0.111	0.111
Solid Layer	17.6	1.71E+05	65%	4764	1.64E-05	2.81E+00	1.02E-06	3.50	0.19	1.22	1.00	0.00	0.03	0.20	0.032	0.032	0.110	0.110
241-B-103	27.7	3.40E+05	71%	4962	2.19E-05	7.45E+00	5.18E-06	3.52	0.18	1.21	1.00	0.00	0.03	0.20	0.032	0.032	0.110	0.110
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	27.7	3.40E+05	71%	4962	2.19E-05	7.45E+00	5.18E-06	3.52	0.18	1.21	1.00	0.00	0.03	0.20	0.032	0.032	0.110	0.110
241-B-104	143.6	1.96E+06	68%	7237	4.45E-05	8.74E+01	1.58E-06	3.49	0.18	1.23	1.00	0.00	0.03	0.20	0.032	0.032	0.111	0.111
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	143.6	1.96E+06	68%	7237	4.45E-05	8.74E+01	1.58E-06	3.49	0.18	1.23	1.00	0.00	0.03	0.20	0.032	0.032	0.111	0.111
241-B-105	112.9	1.82E+06	62%	6635	1.48E-05	2.69E+01	1.20E-06	3.49	0.18	1.24	1.00	0.00	0.03	0.20	0.032	0.032	0.111	0.111
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	112.9	1.82E+06	62%	6635	1.48E-05	2.69E+01	1.20E-06	3.49	0.18	1.24	1.00	0.00	0.03	0.20	0.032	0.032	0.111	0.111
241-B-106	52.0	6.40E+05	89%	5439	4.00E-04	2.56E+02	1.31E-06	3.50	0.18	1.23	1.00	0.00	0.03	0.20	0.032	0.032	0.110	0.110
Supernatant	0.4	5.04E+03	100%	8	4.48E-05	2.26E-01	1.82E-07	3.50	0.18	1.23	1.00	0.00	0.03	0.20	0.032	0.032	0.110	0.110
Solid Layer	51.6	6.35E+05	89%	5432	4.02E-04	2.56E+02	1.32E-06	3.50	0.18	1.23	1.00	0.00	0.03	0.20	0.032	0.032	0.110	0.110
241-B-107	66.1	9.93E+05	70%	5717	7.35E-05	7.30E+01	1.53E-06	5.34	0.14	0.89	1.00	0.00	0.00	0.20	0.023	0.023	0.076	0.076
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	66.1	9.93E+05	70%	5717	7.35E-05	7.30E+01	1.53E-06	5.34	0.14	0.89	1.00	0.00	0.00	0.20	0.023	0.023	0.076	0.076
241-B-108	41.1	5.96E+05	50%	5224	7.02E-05	4.18E+01	1.22E-07	6.07	1.17	0.33	1.00	0.00	0.07	0.20	0.020	0.020	0.064	0.064
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	41.1	5.96E+05	50%	5224	7.02E-05	4.18E+01	1.22E-07	6.07	1.17	0.33	1.00	0.00	0.07	0.20	0.020	0.020	0.064	0.064
241-B-109	53.1	8.64E+05	57%	5460	9.97E-06	8.62E+00	8.88E-07	3.50	0.19	1.22	1.00	0.00	0.03	0.20	0.032	0.032	0.110	0.110
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	53.1	8.64E+05	57%	5460	9.97E-06	8.62E+00	8.88E-07	3.50	0.19	1.22	1.00	0.00	0.03	0.20	0.032	0.032	0.110	0.110
241-B-110	96.7	1.26E+06	76%	6317	5.69E-04	7.19E+02	5.87E-06	1.25	0.86	2.04	1.00	0.55	1.03	0.20	0.055	0.059	0.231	0.233
Supernatant	0.4	4.76E+03	100%	8	6.86E-05	3.27E-01	3.51E-07	1.25	0.86	2.04	1.00	0.47	0.87	0.20	0.055	0.059	0.231	0.233
Solid Layer	96.3	1.26E+06	76%	6309	5.71E-04	7.19E+02	5.89E-06	1.25	0.86	2.04	1.00	0.55	1.03	0.20	0.055	0.059	0.231	0.233
241-B-111	95.3	1.16E+06	76%	6288	1.86E-03	2.16E+03	5.84E-06	1.25	0.86	2.04	1.00	0.55	1.03	0.20	0.055	0.060	0.231	0.233
Supernatant	0.4	4.76E+03	100%	8	6.86E-05	3.27E-01	3.51E-07	1.25	0.86	2.04	1.00	0.47	0.87	0.20	0.055	0.059	0.231	0.233
Solid Layer	94.9	1.16E+06	76%	6281	1.87E-03	2.16E+03	5.86E-06	1.25	0.86	2.04	1.00	0.55	1.03	0.20	0.055	0.060	0.231	0.233
241-B-112	20.1	1.97E+05	90%	4813	2.16E-04	4.26E+01	1.40E-07	3.50	2.54	5.05	1.00	1.20	3.13	0.20	0.017	0.028	0.095	0.101
Supernatant	1.1	1.66E+04	100%	21	4.89E-04	8.12E+00	2.77E-07	3.50	2.55	5.01	1.00	1.20	3.13	0.20	0.017	0.028	0.095	0.101
Solid Layer	19.1	1.81E+05	89%	4792	1.91E-04	3.45E+01	1.27E-07	3.50	2.54	5.05	1.00	1.20	3.13	0.20	0.017	0.028	0.096	0.101
241-B-201	152.6	1.40E+05	86%	1113	1.21E-05	1.69E+00	2.54E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	152.6	1.40E+05	86%	1113	1.21E-05	1.69E+00	2.54E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
241-B-202	148.6	1.32E+05	91%	1092	2.04E-05	2.69E+00	6.83E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	148.6	1.32E+05	91%	1092	2.04E-05	2.69E+00	6.83E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load ^{b/r} H _L (watt)	Tank heat load ^a H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _L (mole/L)	NO ₂ in liquid [NO ₂] _L (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} b/r (H ₂ /100eV)	Total G values G _{TOT} b/r (H ₂ /100eV)	G values for water G _{H2O} alpha (H ₂ /100eV)	Total G values G _{TOT} alpha (H ₂ /100eV)
241-B-203	259.1	2.26E+05	85%	1671	4.90E-07	1.11E-01	9.13E-06	0.91	0.03	0.41	1.00	0.01	0.00	0.50	0.099	0.099	0.327	0.327
Supernatant	2.7	2.10E+03	100%	14	9.45E-10	1.98E-06	1.34E-07	0.91	0.03	0.41	1.00	0.01	0.00	0.50	0.099	0.099	0.327	0.327
Solid Layer	256.4	2.24E+05	85%	1657	4.95E-07	1.11E-01	9.22E-06	0.91	0.03	0.41	1.00	0.01	0.00	0.50	0.099	0.099	0.327	0.327
241-B-204	255.0	2.22E+05	85%	1650	1.39E-07	3.09E-02	8.04E-06	0.56	0.03	0.62	1.00	0.01	0.00	0.50	0.131	0.131	0.445	0.445
Supernatant	4.0	3.15E+03	100%	21	4.19E-10	1.32E-06	2.29E-09	0.56	0.03	0.62	1.00	0.01	0.00	0.50	0.131	0.131	0.445	0.445
Solid Layer	251.0	2.19E+05	85%	1628	1.41E-07	3.09E-02	8.16E-06	0.56	0.03	0.62	1.00	0.01	0.00	0.50	0.131	0.131	0.445	0.445
241-BX-101	24.7	3.02E+05	21%	4904	2.14E-03	6.46E+02	2.87E-05	1.95	1.40	2.83	1.00	0.39	0.40	0.20	0.036	0.039	0.160	0.161
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	24.7	3.02E+05	21%	4904	2.14E-03	6.46E+02	2.87E-05	1.95	1.40	2.83	1.00	0.39	0.40	0.20	0.036	0.039	0.160	0.161
241-BX-102	36.1	3.34E+05	43%	5126	2.26E-03	7.56E+02	7.43E-07	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.063	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	36.1	3.34E+05	43%	5126	2.26E-03	7.56E+02	7.43E-07	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.063	0.230	0.231
241-BX-103	34.8	4.44E+05	68%	5102	2.96E-03	1.31E+03	8.26E-05	0.72	0.30	0.67	1.00	0.33	1.60	0.20	0.106	0.109	0.361	0.363
Supernatant	4.8	5.35E+04	100%	94	5.98E-06	3.20E-01	3.67E-07	0.72	0.30	0.67	1.00	0.34	1.66	0.20	0.106	0.109	0.361	0.363
Solid Layer	30.0	3.90E+05	64%	5008	3.36E-03	1.31E+03	9.39E-05	0.72	0.30	0.67	1.00	0.33	1.60	0.20	0.106	0.109	0.361	0.363
241-BX-104	44.0	6.34E+05	47%	5281	1.56E-03	9.89E+02	2.91E-05	2.16	1.39	2.55	1.00	0.25	0.22	0.20	0.036	0.039	0.149	0.151
Supernatant	1.1	1.41E+04	100%	21	4.66E-04	6.56E+00	1.31E-08	2.16	1.39	2.55	1.00	0.25	0.22	0.20	0.036	0.039	0.149	0.151
Solid Layer	42.9	6.20E+05	46%	5260	1.58E-03	9.82E+02	2.97E-05	2.16	1.39	2.55	1.00	0.25	0.22	0.20	0.036	0.039	0.149	0.151
241-BX-105	33.6	4.53E+05	24%	5077	1.51E-03	6.87E+02	5.30E-06	1.89	0.87	2.63	1.00	0.73	0.46	0.20	0.039	0.045	0.173	0.176
Supernatant	1.7	2.32E+04	100%	34	4.75E-04	1.10E+01	1.04E-06	1.89	0.87	2.63	1.00	0.73	0.46	0.20	0.039	0.044	0.173	0.175
Solid Layer	31.9	4.30E+05	20%	5043	1.57E-03	6.76E+02	5.53E-06	1.89	0.87	2.63	1.00	0.73	0.46	0.20	0.039	0.046	0.173	0.176
241-BX-106	21.2	2.31E+05	86%	4834	2.47E-03	5.72E+02	1.55E-05	3.50	2.55	5.03	1.00	1.21	3.13	0.20	0.017	0.025	0.096	0.100
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	21.2	2.31E+05	86%	4834	2.47E-03	5.72E+02	1.55E-05	3.50	2.55	5.03	1.00	1.21	3.13	0.20	0.017	0.025	0.096	0.100
241-BX-107	133.6	1.89E+06	67%	7041	1.14E-04	2.15E+02	2.18E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	133.6	1.89E+06	67%	7041	1.14E-04	2.15E+02	2.18E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
241-BX-108	18.9	1.73E+05	23%	4789	9.70E-04	1.68E+02	2.24E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	18.9	1.73E+05	23%	4789	9.70E-04	1.68E+02	2.24E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
241-BX-109	77.6	1.11E+06	70%	5941	7.69E-04	8.53E+02	5.07E-07	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.063	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	77.6	1.11E+06	70%	5941	7.69E-04	8.53E+02	5.07E-07	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.063	0.230	0.231
241-BX-110	85.5	1.35E+06	79%	6096	2.85E-04	3.86E+02	6.76E-07	6.65	1.13	1.92	1.00	1.06	0.31	0.20	0.017	0.025	0.059	0.063
Supernatant	0.5	7.20E+03	100%	9	4.27E-04	3.08E+00	2.42E-07	6.65	1.13	1.96	1.00	1.05	0.31	0.20	0.017	0.024	0.059	0.063
Solid Layer	85.0	1.35E+06	79%	6086	2.84E-04	3.83E+02	6.78E-07	6.65	1.13	1.92	1.00	1.06	0.31	0.20	0.017	0.025	0.059	0.063
241-BX-111	75.9	1.03E+06	10%	5909	3.83E-04	3.95E+02	6.08E-07	2.99	2.31	4.53	1.00	0.12	3.36	0.20	0.020	0.021	0.109	0.110
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	75.9	1.03E+06	10%	5909	3.83E-04	3.95E+02	6.08E-07	2.99	2.31	4.53	1.00	0.12	3.36	0.20	0.020	0.021	0.109	0.110

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load ^{b/r} H _L (watt)	Tank heat load ^a H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] ₃ (wt%)	Al in liquid [Al] ₃ (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} b/r (H ₂ /100eV)	Total G values G _{TOT} b/r (H ₂ /100eV)	G values for water G _{H2O} alpha (H ₂ /100eV)	Total G values G _{TOT} alpha (H ₂ /100eV)
241-BX-112	67.2	8.14E+05	94%	5737	2.29E-04	1.87E+02	5.68E-06	1.59	0.77	1.03	1.00	0.00	0.00	0.20	0.057	0.057	0.198	0.198
Supernatant	0.5	5.90E+03	100%	9	7.62E-06	4.49E-02	5.19E-08	1.59	0.77	1.03	1.00	0.00	0.00	0.20	0.057	0.057	0.198	0.198
Solid Layer	66.7	8.08E+05	94%	5728	2.31E-04	1.87E+02	5.72E-06	1.59	0.77	1.03	1.00	0.00	0.00	0.20	0.057	0.057	0.198	0.198
241-BY-101	141.9	2.57E+06	29%	7205	8.10E-04	2.08E+03	6.96E-07	3.50	2.54	5.07	2.25	1.20	3.13	0.20	0.017	0.027	0.095	0.100
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	141.9	2.57E+06	29%	7205	8.10E-04	2.08E+03	6.96E-07	3.50	2.54	5.07	2.25	1.20	3.13	0.20	0.017	0.027	0.095	0.100
241-BY-102	108.7	1.66E+06	34%	6552	3.85E-04	6.37E+02	2.50E-06	2.38	1.83	5.98	2.25	0.11	3.87	0.20	0.017	0.018	0.133	0.134
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	108.7	1.66E+06	34%	6552	3.85E-04	6.37E+02	2.50E-06	2.38	1.83	5.98	2.25	0.11	3.87	0.20	0.017	0.018	0.133	0.134
241-BY-103	157.7	2.60E+06	34%	7514	3.92E-04	1.02E+03	6.00E-07	2.28	0.98	4.57	1.85	0.12	2.68	0.20	0.024	0.025	0.148	0.149
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	157.7	2.60E+06	34%	7514	3.92E-04	1.02E+03	6.00E-07	2.28	0.98	4.57	1.85	0.12	2.68	0.20	0.024	0.025	0.148	0.149
241-BY-104	154.7	2.63E+06	29%	7456	1.33E-03	3.51E+03	2.91E-06	3.33	2.42	5.02	2.25	0.16	4.76	0.20	0.018	0.022	0.100	0.102
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	154.7	2.63E+06	29%	7456	1.33E-03	3.51E+03	2.91E-06	3.33	2.42	5.02	2.25	0.16	4.76	0.20	0.018	0.022	0.100	0.102
241-BY-105	182.4	3.28E+06	35%	7999	5.05E-04	1.66E+03	2.04E-06	3.22	1.49	4.32	2.25	0.17	2.72	0.20	0.021	0.023	0.109	0.110
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	182.4	3.28E+06	35%	7999	5.05E-04	1.66E+03	2.04E-06	3.22	1.49	4.32	2.25	0.17	2.72	0.20	0.021	0.023	0.109	0.110
241-BY-106	163.4	2.68E+06	45%	7626	8.72E-04	2.33E+03	7.79E-07	1.78	1.70	3.67	2.10	0.20	3.04	0.20	0.031	0.035	0.166	0.168
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	163.4	2.68E+06	45%	7626	8.72E-04	2.33E+03	7.79E-07	1.78	1.70	3.67	2.10	0.20	3.04	0.20	0.031	0.035	0.166	0.168
241-BY-107	106.2	1.74E+06	49%	6503	8.30E-04	1.44E+03	6.81E-07	2.11	2.54	5.90	2.25	0.16	3.51	0.20	0.018	0.021	0.137	0.138
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	106.2	1.74E+06	49%	6503	8.30E-04	1.44E+03	6.81E-07	2.11	2.54	5.90	2.25	0.16	3.51	0.20	0.018	0.021	0.137	0.138
241-BY-108	88.2	1.25E+06	51%	6151	8.91E-04	1.11E+03	1.81E-06	4.74	1.71	5.79	2.25	0.18	2.73	0.20	0.014	0.018	0.078	0.080
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	88.2	1.25E+06	51%	6151	8.91E-04	1.11E+03	1.81E-06	4.74	1.71	5.79	2.25	0.18	2.73	0.20	0.014	0.018	0.078	0.080
241-BY-109	111.8	1.85E+06	34%	6613	2.88E-04	5.33E+02	1.92E-06	3.07	1.80	4.24	2.25	0.13	2.58	0.20	0.021	0.022	0.110	0.111
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	111.8	1.85E+06	34%	6613	2.88E-04	5.33E+02	1.92E-06	3.07	1.80	4.24	2.25	0.13	2.58	0.20	0.021	0.022	0.110	0.111
241-BY-110	140.4	2.17E+06	28%	7175	9.01E-04	1.95E+03	1.71E-06	2.00	2.70	6.32	2.25	1.35	4.57	0.20	0.016	0.043	0.140	0.153
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	140.4	2.17E+06	28%	7175	9.01E-04	1.95E+03	1.71E-06	2.00	2.70	6.32	2.25	1.35	4.57	0.20	0.016	0.043	0.140	0.153
241-BY-111	153.8	2.55E+06	9%	7437	3.51E-04	8.93E+02	3.04E-06	3.24	1.19	4.99	2.25	0.09	3.03	0.20	0.019	0.020	0.110	0.111
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	153.8	2.55E+06	9%	7437	3.51E-04	8.93E+02	3.04E-06	3.24	1.19	4.99	2.25	0.09	3.03	0.20	0.019	0.020	0.110	0.111
241-BY-112	111.5	1.88E+06	12%	6607	3.78E-04	7.13E+02	2.13E-06	3.06	3.05	4.50	2.25	0.12	3.77	0.20	0.020	0.021	0.102	0.103
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	111.5	1.88E+06	12%	6607	3.78E-04	7.13E+02	2.13E-06	3.06	3.05	4.50	2.25	0.12	3.77	0.20	0.020	0.021	0.102	0.103

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load ^{b/r} H _L (watt)	Tank heat load ² H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} ^{b/r} (H ₂ /100eV)	Total G values G _{TOT} ^{b/r} (H ₂ /100eV)	G values for water G _{H2O} ^{alpha} (H ₂ /100eV)	Total G values G _{TOT} ^{alpha} (H ₂ /100eV)
241-C-101	39.4	5.93E+05	32%	5192	6.69E-04	3.96E+02	3.33E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.065	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	39.4	5.93E+05	32%	5192	6.69E-04	3.96E+02	3.33E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.065	0.230	0.231
241-C-102	122.3	2.01E+06	37%	6820	1.54E-04	3.10E+02	8.20E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.064	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	122.3	2.01E+06	37%	6820	1.54E-04	3.10E+02	8.20E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.064	0.230	0.231
241-C-103	8.4	1.48E+04	15%	4582	4.78E-03	7.08E+01	2.66E-05	0.00	0.00	0.00	0.90	0.00	0.00	0.50	0.431	0.431	1.124	1.124
Supernatant	0.1	9.11E+02	100%	2	9.96E-07	9.08E-04	6.25E-10	0.00	0.00	0.00	0.00	0.00	0.00	0.50	0.431	0.431	1.124	1.124
Solid Layer	8.3	1.39E+04	9%	4581	5.09E-03	7.08E+01	2.83E-05	0.00	0.00	0.00	1.00	0.00	0.00	0.50	0.431	0.431	1.124	1.124
241-C-104	101.6	1.65E+06	59%	6413	2.07E-03	3.41E+03	2.52E-04	1.28	0.78	1.55	1.00	0.48	0.42	0.20	0.061	0.070	0.230	0.234
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	101.6	1.65E+06	59%	6413	2.07E-03	3.41E+03	2.52E-04	1.28	0.78	1.55	1.00	0.48	0.42	0.20	0.061	0.070	0.230	0.234
241-C-105	55.5	7.75E+05	42%	5507	4.27E-03	3.31E+03	1.45E-04	0.55	0.80	3.62	1.00	0.23	0.00	0.20	0.048	0.056	0.371	0.375
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	55.5	7.75E+05	42%	5507	4.27E-03	3.31E+03	1.45E-04	0.55	0.80	3.62	1.00	0.23	0.00	0.20	0.048	0.056	0.371	0.375
241-C-106	8.5	1.62E+04	44%	4584	2.77E-02	4.49E+02	1.76E-04	0.00	0.00	0.42	0.41	0.03	0.01	0.50	0.411	0.411	1.113	1.113
Supernatant	0.0	3.28E+02	100%	1	2.31E-06	7.57E-04	3.03E-10	0.00	0.00	0.42	0.41	0.03	0.01	0.50	0.411	0.411	1.113	1.114
Solid Layer	8.4	1.59E+04	43%	4583	2.83E-02	4.49E+02	1.79E-04	0.00	0.00	0.42	0.41	0.03	0.01	0.50	0.411	0.411	1.113	1.113
241-C-107	97.3	1.45E+06	40%	6328	9.79E-03	1.42E+04	2.06E-04	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.068	0.230	0.233
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	97.3	1.45E+06	40%	6328	9.79E-03	1.42E+04	2.06E-04	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.068	0.230	0.233
241-C-108	16.6	1.41E+05	51%	4743	1.14E-03	1.60E+02	1.24E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.063	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	16.6	1.41E+05	51%	4743	1.14E-03	1.60E+02	1.24E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.063	0.230	0.231
241-C-109	30.5	3.71E+05	52%	5017	6.75E-03	2.51E+03	1.09E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.063	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	30.5	3.71E+05	52%	5017	6.75E-03	2.51E+03	1.09E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.063	0.230	0.231
241-C-110	72.2	9.02E+05	56%	5836	9.64E-05	8.70E+01	3.85E-06	0.97	0.10	0.25	1.00	0.05	0.02	0.50	0.095	0.095	0.309	0.310
Supernatant	0.4	4.40E+03	100%	8	1.63E-05	7.15E-02	4.95E-08	0.97	0.10	0.25	1.00	0.05	0.02	0.50	0.095	0.095	0.309	0.310
Solid Layer	71.8	8.98E+05	56%	5828	9.68E-05	8.69E+01	3.87E-06	0.97	0.10	0.25	1.00	0.05	0.02	0.50	0.095	0.095	0.309	0.310
241-C-111	28.3	3.36E+05	48%	4974	1.84E-02	6.16E+03	3.74E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.063	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	28.3	3.36E+05	48%	4974	1.84E-02	6.16E+03	3.74E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.063	0.230	0.231
241-C-112	45.2	6.19E+05	69%	5306	7.30E-03	4.52E+03	2.61E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.064	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	45.2	6.19E+05	69%	5306	7.30E-03	4.52E+03	2.61E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.064	0.230	0.231
241-C-201	3.7	9.47E+02	25%	334	1.83E-03	1.73E+00	7.20E-04	0.00	0.00	0.00	1.00	0.00	0.00	0.50	0.450	0.450	1.400	1.400
Supernatant	0.0	7.00E+00	100%	0	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0.00	1.00	0.00	0.00	0.50	0.450	0.450	1.400	1.400
Solid Layer	3.7	9.40E+02	24%	334	1.84E-03	1.73E+00	7.25E-04	0.00	0.00	0.00	1.00	0.00	0.00	0.50	0.450	0.450	1.400	1.400

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load ^{b/r} H _L (watt)	Tank heat load ^a H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} ^{b/r} (H ₂ /100eV)	Total G values G _{TOT} ^{b/r} (H ₂ /100eV)	G values for water G _{H2O} ^{alpha} (H ₂ /100eV)	Total G values G _{TOT} ^{alpha} (H ₂ /100eV)
241-C-202	3.7	9.68E+02	25%	334	3.41E-03	3.30E+00	6.02E-04	0.00	0.00	0.00	1.00	0.00	0.00	0.50	0.450	0.450	1.400	1.400
Supernatant	0.0	9.00E+00	100%	0	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0.00	1.00	0.00	0.00	0.50	0.450	0.450	1.400	1.400
Solid Layer	3.7	9.59E+02	24%	334	3.44E-03	3.30E+00	6.08E-04	0.00	0.00	0.00	1.00	0.00	0.00	0.50	0.450	0.450	1.400	1.400
241-C-203	3.7	9.67E+02	39%	334	8.04E-05	7.78E-02	2.02E-05	0.00	0.00	0.00	1.00	0.00	0.00	0.50	0.450	0.450	1.400	1.400
Supernatant	0.1	4.80E+01	100%	0	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0.00	1.00	0.00	0.00	0.50	0.450	0.450	1.400	1.400
Solid Layer	3.6	9.19E+02	36%	333	8.46E-05	7.78E-02	2.12E-05	0.00	0.00	0.00	1.00	0.00	0.00	0.50	0.450	0.450	1.400	1.400
241-C-204	3.7	9.08E+02	39%	333	1.15E-03	1.05E+00	5.27E-07	0.00	0.00	0.00	1.00	0.00	0.00	0.50	0.450	0.450	1.400	1.400
Supernatant	0.0	1.10E+01	100%	0	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0.00	1.00	0.00	0.00	0.50	0.450	0.450	1.400	1.400
Solid Layer	3.7	8.97E+02	38%	333	1.16E-03	1.05E+00	5.34E-07	0.00	0.00	0.00	1.00	0.00	0.00	0.50	0.450	0.450	1.400	1.400
241-S-101	135.4	2.20E+06	77%	7077	1.91E-03	4.19E+03	8.72E-06	3.45	2.45	3.75	2.80	0.12	2.04	0.20	0.021	0.024	0.097	0.098
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	135.4	2.20E+06	77%	7077	1.91E-03	4.19E+03	8.72E-06	3.45	2.45	3.75	2.80	0.12	2.04	0.20	0.021	0.024	0.097	0.098
241-S-102	29.5	2.26E+05	58%	4996	2.05E-03	4.64E+02	4.27E-06	2.50	2.77	4.91	2.21	0.26	3.85	0.20	0.020	0.023	0.120	0.121
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	29.5	2.26E+05	58%	4996	2.05E-03	4.64E+02	4.27E-06	2.50	2.77	4.91	2.21	0.26	3.85	0.20	0.020	0.023	0.120	0.121
241-S-103	93.5	1.44E+06	72%	6254	8.32E-04	1.20E+03	5.53E-06	3.49	3.19	3.23	2.14	0.32	2.21	0.20	0.022	0.025	0.092	0.094
Supernatant	0.4	5.80E+03	100%	8	1.05E-03	6.11E+00	2.82E-08	3.48	3.20	3.23	2.15	0.32	2.21	0.20	0.022	0.025	0.092	0.094
Solid Layer	93.1	1.44E+06	72%	6247	8.31E-04	1.19E+03	5.56E-06	3.49	3.19	3.23	2.14	0.32	2.21	0.20	0.022	0.025	0.092	0.094
241-S-104	112.2	1.82E+06	70%	6620	1.63E-03	2.96E+03	1.06E-05	4.33	0.83	3.44	0.30	0.03	0.87	0.20	0.021	0.021	0.088	0.088
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	112.2	1.82E+06	70%	6620	1.63E-03	2.96E+03	1.06E-05	4.33	0.83	3.44	0.30	0.03	0.87	0.20	0.021	0.021	0.088	0.088
241-S-105	155.0	2.55E+06	5%	7461	1.79E-04	4.55E+02	2.36E-07	3.06	2.66	4.55	4.81	0.28	2.60	0.20	0.020	0.022	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	155.0	2.55E+06	5%	7461	1.79E-04	4.55E+02	2.36E-07	3.06	2.66	4.55	4.81	0.28	2.60	0.20	0.020	0.022	0.105	0.106
241-S-106	173.0	2.97E+06	64%	7814	5.14E-04	1.53E+03	8.75E-07	3.81	2.26	4.55	3.26	0.14	2.66	0.20	0.018	0.019	0.091	0.091
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	173.0	2.97E+06	64%	7814	5.14E-04	1.53E+03	8.75E-07	3.81	2.26	4.55	3.26	0.14	2.66	0.20	0.018	0.019	0.091	0.091
241-S-107	137.7	2.41E+06	53%	7122	1.19E-03	2.86E+03	2.92E-05	1.85	1.55	3.39	1.76	0.09	0.82	0.20	0.033	0.034	0.164	0.165
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	137.7	2.41E+06	53%	7122	1.19E-03	2.86E+03	2.92E-05	1.85	1.55	3.39	1.76	0.09	0.82	0.20	0.033	0.034	0.164	0.165
241-S-108	207.5	3.49E+06	3%	8491	5.94E-04	2.08E+03	3.59E-06	3.06	2.65	4.55	2.83	0.28	2.60	0.20	0.020	0.023	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	207.5	3.49E+06	3%	8491	5.94E-04	2.08E+03	3.59E-06	3.06	2.65	4.55	2.83	0.28	2.60	0.20	0.020	0.023	0.105	0.106
241-S-109	201.2	3.34E+06	20%	8369	1.61E-04	5.37E+02	9.10E-07	2.12	1.85	5.56	4.82	0.07	3.08	0.20	0.019	0.020	0.145	0.145
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	201.2	3.34E+06	20%	8369	1.61E-04	5.37E+02	9.10E-07	2.12	1.85	5.56	4.82	0.07	3.08	0.20	0.019	0.020	0.145	0.145
241-S-110	149.0	2.45E+06	24%	7343	9.73E-04	2.38E+03	8.75E-06	3.51	1.87	3.82	4.81	0.16	2.16	0.20	0.021	0.026	0.099	0.101
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	149.0	2.45E+06	24%	7343	9.73E-04	2.38E+03	8.75E-06	3.51	1.87	3.82	4.81	0.16	2.16	0.20	0.021	0.026	0.099	0.101

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load ^{b/r} H _L (watt)	Tank heat load ² H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} b/r (H ₂ /100eV)	Total G values G _{TOT} b/r (H ₂ /100eV)	G values for water G _{H2O} alpha (H ₂ /100eV)	Total G values G _{TOT} alpha (H ₂ /100eV)
241-S-111	153.2	2.16E+06	57%	7426	1.71E-03	3.70E+03	7.47E-07	3.11	1.82	4.75	3.00	0.10	2.51	0.20	0.020	0.021	0.109	0.110
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	153.2	2.16E+06	57%	7426	1.71E-03	3.70E+03	7.47E-07	3.11	1.82	4.75	3.00	0.10	2.51	0.20	0.020	0.021	0.109	0.110
241-S-112	8.3	1.51E+04	71%	4581	4.16E-03	6.30E+01	2.80E-05	0.00	0.00	0.00	2.86	0.00	0.00	0.50	0.450	0.450	1.400	1.400
Supernatant	0.0	4.69E+02	100%	1	0.00E+00	0.00E+00	0.00E+00	0.00	0.00	0.00	2.86	0.00	0.00	0.50	0.450	0.450	1.400	1.400
Solid Layer	8.3	1.47E+04	70%	4580	4.29E-03	6.30E+01	2.89E-05	0.00	0.00	0.00	2.86	0.00	0.00	0.50	0.450	0.450	1.400	1.400
241-SX-101	160.3	2.66E+06	54%	7566	1.23E-03	3.28E+03	1.25E-05	1.74	1.63	7.16	2.87	0.02	5.41	0.20	0.015	0.016	0.169	0.170
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	160.3	2.66E+06	54%	7566	1.23E-03	3.28E+03	1.25E-05	1.74	1.63	7.16	2.87	0.02	5.41	0.20	0.015	0.016	0.169	0.170
241-SX-102	132.3	2.19E+06	82%	7015	1.21E-03	2.66E+03	6.20E-06	2.53	3.29	4.40	2.95	0.10	3.12	0.20	0.021	0.026	0.115	0.117
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	132.3	2.19E+06	82%	7015	1.21E-03	2.66E+03	6.20E-06	2.53	3.29	4.40	2.95	0.10	3.12	0.20	0.021	0.026	0.115	0.117
241-SX-103	193.2	3.33E+06	65%	8211	1.61E-03	5.38E+03	9.95E-06	2.52	3.42	4.50	2.66	0.23	3.02	0.20	0.021	0.037	0.114	0.122
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	193.2	3.33E+06	65%	8211	1.61E-03	5.38E+03	9.95E-06	2.52	3.42	4.50	2.66	0.23	3.02	0.20	0.021	0.037	0.114	0.122
241-SX-104	170.3	2.86E+06	62%	7762	1.36E-03	3.89E+03	1.06E-05	4.68	2.55	3.67	1.79	0.14	2.42	0.20	0.018	0.024	0.076	0.079
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	170.3	2.86E+06	62%	7762	1.36E-03	3.89E+03	1.06E-05	4.68	2.55	3.67	1.79	0.14	2.42	0.20	0.018	0.024	0.076	0.079
241-SX-105	144.8	2.32E+06	82%	7261	2.14E-03	4.95E+03	1.92E-05	2.65	3.11	4.49	2.41	0.22	3.00	0.20	0.021	0.038	0.113	0.121
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	144.8	2.32E+06	82%	7261	2.14E-03	4.95E+03	1.92E-05	2.65	3.11	4.49	2.41	0.22	3.00	0.20	0.021	0.038	0.113	0.121
241-SX-106	152.4	2.37E+06	81%	7410	7.02E-04	1.66E+03	8.15E-06	3.95	3.24	2.25	1.88	0.24	1.75	0.20	0.023	0.026	0.084	0.086
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	152.4	2.37E+06	81%	7410	7.02E-04	1.66E+03	8.15E-06	3.95	3.24	2.25	1.88	0.24	1.75	0.20	0.023	0.026	0.084	0.086
241-SX-107	42.4	6.30E+05	44%	5250	1.38E-02	8.69E+03	4.89E-05	3.50	2.14	5.44	3.57	0.07	3.15	0.20	0.016	0.024	0.098	0.102
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	42.4	6.30E+05	44%	5250	1.38E-02	8.69E+03	4.89E-05	3.50	2.14	5.44	3.57	0.07	3.15	0.20	0.016	0.024	0.098	0.102
241-SX-108	35.1	4.96E+05	3%	5106	1.80E-02	8.92E+03	1.04E-04	1.28	0.78	1.55	3.57	0.26	0.42	0.20	0.061	0.104	0.230	0.251
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	35.1	4.96E+05	3%	5106	1.80E-02	8.92E+03	1.04E-04	1.28	0.78	1.55	3.57	0.26	0.42	0.20	0.061	0.104	0.230	0.251
241-SX-109	95.9	1.58E+06	27%	6300	4.18E-03	6.62E+03	1.64E-05	2.83	2.33	3.43	3.57	0.66	1.98	0.20	0.025	0.060	0.113	0.131
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	95.9	1.58E+06	27%	6300	4.18E-03	6.62E+03	1.64E-05	2.83	2.33	3.43	3.57	0.66	1.98	0.20	0.025	0.060	0.113	0.131
241-SX-110	28.5	3.74E+05	30%	4978	3.12E-02	1.17E+04	8.28E-05	1.28	0.78	1.55	3.57	0.26	0.42	0.20	0.061	0.091	0.230	0.245
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	28.5	3.74E+05	30%	4978	3.12E-02	1.17E+04	8.28E-05	1.28	0.78	1.55	3.57	0.26	0.42	0.20	0.061	0.091	0.230	0.245
241-SX-111	50.1	7.68E+05	44%	5401	1.80E-02	1.39E+04	5.52E-05	3.50	2.15	5.44	3.57	0.07	3.14	0.20	0.016	0.027	0.098	0.103
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	50.1	7.68E+05	44%	5401	1.80E-02	1.39E+04	5.52E-05	3.50	2.15	5.44	3.57	0.07	3.14	0.20	0.016	0.027	0.098	0.103

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load ^{b/r} H _L (watt)	Tank heat load ^a H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} ^{b/r} (H ₂ /100eV)	Total G values G _{TOT} ^{b/r} (H ₂ /100eV)	G values for water G _{H2O} ^{alpha} (H ₂ /100eV)	Total G values G _{TOT} ^{alpha} (H ₂ /100eV)
241-SX-112	35.4	5.01E+05	44%	5112	1.91E-02	9.54E+03	5.99E-05	3.50	2.15	5.44	3.57	0.07	3.15	0.20	0.016	0.022	0.098	0.100
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	35.4	5.01E+05	44%	5112	1.91E-02	9.54E+03	5.99E-05	3.50	2.15	5.44	3.57	0.07	3.15	0.20	0.016	0.022	0.098	0.100
241-SX-113	15.1	1.03E+05	61%	4714	2.80E-04	2.88E+01	5.39E-06	1.28	0.78	1.55	3.57	0.26	0.42	0.20	0.061	0.064	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	15.1	1.03E+05	61%	4714	2.80E-04	2.88E+01	5.39E-06	1.28	0.78	1.55	3.57	0.26	0.42	0.20	0.061	0.064	0.230	0.231
241-SX-114	64.7	1.03E+06	46%	5687	1.27E-02	1.31E+04	4.34E-05	3.50	2.15	5.27	3.57	0.07	3.15	0.20	0.017	0.026	0.098	0.102
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	64.7	1.03E+06	46%	5687	1.27E-02	1.31E+04	4.34E-05	3.50	2.15	5.27	3.57	0.07	3.15	0.20	0.017	0.026	0.098	0.102
241-SX-115	9.7	2.83E+04	13%	4609	9.06E-02	2.57E+03	1.11E-03	1.28	0.78	1.55	3.57	0.26	0.42	0.20	0.061	0.063	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	9.7	2.83E+04	13%	4609	9.06E-02	2.57E+03	1.11E-03	1.28	0.78	1.55	3.57	0.26	0.42	0.20	0.061	0.063	0.230	0.231
241-T-101	43.6	5.81E+05	80%	5273	3.24E-04	1.88E+02	1.74E-05	3.06	2.65	4.59	2.83	0.28	2.60	0.20	0.020	0.022	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	43.6	5.81E+05	80%	5273	3.24E-04	1.88E+02	1.74E-05	3.06	2.65	4.59	2.83	0.28	2.60	0.20	0.020	0.022	0.105	0.106
241-T-102	19.0	1.84E+05	56%	4790	7.24E-04	1.33E+02	4.66E-06	1.76	0.50	0.55	0.00	0.04	0.74	0.50	0.057	0.058	0.190	0.190
Supernatant	4.6	5.47E+04	100%	90	2.19E-04	1.20E+01	2.97E-07	1.76	0.50	0.55	0.00	0.04	0.74	0.50	0.057	0.058	0.190	0.190
Solid Layer	14.4	1.29E+05	37%	4700	9.37E-04	1.21E+02	6.51E-06	1.76	0.50	0.55	0.00	0.04	0.74	0.50	0.057	0.058	0.190	0.190
241-T-103	17.3	1.67E+05	57%	4757	3.92E-05	6.54E+00	9.91E-07	1.26	0.86	2.03	1.00	0.47	0.88	0.20	0.056	0.058	0.230	0.232
Supernatant	1.4	1.79E+04	100%	28	6.86E-05	1.22E+00	5.30E-07	1.26	0.86	2.03	1.00	0.47	0.87	0.20	0.056	0.058	0.230	0.232
Solid Layer	15.8	1.49E+05	52%	4728	3.57E-05	5.32E+00	1.05E-06	1.26	0.86	2.03	1.00	0.47	0.88	0.20	0.056	0.058	0.230	0.232
241-T-104	122.6	1.55E+06	84%	6826	1.43E-05	2.21E+01	4.91E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	122.6	1.55E+06	84%	6826	1.43E-05	2.21E+01	4.91E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
241-T-105	43.1	5.42E+05	66%	5264	3.91E-04	2.12E+02	1.13E-05	0.60	1.18	2.07	1.00	0.25	0.03	0.20	0.072	0.073	0.330	0.331
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	43.1	5.42E+05	66%	5264	3.91E-04	2.12E+02	1.13E-05	0.60	1.18	2.07	1.00	0.25	0.03	0.20	0.072	0.073	0.330	0.331
241-T-106	15.3	1.30E+05	22%	4719	1.06E-04	1.38E+01	6.15E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	15.3	1.30E+05	22%	4719	1.06E-04	1.38E+01	6.15E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
241-T-107	70.4	1.02E+06	50%	5800	7.42E-04	7.58E+02	1.24E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	70.4	1.02E+06	50%	5800	7.42E-04	7.58E+02	1.24E-05	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
241-T-108	13.2	9.28E+04	50%	4677	4.39E-05	4.07E+00	2.22E-06	3.50	0.18	1.23	1.00	0.00	0.03	0.20	0.032	0.032	0.110	0.110
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	13.2	9.28E+04	50%	4677	4.39E-05	4.07E+00	2.22E-06	3.50	0.18	1.23	1.00	0.00	0.03	0.20	0.032	0.032	0.110	0.110
241-T-109	30.0	3.87E+05	73%	5008	1.18E-05	4.57E+00	3.19E-07	3.50	0.18	1.22	1.00	0.00	0.03	0.20	0.032	0.032	0.110	0.110
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	30.0	3.87E+05	73%	5008	1.18E-05	4.57E+00	3.19E-07	3.50	0.18	1.22	1.00	0.00	0.03	0.20	0.032	0.032	0.110	0.110

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load ^{b/r} H _L (watt)	Tank heat load ² H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} ^{b/r} (H ₂ /100eV)	Total G values G _{TOT} ^{b/r} (H ₂ /100eV)	G values for water G _{H2O} ^{alpha} (H ₂ /100eV)	Total G values G _{TOT} ^{alpha} (H ₂ /100eV)
241-T-110	141.9	1.75E+06	87%	7205	2.53E-07	4.42E-01	2.06E-06	0.30	0.00	1.31	1.00	0.00	0.00	0.50	0.146	0.146	0.615	0.615
Supernatant	0.3	3.15E+03	100%	6	1.61E-08	5.06E-05	4.97E-09	0.30	0.00	1.31	1.00	0.00	0.00	0.50	0.146	0.146	0.615	0.615
Solid Layer	141.7	1.75E+06	87%	7199	2.53E-07	4.42E-01	2.07E-06	0.30	0.00	1.31	1.00	0.00	0.00	0.50	0.146	0.146	0.615	0.615
241-T-111	169.9	2.10E+06	86%	7754	2.78E-05	5.82E+01	5.80E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	169.9	2.10E+06	86%	7754	2.78E-05	5.82E+01	5.80E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
241-T-112	31.7	3.18E+05	88%	5039	1.97E-06	6.27E-01	7.18E-06	0.38	0.84	1.27	1.00	0.15	0.00	0.20	0.111	0.112	0.432	0.432
Supernatant	2.5	2.86E+04	100%	49	2.16E-05	6.18E-01	6.37E-07	0.38	0.84	1.27	1.00	0.15	0.00	0.20	0.111	0.112	0.432	0.432
Solid Layer	29.2	2.89E+05	87%	4991	3.16E-08	9.14E-03	7.82E-06	0.38	0.84	1.27	1.00	0.15	0.00	0.20	0.111	0.112	0.432	0.432
241-T-201	158.0	1.49E+05	75%	1141	5.24E-07	7.78E-02	2.19E-05	0.74	0.01	0.34	1.00	0.01	0.00	0.50	0.114	0.115	0.376	0.376
Supernatant	10.8	8.48E+03	100%	56	4.29E-10	3.64E-06	8.15E-10	0.74	0.01	0.34	1.00	0.01	0.00	0.50	0.114	0.115	0.376	0.376
Solid Layer	147.2	1.40E+05	74%	1085	5.55E-07	7.78E-02	2.32E-05	0.74	0.01	0.34	1.00	0.01	0.00	0.50	0.114	0.115	0.376	0.376
241-T-202	106.8	9.09E+04	101%	873	4.70E-08	4.27E-03	6.85E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	106.8	9.09E+04	101%	873	4.70E-08	4.27E-03	6.85E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
241-T-203	186.3	1.66E+05	90%	1290	4.62E-08	7.66E-03	8.97E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	186.3	1.66E+05	90%	1290	4.62E-08	7.66E-03	8.97E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
241-T-204	186.3	1.60E+05	100%	1290	5.94E-08	9.53E-03	7.33E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	186.3	1.60E+05	100%	1290	5.94E-08	9.53E-03	7.33E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
241-TX-101	40.5	5.99E+05	51%	5213	2.48E-03	1.49E+03	3.63E-05	3.06	2.65	4.54	1.00	0.28	2.61	0.20	0.020	0.022	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	40.5	5.99E+05	51%	5213	2.48E-03	1.49E+03	3.63E-05	3.06	2.65	4.54	1.00	0.28	2.61	0.20	0.020	0.022	0.105	0.106
241-TX-102	86.3	1.33E+06	22%	6113	4.24E-04	5.62E+02	7.51E-06	3.07	2.66	4.55	1.00	0.28	2.60	0.20	0.020	0.023	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	86.3	1.33E+06	22%	6113	4.24E-04	5.62E+02	7.51E-06	3.07	2.66	4.55	1.00	0.28	2.60	0.20	0.020	0.023	0.105	0.106
241-TX-103	60.1	8.83E+05	32%	5598	4.18E-04	3.69E+02	7.42E-06	3.08	2.56	4.45	1.00	0.27	2.53	0.20	0.020	0.022	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	60.1	8.83E+05	32%	5598	4.18E-04	3.69E+02	7.42E-06	3.08	2.56	4.45	1.00	0.27	2.53	0.20	0.020	0.022	0.105	0.106
241-TX-104	32.6	4.53E+05	88%	5058	1.40E-03	6.32E+02	9.00E-06	5.70	2.05	1.16	1.00	0.09	0.22	0.20	0.020	0.020	0.066	0.066
Supernatant	0.9	1.30E+04	100%	17	1.10E-03	1.42E+01	3.06E-07	5.72	2.05	1.17	1.00	0.09	0.22	0.20	0.020	0.020	0.066	0.066
Solid Layer	31.8	4.40E+05	88%	5041	1.41E-03	6.18E+02	9.25E-06	5.70	2.05	1.16	1.00	0.09	0.22	0.20	0.020	0.020	0.066	0.066
241-TX-105	217.0	3.56E+06	7%	8678	3.49E-04	1.24E+03	8.27E-06	3.06	2.65	4.55	1.00	0.28	2.61	0.20	0.020	0.024	0.105	0.107
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	217.0	3.56E+06	7%	8678	3.49E-04	1.24E+03	8.27E-06	3.06	2.65	4.55	1.00	0.28	2.61	0.20	0.020	0.024	0.105	0.107
241-TX-106	134.1	2.14E+06	28%	7050	4.32E-04	9.23E+02	8.07E-06	3.07	2.65	4.56	1.00	0.28	2.61	0.20	0.020	0.022	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	134.1	2.14E+06	28%	7050	4.32E-04	9.23E+02	8.07E-06	3.07	2.65	4.56	1.00	0.28	2.61	0.20	0.020	0.022	0.105	0.106

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load ^{b/r} H _L (watt)	Tank heat load ^a H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} ^{b/r} (H ₂ /100eV)	Total G values G _{TOT} ^{b/r} (H ₂ /100eV)	G values for water G _{H2O} ^{alpha} (H ₂ /100eV)	Total G values G _{TOT} ^{alpha} (H ₂ /100eV)
241-TX-107	18.2	2.00E+05	56%	4775	5.18E-04	1.03E+02	8.76E-05	3.18	2.52	4.73	1.00	0.22	2.75	0.20	0.019	0.021	0.103	0.104
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	18.2	2.00E+05	56%	4775	5.18E-04	1.03E+02	8.76E-05	3.18	2.52	4.73	1.00	0.22	2.75	0.20	0.019	0.021	0.103	0.104
241-TX-108	53.4	7.75E+05	17%	5466	3.90E-04	3.03E+02	7.75E-06	3.06	2.65	4.54	1.00	0.28	2.60	0.20	0.020	0.022	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	53.4	7.75E+05	17%	5466	3.90E-04	3.03E+02	7.75E-06	3.06	2.65	4.54	1.00	0.28	2.60	0.20	0.020	0.022	0.105	0.106
241-TX-109	139.5	1.97E+06	65%	7158	1.07E-04	2.11E+02	3.29E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.065	0.230	0.232
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	139.5	1.97E+06	65%	7158	1.07E-04	2.11E+02	3.29E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.065	0.230	0.232
241-TX-110	177.4	2.86E+06	9%	7901	3.15E-04	9.02E+02	8.17E-06	3.06	2.65	4.58	1.00	0.28	2.60	0.20	0.020	0.023	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	177.4	2.86E+06	9%	7901	3.15E-04	9.02E+02	8.17E-06	3.06	2.65	4.58	1.00	0.28	2.60	0.20	0.020	0.023	0.105	0.106
241-TX-111	140.1	2.23E+06	11%	7169	3.02E-04	6.71E+02	8.07E-06	3.06	2.65	4.54	1.00	0.28	2.61	0.20	0.020	0.023	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	140.1	2.23E+06	11%	7169	3.02E-04	6.71E+02	8.07E-06	3.06	2.65	4.54	1.00	0.28	2.61	0.20	0.020	0.023	0.105	0.106
241-TX-112	237.8	3.92E+06	13%	9087	3.27E-04	1.28E+03	8.19E-06	3.13	2.30	4.07	2.83	0.24	2.29	0.20	0.021	0.023	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	237.8	3.92E+06	13%	9087	3.27E-04	1.28E+03	8.19E-06	3.13	2.30	4.07	2.83	0.24	2.29	0.20	0.021	0.023	0.105	0.106
241-TX-113	239.5	3.88E+06	5%	9121	4.80E-05	1.87E+02	6.80E-07	3.06	2.65	4.54	2.83	0.28	2.61	0.20	0.020	0.022	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	239.5	3.88E+06	5%	9121	4.80E-05	1.87E+02	6.80E-07	3.06	2.65	4.54	2.83	0.28	2.61	0.20	0.020	0.022	0.105	0.106
241-TX-114	200.7	3.29E+06	7%	8359	2.86E-04	9.40E+02	7.80E-06	3.33	1.12	2.48	1.00	0.11	1.09	0.20	0.028	0.029	0.108	0.109
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	200.7	3.29E+06	7%	8359	2.86E-04	9.40E+02	7.80E-06	3.33	1.12	2.48	1.00	0.11	1.09	0.20	0.028	0.029	0.108	0.109
241-TX-115	208.5	3.41E+06	8%	8512	3.52E-04	1.20E+03	8.29E-06	3.07	2.66	4.53	2.83	0.28	2.60	0.20	0.020	0.022	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	208.5	3.41E+06	8%	8512	3.52E-04	1.20E+03	8.29E-06	3.07	2.66	4.53	2.83	0.28	2.60	0.20	0.020	0.022	0.105	0.106
241-TX-116	224.9	3.75E+06	8%	8835	1.68E-04	6.32E+02	4.21E-06	6.11	0.23	0.24	0.15	0.02	0.00	0.20	0.020	0.021	0.066	0.067
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	224.9	3.75E+06	8%	8835	1.68E-04	6.32E+02	4.21E-06	6.11	0.23	0.24	0.15	0.02	0.00	0.20	0.020	0.021	0.066	0.067
241-TX-117	182.0	2.87E+06	5%	7991	1.87E-04	5.38E+02	5.65E-06	3.49	0.18	1.23	1.00	0.00	0.03	0.20	0.032	0.032	0.111	0.111
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	182.0	2.87E+06	5%	7991	1.87E-04	5.38E+02	5.65E-06	3.49	0.18	1.23	1.00	0.00	0.03	0.20	0.032	0.032	0.111	0.111
241-TX-118	97.3	1.58E+06	33%	6328	1.06E-03	1.68E+03	2.08E-04	3.06	2.66	4.54	2.83	0.28	2.60	0.20	0.020	0.022	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	97.3	1.58E+06	33%	6328	1.06E-03	1.68E+03	2.08E-04	3.06	2.66	4.54	2.83	0.28	2.60	0.20	0.020	0.022	0.105	0.106
241-TY-101	50.4	7.27E+05	14%	5407	6.57E-05	4.78E+01	6.12E-06	3.49	0.18	1.22	1.00	0.00	0.03	0.20	0.032	0.032	0.111	0.111
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	50.4	7.27E+05	14%	5407	6.57E-05	4.78E+01	6.12E-06	3.49	0.18	1.22	1.00	0.00	0.03	0.20	0.032	0.032	0.111	0.111

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load ^{b/r} H _L (watt)	Tank heat load ^a H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} ^{b/r} (H ₂ /100eV)	Total G values G _{TOT} ^{b/r} (H ₂ /100eV)	G values for water G _{H2O} ^{alpha} (H ₂ /100eV)	Total G values G _{TOT} ^{alpha} (H ₂ /100eV)
241-TY-102	32.6	4.60E+05	55%	5058	1.53E-04	7.04E+01	1.29E-07	3.26	1.52	3.02	2.84	0.16	1.52	0.20	0.026	0.026	0.107	0.108
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	32.6	4.60E+05	55%	5058	1.53E-04	7.04E+01	1.29E-07	3.26	1.52	3.02	2.84	0.16	1.52	0.20	0.026	0.026	0.107	0.108
241-TY-103	63.7	9.83E+05	91%	5668	6.00E-04	5.90E+02	6.35E-06	3.06	2.65	4.52	2.82	0.28	2.61	0.20	0.020	0.022	0.105	0.106
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	63.7	9.83E+05	91%	5668	6.00E-04	5.90E+02	6.35E-06	3.06	2.65	4.52	2.82	0.28	2.61	0.20	0.020	0.022	0.105	0.106
241-TY-104	23.6	2.75E+05	68%	4881	7.31E-04	2.01E+02	8.13E-06	1.60	0.25	1.78	1.00	0.18	0.05	0.20	0.054	0.055	0.211	0.211
Supernatant	0.5	5.90E+03	100%	9	4.63E-05	2.73E-01	5.59E-08	1.60	0.25	1.78	1.00	0.18	0.05	0.20	0.054	0.055	0.211	0.211
Solid Layer	23.1	2.69E+05	67%	4872	7.46E-04	2.01E+02	8.31E-06	1.60	0.25	1.78	1.00	0.18	0.05	0.20	0.054	0.055	0.211	0.211
241-TY-105	91.4	1.34E+06	39%	6213	1.02E-03	1.36E+03	9.70E-07	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.063	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	91.4	1.34E+06	39%	6213	1.02E-03	1.36E+03	9.70E-07	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.063	0.230	0.231
241-TY-106	13.4	8.68E+04	51%	4681	1.08E-03	9.35E+01	1.19E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	13.4	8.68E+04	51%	4681	1.08E-03	9.35E+01	1.19E-06	1.28	0.78	1.55	1.00	0.26	0.42	0.20	0.061	0.062	0.230	0.230
241-U-101	15.8	1.54E+05	39%	4728	2.76E-03	4.24E+02	2.18E-06	1.28	0.78	1.55	2.89	0.26	0.42	0.20	0.061	0.063	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	15.8	1.54E+05	39%	4728	2.76E-03	4.24E+02	2.18E-06	1.28	0.78	1.55	2.89	0.26	0.42	0.20	0.061	0.063	0.230	0.231
241-U-102	126.4	2.07E+06	72%	6899	1.23E-03	2.54E+03	8.14E-06	3.20	3.18	3.32	1.72	0.76	2.24	0.20	0.023	0.030	0.098	0.102
Supernatant	0.4	5.92E+03	100%	8	1.47E-03	8.69E+00	2.70E-07	3.19	3.17	3.33	1.72	0.76	2.25	0.20	0.023	0.031	0.098	0.102
Solid Layer	126.0	2.06E+06	72%	6892	1.23E-03	2.53E+03	8.16E-06	3.20	3.18	3.32	1.72	0.76	2.24	0.20	0.023	0.030	0.098	0.102
241-U-103	159.0	2.40E+06	79%	7541	6.75E-04	1.62E+03	4.43E-06	2.45	2.98	4.58	1.81	0.86	2.84	0.20	0.021	0.031	0.120	0.125
Supernatant	0.2	2.88E+03	100%	4	1.51E-03	4.34E+00	4.32E-07	2.45	2.98	4.59	1.81	0.86	2.84	0.20	0.021	0.031	0.120	0.125
Solid Layer	158.8	2.40E+06	79%	7537	6.74E-04	1.61E+03	4.44E-06	2.45	2.98	4.58	1.81	0.86	2.84	0.20	0.021	0.031	0.120	0.125
241-U-104	27.1	2.31E+05	130%	4951	1.79E-05	4.13E+00	2.06E-07	3.34	2.29	3.20	2.89	0.68	2.29	0.20	0.024	0.031	0.101	0.104
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	27.1	2.31E+05	130%	4951	1.79E-05	4.13E+00	2.06E-07	3.34	2.29	3.20	2.89	0.68	2.29	0.20	0.024	0.031	0.101	0.104
241-U-105	135.8	2.23E+06	59%	7084	7.24E-04	1.61E+03	2.17E-05	2.92	2.34	4.61	1.23	1.12	2.04	0.20	0.020	0.033	0.111	0.117
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	135.8	2.23E+06	59%	7084	7.24E-04	1.61E+03	2.17E-05	2.92	2.34	4.61	1.23	1.12	2.04	0.20	0.020	0.033	0.111	0.117
241-U-106	69.3	9.98E+05	86%	5779	1.08E-03	1.08E+03	2.99E-05	4.01	2.15	3.53	0.30	2.52	0.90	0.20	0.020	0.047	0.088	0.101
Supernatant	0.6	8.04E+03	100%	11	1.27E-03	1.02E+01	7.26E-06	4.01	2.15	3.55	0.30	2.52	0.90	0.20	0.020	0.043	0.088	0.099
Solid Layer	68.7	9.90E+05	86%	5768	1.08E-03	1.07E+03	3.01E-05	4.01	2.15	3.53	0.30	2.52	0.90	0.20	0.020	0.047	0.088	0.101
241-U-107	114.4	1.93E+06	66%	6664	3.71E-04	7.18E+02	1.25E-05	2.29	2.77	3.84	1.84	0.44	2.86	0.20	0.025	0.029	0.127	0.129
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	114.4	1.93E+06	66%	6664	3.71E-04	7.18E+02	1.25E-05	2.29	2.77	3.84	1.84	0.44	2.86	0.20	0.025	0.029	0.127	0.129
241-U-108	165.1	2.76E+06	74%	7659	6.32E-04	1.74E+03	3.61E-06	2.97	2.91	4.03	2.89	0.51	2.18	0.20	0.022	0.028	0.106	0.109
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	165.1	2.76E+06	74%	7659	6.32E-04	1.74E+03	3.61E-06	2.97	2.91	4.03	2.89	0.51	2.18	0.20	0.022	0.028	0.106	0.109

Table B-2. Derived Data for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L b/r (watt/kg)	Tank heat load ^{b/r} H _L (watt)	Tank heat load ^a H _L alpha (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/mL)	OH in liquid [OH] (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency of H ₂ by corrosion	G values for water G _{H2O} ^{b/r} (H ₂ /100eV)	Total G values G _{TOT} ^{b/r} (H ₂ /100eV)	G values for water G _{H2O} ^{alpha} (H ₂ /100eV)	Total G values G _{TOT} ^{alpha} (H ₂ /100eV)
241-U-109	153.3	2.23E+06	57%	7427	5.81E-04	1.30E+03	1.20E-06	2.98	2.78	4.15	2.60	0.44	1.99	0.20	0.021	0.027	0.106	0.109
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	153.3	2.23E+06	57%	7427	5.81E-04	1.30E+03	1.20E-06	2.98	2.78	4.15	2.60	0.44	1.99	0.20	0.021	0.027	0.106	0.109
241-U-110	71.3	1.14E+06	41%	5819	1.17E-03	1.34E+03	9.07E-06	1.28	0.78	1.55	2.89	0.26	0.42	0.20	0.061	0.063	0.230	0.231
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	71.3	1.14E+06	41%	5819	1.17E-03	1.34E+03	9.07E-06	1.28	0.78	1.55	2.89	0.26	0.42	0.20	0.061	0.063	0.230	0.231
241-U-111	88.1	1.35E+06	68%	6149	8.55E-04	1.16E+03	7.21E-06	2.69	2.61	5.09	1.99	0.39	2.62	0.20	0.019	0.022	0.116	0.117
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	88.1	1.35E+06	68%	6149	8.55E-04	1.16E+03	7.21E-06	2.69	2.61	5.09	1.99	0.39	2.62	0.20	0.019	0.022	0.116	0.117
241-U-112	24.0	3.00E+05	43%	4889	1.24E-03	3.73E+02	7.62E-07	1.28	0.78	1.55	2.89	0.26	0.42	0.20	0.061	0.063	0.230	0.230
Supernatant	na	na	na	na	na	na	na	na	na	na	na	na	na	0.20	na	na	na	na
Solid Layer	24.0	3.00E+05	43%	4889	1.24E-03	3.73E+02	7.62E-07	1.28	0.78	1.55	2.89	0.26	0.42	0.20	0.061	0.063	0.230	0.230
241-U-201	23.2	2.30E+04	52%	436	4.07E-05	9.34E-01	9.72E-08	2.30	0.45	2.28	0.74	0.00	0.01	0.20	0.038	0.038	0.154	0.154
Supernatant	5.4	5.04E+03	100%	28	1.02E-04	5.16E-01	2.09E-08	2.30	0.45	2.28	0.74	0.00	0.01	0.20	0.038	0.038	0.154	0.154
Solid Layer	17.8	1.79E+04	39%	407	2.33E-05	4.18E-01	1.19E-07	2.30	0.45	2.28	0.74	0.00	0.01	0.20	0.038	0.038	0.154	0.154
241-U-202	21.9	2.02E+04	55%	429	3.32E-05	6.72E-01	1.18E-07	2.45	0.53	2.21	1.05	0.01	0.02	0.20	0.037	0.037	0.146	0.146
Supernatant	5.4	5.12E+03	100%	28	7.23E-05	3.70E-01	4.06E-10	2.45	0.53	2.21	1.05	0.01	0.02	0.20	0.037	0.037	0.146	0.146
Solid Layer	16.5	1.51E+04	40%	400	2.00E-05	3.01E-01	1.58E-07	2.45	0.53	2.21	1.05	0.01	0.02	0.20	0.037	0.037	0.146	0.146
241-U-203	20.5	1.94E+04	69%	422	3.20E-05	6.23E-01	7.87E-08	2.32	0.42	1.62	0.28	0.00	0.01	0.20	0.042	0.042	0.154	0.154
Supernatant	5.4	5.12E+03	100%	28	6.78E-05	3.47E-01	9.45E-10	2.32	0.42	1.62	0.28	0.00	0.01	0.20	0.042	0.042	0.154	0.154
Solid Layer	15.1	1.43E+04	59%	393	1.93E-05	2.76E-01	1.06E-07	2.32	0.42	1.62	0.28	0.00	0.01	0.20	0.042	0.042	0.154	0.154
241-U-204	17.8	1.47E+04	51%	407	4.30E-05	6.33E-01	2.14E-06	0.89	0.15	0.66	0.09	0.01	0.00	0.50	0.096	0.096	0.325	0.325
Supernatant	5.4	4.44E+03	100%	28	2.90E-05	1.29E-01	4.09E-10	0.89	0.15	0.66	0.09	0.01	0.00	0.50	0.096	0.096	0.325	0.325
Solid Layer	12.4	1.03E+04	30%	379	4.90E-05	5.04E-01	3.06E-06	0.89	0.15	0.66	0.09	0.01	0.00	0.50	0.096	0.096	0.325	0.325
AY102-S-14U	11.5	1.92E+05	44%	4644	4.67E-02	8.98E+03	2.47E-04	0.01	0.39	3.36	0.09	0.12	0.08	0.50	0.073	0.077	0.835	0.837
AY102-S-14L	8.5	1.40E+05	50%	4585	6.22E-02	8.73E+03	2.47E-04	0.01	0.28	3.46	0.05	0.12	0.05	0.50	0.073	0.079	0.885	0.888
AY102-S-15U	3.5	5.65E+04	44%	4487	2.89E-02	1.63E+03	2.47E-04	0.00	0.19	3.14	0.01	0.12	0.02	0.50	0.088	0.096	0.937	0.940
AY102-S-15L	12.0	2.00E+05	51%	4653	4.30E-02	8.61E+03	2.47E-04	0.00	0.08	2.91	0.02	0.15	0.02	0.50	0.110	0.124	1.000	1.007
AY-102-S-16	10.5	1.53E+05	50%	4624	5.28E-02	8.08E+03	2.47E-04	0.00	0.01	2.34	0.15	0.16	0.00	0.50	0.190	0.213	1.067	1.078
AY102-Orig-9"	9.0	1.35E+05	51%	4595	9.49E-02	1.28E+04	2.47E-04	0.00	0.00	2.18	0.01	0.10	0.01	0.50	0.227	0.246	1.083	1.092

iR in this solid layer matching the total HGR calculated by the core segments.

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-AN-101	2.50E-07	1.13E-10	2.09E-07	2.07E-07	6.66E-07	4.06E-09	1.84E-12	3.39E-09	3.37E-09	1.08E-08
Supernatant	2.52E-07	6.47E-11	2.11E-07	2.70E-08	4.91E-07	4.09E-09	1.05E-12	3.43E-09	4.37E-10	7.95E-09
Solid Layer	1.83E-07	1.22E-09	1.14E-07	5.09E-07	8.06E-07	3.28E-09	2.19E-11	2.04E-09	9.12E-09	1.45E-08
241-AN-102	1.04E-06	7.49E-09	1.47E-06	2.09E-07	2.72E-06	1.71E-08	1.24E-10	2.43E-08	3.45E-09	4.50E-08
Supernatant	1.03E-06	4.59E-09	1.55E-06	2.68E-08	2.61E-06	1.68E-08	7.48E-11	2.52E-08	4.37E-10	4.26E-08
Solid Layer	1.02E-06	2.00E-08	1.10E-06	1.24E-07	2.26E-06	1.80E-08	3.54E-10	1.94E-08	2.19E-09	4.00E-08
241-AN-103	2.60E-07	1.71E-10	4.09E-07	2.07E-07	8.77E-07	4.80E-09	3.16E-12	7.56E-09	3.83E-09	1.62E-08
Supernatant	4.09E-07	1.78E-10	4.85E-07	2.55E-08	9.20E-07	7.01E-09	3.05E-12	8.30E-09	4.37E-10	1.58E-08
Solid Layer	1.48E-07	1.60E-10	3.43E-07	5.63E-08	5.47E-07	2.94E-09	3.19E-12	6.82E-09	1.12E-09	1.09E-08
241-AN-104	3.40E-07	3.06E-10	4.65E-07	2.09E-07	1.01E-06	5.81E-09	5.23E-12	7.94E-09	3.58E-09	1.73E-08
Supernatant	3.52E-07	1.01E-11	4.23E-07	2.70E-08	8.02E-07	5.71E-09	1.63E-13	6.86E-09	4.37E-10	1.30E-08
Solid Layer	3.23E-07	6.48E-10	5.21E-07	6.11E-08	9.06E-07	5.95E-09	1.19E-11	9.59E-09	1.12E-09	1.67E-08
241-AN-105	2.13E-07	3.41E-10	2.49E-07	2.02E-07	6.63E-07	3.67E-09	5.87E-12	4.29E-09	3.47E-09	1.14E-08
Supernatant	1.95E-07	3.86E-10	2.31E-07	2.66E-08	4.53E-07	3.20E-09	6.35E-12	3.80E-09	4.37E-10	7.44E-09
Solid Layer	2.29E-07	2.96E-10	2.67E-07	5.47E-08	5.51E-07	4.16E-09	5.38E-12	4.86E-09	9.94E-10	1.00E-08
241-AN-106	4.80E-06	2.14E-07	6.31E-08	2.93E-07	5.37E-06	6.73E-08	3.00E-09	8.84E-10	4.10E-09	7.52E-08
Supernatant	1.22E-07	4.12E-10	8.72E-08	8.50E-08	2.95E-07	1.57E-09	5.30E-12	1.12E-09	1.09E-09	3.79E-09
Solid Layer	9.04E-06	4.11E-07	2.87E-08	2.71E-07	9.75E-06	1.55E-07	7.05E-09	4.94E-10	4.66E-09	1.68E-07
241-AN-107	1.11E-06	2.51E-08	7.69E-07	2.05E-07	2.11E-06	1.86E-08	4.19E-10	1.28E-08	3.41E-09	3.52E-08
Supernatant	9.99E-07	2.20E-08	7.76E-07	2.64E-08	1.82E-06	1.65E-08	3.64E-10	1.28E-08	4.37E-10	3.02E-08
Solid Layer	1.47E-06	3.47E-08	7.36E-07	9.41E-08	2.33E-06	2.52E-08	5.95E-10	1.26E-08	1.61E-09	4.00E-08
241-AP-101	1.01E-07	8.16E-11	1.52E-08	2.38E-07	3.54E-07	1.43E-09	1.15E-12	2.14E-10	3.35E-09	5.00E-09
Supernatant	1.01E-07	8.16E-11	1.52E-08	4.75E-08	1.64E-07	1.43E-09	1.15E-12	2.14E-10	6.71E-10	2.32E-09
Solid Layer	na	na	na	na	na	na	na	na	na	na
241-AP-102	2.01E-07	5.19E-11	9.50E-08	2.12E-07	5.08E-07	3.26E-09	8.40E-13	1.54E-09	3.42E-09	8.22E-09
Supernatant	2.07E-07	5.28E-11	9.55E-08	2.71E-08	3.29E-07	3.33E-09	8.50E-13	1.54E-09	4.37E-10	5.30E-09
Solid Layer	5.30E-08	2.29E-11	6.69E-08	5.96E-07	7.16E-07	1.07E-09	4.63E-13	1.36E-09	1.21E-08	1.45E-08
241-AP-103	2.53E-07	2.63E-10	3.38E-07	2.49E-07	8.40E-07	4.04E-09	4.19E-12	5.38E-09	3.96E-09	1.34E-08
Supernatant	2.58E-07	2.72E-10	3.44E-07	2.75E-08	6.31E-07	4.10E-09	4.31E-12	5.46E-09	4.37E-10	1.00E-08
Solid Layer	1.19E-07	3.75E-11	1.66E-07	7.75E-07	1.06E-06	2.31E-09	7.29E-13	3.23E-09	1.51E-08	2.06E-08
241-AP-104	2.89E-07	1.29E-10	1.22E-07	2.31E-07	6.41E-07	4.28E-09	1.91E-12	1.80E-09	3.42E-09	9.50E-09
Supernatant	2.89E-07	1.29E-10	1.22E-07	4.61E-08	4.57E-07	4.28E-09	1.91E-12	1.80E-09	6.83E-10	6.77E-09
Solid Layer	not exist	na	na	na	na	na	na	na	na	na
241-AP-105	1.92E-07	8.56E-11	2.96E-08	2.25E-07	4.47E-07	2.89E-09	1.28E-12	4.45E-10	3.37E-09	6.71E-09
Supernatant	1.76E-07	4.30E-11	3.04E-08	2.97E-08	2.36E-07	2.59E-09	6.32E-13	4.47E-10	4.37E-10	3.47E-09
Solid Layer	2.75E-07	3.41E-10	2.18E-08	1.87E-07	4.83E-07	5.12E-09	6.35E-12	4.06E-10	3.48E-09	9.00E-09
241-AP-106	3.48E-07	4.12E-11	6.88E-08	2.41E-07	6.58E-07	4.87E-09	5.77E-13	9.63E-10	3.37E-09	9.21E-09
Supernatant	3.48E-07	4.12E-11	6.88E-08	4.82E-08	4.65E-07	4.87E-09	5.77E-13	9.63E-10	6.75E-10	6.51E-09
Solid Layer	not exist	na	na	na	na	na	na	na	na	na

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-AP-107	1.10E-07	1.37E-11	2.47E-08	2.28E-07	3.63E-07	1.64E-09	2.03E-13	3.65E-10	3.38E-09	5.38E-09
Supernatant	1.10E-07	1.37E-11	2.47E-08	4.57E-08	1.81E-07	1.64E-09	2.03E-13	3.65E-10	6.76E-10	2.68E-09
Solid Layer	not exist	na	na	na	na	na	na	na	na	na
241-AP-108	1.56E-07	5.50E-11	9.77E-08	1.99E-07	4.53E-07	2.57E-09	9.05E-13	1.61E-09	3.27E-09	7.44E-09
Supernatant	1.59E-07	5.93E-11	9.78E-08	2.68E-08	2.84E-07	2.60E-09	9.68E-13	1.60E-09	4.37E-10	4.63E-09
Solid Layer	1.26E-07	1.49E-11	9.61E-08	1.73E-07	3.96E-07	2.26E-09	2.67E-13	1.72E-09	3.11E-09	7.10E-09
241-AW-101	2.79E-07	1.27E-09	3.45E-07	1.98E-07	8.23E-07	4.87E-09	2.23E-11	6.04E-09	3.46E-09	1.44E-08
Supernatant	2.75E-07	1.83E-11	3.35E-07	2.57E-08	6.35E-07	4.68E-09	3.12E-13	5.70E-09	4.37E-10	1.08E-08
Solid Layer	2.86E-07	3.57E-09	3.65E-07	6.50E-08	7.20E-07	5.26E-09	6.58E-11	6.72E-09	1.20E-09	1.32E-08
241-AW-102	4.00E-07	1.64E-08	5.09E-08	2.74E-07	7.41E-07	5.02E-09	2.06E-10	6.40E-10	3.44E-09	9.30E-09
Supernatant	1.90E-07	2.86E-10	5.24E-08	3.53E-08	2.78E-07	2.35E-09	3.54E-12	6.49E-10	4.37E-10	3.44E-09
Solid Layer	2.06E-06	1.50E-07	1.84E-08	5.00E-07	2.73E-06	3.82E-08	2.78E-09	3.41E-10	9.27E-09	5.06E-08
241-AW-103	1.25E-07	5.67E-09	5.26E-08	2.25E-07	4.08E-07	1.91E-09	8.64E-11	8.00E-10	3.42E-09	6.21E-09
Supernatant	1.97E-07	9.46E-12	3.14E-08	3.04E-08	2.59E-07	2.83E-09	1.36E-13	4.50E-10	4.37E-10	3.72E-09
Solid Layer	4.87E-08	1.08E-08	9.57E-08	7.27E-08	2.28E-07	8.39E-10	1.86E-10	1.65E-09	1.25E-09	3.93E-09
241-AW-104	2.31E-07	6.29E-09	2.22E-07	2.16E-07	6.75E-07	3.68E-09	1.00E-10	3.54E-09	3.45E-09	1.08E-08
Supernatant	2.68E-07	6.33E-11	2.24E-07	2.80E-08	5.20E-07	4.19E-09	9.89E-13	3.50E-09	4.37E-10	8.13E-09
Solid Layer	1.40E-07	2.47E-08	2.05E-07	9.61E-08	4.66E-07	2.41E-09	4.24E-10	3.52E-09	1.65E-09	8.00E-09
241-AW-105	3.51E-07	1.03E-07	1.55E-09	3.86E-07	8.43E-07	4.94E-09	1.45E-09	2.18E-11	5.43E-09	1.18E-08
Supernatant	6.10E-08	5.14E-11	2.05E-09	9.07E-08	1.54E-07	7.34E-10	6.19E-13	2.46E-11	1.09E-09	1.85E-09
Solid Layer	4.59E-07	1.42E-07	1.32E-09	2.48E-07	8.50E-07	7.07E-09	2.19E-09	2.03E-11	3.82E-09	1.31E-08
241-AW-106	2.69E-07	1.92E-09	9.52E-08	2.15E-07	5.82E-07	4.23E-09	3.01E-11	1.49E-09	3.38E-09	9.13E-09
Supernatant	1.89E-07	7.33E-11	7.97E-08	3.09E-08	3.00E-07	2.67E-09	1.03E-12	1.13E-09	4.37E-10	4.23E-09
Solid Layer	2.75E-07	3.02E-09	1.07E-07	6.84E-08	4.53E-07	5.63E-09	6.19E-11	2.20E-09	1.40E-09	9.29E-09
241-AY-101	2.51E-06	3.22E-07	2.83E-08	2.74E-07	3.13E-06	3.48E-08	4.48E-09	3.93E-10	3.81E-09	4.35E-08
Supernatant	6.95E-08	6.22E-10	1.71E-08	3.34E-08	1.21E-07	9.09E-10	8.14E-12	2.23E-10	4.37E-10	1.58E-09
Solid Layer	1.04E-05	1.62E-06	4.83E-08	3.85E-07	1.24E-05	2.03E-07	3.15E-08	9.41E-10	7.51E-09	2.43E-07
241-AY-102	4.92E-06	7.65E-08	3.56E-07	2.29E-07	5.58E-06	7.60E-08	1.18E-09	5.50E-09	3.54E-09	8.62E-08
Supernatant	2.02E-07	2.00E-11	3.35E-07	2.93E-08	5.66E-07	3.02E-09	2.98E-13	5.00E-09	4.37E-10	8.45E-09
Solid Layer	3.91E-05	1.11E-06	1.77E-07	3.03E-07	4.07E-05	7.21E-07	2.04E-08	3.26E-09	5.58E-09	7.50E-07
241-AZ-101	6.90E-06	4.87E-07	2.06E-07	2.59E-07	7.85E-06	1.01E-07	7.11E-09	3.00E-09	3.79E-09	1.15E-07
Supernatant	2.99E-06	1.29E-10	1.69E-07	3.04E-08	3.19E-06	4.29E-08	1.86E-12	2.43E-09	4.37E-10	4.58E-08
Solid Layer	3.24E-05	3.17E-06	1.32E-06	3.03E-07	3.72E-05	6.04E-07	5.91E-08	2.46E-08	5.64E-09	6.93E-07
241-AZ-102	1.10E-05	1.07E-06	2.66E-07	2.68E-07	1.26E-05	1.48E-07	1.43E-08	3.57E-09	3.60E-09	1.69E-07
Supernatant	4.55E-06	1.41E-09	1.72E-07	3.34E-08	4.76E-06	5.95E-08	1.85E-11	2.25E-09	4.37E-10	6.22E-08
Solid Layer	4.69E-05	5.66E-06	3.06E-06	1.85E-07	5.58E-05	7.65E-07	9.24E-08	4.99E-08	3.02E-09	9.10E-07
241-SY-101	2.09E-07	7.44E-09	1.21E-08	2.48E-07	4.76E-07	2.94E-09	1.05E-10	1.70E-10	3.48E-09	6.69E-09
Supernatant	8.33E-08	5.85E-10	1.14E-08	3.34E-08	1.29E-07	1.09E-09	7.65E-12	1.49E-10	4.37E-10	1.68E-09
Solid Layer	4.00E-07	1.83E-08	1.30E-08	9.25E-08	5.24E-07	7.03E-09	3.21E-10	2.28E-10	1.63E-09	9.21E-09

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-SY-102	4.03E-07	6.49E-07	4.61E-08	3.34E-07	1.43E-06	6.08E-09	9.79E-09	6.96E-10	5.04E-09	2.16E-08
Supernatant	9.06E-08	5.32E-12	2.21E-08	3.34E-08	1.46E-07	1.19E-09	6.96E-14	2.89E-10	4.37E-10	1.91E-09
Solid Layer	4.55E-07	7.74E-07	6.62E-08	1.01E-07	1.40E-06	8.13E-09	1.38E-08	1.18E-09	1.80E-09	2.49E-08
241-SY-103	4.05E-07	1.05E-08	5.51E-07	2.34E-07	1.20E-06	7.18E-09	1.86E-10	9.77E-09	4.15E-09	2.13E-08
Supernatant	4.31E-07	2.34E-10	4.18E-07	2.57E-08	8.76E-07	7.34E-09	3.99E-12	7.12E-09	4.37E-10	1.49E-08
Solid Layer	3.76E-07	2.05E-08	7.42E-07	7.09E-08	1.21E-06	7.00E-09	3.81E-10	1.38E-08	1.32E-09	2.25E-08
241-A-101	1.88E-07	4.75E-09	5.81E-07	3.04E-07	1.08E-06	3.70E-09	9.37E-11	1.14E-08	6.00E-09	2.12E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.88E-07	4.75E-09	5.81E-07	3.04E-07	1.08E-06	3.70E-09	9.37E-11	1.14E-08	6.00E-09	2.12E-08
241-A-102	6.49E-07	5.92E-08	1.65E-07	1.50E-06	2.38E-06	1.25E-08	1.14E-09	3.18E-09	2.89E-08	4.57E-08
Supernatant	4.28E-07	1.02E-10	2.56E-07	9.63E-08	7.80E-07	7.77E-09	1.86E-12	4.64E-09	1.75E-09	1.42E-08
Solid Layer	6.60E-07	6.28E-08	1.59E-07	1.62E-06	2.50E-06	1.28E-08	1.21E-09	3.08E-09	3.13E-08	4.83E-08
241-A-103	2.55E-07	5.66E-09	6.45E-07	2.91E-07	1.20E-06	4.03E-09	8.96E-11	1.02E-08	4.61E-09	1.89E-08
Supernatant	2.40E-07	5.23E-10	7.83E-07	1.00E-07	1.12E-06	4.20E-09	9.14E-12	1.37E-08	1.75E-09	1.96E-08
Solid Layer	2.55E-07	5.72E-09	6.44E-07	2.94E-07	1.20E-06	4.02E-09	9.04E-11	1.02E-08	4.64E-09	1.89E-08
241-A-104	0.00E+00	0.00E+00	0.00E+00	3.69E-06	3.69E-06	0.00E+00	0.00E+00	0.00E+00	4.05E-08	4.05E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	0.00E+00	0.00E+00	0.00E+00	3.69E-06	3.69E-06	0.00E+00	0.00E+00	0.00E+00	4.05E-08	4.05E-08
241-A-105	0.00E+00	0.00E+00	0.00E+00	1.75E-06	1.75E-06	0.00E+00	0.00E+00	0.00E+00	3.13E-08	3.13E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	0.00E+00	0.00E+00	0.00E+00	1.75E-06	1.75E-06	0.00E+00	0.00E+00	0.00E+00	3.13E-08	3.13E-08
241-A-106	3.10E-06	1.20E-07	1.54E-06	7.86E-07	5.54E-06	6.09E-08	2.37E-09	3.03E-08	1.55E-08	1.09E-07
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.10E-06	1.20E-07	1.54E-06	7.86E-07	5.54E-06	6.09E-08	2.37E-09	3.03E-08	1.55E-08	1.09E-07
241-AX-101	2.24E-07	4.15E-09	2.53E-07	2.43E-07	7.24E-07	4.42E-09	8.18E-11	4.99E-09	4.78E-09	1.43E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.24E-07	4.15E-09	2.53E-07	2.43E-07	7.24E-07	4.42E-09	8.18E-11	4.99E-09	4.78E-09	1.43E-08
241-AX-102	2.29E-06	3.26E-07	3.07E-07	2.08E-06	5.00E-06	4.18E-08	5.95E-09	5.60E-09	3.81E-08	9.14E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.29E-06	3.26E-07	3.07E-07	2.08E-06	5.00E-06	4.18E-08	5.95E-09	5.60E-09	3.81E-08	9.14E-08
241-AX-103	1.13E-06	3.75E-08	3.47E-07	6.52E-07	2.17E-06	2.06E-08	6.85E-10	6.35E-09	1.19E-08	3.96E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.13E-06	3.75E-08	3.47E-07	6.52E-07	2.17E-06	2.06E-08	6.85E-10	6.35E-09	1.19E-08	3.96E-08
241-AX-104	1.75E-05	1.88E-07	1.01E-08	7.12E-06	2.48E-05	3.65E-07	3.92E-09	2.10E-10	1.48E-07	5.18E-07
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.75E-05	1.88E-07	1.01E-08	7.12E-06	2.48E-05	3.65E-07	3.92E-09	2.10E-10	1.48E-07	5.18E-07
241-B-101	3.02E-07	4.41E-08	1.18E-10	6.89E-07	1.03E-06	5.29E-09	7.73E-10	2.06E-12	1.21E-08	1.81E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.02E-07	4.41E-08	1.18E-10	6.89E-07	1.03E-06	5.29E-09	7.73E-10	2.06E-12	1.21E-08	1.81E-08

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-B-102	3.82E-09	6.31E-10	4.39E-12	2.03E-06	2.03E-06	6.93E-11	1.15E-11	7.96E-14	3.68E-08	3.69E-08
Supernatant	1.30E-08	1.80E-10	6.41E-12	1.20E-07	1.33E-07	1.89E-10	2.63E-12	9.35E-14	1.75E-09	1.94E-09
Solid Layer	3.09E-09	6.52E-10	4.16E-12	2.24E-06	2.24E-06	5.77E-11	1.22E-11	7.77E-14	4.17E-08	4.18E-08
241-B-103	4.49E-09	3.63E-09	4.13E-12	1.17E-06	1.18E-06	8.38E-11	6.77E-11	7.71E-14	2.18E-08	2.20E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.49E-09	3.63E-09	4.13E-12	1.17E-06	1.18E-06	8.38E-11	6.77E-11	7.71E-14	2.18E-08	2.20E-08
241-B-104	8.82E-09	1.07E-09	6.63E-12	2.96E-07	3.06E-07	1.41E-10	1.71E-11	1.06E-13	4.74E-09	4.90E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	8.82E-09	1.07E-09	6.63E-12	2.96E-07	3.06E-07	1.41E-10	1.71E-11	1.06E-13	4.74E-09	4.90E-09
241-B-105	2.67E-09	7.39E-10	4.41E-12	2.93E-07	2.97E-07	5.11E-11	1.41E-11	8.44E-14	5.61E-09	5.68E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.67E-09	7.39E-10	4.41E-12	2.93E-07	2.97E-07	5.11E-11	1.41E-11	8.44E-14	5.61E-09	5.68E-09
241-B-106	1.03E-07	1.16E-09	1.12E-11	6.81E-07	7.86E-07	1.65E-09	1.85E-11	1.79E-13	1.09E-08	1.26E-08
Supernatant	1.30E-08	1.80E-10	6.01E-12	1.20E-07	1.33E-07	1.89E-10	2.63E-12	8.76E-14	1.75E-09	1.94E-09
Solid Layer	1.04E-07	1.16E-09	1.13E-11	6.86E-07	7.91E-07	1.66E-09	1.86E-11	1.80E-13	1.10E-08	1.26E-08
241-B-107	1.05E-08	7.24E-10	1.48E-12	4.62E-07	4.73E-07	1.97E-10	1.36E-11	2.78E-14	8.69E-09	8.90E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.05E-08	7.24E-10	1.48E-12	4.62E-07	4.73E-07	1.97E-10	1.36E-11	2.78E-14	8.69E-09	8.90E-09
241-B-108	6.16E-09	3.50E-11	6.50E-12	7.03E-07	7.09E-07	1.21E-10	6.89E-13	1.28E-13	1.39E-08	1.40E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.16E-09	3.50E-11	6.50E-12	7.03E-07	7.09E-07	1.21E-10	6.89E-13	1.28E-13	1.39E-08	1.40E-08
241-B-109	1.63E-09	4.97E-10	4.76E-12	5.07E-07	5.09E-07	3.44E-11	1.05E-11	1.00E-13	1.07E-08	1.07E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.63E-09	4.97E-10	4.76E-12	5.07E-07	5.09E-07	3.44E-11	1.05E-11	1.00E-13	1.07E-08	1.07E-08
241-B-110	2.31E-07	9.33E-09	6.37E-08	4.01E-07	7.06E-07	3.64E-09	1.47E-10	1.00E-09	6.31E-09	1.11E-08
Supernatant	3.62E-08	7.32E-10	6.65E-08	1.27E-07	2.30E-07	4.98E-10	1.01E-11	9.16E-10	1.75E-09	3.17E-09
Solid Layer	2.32E-07	9.35E-09	6.37E-08	4.02E-07	7.07E-07	3.65E-09	1.47E-10	1.00E-09	6.33E-09	1.11E-08
241-B-111	7.63E-07	9.24E-09	9.44E-08	4.35E-07	1.30E-06	1.12E-08	1.36E-10	1.39E-09	6.39E-09	1.91E-08
Supernatant	3.65E-08	7.33E-10	8.68E-08	1.27E-07	2.51E-07	5.03E-10	1.01E-11	1.20E-09	1.75E-09	3.46E-09
Solid Layer	7.66E-07	9.27E-09	9.44E-08	4.36E-07	1.31E-06	1.13E-08	1.36E-10	1.39E-09	6.41E-09	1.92E-08
241-B-112	4.86E-08	1.13E-10	3.74E-07	1.96E-06	2.38E-06	8.40E-10	1.96E-12	6.46E-09	3.39E-08	4.12E-08
Supernatant	1.23E-07	2.50E-10	4.16E-07	1.00E-07	6.39E-07	2.15E-09	4.37E-12	7.28E-09	1.75E-09	1.12E-08
Solid Layer	4.25E-08	1.02E-10	3.70E-07	2.13E-06	2.54E-06	7.34E-10	1.76E-12	6.39E-09	3.68E-08	4.39E-08
241-B-201	5.76E-09	4.48E-08	1.32E-08	6.39E-07	7.02E-07	8.40E-11	6.53E-10	1.93E-10	9.31E-09	1.02E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.76E-09	4.48E-08	1.32E-08	6.39E-07	7.02E-07	8.40E-11	6.53E-10	1.93E-10	9.31E-09	1.02E-08
241-B-202	1.04E-08	1.29E-08	1.59E-08	6.65E-07	7.04E-07	1.47E-10	1.82E-10	2.25E-10	9.39E-09	9.94E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.04E-08	1.29E-08	1.59E-08	6.65E-07	7.04E-07	1.47E-10	1.82E-10	2.25E-10	9.39E-09	9.94E-09

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis $RC_{therm}^{b/r}$ (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis $RC_{therm}^{b/r}$ (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-B-203	3.70E-10	2.27E-08	0.00E+00	1.48E-06	1.51E-06	5.08E-12	3.12E-10	0.00E+00	2.04E-08	2.07E-08
Supernatant	8.40E-13	3.93E-10	0.00E+00	1.35E-06	1.35E-06	1.02E-14	4.78E-12	0.00E+00	1.64E-08	1.64E-08
Solid Layer	3.72E-10	2.29E-08	0.00E+00	1.49E-06	1.51E-06	5.13E-12	3.15E-10	0.00E+00	2.05E-08	2.08E-08
241-B-204	1.38E-10	2.72E-08	0.00E+00	1.49E-06	1.52E-06	1.90E-12	3.74E-10	0.00E+00	2.05E-08	2.09E-08
Supernatant	4.91E-13	9.12E-12	0.00E+00	1.35E-06	1.35E-06	5.96E-15	1.11E-13	0.00E+00	1.64E-08	1.64E-08
Solid Layer	1.40E-10	2.75E-08	0.00E+00	1.49E-06	1.52E-06	1.93E-12	3.79E-10	0.00E+00	2.05E-08	2.09E-08
241-BX-101	1.54E-07	8.59E-09	9.69E-09	1.30E-06	1.47E-06	2.99E-09	1.67E-10	1.88E-10	2.53E-08	2.86E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.54E-07	8.59E-09	9.69E-09	1.30E-06	1.47E-06	2.99E-09	1.67E-10	1.88E-10	2.53E-08	2.86E-08
241-BX-102	5.46E-07	6.58E-10	1.28E-08	1.23E-06	1.79E-06	7.09E-09	8.55E-12	1.67E-10	1.60E-08	2.32E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.46E-07	6.58E-10	1.28E-08	1.23E-06	1.79E-06	7.09E-09	8.55E-12	1.67E-10	1.60E-08	2.32E-08
241-BX-103	1.96E-06	1.83E-07	4.08E-08	9.22E-07	3.11E-06	3.53E-08	3.30E-09	7.36E-10	1.66E-08	5.60E-08
Supernatant	5.84E-09	1.19E-09	7.85E-08	1.41E-07	2.27E-07	7.23E-11	1.48E-11	9.73E-10	1.75E-09	2.81E-09
Solid Layer	2.08E-06	1.94E-07	3.68E-08	1.03E-06	3.34E-06	4.01E-08	3.74E-09	7.07E-10	1.98E-08	6.43E-08
241-BX-104	2.53E-07	1.83E-08	2.54E-08	6.68E-07	9.66E-07	4.89E-09	3.54E-10	4.91E-10	1.29E-08	1.86E-08
Supernatant	1.62E-07	1.76E-11	5.44E-08	1.18E-07	3.35E-07	2.40E-09	2.61E-13	8.06E-10	1.75E-09	4.96E-09
Solid Layer	2.51E-07	1.83E-08	2.48E-08	6.81E-07	9.75E-07	4.88E-09	3.55E-10	4.82E-10	1.32E-08	1.90E-08
241-BX-105	1.49E-07	2.01E-09	2.48E-08	8.98E-07	1.07E-06	2.87E-09	3.89E-11	4.78E-10	1.73E-08	2.07E-08
Supernatant	1.89E-07	1.63E-09	7.00E-08	1.17E-07	3.77E-07	2.81E-09	2.44E-11	1.05E-09	1.75E-09	5.63E-09
Solid Layer	1.28E-07	1.75E-09	2.10E-08	9.41E-07	1.09E-06	2.52E-09	3.42E-11	4.12E-10	1.84E-08	2.14E-08
241-BX-106	4.86E-07	1.20E-08	2.17E-07	1.68E-06	2.39E-06	9.10E-09	2.24E-10	4.06E-09	3.14E-08	4.48E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.86E-07	1.20E-08	2.17E-07	1.68E-06	2.39E-06	9.10E-09	2.24E-10	4.06E-09	3.14E-08	4.48E-08
241-BX-107	4.29E-08	3.03E-09	1.42E-08	2.99E-07	3.59E-07	7.14E-10	5.05E-11	2.37E-10	4.98E-09	5.98E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.29E-08	3.03E-09	1.42E-08	2.99E-07	3.59E-07	7.14E-10	5.05E-11	2.37E-10	4.98E-09	5.98E-09
241-BX-108	1.25E-07	1.06E-09	5.14E-09	2.22E-06	2.35E-06	2.10E-09	1.79E-11	8.66E-11	3.74E-08	3.96E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.25E-07	1.06E-09	5.14E-09	2.22E-06	2.35E-06	2.10E-09	1.79E-11	8.66E-11	3.74E-08	3.96E-08
241-BX-109	3.07E-07	7.37E-10	3.39E-08	4.30E-07	7.71E-07	5.39E-09	1.30E-11	5.96E-10	7.56E-09	1.36E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.07E-07	7.37E-10	3.39E-08	4.30E-07	7.71E-07	5.39E-09	1.30E-11	5.96E-10	7.56E-09	1.36E-08
241-BX-110	5.01E-08	3.01E-10	7.90E-08	3.62E-07	4.91E-07	9.65E-10	5.81E-12	1.52E-09	6.97E-09	9.46E-09
Supernatant	9.20E-08	1.36E-10	8.13E-08	1.05E-07	2.78E-07	1.53E-09	2.27E-12	1.35E-09	1.75E-09	4.64E-09
Solid Layer	4.99E-08	3.02E-10	7.90E-08	3.63E-07	4.92E-07	9.62E-10	5.83E-12	1.52E-09	7.00E-09	9.49E-09
241-BX-111	7.06E-09	5.84E-11	2.18E-09	4.60E-07	4.69E-07	1.18E-10	9.77E-13	3.65E-11	7.70E-09	7.85E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	7.06E-09	5.84E-11	2.18E-09	4.60E-07	4.69E-07	1.18E-10	9.77E-13	3.65E-11	7.70E-09	7.85E-09

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-BX-112	1.11E-07	9.45E-09	0.00E+00	5.65E-07	6.85E-07	1.67E-09	1.43E-10	0.00E+00	8.57E-09	1.04E-08
Supernatant	3.92E-09	9.22E-11	0.00E+00	1.28E-07	1.32E-07	5.35E-11	1.26E-12	0.00E+00	1.75E-09	1.80E-09
Solid Layer	1.11E-07	9.52E-09	0.00E+00	5.69E-07	6.89E-07	1.69E-09	1.44E-10	0.00E+00	8.62E-09	1.05E-08
241-BY-101	5.81E-08	1.84E-10	1.09E-07	2.25E-07	3.92E-07	1.24E-09	3.92E-12	2.31E-09	4.78E-09	8.33E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.81E-08	1.84E-10	1.09E-07	2.25E-07	3.92E-07	1.24E-09	3.92E-12	2.31E-09	4.78E-09	8.33E-09
241-BY-102	2.10E-08	1.01E-09	9.79E-09	3.18E-07	3.49E-07	3.82E-10	1.84E-11	1.78E-10	5.77E-09	6.35E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.10E-08	1.01E-09	9.79E-09	3.18E-07	3.49E-07	3.82E-10	1.84E-11	1.78E-10	5.77E-09	6.35E-09
241-BY-103	3.01E-08	2.73E-10	1.42E-08	2.32E-07	2.77E-07	5.79E-10	5.25E-12	2.72E-10	4.46E-09	5.32E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.01E-08	2.73E-10	1.42E-08	2.32E-07	2.77E-07	5.79E-10	5.25E-12	2.72E-10	4.46E-09	5.32E-09
241-BY-104	7.50E-08	7.69E-10	1.26E-07	2.28E-07	4.30E-07	1.49E-09	1.52E-11	2.50E-09	4.52E-09	8.52E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	7.50E-08	7.69E-10	1.26E-07	2.28E-07	4.30E-07	1.49E-09	1.52E-11	2.50E-09	4.52E-09	8.52E-09
241-BY-105	3.68E-08	7.01E-10	4.17E-08	1.96E-07	2.75E-07	7.67E-10	1.46E-11	8.69E-10	4.08E-09	5.73E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.68E-08	7.01E-10	4.17E-08	1.96E-07	2.75E-07	7.67E-10	1.46E-11	8.69E-10	4.08E-09	5.73E-09
241-BY-106	1.23E-07	5.28E-10	1.32E-07	2.29E-07	4.84E-07	2.34E-09	1.01E-11	2.51E-09	4.36E-09	9.23E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.23E-07	5.28E-10	1.32E-07	2.29E-07	4.84E-07	2.34E-09	1.01E-11	2.51E-09	4.36E-09	9.23E-09
241-BY-107	7.60E-08	4.17E-10	1.11E-07	3.00E-07	4.88E-07	1.49E-09	8.15E-12	2.18E-09	5.87E-09	9.54E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	7.60E-08	4.17E-10	1.11E-07	3.00E-07	4.88E-07	1.49E-09	8.15E-12	2.18E-09	5.87E-09	9.54E-09
241-BY-108	7.35E-08	6.66E-10	1.85E-07	3.95E-07	6.55E-07	1.26E-09	1.15E-11	3.18E-09	6.79E-09	1.12E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	7.35E-08	6.66E-10	1.85E-07	3.95E-07	6.55E-07	1.26E-09	1.15E-11	3.18E-09	6.79E-09	1.12E-08
241-BY-109	1.96E-08	6.53E-10	6.52E-09	2.86E-07	3.13E-07	3.87E-10	1.29E-11	1.29E-10	5.65E-09	6.18E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.96E-08	6.53E-10	6.52E-09	2.86E-07	3.13E-07	3.87E-10	1.29E-11	1.29E-10	5.65E-09	6.18E-09
241-BY-110	9.86E-08	6.61E-10	6.70E-07	2.66E-07	1.03E-06	1.79E-09	1.20E-11	1.21E-08	4.81E-09	1.87E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	9.86E-08	6.61E-10	6.70E-07	2.66E-07	1.03E-06	1.79E-09	1.20E-11	1.21E-08	4.81E-09	1.87E-08
241-BY-111	5.60E-09	2.70E-10	5.17E-09	2.34E-07	2.45E-07	1.09E-10	5.23E-12	1.00E-10	4.53E-09	4.75E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.60E-09	2.70E-10	5.17E-09	2.34E-07	2.45E-07	1.09E-10	5.23E-12	1.00E-10	4.53E-09	4.75E-09
241-BY-112	8.83E-09	2.41E-10	1.36E-08	2.81E-07	3.04E-07	1.78E-10	4.84E-12	2.74E-10	5.67E-09	6.12E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	8.83E-09	2.41E-10	1.36E-08	2.81E-07	3.04E-07	1.78E-10	4.84E-12	2.74E-10	5.67E-09	6.12E-09

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-C-101	1.22E-07	2.18E-08	3.01E-08	7.03E-07	8.77E-07	2.52E-09	4.50E-10	6.21E-10	1.45E-08	1.81E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.22E-07	2.18E-08	3.01E-08	7.03E-07	8.77E-07	2.52E-09	4.50E-10	6.21E-10	1.45E-08	1.81E-08
241-C-102	3.28E-08	6.33E-08	2.26E-08	2.72E-07	3.91E-07	6.39E-10	1.23E-09	4.39E-10	5.30E-09	7.61E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.28E-08	6.33E-08	2.26E-08	2.72E-07	3.91E-07	6.39E-10	1.23E-09	4.39E-10	5.30E-09	7.61E-09
241-C-103	2.72E-06	3.95E-08	3.46E-13	6.20E-05	6.48E-05	4.88E-08	7.09E-10	6.19E-15	1.11E-06	1.16E-06
Supernatant	3.85E-09	6.29E-12	2.75E-12	3.86E-07	3.89E-07	4.37E-11	7.13E-14	3.12E-14	4.37E-09	4.42E-09
Solid Layer	1.81E-06	2.62E-08	2.12E-13	6.61E-05	6.79E-05	3.36E-08	4.88E-10	3.96E-15	1.23E-06	1.26E-06
241-C-104	7.63E-07	3.12E-07	1.62E-07	3.13E-07	1.55E-06	1.48E-08	6.06E-09	3.14E-09	6.08E-09	3.01E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	7.63E-07	3.12E-07	1.62E-07	3.13E-07	1.55E-06	1.48E-08	6.06E-09	3.14E-09	6.08E-09	3.01E-08
241-C-105	8.99E-07	2.06E-07	1.44E-08	5.70E-07	1.69E-06	1.61E-08	3.69E-09	2.58E-10	1.02E-08	3.03E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	8.99E-07	2.06E-07	1.44E-08	5.70E-07	1.69E-06	1.61E-08	3.69E-09	2.58E-10	1.02E-08	3.03E-08
241-C-106	4.50E-05	7.71E-07	7.64E-10	5.68E-05	1.03E-04	8.03E-07	1.38E-08	1.36E-11	1.01E-06	1.83E-06
Supernatant	8.49E-09	3.03E-12	2.37E-09	3.70E-07	3.81E-07	1.00E-10	3.57E-14	2.80E-11	4.37E-09	4.50E-09
Solid Layer	4.47E-05	7.67E-07	7.38E-10	5.80E-05	1.03E-04	8.07E-07	1.38E-08	1.33E-11	1.05E-06	1.87E-06
241-C-107	2.40E-06	1.74E-07	1.23E-07	3.50E-07	3.05E-06	4.31E-08	3.12E-09	2.20E-09	6.28E-09	5.47E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.40E-06	1.74E-07	1.23E-07	3.50E-07	3.05E-06	4.31E-08	3.12E-09	2.20E-09	6.28E-09	5.47E-08
241-C-108	3.28E-07	1.31E-09	2.23E-08	2.71E-06	3.06E-06	5.62E-09	2.24E-11	3.82E-10	4.64E-08	5.24E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.28E-07	1.31E-09	2.23E-08	2.71E-06	3.06E-06	5.62E-09	2.24E-11	3.82E-10	4.64E-08	5.24E-08
241-C-109	1.97E-06	1.16E-08	2.24E-08	1.08E-06	3.09E-06	3.53E-08	2.08E-10	4.01E-10	1.94E-08	5.54E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.97E-06	1.16E-08	2.24E-08	1.08E-06	3.09E-06	3.53E-08	2.08E-10	4.01E-10	1.94E-08	5.54E-08
241-C-110	4.58E-08	5.96E-09	7.90E-10	1.30E-06	1.35E-06	7.10E-10	9.24E-11	1.22E-11	2.01E-08	2.09E-08
Supernatant	1.38E-08	1.37E-10	1.50E-09	3.43E-07	3.59E-07	1.76E-10	1.75E-12	1.91E-11	4.37E-09	4.57E-09
Solid Layer	4.58E-08	5.97E-09	7.86E-10	1.30E-06	1.35E-06	7.11E-10	9.25E-11	1.22E-11	2.02E-08	2.10E-08
241-C-111	4.99E-06	3.72E-08	1.68E-08	1.19E-06	6.23E-06	8.93E-08	6.66E-10	3.00E-10	2.13E-08	1.12E-07
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.99E-06	3.72E-08	1.68E-08	1.19E-06	6.23E-06	8.93E-08	6.66E-10	3.00E-10	2.13E-08	1.12E-07
241-C-112	2.87E-06	3.74E-08	3.74E-08	6.88E-07	3.64E-06	5.24E-08	6.81E-10	6.82E-10	1.25E-08	6.63E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.87E-06	3.74E-08	3.74E-08	6.88E-07	3.64E-06	5.24E-08	6.81E-10	6.82E-10	1.25E-08	6.63E-08
241-C-201	1.84E-06	2.25E-06	0.00E+00	7.07E-05	7.48E-05	3.71E-08	4.54E-08	0.00E+00	1.42E-06	1.51E-06
Supernatant	0.00E+00	0.00E+00	0.00E+00	1.42E-06	1.42E-06	0.00E+00	0.00E+00	0.00E+00	1.64E-08	1.64E-08
Solid Layer	1.81E-06	2.22E-06	0.00E+00	7.12E-05	7.52E-05	3.68E-08	4.50E-08	0.00E+00	1.44E-06	1.52E-06

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-C-202	3.45E-06	1.90E-06	0.00E+00	6.92E-05	7.45E-05	6.94E-08	3.81E-08	0.00E+00	1.39E-06	1.50E-06
Supernatant	0.00E+00	0.00E+00	0.00E+00	1.42E-06	1.42E-06	0.00E+00	0.00E+00	0.00E+00	1.64E-08	1.64E-08
Solid Layer	3.38E-06	1.86E-06	0.00E+00	6.98E-05	7.50E-05	6.86E-08	3.77E-08	0.00E+00	1.41E-06	1.52E-06
241-C-203	1.25E-07	9.79E-08	0.00E+00	6.92E-05	6.94E-05	2.68E-09	2.09E-09	0.00E+00	1.48E-06	1.48E-06
Supernatant	0.00E+00	0.00E+00	0.00E+00	1.42E-06	1.42E-06	0.00E+00	0.00E+00	0.00E+00	1.64E-08	1.64E-08
Solid Layer	1.21E-07	9.45E-08	0.00E+00	7.27E-05	7.30E-05	2.71E-09	2.11E-09	0.00E+00	1.62E-06	1.63E-06
241-C-204	1.81E-06	2.58E-09	0.00E+00	7.36E-05	7.54E-05	3.67E-08	5.23E-11	0.00E+00	1.49E-06	1.53E-06
Supernatant	0.00E+00	0.00E+00	0.00E+00	1.42E-06	1.42E-06	0.00E+00	0.00E+00	0.00E+00	1.64E-08	1.64E-08
Solid Layer	1.79E-06	2.56E-09	0.00E+00	7.45E-05	7.63E-05	3.67E-08	5.24E-11	0.00E+00	1.53E-06	1.56E-06
241-S-101	3.17E-07	5.95E-09	1.45E-07	2.58E-07	7.26E-07	6.06E-09	1.14E-10	2.76E-09	4.93E-09	1.39E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.17E-07	5.95E-09	1.45E-07	2.58E-07	7.26E-07	6.06E-09	1.14E-10	2.76E-09	4.93E-09	1.39E-08
241-S-102	2.43E-07	2.68E-09	8.88E-08	1.77E-06	2.11E-06	5.06E-09	5.57E-11	1.85E-09	3.68E-08	4.38E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.43E-07	2.68E-09	8.88E-08	1.77E-06	2.11E-06	5.06E-09	5.57E-11	1.85E-09	3.68E-08	4.38E-08
241-S-103	1.34E-07	3.33E-09	7.19E-08	3.48E-07	5.57E-07	2.50E-09	6.22E-11	1.34E-09	6.48E-09	1.04E-08
Supernatant	2.37E-07	2.37E-11	1.00E-07	1.04E-07	4.41E-07	3.97E-09	3.98E-13	1.68E-09	1.75E-09	7.40E-09
Solid Layer	1.34E-07	3.34E-09	7.17E-08	3.49E-07	5.57E-07	2.49E-09	6.24E-11	1.34E-09	6.50E-09	1.04E-08
241-S-104	2.18E-07	5.87E-09	2.21E-08	2.92E-07	5.39E-07	4.22E-09	1.13E-10	4.27E-10	5.64E-09	1.04E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.18E-07	5.87E-09	2.21E-08	2.92E-07	5.39E-07	4.22E-09	1.13E-10	4.27E-10	5.64E-09	1.04E-08
241-S-105	1.79E-09	1.11E-11	5.40E-09	2.35E-07	2.42E-07	3.43E-11	2.13E-13	1.04E-10	4.51E-09	4.65E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.79E-09	1.11E-11	5.40E-09	2.35E-07	2.42E-07	3.43E-11	2.13E-13	1.04E-10	4.51E-09	4.65E-09
241-S-106	5.60E-08	4.55E-10	2.39E-08	2.11E-07	2.92E-07	1.12E-09	9.08E-12	4.77E-10	4.21E-09	5.82E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.60E-08	4.55E-10	2.39E-08	2.11E-07	2.92E-07	1.12E-09	9.08E-12	4.77E-10	4.21E-09	5.82E-09
241-S-107	1.93E-07	2.30E-08	2.73E-08	2.37E-07	4.80E-07	3.96E-09	4.72E-10	5.61E-10	4.88E-09	9.87E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.93E-07	2.30E-08	2.73E-08	2.37E-07	4.80E-07	3.96E-09	4.72E-10	5.61E-10	4.88E-09	9.87E-09
241-S-108	3.46E-09	9.79E-11	3.66E-09	1.95E-07	2.02E-07	6.73E-11	1.90E-12	7.10E-11	3.79E-09	3.93E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.46E-09	9.79E-11	3.66E-09	1.95E-07	2.02E-07	6.73E-11	1.90E-12	7.10E-11	3.79E-09	3.93E-09
241-S-109	5.83E-09	2.38E-10	6.25E-09	2.01E-07	2.13E-07	1.12E-10	4.57E-12	1.20E-10	3.85E-09	4.09E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.83E-09	2.38E-10	6.25E-09	2.01E-07	2.13E-07	1.12E-10	4.57E-12	1.20E-10	3.85E-09	4.09E-09
241-S-110	5.44E-08	1.93E-09	8.57E-08	2.41E-07	3.83E-07	1.05E-09	3.71E-11	1.65E-09	4.63E-09	7.36E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.44E-08	1.93E-09	8.57E-08	2.41E-07	3.83E-07	1.05E-09	3.71E-11	1.65E-09	4.63E-09	7.36E-09

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-S-111	1.80E-07	4.18E-10	2.76E-08	2.76E-07	4.84E-07	3.23E-09	7.49E-12	4.95E-10	4.94E-09	8.67E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.80E-07	4.18E-10	2.76E-08	2.76E-07	4.84E-07	3.23E-09	7.49E-12	4.95E-10	4.94E-09	8.67E-09
241-S-112	1.19E-05	2.49E-07	0.00E+00	6.07E-05	7.28E-05	2.30E-07	4.82E-09	0.00E+00	1.18E-06	1.41E-06
Supernatant	0.00E+00	0.00E+00	0.00E+00	3.78E-07	3.78E-07	0.00E+00	0.00E+00	0.00E+00	4.37E-09	4.37E-09
Solid Layer	1.21E-05	2.53E-07	0.00E+00	6.26E-05	7.50E-05	2.39E-07	5.01E-09	0.00E+00	1.24E-06	1.48E-06
241-SX-101	9.40E-08	1.03E-08	7.07E-08	2.28E-07	4.03E-07	1.83E-09	2.01E-10	1.37E-09	4.44E-09	7.84E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	9.40E-08	1.03E-08	7.07E-08	2.28E-07	4.03E-07	1.83E-09	2.01E-10	1.37E-09	4.44E-09	7.84E-09
241-SX-102	2.31E-07	5.31E-09	5.75E-07	2.57E-07	1.07E-06	4.54E-09	1.04E-10	1.13E-08	5.04E-09	2.10E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.31E-07	5.31E-09	5.75E-07	2.57E-07	1.07E-06	4.54E-09	1.04E-10	1.13E-08	5.04E-09	2.10E-08
241-SX-103	3.46E-07	7.10E-09	2.12E-06	1.98E-07	2.67E-06	6.92E-09	1.42E-10	4.24E-08	3.96E-09	5.34E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.46E-07	7.10E-09	2.12E-06	1.98E-07	2.67E-06	6.92E-09	1.42E-10	4.24E-08	3.96E-09	5.34E-08
241-SX-104	1.81E-07	4.66E-09	4.54E-07	2.18E-07	8.57E-07	3.55E-09	9.15E-11	8.91E-09	4.27E-09	1.68E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.81E-07	4.66E-09	4.54E-07	2.18E-07	8.57E-07	3.55E-09	9.15E-11	8.91E-09	4.27E-09	1.68E-08
241-SX-105	5.99E-07	1.71E-08	3.31E-06	2.51E-07	4.18E-06	1.13E-08	3.22E-10	6.25E-08	4.74E-09	7.88E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.99E-07	1.71E-08	3.31E-06	2.51E-07	4.18E-06	1.13E-08	3.22E-10	6.25E-08	4.74E-09	7.88E-08
241-SX-106	1.34E-07	5.04E-09	1.26E-07	2.51E-07	5.16E-07	2.45E-09	9.20E-11	2.31E-09	4.58E-09	9.43E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.34E-07	5.04E-09	1.26E-07	2.51E-07	5.16E-07	2.45E-09	9.20E-11	2.31E-09	4.58E-09	9.43E-09
241-SX-107	1.32E-06	1.95E-08	1.22E-06	6.68E-07	3.23E-06	2.71E-08	3.99E-10	2.50E-08	1.37E-08	6.62E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.32E-06	1.95E-08	1.22E-06	6.68E-07	3.23E-06	2.71E-08	3.99E-10	2.50E-08	1.37E-08	6.62E-08
241-SX-108	4.55E-07	6.31E-09	2.39E-07	8.27E-07	1.53E-06	9.32E-09	1.29E-10	4.89E-09	1.69E-08	3.13E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.55E-07	6.31E-09	2.39E-07	8.27E-07	1.53E-06	9.32E-09	1.29E-10	4.89E-09	1.69E-08	3.13E-08
241-SX-109	6.21E-07	5.29E-09	1.38E-06	3.19E-07	2.32E-06	1.25E-08	1.06E-10	2.76E-08	6.41E-09	4.66E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.21E-07	5.29E-09	1.38E-06	3.19E-07	2.32E-06	1.25E-08	1.06E-10	2.76E-08	6.41E-09	4.66E-08
241-SX-110	7.70E-06	5.51E-08	1.35E-06	1.07E-06	1.02E-05	1.57E-07	1.12E-09	2.76E-08	2.18E-08	2.08E-07
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	7.70E-06	5.51E-08	1.35E-06	1.07E-06	1.02E-05	1.57E-07	1.12E-09	2.76E-08	2.18E-08	2.08E-07
241-SX-111	1.93E-06	2.24E-08	2.09E-06	5.64E-07	4.61E-06	3.94E-08	4.57E-10	4.26E-08	1.15E-08	9.40E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.93E-06	2.24E-08	2.09E-06	5.64E-07	4.61E-06	3.94E-08	4.57E-10	4.26E-08	1.15E-08	9.40E-08

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-SX-112	1.61E-06	2.35E-08	5.43E-07	8.19E-07	3.00E-06	3.30E-08	4.82E-10	1.11E-08	1.68E-08	6.14E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.61E-06	2.35E-08	5.43E-07	8.19E-07	3.00E-06	3.30E-08	4.82E-10	1.11E-08	1.68E-08	6.14E-08
241-SX-113	9.80E-08	6.84E-09	3.74E-08	3.67E-06	3.82E-06	1.62E-09	1.13E-10	6.19E-10	6.08E-08	6.32E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	9.80E-08	6.84E-09	3.74E-08	3.67E-06	3.82E-06	1.62E-09	1.13E-10	6.19E-10	6.08E-08	6.32E-08
241-SX-114	1.38E-06	1.83E-08	1.71E-06	4.43E-07	3.55E-06	2.79E-08	3.72E-10	3.46E-08	8.98E-09	7.19E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.38E-06	1.83E-08	1.71E-06	4.43E-07	3.55E-06	2.79E-08	3.72E-10	3.46E-08	8.98E-09	7.19E-08
241-SX-115	6.91E-06	3.08E-07	5.92E-09	1.31E-05	2.03E-05	1.42E-07	6.31E-09	1.21E-10	2.67E-07	4.15E-07
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.91E-06	3.08E-07	5.92E-09	1.31E-05	2.03E-05	1.42E-07	6.31E-09	1.21E-10	2.67E-07	4.15E-07
241-T-101	5.04E-08	1.33E-08	4.67E-08	7.29E-07	8.39E-07	9.01E-10	2.37E-10	8.35E-10	1.30E-08	1.50E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.04E-08	1.33E-08	4.67E-08	7.29E-07	8.39E-07	9.01E-10	2.37E-10	8.35E-10	1.30E-08	1.50E-08
241-T-102	2.08E-07	4.43E-09	1.86E-09	5.22E-06	5.43E-06	3.70E-09	7.86E-11	3.30E-11	9.27E-08	9.65E-08
Supernatant	1.13E-07	5.06E-10	3.33E-09	3.31E-07	4.48E-07	1.49E-09	6.68E-12	4.40E-11	4.37E-09	5.92E-09
Solid Layer	1.79E-07	4.11E-09	1.24E-09	7.29E-06	7.47E-06	3.73E-09	8.55E-11	2.57E-11	1.52E-07	1.55E-07
241-T-103	1.17E-08	1.17E-09	2.83E-08	2.29E-06	2.33E-06	2.22E-10	2.22E-11	5.35E-10	4.33E-08	4.41E-08
Supernatant	3.59E-08	1.10E-09	5.02E-08	1.27E-07	2.14E-07	4.95E-10	1.52E-11	6.92E-10	1.75E-09	2.95E-09
Solid Layer	9.69E-09	1.13E-09	2.57E-08	2.54E-06	2.58E-06	1.92E-10	2.24E-11	5.09E-10	5.05E-08	5.12E-08
241-T-104	6.72E-09	8.51E-09	1.74E-08	3.54E-07	3.87E-07	1.00E-10	1.27E-10	2.59E-10	5.29E-09	5.77E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.72E-09	8.51E-09	1.74E-08	3.54E-07	3.87E-07	1.00E-10	1.27E-10	2.59E-10	5.29E-09	5.77E-09
241-T-105	1.70E-07	2.22E-08	3.40E-09	7.80E-07	9.76E-07	2.88E-09	3.76E-10	5.75E-11	1.32E-08	1.65E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.70E-07	2.22E-08	3.40E-09	7.80E-07	9.76E-07	2.88E-09	3.76E-10	5.75E-11	1.32E-08	1.65E-08
241-T-106	1.32E-08	2.83E-09	4.80E-09	2.91E-06	2.93E-06	2.43E-10	5.19E-11	8.82E-11	5.34E-08	5.38E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.32E-08	2.83E-09	4.80E-09	2.91E-06	2.93E-06	2.43E-10	5.19E-11	8.82E-11	5.34E-08	5.38E-08
241-T-107	2.09E-07	1.28E-08	1.02E-08	4.55E-07	6.87E-07	3.77E-09	2.32E-10	1.85E-10	8.22E-09	1.24E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.09E-07	1.28E-08	1.02E-08	4.55E-07	6.87E-07	3.77E-09	2.32E-10	1.85E-10	8.22E-09	1.24E-08
241-T-108	6.30E-09	1.09E-09	2.49E-12	4.04E-06	4.05E-06	1.13E-10	1.95E-11	4.45E-14	7.24E-08	7.25E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.30E-09	1.09E-09	2.49E-12	4.04E-06	4.05E-06	1.13E-10	1.95E-11	4.45E-14	7.24E-08	7.25E-08
241-T-109	2.49E-09	2.29E-10	5.26E-12	1.04E-06	1.04E-06	4.74E-11	4.36E-12	1.00E-13	1.98E-08	1.98E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.49E-09	2.29E-10	5.26E-12	1.04E-06	1.04E-06	4.74E-11	4.36E-12	1.00E-13	1.98E-08	1.98E-08

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-T-110	2.87E-10	9.87E-09	0.00E+00	8.26E-07	8.36E-07	4.15E-12	1.43E-10	0.00E+00	1.19E-08	1.21E-08
Supernatant	2.10E-11	2.74E-11	0.00E+00	3.60E-07	3.60E-07	2.55E-13	3.33E-13	0.00E+00	4.37E-09	4.37E-09
Solid Layer	2.87E-10	9.89E-09	0.00E+00	8.27E-07	8.37E-07	4.16E-12	1.43E-10	0.00E+00	1.20E-08	1.21E-08
241-T-111	1.33E-08	1.03E-08	1.59E-08	2.97E-07	3.36E-07	1.91E-10	1.47E-10	2.29E-10	4.26E-09	4.82E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.33E-08	1.03E-08	1.59E-08	2.97E-07	3.36E-07	1.91E-10	1.47E-10	2.29E-10	4.26E-09	4.82E-09
241-T-112	1.74E-09	2.45E-08	6.44E-10	1.27E-06	1.30E-06	2.54E-11	3.57E-10	9.40E-12	1.86E-08	1.90E-08
Supernatant	2.16E-08	2.46E-09	7.40E-10	1.37E-07	1.62E-07	2.75E-10	3.14E-11	9.42E-12	1.75E-09	2.06E-09
Solid Layer	2.75E-11	2.63E-08	6.35E-10	1.38E-06	1.41E-06	4.07E-13	3.90E-10	9.40E-12	2.05E-08	2.09E-08
241-T-201	4.05E-10	5.57E-08	0.00E+00	1.54E-06	1.60E-06	6.07E-12	8.34E-10	0.00E+00	2.30E-08	2.39E-08
Supernatant	4.40E-13	2.75E-12	0.00E+00	1.34E-06	1.34E-06	5.40E-15	3.37E-14	0.00E+00	1.64E-08	1.64E-08
Solid Layer	4.21E-10	5.79E-08	0.00E+00	1.55E-06	1.61E-06	6.39E-12	8.78E-10	0.00E+00	2.35E-08	2.44E-08
241-T-202	2.65E-11	1.43E-08	1.77E-08	7.71E-07	8.03E-07	3.62E-13	1.95E-10	2.42E-10	1.05E-08	1.10E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.65E-11	1.43E-08	1.77E-08	7.71E-07	8.03E-07	3.62E-13	1.95E-10	2.42E-10	1.05E-08	1.10E-08
241-T-203	2.31E-11	1.66E-08	1.39E-08	6.24E-07	6.54E-07	3.25E-13	2.34E-10	1.96E-10	8.81E-09	9.24E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.31E-11	1.66E-08	1.39E-08	6.24E-07	6.54E-07	3.25E-13	2.34E-10	1.96E-10	8.81E-09	9.24E-09
241-T-204	3.31E-11	1.51E-08	1.60E-08	6.45E-07	6.76E-07	4.52E-13	2.06E-10	2.19E-10	8.81E-09	9.23E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.31E-11	1.51E-08	1.60E-08	6.45E-07	6.76E-07	4.52E-13	2.06E-10	2.19E-10	8.81E-09	9.23E-09
241-TX-101	2.54E-07	1.76E-08	5.01E-08	6.99E-07	1.02E-06	5.12E-09	3.55E-10	1.01E-09	1.41E-08	2.06E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.54E-07	1.76E-08	5.01E-08	6.99E-07	1.02E-06	5.12E-09	3.55E-10	1.01E-09	1.41E-08	2.06E-08
241-TX-102	1.87E-08	1.56E-09	2.46E-08	3.70E-07	4.15E-07	3.49E-10	2.91E-11	4.60E-10	6.91E-09	7.75E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.87E-08	1.56E-09	2.46E-08	3.70E-07	4.15E-07	3.49E-10	2.91E-11	4.60E-10	6.91E-09	7.75E-09
241-TX-103	2.62E-08	2.23E-09	2.00E-08	5.09E-07	5.57E-07	4.89E-10	4.16E-11	3.73E-10	9.49E-09	1.04E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.62E-08	2.23E-09	2.00E-08	5.09E-07	5.57E-07	4.89E-10	4.16E-11	3.73E-10	9.49E-09	1.04E-08
241-TX-104	2.24E-07	4.69E-09	6.15E-09	8.97E-07	1.13E-06	4.48E-09	9.38E-11	1.23E-10	1.79E-08	2.26E-08
Supernatant	2.00E-07	1.81E-10	6.97E-09	1.05E-07	3.12E-07	3.33E-09	3.01E-12	1.16E-10	1.75E-09	5.20E-09
Solid Layer	2.25E-07	4.81E-09	6.12E-09	9.20E-07	1.16E-06	4.52E-09	9.66E-11	1.23E-10	1.85E-08	2.32E-08
241-TX-105	5.15E-09	5.42E-10	1.76E-08	1.95E-07	2.19E-07	9.74E-11	1.02E-11	3.32E-10	3.69E-09	4.13E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.15E-09	5.42E-10	1.76E-08	1.95E-07	2.19E-07	9.74E-11	1.02E-11	3.32E-10	3.69E-09	4.13E-09
241-TX-106	2.40E-08	2.12E-09	2.79E-08	2.65E-07	3.19E-07	4.50E-10	3.98E-11	5.23E-10	4.97E-09	5.98E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.40E-08	2.12E-09	2.79E-08	2.65E-07	3.19E-07	4.50E-10	3.98E-11	5.23E-10	4.97E-09	5.98E-09

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-TX-107	5.31E-08	4.52E-08	3.07E-08	1.92E-06	2.05E-06	1.10E-09	9.31E-10	6.32E-10	3.96E-08	4.23E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.31E-08	4.52E-08	3.07E-08	1.92E-06	2.05E-06	1.10E-09	9.31E-10	6.32E-10	3.96E-08	4.23E-08
241-TX-108	1.26E-08	1.22E-09	9.36E-09	5.66E-07	5.89E-07	2.36E-10	2.28E-11	1.76E-10	1.06E-08	1.11E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.26E-08	1.22E-09	9.36E-09	5.66E-07	5.89E-07	2.36E-10	2.28E-11	1.76E-10	1.06E-08	1.11E-08
241-TX-109	4.07E-08	4.43E-09	9.49E-08	2.92E-07	4.32E-07	6.74E-10	7.33E-11	1.57E-09	4.83E-09	7.15E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.07E-08	4.43E-09	9.49E-08	2.92E-07	4.32E-07	6.74E-10	7.33E-11	1.57E-09	4.83E-09	7.15E-09
241-TX-110	6.01E-09	7.30E-10	1.20E-08	2.21E-07	2.40E-07	1.12E-10	1.37E-11	2.25E-10	4.15E-09	4.50E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.01E-09	7.30E-10	1.20E-08	2.21E-07	2.40E-07	1.12E-10	1.37E-11	2.25E-10	4.15E-09	4.50E-09
241-TX-111	6.65E-09	8.34E-10	1.28E-08	2.58E-07	2.79E-07	1.24E-10	1.56E-11	2.39E-10	4.82E-09	5.20E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.65E-09	8.34E-10	1.28E-08	2.58E-07	2.79E-07	1.24E-10	1.56E-11	2.39E-10	4.82E-09	5.20E-09
241-TX-112	9.19E-09	1.05E-09	7.31E-09	1.86E-07	2.04E-07	1.74E-10	1.99E-11	1.38E-10	3.52E-09	3.85E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	9.19E-09	1.05E-09	7.31E-09	1.86E-07	2.04E-07	1.74E-10	1.99E-11	1.38E-10	3.52E-09	3.85E-09
241-TX-113	5.04E-10	3.46E-11	3.38E-09	1.88E-07	1.92E-07	9.37E-12	6.44E-13	6.30E-11	3.51E-09	3.58E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.04E-10	3.46E-11	3.38E-09	1.88E-07	1.92E-07	9.37E-12	6.44E-13	6.30E-11	3.51E-09	3.58E-09
241-TX-114	5.27E-09	5.45E-10	1.20E-09	2.04E-07	2.11E-07	9.96E-11	1.03E-11	2.27E-11	3.86E-09	3.99E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.27E-09	5.45E-10	1.20E-09	2.04E-07	2.11E-07	9.96E-11	1.03E-11	2.27E-11	3.86E-09	3.99E-09
241-TX-115	5.75E-09	6.56E-10	5.20E-09	2.00E-07	2.12E-07	1.08E-10	1.24E-11	9.80E-11	3.78E-09	4.00E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.75E-09	6.56E-10	5.20E-09	2.00E-07	2.12E-07	1.08E-10	1.24E-11	9.80E-11	3.78E-09	4.00E-09
241-TX-116	2.54E-09	2.06E-10	1.42E-11	1.89E-07	1.92E-07	4.88E-11	3.96E-12	2.72E-13	3.62E-09	3.68E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.54E-09	2.06E-10	1.42E-11	1.89E-07	1.92E-07	4.88E-11	3.96E-12	2.72E-13	3.62E-09	3.68E-09
241-TX-117	2.72E-09	2.80E-10	4.65E-13	2.23E-07	2.26E-07	4.98E-11	5.12E-12	8.51E-15	4.08E-09	4.14E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.72E-09	2.80E-10	4.65E-13	2.23E-07	2.26E-07	4.98E-11	5.12E-12	8.51E-15	4.08E-09	4.14E-09
241-TX-118	6.92E-08	6.46E-08	2.77E-08	3.21E-07	4.82E-07	1.36E-09	1.26E-09	5.42E-10	6.28E-09	9.45E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.92E-08	6.46E-08	2.77E-08	3.21E-07	4.82E-07	1.36E-09	1.26E-09	5.42E-10	6.28E-09	9.45E-09
241-TY-101	2.69E-09	8.56E-10	9.88E-13	5.96E-07	6.00E-07	5.07E-11	1.61E-11	1.86E-14	1.12E-08	1.13E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.69E-09	8.56E-10	9.88E-13	5.96E-07	6.00E-07	5.07E-11	1.61E-11	1.86E-14	1.12E-08	1.13E-08

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-TY-102	2.01E-08	6.92E-11	7.84E-09	8.82E-07	9.10E-07	4.08E-10	1.41E-12	1.59E-10	1.79E-08	1.85E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.01E-08	6.92E-11	7.84E-09	8.82E-07	9.10E-07	4.08E-10	1.41E-12	1.59E-10	1.79E-08	1.85E-08
241-TY-103	1.09E-07	5.49E-09	7.42E-08	4.62E-07	6.51E-07	2.11E-09	1.07E-10	1.44E-09	9.00E-09	1.27E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.09E-07	5.49E-09	7.42E-08	4.62E-07	6.51E-07	2.11E-09	1.07E-10	1.44E-09	9.00E-09	1.27E-08
241-TY-104	2.44E-07	1.04E-08	2.55E-09	1.42E-06	1.68E-06	4.62E-09	1.97E-10	4.84E-11	2.70E-08	3.18E-08
Supernatant	2.28E-08	1.06E-10	3.98E-09	1.28E-07	1.55E-07	3.12E-10	1.44E-12	5.44E-11	1.75E-09	2.12E-09
Solid Layer	2.46E-07	1.05E-08	2.53E-09	1.45E-06	1.71E-06	4.70E-09	2.01E-10	4.82E-11	2.78E-08	3.27E-08
241-TY-105	2.26E-07	7.86E-10	1.65E-08	3.73E-07	6.16E-07	4.01E-09	1.39E-11	2.92E-10	6.60E-09	1.09E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.26E-07	7.86E-10	1.65E-08	3.73E-07	6.16E-07	4.01E-09	1.39E-11	2.92E-10	6.60E-09	1.09E-08
241-TY-106	3.05E-07	1.25E-09	6.95E-09	4.33E-06	4.64E-06	4.93E-09	2.02E-11	1.13E-10	7.01E-08	7.52E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.05E-07	1.25E-09	6.95E-09	4.33E-06	4.64E-06	4.93E-09	2.02E-11	1.13E-10	7.01E-08	7.52E-08
241-U-101	6.07E-07	1.76E-09	1.06E-08	2.46E-06	3.08E-06	1.24E-08	3.61E-11	2.17E-10	5.05E-08	6.32E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.07E-07	1.76E-09	1.06E-08	2.46E-06	3.08E-06	1.24E-08	3.61E-11	2.17E-10	5.05E-08	6.32E-08
241-U-102	2.39E-07	5.35E-09	1.89E-07	2.67E-07	7.02E-07	4.64E-09	1.03E-10	3.67E-09	5.18E-09	1.36E-08
Supernatant	4.05E-07	2.47E-10	2.99E-07	1.02E-07	8.07E-07	6.94E-09	4.24E-12	5.12E-09	1.75E-09	1.38E-08
Solid Layer	2.39E-07	5.35E-09	1.89E-07	2.68E-07	7.01E-07	4.63E-09	1.04E-10	3.66E-09	5.19E-09	1.36E-08
241-U-103	1.49E-07	3.93E-09	3.59E-07	2.52E-07	7.64E-07	2.94E-09	7.73E-11	7.06E-09	4.97E-09	1.50E-08
Supernatant	4.20E-07	4.83E-10	4.51E-07	1.05E-07	9.76E-07	7.00E-09	8.05E-12	7.52E-09	1.75E-09	1.63E-08
Solid Layer	1.49E-07	3.93E-09	3.58E-07	2.52E-07	7.64E-07	2.93E-09	7.74E-11	7.06E-09	4.97E-09	1.50E-08
241-U-104	6.56E-09	2.50E-10	4.11E-07	1.72E-06	2.14E-06	8.53E-11	3.25E-12	5.35E-09	2.24E-08	2.79E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.56E-09	2.50E-10	4.11E-07	1.72E-06	2.14E-06	8.53E-11	3.25E-12	5.35E-09	2.24E-08	2.79E-08
241-U-105	1.24E-07	1.34E-08	2.78E-07	2.55E-07	6.70E-07	2.40E-09	2.59E-10	5.38E-09	4.92E-09	1.30E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.24E-07	1.34E-08	2.78E-07	2.55E-07	6.70E-07	2.40E-09	2.59E-10	5.38E-09	4.92E-09	1.30E-08
241-U-106	3.89E-07	2.32E-08	5.99E-07	4.64E-07	1.48E-06	6.98E-09	4.16E-10	1.07E-08	8.33E-09	2.65E-08
Supernatant	4.88E-07	6.44E-09	5.26E-07	1.13E-07	1.13E-06	7.57E-09	9.99E-11	8.16E-09	1.75E-09	1.76E-08
Solid Layer	3.88E-07	2.33E-08	5.99E-07	4.67E-07	1.48E-06	6.98E-09	4.19E-10	1.08E-08	8.40E-09	2.66E-08
241-U-107	6.28E-08	9.50E-09	7.37E-08	2.76E-07	4.22E-07	1.26E-09	1.91E-10	1.48E-09	5.56E-09	8.50E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.28E-08	9.50E-09	7.37E-08	2.76E-07	4.22E-07	1.26E-09	1.91E-10	1.48E-09	5.56E-09	8.50E-09
241-U-108	1.16E-07	2.60E-09	1.94E-07	2.23E-07	5.35E-07	2.26E-09	5.05E-11	3.77E-09	4.33E-09	1.04E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.16E-07	2.60E-09	1.94E-07	2.23E-07	5.35E-07	2.26E-09	5.05E-11	3.77E-09	4.33E-09	1.04E-08

Table B-3. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{alpha} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{rad}^{b/r}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{alpha} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
241-U-109	7.92E-08	6.63E-10	1.32E-07	2.67E-07	4.79E-07	1.51E-09	1.27E-11	2.53E-09	5.10E-09	9.16E-09
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	7.92E-08	6.63E-10	1.32E-07	2.67E-07	4.79E-07	1.51E-09	1.27E-11	2.53E-09	5.10E-09	9.16E-09
241-U-110	2.70E-07	7.64E-09	1.62E-08	4.09E-07	7.03E-07	5.36E-09	1.52E-10	3.22E-10	8.13E-09	1.40E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.70E-07	7.64E-09	1.62E-08	4.09E-07	7.03E-07	5.36E-09	1.52E-10	3.22E-10	8.13E-09	1.40E-08
241-U-111	1.16E-07	5.15E-09	7.27E-08	3.65E-07	5.59E-07	2.15E-09	9.60E-11	1.35E-09	6.80E-09	1.04E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.16E-07	5.15E-09	7.27E-08	3.65E-07	5.59E-07	2.15E-09	9.60E-11	1.35E-09	6.80E-09	1.04E-08
241-U-112	3.00E-07	6.77E-10	1.08E-08	1.31E-06	1.62E-06	6.06E-09	1.37E-11	2.18E-10	2.64E-08	3.27E-08
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.00E-07	6.77E-10	1.08E-08	1.31E-06	1.62E-06	6.06E-09	1.37E-11	2.18E-10	2.64E-08	3.27E-08
241-U-201	7.34E-09	7.05E-11	0.00E+00	1.52E-06	1.53E-06	5.92E-11	1.25E-12	0.00E+00	2.70E-08	2.70E-08
Supernatant	3.52E-08	2.88E-11	0.00E+00	4.49E-07	4.85E-07	5.13E-10	4.21E-13	0.00E+00	6.55E-09	7.07E-09
Solid Layer	3.14E-09	6.41E-11	0.00E+00	1.82E-06	1.83E-06	5.92E-11	1.21E-12	0.00E+00	3.44E-08	3.45E-08
241-U-202	6.11E-09	8.53E-11	1.33E-10	1.70E-06	1.71E-06	4.66E-11	1.43E-12	2.22E-12	2.84E-08	2.85E-08
Supernatant	2.40E-08	5.30E-13	2.24E-10	4.42E-07	4.67E-07	3.56E-10	7.85E-15	3.32E-12	6.55E-09	6.91E-09
Solid Layer	2.67E-09	8.29E-11	9.89E-11	2.13E-06	2.13E-06	4.66E-11	1.45E-12	1.73E-12	3.72E-08	3.72E-08
241-U-203	8.42E-09	7.52E-11	0.00E+00	1.74E-06	1.75E-06	7.84E-11	1.30E-12	0.00E+00	3.01E-08	3.02E-08
Supernatant	2.57E-08	1.30E-12	0.00E+00	4.42E-07	4.68E-07	3.80E-10	1.93E-14	0.00E+00	6.55E-09	6.93E-09
Solid Layer	4.26E-09	8.57E-11	0.00E+00	2.21E-06	2.21E-06	7.84E-11	1.58E-12	0.00E+00	4.06E-08	4.07E-08
241-U-204	1.89E-08	3.18E-09	2.57E-11	5.55E-06	5.57E-06	2.16E-10	4.93E-11	3.98E-13	1.26E-07	1.26E-07
Supernatant	2.49E-08	1.19E-12	5.01E-11	1.28E-06	1.30E-06	3.20E-10	1.53E-14	6.44E-13	1.64E-08	1.67E-08
Solid Layer	1.27E-08	2.68E-09	1.51E-11	7.39E-06	7.41E-06	2.16E-10	4.56E-11	2.57E-13	1.26E-07	1.26E-07
AY102-S-14U	1.44E-05	8.24E-07	3.00E-08	1.21E-06	1.64E-05	2.67E-07	1.53E-08	5.58E-10	2.25E-08	3.05E-07
AY102-S-14L	2.21E-05	9.89E-07	5.48E-08	1.64E-06	2.48E-05	4.06E-07	1.81E-08	1.00E-09	3.00E-08	4.55E-07
AY102-S-15U	1.09E-05	9.15E-07	5.15E-08	3.98E-06	1.58E-05	1.95E-07	1.64E-08	9.23E-10	7.13E-08	2.84E-07
AY102-S-15L	2.43E-05	1.14E-06	1.45E-07	1.17E-06	2.67E-05	4.49E-07	2.11E-08	2.68E-09	2.16E-08	4.95E-07
AY-102-S-16	5.05E-05	1.20E-06	1.78E-07	1.51E-06	5.34E-05	8.18E-07	1.94E-08	2.88E-09	2.45E-08	8.64E-07
AY102-Orig-9"	1.06E-04	1.23E-06	1.88E-07	1.71E-06	1.09E-04	1.76E-06	2.04E-08	3.13E-09	2.84E-08	1.81E-06

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-AN-101	9.05E-04	3.60E-07	7.54E-04	1.50E-04	50.0%	0.02%	41.7%	8.3%	1.81E-03	74
Supernatant	8.85E-04	2.27E-07	7.42E-04	9.46E-05	51.4%	0.01%	43.1%	5.5%	1.72E-03	70
Solid Layer	1.99E-05	1.33E-07	1.24E-05	5.54E-05	22.7%	0.15%	14.1%	63.1%	8.78E-05	4
241-AN-102	3.60E-03	2.44E-05	5.17E-03	1.47E-04	40.3%	0.27%	57.8%	1.6%	8.95E-03	365
Supernatant	3.05E-03	1.36E-05	4.58E-03	7.92E-05	39.5%	0.18%	59.3%	1.0%	7.72E-03	315
Solid Layer	5.53E-04	1.09E-05	5.97E-04	6.73E-05	45.0%	0.89%	48.6%	5.5%	1.23E-03	50
241-AN-103	9.03E-04	5.57E-07	1.36E-03	1.37E-04	37.7%	0.02%	56.6%	5.7%	2.40E-03	98
Supernatant	6.51E-04	2.83E-07	7.71E-04	4.05E-05	44.5%	0.02%	52.7%	2.8%	1.46E-03	60
Solid Layer	2.53E-04	2.74E-07	5.86E-04	9.63E-05	27.0%	0.03%	62.7%	10.3%	9.36E-04	38
241-AN-104	1.17E-03	9.95E-07	1.61E-03	1.44E-04	40.1%	0.03%	55.0%	4.9%	2.92E-03	119
Supernatant	6.85E-04	1.96E-08	8.23E-04	5.24E-05	43.9%	0.00%	52.7%	3.4%	1.56E-03	64
Solid Layer	4.87E-04	9.75E-07	7.85E-04	9.19E-05	35.7%	0.07%	57.5%	6.7%	1.36E-03	56
241-AN-105	7.80E-04	1.26E-06	9.18E-04	1.49E-04	42.2%	0.07%	49.7%	8.0%	1.85E-03	75
Supernatant	3.68E-04	7.29E-07	4.36E-04	5.01E-05	43.0%	0.09%	51.0%	5.9%	8.54E-04	35
Solid Layer	4.13E-04	5.34E-07	4.82E-04	9.86E-05	41.5%	0.05%	48.5%	9.9%	9.94E-04	41
241-AN-106	6.12E-03	2.71E-04	1.36E-04	2.93E-04	89.7%	3.97%	2.0%	4.3%	6.83E-03	278
Supernatant	1.64E-04	5.55E-07	1.17E-04	1.14E-04	41.4%	0.14%	29.6%	28.8%	3.97E-04	16
Solid Layer	5.96E-03	2.71E-04	1.89E-05	1.79E-04	92.7%	4.21%	0.3%	2.8%	6.43E-03	262
241-AN-107	4.01E-03	9.00E-05	2.79E-03	1.49E-04	56.9%	1.28%	39.7%	2.1%	7.04E-03	287
Supernatant	2.86E-03	6.28E-05	2.22E-03	7.54E-05	54.8%	1.21%	42.5%	1.4%	5.21E-03	213
Solid Layer	1.15E-03	2.72E-05	5.76E-04	7.36E-05	63.0%	1.49%	31.5%	4.0%	1.83E-03	74
241-AP-101	3.21E-04	2.58E-07	4.81E-05	1.50E-04	61.8%	0.05%	9.3%	28.9%	5.19E-04	21
Supernatant	3.21E-04	2.58E-07	4.81E-05	1.50E-04	61.8%	0.05%	9.3%	28.9%	5.19E-04	21
Solid Layer	na	na	na	na	na	na	na	na	na	na
241-AP-102	7.17E-04	1.84E-07	3.35E-04	1.50E-04	59.7%	0.02%	27.9%	12.5%	1.20E-03	49
Supernatant	7.12E-04	1.82E-07	3.29E-04	9.35E-05	62.8%	0.02%	29.0%	8.2%	1.13E-03	46
Solid Layer	4.99E-06	2.16E-09	6.31E-06	5.62E-05	7.4%	0.00%	9.3%	83.3%	6.75E-05	3
241-AP-103	5.99E-04	6.24E-07	7.99E-04	1.17E-04	39.5%	0.04%	52.7%	7.7%	1.52E-03	62
Supernatant	5.90E-04	6.21E-07	7.87E-04	6.29E-05	41.0%	0.04%	54.6%	4.4%	1.44E-03	59
Solid Layer	8.29E-06	2.62E-09	1.16E-05	5.42E-05	11.2%	0.00%	15.7%	73.1%	7.41E-05	3
241-AP-104	9.11E-04	4.06E-07	3.84E-04	1.45E-04	63.2%	0.03%	26.7%	10.1%	1.44E-03	59
Supernatant	9.11E-04	4.06E-07	3.84E-04	1.45E-04	63.2%	0.03%	26.7%	10.1%	1.44E-03	59
Solid Layer	na	na	na	na	na	na	na	na	na	na
241-AP-105	6.11E-04	2.37E-07	9.73E-05	1.48E-04	71.3%	0.03%	11.4%	17.3%	8.56E-04	35
Supernatant	5.23E-04	1.28E-07	9.03E-05	8.82E-05	74.5%	0.02%	12.9%	12.6%	7.01E-04	29
Solid Layer	8.78E-05	1.09E-07	6.97E-06	5.97E-05	56.8%	0.07%	4.5%	38.6%	1.55E-04	6
241-AP-106	1.07E-03	1.26E-07	2.11E-04	1.48E-04	74.8%	0.01%	14.8%	10.4%	1.42E-03	58
Supernatant	1.07E-03	1.26E-07	2.11E-04	1.48E-04	74.8%	0.01%	14.8%	10.4%	1.42E-03	58
Solid Layer	na	na	na	na	na	na	na	na	na	na

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-AP-107	3.49E-04	4.33E-08	7.79E-05	1.44E-04	61.1%	0.01%	13.6%	25.3%	5.72E-04	23
Supernatant	3.49E-04	4.33E-08	7.79E-05	1.44E-04	61.1%	0.01%	13.6%	25.3%	5.72E-04	23
Solid Layer	na	na	na	na	na	na	na	na	na	na
241-AP-108	6.21E-04	2.20E-07	3.89E-04	1.58E-04	53.2%	0.02%	33.3%	13.5%	1.17E-03	48
Supernatant	5.77E-04	2.15E-07	3.55E-04	9.70E-05	56.1%	0.02%	34.5%	9.4%	1.03E-03	42
Solid Layer	4.43E-05	5.24E-09	3.38E-05	6.11E-05	31.9%	0.00%	24.3%	43.8%	1.39E-04	6
241-AW-101	1.05E-03	4.81E-06	1.30E-03	1.49E-04	41.9%	0.19%	52.0%	6.0%	2.50E-03	102
Supernatant	6.68E-04	4.46E-08	8.14E-04	6.24E-05	43.3%	0.00%	52.7%	4.0%	1.55E-03	63
Solid Layer	3.81E-04	4.76E-06	4.87E-04	8.66E-05	39.7%	0.50%	50.8%	9.0%	9.59E-04	39
241-AW-102	7.13E-04	1.74E-05	1.36E-04	1.45E-04	70.5%	1.72%	13.4%	14.4%	1.01E-03	41
Supernatant	4.84E-04	7.27E-07	1.34E-04	8.98E-05	68.4%	0.10%	18.9%	12.7%	7.08E-04	29
Solid Layer	2.29E-04	1.67E-05	2.05E-06	5.56E-05	75.5%	5.49%	0.7%	18.3%	3.04E-04	12
241-AW-103	4.74E-04	1.20E-05	1.73E-04	1.45E-04	58.9%	1.49%	21.5%	18.1%	8.05E-04	33
Supernatant	4.20E-04	2.01E-08	6.68E-05	6.48E-05	76.2%	0.00%	12.1%	11.7%	5.52E-04	23
Solid Layer	5.40E-05	1.20E-05	1.06E-04	8.06E-05	21.4%	4.75%	42.0%	31.9%	2.53E-04	10
241-AW-104	8.00E-04	1.87E-05	7.36E-04	1.45E-04	47.1%	1.10%	43.3%	8.5%	1.70E-03	69
Supernatant	6.95E-04	1.64E-07	5.82E-04	7.25E-05	51.5%	0.01%	43.1%	5.4%	1.35E-03	55
Solid Layer	1.05E-04	1.85E-05	1.54E-04	7.22E-05	30.1%	5.30%	44.0%	20.7%	3.49E-04	14
241-AW-105	3.62E-04	1.05E-04	1.77E-06	2.18E-04	52.7%	15.27%	0.3%	31.7%	6.86E-04	28
Supernatant	2.38E-05	2.01E-08	7.99E-07	3.54E-05	39.6%	0.03%	1.3%	59.0%	6.01E-05	2
Solid Layer	3.38E-04	1.05E-04	9.71E-07	1.82E-04	54.0%	16.74%	0.2%	29.1%	6.26E-04	26
241-AW-106	7.46E-04	3.53E-06	3.05E-04	1.48E-04	62.0%	0.29%	25.4%	12.3%	1.20E-03	49
Supernatant	4.40E-04	1.71E-07	1.86E-04	7.20E-05	63.0%	0.02%	26.6%	10.3%	6.98E-04	28
Solid Layer	3.06E-04	3.36E-06	1.19E-04	7.61E-05	60.6%	0.67%	23.6%	15.1%	5.05E-04	21
241-AY-101	4.32E-03	6.53E-04	5.13E-05	2.18E-04	82.4%	12.47%	1.0%	4.2%	5.24E-03	214
Supernatant	1.30E-04	1.16E-06	3.18E-05	6.23E-05	57.6%	0.52%	14.2%	27.7%	2.25E-04	9
Solid Layer	4.19E-03	6.52E-04	1.95E-05	1.55E-04	83.5%	13.00%	0.4%	3.1%	5.02E-03	205
241-AY-102	2.29E-02	6.33E-04	9.74E-04	2.49E-04	92.5%	2.56%	3.9%	1.0%	2.48E-02	1009
Supernatant	5.27E-04	5.21E-08	8.73E-04	7.63E-05	35.7%	0.00%	59.1%	5.2%	1.48E-03	60
Solid Layer	2.24E-02	6.33E-04	1.01E-04	1.73E-04	96.1%	2.72%	0.4%	0.7%	2.33E-02	949
241-AZ-101	1.37E-02	6.45E-04	6.71E-04	1.34E-04	90.4%	4.26%	4.4%	0.9%	1.52E-02	618
Supernatant	7.11E-03	3.08E-07	4.02E-04	7.24E-05	93.7%	0.00%	5.3%	1.0%	7.59E-03	309
Solid Layer	6.59E-03	6.45E-04	2.69E-04	6.15E-05	87.1%	8.53%	3.6%	0.8%	7.56E-03	308
241-AZ-102	2.88E-02	2.14E-03	1.57E-03	1.52E-04	88.2%	6.54%	4.8%	0.5%	3.27E-02	1332
Supernatant	1.11E-02	3.46E-06	4.22E-04	8.18E-05	95.6%	0.03%	3.6%	0.7%	1.17E-02	475
Solid Layer	1.77E-02	2.13E-03	1.15E-03	6.98E-05	84.0%	10.16%	5.5%	0.3%	2.10E-02	857
241-SY-101	4.95E-04	1.58E-05	3.45E-05	1.44E-04	71.8%	2.29%	5.0%	20.9%	6.89E-04	28
Supernatant	1.77E-04	1.24E-06	2.42E-05	7.08E-05	64.7%	0.45%	8.9%	26.0%	2.73E-04	11
Solid Layer	3.18E-04	1.45E-05	1.03E-05	7.36E-05	76.4%	3.49%	2.5%	17.7%	4.17E-04	17

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-SY-102	3.76E-04	5.33E-04	6.09E-05	9.25E-05	35.4%	50.15%	5.7%	8.7%	1.06E-03	43
Supernatant	6.31E-05	3.70E-09	1.54E-05	2.32E-05	62.0%	0.00%	15.1%	22.9%	1.02E-04	4
Solid Layer	3.13E-04	5.33E-04	4.55E-05	6.93E-05	32.6%	55.46%	4.7%	7.2%	9.60E-04	39
241-SY-103	1.00E-03	2.39E-05	1.41E-03	1.16E-04	39.3%	0.94%	55.2%	4.5%	2.55E-03	104
Supernatant	5.68E-04	3.09E-07	5.51E-04	3.38E-05	49.3%	0.03%	47.8%	2.9%	1.15E-03	47
Solid Layer	4.34E-04	2.36E-05	8.57E-04	8.18E-05	31.1%	1.69%	61.4%	5.9%	1.40E-03	57
241-A-101	2.01E-04	5.09E-06	6.21E-04	3.26E-04	17.4%	0.44%	53.9%	28.2%	1.15E-03	47
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.01E-04	5.09E-06	6.21E-04	3.26E-04	17.4%	0.44%	53.9%	28.2%	1.15E-03	47
241-A-102	9.85E-05	8.91E-06	2.55E-05	2.31E-04	27.1%	2.45%	7.0%	63.4%	3.64E-04	15
Supernatant	4.93E-06	1.18E-09	2.94E-06	1.11E-06	54.9%	0.01%	32.8%	12.3%	8.98E-06	0
Solid Layer	9.36E-05	8.91E-06	2.26E-05	2.30E-04	26.4%	2.51%	6.4%	64.7%	3.55E-04	14
241-A-103	3.02E-04	6.70E-06	7.65E-04	3.45E-04	21.3%	0.47%	53.9%	24.3%	1.42E-03	58
Supernatant	3.73E-06	8.11E-09	1.21E-05	1.55E-06	21.4%	0.05%	69.7%	8.9%	1.74E-05	1
Solid Layer	2.98E-04	6.69E-06	7.53E-04	3.44E-04	21.3%	0.48%	53.7%	24.5%	1.40E-03	57
241-A-104	0.00E+00	0.00E+00	0.00E+00	2.29E-04	0.0%	0.00%	0.0%	100.0%	2.29E-04	9
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	0.00E+00	0.00E+00	0.00E+00	2.29E-04	0.0%	0.00%	0.0%	100.0%	2.29E-04	9
241-A-105	na	na	na	na	na	na	na	na	na	na
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	na	na	na	na	na	na	na	na	na	na
241-A-106	9.87E-04	3.84E-05	4.91E-04	2.51E-04	55.9%	2.17%	27.8%	14.2%	1.77E-03	72
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	9.87E-04	3.84E-05	4.91E-04	2.51E-04	55.9%	2.17%	27.8%	14.2%	1.77E-03	72
241-AX-101	3.13E-04	5.79E-06	3.53E-04	3.39E-04	31.0%	0.57%	34.9%	33.5%	1.01E-03	41
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.13E-04	5.79E-06	3.53E-04	3.39E-04	31.0%	0.57%	34.9%	33.5%	1.01E-03	41
241-AX-102	2.44E-04	3.47E-05	3.27E-05	2.22E-04	45.7%	6.51%	6.1%	41.6%	5.33E-04	22
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.44E-04	3.47E-05	3.27E-05	2.22E-04	45.7%	6.51%	6.1%	41.6%	5.33E-04	22
241-AX-103	4.39E-04	1.46E-05	1.35E-04	2.54E-04	52.1%	1.73%	16.0%	30.1%	8.42E-04	34
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.39E-04	1.46E-05	1.35E-04	2.54E-04	52.1%	1.73%	16.0%	30.1%	8.42E-04	34
241-AX-104	5.39E-04	5.79E-06	3.11E-07	2.19E-04	70.6%	0.76%	0.0%	28.6%	7.64E-04	31
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.39E-04	5.79E-06	3.11E-07	2.19E-04	70.6%	0.76%	0.0%	28.6%	7.64E-04	31
241-B-101	1.15E-04	1.69E-05	4.50E-08	2.63E-04	29.2%	4.26%	0.0%	66.6%	3.95E-04	16
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.15E-04	1.69E-05	4.50E-08	2.63E-04	29.2%	4.26%	0.0%	66.6%	3.95E-04	16

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-B-102	4.62E-07	6.86E-08	4.97E-10	2.30E-04	0.2%	0.03%	0.0%	99.8%	2.30E-04	9
Supernatant	1.47E-07	2.03E-09	7.24E-11	1.35E-06	9.8%	0.14%	0.0%	90.1%	1.50E-06	0
Solid Layer	3.15E-07	6.66E-08	4.25E-10	2.28E-04	0.1%	0.03%	0.0%	99.8%	2.29E-04	9
241-B-103	9.02E-07	7.28E-07	8.30E-10	2.35E-04	0.4%	0.31%	0.0%	99.3%	2.37E-04	10
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	9.02E-07	7.28E-07	8.30E-10	2.35E-04	0.4%	0.31%	0.0%	99.3%	2.37E-04	10
241-B-104	1.03E-05	1.24E-06	7.71E-09	3.44E-04	2.9%	0.35%	0.0%	96.8%	3.56E-04	15
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.03E-05	1.24E-06	7.71E-09	3.44E-04	2.9%	0.35%	0.0%	96.8%	3.56E-04	15
241-B-105	2.83E-06	7.85E-07	4.68E-09	3.11E-04	0.9%	0.25%	0.0%	98.8%	3.15E-04	13
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.83E-06	7.85E-07	4.68E-09	3.11E-04	0.9%	0.25%	0.0%	98.8%	3.15E-04	13
241-B-106	3.91E-05	4.38E-07	4.27E-09	2.59E-04	13.1%	0.15%	0.0%	86.7%	2.98E-04	12
Supernatant	3.87E-08	5.38E-10	1.80E-11	3.58E-07	9.7%	0.14%	0.0%	90.1%	3.98E-07	0
Solid Layer	3.91E-05	4.38E-07	4.25E-09	2.58E-04	13.1%	0.15%	0.0%	86.7%	2.98E-04	12
241-B-107	6.22E-06	4.31E-07	8.79E-10	2.75E-04	2.2%	0.15%	0.0%	97.6%	2.81E-04	11
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.22E-06	4.31E-07	8.79E-10	2.75E-04	2.2%	0.15%	0.0%	97.6%	2.81E-04	11
241-B-108	2.18E-06	1.24E-08	2.30E-09	2.49E-04	0.9%	0.00%	0.0%	99.1%	2.51E-04	10
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.18E-06	1.24E-08	2.30E-09	2.49E-04	0.9%	0.00%	0.0%	99.1%	2.51E-04	10
241-B-109	8.32E-07	2.53E-07	2.43E-09	2.58E-04	0.3%	0.10%	0.0%	99.6%	2.59E-04	11
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	8.32E-07	2.53E-07	2.43E-09	2.58E-04	0.3%	0.10%	0.0%	99.6%	2.59E-04	11
241-B-110	1.74E-04	7.00E-06	4.79E-05	3.02E-04	32.7%	1.32%	9.0%	56.9%	5.30E-04	22
Supernatant	1.03E-07	2.07E-09	1.88E-07	3.60E-07	15.7%	0.32%	28.9%	55.1%	6.53E-07	0
Solid Layer	1.73E-04	7.00E-06	4.77E-05	3.01E-04	32.8%	1.32%	9.0%	56.9%	5.29E-04	22
241-B-111	5.29E-04	6.41E-06	6.55E-05	3.02E-04	58.6%	0.71%	7.3%	33.4%	9.03E-04	37
Supernatant	1.04E-07	2.08E-09	2.47E-07	3.61E-07	14.5%	0.29%	34.6%	50.6%	7.15E-07	0
Solid Layer	5.29E-04	6.40E-06	6.52E-05	3.01E-04	58.7%	0.71%	7.2%	33.4%	9.02E-04	37
241-B-112	5.76E-06	1.34E-08	4.37E-05	2.29E-04	2.1%	0.00%	15.7%	82.2%	2.79E-04	11
Supernatant	1.21E-06	2.46E-09	4.10E-06	9.86E-07	19.2%	0.04%	65.1%	15.7%	6.30E-06	0
Solid Layer	4.55E-06	1.09E-08	3.96E-05	2.28E-04	1.7%	0.00%	14.6%	83.8%	2.72E-04	11
241-B-201	4.73E-07	3.68E-06	1.09E-06	5.25E-05	0.8%	6.37%	1.9%	90.9%	5.77E-05	2
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.73E-07	3.68E-06	1.09E-06	5.25E-05	0.8%	6.37%	1.9%	90.9%	5.77E-05	2
241-B-202	8.09E-07	1.00E-06	1.24E-06	5.16E-05	1.5%	1.83%	2.3%	94.4%	5.47E-05	2
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	8.09E-07	1.00E-06	1.24E-06	5.16E-05	1.5%	1.83%	2.3%	94.4%	5.47E-05	2

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-B-203	4.78E-08	2.94E-06	0.00E+00	1.92E-04	0.0%	1.50%	0.0%	98.5%	1.95E-04	8
Supernatant	1.01E-12	4.74E-10	0.00E+00	1.62E-06	0.0%	0.03%	0.0%	100.0%	1.63E-06	0
Solid Layer	4.78E-08	2.94E-06	0.00E+00	1.91E-04	0.0%	1.52%	0.0%	98.5%	1.94E-04	8
241-B-204	1.81E-08	3.55E-06	0.00E+00	1.95E-04	0.0%	1.79%	0.0%	98.2%	1.99E-04	8
Supernatant	9.11E-13	1.69E-11	0.00E+00	2.50E-06	0.0%	0.00%	0.0%	100.0%	2.50E-06	0
Solid Layer	1.81E-08	3.55E-06	0.00E+00	1.93E-04	0.0%	1.81%	0.0%	98.2%	1.96E-04	8
241-BX-101	2.77E-05	1.55E-06	1.74E-06	2.34E-04	10.4%	0.58%	0.7%	88.3%	2.65E-04	11
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.77E-05	1.55E-06	1.74E-06	2.34E-04	10.4%	0.58%	0.7%	88.3%	2.65E-04	11
241-BX-102	1.08E-04	1.31E-07	2.55E-06	2.44E-04	30.5%	0.04%	0.7%	68.7%	3.55E-04	14
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.08E-04	1.31E-07	2.55E-06	2.44E-04	30.5%	0.04%	0.7%	68.7%	3.55E-04	14
241-BX-103	4.85E-04	4.52E-05	1.11E-05	2.44E-04	61.8%	5.77%	1.4%	31.1%	7.84E-04	32
Supernatant	1.86E-07	3.80E-08	2.50E-06	4.50E-06	2.6%	0.53%	34.6%	62.3%	7.22E-06	0
Solid Layer	4.84E-04	4.52E-05	8.55E-06	2.39E-04	62.3%	5.81%	1.1%	30.8%	7.77E-04	32
241-BX-104	9.45E-05	6.78E-06	9.65E-06	2.54E-04	25.9%	1.86%	2.6%	69.6%	3.65E-04	15
Supernatant	1.37E-06	1.49E-10	4.59E-07	9.95E-07	48.4%	0.01%	16.3%	35.3%	2.82E-06	0
Solid Layer	9.31E-05	6.78E-06	9.19E-06	2.53E-04	25.7%	1.87%	2.5%	69.8%	3.62E-04	15
241-BX-105	3.56E-05	4.70E-07	6.36E-06	2.43E-04	12.5%	0.16%	2.2%	85.1%	2.85E-04	12
Supernatant	2.61E-06	2.26E-08	9.70E-07	1.62E-06	50.0%	0.43%	18.6%	31.0%	5.22E-06	0
Solid Layer	3.30E-05	4.48E-07	5.39E-06	2.41E-04	11.8%	0.16%	1.9%	86.1%	2.80E-04	11
241-BX-106	6.78E-05	1.67E-06	3.03E-05	2.34E-04	20.3%	0.50%	9.1%	70.1%	3.34E-04	14
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.78E-05	1.67E-06	3.03E-05	2.34E-04	20.3%	0.50%	9.1%	70.1%	3.34E-04	14
241-BX-107	4.76E-05	3.37E-06	1.58E-05	3.32E-04	11.9%	0.84%	4.0%	83.2%	3.99E-04	16
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.76E-05	3.37E-06	1.58E-05	3.32E-04	11.9%	0.84%	4.0%	83.2%	3.99E-04	16
241-BX-108	1.29E-05	1.10E-07	5.30E-07	2.29E-04	5.3%	0.05%	0.2%	94.4%	2.42E-04	10
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.29E-05	1.10E-07	5.30E-07	2.29E-04	5.3%	0.05%	0.2%	94.4%	2.42E-04	10
241-BX-109	2.03E-04	4.88E-07	2.25E-05	2.85E-04	39.8%	0.10%	4.4%	55.7%	5.11E-04	21
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.03E-04	4.88E-07	2.25E-05	2.85E-04	39.8%	0.10%	4.4%	55.7%	5.11E-04	21
241-BX-110	3.96E-05	2.38E-07	6.24E-05	2.86E-04	10.2%	0.06%	16.1%	73.7%	3.88E-04	16
Supernatant	3.88E-07	5.74E-10	3.42E-07	4.42E-07	33.1%	0.05%	29.2%	37.7%	1.17E-06	0
Solid Layer	3.92E-05	2.38E-07	6.21E-05	2.86E-04	10.1%	0.06%	16.0%	73.8%	3.87E-04	16
241-BX-111	4.28E-06	3.54E-08	1.32E-06	2.78E-04	1.5%	0.01%	0.5%	98.0%	2.84E-04	12
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.28E-06	3.54E-08	1.32E-06	2.78E-04	1.5%	0.01%	0.5%	98.0%	2.84E-04	12

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-BX-112	5.28E-05	4.52E-06	0.00E+00	2.70E-04	16.1%	1.38%	0.0%	82.5%	3.28E-04	13
Supernatant	1.36E-08	3.19E-10	0.00E+00	4.44E-07	3.0%	0.07%	0.0%	97.0%	4.58E-07	0
Solid Layer	5.28E-05	4.52E-06	0.00E+00	2.70E-04	16.1%	1.38%	0.0%	82.5%	3.27E-04	13
241-BY-101	8.93E-05	2.83E-07	1.67E-04	3.45E-04	14.8%	0.05%	27.8%	57.4%	6.02E-04	25
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	8.93E-05	2.83E-07	1.67E-04	3.45E-04	14.8%	0.05%	27.8%	57.4%	6.02E-04	25
241-BY-102	2.07E-05	9.98E-07	9.63E-06	3.12E-04	6.0%	0.29%	2.8%	90.9%	3.44E-04	14
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.07E-05	9.98E-07	9.63E-06	3.12E-04	6.0%	0.29%	2.8%	90.9%	3.44E-04	14
241-BY-103	4.63E-05	4.20E-07	2.18E-05	3.57E-04	10.9%	0.10%	5.1%	83.9%	4.25E-04	17
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.63E-05	4.20E-07	2.18E-05	3.57E-04	10.9%	0.10%	5.1%	83.9%	4.25E-04	17
241-BY-104	1.19E-04	1.22E-06	2.00E-04	3.60E-04	17.5%	0.18%	29.4%	53.0%	6.79E-04	28
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.19E-04	1.22E-06	2.00E-04	3.60E-04	17.5%	0.18%	29.4%	53.0%	6.79E-04	28
241-BY-105	7.16E-05	1.37E-06	8.12E-05	3.81E-04	13.4%	0.26%	15.2%	71.2%	5.35E-04	22
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	7.16E-05	1.37E-06	8.12E-05	3.81E-04	13.4%	0.26%	15.2%	71.2%	5.35E-04	22
241-BY-106	2.05E-04	8.81E-07	2.20E-04	3.81E-04	25.4%	0.11%	27.2%	47.3%	8.07E-04	33
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.05E-04	8.81E-07	2.20E-04	3.81E-04	25.4%	0.11%	27.2%	47.3%	8.07E-04	33
241-BY-107	8.00E-05	4.39E-07	1.17E-04	3.16E-04	15.6%	0.09%	22.8%	61.6%	5.14E-04	21
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	8.00E-05	4.39E-07	1.17E-04	3.16E-04	15.6%	0.09%	22.8%	61.6%	5.14E-04	21
241-BY-108	5.62E-05	5.10E-07	1.42E-04	3.02E-04	11.2%	0.10%	28.3%	60.4%	5.01E-04	20
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.62E-05	5.10E-07	1.42E-04	3.02E-04	11.2%	0.10%	28.3%	60.4%	5.01E-04	20
241-BY-109	2.12E-05	7.06E-07	7.05E-06	3.10E-04	6.3%	0.21%	2.1%	91.5%	3.39E-04	14
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.12E-05	7.06E-07	7.05E-06	3.10E-04	6.3%	0.21%	2.1%	91.5%	3.39E-04	14
241-BY-110	1.28E-04	8.56E-07	8.67E-04	3.44E-04	9.5%	0.06%	64.7%	25.7%	1.34E-03	55
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.28E-04	8.56E-07	8.67E-04	3.44E-04	9.5%	0.06%	64.7%	25.7%	1.34E-03	55
241-BY-111	8.57E-06	4.13E-07	7.91E-06	3.58E-04	2.3%	0.11%	2.1%	95.5%	3.75E-04	15
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	8.57E-06	4.13E-07	7.91E-06	3.58E-04	2.3%	0.11%	2.1%	95.5%	3.75E-04	15
241-BY-112	9.96E-06	2.71E-07	1.54E-05	3.17E-04	2.9%	0.08%	4.5%	92.5%	3.43E-04	14
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	9.96E-06	2.71E-07	1.54E-05	3.17E-04	2.9%	0.08%	4.5%	92.5%	3.43E-04	14

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-C-101	4.45E-05	7.95E-06	1.10E-05	2.56E-04	13.9%	2.49%	3.4%	80.1%	3.19E-04	13
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.45E-05	7.95E-06	1.10E-05	2.56E-04	13.9%	2.49%	3.4%	80.1%	3.19E-04	13
241-C-102	3.97E-05	7.66E-05	2.73E-05	3.29E-04	8.4%	16.20%	5.8%	69.6%	4.73E-04	19
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.97E-05	7.66E-05	2.73E-05	3.29E-04	8.4%	16.20%	5.8%	69.6%	4.73E-04	19
241-C-103	1.51E-05	2.19E-07	3.28E-12	5.51E-04	2.7%	0.04%	0.0%	97.3%	5.67E-04	23
Supernatant	2.10E-09	3.44E-12	1.51E-12	2.11E-07	1.0%	0.00%	0.0%	99.0%	2.13E-07	0
Solid Layer	1.51E-05	2.19E-07	1.77E-12	5.51E-04	2.7%	0.04%	0.0%	97.3%	5.67E-04	23
241-C-104	7.75E-04	3.17E-04	1.64E-04	3.17E-04	49.3%	20.13%	10.4%	20.2%	1.57E-03	64
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	7.75E-04	3.17E-04	1.64E-04	3.17E-04	49.3%	20.13%	10.4%	20.2%	1.57E-03	64
241-C-105	4.40E-04	1.01E-04	7.05E-06	2.79E-04	53.2%	12.18%	0.9%	33.7%	8.27E-04	34
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.40E-04	1.01E-04	7.05E-06	2.79E-04	53.2%	12.18%	0.9%	33.7%	8.27E-04	34
241-C-106	4.25E-04	7.30E-06	7.50E-09	5.52E-04	43.2%	0.74%	0.0%	56.1%	9.84E-04	40
Supernatant	1.67E-09	5.96E-13	4.68E-10	7.30E-08	2.2%	0.00%	0.6%	97.1%	7.51E-08	0
Solid Layer	4.25E-04	7.30E-06	7.03E-09	5.52E-04	43.2%	0.74%	0.0%	56.1%	9.84E-04	40.1
241-C-107	2.19E-03	1.59E-04	1.12E-04	3.20E-04	78.8%	5.70%	4.0%	11.5%	2.78E-03	113
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.19E-03	1.59E-04	1.12E-04	3.20E-04	78.8%	5.70%	4.0%	11.5%	2.78E-03	113
241-C-108	2.77E-05	1.10E-07	1.88E-06	2.29E-04	10.7%	0.04%	0.7%	88.5%	2.58E-04	11
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.77E-05	1.10E-07	1.88E-06	2.29E-04	10.7%	0.04%	0.7%	88.5%	2.58E-04	11
241-C-109	4.39E-04	2.58E-06	4.98E-06	2.41E-04	63.8%	0.38%	0.7%	35.1%	6.88E-04	28
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.39E-04	2.58E-06	4.98E-06	2.41E-04	63.8%	0.38%	0.7%	35.1%	6.88E-04	28
241-C-110	2.45E-05	3.18E-06	4.23E-07	6.95E-04	3.4%	0.44%	0.1%	96.1%	7.23E-04	29
Supernatant	3.61E-08	3.59E-10	3.91E-09	8.97E-07	3.9%	0.04%	0.4%	95.7%	9.38E-07	0
Solid Layer	2.44E-05	3.18E-06	4.19E-07	6.94E-04	3.4%	0.44%	0.1%	96.1%	7.22E-04	29
241-C-111	1.00E-03	7.46E-06	3.36E-06	2.39E-04	80.1%	0.60%	0.3%	19.1%	1.25E-03	51
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.00E-03	7.46E-06	3.36E-06	2.39E-04	80.1%	0.60%	0.3%	19.1%	1.25E-03	51
241-C-112	1.07E-03	1.40E-05	1.40E-05	2.57E-04	79.0%	1.03%	1.0%	18.9%	1.36E-03	55
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.07E-03	1.40E-05	1.40E-05	2.57E-04	79.0%	1.03%	1.0%	18.9%	1.36E-03	55
241-C-201	1.00E-06	1.23E-06	0.00E+00	3.94E-05	2.4%	2.95%	0.0%	94.6%	4.17E-05	2
Supernatant	0.00E+00	0.00E+00	0.00E+00	5.84E-09	0.0%	0.00%	0.0%	100.0%	5.84E-09	0
Solid Layer	1.00E-06	1.23E-06	0.00E+00	3.94E-05	2.4%	2.95%	0.0%	94.6%	4.16E-05	2

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-C-202	1.91E-06	1.05E-06	0.00E+00	3.93E-05	4.5%	2.48%	0.0%	93.0%	4.23E-05	2
Supernatant	0.00E+00	0.00E+00	0.00E+00	7.48E-09	0.0%	0.00%	0.0%	100.0%	7.48E-09	0
Solid Layer	1.91E-06	1.05E-06	0.00E+00	3.93E-05	4.5%	2.48%	0.0%	93.0%	4.23E-05	2
241-C-203	6.54E-08	5.10E-08	0.00E+00	3.93E-05	0.2%	0.13%	0.0%	99.7%	3.94E-05	2
Supernatant	0.00E+00	0.00E+00	0.00E+00	3.99E-08	0.0%	0.00%	0.0%	100.0%	3.99E-08	0
Solid Layer	6.54E-08	5.10E-08	0.00E+00	3.93E-05	0.2%	0.13%	0.0%	99.7%	3.94E-05	2
241-C-204	9.34E-07	1.33E-09	0.00E+00	3.88E-05	2.3%	0.00%	0.0%	97.6%	3.98E-05	2
Supernatant	0.00E+00	0.00E+00	0.00E+00	9.04E-09	0.0%	0.00%	0.0%	100.0%	9.04E-09	0
Solid Layer	9.34E-07	1.33E-09	0.00E+00	3.88E-05	2.3%	0.00%	0.0%	97.6%	3.98E-05	2
241-S-101	4.26E-04	8.00E-06	1.94E-04	3.47E-04	43.7%	0.82%	19.9%	35.6%	9.76E-04	40
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.26E-04	8.00E-06	1.94E-04	3.47E-04	43.7%	0.82%	19.9%	35.6%	9.76E-04	40
241-S-102	3.30E-05	3.63E-07	1.20E-05	2.40E-04	11.6%	0.13%	4.2%	84.1%	2.86E-04	12
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.30E-05	3.63E-07	1.20E-05	2.40E-04	11.6%	0.13%	4.2%	84.1%	2.86E-04	12
241-S-103	1.16E-04	2.88E-06	6.22E-05	3.01E-04	24.1%	0.60%	12.9%	62.4%	4.82E-04	20
Supernatant	8.23E-07	8.24E-11	3.48E-07	3.62E-07	53.7%	0.01%	22.7%	23.6%	1.53E-06	0
Solid Layer	1.15E-04	2.88E-06	6.19E-05	3.01E-04	24.0%	0.60%	12.9%	62.5%	4.81E-04	20
241-S-104	2.43E-04	6.52E-06	2.46E-05	3.25E-04	40.5%	1.09%	4.1%	54.3%	5.98E-04	24
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.43E-04	6.52E-06	2.46E-05	3.25E-04	40.5%	1.09%	4.1%	54.3%	5.98E-04	24
241-S-105	2.70E-06	1.68E-08	8.16E-06	3.55E-04	0.7%	0.00%	2.2%	97.0%	3.66E-04	15
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.70E-06	1.68E-08	8.16E-06	3.55E-04	0.7%	0.00%	2.2%	97.0%	3.66E-04	15
241-S-106	9.92E-05	8.06E-07	4.24E-05	3.74E-04	19.2%	0.16%	8.2%	72.4%	5.16E-04	21
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	9.92E-05	8.06E-07	4.24E-05	3.74E-04	19.2%	0.16%	8.2%	72.4%	5.16E-04	21
241-S-107	2.81E-04	3.34E-05	3.98E-05	3.46E-04	40.1%	4.78%	5.7%	49.4%	6.99E-04	29
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.81E-04	3.34E-05	3.98E-05	3.46E-04	40.1%	4.78%	5.7%	49.4%	6.99E-04	29
241-S-108	7.19E-06	2.03E-07	7.59E-06	4.05E-04	1.7%	0.05%	1.8%	96.4%	4.20E-04	17
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	7.19E-06	2.03E-07	7.59E-06	4.05E-04	1.7%	0.05%	1.8%	96.4%	4.20E-04	17
241-S-109	1.16E-05	4.72E-07	1.24E-05	3.98E-04	2.7%	0.11%	2.9%	94.2%	4.23E-04	17
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.16E-05	4.72E-07	1.24E-05	3.98E-04	2.7%	0.11%	2.9%	94.2%	4.23E-04	17
241-S-110	8.12E-05	2.88E-06	1.28E-04	3.60E-04	14.2%	0.50%	22.4%	62.9%	5.72E-04	23
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	8.12E-05	2.88E-06	1.28E-04	3.60E-04	14.2%	0.50%	22.4%	62.9%	5.72E-04	23

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-S-111	2.33E-04	5.40E-07	3.57E-05	3.56E-04	37.3%	0.09%	5.7%	56.9%	6.26E-04	26
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.33E-04	5.40E-07	3.57E-05	3.56E-04	37.3%	0.09%	5.7%	56.9%	6.26E-04	26
241-S-112	1.05E-04	2.19E-06	0.00E+00	5.43E-04	16.1%	0.34%	0.0%	83.5%	6.50E-04	26
Supernatant	0.00E+00	0.00E+00	0.00E+00	1.05E-07	0.0%	0.00%	0.0%	100.0%	1.05E-07	0
Solid Layer	1.05E-04	2.19E-06	0.00E+00	5.43E-04	16.1%	0.34%	0.0%	83.5%	6.50E-04	26
241-SX-101	1.55E-04	1.71E-05	1.17E-04	3.77E-04	23.3%	2.56%	17.5%	56.6%	6.66E-04	27
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.55E-04	1.71E-05	1.17E-04	3.77E-04	23.3%	2.56%	17.5%	56.6%	6.66E-04	27
241-SX-102	3.10E-04	7.12E-06	7.71E-04	3.45E-04	21.7%	0.50%	53.8%	24.0%	1.43E-03	58
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.10E-04	7.12E-06	7.71E-04	3.45E-04	21.7%	0.50%	53.8%	24.0%	1.43E-03	58
241-SX-103	6.94E-04	1.43E-05	4.25E-03	3.97E-04	13.0%	0.27%	79.3%	7.4%	5.36E-03	218
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.94E-04	1.43E-05	4.25E-03	3.97E-04	13.0%	0.27%	79.3%	7.4%	5.36E-03	218
241-SX-104	3.47E-04	8.95E-06	8.71E-04	4.18E-04	21.1%	0.54%	53.0%	25.4%	1.65E-03	67
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.47E-04	8.95E-06	8.71E-04	4.18E-04	21.1%	0.54%	53.0%	25.4%	1.65E-03	67
241-SX-105	8.63E-04	2.46E-05	4.77E-03	3.62E-04	14.3%	0.41%	79.2%	6.0%	6.02E-03	246
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	8.63E-04	2.46E-05	4.77E-03	3.62E-04	14.3%	0.41%	79.2%	6.0%	6.02E-03	246
241-SX-106	1.91E-04	7.18E-06	1.80E-04	3.58E-04	25.9%	0.98%	24.5%	48.6%	7.36E-04	30
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.91E-04	7.18E-06	1.80E-04	3.58E-04	25.9%	0.98%	24.5%	48.6%	7.36E-04	30
241-SX-107	5.47E-04	8.05E-06	5.05E-04	2.76E-04	40.9%	0.60%	37.8%	20.7%	1.34E-03	54
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.47E-04	8.05E-06	5.05E-04	2.76E-04	40.9%	0.60%	37.8%	20.7%	1.34E-03	54
241-SX-108	1.51E-04	2.09E-06	7.91E-05	2.74E-04	29.8%	0.41%	15.6%	54.1%	5.06E-04	21
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.51E-04	2.09E-06	7.91E-05	2.74E-04	29.8%	0.41%	15.6%	54.1%	5.06E-04	21
241-SX-109	6.36E-04	5.42E-06	1.41E-03	3.27E-04	26.8%	0.23%	59.3%	13.8%	2.38E-03	97
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.36E-04	5.42E-06	1.41E-03	3.27E-04	26.8%	0.23%	59.3%	13.8%	2.38E-03	97
241-SX-110	1.83E-03	1.31E-05	3.20E-04	2.53E-04	75.7%	0.54%	13.3%	10.5%	2.41E-03	98
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.83E-03	1.31E-05	3.20E-04	2.53E-04	75.7%	0.54%	13.3%	10.5%	2.41E-03	98
241-SX-111	9.97E-04	1.16E-05	1.08E-03	2.91E-04	42.0%	0.49%	45.3%	12.2%	2.38E-03	97
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	9.97E-04	1.16E-05	1.08E-03	2.91E-04	42.0%	0.49%	45.3%	12.2%	2.38E-03	97

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-SX-112	5.27E-04	7.70E-06	1.78E-04	2.68E-04	53.7%	0.79%	18.1%	27.3%	9.81E-04	40
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.27E-04	7.70E-06	1.78E-04	2.68E-04	53.7%	0.79%	18.1%	27.3%	9.81E-04	40
241-SX-113	6.11E-06	4.26E-07	2.33E-06	2.29E-04	2.6%	0.18%	1.0%	96.3%	2.38E-04	10
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.11E-06	4.26E-07	2.33E-06	2.29E-04	2.6%	0.18%	1.0%	96.3%	2.38E-04	10
241-SX-114	9.28E-04	1.24E-05	1.15E-03	2.99E-04	38.8%	0.52%	48.1%	12.5%	2.39E-03	97
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	9.28E-04	1.24E-05	1.15E-03	2.99E-04	38.8%	0.52%	48.1%	12.5%	2.39E-03	97
241-SX-115	1.17E-04	5.24E-06	1.01E-07	2.22E-04	34.1%	1.52%	0.0%	64.4%	3.45E-04	14
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.17E-04	5.24E-06	1.01E-07	2.22E-04	34.1%	1.52%	0.0%	64.4%	3.45E-04	14
241-T-101	1.73E-05	4.56E-06	1.61E-05	2.51E-04	6.0%	1.58%	5.6%	86.8%	2.89E-04	12
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.73E-05	4.56E-06	1.61E-05	2.51E-04	6.0%	1.58%	5.6%	86.8%	2.89E-04	12
241-T-102	1.72E-05	3.28E-07	2.01E-07	5.63E-04	3.0%	0.06%	0.0%	96.9%	5.81E-04	24
Supernatant	3.63E-06	1.62E-08	1.07E-07	1.06E-05	25.2%	0.11%	0.7%	73.9%	1.44E-05	1
Solid Layer	1.36E-05	3.12E-07	9.37E-08	5.52E-04	2.4%	0.06%	0.0%	97.5%	5.66E-04	23
241-T-103	1.23E-06	1.11E-07	2.79E-06	2.25E-04	0.5%	0.05%	1.2%	98.2%	2.29E-04	9
Supernatant	3.78E-07	1.16E-08	5.28E-07	1.34E-06	16.8%	0.51%	23.4%	59.3%	2.25E-06	0
Solid Layer	8.52E-07	9.91E-08	2.26E-06	2.24E-04	0.4%	0.04%	1.0%	98.6%	2.27E-04	9
241-T-104	6.17E-06	7.82E-06	1.60E-05	3.25E-04	1.7%	2.20%	4.5%	91.6%	3.55E-04	14
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.17E-06	7.82E-06	1.60E-05	3.25E-04	1.7%	2.20%	4.5%	91.6%	3.55E-04	14
241-T-105	5.37E-05	7.00E-06	1.07E-06	2.46E-04	17.5%	2.28%	0.3%	79.9%	3.07E-04	13
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.37E-05	7.00E-06	1.07E-06	2.46E-04	17.5%	2.28%	0.3%	79.9%	3.07E-04	13
241-T-106	1.01E-06	2.17E-07	3.69E-07	2.24E-04	0.5%	0.10%	0.2%	99.3%	2.25E-04	9
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.01E-06	2.17E-07	3.69E-07	2.24E-04	0.5%	0.10%	0.2%	99.3%	2.25E-04	9
241-T-107	1.27E-04	7.79E-06	6.20E-06	2.76E-04	30.4%	1.87%	1.5%	66.3%	4.17E-04	17
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.27E-04	7.79E-06	6.20E-06	2.76E-04	30.4%	1.87%	1.5%	66.3%	4.17E-04	17
241-T-108	3.47E-07	5.99E-08	1.37E-10	2.23E-04	0.2%	0.03%	0.0%	99.8%	2.23E-04	9
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.47E-07	5.99E-08	1.37E-10	2.23E-04	0.2%	0.03%	0.0%	99.8%	2.23E-04	9
241-T-109	5.67E-07	5.22E-08	1.20E-09	2.37E-04	0.2%	0.02%	0.0%	99.7%	2.37E-04	10
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.67E-07	5.22E-08	1.20E-09	2.37E-04	0.2%	0.02%	0.0%	99.7%	2.37E-04	10

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-T-110	2.96E-07	1.02E-05	0.00E+00	8.53E-04	0.0%	1.18%	0.0%	98.8%	8.64E-04	35
Supernatant	3.90E-11	5.09E-11	0.00E+00	6.69E-07	0.0%	0.01%	0.0%	100.0%	6.69E-07	0
Solid Layer	2.96E-07	1.02E-05	0.00E+00	8.53E-04	0.0%	1.18%	0.0%	98.8%	8.63E-04	35
241-T-111	1.65E-05	1.27E-05	1.98E-05	3.69E-04	4.0%	3.05%	4.7%	88.3%	4.18E-04	17
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.65E-05	1.27E-05	1.98E-05	3.69E-04	4.0%	3.05%	4.7%	88.3%	4.18E-04	17
241-T-112	3.69E-07	4.53E-06	1.21E-07	2.39E-04	0.2%	1.86%	0.0%	97.9%	2.44E-04	10
Supernatant	3.64E-07	4.16E-08	1.25E-08	2.32E-06	13.3%	1.52%	0.5%	84.7%	2.74E-06	0
Solid Layer	4.69E-09	4.49E-06	1.08E-07	2.36E-04	0.0%	1.86%	0.0%	98.1%	2.41E-04	10
241-T-201	3.48E-08	4.79E-06	0.00E+00	1.35E-04	0.0%	3.42%	0.0%	96.6%	1.40E-04	6
Supernatant	2.20E-12	1.37E-11	0.00E+00	6.68E-06	0.0%	0.00%	0.0%	100.0%	6.68E-06	0
Solid Layer	3.48E-08	4.79E-06	0.00E+00	1.28E-04	0.0%	3.60%	0.0%	96.4%	1.33E-04	5
241-T-202	1.42E-09	7.66E-07	9.48E-07	4.13E-05	0.0%	1.78%	2.2%	96.0%	4.31E-05	2
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.42E-09	7.66E-07	9.48E-07	4.13E-05	0.0%	1.78%	2.2%	96.0%	4.31E-05	2
241-T-203	2.25E-09	1.62E-06	1.35E-06	6.10E-05	0.0%	2.54%	2.1%	95.3%	6.40E-05	3
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.25E-09	1.62E-06	1.35E-06	6.10E-05	0.0%	2.54%	2.1%	95.3%	6.40E-05	3
241-T-204	3.14E-09	1.43E-06	1.52E-06	6.11E-05	0.0%	2.24%	2.4%	95.4%	6.40E-05	3
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.14E-09	1.43E-06	1.52E-06	6.11E-05	0.0%	2.24%	2.4%	95.4%	6.40E-05	3
241-TX-101	9.08E-05	6.29E-06	1.79E-05	2.50E-04	24.9%	1.73%	4.9%	68.5%	3.64E-04	15
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	9.08E-05	6.29E-06	1.79E-05	2.50E-04	24.9%	1.73%	4.9%	68.5%	3.64E-04	15
241-TX-102	1.48E-05	1.24E-06	1.96E-05	2.94E-04	4.5%	0.38%	5.9%	89.2%	3.30E-04	13
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.48E-05	1.24E-06	1.96E-05	2.94E-04	4.5%	0.38%	5.9%	89.2%	3.30E-04	13
241-TX-103	1.37E-05	1.17E-06	1.05E-05	2.66E-04	4.7%	0.40%	3.6%	91.3%	2.92E-04	12
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.37E-05	1.17E-06	1.05E-05	2.66E-04	4.7%	0.40%	3.6%	91.3%	2.92E-04	12
241-TX-104	5.99E-05	1.25E-06	1.64E-06	2.40E-04	19.8%	0.41%	0.5%	79.3%	3.03E-04	12
Supernatant	1.53E-06	1.38E-09	5.34E-08	8.04E-07	64.1%	0.06%	2.2%	33.7%	2.39E-06	0
Solid Layer	5.84E-05	1.25E-06	1.59E-06	2.39E-04	19.4%	0.42%	0.5%	79.6%	3.00E-04	12
241-TX-105	1.10E-05	1.15E-06	3.73E-05	4.15E-04	2.4%	0.25%	8.0%	89.4%	4.65E-04	19
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.10E-05	1.15E-06	3.73E-05	4.15E-04	2.4%	0.25%	8.0%	89.4%	4.65E-04	19
241-TX-106	3.07E-05	2.72E-06	3.57E-05	3.39E-04	7.5%	0.67%	8.8%	83.1%	4.08E-04	17
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	3.07E-05	2.72E-06	3.57E-05	3.39E-04	7.5%	0.67%	8.8%	83.1%	4.08E-04	17

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-TX-107	6.13E-06	5.21E-06	3.54E-06	2.22E-04	2.6%	2.20%	1.5%	93.7%	2.37E-04	10
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.13E-06	5.21E-06	3.54E-06	2.22E-04	2.6%	2.20%	1.5%	93.7%	2.37E-04	10
241-TX-108	5.76E-06	5.58E-07	4.30E-06	2.60E-04	2.1%	0.21%	1.6%	96.1%	2.70E-04	11
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.76E-06	5.58E-07	4.30E-06	2.60E-04	2.1%	0.21%	1.6%	96.1%	2.70E-04	11
241-TX-109	5.02E-05	5.46E-06	1.17E-04	3.60E-04	9.4%	1.02%	22.0%	67.6%	5.33E-04	22
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.02E-05	5.46E-06	1.17E-04	3.60E-04	9.4%	1.02%	22.0%	67.6%	5.33E-04	22
241-TX-110	1.02E-05	1.24E-06	2.04E-05	3.76E-04	2.5%	0.30%	5.0%	92.2%	4.08E-04	17
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.02E-05	1.24E-06	2.04E-05	3.76E-04	2.5%	0.30%	5.0%	92.2%	4.08E-04	17
241-TX-111	8.79E-06	1.10E-06	1.70E-05	3.42E-04	2.4%	0.30%	4.6%	92.7%	3.69E-04	15
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	8.79E-06	1.10E-06	1.70E-05	3.42E-04	2.4%	0.30%	4.6%	92.7%	3.69E-04	15
241-TX-112	2.11E-05	2.41E-06	1.68E-05	4.27E-04	4.5%	0.52%	3.6%	91.4%	4.68E-04	19
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	2.11E-05	2.41E-06	1.68E-05	4.27E-04	4.5%	0.52%	3.6%	91.4%	4.68E-04	19
241-TX-113	1.16E-06	7.99E-08	7.81E-06	4.35E-04	0.3%	0.02%	1.8%	98.0%	4.44E-04	18
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.16E-06	7.99E-08	7.81E-06	4.35E-04	0.3%	0.02%	1.8%	98.0%	4.44E-04	18
241-TX-114	1.01E-05	1.05E-06	2.31E-06	3.93E-04	2.5%	0.26%	0.6%	96.7%	4.06E-04	17
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.01E-05	1.05E-06	2.31E-06	3.93E-04	2.5%	0.26%	0.6%	96.7%	4.06E-04	17
241-TX-115	1.16E-05	1.32E-06	1.05E-05	4.05E-04	2.7%	0.31%	2.5%	94.5%	4.28E-04	17
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.16E-05	1.32E-06	1.05E-05	4.05E-04	2.7%	0.31%	2.5%	94.5%	4.28E-04	17
241-TX-116	5.62E-06	4.55E-07	3.13E-08	4.17E-04	1.3%	0.11%	0.0%	98.6%	4.23E-04	17
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.62E-06	4.55E-07	3.13E-08	4.17E-04	1.3%	0.11%	0.0%	98.6%	4.23E-04	17
241-TX-117	4.60E-06	4.73E-07	7.86E-10	3.77E-04	1.2%	0.12%	0.0%	98.7%	3.82E-04	16
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	4.60E-06	4.73E-07	7.86E-10	3.77E-04	1.2%	0.12%	0.0%	98.7%	3.82E-04	16
241-TX-118	6.54E-05	6.10E-05	2.61E-05	3.03E-04	14.3%	13.38%	5.7%	66.5%	4.56E-04	19
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.54E-05	6.10E-05	2.61E-05	3.03E-04	14.3%	13.38%	5.7%	66.5%	4.56E-04	19
241-TY-101	1.15E-06	3.67E-07	4.24E-10	2.56E-04	0.4%	0.14%	0.0%	99.4%	2.57E-04	10
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.15E-06	3.67E-07	4.24E-10	2.56E-04	0.4%	0.14%	0.0%	99.4%	2.57E-04	10

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-TY-102	5.44E-06	1.87E-08	2.12E-06	2.39E-04	2.2%	0.01%	0.9%	96.9%	2.46E-04	10
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.44E-06	1.87E-08	2.12E-06	2.39E-04	2.2%	0.01%	0.9%	96.9%	2.46E-04	10
241-TY-103	6.22E-05	3.15E-06	4.26E-05	2.65E-04	16.7%	0.84%	11.4%	71.1%	3.73E-04	15
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	6.22E-05	3.15E-06	4.26E-05	2.65E-04	16.7%	0.84%	11.4%	71.1%	3.73E-04	15
241-TY-104	3.90E-05	1.66E-06	4.13E-07	2.30E-04	14.4%	0.61%	0.2%	84.9%	2.71E-04	11
Supernatant	7.90E-08	3.66E-10	1.38E-08	4.44E-07	14.7%	0.07%	2.6%	82.6%	5.37E-07	0
Solid Layer	3.89E-05	1.66E-06	3.99E-07	2.29E-04	14.4%	0.61%	0.1%	84.9%	2.70E-04	11
241-TY-105	1.80E-04	6.26E-07	1.31E-05	2.97E-04	36.7%	0.13%	2.7%	60.5%	4.91E-04	20
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.80E-04	6.26E-07	1.31E-05	2.97E-04	36.7%	0.13%	2.7%	60.5%	4.91E-04	20
241-TY-106	1.56E-05	6.37E-08	3.55E-07	2.21E-04	6.6%	0.03%	0.1%	93.3%	2.37E-04	10
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.56E-05	6.37E-08	3.55E-07	2.21E-04	6.6%	0.03%	0.1%	93.3%	2.37E-04	10
241-U-101	5.53E-05	1.61E-07	9.66E-07	2.25E-04	19.7%	0.06%	0.3%	79.9%	2.81E-04	11
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.53E-05	1.61E-07	9.66E-07	2.25E-04	19.7%	0.06%	0.3%	79.9%	2.81E-04	11
241-U-102	3.00E-04	6.68E-06	2.37E-04	3.34E-04	34.1%	0.76%	27.0%	38.1%	8.78E-04	36
Supernatant	1.45E-06	8.85E-10	1.07E-06	3.65E-07	50.2%	0.03%	37.1%	12.7%	2.88E-06	0
Solid Layer	2.98E-04	6.68E-06	2.36E-04	3.34E-04	34.1%	0.76%	27.0%	38.2%	8.75E-04	36
241-U-103	2.13E-04	5.60E-06	5.11E-04	3.60E-04	19.5%	0.51%	46.9%	33.0%	1.09E-03	44
Supernatant	7.19E-07	8.27E-10	7.72E-07	1.80E-07	43.0%	0.05%	46.2%	10.7%	1.67E-06	0
Solid Layer	2.12E-04	5.60E-06	5.10E-04	3.59E-04	19.5%	0.51%	46.9%	33.0%	1.09E-03	44
241-U-104	9.05E-07	3.45E-08	5.68E-05	2.38E-04	0.3%	0.01%	19.2%	80.5%	2.95E-04	12
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	9.05E-07	3.45E-08	5.68E-05	2.38E-04	0.3%	0.01%	19.2%	80.5%	2.95E-04	12
241-U-105	1.65E-04	1.78E-05	3.70E-04	3.39E-04	18.5%	2.00%	41.5%	38.0%	8.91E-04	36
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.65E-04	1.78E-05	3.70E-04	3.39E-04	18.5%	2.00%	41.5%	38.0%	8.91E-04	36
241-U-106	2.31E-04	1.37E-05	3.55E-04	2.75E-04	26.4%	1.57%	40.6%	31.5%	8.75E-04	36
Supernatant	2.33E-06	3.08E-08	2.51E-06	5.39E-07	43.1%	0.57%	46.4%	10.0%	5.41E-06	0
Solid Layer	2.29E-04	1.37E-05	3.53E-04	2.75E-04	26.3%	1.58%	40.5%	31.6%	8.70E-04	35
241-U-107	7.23E-05	1.09E-05	8.49E-05	3.18E-04	14.9%	2.25%	17.4%	65.4%	4.87E-04	20
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	7.23E-05	1.09E-05	8.49E-05	3.18E-04	14.9%	2.25%	17.4%	65.4%	4.87E-04	20
241-U-108	1.94E-04	4.34E-06	3.24E-04	3.72E-04	21.7%	0.49%	36.2%	41.6%	8.95E-04	36
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.94E-04	4.34E-06	3.24E-04	3.72E-04	21.7%	0.49%	36.2%	41.6%	8.95E-04	36

Table B-4. Calculated Total Hydrogen Generation Rate In Dome Space for 177 Tanks. (14 sheets)

Tank	HGR from radiolysis $G_{rad}^{b/r}$ (cfm)	HGR from radiolysis G_{rad}^{alpha} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad}^{b/r}$)%	Percent of HGR from radiolysis (G_{rad}^{alpha})%	Percent of HGR from thermolysis (G_{therm})%	Percent of HGR from corrosion (G_{corr})%	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
241-U-109	1.06E-04	8.92E-07	1.78E-04	3.59E-04	16.5%	0.14%	27.6%	55.7%	6.44E-04	26
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.06E-04	8.92E-07	1.78E-04	3.59E-04	16.5%	0.14%	27.6%	55.7%	6.44E-04	26
241-U-110	1.84E-04	5.20E-06	1.11E-05	2.79E-04	38.4%	1.09%	2.3%	58.2%	4.79E-04	20
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	1.84E-04	5.20E-06	1.11E-05	2.79E-04	38.4%	1.09%	2.3%	58.2%	4.79E-04	20
241-U-111	9.36E-05	4.17E-06	5.88E-05	2.95E-04	20.7%	0.92%	13.0%	65.3%	4.52E-04	18
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	9.36E-05	4.17E-06	5.88E-05	2.95E-04	20.7%	0.92%	13.0%	65.3%	4.52E-04	18
241-U-112	5.33E-05	1.20E-07	1.92E-06	2.32E-04	18.5%	0.04%	0.7%	80.8%	2.88E-04	12
Supernatant	na	na	na	na	na	na	na	na	na	na
Solid Layer	5.33E-05	1.20E-07	1.92E-06	2.32E-04	18.5%	0.04%	0.7%	80.8%	2.88E-04	12
241-U-201	1.36E-07	7.55E-10	0.00E+00	2.04E-05	0.7%	0.00%	0.0%	99.3%	2.05E-05	1
Supernatant	1.04E-07	8.48E-11	0.00E+00	1.32E-06	7.3%	0.01%	0.0%	92.7%	1.42E-06	0
Solid Layer	3.28E-08	6.71E-10	0.00E+00	1.91E-05	0.2%	0.00%	0.0%	99.8%	1.91E-05	1
241-U-202	9.61E-08	7.38E-10	1.55E-09	2.02E-05	0.5%	0.00%	0.0%	99.5%	2.03E-05	1
Supernatant	7.24E-08	1.60E-12	6.75E-10	1.33E-06	5.2%	0.00%	0.0%	94.8%	1.40E-06	0
Solid Layer	2.37E-08	7.36E-10	8.78E-10	1.89E-05	0.1%	0.00%	0.0%	99.9%	1.89E-05	1
241-U-203	1.13E-07	7.24E-10	0.00E+00	1.99E-05	0.6%	0.00%	0.0%	99.4%	2.00E-05	1
Supernatant	7.71E-08	3.91E-12	0.00E+00	1.33E-06	5.5%	0.00%	0.0%	94.5%	1.41E-06	0
Solid Layer	3.58E-08	7.20E-10	0.00E+00	1.85E-05	0.2%	0.00%	0.0%	99.8%	1.86E-05	1
241-U-204	1.42E-07	1.62E-08	2.22E-10	4.80E-05	0.3%	0.03%	0.0%	99.7%	4.81E-05	2
Supernatant	6.49E-08	3.10E-12	1.31E-10	3.32E-06	1.9%	0.00%	0.0%	98.1%	3.39E-06	0
Solid Layer	7.66E-08	1.62E-08	9.12E-11	4.46E-05	0.2%	0.04%	0.0%	99.8%	4.47E-05	2
AY102-S-14U	1.68E-03	9.66E-05	3.52E-06	1.42E-04	87.4%	5.02%	0.2%	7.4%	1.92E-03	78
AY102-S-14L	1.89E-03	8.44E-05	4.68E-06	1.40E-04	89.2%	3.98%	0.2%	6.6%	2.12E-03	86
AY102-S-15U	3.74E-04	3.15E-05	1.77E-06	1.37E-04	68.8%	5.78%	0.3%	25.1%	5.44E-04	22
AY102-S-15L	2.95E-03	1.39E-04	1.76E-05	1.42E-04	90.8%	4.26%	0.5%	4.4%	3.25E-03	133
AY-102-S-16	4.71E-03	1.11E-04	1.66E-05	1.41E-04	94.6%	2.24%	0.3%	2.8%	4.97E-03	203
AY102-Orig-9"	8.67E-03	1.01E-04	1.54E-05	1.40E-04	97.1%	1.13%	0.2%	1.6%	8.93E-03	364

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (μg/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-AN-101	3.29E+04	5.29E+03	1.10E+05	1.61E+05	2.08E+05	1.93E+04	2.02E+00	2.63E-03	9.21E-05	4.35E-04	1.65E-05	1.92E+02	1.40	1.40	4364	52%	52%	30	28
Supernatant	3.25E+04	5.32E+03	1.10E+05	1.60E+05	2.08E+05	1.89E+04	1.33E+00	1.62E-03	2.36E-05	1.41E-04	4.40E-06	1.92E+02	1.40	1.40	4246	52%	52%	30	28
Solid Layer	4.82E+04	4.04E+03	1.22E+05	1.90E+05	2.36E+05	3.79E+04	2.46E+01	3.55E-02	2.31E-03	9.97E-03	4.10E-04	1.84E+02	1.55	1.45	118	40%	49%	27	28
241-AN-102	8.19E+03	2.39E+04	8.62E+04	1.95E+05	2.10E+05	1.31E+04	6.86E+01	1.89E-01	2.36E-03	9.08E-03	6.60E-04	2.76E+02	1.42	1.41	4068	48%	49%	36	35
Supernatant	8.09E+03	2.39E+04	8.61E+04	1.95E+05	2.10E+05	1.31E+04	5.62E+01	1.15E-01	8.74E-04	3.37E-03	2.45E-04	2.78E+02	1.41	1.41	3484	49%	49%	36	35
Solid Layer	8.85E+03	2.41E+04	8.71E+04	1.97E+05	2.12E+05	1.32E+04	1.37E+02	5.99E-01	1.05E-02	4.04E-02	2.93E-03	2.64E+02	1.53	1.41	584	40%	49%	35	35
241-AN-103	6.64E+04	3.01E+03	1.28E+05	1.27E+05	2.67E+05	2.96E+04	1.15E+00	3.78E-03	2.06E-04	7.93E-04	5.75E-05	3.10E+02	1.59	1.47	3445	41%	47%	41	34
Supernatant	6.59E+04	2.98E+03	1.27E+05	1.26E+05	2.65E+05	2.93E+04	1.18E-02	4.07E-03	4.41E-05	1.70E-04	1.23E-05	4.22E+02	1.47	1.47	1807	47%	47%	41	34
Solid Layer	6.72E+04	3.05E+03	1.30E+05	1.28E+05	2.70E+05	3.00E+04	2.22E+00	3.51E-03	3.58E-04	1.38E-03	1.00E-04	2.06E+02	1.72	1.48	1638	35%	47%	41	34
241-AN-104	6.46E+04	3.11E+03	1.18E+05	1.87E+05	2.56E+05	3.86E+04	1.25E+01	8.34E-03	3.30E-04	1.27E-03	9.19E-05	3.27E+02	1.47	1.40	3902	49%	51%	40	32
Supernatant	6.42E+04	3.09E+03	1.17E+05	1.86E+05	2.54E+05	3.84E+04	5.78E-02	2.48E-04	1.33E-05	5.10E-05	3.69E-06	3.47E+02	1.39	1.39	2336	52%	52%	38	32
Solid Layer	6.53E+04	3.14E+03	1.19E+05	1.89E+05	2.58E+05	3.90E+04	2.88E+01	1.89E-02	7.43E-04	2.86E-03	2.07E-04	3.00E+02	1.59	1.40	1566	46%	51%	41	32
241-AN-105	5.92E+04	2.74E+03	1.17E+05	1.55E+05	2.45E+05	4.13E+04	4.62E+00	8.50E-03	2.83E-04	1.08E-03	7.86E-05	2.26E+02	1.49	1.42	4190	48%	50%	35	28
Supernatant	5.87E+04	2.72E+03	1.17E+05	1.54E+05	2.43E+05	4.10E+04	2.42E-02	1.00E-02	1.09E-04	4.19E-04	3.04E-05	2.04E+02	1.41	1.41	2265	50%	50%	34	28
Solid Layer	5.97E+04	2.76E+03	1.19E+05	1.56E+05	2.47E+05	4.17E+04	9.50E+00	6.92E-03	4.67E-04	1.79E-03	1.30E-04	2.50E+02	1.57	1.42	1925	44%	50%	36	28
241-AN-106	6.59E+03	8.75E+02	2.75E+04	1.83E+03	5.18E+04	1.21E+03	6.03E+02	7.25E-01	8.30E-02	3.86E-01	1.26E-02	5.01E+01	1.21	1.11	2713	71%	84%	44	40
Supernatant	6.56E+03	8.72E+02	2.74E+04	1.83E+03	5.16E+04	1.20E+03	8.91E-01	1.65E-04	2.88E-04	1.37E-03	2.00E-04	1.80E+01	1.11	1.11	1996	84%	84%	45	40
Solid Layer	6.68E+03	8.90E+02	2.79E+04	1.86E+03	5.26E+04	1.22E+03	1.85E+03	2.23E+00	2.55E-01	1.19E+00	3.84E-02	1.17E+02	1.48	1.11	717	45%	84%	41	40
241-AN-107	1.78E+04	3.22E+04	6.61E+04	2.07E+05	2.06E+05	1.11E+03	7.73E+01	5.97E-01	9.45E-03	3.64E-02	2.64E-03	2.13E+02	1.44	1.43	4207	50%	52%	36	33
Supernatant	1.78E+04	3.21E+04	6.60E+04	2.07E+05	2.05E+05	1.11E+03	5.32E+01	5.07E-01	8.14E-03	3.14E-02	2.27E-03	2.07E+02	1.43	1.43	3335	52%	52%	36	33
Solid Layer	1.80E+04	3.25E+04	6.67E+04	2.09E+05	2.08E+05	1.12E+03	1.66E+02	9.30E-01	1.43E-02	5.49E-02	3.98E-03	2.33E+02	1.48	1.43	872	44%	52%	37	33
241-AP-101	2.18E+04	1.04E+03	2.10E+04	1.35E+05	1.05E+05	4.85E+03	5.81E-04	5.81E-04	5.81E-04	5.81E-04	1.84E-05	5.43E+01	1.22	1.22	4412	69%	69%	25	27
Supernatant	2.18E+04	1.04E+03	2.10E+04	1.35E+05	1.05E+05	4.85E+03	7.76E-01	1.05E-03	1.14E-04	5.81E-04	1.84E-05	5.43E+01	1.22	1.22	4412	69%	69%	25	27
Solid Layer	0.00E+00	0.0	0.0	0.0	0.0	0.0	0.0	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.0	0.00	0.00	0	0%	0%	5	5
241-AP-102	3.18E+04	2.99E+03	9.74E+04	1.66E+05	1.93E+05	3.06E+04	2.78E-01	1.22E-03	3.84E-05	2.27E-04	5.88E-06	1.68E+02	1.39	1.39	4175	58%	59%	27	36
Supernatant	3.18E+04	2.99E+03	9.74E+04	1.66E+05	1.93E+05	3.06E+04	2.75E-01	1.24E-03	3.72E-05	2.21E-04	5.72E-06	1.71E+02	1.39	1.39	4087	59%	59%	27	36
Solid Layer	3.21E+04	3013.1	98295.9	167448.8	194862.9	30871.8	0.4	6.95E-04	7.92E-05	4.68E-04	1.20E-05	81.2	1.75	1.39	88	31%	59%	29	36
241-AP-103	2.06E+04	6.51E+03	8.13E+04	1.59E+05	1.84E+05	1.96E+04	1.58E+00	6.21E-03	9.25E-05	5.51E-04	1.94E-05	1.64E+02	1.37	1.36	2914	55%	56%	32	27
Supernatant	2.07E+04	6.51E+03	8.12E+04	1.59E+05	1.84E+05	1.96E+04	1.62E+00	6.39E-03	9.04E-05	5.38E-04	1.90E-05	1.66E+02	1.37	1.37	2844	56%	56%	32	27
Solid Layer	1.67E+04	6593.0	82323.6	160727.0	186742.7	19886.0	0.2	2.49E-04	1.62E-04	9.61E-04	3.16E-05	111.4	1.68	1.35	70	41%	55%	29	27
241-AP-104	1.95E+04	4.13E+03	6.34E+04	9.99E+04	1.27E+05	1.66E+04	1.37E-04	1.37E-04	1.37E-04	1.37E-04	3.08E-05	1.44E+02	1.28	1.28	4193	67%	67%	27	27
Supernatant	1.95E+04	4.13E+03	6.34E+04	9.99E+04	1.27E+05	1.66E+04	1.30E+00	2.18E-03	2.33E-05	1.37E-04	3.08E-05	1.44E+02	1.28	1.28	4193	67%	67%	27	27
Solid Layer	0.00E+00	0.0	0.0	0.0	0.0	0.0	0.0	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.0	0.00	0.00	0	0%	0%	5	5
241-AP-105	2.57E+04	1.48E+03	4.70E+04	1.05E+05	1.33E+05	1.91E+04	1.92E+00	9.94E-04	1.19E-04	5.31E-04	3.54E-05	1.18E+02	1.29	1.27	4340	69%	72%	24	25
Supernatant	2.57E+04	1.48E+03	4.70E+04	1.05E+05	1.33E+05	1.91E+04	2.13E-01	5.42E-04	3.63E-05	2.21E-04	1.26E-05	1.06E+02	1.27	1.27	4003	72%	72%	24	25
Solid Layer	2.59E+04	1.50E+03	4.74E+04	1.06E+05	1.34E+05	1.92E+04	1.79E+01	5.22E-03	8.90E-04	3.43E-03	2.49E-04	2.25E+02	1.61	1.27	337	48%	71%	24	25
241-AP-106	7.31E+03	3.43E+03	4.10E+04	7.01E+04	1.03E+05	1.34E+04	6.07E-05	6.07E-05	6.07E-05	6.07E-05	1.70E-06	1.44E+02	1.21	1.21	4339	73%	73%	24	24
Supernatant	7.31E+03	3.43E+03	4.10E+04	7.01E+04	1.03E+05	1.34E+04	9.77E-01	4.98E-04	1.04E-05	6.07E-05	1.70E-06	1.44E+02	1.21	1.21	4339	73%	73%	24	24
Solid Layer	0.00E+00	0.0	0.0	0.0	0.0	0.0	0.0	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.0	0.00	0.00	0	0%	0%	5	5

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (µg/mL)	TOC in liquid [TOC] (µg/mL)	NO ₂ in liquid [NO ₂] (µg/mL)	NO ₃ in liquid [NO ₃] (µg/mL)	Na in liquid [Na] (µg/mL)	Al in liquid [Al] (µg/mL)	⁹⁰ Sr in waste [Sr] (µCi/g)	²⁴¹ Am in waste [Am241] (µCi/g)	²⁴⁰ Pu in waste [Pu240] (µCi/g)	²³⁹ Pu in waste [Pu240] (µCi/g)	²³⁸ Pu in waste [Pu238] (µCi/g)	¹³⁷ Cs in waste [Cs] (µCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-AP-107	1.86E+04	1.59E+03	3.20E+04	1.51E+05	1.24E+05	9.02E+03	8.01E-05	8.01E-05	8.01E-05	8.01E-05	3.63E-06	6.83E+01	1.28	1.28	4312	68%	68%	24	19
Supernatant	1.86E+04	1.59E+03	3.20E+04	1.51E+05	1.24E+05	9.02E+03	4.45E-01	2.29E-04	1.63E-05	8.01E-05	3.63E-06	6.83E+01	1.28	1.28	4312	68%	68%	24	19
Solid Layer	0.00E+00	0.0	0.0	0.0	0.0	0.0	0.0	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.0	0.00	0.00	0	0%	0%	5	5
241-AP-108	3.66E+04	3.48E+03	7.91E+04	1.73E+05	2.06E+05	2.29E+04	6.98E-01	1.24E-03	5.29E-05	2.77E-04	1.74E-05	1.45E+02	1.42	1.41	4758	51%	51%	27	27
Supernatant	3.63E+04	3.47E+03	7.91E+04	1.73E+05	2.05E+05	2.29E+04	7.20E-01	1.34E-03	5.38E-05	2.83E-04	1.76E-05	1.46E+02	1.41	1.41	4375	51%	51%	27	27
Solid Layer	3.95E+04	3504.7	79778.6	174775.2	207286.1	23057.4	0.5	2.19E-04	4.33E-05	2.14E-04	1.60E-05	130.5	1.55	1.42	383	45%	51%	28	27
241-AW-101	9.88E+04	2.59E+03	1.04E+05	1.70E+05	2.31E+05	2.92E+04	1.31E+01	1.65E-02	4.12E-03	1.58E-02	1.15E-03	2.41E+02	1.51	1.47	4211	44%	44%	40	29
Supernatant	9.83E+04	2.58E+03	1.04E+05	1.69E+05	2.30E+05	2.91E+04	2.53E-01	1.75E-04	7.20E-05	2.77E-04	2.01E-05	2.55E+02	1.46	1.46	2808	44%	44%	40	29
Solid Layer	9.96E+04	2.61E+03	1.05E+05	1.71E+05	2.33E+05	2.95E+04	3.68E+01	4.66E-02	1.16E-02	4.45E-02	3.23E-03	2.13E+02	1.59	1.47	1403	44%	44%	40	29
241-AW-102	3.16E+03	1.90E+03	1.50E+04	1.59E+04	3.77E+04	1.94E+03	2.27E+01	7.60E-02	4.05E-03	1.97E-02	5.54E-04	3.07E+01	1.08	1.07	4127	86%	88%	32	30
Supernatant	2.94E+03	1.90E+03	1.50E+04	1.59E+04	3.76E+04	1.94E+03	8.44E-02	1.18E-05	2.18E-04	1.30E-03	2.47E-04	2.89E+01	1.07	1.07	4011	88%	88%	32	30
Solid Layer	1.85E+04	1.92E+03	1.52E+04	1.60E+04	3.80E+04	1.96E+03	5.44E+02	1.83E+00	9.27E-02	4.45E-01	7.65E-03	7.11E+01	1.60	1.22	116	33%	88%	33	30
241-AW-103	1.75E+04	3.24E+03	5.27E+04	1.45E+05	1.33E+05	8.02E+03	2.43E+00	3.05E-02	2.09E-02	7.45E-02	7.36E-03	6.85E+01	1.31	1.30	4187	64%	63%	25	27
Supernatant	1.29E+04	1.85E+03	3.31E+04	9.52E+04	9.96E+04	7.98E+03	1.76E-01	4.08E-05	2.02E-05	9.52E-05	8.61E-06	8.97E+01	1.24	1.24	2931	70%	70%	25	27
Solid Layer	2.72E+04	6.11E+03	9.31E+04	2.47E+05	2.01E+05	8.08E+03	6.81E+00	8.94E-02	6.13E-02	2.19E-01	2.16E-02	2.75E+01	1.49	1.42	1256	55%	51%	25	27
241-AW-104	2.81E+04	4.12E+03	7.53E+04	1.13E+05	1.82E+05	2.67E+04	1.06E+00	1.21E-02	2.59E-02	9.23E-02	9.18E-03	1.75E+02	1.37	1.36	4086	54%	56%	32	30
Supernatant	2.51E+04	4.29E+03	7.40E+04	1.12E+05	1.69E+05	2.53E+04	1.20E+00	1.16E-03	1.87E-05	1.05E-04	3.35E-06	1.76E+02	1.35	1.35	3243	56%	56%	31	30
Solid Layer	4.01E+04	3.42E+03	8.04E+04	1.18E+05	2.36E+05	3.29E+04	5.88E-01	5.02E-02	1.16E-01	4.14E-01	4.12E-02	1.69E+02	1.48	1.41	843	50%	55%	33	30
241-AW-105	6.73E+03	5.64E+02	2.89E+03	2.68E+04	2.45E+04	1.71E+02	3.09E+01	3.43E-01	1.05E-01	3.72E-01	3.71E-02	2.20E+01	1.21	1.07	1616	73%	86%	22	24
Supernatant	4.25E+03	5.46E+02	2.80E+03	2.59E+04	2.37E+04	1.66E+02	2.04E-02	5.87E-05	5.95E-05	2.11E-04	2.10E-05	9.20E+00	1.04	1.04	676	91%	91%	23	24
Solid Layer	8.70E+03	5.78E+02	2.96E+03	2.74E+04	2.51E+04	1.76E+02	4.82E+01	5.35E-01	1.63E-01	5.81E-01	5.78E-02	2.91E+01	1.33	1.10	940	63%	84%	22	24
241-AW-106	1.41E+04	2.30E+03	3.22E+04	1.26E+05	1.18E+05	9.67E+03	7.97E+00	8.76E-03	8.12E-03	3.13E-02	2.25E-03	1.66E+02	1.35	1.22	4325	58%	71%	33	26
Supernatant	1.16E+04	2.30E+03	3.22E+04	1.26E+05	1.18E+05	9.65E+03	4.08E-01	5.41E-04	1.34E-04	8.61E-04	1.44E-05	1.02E+02	1.22	1.22	3263	71%	71%	30	26
Solid Layer	2.72E+04	2.33E+03	3.26E+04	1.27E+05	1.19E+05	9.77E+03	2.39E+01	2.61E-02	2.50E-02	9.58E-02	6.97E-03	3.01E+02	1.77	1.25	1062	30%	71%	40	26
241-AY-101	1.12E+04	8.29E+02	1.49E+04	6.14E+04	6.35E+04	2.41E+03	5.59E+02	3.78E+00	6.17E-02	2.02E-01	1.71E-02	3.56E+01	1.20	1.13	3187	74%	82%	33	30
Supernatant	1.23E+04	6.10E+02	9.68E+03	6.71E+04	6.21E+04	2.61E+03	7.88E-01	3.59E-03	7.41E-04	3.31E-03	1.28E-04	2.06E+01	1.13	1.13	2788	82%	82%	32	30
Solid Layer	5.00E+02	2.95E+03	6.53E+04	6.75E+03	7.80E+04	5.30E+02	3.17E+03	2.14E+01	3.47E-01	1.13E+00	9.67E-02	1.06E+02	1.68	1.14	399	40%	81%	39	30
241-AY-102	3.31E+04	1.77E+03	3.56E+04	9.68E+04	1.17E+05	6.10E+03	1.65E+03	9.76E-01	7.24E-02	3.15E-01	1.21E-02	1.31E+02	1.33	1.27	3821	60%	68%	49	45
Supernatant	3.69E+04	1.80E+03	3.97E+04	1.08E+05	1.22E+05	6.77E+03	1.37E-01	1.50E-04	3.97E-05	1.68E-04	2.05E-05	1.00E+02	1.29	1.29	3250	65%	65%	46	45
Solid Layer	5.52E+02	1.53E+03	7.25E+04	3.88E+02	7.03E+04	3.41E+02	9.26E+03	5.46E+00	4.05E-01	1.76E+00	6.74E-02	2.75E+02	1.59	1.15	571	39%	82%	59	45
241-AZ-101	1.22E+04	5.48E+02	6.57E+04	5.65E+04	1.19E+05	6.47E+03	1.36E+03	6.30E+00	8.18E-02	2.89E-01	2.85E-02	1.30E+03	1.26	1.24	3226	69%	72%	53	51
Supernatant	1.22E+04	5.48E+02	6.57E+04	5.65E+04	1.19E+05	6.47E+03	7.50E-01	1.25E-04	3.47E-04	1.21E-03	1.25E-04	1.35E+03	1.24	1.24	3029	72%	72%	51	51
Solid Layer	1.15E+04	5.55E+02	6.65E+04	5.72E+04	1.20E+05	6.55E+03	1.74E+04	8.07E+01	1.04E+00	3.69E+00	3.63E-01	7.66E+02	1.61	1.22	197	34%	71%	79	51
241-AZ-102	2.07E+03	1.06E+03	3.42E+04	1.36E+04	5.82E+04	5.64E+02	9.25E+02	6.71E+00	8.30E-02	3.15E-01	4.66E-02	8.28E+02	1.16	1.13	3646	80%	84%	57	67
Supernatant	2.03E+03	1.06E+03	3.42E+04	1.35E+04	5.82E+04	5.63E+02	1.78E+00	5.64E-04	1.80E-03	6.60E-03	6.38E-04	8.53E+02	1.13	1.13	3250	84%	84%	53	67
Solid Layer	2.45E+03	1.07E+03	3.46E+04	1.37E+04	5.88E+04	5.70E+02	6.99E+03	5.08E+01	6.16E-01	2.34E+00	3.48E-01	6.63E+02	1.41	1.11	396	55%	84%	87	67
241-SY-101	1.64E+04	9.10E+02	9.41E+03	6.34E+04	5.82E+04	3.59E+03	1.11E+01	8.55E-02	1.89E-03	8.80E-03	3.08E-04	5.29E+01	1.21	1.15	4131	72%	79%	26	23
Supernatant	1.20E+04	9.08E+02	9.39E+03	6.33E+04	5.81E+04	3.58E+03	9.61E-01	4.21E-03	4.68E-04	2.19E-03	7.77E-05	2.32E+01	1.13	1.13	3238	80%	80%	24	23
Solid Layer	3.74E+04	9.19E+02	9.50E+03	6.41E+04	5.88E+04	3.63E+03	3.85E+01	3.04E-01	5.70E-03	2.66E-02	9.28E-04	1.33E+02	1.52	1.28	893	50%	79%	30	23

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (µg/mL)	TOC in liquid [TOC] (µg/mL)	NO ₂ in liquid [NO ₂] (µg/mL)	NO ₃ in liquid [NO ₃] (µg/mL)	Na in liquid [Na] (µg/mL)	Al in liquid [Al] (µg/mL)	⁹⁰ Sr in waste [Sr] (µCi/g)	²⁴¹ Am in waste [Am241] (µCi/g)	²⁴⁰ Pu in waste [Pu240] (µCi/g)	²³⁹ Pu in waste [Pu239] (µCi/g)	²³⁸ Pu in waste [Pu238] (µCi/g)	¹³⁷ Cs in waste [Cs] (µCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-SY-102	1.48E+04	1.93E+03	2.67E+04	8.04E+04	8.30E+04	5.04E+03	8.57E+01	8.72E+00	4.74E-01	2.06E+00	9.73E-02	6.38E+01	1.30	1.19	1829	65%	74%	29	27
Supernatant	1.12E+04	9.38E+02	9.22E+03	5.27E+04	5.27E+04	3.51E+03	1.68E-02	2.32E-05	5.09E-06	2.38E-05	4.03E-06	2.36E+01	1.13	1.13	1077	81%	81%	29	27
Solid Layer	2.06E+04	3.61E+03	5.61E+04	1.27E+05	1.34E+05	7.61E+03	1.75E+02	1.78E+01	9.69E-01	4.20E+00	1.99E-01	1.06E+02	1.54	1.31	752	48%	66%	29	27
241-SY-103	2.94E+04	6.13E+03	1.50E+05	1.65E+05	2.12E+05	3.71E+04	1.63E+01	2.98E-01	5.84E-03	2.73E-02	9.50E-04	2.56E+02	1.52	1.46	2744	41%	44%	36	28
Supernatant	2.91E+04	6.07E+03	1.49E+05	1.64E+05	2.10E+05	3.67E+04	2.02E+00	6.81E-03	7.83E-06	3.65E-05	1.28E-06	2.87E+02	1.46	1.46	1541	44%	44%	33	28
Solid Layer	2.99E+04	6.22E+03	1.52E+05	1.68E+05	2.15E+05	3.76E+04	3.28E+01	6.35E-01	1.26E-02	5.89E-02	2.05E-03	2.20E+02	1.61	1.47	1203	37%	43%	40	28
241-A-101	4.27E+04	3.74E+03	1.65E+05	2.33E+05	2.78E+05	5.18E+04	6.85E+01	2.15E-01	1.09E-02	4.53E-02	2.02E-03	1.71E+02	1.70	1.49	1075	32%	47%	44	28
Supernatant	4.27E+04	3.74E+03	1.65E+05	2.33E+05	2.78E+05	5.18E+04	6.85E+01	2.15E-01	1.09E-02	4.53E-02	2.02E-03	1.71E+02	1.49	1.49	38	47%	47%	36	28
Solid Layer	4.27E+04	3.74E+03	1.65E+05	2.33E+05	2.78E+05	5.18E+04	6.85E+01	2.15E-01	1.09E-02	4.53E-02	2.02E-03	1.71E+02	1.70	1.49	1037	32%	47%	44	28
241-A-102	1.34E+04	3.43E+03	1.34E+05	1.47E+05	1.55E+05	3.17E+04	2.69E+02	8.59E-01	2.51E-01	1.08E+00	4.44E-02	1.41E+02	1.53	1.44	189	46%	53%	31	31
Supernatant	4.17E+03	1.06E+04	4.15E+04	4.55E+04	4.81E+04	9.87E+03	2.35E-01	2.28E-04	1.80E-04	7.78E-04	3.19E-05	1.05E+02	1.14	1.14	50	82%	82%	33	31
Solid Layer	1.73E+04	4.42E+03	1.72E+05	1.89E+05	2.00E+05	4.09E+04	3.34E+02	1.07E+00	3.12E-01	1.35E+00	5.52E-02	1.50E+02	1.67	1.57	139	37%	46%	31	31
241-A-103	4.71E+04	8.03E+03	1.20E+05	2.34E+05	2.27E+05	3.43E+04	6.18E+01	1.18E-01	2.53E-02	1.10E-01	4.38E-03	1.41E+02	1.36	1.49	1472	42%	51%	38	27
Supernatant	1.52E+04	2.57E+03	3.85E+04	7.49E+04	7.29E+04	1.10E+04	5.18E-01	8.36E-04	1.35E-03	5.82E-03	2.39E-04	7.23E+01	1.16	1.16	55	80%	80%	38	27
Solid Layer	4.88E+04	8.31E+03	1.24E+05	2.42E+05	2.35E+05	3.55E+04	6.39E+01	1.21E-01	2.61E-02	1.14E-01	4.52E-03	1.43E+02	1.37	1.51	1417	41%	50%	38	27
241-A-104	4.27E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.29E+04	8.04E+00	1.49E+00	6.79E+00	2.25E-01	6.18E+02	1.00	1.17	144	23%	75%	74	34
Supernatant	4.27E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.29E+04	8.04E+00	1.49E+00	6.79E+00	2.25E-01	6.18E+02	1.17	1.17	38	75%	75%	54	34
Solid Layer	4.27E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.29E+04	8.04E+00	1.49E+00	6.79E+00	2.25E-01	6.18E+02	0.95	1.17	106	0%	75%	74	34
241-A-105	4.27E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.35E+04	2.63E+01	6.35E-01	2.60E+00	1.22E-01	5.00E+02	1.46	1.17	177	0%	0%	0	0
Supernatant	4.27E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.35E+04	2.63E+01	6.35E-01	2.60E+00	1.22E-01	5.00E+02	1.17	1.17	38	0%	0%	61	61
Solid Layer	4.27E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.35E+04	2.63E+01	6.35E-01	2.60E+00	1.22E-01	5.00E+02	1.54	1.17	139	0%	0%	61	61
241-A-106	4.27E+04	1.10E+04	3.60E+04	7.96E+04	8.32E+04	4.94E+03	9.62E+02	1.14E+00	4.64E-01	2.03E+00	7.93E-02	1.26E+02	1.64	1.17	337	38%	75%	53	39
Supernatant	4.27E+04	1.10E+04	3.60E+04	7.96E+04	8.32E+04	4.94E+03	9.62E+02	1.14E+00	4.64E-01	2.03E+00	7.93E-02	1.26E+02	1.17	1.17	38	75%	75%	46	39
Solid Layer	4.27E+04	1.10E+04	3.60E+04	7.96E+04	8.32E+04	4.94E+03	9.62E+02	1.14E+00	4.64E-01	2.03E+00	7.93E-02	1.26E+02	1.70	1.17	299	34%	75%	53	39
241-AX-101	3.90E+04	3.98E+03	1.73E+05	2.72E+05	2.82E+05	5.03E+04	9.59E+01	1.71E-01	1.17E-02	5.02E-02	2.08E-03	1.76E+02	1.70	1.53	1391	34%	43%	35	28
Supernatant	3.90E+04	3.98E+03	1.73E+05	2.72E+05	2.82E+05	5.03E+04	9.59E+01	1.71E-01	1.17E-02	5.02E-02	2.08E-03	1.76E+02	1.53	1.53	38	43%	43%	32	28
Solid Layer	3.90E+04	3.98E+03	1.73E+05	2.72E+05	2.82E+05	5.03E+04	9.59E+01	1.71E-01	1.17E-02	5.02E-02	2.08E-03	1.76E+02	1.70	1.53	1353	34%	43%	35	28
241-AX-102	3.89E+04	2.30E+04	1.07E+05	1.76E+05	1.98E+05	2.75E+04	1.29E+03	1.20E+01	2.73E-01	8.55E-01	7.90E-02	1.38E+02	1.53	1.39	151	39%	51%	24	24
Supernatant	3.89E+04	2.30E+04	1.07E+05	1.76E+05	1.98E+05	2.75E+04	1.29E+03	1.20E+01	2.73E-01	8.55E-01	7.90E-02	1.38E+02	1.39	1.39	38	51%	51%	24	24
Solid Layer	3.89E+04	2.30E+04	1.07E+05	1.76E+05	1.98E+05	2.75E+04	1.29E+03	1.20E+01	2.73E-01	8.55E-01	7.90E-02	1.38E+02	1.58	1.39	113	36%	51%	24	24
241-AX-103	3.89E+04	4.03E+03	1.22E+05	1.91E+05	2.36E+05	3.79E+04	6.98E+02	1.14E+00	3.66E-02	1.45E-01	6.80E-03	1.81E+02	1.57	1.45	441	45%	49%	37	30
Supernatant	3.89E+04	4.03E+03	1.22E+05	1.91E+05	2.36E+05	3.79E+04	6.98E+02	1.14E+00	3.66E-02	1.45E-01	6.80E-03	1.81E+02	1.45	1.45	38	49%	49%	34	30
Solid Layer	3.89E+04	4.03E+03	1.22E+05	1.91E+05	2.36E+05	3.79E+04	6.98E+02	1.14E+00	3.66E-02	1.45E-01	6.80E-03	1.81E+02	1.58	1.45	403	44%	49%	37	30
241-AX-104	3.89E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.07E+04	1.88E+01	1.31E+00	5.34E+00	2.52E-01	9.86E+02	1.44	1.17	66	39%	75%	32	30
Supernatant	3.89E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.07E+04	1.88E+01	1.31E+00	5.34E+00	2.52E-01	9.86E+02	1.17	1.17	38	75%	75%	31	30
Solid Layer	3.89E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.07E+04	1.88E+01	1.31E+00	5.34E+00	2.52E-01	9.86E+02	1.80	1.17	28	8%	75%	32	30
241-B-101	1.70E+04	6.77E+00	1.32E+05	3.56E+05	2.26E+05	7.23E+02	3.26E+02	2.28E+00	1.55E-01	5.02E-01	4.39E-02	3.48E+00	1.51	1.53	449	41%	50%	39	32
Supernatant	1.70E+04	6.77E+00	1.32E+05	3.56E+05	2.26E+05	7.23E+02	3.26E+02	2.28E+00	1.55E-01	5.02E-01	4.39E-02	3.48E+00	1.53	1.53	38	50%	50%	35	32
Solid Layer	1.70E+04	6.77E+00	1.32E+05	3.56E+05	2.26E+05	7.23E+02	3.26E+02	2.28E+00	1.55E-01	5.02E-01	4.39E-02	3.48E+00	1.51	1.53	411	40%	50%	39	32

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (µg/mL)	TOC in liquid [TOC] (µg/mL)	NO ₂ in liquid [NO ₂] (µg/mL)	NO ₃ in liquid [NO ₃] (µg/mL)	Na in liquid [Na] (ug/mL)	Al in liquid [Al] (µg/mL)	⁹⁰ Sr in waste [Sr] (µCi/g)	²⁴¹ Am in waste [Am241] (µCi/g)	²⁴⁰ Pu in waste [Pu240] (µCi/g)	²³⁹ Pu in waste [Pu240] (µCi/g)	²³⁸ Pu in waste [Pu238] (µCi/g)	¹³⁷ Cs in waste [Cs] (µCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-B-102	1.24E+04	2.47E+00	6.23E+03	1.59E+05	8.25E+04	2.64E+02	5.84E-01	4.15E-04	2.53E-03	2.24E-02	1.66E-04	2.57E+00	1.43	1.19	159	56%	75%	18	24
Supernatant	4.82E+03	9.59E-01	2.40E+03	6.15E+04	3.20E+04	1.03E+02	5.60E-01	4.09E-04	1.56E-04	1.38E-03	1.03E-05	2.36E+00	1.07	1.07	53	90%	90%	18	24
Solid Layer	1.70E+04	3.38E+00	8.52E+03	2.17E+05	1.13E+05	3.61E+02	5.91E-01	4.17E-04	3.32E-03	2.93E-02	2.18E-04	2.64E+00	1.61	1.26	106	45%	70%	18	24
241-B-103	1.70E+04	3.38E+00	8.50E+03	2.18E+05	1.13E+05	3.62E+02	1.40E+00	1.23E-03	1.70E-02	1.50E-01	1.12E-03	2.65E+00	1.56	1.26	249	52%	70%	17	20
Supernatant	1.70E+04	3.38E+00	8.50E+03	2.18E+05	1.13E+05	3.62E+02	1.40E+00	1.23E-03	1.70E-02	1.50E-01	1.12E-03	2.65E+00	1.26	1.26	38	70%	70%	19	20
Solid Layer	1.70E+04	3.38E+00	8.50E+03	2.18E+05	1.13E+05	3.62E+02	1.40E+00	1.23E-03	1.70E-02	1.50E-01	1.12E-03	2.65E+00	1.61	1.26	211	49%	70%	17	20
241-B-104	1.70E+04	3.38E+00	8.49E+03	2.16E+05	1.13E+05	3.62E+02	1.98E+00	2.44E-03	4.71E-03	4.40E-02	3.03E-04	6.62E+00	1.38	1.26	1455	48%	70%	21	22
Supernatant	1.70E+04	3.38E+00	8.49E+03	2.16E+05	1.13E+05	3.62E+02	1.98E+00	2.44E-03	4.71E-03	4.40E-02	3.03E-04	6.62E+00	1.26	1.26	38	70%	70%	22	22
Solid Layer	1.70E+04	3.38E+00	8.49E+03	2.16E+05	1.13E+05	3.62E+02	1.98E+00	2.44E-03	4.71E-03	4.40E-02	3.03E-04	6.62E+00	1.38	1.26	1417	48%	70%	21	22
241-B-105	1.70E+04	3.38E+00	8.51E+03	2.16E+05	1.13E+05	3.62E+02	5.56E-01	7.57E-04	3.87E-03	3.43E-02	2.53E-04	2.34E+00	1.64	1.26	1136	44%	70%	19	18
Supernatant	1.70E+04	3.38E+00	8.51E+03	2.16E+05	1.13E+05	3.62E+02	5.56E-01	7.57E-04	3.87E-03	3.43E-02	2.53E-04	2.34E+00	1.26	1.26	38	70%	70%	18	18
Solid Layer	1.70E+04	3.38E+00	8.51E+03	2.16E+05	1.13E+05	3.62E+02	5.56E-01	7.57E-04	3.87E-03	3.43E-02	2.53E-04	2.34E+00	1.65	1.26	1098	43%	70%	19	18
241-B-106	1.58E+04	3.13E+00	7.88E+03	2.01E+05	1.05E+05	3.34E+02	4.61E+01	9.33E-03	2.95E-03	2.74E-02	1.91E-04	1.46E+01	1.35	1.18	502	62%	69%	23	22
Supernatant	1.62E+03	3.23E-01	8.12E+02	2.07E+04	1.08E+04	3.44E+01	1.98E-01	1.44E-04	5.50E-05	4.87E-04	3.61E-06	8.32E-01	1.02	1.02	42	96%	96%	18	22
Solid Layer	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.60E+02	4.92E+01	9.95E-03	3.14E-03	2.92E-02	2.04E-04	1.55E+01	1.38	1.19	460	60%	67%	23	22
241-B-107	1.70E+04	5.04E+00	6.51E+03	3.31E+05	1.46E+05	2.01E+01	3.22E+00	4.59E-03	4.74E-03	4.03E-02	3.27E-04	1.10E+01	1.61	1.34	649	41%	58%	16	25
Supernatant	1.70E+04	5.04E+00	6.51E+03	3.31E+05	1.46E+05	2.01E+01	3.22E+00	4.59E-03	4.74E-03	4.03E-02	3.27E-04	1.10E+01	1.34	1.34	38	58%	58%	20	25
Solid Layer	1.70E+04	5.04E+00	6.51E+03	3.31E+05	1.46E+05	2.01E+01	3.22E+00	4.59E-03	4.74E-03	4.03E-02	3.27E-04	1.10E+01	1.63	1.34	611	40%	58%	16	25
241-B-108	1.70E+04	3.71E+00	5.38E+04	3.76E+05	1.74E+05	8.98E+02	1.56E+00	1.80E-04	4.83E-04	3.29E-03	3.91E-05	1.26E+01	1.67	1.38	388	37%	70%	21	22
Supernatant	1.70E+04	3.71E+00	5.38E+04	3.76E+05	1.74E+05	8.98E+02	1.56E+00	1.80E-04	4.83E-04	3.29E-03	3.91E-05	1.26E+01	1.38	1.38	38	70%	70%	22	22
Solid Layer	1.70E+04	3.71E+00	5.38E+04	3.76E+05	1.74E+05	8.98E+02	1.56E+00	1.80E-04	4.83E-04	3.29E-03	3.91E-05	1.26E+01	1.70	1.38	350	35%	70%	21	22
241-B-109	1.70E+04	3.39E+00	8.51E+03	2.17E+05	1.13E+05	3.61E+02	4.34E-01	7.25E-04	3.33E-03	2.47E-02	2.54E-04	1.49E+00	1.78	1.26	513	41%	70%	20	20
Supernatant	1.70E+04	3.39E+00	8.51E+03	2.17E+05	1.13E+05	3.61E+02	4.34E-01	7.25E-04	3.33E-03	2.47E-02	2.54E-04	1.49E+00	1.26	1.26	38	70%	70%	20	20
Solid Layer	1.70E+04	3.39E+00	8.51E+03	2.17E+05	1.13E+05	3.61E+02	4.34E-01	7.25E-04	3.33E-03	2.47E-02	2.54E-04	1.49E+00	1.82	1.26	475	39%	70%	20	20
241-B-110	1.64E+04	5.34E+03	3.80E+04	7.48E+04	9.18E+04	1.00E+04	7.52E+01	7.00E-02	1.04E-02	9.78E-02	3.03E-03	1.05E+01	1.35	1.01	967	60%	77%	21	23
Supernatant	1.62E+03	5.30E+02	3.78E+03	7.43E+03	9.13E+03	9.94E+02	2.17E-01	6.34E-04	1.10E-04	4.74E-04	1.98E-05	1.31E+00	1.02	1.02	42	97%	97%	21	23
Solid Layer	1.70E+04	5.55E+03	3.95E+04	7.78E+04	9.55E+04	1.04E+04	7.77E+01	7.24E-02	1.08E-02	1.01E-01	3.13E-03	1.09E+01	1.36	1.01	925	58%	76%	21	23
241-B-111	1.63E+04	5.32E+03	3.79E+04	7.45E+04	9.15E+04	9.97E+03	1.85E+02	8.21E-02	1.06E-02	8.33E-02	2.85E-03	1.19E+02	1.26	1.01	952	64%	77%	25	24
Supernatant	1.62E+03	5.30E+02	3.78E+03	7.43E+03	9.13E+03	9.94E+02	2.17E-01	6.34E-04	1.10E-04	4.74E-04	1.98E-05	1.31E+00	1.02	1.02	42	97%	97%	24	24
Solid Layer	1.70E+04	5.55E+03	3.95E+04	7.78E+04	9.55E+04	1.04E+04	1.92E+02	8.51E-02	1.09E-02	8.64E-02	2.96E-03	1.24E+02	1.27	1.01	910	63%	76%	25	24
241-B-112	1.28E+04	1.37E+04	8.84E+04	1.64E+05	1.93E+05	3.58E+04	3.35E+00	1.21E-03	3.30E-04	2.17E-03	3.88E-05	3.36E+01	1.38	1.39	170	51%	55%	25	22
Supernatant	3.83E+03	4.09E+03	2.64E+04	4.89E+04	5.73E+04	1.06E+04	4.66E-01	1.36E-03	2.44E-04	1.02E-03	3.93E-05	3.08E+01	1.11	1.11	49	84%	84%	25	22
Solid Layer	1.70E+04	1.82E+04	1.17E+05	2.17E+05	2.55E+05	4.73E+04	4.23E+00	1.16E-03	3.56E-04	2.52E-03	3.86E-05	3.44E+01	1.49	1.51	121	41%	46%	25	22
241-B-201	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.71E+00	2.84E-02	4.33E-02	7.51E-01	6.28E-03	1.36E-01	1.26	1.17	115	65%	75%	17	19
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.71E+00	2.84E-02	4.33E-02	7.51E-01	6.28E-03	1.36E-01	1.17	1.17	4	75%	75%	18	19
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.71E+00	2.84E-02	4.33E-02	7.51E-01	6.28E-03	1.36E-01	1.26	1.17	111	64%	75%	17	19
241-B-202	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.00E+00	6.67E-02	2.17E-02	1.28E-01	2.03E-03	7.67E-02	1.22	1.17	112	76%	83%	18	20
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.00E+00	6.67E-02	2.17E-02	1.28E-01	2.03E-03	7.67E-02	1.17	1.17	4	83%	83%	19	20
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.00E+00	6.67E-02	2.17E-02	1.28E-01	2.03E-03	7.67E-02	1.22	1.17	108	76%	83%	18	20

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (ug/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-B-203	1.65E+04	9.40E+01	1.54E+03	5.54E+04	3.05E+04	0.00E+00	6.75E-02	3.37E-02	2.87E-02	2.27E-01	1.97E-03	6.45E-03	1.18	1.05	194	76%	90%	19	12
Supernatant	8.53E+02	3.32E+01	5.43E+02	1.95E+04	1.08E+04	0.00E+00	2.77E-05	1.45E-05	1.73E-04	1.37E-03	1.18E-05	3.21E-05	1.02	1.02	6	96%	96%	20	12
Solid Layer	1.70E+04	9.60E+01	1.57E+03	5.65E+04	3.12E+04	0.00E+00	6.93E-02	3.46E-02	2.95E-02	2.33E-01	2.02E-03	6.62E-03	1.19	1.05	188	76%	89%	19	12
241-B-204	1.64E+04	7.38E+01	1.34E+03	3.40E+04	2.73E+04	0.00E+00	2.54E-03	3.72E-02	2.43E-02	1.93E-01	1.67E-03	2.54E-02	1.18	1.05	191	78%	92%	19	20
Supernatant	1.25E+03	3.33E+01	6.03E+02	1.53E+04	1.23E+04	0.00E+00	1.57E-05	7.09E-08	2.13E-06	3.17E-05	1.07E-07	1.80E-05	1.02	1.02	7	96%	96%	19	20
Solid Layer	1.70E+04	7.53E+01	1.36E+03	3.47E+04	2.78E+04	0.00E+00	2.62E-03	3.84E-02	2.51E-02	1.99E-01	1.72E-03	2.62E-02	1.19	1.05	184	77%	91%	19	20
241-BX-101	1.70E+04	4.98E+03	6.43E+04	1.21E+05	1.42E+05	5.17E+03	2.55E+02	1.37E-01	1.32E-01	6.39E-01	2.11E-02	9.08E+01	1.61	1.28	218	24%	75%	23	23
Supernatant	1.70E+04	4.98E+03	6.43E+04	1.21E+05	1.42E+05	5.17E+03	2.55E+02	1.37E-01	1.32E-01	6.39E-01	2.11E-02	9.08E+01	1.28	1.28	38	75%	75%	23	23
Solid Layer	1.70E+04	4.98E+03	6.43E+04	1.21E+05	1.42E+05	5.17E+03	2.55E+02	1.37E-01	1.32E-01	6.39E-01	2.11E-02	9.08E+01	1.68	1.28	180	16%	75%	23	23
241-BX-102	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.14E+02	3.48E-03	3.51E-03	1.67E-02	3.38E-04	3.40E+01	1.13	1.17	336	37%	75%	22	22
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.14E+02	3.48E-03	3.51E-03	1.67E-02	3.38E-04	3.40E+01	1.17	1.17	38	75%	75%	22	22
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.14E+02	3.48E-03	3.51E-03	1.67E-02	3.38E-04	3.40E+01	1.12	1.17	298	32%	75%	22	22
241-BX-103	1.49E+04	3.20E+03	1.20E+04	3.90E+04	3.41E+04	1.56E+04	3.78E+02	2.67E-01	4.00E-01	1.76E+00	3.95E-02	4.10E+01	1.49	1.09	323	57%	80%	21	23
Supernatant	9.68E+03	2.07E+03	7.77E+03	2.53E+04	2.21E+04	1.01E+04	2.86E-01	3.17E-03	6.79E-04	2.88E-03	6.80E-05	3.36E-01	1.04	1.04	88	87%	87%	23	23
Solid Layer	1.70E+04	3.64E+03	1.37E+04	4.44E+04	3.88E+04	1.77E+04	4.66E+02	3.29E-01	4.94E-01	2.18E+00	4.88E-02	5.05E+01	1.66	1.11	235	50%	78%	21	23
241-BX-104	1.46E+04	2.74E+03	5.48E+04	1.15E+05	1.20E+05	2.44E+03	1.79E+02	4.95E-01	4.16E-02	3.22E-01	3.19E-03	5.80E+01	1.61	1.24	418	32%	61%	30	25
Supernatant	3.83E+03	7.18E+02	1.43E+04	3.01E+04	3.15E+04	6.39E+02	3.58E-01	5.70E-05	8.65E-06	4.54E-05	7.07E-07	2.62E+01	1.06	1.06	49	89%	89%	30	25
Solid Layer	1.70E+04	3.19E+03	6.37E+04	1.34E+05	1.40E+05	2.84E+03	1.94E+02	5.37E-01	4.51E-02	3.49E-01	3.46E-03	6.07E+01	1.68	1.28	369	27%	59%	30	25
241-BX-105	1.18E+04	6.53E+03	2.77E+04	8.11E+04	8.57E+04	4.11E+03	1.61E+02	5.25E-02	1.70E-02	8.49E-02	1.81E-03	6.85E+01	1.59	1.20	310	23%	71%	23	23
Supernatant	5.48E+03	3.04E+03	1.29E+04	3.78E+04	3.99E+04	1.92E+03	2.21E+00	7.27E-03	9.63E-04	4.09E-03	9.64E-05	3.50E+01	1.09	1.09	56	88%	88%	20	23
Solid Layer	1.70E+04	9.44E+03	4.00E+04	1.17E+05	1.24E+05	5.94E+03	1.83E+02	5.90E-02	1.92E-02	9.64E-02	2.05E-03	7.32E+01	1.69	1.29	254	14%	69%	24	23
241-BX-106	1.70E+04	1.82E+04	1.17E+05	2.17E+05	2.55E+05	4.72E+04	3.13E+02	2.50E-01	4.01E-02	1.96E-01	5.18E-03	7.98E+01	1.59	1.51	181	41%	46%	20	27
Supernatant	1.70E+04	1.82E+04	1.17E+05	2.17E+05	2.55E+05	4.72E+04	3.13E+02	2.50E-01	4.01E-02	1.96E-01	5.18E-03	7.98E+01	1.51	1.51	38	46%	46%	24	27
Solid Layer	1.70E+04	1.82E+04	1.17E+05	2.17E+05	2.55E+05	4.72E+04	3.13E+02	2.50E-01	4.01E-02	1.96E-01	5.18E-03	7.98E+01	1.62	1.51	143	40%	46%	20	27
241-BX-107	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	7.51E+00	1.30E-02	5.61E-03	5.16E-02	3.63E-04	1.34E+01	1.43	1.17	1351	51%	75%	19	19
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	7.51E+00	1.30E-02	5.61E-03	5.16E-02	3.63E-04	1.34E+01	1.17	1.17	38	75%	75%	19	19
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	7.51E+00	1.30E-02	5.61E-03	5.16E-02	3.63E-04	1.34E+01	1.44	1.17	1313	51%	75%	19	19
241-BX-108	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.29E+02	1.87E-02	5.16E-03	4.79E-02	3.34E-04	2.26E+01	1.39	1.17	157	29%	75%	20	23
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.29E+02	1.87E-02	5.16E-03	4.79E-02	3.34E-04	2.26E+01	1.17	1.17	38	75%	75%	21	23
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.29E+02	1.87E-02	5.16E-03	4.79E-02	3.34E-04	2.26E+01	1.46	1.17	119	17%	75%	20	23
241-BX-109	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.07E+02	5.36E-03	1.05E-03	9.73E-03	6.79E-05	1.08E+01	1.50	1.17	768	51%	72%	26	24
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.07E+02	5.36E-03	1.05E-03	9.73E-03	6.79E-05	1.08E+01	1.17	1.17	38	72%	72%	25	24
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.07E+02	5.36E-03	1.05E-03	9.73E-03	6.79E-05	1.08E+01	1.52	1.17	730	51%	72%	26	24
241-BX-110	1.62E+04	1.45E+04	4.96E+04	3.92E+05	2.12E+05	4.18E+03	7.61E+00	4.60E-03	1.75E-03	1.47E-02	1.41E-04	4.79E+01	1.64	1.42	850	43%	54%	22	18
Supernatant	1.98E+03	1.77E+03	6.09E+03	4.81E+04	2.61E+04	5.13E+02	2.13E-01	6.24E-04	1.12E-04	4.66E-04	1.80E-05	1.41E+01	1.05	1.05	43	93%	93%	20	18
Solid Layer	1.70E+04	1.52E+04	5.21E+04	4.12E+05	2.23E+05	4.40E+03	7.86E+00	4.73E-03	1.81E-03	1.52E-02	1.45E-04	4.90E+01	1.67	1.44	807	42%	53%	22	18
241-BX-111	1.70E+04	1.70E+03	1.06E+05	1.85E+05	2.26E+05	4.87E+04	1.15E+01	3.43E-03	1.64E-03	1.45E-02	1.17E-04	6.47E+01	1.45	1.45	751	26%	51%	19	19
Supernatant	1.70E+04	1.70E+03	1.06E+05	1.85E+05	2.26E+05	4.87E+04	1.15E+01	3.43E-03	1.64E-03	1.45E-02	1.17E-04	6.47E+01	1.45	1.45	38	51%	51%	19	19
Solid Layer	1.70E+04	1.70E+03	1.06E+05	1.85E+05	2.26E+05	4.87E+04	1.15E+01	3.43E-03	1.64E-03	1.45E-02	1.17E-04	6.47E+01	1.45	1.45	713	25%	51%	19	19

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (ug/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-BX-112	1.61E+04	0.00E+00	3.33E+04	9.31E+04	7.35E+04	4.52E+01	5.52E+00	2.29E-02	1.50E-02	1.37E-01	9.70E-04	3.85E+01	1.29	1.17	660	65%	69%	21	19
Supernatant	1.98E+03	0.00E+00	4.11E+03	1.15E+04	9.08E+03	5.58E+00	8.39E-02	1.84E-05	2.58E-05	1.82E-04	1.81E-06	9.85E-02	1.02	1.02	43	96%	96%	19	19
Solid Layer	1.70E+04	0.00E+00	3.52E+04	9.86E+04	7.78E+04	4.78E+01	5.81E+00	2.41E-02	1.58E-02	1.45E-01	1.02E-03	4.06E+01	1.31	1.18	617	63%	68%	21	19
241-BY-101	3.83E+04	1.82E+04	1.17E+05	2.17E+05	2.56E+05	4.73E+04	5.71E+01	9.97E-03	1.24E-03	1.08E-02	9.44E-05	9.05E+01	1.83	1.51	1438	23%	46%	24	24
Supernatant	3.83E+04	1.82E+04	1.17E+05	2.17E+05	2.56E+05	4.73E+04	5.71E+01	9.97E-03	1.24E-03	1.08E-02	9.44E-05	9.05E+01	1.51	1.51	38	46%	46%	24	24
Solid Layer	3.83E+04	1.82E+04	1.17E+05	2.17E+05	2.56E+05	4.73E+04	5.71E+01	9.97E-03	1.24E-03	1.08E-02	9.44E-05	9.05E+01	1.84	1.51	1400	22%	46%	24	24
241-BY-102	3.83E+04	1.55E+03	8.41E+04	1.48E+05	2.34E+05	5.66E+04	1.05E+01	5.05E-02	5.15E-03	2.16E-02	8.32E-04	6.65E+01	1.57	1.46	1092	32%	51%	22	22
Supernatant	3.83E+04	1.55E+03	8.41E+04	1.48E+05	2.34E+05	5.66E+04	1.05E+01	5.05E-02	5.15E-03	2.16E-02	8.32E-04	6.65E+01	1.46	1.46	38	51%	51%	22	22
Solid Layer	3.83E+04	1.55E+03	8.41E+04	1.48E+05	2.34E+05	5.66E+04	1.05E+01	5.05E-02	5.15E-03	2.16E-02	8.32E-04	6.65E+01	1.57	1.46	1054	31%	51%	22	22
241-BY-103	3.15E+04	1.59E+03	4.49E+04	1.41E+05	1.80E+05	3.46E+04	1.13E+01	1.16E-02	1.34E-03	5.61E-03	2.05E-04	6.69E+01	1.65	1.29	1602	28%	59%	25	21
Supernatant	3.15E+04	1.59E+03	4.49E+04	1.41E+05	1.80E+05	3.46E+04	1.13E+01	1.16E-02	1.34E-03	5.61E-03	2.05E-04	6.69E+01	1.29	1.29	38	59%	59%	23	21
Solid Layer	3.15E+04	1.59E+03	4.49E+04	1.41E+05	1.80E+05	3.46E+04	1.13E+01	1.16E-02	1.34E-03	5.61E-03	2.05E-04	6.69E+01	1.66	1.29	1564	28%	59%	25	21
241-BY-104	3.83E+04	2.37E+03	1.11E+05	2.07E+05	2.48E+05	7.19E+04	1.38E+02	5.52E-02	5.83E-03	2.94E-02	8.46E-04	8.65E+01	1.71	1.51	1571	26%	49%	41	26
Supernatant	3.83E+04	2.37E+03	1.11E+05	2.07E+05	2.48E+05	7.19E+04	1.38E+02	5.52E-02	5.83E-03	2.94E-02	8.46E-04	8.65E+01	1.51	1.51	38	49%	49%	34	26
Solid Layer	3.83E+04	2.37E+03	1.11E+05	2.07E+05	2.48E+05	7.19E+04	1.38E+02	5.52E-02	5.83E-03	2.94E-02	8.46E-04	8.65E+01	1.71	1.51	1533	26%	49%	41	26
241-BY-105	3.82E+04	2.43E+03	6.86E+04	1.99E+05	2.08E+05	3.92E+04	4.26E+01	3.61E-02	3.91E-03	2.38E-02	4.88E-04	4.65E+01	1.79	1.44	1859	18%	51%	31	22
Supernatant	3.82E+04	2.43E+03	6.86E+04	1.99E+05	2.08E+05	3.92E+04	4.26E+01	3.61E-02	3.91E-03	2.38E-02	4.88E-04	4.65E+01	1.44	1.44	38	51%	51%	27	22
Solid Layer	3.82E+04	2.43E+03	6.86E+04	1.99E+05	2.08E+05	3.92E+04	4.26E+01	3.61E-02	3.91E-03	2.38E-02	4.88E-04	4.65E+01	1.80	1.44	1821	18%	51%	31	22
241-BY-106	3.57E+04	2.67E+03	7.83E+04	1.10E+05	1.64E+05	3.98E+04	5.09E+01	1.44E-02	1.20E-03	8.72E-03	1.23E-04	1.12E+02	1.64	1.31	1661	27%	59%	37	37
Supernatant	3.57E+04	2.67E+03	7.83E+04	1.10E+05	1.64E+05	3.98E+04	5.09E+01	1.44E-02	1.20E-03	8.72E-03	1.23E-04	1.12E+02	1.31	1.31	38	59%	59%	37	37
Solid Layer	3.57E+04	2.67E+03	7.83E+04	1.10E+05	1.64E+05	3.98E+04	5.09E+01	1.44E-02	1.20E-03	8.72E-03	1.23E-04	1.12E+02	1.65	1.31	1623	27%	59%	37	37
241-BY-107	3.83E+04	2.40E+03	1.17E+05	1.31E+05	2.43E+05	5.12E+04	4.29E+01	1.18E-02	1.33E-03	8.10E-03	1.66E-04	1.15E+02	1.68	1.46	1066	38%	49%	36	28
Supernatant	3.83E+04	2.40E+03	1.17E+05	1.31E+05	2.43E+05	5.12E+04	4.29E+01	1.18E-02	1.33E-03	8.10E-03	1.66E-04	1.15E+02	1.46	1.46	38	49%	49%	32	28
Solid Layer	3.83E+04	2.40E+03	1.17E+05	1.31E+05	2.43E+05	5.12E+04	4.29E+01	1.18E-02	1.33E-03	8.10E-03	1.66E-04	1.15E+02	1.69	1.46	1028	38%	49%	36	28
241-BY-108	3.83E+04	2.37E+03	7.85E+04	2.94E+05	2.82E+05	3.63E+04	1.03E+02	3.05E-02	3.43E-03	2.26E-02	3.96E-04	4.21E+01	1.48	1.33	879	28%	33%	40	31
Supernatant	3.83E+04	2.37E+03	7.85E+04	2.94E+05	2.82E+05	3.63E+04	1.03E+02	3.05E-02	3.43E-03	2.26E-02	3.96E-04	4.21E+01	1.33	1.33	38	33%	33%	36	31
Solid Layer	3.83E+04	2.37E+03	7.85E+04	2.94E+05	2.82E+05	3.63E+04	1.03E+02	3.05E-02	3.43E-03	2.26E-02	3.96E-04	4.21E+01	1.48	1.33	841	27%	33%	40	31
241-BY-109	3.83E+04	1.88E+03	8.29E+04	1.90E+05	2.10E+05	3.88E+04	7.75E+00	3.69E-02	4.35E-03	1.82E-02	6.67E-04	4.98E+01	1.70	1.50	1124	42%	53%	18	17
Supernatant	3.83E+04	1.88E+03	8.29E+04	1.90E+05	2.10E+05	3.88E+04	7.75E+00	3.69E-02	4.35E-03	1.82E-02	6.67E-04	4.98E+01	1.50	1.50	38	53%	53%	18	17
Solid Layer	3.83E+04	1.88E+03	8.29E+04	1.90E+05	2.10E+05	3.88E+04	7.75E+00	3.69E-02	4.35E-03	1.82E-02	6.67E-04	4.98E+01	1.71	1.50	1086	42%	53%	18	17
241-BY-110	3.83E+04	1.94E+04	1.24E+05	1.24E+05	2.54E+05	6.58E+04	7.28E+01	2.76E-02	3.82E-03	2.22E-02	4.97E-04	8.75E+01	1.56	1.44	1422	29%	40%	37	24
Supernatant	3.83E+04	1.94E+04	1.24E+05	1.24E+05	2.54E+05	6.58E+04	7.28E+01	2.76E-02	3.82E-03	2.22E-02	4.97E-04	8.75E+01	1.44	1.44	38	40%	40%	31	24
Solid Layer	3.83E+04	1.94E+04	1.24E+05	1.24E+05	2.54E+05	6.58E+04	7.28E+01	2.76E-02	3.82E-03	2.22E-02	4.97E-04	8.75E+01	1.57	1.44	1384	28%	40%	37	24
241-BY-111	3.83E+04	1.28E+03	5.46E+04	2.01E+05	2.17E+05	4.30E+04	1.02E+01	6.14E-02	6.28E-03	2.63E-02	1.01E-03	5.96E+01	1.67	1.42	1561	36%	54%	30	25
Supernatant	3.83E+04	1.28E+03	5.46E+04	2.01E+05	2.17E+05	4.30E+04	1.02E+01	6.14E-02	6.28E-03	2.63E-02	1.01E-03	5.96E+01	1.42	1.42	38	54%	54%	28	25
Solid Layer	3.83E+04	1.28E+03	5.46E+04	2.01E+05	2.17E+05	4.30E+04	1.02E+01	6.14E-02	6.28E-03	2.63E-02	1.01E-03	5.96E+01	1.67	1.42	1523	35%	54%	30	25
241-BY-112	3.83E+04	1.72E+03	1.41E+05	1.90E+05	2.44E+05	5.54E+04	1.18E+01	4.31E-02	4.40E-03	1.84E-02	7.09E-04	6.33E+01	1.73	1.47	1121	30%	49%	32	25
Supernatant	3.83E+04	1.72E+03	1.41E+05	1.90E+05	2.44E+05	5.54E+04	1.18E+01	4.31E-02	4.40E-03	1.84E-02	7.09E-04	6.33E+01	1.47	1.47	38	49%	49%	29	25
Solid Layer	3.83E+04	1.72E+03	1.41E+05	1.90E+05	2.44E+05	5.54E+04	1.18E+01	4.31E-02	4.40E-03	1.84E-02	7.09E-04	6.33E+01	1.74	1.47	1083	30%	49%	32	25

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (µg/mL)	TOC in liquid [TOC] (µg/mL)	NO ₂ in liquid [NO ₂] (µg/mL)	NO ₃ in liquid [NO ₃] (µg/mL)	Na in liquid [Na] (µg/mL)	Al in liquid [Al] (µg/mL)	⁹⁰ Sr in waste [Sr] (µCi/g)	²⁴¹ Am in waste [Am241] (µCi/g)	²⁴⁰ Pu in waste [Pu240] (µCi/g)	²³⁹ Pu in waste [Pu240] (µCi/g)	²³⁸ Pu in waste [Pu238] (µCi/g)	¹³⁷ Cs in waste [Cs] (µCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-C-101	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	6.42E+01	1.43E-01	1.40E-01	7.86E-01	1.11E-02	5.06E+01	1.72	1.17	371	27%	74%	32	32
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	6.42E+01	1.43E-01	1.40E-01	7.86E-01	1.11E-02	5.06E+01	1.17	1.17	38	74%	74%	32	32
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	6.42E+01	1.43E-01	1.40E-01	7.86E-01	1.11E-02	5.06E+01	1.78	1.17	333	23%	74%	32	32
241-C-102	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.39E+01	5.08E-01	4.05E-01	1.69E+00	4.38E-02	1.29E+01	1.67	1.17	1234	44%	75%	28	26
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.39E+01	5.08E-01	4.05E-01	1.69E+00	4.38E-02	1.29E+01	1.17	1.17	38	75%	75%	27	26
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.39E+01	5.08E-01	4.05E-01	1.69E+00	4.38E-02	1.29E+01	1.68	1.17	1196	43%	75%	28	26
241-C-103	4.90E+02	2.76E-02	2.01E+00	2.67E+00	6.56E+00	6.28E-02	1.89E+02	9.36E-02	1.97E-02	9.47E-02	2.81E-02	1.67E+01	1.11	1.00	47	76%	99%	43	25
Supernatant	2.41E-03	1.27E-02	9.23E-01	1.23E+00	3.02E+00	2.89E-02	1.72E-03	1.19E-07	3.77E-08	2.42E-07	6.81E-08	2.53E-03	1.00	1.00	39	100%	100%	43	25
Solid Layer	1.70E+04	5.30E-01	3.85E+01	5.13E+01	1.26E+02	1.20E+00	7.16E+02	3.54E-01	7.48E-02	3.59E-01	1.06E-01	6.31E+01	1.61	1.11	9	9%	98%	43	25
241-C-104	1.70E+04	5.60E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.71E+02	3.85E+00	8.10E-01	3.14E+00	1.39E-01	5.38E+01	1.66	1.17	1018	49%	81%	36	34
Supernatant	1.70E+04	5.60E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.71E+02	3.85E+00	8.10E-01	3.14E+00	1.39E-01	5.38E+01	1.17	1.17	38	81%	81%	35	34
Solid Layer	1.70E+04	5.60E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.71E+02	3.85E+00	8.10E-01	3.14E+00	1.39E-01	5.38E+01	1.68	1.17	980	48%	81%	36	34
241-C-105	1.70E+04	2.87E+03	3.70E+04	3.43E+04	1.14E+05	9.02E+00	5.69E+02	1.54E+00	5.03E-01	2.56E+00	4.11E-02	9.85E+01	1.53	1.23	538	30%	67%	46	41
Supernatant	1.70E+04	2.87E+03	3.70E+04	3.43E+04	1.14E+05	9.02E+00	5.69E+02	1.54E+00	5.03E-01	2.56E+00	4.11E-02	9.85E+01	1.23	1.23	38	67%	67%	44	41
Solid Layer	1.70E+04	2.87E+03	3.70E+04	3.43E+04	1.14E+05	9.02E+00	5.69E+02	1.54E+00	5.03E-01	2.56E+00	4.11E-02	9.85E+01	1.55	1.23	500	28%	67%	46	41
241-C-106	9.99E+02	4.73E+01	7.74E+00	8.58E+00	1.39E+03	1.33E+01	1.22E+03	1.21E+00	6.61E-02	3.09E-01	5.00E-02	2.68E+01	1.12	1.02	48	83%	99%	30	25
Supernatant	5.92E+01	2.80E+00	4.58E-01	5.08E-01	8.25E+01	7.91E-01	3.72E-04	3.54E-08	7.31E-09	3.43E-08	5.50E-09	3.67E-03	1.00	1.00	38.2	100%	100%	31.0	25.2
Solid Layer	7.02E+03	3.32E+02	5.43E+01	6.02E+01	9.78E+03	9.38E+01	4.17E+03	4.11E+00	2.25E-01	1.05E+00	1.70E-01	9.14E+01	1.56	1.14	10.2	42%	98%	29.6	25.2
241-C-107	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.44E+03	4.62E+00	2.44E-01	1.51E+00	3.05E-02	4.07E+01	1.54	1.17	973	48%	79%	42	40
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.44E+03	4.62E+00	2.44E-01	1.51E+00	3.05E-02	4.07E+01	1.17	1.17	37.9	79%	79%	41	40
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.44E+03	4.62E+00	2.44E-01	1.51E+00	3.05E-02	4.07E+01	1.55	1.17	935	48%	79%	42	40
241-C-108	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.16E+01	2.90E-02	9.17E-04	8.46E-03	5.93E-05	2.10E+02	1.39	1.17	133	47%	75%	25	26
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.16E+01	2.90E-02	9.17E-04	8.46E-03	5.93E-05	2.10E+02	1.17	1.17	38	75%	75%	26	26
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.16E+01	2.90E-02	9.17E-04	8.46E-03	5.93E-05	2.10E+02	1.48	1.17	95	38%	75%	25	26
241-C-109	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	6.80E+02	1.35E-01	3.02E-02	1.76E-01	4.44E-03	4.65E+02	1.50	1.17	278	43%	75%	25	25
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	6.80E+02	1.35E-01	3.02E-02	1.76E-01	4.44E-03	4.65E+02	1.17	1.17	38	75%	75%	25	25
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	6.80E+02	1.35E-01	3.02E-02	1.76E-01	4.44E-03	4.65E+02	1.55	1.17	240	39%	75%	25	25
241-C-110	1.57E+04	5.36E+02	4.25E+03	5.57E+04	2.82E+04	1.93E+02	3.67E+00	4.11E-02	7.50E-03	6.89E-02	4.85E-04	1.44E+01	1.32	1.09	712	62%	84%	20	22
Supernatant	1.62E+03	5.54E+01	4.40E+02	5.76E+03	2.91E+03	1.99E+01	2.00E-03	1.79E-06	1.05E-05	1.56E-04	5.28E-07	3.55E-01	1.01	1.01	42	98%	98%	21	22
Solid Layer	1.70E+04	5.80E+02	4.60E+03	6.03E+04	3.05E+04	2.09E+02	3.84E+00	4.30E-02	7.85E-03	7.22E-02	5.08E-04	1.50E+01	1.34	1.10	670	60%	83%	20	22
241-C-111	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.70E+03	5.67E-01	9.85E-02	5.06E-01	9.30E-03	5.89E+01	1.49	1.17	255	41%	75%	23	24
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.70E+03	5.67E-01	9.85E-02	5.06E-01	9.30E-03	5.89E+01	1.17	1.17	38	75%	75%	24	24
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.70E+03	5.67E-01	9.85E-02	5.06E-01	9.30E-03	5.89E+01	1.55	1.17	217	36%	75%	23	24
241-C-112	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	8.31E+02	6.53E-01	1.62E-02	1.27E-01	1.09E-02	3.69E+02	1.54	1.17	431	53%	75%	27	27
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	8.31E+02	6.53E-01	1.62E-02	1.27E-01	1.09E-02	3.69E+02	1.17	1.17	38	75%	75%	27	27
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	8.31E+02	6.53E-01	1.62E-02	1.27E-01	1.09E-02	3.69E+02	1.58	1.17	393	52%	75%	27	27
241-C-201	9.72E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.33E+01	5.11E-01	7.18E-01	3.34E+00	1.06E-01	2.13E+00	1.09	1.00	4	85%	100%	16	20
Supernatant	3.14E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.00	1.00	4	100%	100%	16	20
Solid Layer	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.68E+02	2.58E+00	3.62E+00	1.68E+01	5.33E-01	1.07E+01	1.75	1.00	1	24%	100%	16	20

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (µg/mL)	TOC in liquid [TOC] (µg/mL)	NO ₂ in liquid [NO ₂] (µg/mL)	NO ₃ in liquid [NO ₃] (µg/mL)	Na in liquid [Na] (µg/mL)	Al in liquid [Al] (µg/mL)	⁹⁰ Sr in waste [Sr] (µCi/g)	²⁴¹ Am in waste [Am241] (µCi/g)	²⁴⁰ Pu in waste [Pu240] (µCi/g)	²³⁹ Pu in waste [Pu240] (µCi/g)	²³⁸ Pu in waste [Pu238] (µCi/g)	¹³⁷ Cs in waste [Cs] (µCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-C-202	9.91E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.02E+02	2.42E-01	6.48E-01	3.01E+00	9.55E-02	1.88E+00	1.09	1.00	4	85%	100%	16	19
Supernatant	4.04E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.00	1.00	4	100%	100%	16	19
Solid Layer	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	5.08E+02	1.20E+00	3.21E+00	1.49E+01	4.73E-01	9.31E+00	1.75	1.00	1	24%	100%	16	19
241-C-203	1.35E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	4.97E-01	6.12E-03	2.21E-02	1.02E-01	3.26E-03	2.76E+00	1.10	1.00	4.3	88%	100%	15	19
Supernatant	2.15E+01	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.00	1.00	3.83	100%	100%	19	19
Solid Layer	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	2.57E+00	3.17E-02	1.14E-01	5.29E-01	1.69E-02	1.43E+01	1.93	1.00	0.48	36%	100%	15	19
241-C-204	1.22E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	3.24E+01	6.75E-04	4.52E-04	2.10E-03	6.67E-05	1.27E+00	1.09	1.01	4	88%	100%	17	16
Supernatant	4.94E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.00	1.00	4	100%	100%	17	16
Solid Layer	1.70E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.69E+02	3.53E-03	2.36E-03	1.10E-02	3.49E-04	6.64E+00	1.77	1.17	1	38%	100%	17	16
241-S-101	4.76E+04	1.79E+03	1.13E+05	2.14E+05	2.22E+05	2.99E+04	2.06E+02	1.00E-01	2.87E-02	1.46E-01	3.05E-03	1.12E+02	1.65	1.47	1370	39%	51%	39	31
Supernatant	4.76E+04	1.79E+03	1.13E+05	2.14E+05	2.22E+05	2.99E+04	2.06E+02	1.00E-01	2.87E-02	1.46E-01	3.05E-03	1.12E+02	1.47	1.47	38	51%	51%	35	31
Solid Layer	4.76E+04	1.79E+03	1.13E+05	2.14E+05	2.22E+05	2.99E+04	2.06E+02	1.00E-01	2.87E-02	1.46E-01	3.05E-03	1.12E+02	1.65	1.47	1332	39%	51%	39	31
241-S-102	3.76E+04	3.76E+03	1.27E+05	1.55E+05	2.34E+05	5.62E+04	2.51E+02	6.26E-02	1.20E-02	5.90E-02	1.47E-03	7.84E+01	1.72	1.46	164	32%	49%	28	25
Supernatant	3.76E+04	3.76E+03	1.27E+05	1.55E+05	2.34E+05	5.62E+04	2.51E+02	6.26E-02	1.20E-02	5.90E-02	1.47E-03	7.84E+01	1.46	1.46	38	49%	49%	27	25
Solid Layer	3.76E+04	3.76E+03	1.27E+05	1.55E+05	2.34E+05	5.62E+04	2.51E+02	6.26E-02	1.20E-02	5.90E-02	1.47E-03	7.84E+01	1.80	1.46	126	28%	49%	28	25
241-S-103	3.46E+04	4.44E+03	1.40E+05	2.05E+05	2.16E+05	3.04E+04	2.80E+01	9.12E-02	1.32E-02	6.34E-02	1.89E-03	1.32E+02	1.59	1.43	934	37%	51%	25	25
Supernatant	3.49E+03	4.47E+02	1.40E+04	2.06E+04	2.18E+04	3.06E+03	3.39E-02	1.08E-04	1.12E-06	5.25E-06	1.83E-07	2.96E+01	1.04	1.04	42	93%	93%	25	25
Solid Layer	3.64E+04	4.68E+03	1.47E+05	2.16E+05	2.28E+05	3.20E+04	2.88E+01	9.40E-02	1.36E-02	6.54E-02	1.95E-03	1.35E+02	1.61	1.45	892	36%	50%	25	25
241-S-104	5.10E+03	3.96E+02	3.82E+04	2.68E+05	1.98E+05	1.19E+04	2.14E+02	1.07E-01	3.83E-02	1.88E-01	5.38E-03	4.27E+01	1.66	1.37	1128	39%	55%	39	31
Supernatant	5.10E+03	3.96E+02	3.82E+04	2.68E+05	1.98E+05	1.19E+04	2.14E+02	1.07E-01	3.83E-02	1.88E-01	5.38E-03	4.27E+01	1.37	1.37	38	55%	55%	35	31
Solid Layer	5.10E+03	3.96E+02	3.82E+04	2.68E+05	1.98E+05	1.19E+04	2.14E+02	1.07E-01	3.83E-02	1.88E-01	5.38E-03	4.27E+01	1.67	1.37	1090	39%	55%	39	31
241-S-105	8.18E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	2.56E+00	3.05E-03	7.25E-04	3.63E-03	8.19E-05	3.42E+01	1.65	1.45	1574	9%	49%	26	22
Supernatant	8.18E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	2.56E+00	3.05E-03	7.25E-04	3.63E-03	8.19E-05	3.42E+01	1.45	1.45	38	49%	49%	24	22
Solid Layer	8.18E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	2.56E+00	3.05E-03	7.25E-04	3.63E-03	8.19E-05	3.42E+01	1.66	1.45	1536	8%	49%	26	22
241-S-106	5.55E+04	1.98E+03	1.04E+05	2.36E+05	2.44E+05	3.80E+04	1.23E+01	1.96E-02	1.32E-03	6.04E-03	2.13E-04	9.13E+01	1.72	1.43	1761	35%	54%	23	23
Supernatant	5.55E+04	1.98E+03	1.04E+05	2.36E+05	2.44E+05	3.80E+04	1.23E+01	1.96E-02	1.32E-03	6.04E-03	2.13E-04	9.13E+01	1.43	1.43	38	54%	54%	23	23
Solid Layer	5.55E+04	1.98E+03	1.04E+05	2.36E+05	2.44E+05	3.80E+04	1.23E+01	1.96E-02	1.32E-03	6.04E-03	2.13E-04	9.13E+01	1.72	1.43	1723	34%	54%	23	23
241-S-107	2.99E+04	1.18E+03	7.11E+04	1.14E+05	1.56E+05	1.07E+04	1.30E+02	3.10E-01	1.06E-01	5.04E-01	1.22E-02	6.77E+01	1.76	1.31	1394	35%	64%	33	28
Supernatant	2.99E+04	1.18E+03	7.11E+04	1.14E+05	1.56E+05	1.07E+04	1.30E+02	3.10E-01	1.06E-01	5.04E-01	1.22E-02	6.77E+01	1.31	1.31	38	64%	64%	30	28
Solid Layer	2.99E+04	1.18E+03	7.11E+04	1.14E+05	1.56E+05	1.07E+04	1.30E+02	3.10E-01	1.06E-01	5.04E-01	1.22E-02	6.77E+01	1.78	1.31	1356	34%	64%	33	28
241-S-108	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.77E+04	2.10E+01	7.72E-02	5.96E-03	2.79E-02	9.05E-04	9.60E+01	1.67	1.45	2120	31%	49%	27	22
Supernatant	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.77E+04	2.10E+01	7.72E-02	5.96E-03	2.79E-02	9.05E-04	9.60E+01	1.45	1.45	38	49%	49%	25	22
Solid Layer	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.77E+04	2.10E+01	7.72E-02	5.96E-03	2.79E-02	9.05E-04	9.60E+01	1.68	1.45	2082	30%	49%	27	22
241-S-109	8.19E+04	1.11E+03	8.49E+04	1.32E+05	2.19E+05	4.59E+04	1.48E+01	1.15E-02	2.83E-03	1.44E-02	2.92E-04	1.30E+01	1.65	1.49	2055	11%	53%	26	22
Supernatant	8.19E+04	1.11E+03	8.49E+04	1.32E+05	2.19E+05	4.59E+04	1.48E+01	1.15E-02	2.83E-03	1.44E-02	2.92E-04	1.30E+01	1.49	1.49	38	53%	53%	24	22
Solid Layer	8.19E+04	1.11E+03	8.49E+04	1.32E+05	2.19E+05	4.59E+04	1.48E+01	1.15E-02	2.83E-03	1.44E-02	2.92E-04	1.30E+01	1.66	1.49	2017	11%	53%	26	22
241-S-110	8.18E+04	2.28E+03	8.58E+04	2.17E+05	2.11E+05	3.10E+04	9.40E+01	1.23E-01	2.50E-02	1.26E-01	2.63E-03	7.27E+01	1.66	1.43	1511	21%	49%	42	30
Supernatant	8.18E+04	2.28E+03	8.58E+04	2.17E+05	2.11E+05	3.10E+04	9.40E+01	1.23E-01	2.50E-02	1.26E-01	2.63E-03	7.27E+01	1.43	1.43	38	49%	49%	36	30
Solid Layer	8.18E+04	2.28E+03	8.58E+04	2.17E+05	2.11E+05	3.10E+04	9.40E+01	1.23E-01	2.50E-02	1.26E-01	2.63E-03	7.27E+01	1.66	1.43	1473	20%	49%	42	30

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (µg/mL)	TOC in liquid [TOC] (µg/mL)	NO ₂ in liquid [NO ₂] (µg/mL)	NO ₃ in liquid [NO ₃] (µg/mL)	Na in liquid [Na] (µg/mL)	Al in liquid [Al] (µg/mL)	⁹⁰ Sr in waste [Sr] (µCi/g)	²⁴¹ Am in waste [Am241] (µCi/g)	²⁴⁰ Pu in waste [Pu240] (µCi/g)	²³⁹ Pu in waste [Pu240] (µCi/g)	²³⁸ Pu in waste [Pu238] (µCi/g)	¹³⁷ Cs in waste [Cs] (µCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-S-111	5.10E+04	1.49E+03	8.39E+04	1.93E+05	2.23E+05	3.64E+04	1.83E+02	1.48E-02	1.44E-03	6.90E-03	1.96E-04	1.03E+02	1.54	1.45	1435	30%	51%	28	24
Supernatant	5.10E+04	1.49E+03	8.39E+04	1.93E+05	2.23E+05	3.64E+04	1.83E+02	1.48E-02	1.44E-03	6.90E-03	1.96E-04	1.03E+02	1.45	1.45	38	51%	51%	26	24
Solid Layer	5.10E+04	1.49E+03	8.39E+04	1.93E+05	2.23E+05	3.64E+04	1.83E+02	1.48E-02	1.44E-03	6.90E-03	1.96E-04	1.03E+02	1.55	1.45	1397	29%	51%	28	24
241-S-112	8.07E+03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.74E+02	1.45E-01	1.57E-02	8.83E-02	2.00E-03	4.66E+00	1.13	1.07	47	82%	87%	29	21
Supernatant	5.95E+02	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.00	1.00	38	100%	100%	29	21
Solid Layer	4.86E+04	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00	6.30E+02	5.24E-01	5.66E-02	3.19E-01	7.21E-03	1.68E+01	1.71	1.45	9	36%	52%	29	21
241-SX-101	4.88E+04	3.35E+02	7.49E+04	1.08E+05	2.42E+05	8.00E+04	1.13E+02	1.91E-01	3.39E-02	1.66E-01	4.59E-03	1.00E+02	1.67	1.48	1622	27%	49%	47	36
Supernatant	4.88E+04	3.35E+02	7.49E+04	1.08E+05	2.42E+05	8.00E+04	1.13E+02	1.91E-01	3.39E-02	1.66E-01	4.59E-03	1.00E+02	1.48	1.48	38	49%	49%	41	36
Solid Layer	4.88E+04	3.35E+02	7.49E+04	1.08E+05	2.42E+05	8.00E+04	1.13E+02	1.91E-01	3.39E-02	1.66E-01	4.59E-03	1.00E+02	1.68	1.48	1584	27%	49%	47	36
241-SX-102	5.01E+04	1.51E+03	1.51E+05	1.57E+05	2.35E+05	4.56E+04	8.21E+01	1.22E-01	1.21E-02	5.77E-02	1.69E-03	1.40E+02	1.69	1.46	1330	39%	48%	51	31
Supernatant	5.01E+04	1.51E+03	1.51E+05	1.57E+05	2.35E+05	4.56E+04	8.21E+01	1.22E-01	1.21E-02	5.77E-02	1.69E-03	1.40E+02	1.46	1.46	38	48%	48%	41	31
Solid Layer	5.01E+04	1.51E+03	1.51E+05	1.57E+05	2.35E+05	4.56E+04	8.21E+01	1.22E-01	1.21E-02	5.77E-02	1.69E-03	1.40E+02	1.70	1.46	1292	39%	48%	51	31
241-SX-103	4.52E+04	3.38E+03	1.57E+05	1.56E+05	2.40E+05	4.44E+04	1.54E+02	2.16E-01	1.56E-02	7.61E-02	2.05E-03	1.23E+02	1.72	1.47	1964	31%	47%	59	27
Supernatant	4.52E+04	3.38E+03	1.57E+05	1.56E+05	2.40E+05	4.44E+04	1.54E+02	2.16E-01	1.56E-02	7.61E-02	2.05E-03	1.23E+02	1.47	1.47	38	47%	47%	43	27
Solid Layer	4.52E+04	3.38E+03	1.57E+05	1.56E+05	2.40E+05	4.44E+04	1.54E+02	2.16E-01	1.56E-02	7.61E-02	2.05E-03	1.23E+02	1.73	1.47	1926	30%	47%	59	27
241-SX-104	3.05E+04	2.13E+03	1.17E+05	2.90E+05	2.50E+05	3.56E+04	1.42E+02	1.26E-01	3.42E-02	1.74E-01	3.52E-03	8.70E+01	1.69	1.47	1726	29%	45%	49	60
Supernatant	3.05E+04	2.13E+03	1.17E+05	2.90E+05	2.50E+05	3.56E+04	1.42E+02	1.26E-01	3.42E-02	1.74E-01	3.52E-03	8.70E+01	1.47	1.47	38	45%	45%	55	60
Solid Layer	3.05E+04	2.13E+03	1.17E+05	2.90E+05	2.50E+05	3.56E+04	1.42E+02	1.26E-01	3.42E-02	1.74E-01	3.52E-03	8.70E+01	1.69	1.47	1688	28%	45%	49	60
241-SX-105	4.10E+04	3.26E+03	1.43E+05	1.64E+05	2.36E+05	4.41E+04	2.52E+02	2.57E-01	5.74E-02	2.89E-01	6.66E-03	9.47E+01	1.63	1.47	1460	35%	43%	61	36
Supernatant	4.10E+04	3.26E+03	1.43E+05	1.64E+05	2.36E+05	4.41E+04	2.52E+02	2.57E-01	5.74E-02	2.89E-01	6.66E-03	9.47E+01	1.47	1.47	38	43%	43%	49	36
Solid Layer	4.10E+04	3.26E+03	1.43E+05	1.64E+05	2.36E+05	4.41E+04	2.52E+02	2.57E-01	5.74E-02	2.89E-01	6.66E-03	9.47E+01	1.63	1.47	1422	35%	43%	61	36
241-SX-106	3.20E+04	3.14E+03	1.49E+05	2.45E+05	2.17E+05	2.26E+04	1.21E+01	1.47E-01	1.86E-02	8.68E-02	3.03E-03	1.31E+02	1.57	1.29	1539	40%	49%	32	26
Supernatant	3.20E+04	3.14E+03	1.49E+05	2.45E+05	2.17E+05	2.26E+04	1.21E+01	1.47E-01	1.86E-02	8.68E-02	3.03E-03	1.31E+02	1.29	1.29	38	49%	49%	29	26
Solid Layer	3.20E+04	3.14E+03	1.49E+05	2.45E+05	2.17E+05	2.26E+04	1.21E+01	1.47E-01	1.86E-02	8.68E-02	3.03E-03	1.31E+02	1.58	1.29	1501	40%	49%	32	26
241-SX-107	6.07E+04	1.01E+03	9.86E+04	2.17E+05	2.55E+05	4.72E+04	2.00E+03	8.87E-01	1.08E-01	5.19E-01	1.87E-02	8.20E+01	1.74	1.50	394	25%	52%	70	53
Supernatant	6.07E+04	1.01E+03	9.86E+04	2.17E+05	2.55E+05	4.72E+04	2.00E+03	8.87E-01	1.08E-01	5.19E-01	1.87E-02	8.20E+01	1.50	1.50	38	52%	52%	62	53
Solid Layer	6.07E+04	1.01E+03	9.86E+04	2.17E+05	2.55E+05	4.72E+04	2.00E+03	8.87E-01	1.08E-01	5.19E-01	1.87E-02	8.20E+01	1.77	1.50	356	23%	52%	70	53
241-SX-108	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.57E+03	1.46E+00	2.96E-01	1.49E+00	3.78E-02	1.65E+02	1.70	1.17	318	8%	75%	77	59
Supernatant	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.57E+03	1.46E+00	2.96E-01	1.49E+00	3.78E-02	1.65E+02	1.17	1.17	38	75%	75%	68	59
Solid Layer	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.57E+03	1.46E+00	2.96E-01	1.49E+00	3.78E-02	1.65E+02	1.77	1.17	280	2%	75%	77	59
241-SX-109	6.07E+04	9.20E+03	1.07E+05	1.76E+05	1.98E+05	2.75E+04	5.70E+02	2.92E-01	3.75E-02	1.79E-01	6.46E-03	7.91E+01	1.72	1.39	951	24%	51%	54	48
Supernatant	6.07E+04	9.20E+03	1.07E+05	1.76E+05	1.98E+05	2.75E+04	5.70E+02	2.92E-01	3.75E-02	1.79E-01	6.46E-03	7.91E+01	1.39	1.39	38	51%	51%	51	48
Solid Layer	6.07E+04	9.20E+03	1.07E+05	1.76E+05	1.98E+05	2.75E+04	5.70E+02	2.92E-01	3.75E-02	1.79E-01	6.46E-03	7.91E+01	1.73	1.39	913	23%	51%	54	48
241-SX-110	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.58E+03	1.91E+00	1.18E-01	5.04E-01	3.34E-02	1.15E+02	1.67	1.17	250	28%	75%	69	42
Supernatant	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.58E+03	1.91E+00	1.18E-01	5.04E-01	3.34E-02	1.15E+02	1.17	1.17	38	75%	75%	56	42
Solid Layer	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.58E+03	1.91E+00	1.18E-01	5.04E-01	3.34E-02	1.15E+02	1.76	1.17	212	23%	75%	69	42
241-SX-111	6.07E+04	1.01E+03	9.89E+04	2.17E+05	2.55E+05	4.71E+04	2.63E+03	1.14E+00	1.01E-01	4.64E-01	2.17E-02	9.25E+01	1.74	1.50	474	25%	52%	76	60
Supernatant	6.07E+04	1.01E+03	9.89E+04	2.17E+05	2.55E+05	4.71E+04	2.63E+03	1.14E+00	1.01E-01	4.64E-01	2.17E-02	9.25E+01	1.50	1.50	38	52%	52%	68	60
Solid Layer	6.07E+04	1.01E+03	9.89E+04	2.17E+05	2.55E+05	4.71E+04	2.63E+03	1.14E+00	1.01E-01	4.64E-01	2.17E-02	9.25E+01	1.76	1.50	436	23%	52%	76	60

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (ug/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-SX-112	6.07E+04	1.01E+03	9.88E+04	2.17E+05	2.55E+05	4.72E+04	2.78E+03	1.20E+00	1.15E-01	5.31E-01	2.34E-02	9.14E+01	1.74	1.50	321	26%	52%	61	52
Supernatant	6.07E+04	1.01E+03	9.88E+04	2.17E+05	2.55E+05	4.72E+04	2.78E+03	1.20E+00	1.15E-01	5.31E-01	2.34E-02	9.14E+01	1.50	1.50	38	52%	52%	57	52
Solid Layer	6.07E+04	1.01E+03	9.88E+04	2.17E+05	2.55E+05	4.72E+04	2.78E+03	1.20E+00	1.15E-01	5.31E-01	2.34E-02	9.14E+01	1.77	1.50	283	23%	52%	61	52
241-SX-113	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.75E+01	1.09E-01	9.47E-03	4.88E-02	9.06E-04	2.02E+01	1.34	1.17	110	55%	75%	28	28
Supernatant	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.75E+01	1.09E-01	9.47E-03	4.88E-02	9.06E-04	2.02E+01	1.17	1.17	38	75%	75%	28	28
Solid Layer	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.75E+01	1.09E-01	9.47E-03	4.88E-02	9.06E-04	2.02E+01	1.43	1.17	72	46%	75%	28	28
241-SX-114	6.07E+04	1.01E+03	9.88E+04	2.17E+05	2.51E+05	4.73E+04	1.84E+03	8.15E-01	9.20E-02	4.37E-01	1.67E-02	8.77E+01	1.74	1.50	626	25%	52%	73	52
Supernatant	6.07E+04	1.01E+03	9.88E+04	2.17E+05	2.51E+05	4.73E+04	1.84E+03	8.15E-01	9.20E-02	4.37E-01	1.67E-02	8.77E+01	1.50	1.50	38	52%	52%	63	52
Solid Layer	6.07E+04	1.01E+03	9.88E+04	2.17E+05	2.51E+05	4.73E+04	1.84E+03	8.15E-01	9.20E-02	4.37E-01	1.67E-02	8.77E+01	1.75	1.50	588	24%	52%	73	52
241-SX-115	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.35E+04	1.42E+01	3.78E+00	1.61E+01	1.07E+00	2.05E+01	1.35	1.17	54	50%	75%	25	25
Supernatant	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.35E+04	1.42E+01	3.78E+00	1.61E+01	1.07E+00	2.05E+01	1.17	1.17	38	75%	75%	25	25
Solid Layer	6.07E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.35E+04	1.42E+01	3.78E+00	1.61E+01	1.07E+00	2.05E+01	1.77	1.17	16	10%	75%	25	25
241-T-101	4.81E+04	4.04E+03	1.22E+05	1.89E+05	2.37E+05	3.77E+04	6.63E-01	1.15E-01	7.84E-02	3.58E-01	9.37E-03	6.76E+01	1.54	1.45	414	40%	49%	21	21
Supernatant	4.81E+04	4.04E+03	1.22E+05	1.89E+05	2.37E+05	3.77E+04	6.63E-01	1.15E-01	7.84E-02	3.58E-01	9.37E-03	6.76E+01	1.45	1.45	38	49%	49%	21	21
Solid Layer	4.81E+04	4.04E+03	1.22E+05	1.89E+05	2.37E+05	3.77E+04	6.63E-01	1.15E-01	7.84E-02	3.58E-01	9.37E-03	6.76E+01	1.54	1.45	376	39%	49%	21	21
241-T-102	4.40E+01	3.17E+02	1.61E+04	7.67E+04	4.55E+04	5.96E+03	7.51E+01	9.65E-02	4.27E-03	1.83E-02	4.46E-04	2.07E+01	1.41	1.10	158	54%	83%	18	18
Supernatant	3.49E+01	2.52E+02	1.28E+04	6.09E+04	3.61E+04	4.73E+03	5.06E-01	2.21E-03	6.14E-04	2.65E-03	1.11E-04	2.67E+01	1.08	1.08	86	88%	88%	18	18
Solid Layer	6.25E+01	4.50E+02	2.29E+04	1.09E+05	6.46E+04	8.46E+03	1.28E+02	1.64E-01	6.89E-03	2.95E-02	6.86E-04	1.64E+01	1.80	1.14	72	30%	80%	18	18
241-T-103	1.16E+04	3.78E+03	2.69E+04	5.31E+04	6.48E+04	7.07E+03	3.40E+00	3.12E-03	4.29E-03	1.84E-02	4.37E-04	1.95E+00	1.46	1.12	140	52%	77%	19	20
Supernatant	4.82E+03	1.58E+03	1.12E+04	2.21E+04	2.71E+04	2.95E+03	6.21E-01	2.75E-03	4.76E-04	2.05E-03	8.58E-05	3.77E+00	1.05	1.05	53	91%	91%	19	20
Solid Layer	1.70E+04	5.55E+03	3.96E+04	7.80E+04	9.53E+04	1.04E+04	4.43E+00	3.26E-03	5.72E-03	2.44E-02	5.68E-04	1.27E+00	1.71	1.18	87	37%	72%	19	20
241-T-104	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.03E+00	1.81E-02	1.51E-02	1.25E-01	1.62E-03	1.55E-01	1.29	1.17	1237	71%	84%	19	22
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.03E+00	1.81E-02	1.51E-02	1.25E-01	1.62E-03	1.55E-01	1.17	1.17	38	84%	84%	21	22
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.03E+00	1.81E-02	1.51E-02	1.25E-01	1.62E-03	1.55E-01	1.29	1.17	1199	71%	84%	19	22
241-T-105	1.70E+04	2.98E+03	5.42E+04	3.71E+04	8.84E+04	3.62E+02	5.19E+01	5.81E-02	2.93E-02	2.77E-01	2.08E-03	9.23E+00	1.43	1.18	409	55%	80%	17	16
Supernatant	1.70E+04	2.98E+03	5.42E+04	3.71E+04	8.84E+04	3.62E+02	5.19E+01	5.81E-02	2.93E-02	2.77E-01	2.08E-03	9.23E+00	1.18	1.18	38	80%	80%	16	16
Solid Layer	1.70E+04	2.98E+03	5.42E+04	3.71E+04	8.84E+04	3.62E+02	5.19E+01	5.81E-02	2.93E-02	2.77E-01	2.08E-03	9.23E+00	1.46	1.18	371	53%	80%	17	16
241-T-106	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	5.02E+00	4.27E-02	2.00E-02	1.34E-01	1.61E-03	1.53E+01	1.46	1.17	120	32%	75%	20	21
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	5.02E+00	4.27E-02	2.00E-02	1.34E-01	1.61E-03	1.53E+01	1.17	1.17	38	75%	75%	20	21
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	5.02E+00	4.27E-02	2.00E-02	1.34E-01	1.61E-03	1.53E+01	1.59	1.17	82	17%	75%	20	21
241-T-107	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.01E+02	5.89E-02	3.48E-02	3.04E-01	2.37E-03	1.47E+01	1.54	1.17	693	47%	84%	19	22
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.01E+02	5.89E-02	3.48E-02	3.04E-01	2.37E-03	1.47E+01	1.17	1.17	38	84%	84%	21	22
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.01E+02	5.89E-02	3.48E-02	3.04E-01	2.37E-03	1.47E+01	1.56	1.17	655	46%	84%	19	22
241-T-108	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.61E+02	1.77E+00	4.65E-03	6.74E-03	6.05E-02	4.41E-04	6.77E+00	1.44	1.26	98	46%	70%	16	22
Supernatant	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.61E+02	1.77E+00	4.65E-03	6.74E-03	6.05E-02	4.41E-04	6.77E+00	1.26	1.26	38	70%	70%	19	22
Solid Layer	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.61E+02	1.77E+00	4.65E-03	6.74E-03	6.05E-02	4.41E-04	6.77E+00	1.55	1.26	60	35%	70%	16	22
241-T-109	1.70E+04	3.37E+00	8.50E+03	2.17E+05	1.13E+05	3.61E+02	2.62E-01	2.10E-04	1.04E-03	9.12E-03	6.79E-05	2.13E+00	1.59	1.26	273	53%	70%	19	20
Supernatant	1.70E+04	3.37E+00	8.50E+03	2.17E+05	1.13E+05	3.61E+02	2.62E-01	2.10E-04	1.04E-03	9.12E-03	6.79E-05	2.13E+00	1.26	1.26	38	70%	70%	20	20
Solid Layer	1.70E+04	3.37E+00	8.50E+03	2.17E+05	1.13E+05	3.61E+02	2.62E-01	2.10E-04	1.04E-03	9.12E-03	6.79E-05	2.13E+00	1.65	1.26	235	51%	70%	19	20

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (µg/mL)	TOC in liquid [TOC] (µg/mL)	NO ₂ in liquid [NO ₂] (µg/mL)	NO ₃ in liquid [NO ₃] (µg/mL)	Na in liquid [Na] (µg/mL)	Al in liquid [Al] (µg/mL)	⁹⁰ Sr in waste [Sr] (µCi/g)	²⁴¹ Am in waste [Am241] (µCi/g)	²⁴⁰ Pu in waste [Pu240] (µCi/g)	²³⁹ Pu in waste [Pu240] (µCi/g)	²³⁸ Pu in waste [Pu238] (µCi/g)	¹³⁷ Cs in waste [Cs] (µCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-T-110	1.66E+04	4.39E+01	5.75E+01	1.78E+04	3.61E+04	0.00E+00	2.67E-02	4.83E-03	5.75E-03	5.48E-02	3.66E-04	1.45E-02	1.24	1.05	1438	76%	87%	17	20
Supernatant	1.25E+03	3.30E+00	4.33E+00	1.34E+03	2.72E+03	0.00E+00	3.29E-05	2.19E-07	7.66E-07	1.14E-05	1.46E-07	2.14E-04	1.00	1.00	41	99%	99%	19	20
Solid Layer	1.70E+04	4.50E+01	5.90E+01	1.83E+04	3.70E+04	0.00E+00	2.73E-02	4.94E-03	5.88E-03	5.61E-02	3.75E-04	1.49E-02	1.25	1.05	1397	76%	87%	17	20
241-T-111	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.08E+00	4.70E-02	1.44E-02	1.24E-01	6.19E-04	1.02E-01	1.24	1.17	1729	75%	75%	18	22
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.08E+00	4.70E-02	1.44E-02	1.24E-01	6.19E-04	1.02E-01	1.17	1.17	38	75%	75%	20	22
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.08E+00	4.70E-02	1.44E-02	1.24E-01	6.19E-04	1.02E-01	1.24	1.17	1691	75%	75%	18	22
241-T-112	1.48E+04	1.40E+03	3.38E+04	2.03E+04	4.98E+04	4.39E+00	5.05E-02	1.32E-02	1.97E-02	1.75E-01	1.31E-03	3.01E-01	1.23	1.09	290	78%	87%	19	20
Supernatant	6.92E+03	6.56E+02	1.58E+04	9.49E+03	2.33E+04	2.05E+00	2.62E-01	4.42E-03	7.67E-04	3.31E-03	1.38E-04	1.60E+00	1.04	1.04	64	94%	94%	19	20
Solid Layer	1.70E+04	1.61E+03	3.88E+04	2.33E+04	5.72E+04	5.04E+00	2.00E-03	1.52E-02	2.41E-02	2.14E-01	1.58E-03	3.85E-03	1.28	1.10	226	74%	85%	19	20
241-T-201	1.55E+04	7.51E+01	3.23E+02	4.45E+04	2.43E+04	0.00E+00	6.19E-02	3.65E-02	4.16E-02	6.17E-01	2.09E-03	2.03E-02	1.28	1.06	119	70%	91%	18	20
Supernatant	2.97E+03	5.28E+01	2.27E+02	3.13E+04	1.71E+04	0.00E+00	2.45E-05	3.85E-08	1.16E-06	1.72E-05	5.81E-08	2.81E-05	1.04	1.04	12	94%	94%	19	20
Solid Layer	1.70E+04	7.78E+01	3.35E+02	4.61E+04	2.51E+04	0.00E+00	6.73E-02	3.97E-02	4.52E-02	6.71E-01	2.27E-03	2.21E-02	1.31	1.06	107	68%	91%	17	20
241-T-202	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.23E-03	3.22E-02	2.11E-02	1.67E-01	1.45E-03	6.77E-03	1.18	1.17	81	76%	75%	18	20
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.23E-03	3.22E-02	2.11E-02	1.67E-01	1.45E-03	6.77E-03	1.17	1.17	4	75%	75%	19	20
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.23E-03	3.22E-02	2.11E-02	1.67E-01	1.45E-03	6.77E-03	1.18	1.17	77	76%	75%	18	20
241-T-203	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.21E-03	3.75E-02	2.81E-02	2.24E-01	1.93E-03	6.63E-03	1.22	1.17	140	76%	85%	17	20
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.21E-03	3.75E-02	2.81E-02	2.24E-01	1.93E-03	6.63E-03	1.17	1.17	4	85%	85%	18	20
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	2.21E-03	3.75E-02	2.81E-02	2.24E-01	1.93E-03	6.63E-03	1.22	1.17	136	76%	85%	17	20
241-T-204	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.03E-03	2.27E-02	2.39E-02	1.90E-01	1.64E-03	6.85E-03	1.18	1.17	140	75%	75%	17	20
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.03E-03	2.27E-02	2.39E-02	1.90E-01	1.64E-03	6.85E-03	1.17	1.17	4	75%	75%	19	20
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.03E-03	2.27E-02	2.39E-02	1.90E-01	1.64E-03	6.85E-03	1.18	1.17	136	75%	75%	17	20
241-TX-101	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	3.23E+02	4.20E-01	1.26E-01	5.90E-01	1.95E-02	6.70E+01	1.71	1.45	382	27%	49%	25	23
Supernatant	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	3.23E+02	4.20E-01	1.26E-01	5.90E-01	1.95E-02	6.70E+01	1.45	1.45	38	49%	49%	24	23
Solid Layer	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	3.23E+02	4.20E-01	1.26E-01	5.90E-01	1.95E-02	6.70E+01	1.74	1.45	344	25%	49%	25	23
241-TX-102	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.57E+00	1.45E-01	1.52E-02	7.23E-02	2.54E-03	8.75E+01	1.61	1.45	859	32%	49%	26	25
Supernatant	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.57E+00	1.45E-01	1.52E-02	7.23E-02	2.54E-03	8.75E+01	1.45	1.45	38	49%	49%	26	25
Solid Layer	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.57E+00	1.45E-01	1.52E-02	7.23E-02	2.54E-03	8.75E+01	1.61	1.45	821	31%	49%	26	25
241-TX-103	1.70E+04	3.88E+03	1.18E+05	1.91E+05	2.32E+05	3.65E+04	7.29E-01	1.43E-01	1.50E-02	7.18E-02	2.51E-03	8.73E+01	1.60	1.44	586	32%	50%	22	22
Supernatant	1.70E+04	3.88E+03	1.18E+05	1.91E+05	2.32E+05	3.65E+04	7.29E-01	1.43E-01	1.50E-02	7.18E-02	2.51E-03	8.73E+01	1.44	1.44	38	50%	50%	22	22
Solid Layer	1.70E+04	3.88E+03	1.18E+05	1.91E+05	2.32E+05	3.65E+04	7.29E-01	1.43E-01	1.50E-02	7.18E-02	2.51E-03	8.73E+01	1.61	1.44	548	31%	50%	22	22
241-TX-104	1.50E+04	1.19E+03	8.30E+04	3.11E+05	1.80E+05	2.81E+03	1.47E+02	1.44E-01	1.95E-02	9.53E-02	2.81E-03	6.42E+01	1.64	1.39	300	50%	56%	21	21
Supernatant	3.27E+03	2.60E+02	1.81E+04	6.81E+04	3.95E+04	6.13E+02	1.65E-01	2.26E-03	2.07E-05	9.84E-05	3.48E-06	5.90E+01	1.08	1.08	47	88%	88%	21	21
Solid Layer	1.70E+04	1.36E+03	9.43E+04	3.53E+05	2.05E+05	3.19E+03	1.64E+02	1.60E-01	2.17E-02	1.06E-01	3.13E-03	6.48E+01	1.74	1.44	253	46%	52%	21	21
241-TX-105	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.95E+00	1.60E-01	1.67E-02	7.95E-02	2.79E-03	7.10E+01	1.63	1.45	2219	30%	49%	33	23
Supernatant	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.95E+00	1.60E-01	1.67E-02	7.95E-02	2.79E-03	7.10E+01	1.45	1.45	38	49%	49%	28	23
Solid Layer	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.95E+00	1.60E-01	1.67E-02	7.95E-02	2.79E-03	7.10E+01	1.63	1.45	2181	29%	49%	33	23
241-TX-106	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	6.09E+00	1.53E-01	1.68E-02	8.06E-02	2.73E-03	8.27E+01	1.62	1.45	1356	31%	49%	25	25
Supernatant	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	6.09E+00	1.53E-01	1.68E-02	8.06E-02	2.73E-03	8.27E+01	1.45	1.45	38	49%	49%	25	25
Solid Layer	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	6.09E+00	1.53E-01	1.68E-02	8.06E-02	2.73E-03	8.27E+01	1.62	1.45	1318	30%	49%	25	25

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (μg/mL)	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Na in liquid [Na] (ug/mL)	Al in liquid [Al] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	²⁴¹ Am in waste [Am241] (μCi/g)	²⁴⁰ Pu in waste [Pu240] (μCi/g)	²³⁹ Pu in waste [Pu240] (μCi/g)	²³⁸ Pu in waste [Pu238] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-TX-107	1.70E+04	3.22E+03	1.16E+05	1.97E+05	2.40E+05	4.03E+04	5.47E+00	1.69E+00	1.77E-01	8.41E-01	2.97E-02	1.02E+02	1.70	1.46	150	33%	50%	22	14
Supernatant	1.70E+04	3.22E+03	1.16E+05	1.97E+05	2.40E+05	4.03E+04	5.47E+00	1.69E+00	1.77E-01	8.41E-01	2.97E-02	1.02E+02	1.46	1.46	38	50%	50%	18	14
Solid Layer	1.70E+04	3.22E+03	1.16E+05	1.97E+05	2.40E+05	4.03E+04	5.47E+00	1.69E+00	1.77E-01	8.41E-01	2.97E-02	1.02E+02	1.78	1.46	112	28%	50%	22	14
241-TX-108	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	5.27E+00	1.50E-01	1.55E-02	7.45E-02	2.61E-03	7.50E+01	1.61	1.45	516	32%	49%	21	21
Supernatant	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	5.27E+00	1.50E-01	1.55E-02	7.45E-02	2.61E-03	7.50E+01	1.45	1.45	38	49%	49%	21	21
Solid Layer	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	5.27E+00	1.50E-01	1.55E-02	7.45E-02	2.61E-03	7.50E+01	1.62	1.45	478	31%	49%	21	21
241-TX-109	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.82E+00	1.38E-02	9.05E-03	8.34E-02	5.85E-04	1.59E+01	1.42	1.17	1413	55%	75%	36	39
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.82E+00	1.38E-02	9.05E-03	8.34E-02	5.85E-04	1.59E+01	1.17	1.17	38	75%	75%	37	39
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	4.82E+00	1.38E-02	9.05E-03	8.34E-02	5.85E-04	1.59E+01	1.43	1.17	1375	54%	75%	36	39
241-TX-110	1.70E+04	4.02E+03	1.22E+05	1.90E+05	2.37E+05	3.78E+04	1.03E+00	1.55E-01	1.66E-02	8.20E-02	2.73E-03	6.52E+01	1.61	1.45	1807	31%	49%	28	22
Supernatant	1.70E+04	4.02E+03	1.22E+05	1.90E+05	2.37E+05	3.78E+04	1.03E+00	1.55E-01	1.66E-02	8.20E-02	2.73E-03	6.52E+01	1.45	1.45	38	49%	49%	25	22
Solid Layer	1.70E+04	4.02E+03	1.22E+05	1.90E+05	2.37E+05	3.78E+04	1.03E+00	1.55E-01	1.66E-02	8.20E-02	2.73E-03	6.52E+01	1.62	1.45	1769	31%	49%	28	22
241-TX-111	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.17E+00	1.51E-01	1.65E-02	8.28E-02	2.67E-03	6.21E+01	1.61	1.45	1419	32%	49%	27	22
Supernatant	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.17E+00	1.51E-01	1.65E-02	8.28E-02	2.67E-03	6.21E+01	1.45	1.45	38	49%	49%	25	22
Solid Layer	1.70E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.17E+00	1.51E-01	1.65E-02	8.28E-02	2.67E-03	6.21E+01	1.61	1.45	1381	31%	49%	27	22
241-TX-112	4.81E+04	3.47E+03	1.06E+05	1.94E+05	2.18E+05	3.26E+04	7.24E-01	1.58E-01	1.66E-02	7.94E-02	2.77E-03	6.81E+01	1.63	1.42	2436	29%	52%	22	18
Supernatant	4.81E+04	3.47E+03	1.06E+05	1.94E+05	2.18E+05	3.26E+04	7.24E-01	1.58E-01	1.66E-02	7.94E-02	2.77E-03	6.81E+01	1.42	1.42	38	52%	52%	20	18
Solid Layer	4.81E+04	3.47E+03	1.06E+05	1.94E+05	2.18E+05	3.26E+04	7.24E-01	1.58E-01	1.66E-02	7.94E-02	2.77E-03	6.81E+01	1.63	1.42	2398	29%	52%	22	18
241-TX-113	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.40E+00	6.72E-03	1.68E-03	1.32E-02	1.62E-04	8.18E+00	1.61	1.45	2454	16%	49%	22	22
Supernatant	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.40E+00	6.72E-03	1.68E-03	1.32E-02	1.62E-04	8.18E+00	1.45	1.45	38	49%	49%	22	22
Solid Layer	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.40E+00	6.72E-03	1.68E-03	1.32E-02	1.62E-04	8.18E+00	1.61	1.45	2416	15%	49%	22	22
241-TX-114	1.70E+04	1.53E+03	5.15E+04	2.07E+05	1.60E+05	1.45E+04	7.29E-01	1.48E-01	1.59E-02	7.75E-02	2.62E-03	5.94E+01	1.63	1.33	2050	30%	61%	21	18
Supernatant	1.70E+04	1.53E+03	5.15E+04	2.07E+05	1.60E+05	1.45E+04	7.29E-01	1.48E-01	1.59E-02	7.75E-02	2.62E-03	5.94E+01	1.33	1.33	38	61%	61%	19	18
Solid Layer	1.70E+04	1.53E+03	5.15E+04	2.07E+05	1.60E+05	1.45E+04	7.29E-01	1.48E-01	1.59E-02	7.75E-02	2.62E-03	5.94E+01	1.63	1.33	2012	29%	61%	21	18
241-TX-115	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	2.15E+00	1.60E-01	1.67E-02	7.97E-02	2.80E-03	7.13E+01	1.63	1.45	2131	30%	49%	22	21
Supernatant	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	2.15E+00	1.60E-01	1.67E-02	7.97E-02	2.80E-03	7.13E+01	1.45	1.45	38	49%	49%	21	21
Solid Layer	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	2.15E+00	1.60E-01	1.67E-02	7.97E-02	2.80E-03	7.13E+01	1.63	1.45	2093	29%	49%	22	21
241-TX-116	2.54E+03	3.19E+02	1.05E+04	3.79E+05	1.51E+05	8.79E+00	3.42E-01	6.88E-02	9.33E-03	5.34E-02	1.34E-03	3.51E+01	1.65	1.39	2302	22%	53%	21	20
Supernatant	2.54E+03	3.19E+02	1.05E+04	3.79E+05	1.51E+05	8.79E+00	3.42E-01	6.88E-02	9.33E-03	5.34E-02	1.34E-03	3.51E+01	1.39	1.39	38	53%	53%	20	20
Solid Layer	2.54E+03	3.19E+02	1.05E+04	3.79E+05	1.51E+05	8.79E+00	3.42E-01	6.88E-02	9.33E-03	5.34E-02	1.34E-03	3.51E+01	1.66	1.39	2264	21%	53%	21	20
241-TX-117	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.60E+02	5.08E-01	1.00E-01	1.20E-02	6.32E-02	1.85E-03	3.89E+01	1.57	1.26	1855	28%	70%	21	20
Supernatant	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.60E+02	5.08E-01	1.00E-01	1.20E-02	6.32E-02	1.85E-03	3.89E+01	1.26	1.26	38	70%	70%	20	20
Solid Layer	1.70E+04	3.38E+00	8.50E+03	2.17E+05	1.13E+05	3.60E+02	5.08E-01	1.00E-01	1.20E-02	6.32E-02	1.85E-03	3.89E+01	1.58	1.26	1817	27%	70%	21	20
241-TX-118	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.21E+02	3.62E+00	4.93E-01	2.34E+00	8.26E-02	5.39E+01	1.68	1.45	973	45%	49%	24	24
Supernatant	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.21E+02	3.62E+00	4.93E-01	2.34E+00	8.26E-02	5.39E+01	1.45	1.45	38	49%	49%	24	24
Solid Layer	4.81E+04	4.03E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	1.21E+02	3.62E+00	4.93E-01	2.34E+00	8.26E-02	5.39E+01	1.69	1.45	935	45%	49%	24	24
241-TY-101	1.70E+04	3.38E+00	8.47E+03	2.17E+05	1.13E+05	3.61E+02	9.53E+00	1.26E-02	1.44E-02	1.72E-01	8.48E-04	4.04E-01	1.60	1.26	485	46%	70%	19	20
Supernatant	1.70E+04	3.38E+00	8.47E+03	2.17E+05	1.13E+05	3.61E+02	9.53E+00	1.26E-02	1.44E-02	1.72E-01	8.48E-04	4.04E-01	1.26	1.26	38	70%	70%	20	20
Solid Layer	1.70E+04	3.38E+00	8.47E+03	2.17E+05	1.13E+05	3.61E+02	9.53E+00	1.26E-02	1.44E-02	1.72E-01	8.48E-04	4.04E-01	1.63	1.26	447	44%	70%	19	20

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (µg/mL)	TOC in liquid [TOC] (µg/mL)	NO ₂ in liquid [NO ₂] (µg/mL)	NO ₃ in liquid [NO ₃] (µg/mL)	Na in liquid [Na] (µg/mL)	Al in liquid [Al] (µg/mL)	⁹⁰ Sr in waste [Sr] (µCi/g)	²⁴¹ Am in waste [Am241] (µCi/g)	²⁴⁰ Pu in waste [Pu240] (µCi/g)	²³⁹ Pu in waste [Pu240] (µCi/g)	²³⁸ Pu in waste [Pu238] (µCi/g)	¹³⁷ Cs in waste [Cs] (µCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-TY-102	4.82E+04	2.18E+03	6.98E+04	2.02E+05	1.79E+05	2.06E+04	2.62E+00	2.50E-03	2.02E-04	1.33E-03	2.46E-05	2.87E+01	1.71	1.36	300	35%	58%	16	19
Supernatant	4.82E+04	2.18E+03	6.98E+04	2.02E+05	1.79E+05	2.06E+04	2.62E+00	2.50E-03	2.02E-04	1.33E-03	2.46E-05	2.87E+01	1.36	1.36	38	58%	58%	18	19
Solid Layer	4.82E+04	2.18E+03	6.98E+04	2.02E+05	1.79E+05	2.06E+04	2.62E+00	2.50E-03	2.02E-04	1.33E-03	2.46E-05	2.87E+01	1.76	1.36	262	32%	58%	16	19
241-TY-103	4.80E+04	4.02E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	7.00E+01	2.42E-02	1.93E-02	1.60E-01	2.10E-03	2.78E+01	1.67	1.45	623	52%	49%	24	17
Supernatant	4.80E+04	4.02E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	7.00E+01	2.42E-02	1.93E-02	1.60E-01	2.10E-03	2.78E+01	1.45	1.45	38	49%	49%	20	17
Solid Layer	4.80E+04	4.02E+03	1.22E+05	1.90E+05	2.36E+05	3.78E+04	7.00E+01	2.42E-02	1.93E-02	1.60E-01	2.10E-03	2.78E+01	1.68	1.45	585	52%	49%	24	17
241-TY-104	1.37E+04	1.71E+03	9.11E+03	7.98E+04	6.73E+04	4.60E+02	7.46E+01	6.86E-02	1.17E-02	1.48E-01	6.74E-04	3.04E+01	1.52	1.15	206	58%	80%	15	19
Supernatant	1.98E+03	2.47E+02	1.32E+03	1.16E+04	9.73E+03	6.65E+01	6.90E-03	4.94E-05	3.57E-05	1.49E-04	8.46E-06	1.31E+00	1.02	1.02	43	97%	97%	16	19
Solid Layer	1.70E+04	2.12E+03	1.13E+04	9.90E+04	8.34E+04	5.70E+02	8.67E+01	7.98E-02	1.36E-02	1.72E-01	7.83E-04	3.51E+01	1.65	1.18	163	52%	78%	15	19
241-TY-105	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.48E+02	7.55E-03	2.27E-03	2.12E-02	1.47E-04	6.24E+00	1.52	1.17	912	41%	75%	25	23
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.48E+02	7.55E-03	2.27E-03	2.12E-02	1.47E-04	6.24E+00	1.17	1.17	38	75%	75%	24	23
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.48E+02	7.55E-03	2.27E-03	2.12E-02	1.47E-04	6.24E+00	1.53	1.17	874	39%	75%	25	23
241-TY-106	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.21E+02	1.66E-02	2.04E-03	1.90E-02	1.32E-04	5.66E+01	1.31	1.17	100	51%	75%	16	20
Supernatant	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.21E+02	1.66E-02	2.04E-03	1.90E-02	1.32E-04	5.66E+01	1.17	1.17	38	75%	75%	18	20
Solid Layer	1.70E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.21E+02	1.66E-02	2.04E-03	1.90E-02	1.32E-04	5.66E+01	1.40	1.17	62	38%	75%	16	20
241-U-101	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.71E+02	2.05E-02	7.86E-03	4.06E-02	7.53E-04	5.73E+01	1.59	1.17	125	40%	76%	21	21
Supernatant	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.71E+02	2.05E-02	7.86E-03	4.06E-02	7.53E-04	5.73E+01	1.17	1.17	38	76%	76%	21	21
Solid Layer	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	3.71E+02	2.05E-02	7.86E-03	4.06E-02	7.53E-04	5.73E+01	1.77	1.17	87	30%	76%	21	21
241-U-102	2.83E+04	1.08E+04	1.41E+05	1.91E+05	2.15E+05	3.20E+04	8.28E+01	1.16E-01	2.25E-02	1.12E-01	2.81E-03	1.38E+02	1.65	1.46	1276	35%	48%	26	27
Supernatant	2.80E+03	1.07E+03	1.40E+04	1.89E+04	2.13E+04	3.18E+03	6.15E-01	1.06E-03	8.91E-06	4.25E-05	1.50E-06	4.11E+01	1.05	1.05	42	93%	93%	27	27
Solid Layer	2.93E+04	1.12E+04	1.46E+05	1.98E+05	2.23E+05	3.32E+04	8.45E+01	1.18E-01	2.30E-02	1.14E-01	2.87E-03	1.40E+02	1.67	1.48	1234	34%	48%	26	27
241-U-103	3.00E+04	1.21E+04	1.33E+05	1.48E+05	2.24E+05	3.98E+04	2.25E+01	8.40E-02	8.91E-03	4.24E-02	1.29E-03	1.09E+02	1.68	1.43	1448	40%	51%	28	22
Supernatant	1.55E+03	6.22E+02	6.88E+03	7.63E+03	1.16E+04	2.05E+03	4.59E-01	9.08E-04	4.22E-06	1.93E-05	6.82E-07	2.19E+01	1.02	1.02	40	96%	96%	28	22
Solid Layer	3.08E+04	1.24E+04	1.37E+05	1.52E+05	2.30E+05	4.09E+04	2.28E+01	8.54E-02	9.07E-03	4.31E-02	1.31E-03	1.10E+02	1.70	1.44	1408	40%	50%	28	22
241-U-104	4.91E+04	9.58E+03	1.05E+05	2.07E+05	2.03E+05	3.21E+04	2.52E+00	1.27E-03	6.00E-04	4.74E-03	4.10E-05	2.21E-01	1.17	1.40	243	68%	55%	28	24
Supernatant	4.91E+04	9.58E+03	1.05E+05	2.07E+05	2.03E+05	3.21E+04	2.52E+00	1.27E-03	6.00E-04	4.74E-03	4.10E-05	2.21E-01	1.40	1.40	38	55%	55%	26	24
Solid Layer	4.91E+04	9.58E+03	1.05E+05	2.07E+05	2.03E+05	3.21E+04	2.52E+00	1.27E-03	6.00E-04	4.74E-03	4.10E-05	2.21E-01	1.12	1.40	205	71%	55%	28	24
241-U-105	2.09E+04	1.64E+04	1.08E+05	1.81E+05	2.27E+05	2.98E+04	1.14E+01	3.63E-01	5.41E-02	2.59E-01	7.94E-03	1.37E+02	1.66	1.46	1374	31%	52%	28	23
Supernatant	2.09E+04	1.64E+04	1.08E+05	1.81E+05	2.27E+05	2.98E+04	1.14E+01	3.63E-01	5.41E-02	2.59E-01	7.94E-03	1.37E+02	1.46	1.46	38	52%	52%	25	23
Solid Layer	2.09E+04	1.64E+04	1.08E+05	1.81E+05	2.27E+05	2.98E+04	1.14E+01	3.63E-01	5.41E-02	2.59E-01	7.94E-03	1.37E+02	1.67	1.46	1336	30%	52%	28	23
241-U-106	4.82E+03	3.19E+04	9.32E+04	2.35E+05	2.10E+05	1.13E+04	5.71E+01	6.56E-01	4.16E-02	1.91E-01	6.72E-03	1.40E+02	1.52	1.32	682	44%	50%	27	22
Supernatant	7.00E+02	4.63E+03	1.35E+04	3.40E+04	3.06E+04	1.65E+03	7.19E+00	3.79E-02	1.61E-04	7.39E-04	2.59E-05	3.68E+01	1.05	1.05	44	91%	91%	24	22
Solid Layer	5.11E+03	3.38E+04	9.87E+04	2.49E+05	2.23E+05	1.20E+04	5.94E+01	6.85E-01	4.35E-02	2.00E-01	7.03E-03	1.45E+02	1.55	1.34	638	42%	49%	27	22
241-U-107	3.12E+04	6.28E+03	1.28E+05	1.42E+05	2.05E+05	4.10E+04	2.09E+00	2.15E-01	3.04E-02	1.42E-01	4.96E-03	7.55E+01	1.73	1.43	1151	33%	50%	22	23
Supernatant	3.12E+04	6.28E+03	1.28E+05	1.42E+05	2.05E+05	4.10E+04	2.09E+00	2.15E-01	3.04E-02	1.42E-01	4.96E-03	7.55E+01	1.43	1.43	38	50%	50%	23	23
Solid Layer	3.12E+04	6.28E+03	1.28E+05	1.42E+05	2.05E+05	4.10E+04	2.09E+00	2.15E-01	3.04E-02	1.42E-01	4.96E-03	7.55E+01	1.74	1.43	1113	33%	50%	22	23
241-U-108	4.92E+04	7.07E+03	1.34E+05	1.84E+05	2.28E+05	3.05E+04	7.54E+00	3.43E-02	1.43E-02	6.53E-02	1.76E-03	1.23E+02	1.67	1.40	1679	37%	50%	29	28
Supernatant	4.92E+04	7.07E+03	1.34E+05	1.84E+05	2.28E+05	3.05E+04	7.54E+00	3.43E-02	1.43E-02	6.53E-02	1.76E-03	1.23E+02	1.40	1.40	38	50%	50%	29	28
Solid Layer	4.92E+04	7.07E+03	1.34E+05	1.84E+05	2.28E+05	3.05E+04	7.54E+00	3.43E-02	1.43E-02	6.53E-02	1.76E-03	1.23E+02	1.68	1.40	1641	37%	50%	29	28

Table B-5. Input Data with DSA Conditions for Hydrogen Generation Rate Model Calculations for 177 Tanks. (14 sheets)

Tank	OH in liquid [OH] (µg/mL)	TOC in liquid [TOC] (µg/mL)	NO ₂ in liquid [NO ₂] (µg/mL)	NO ₃ in liquid [NO ₃] (µg/mL)	Na in liquid [Na] (ug/mL)	Al in liquid [Al] (µg/mL)	⁹⁰ Sr in waste [Sr] (µCi/g)	²⁴¹ Am in waste [Am241] (µCi/g)	²⁴⁰ Pu in waste [Pu240] (µCi/g)	²³⁹ Pu in waste [Pu240] (µCi/g)	²³⁸ Pu in waste [Pu238] (µCi/g)	¹³⁷ Cs in waste [Cs] (µCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
241-U-109	4.42E+04	6.53E+03	1.28E+05	1.85E+05	2.28E+05	2.92E+04	6.95E+00	2.36E-02	2.37E-03	1.11E-02	3.67E-04	1.13E+02	1.65	1.47	1390	29%	51%	30	26
Supernatant	4.42E+04	6.53E+03	1.28E+05	1.85E+05	2.28E+05	2.92E+04	6.95E+00	2.36E-02	2.37E-03	1.11E-02	3.67E-04	1.13E+02	1.47	1.47	38	51%	51%	28	26
Solid Layer	4.42E+04	6.53E+03	1.28E+05	1.85E+05	2.28E+05	2.92E+04	6.95E+00	2.36E-02	2.37E-03	1.11E-02	3.67E-04	1.13E+02	1.65	1.47	1352	29%	51%	30	26
241-U-110	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.62E+02	7.35E-02	3.16E-02	1.84E-01	2.84E-03	1.81E+01	1.69	1.17	703	32%	75%	25	24
Supernatant	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.62E+02	7.35E-02	3.16E-02	1.84E-01	2.84E-03	1.81E+01	1.17	1.17	38	75%	75%	24	24
Solid Layer	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.62E+02	7.35E-02	3.16E-02	1.84E-01	2.84E-03	1.81E+01	1.72	1.17	665	31%	75%	25	24
241-U-111	3.39E+04	5.41E+03	1.20E+05	1.67E+05	2.39E+05	3.66E+04	3.82E+01	1.14E-01	1.88E-02	9.26E-02	2.59E-03	1.27E+02	1.60	1.40	878	36%	53%	23	25
Supernatant	3.39E+04	5.41E+03	1.20E+05	1.67E+05	2.39E+05	3.66E+04	3.82E+01	1.14E-01	1.88E-02	9.26E-02	2.59E-03	1.27E+02	1.40	1.40	38	53%	53%	24	25
Solid Layer	3.39E+04	5.41E+03	1.20E+05	1.67E+05	2.39E+05	3.66E+04	3.82E+01	1.14E-01	1.88E-02	9.26E-02	2.59E-03	1.27E+02	1.61	1.40	840	36%	53%	23	25
241-U-112	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.65E+02	3.36E-03	2.11E-03	1.91E-02	1.38E-04	3.01E+01	1.64	1.17	210	38%	75%	21	21
Supernatant	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.65E+02	3.36E-03	2.11E-03	1.91E-02	1.38E-04	3.01E+01	1.17	1.17	38	75%	75%	21	21
Solid Layer	4.91E+04	2.98E+03	3.60E+04	7.96E+04	8.32E+04	4.94E+03	1.65E+02	3.36E-03	2.11E-03	1.91E-02	1.38E-04	3.01E+01	1.74	1.17	172	32%	75%	21	21
241-U-201	6.07E+03	0.00E+00	1.49E+04	1.03E+05	8.34E+04	1.02E+02	9.87E-02	1.11E-03	2.43E-04	1.28E-03	1.99E-05	7.24E+00	1.42	1.17	19	45%	74%	18	17
Supernatant	1.21E+03	0.00E+00	1.06E+04	7.33E+04	5.95E+04	7.26E+01	5.78E-03	2.47E-04	1.97E-05	1.04E-04	1.61E-06	1.24E+01	1.13	1.13	8	82%	82%	21	17
Solid Layer	1.27E+04	0.00E+00	2.07E+04	1.43E+05	1.16E+05	1.41E+02	1.44E-01	1.53E-03	3.52E-04	1.86E-03	2.89E-05	4.72E+00	1.63	1.22	11	27%	69%	17	17
241-U-202	8.00E+03	9.92E+01	1.73E+04	1.07E+05	8.41E+04	1.68E+02	3.89E-02	1.20E-03	3.10E-04	1.63E-03	2.54E-05	5.86E+00	1.35	1.17	18	48%	74%	18	19
Supernatant	1.71E+03	7.24E+01	1.26E+04	7.80E+04	6.14E+04	1.23E+02	2.77E-04	4.15E-06	5.02E-07	2.64E-06	4.11E-08	8.79E+00	1.14	1.14	8	82%	82%	18	19
Solid Layer	1.79E+04	1.41E+02	2.45E+04	1.52E+05	1.20E+05	2.39E+02	6.17E-02	1.90E-03	4.93E-04	2.60E-03	4.04E-05	4.13E+00	1.51	1.22	10	28%	69%	18	19
241-U-203	2.42E+03	0.00E+00	1.42E+04	1.06E+05	7.38E+04	1.38E+02	7.76E-02	9.53E-04	1.78E-04	9.39E-04	1.46E-05	5.56E+00	1.38	1.21	17	56%	74%	19	19
Supernatant	4.54E+02	0.00E+00	9.94E+03	7.40E+04	5.15E+04	9.63E+01	2.44E-04	3.99E-06	2.13E-06	1.12E-05	1.74E-07	8.24E+00	1.14	1.14	8	82%	82%	19	19
Solid Layer	4.75E+03	0.00E+00	1.94E+04	1.44E+05	1.00E+05	1.88E+02	1.26E-01	1.54E-03	2.88E-04	1.52E-03	2.35E-05	3.89E+00	1.59	1.28	9	40%	69%	19	19
241-U-204	5.38E+02	5.20E+01	4.51E+03	3.55E+04	2.52E+04	9.39E+00	2.12E+00	1.23E-02	6.70E-03	3.53E-02	5.51E-04	4.23E+00	1.25	1.07	15	56%	90%	18	19
Supernatant	1.54E+02	4.16E+01	3.61E+03	2.84E+04	2.02E+04	7.51E+00	9.56E-05	4.58E-06	3.62E-07	1.91E-06	2.95E-08	3.31E+00	1.06	1.06	8	93%	93%	18	19
Solid Layer	1.61E+03	8.10E+01	7.03E+03	5.53E+04	3.93E+04	1.46E+01	3.81E+00	2.21E-02	1.21E-02	6.35E-02	9.91E-04	4.98E+00	1.47	1.11	7	26%	87%	18	19

APPENDIX C

**CALCULATIONS OF THE HENRY'S LAW CONSTANTS AND THE
MASS TRANSPORT PRODUCTS OF h AND A**

This page intentionally left blank.

CONTENTS

Table C-1	Input Ion Concentration for NH ₃ Calculation.....	C-1
Table C-2	Calculations of Henry's Law Constant by Schumpe Model	C-4
Table C-3	Calculation of Mass Transport Properties of h and A from Normal Ventilation Condition and Prediction for Off-Normal Condition.....	C-7

This page intentionally left blank.

Table C-1. Input Ion Concentration for NH₃ Calculation. (3 sheets)

Tanks	Na+ in liquid (µg/mL)	Al+3 in liquid (µg/mL)	Fe+3 in liquid (µg/mL)	Cr+3 in liquid (µg/mL)	Ni+2 in liquid (µg/mL)	K+1 in liquid (µg/mL)	OH-1 in liquid (µg/mL)	NO3-1 in liquid (µg/mL)	NO2-1 in liquid (µg/mL)	CO3-2 in liquid (µg/mL)	PO4-3 in liquid (µg/mL)	SO4-2 in liquid (µg/mL)	F-1 in liquid (µg/mL)	Cl-1 in liquid (µg/mL)
241-AN-101	9.29E+04	1.09E+04	6.32E+00	1.21E+02	3.61E+00	2.68E+03	3.08E+04	7.18E+04	4.07E+04	9.65E+03	1.59E+03	1.36E+03	2.89E+02	2.33E+03
241-AN-102	2.27E+05	1.54E+04	4.90E+01	2.97E+02	4.17E+02	2.88E+03	3.23E+03	2.36E+05	9.04E+04	7.00E+04	5.52E+03	1.53E+04	1.91E+03	4.11E+03
241-AN-103	2.85E+05	3.02E+04	3.01E+01	5.66E+02	1.20E+01	1.68E+04	9.93E+04	1.68E+05	1.65E+05	5.80E+03	1.65E+03	1.45E+03	6.60E+02	9.76E+03
241-AN-104	2.56E+05	3.86E+04	3.01E+01	3.36E+02	1.20E+01	6.69E+03	7.09E+04	1.70E+05	1.25E+05	1.07E+04	2.71E+03	3.54E+03	8.19E+01	8.09E+03
241-AN-105	2.46E+05	4.11E+04	2.47E+01	2.22E+02	9.95E+00	6.50E+03	5.86E+04	1.62E+05	1.21E+05	1.18E+04	1.22E+03	2.85E+03	3.06E+02	9.90E+03
241-AN-106	7.56E+04	3.22E+03	1.77E+00	9.91E+01	2.79E+02	5.96E+03	9.93E+04	6.58E+04	1.76E+04	2.18E+04	2.02E+03	5.50E+03	5.11E+03	9.60E+02
241-AN-107	2.03E+05	2.93E+02	1.67E+03	1.72E+02	5.51E+02	1.81E+03	9.93E+04	2.38E+05	6.59E+04	7.55E+04	2.94E+03	8.98E+03	4.18E+03	2.02E+03
241-AP-101	1.29E+05	6.94E+03	2.50E+00	1.43E+02	7.90E+00	3.12E+04	4.94E+04	1.32E+05	4.19E+04	3.23E+04	1.02E+03	4.03E+03	2.90E+03	1.98E+03
241-AP-102	1.02E+05	1.15E+04	3.82E+00	6.19E+02	2.66E+01	1.29E+03	9.09E+03	7.60E+04	3.59E+04	2.66E+04	1.16E+04	4.52E+03	1.68E+02	2.73E+03
241-AP-103	1.81E+05	8.43E+03	3.01E+01	3.72E+02	1.22E+02	1.33E+04	9.51E+03	1.35E+05	1.06E+05	7.55E+04	3.46E+03	4.50E+03	2.09E+03	2.82E+03
241-AP-104	1.36E+05	1.97E+04	1.04E+02	1.37E+03	7.85E+01	2.11E+03	2.26E+03	1.13E+05	6.74E+04	1.93E+04	3.86E+03	3.84E+03	4.15E+02	5.49E+03
241-AP-105	1.90E+05	2.07E+04	3.01E+01	5.13E+02	2.54E+01	1.23E+04	3.35E+04	2.32E+05	1.01E+05	1.12E+05	3.16E+03	6.78E+03	4.74E+03	5.45E+03
241-AP-106	1.22E+05	1.83E+04	1.13E+02	1.57E+03	7.56E+01	3.12E+03	9.01E+03	9.03E+04	6.14E+04	1.88E+04	2.76E+03	3.20E+03	6.71E+02	4.92E+03
241-AP-107	7.97E+04	8.69E+03	1.01E+01	6.55E+02	2.36E+00	1.58E+03	7.28E+03	9.56E+04	2.80E+04	4.55E+03	4.84E+03	2.41E+03	7.22E+02	2.29E+03
241-AP-108	9.03E+04	1.09E+04	1.01E+01	8.21E+02	4.02E+00	2.85E+03	1.39E+04	9.10E+04	3.27E+04	1.27E+04	3.40E+03	2.72E+03	9.70E+02	2.86E+03
241-AW-101	2.53E+05	3.07E+04	1.80E+01	1.12E+02	6.10E+00	4.12E+04	8.63E+04	1.70E+05	1.20E+05	9.20E+03	9.96E+02	1.26E+03	9.62E+02	7.30E+03
241-AW-102	5.68E+04	6.39E+03	6.95E+00	4.81E+02	1.90E+00	1.32E+03	7.45E+03	6.50E+04	2.01E+04	2.31E+03	6.22E+02	1.72E+03	5.42E+02	1.68E+03
241-AW-103	2.46E+04	6.46E+01	5.57E+00	2.53E+01	5.08E+00	1.43E+04	9.62E+03	4.22E+03	1.78E+03	4.70E+03	5.92E+01	6.72E+02	1.68E+04	1.38E+02
241-AW-104	1.74E+04	7.11E+02	1.86E+00	2.20E+00	7.40E-01	1.67E+03	3.55E+03	1.66E+04	5.33E+03	7.25E+03	2.93E+02	6.54E+02	1.32E+02	2.39E+02
241-AW-105	1.49E+04	4.34E+01	4.61E+00	2.12E+00	9.91E-01	1.99E+03	6.12E+03	2.70E+04	1.28E+03	1.62E+03	1.85E+02	3.01E+02	4.81E+02	2.45E+02
241-AW-106	1.77E+05	1.99E+04	2.18E+01	1.47E+03	8.39E+00	5.65E+03	9.80E+03	1.92E+05	6.35E+04	2.84E+04	1.47E+03	5.14E+03	1.23E+03	5.17E+03
241-AY-101	5.19E+04	1.21E+01	1.20E+01	1.05E+02	5.90E+01	7.63E+02	2.29E+02	2.60E+04	3.53E+04	3.44E+04	1.15E+03	5.87E+03	1.74E+02	6.36E+02
241-AY-102	5.40E+04	1.97E+03	1.01E+01	2.91E+01	4.02E+00	3.88E+02	1.44E+03	4.86E+02	7.29E+03	4.87E+04	3.01E+03	2.32E+03	1.72E+02	1.60E+02
241-AZ-101	1.11E+05	8.56E+03	2.24E+01	7.23E+02	8.02E+00	4.76E+03	1.15E+04	7.12E+04	7.26E+04	3.42E+04	1.34E+03	1.50E+04	1.75E+03	1.51E+02
241-AZ-102	5.59E+04	6.68E+02	1.00E+00	7.37E+02	1.75E+00	3.20E+03	1.21E+03	1.85E+04	3.55E+04	3.50E+04	4.97E+02	1.86E+04	1.14E+03	7.66E+01
241-SY-101	1.63E+05	1.34E+04	3.97E+02	5.18E+03	2.02E+02	4.14E+03	2.63E+04	1.52E+05	9.56E+04	3.44E+04	4.94E+03	4.19E+03	5.50E+02	1.11E+04
241-SY-102	9.84E+04	1.44E+04	1.41E+01	2.41E+02	5.04E+01	1.53E+03	1.97E+04	9.20E+04	5.89E+04	1.31E+04	3.48E+03	2.91E+03	1.51E+02	4.64E+03

Table C-1. Input Ion Concentration for NH₃ Calculation. (3 sheets)

Tanks	Na+ in liquid (µg/mL)	Al+3 in liquid (µg/mL)	Fe+3 in liquid (µg/mL)	Cr+3 in liquid (µg/mL)	Ni+2 in liquid (µg/mL)	K+1 in liquid (µg/mL)	OH-1 in liquid (µg/mL)	NO3-1 in liquid (µg/mL)	NO2-1 in liquid (µg/mL)	CO3-2 in liquid (µg/mL)	PO4-3 in liquid (µg/mL)	SO4-2 in liquid (µg/mL)	F-1 in liquid (µg/mL)	Cl-1 in liquid (µg/mL)
241-SY-103	2.12E+05	4.14E+04	2.10E+01	3.30E+01	4.90E+01	3.91E+03	2.89E+04	1.79E+05	1.43E+05	3.44E+04	3.12E+03	4.08E+03	3.51E+02	1.16E+04
241-A-101	2.78E+05	5.18E+04	4.29E+01	5.73E+01	1.85E+01	7.42E+03	4.48E+04	2.33E+05	1.65E+05	1.33E+04	5.89E+03	1.40E+03	2.17E+02	9.01E+03
241-A-103	2.20E+05	3.56E+04	1.81E+01	2.96E+02	9.46E+01	5.44E+03	4.48E+04	1.33E+05	1.65E+05	1.33E+04	3.67E+03	1.40E+03	2.17E+02	9.01E+03
241-AX-101	2.82E+05	5.03E+04	3.01E+01	1.75E+02	1.20E+01	7.42E+03	3.90E+04	2.72E+05	1.73E+05	1.10E+04	6.59E+03	1.54E+03	5.78E+01	8.82E+03
241-B-203	3.12E+04	1.00E+01	1.00E+01	1.62E+02	4.02E+00	5.44E+03	3.90E+04	5.67E+04	1.57E+03	1.09E+04	1.90E+03	5.62E+02	6.04E+03	6.77E+02
241-B-204	2.94E+04	8.35E+00	8.35E+00	1.52E+02	3.35E+00	6.42E+03	3.90E+04	4.82E+04	1.82E+03	1.09E+04	7.14E+02	8.24E+02	6.55E+03	6.22E+02
241-BY-106	1.65E+05	3.98E+04	3.20E+01	3.54E+02	2.80E+01	8.93E+03	3.58E+04	1.10E+05	7.81E+04	6.60E+03	1.99E+03	2.02E+03	2.93E+02	4.65E+03
241-C-103	3.53E+04	1.16E+01	5.40E+00	7.86E+01	7.85E+01	3.10E+02	4.49E+04	4.30E+03	2.43E+04	2.94E+04	4.59E+03	3.22E+03	1.16E+03	4.05E+02
241-S-101	2.15E+05	2.45E+04	2.01E+01	8.13E+02	8.02E+00	2.36E+03	4.49E+04	1.81E+05	9.40E+04	5.30E+03	3.86E+03	5.65E+03	1.06E+02	7.45E+03
241-S-102	2.36E+05	4.19E+04	4.01E+01	1.08E+02	1.64E+01	3.25E+03	4.10E+04	1.59E+05	1.14E+05	2.01E+04	4.93E+03	4.63E+03	3.50E+02	1.04E+04
241-S-103	2.28E+05	3.20E+04	3.01E+01	2.69E+02	1.20E+01	3.90E+03	3.65E+04	2.16E+05	1.47E+05	2.21E+04	3.57E+03	5.10E+03	2.56E+02	1.33E+04
241-S-106	2.44E+05	3.85E+04	3.01E+01	9.41E+03	1.20E+01	1.84E+03	5.49E+04	2.40E+05	1.09E+05	1.58E+04	6.38E+03	5.73E+03	1.40E+02	1.11E+04
241-S-111	2.19E+05	2.91E+04	2.01E+01	4.06E+03	8.02E+00	1.64E+03	4.73E+04	1.90E+05	7.05E+04	1.28E+04	1.02E+04	4.32E+03	1.05E+02	6.39E+03
241-SX-101	2.42E+05	7.56E+04	3.56E+01	1.21E+04	3.44E+04	2.52E+03	4.87E+04	1.05E+05	7.80E+04	8.05E+03	5.18E+03	1.83E+03	7.14E+01	1.67E+04
241-SX-102	2.35E+05	4.56E+04	3.65E+01	2.77E+03	1.45E+01	3.55E+03	5.01E+04	1.58E+05	1.51E+05	8.80E+03	3.49E+03	3.33E+03	7.80E+01	1.02E+04
241-SX-103	2.37E+05	4.41E+04	3.01E+01	8.36E+01	2.05E+04	4.24E+03	4.15E+04	1.59E+05	1.58E+05	1.28E+04	3.33E+03	2.01E+03	1.01E+02	1.10E+04
241-SX-104	2.50E+05	3.56E+04	3.38E+01	9.39E+02	1.35E+01	2.88E+03	3.42E+04	2.91E+05	1.17E+05	2.48E+04	1.27E+04	3.90E+03	1.87E+02	8.23E+03
241-SX-105	2.36E+05	4.41E+04	3.01E+01	3.38E+02	1.20E+01	3.38E+03	4.09E+04	1.65E+05	1.43E+05	1.41E+04	3.27E+03	4.20E+03	1.04E+02	9.01E+03
241-SX-106	2.45E+05	2.59E+04	3.01E+01	1.30E+02	1.20E+01	3.89E+03	3.31E+04	2.10E+05	1.32E+05	2.56E+04	3.52E+03	7.20E+03	3.11E+02	1.17E+04
241-SX-108	2.27E+05	1.54E+04	4.90E+01	2.97E+02	4.17E+02	2.88E+03	4.14E+04	2.36E+05	9.04E+04	7.00E+04	5.66E+03	1.53E+04	1.91E+03	4.11E+03
241-T-110	3.70E+04	5.00E+00	5.00E+00	3.46E+01	2.00E+00	3.27E+02	5.11E+03	1.83E+04	5.90E+01	7.00E+04	1.49E+03	4.36E+03	4.22E+03	9.58E+02
241-T-203	4.12E+04	5.05E+00	5.05E+00	4.26E+01	2.02E+00	8.39E+03	5.11E+03	7.37E+04	3.53E+02	7.00E+04	1.90E+03	4.69E+02	7.02E+03	7.07E+02
241-U-102	2.43E+05	1.80E+04	2.01E+01	2.79E+02	1.26E+02	3.77E+03	2.93E+04	2.45E+05	1.05E+05	4.68E+04	3.80E+03	9.84E+03	1.33E+02	8.82E+03
241-U-103	2.31E+05	4.09E+04	3.01E+01	1.08E+02	1.69E+02	4.83E+03	3.08E+04	1.52E+05	1.37E+05	1.56E+04	7.64E+02	2.68E+03	1.09E+03	1.14E+04

Table C-1. Input Ion Concentration for NH₃ Calculation. (3 sheets)

Tanks	Na+ in liquid (µg/mL)	Al+3 in liquid (µg/mL)	Fe+3 in liquid (µg/mL)	Cr+3 in liquid (µg/mL)	Ni+2 in liquid (µg/mL)	K+1 in liquid (µg/mL)	OH-1 in liquid (µg/mL)	NO3-1 in liquid (µg/mL)	NO2-1 in liquid (µg/mL)	CO3-2 in liquid (µg/mL)	PO4-3 in liquid (µg/mL)	SO4-2 in liquid (µg/mL)	F-1 in liquid (µg/mL)	Cl-1 in liquid (µg/mL)
241-U-105	2.27E+05	2.98E+04	3.10E+01	2.01E+02	2.48E+02	3.98E+03	2.09E+04	1.81E+05	1.08E+05	2.78E+04	3.92E+03	8.01E+03	1.31E+03	8.92E+03
241-U-106	2.23E+05	1.20E+04	3.93E+01	4.96E+02	5.22E+02	1.89E+03	5.11E+03	2.52E+05	9.90E+04	4.73E+04	3.84E+03	8.64E+03	3.32E+02	5.46E+03
241-U-107	2.21E+05	2.64E+04	3.77E+01	5.75E+02	1.72E+01	3.27E+03	3.61E+04	2.27E+05	1.11E+05	2.65E+04	3.44E+03	6.63E+03	1.67E+02	8.99E+03
241-U-108	2.43E+05	3.29E+04	3.33E+01	1.28E+03	3.13E+01	4.01E+03	4.92E+04	1.81E+05	1.30E+05	2.20E+04	3.13E+03	4.23E+03	7.90E+02	8.94E+03
241-U-109	2.28E+05	2.92E+04	1.00E+02	2.61E+03	4.55E+01	3.33E+03	4.42E+04	1.85E+05	1.28E+05	1.87E+04	3.37E+03	5.17E+03	3.96E+02	8.69E+03

Table C-2. Calculations of Henry's Law Constant by Schumpe Model. (3 sheets)

Tanks	(NH ₃)ss in dome (ppm)	Liquid NH ₃ (µg/mL)	wt% H ₂ O in liquid (%)	Spg in Liquid (g/ml)	Waste Volume (kL)	Head space T(°C)	Waste T (°C)	Sum of ion conc. Sum(Ci) (mole/L)	Sum of ion conc. times ionic coeff. Sum (Ci*Hi) (mole/L)	KHo in water (mole/L-atm)	KH in solns' correction factor	KH in solns' (mole/L-atm)
241-AN-101	11	4.00E+01	70	1.15	606	18	18	8.64	0.82	86.11	1.25	41.96
241-AN-102	300	2.10E+02	48	1.43	4013	29	31	18.10	1.69	46.00	2.03	14.07
241-AN-103	7	3.45E+02	49	1.49	3627	28	38	26.53	2.54	34.01	2.30	4.25
241-AN-104	21	2.46E+02	51	1.40	3986	29	36	22.85	2.24	37.50	2.30	6.17
241-AN-105	15	2.10E+02	50	1.42	4263	28	34	21.62	2.15	40.39	2.26	7.15
241-AN-106	1	2.10E+02	76	1.20	148	18	17	11.59	1.04	88.51	1.38	40.30
241-AN-107	400	2.10E+02	50	1.37	3952	26	29	21.70	1.89	50.41	2.26	16.15
241-AP-101	125	4.39E+02	58	1.31	4221	19	19	13.43	1.22	81.52	1.41	30.97
241-AP-102	75	4.39E+02	75	1.20	4134	20	20	8.15	0.82	77.21	1.23	35.13
241-AP-103	1	2.50E+02	80	1.31	1079	16	16	15.11	1.46	96.18	1.40	24.73
241-AP-104	3	1.33E+02	97	1.29	91	15	15	10.73	1.06	98.90	1.33	37.70
241-AP-105	7	3.24E+02	62	1.35	2896	26	19	19.62	1.84	79.34	1.95	19.84
241-AP-106	5	6.75E+01	94	1.25	352	19	18	9.95	0.99	86.11	1.31	34.54
241-AP-107	5	1.06E+03	87	1.21	3695	17	14	6.67	0.60	101.71	1.17	61.92
241-AP-108	27	8.00E+02	81	1.25	1397	19	16	7.83	0.74	93.55	1.21	49.38
241-AW-101	5	1.00E+01	49	1.47	4263	16	34	24.06	2.31	40.39	2.26	6.46
241-AW-102	3	7.43E+01	88	1.15	303	26	21	4.81	0.44	75.16	1.10	51.68
241-AW-103	138	5.12E+02	93	1.02	1931	27	17	3.09	0.30	88.51	1.10	68.43
241-AW-104	6	1.69E+02	82	1.06	4236	25	21	1.56	0.15	73.16	1.10	68.40
241-AW-105	43	1.01E+03	93	1.02	1624	33	16	1.59	0.12	93.55	1.10	92.16
241-AW-106	28	3.55E+02	59	1.38	1791	33	32	14.42	1.34	44.63	1.60	16.10
241-AY-101	5	1.13E+02	84	1.09	583	30	38	4.15	0.42	34.01	1.00	20.48
241-AY-102	4	7.37E+01	92	1.12	2355	21	37	3.56	0.43	35.19	1.00	19.36
241-AZ-101	1	1.25E+02	72	1.22	3199	27	51	9.52	0.94	19.52	1.67	10.74
241-AZ-102	6	4.38E+02	84	1.14	3524	19	46	4.54	0.47	23.96	1.00	13.29
241-SY-101	400	1.04E+03	61	1.33	3685	30	32	14.89	1.37	43.96	1.63	15.79
241-SY-102	12	1.15E+03	75	1.23	2317	15	22	9.20	0.87	69.34	1.28	32.86

Table C-2. Calculations of Henry's Law Constant by Schumpe Model. (3 sheets)

Tanks	(NH ₃)ss in dome (ppm)	Liquid NH ₃ (µg/mL)	wt% H ₂ O in liquid (%)	Spg in Liquid (g/ml)	Waste Volume (kL)	Head space T(°C)	Waste T (°C)	Sum of ion conc. Sum(Ci) (mole/L)	Sum of ion conc. times ionic coeff. Sum (Ci*Hi) (mole/L)	KH _o in water (mole/L-atm)	KH in solns' correction factor	KH in solns' (mole/L-atm)
241-SY-103	59	1.29E+03	49	1.47	2817	16	31	19.55	1.93	45.77	2.25	10.57
241-A-101	394	5.31E+02	55	1.49	3608	36	60	24.74	2.42	13.69	3.28	2.61
241-A-103	261	5.31E+02	75	1.48	1404	36	58	19.95	1.98	14.96	3.28	4.70
241-AX-101	41	5.41E+02	48	1.49	2832	29	49	25.28	2.42	20.79	2.57	3.32
241-B-203	5	1.00E+02	89	1.17	193	12	12	5.28	0.44	115.89	1.00	76.38
241-B-204	5	1.00E+02	89	1.05	189	14	13	5.11	0.43	107.29	1.00	70.65
241-BY-106	79	1.03E+03	59	1.31	2127	25	49	14.76	1.52	21.17	2.50	8.12
241-C-103	324	1.21E+03	86	1.08	750	38	43	5.43	0.53	27.01	1.17	16.99
241-S-101	765	1.21E+03	63	1.36	1616	31	43	18.34	1.73	26.82	2.27	8.66
241-S-102	588	1.70E+03	50	1.39	1946	27	39	20.10	2.03	32.41	2.31	6.54
241-S-103	149	1.41E+03	50	1.45	939	23	28	20.88	1.96	53.20	2.26	13.35
241-S-106	14	2.40E+02	51	1.46	1613	20	25	22.44	2.12	62.01	2.26	12.86
241-S-111	120	1.50E+03	52	1.40	2044	23	28	18.67	1.79	51.99	2.24	14.83
241-SX-101	4	1.32E+02	49	1.46	1696	38	52	21.14	2.37	19.00	2.57	2.14
241-SX-102	5	1.37E+03	48	1.45	1946	33	55	21.34	2.13	16.63	3.28	4.30
241-SX-103	31	1.80E+03	47	1.47	2400	31	62	21.45	2.17	12.84	3.28	3.10
241-SX-104	5	7.93E+02	51	1.39	1768	29	46	22.36	2.07	23.85	2.57	6.23
241-SX-105	27	1.21E+03	43	1.47	2411	34	63	20.74	2.07	12.06	3.28	3.31
241-SX-106	177	2.50E+03	46	1.42	1601	26	37	20.81	1.96	35.71	2.31	9.06
241-SX-108	5	1.30E+03	47	1.43	329	53	72	20.35	1.88	8.86	4.04	4.48
241-T-110	107	1.50E+03	87	1.17	1465	16	17	3.69	0.41	90.99	1.00	53.35
241-T-203	5	1.00E+02	85	1.17	132	15	17	5.08	0.47	89.83	1.00	53.34
241-U-102	651	7.45E+02	48	1.38	1420	24	28	20.47	1.88	53.34	2.26	15.39
241-U-103	722	1.40E+03	49	1.41	1772	25	28	19.59	1.97	51.99	2.26	11.13

Table C-2. Calculations of Henry's Law Constant by Schumpe Model. (3 sheets)

Tanks	(NH ₃)ss in dome (ppm)	Liquid NH ₃ (µg/mL)	wt% H ₂ O in liquid (%)	Spg in Liquid (g/ml)	Waste Volume (kL)	Head space T(°C)	Waste T (°C)	Sum of ion conc. Sum(Ci) (mole/L)	Sum of ion conc. times ionic coeff. Sum (Ci*Hi) (mole/L)	KHo in water (mole/L-atm)	KH in solns' correction factor	KH in solns' (mole/L-atm)
241-U-105	1936	1.60E+03	69	1.46	1582	25	30	18.50	1.80	48.15	2.10	12.29
241-U-106	940	1.05E+03	49	1.36	856	24	26	17.81	1.60	57.66	2.01	21.04
241-U-107	448	4.03E+02	58	1.41	1545	23	24	19.69	1.82	62.37	2.00	16.58
241-U-108	684	1.05E+03	50	1.40	1772	24	28	21.29	2.06	51.99	2.26	10.70
241-U-109	5	1.10E+03	52	1.47	1760	23	26	20.17	1.93	57.66	2.26	14.45

Table C-3. Calculation of Mass Transport Product of h and A from Normal Ventilation Condition and Prediction for Off-Normal Condition. (3 sheets)

Tanks	Liquid NH ₃ Cl (M/L)	Ammonia Partial P _{NH3} (atm)	Steady State NH ₃ Co (M)	Molar Volume (L/mole)	Normal Vent Q (cfm)	Headspace Volume V (ft ³)	Equiv (NH ₃)ss in Liquid (mole/L)	Product hA from Normal Condition (cfm)	Normal Steady-State Release Rate (cfm)	Off-Normal Barometric Vent Q (cfm)	Off-normal const. k1 (min ⁻¹)	Off-normal const. k2 (mole/L-min)	Off-Normal (NH ₃)ss (atm)	(NH ₃)ss at off-Normal Vent (ppm)	Off-Normal Steady-State Release Rate (cfm)	Time t to reach steady state (day)
241-AN-101	0.002	0.000056	4.73E-07	23.85	113	166,700	0.00047	2.85E-02	1.28E-03	0.52	1.74E-04	4.02E-10	5.50E-05	55	2.86E-05	49
241-AN-102	0.012	0.000876	1.21E-05	24.78	119	46,387	0.00422	1.78E-01	3.57E-02	0.14	1.34E-03	4.72E-08	8.74E-04	874	1.27E-04	5
241-AN-103	0.020	0.004763	2.69E-07	24.69	100	60,023	0.00003	1.33E-03	6.65E-04	0.19	5.46E-06	4.49E-10	2.03E-03	2034	3.82E-04	976
241-AN-104	0.014	0.002339	8.47E-07	24.79	100	47,323	0.00013	5.92E-03	2.10E-03	0.15	2.23E-05	1.81E-09	2.01E-03	2011	2.97E-04	250
241-AN-105	0.012	0.001725	6.14E-07	24.66	100	3756430%	0.00011	5.02E-03	1.51E-03	0.12	2.67E-05	1.65E-09	1.52E-03	1523	1.79E-04	271
241-AN-106	0.012	0.000306	4.19E-08	23.84	117	182,875	0.00004	3.99E-04	1.17E-04	0.57	5.22E-06	2.69E-11	1.23E-04	123	7.02E-05	200
241-AN-107	0.012	0.000763	1.63E-05	24.53	129	48,526	0.00646	3.58E-01	5.16E-02	0.15	2.93E-03	9.11E-08	7.63E-04	763	1.16E-04	1
241-AP-101	0.026	0.000832	5.21E-06	23.98	108	39,035	0.00387	2.57E-02	1.35E-02	0.12	4.92E-04	1.70E-08	8.27E-04	827	1.01E-04	13
241-AP-102	0.026	0.000734	3.13E-06	24.02	135	42,109	0.00264	1.83E-02	1.02E-02	0.13	3.69E-04	1.12E-08	7.28E-04	728	9.57E-05	13
241-AP-103	0.015	0.000594	4.22E-08	23.68	200	149,990	0.00002	5.76E-04	2.00E-04	0.47	5.38E-06	5.64E-11	2.48E-04	248	1.16E-04	822
241-AP-104	0.008	0.000207	1.33E-07	23.64	71	184,881	0.00012	1.23E-03	2.23E-04	0.58	9.04E-06	5.19E-11	1.36E-04	136	7.83E-05	433
241-AP-105	0.019	0.000959	2.99E-07	24.52	176	85,823	0.00015	2.79E-03	1.29E-03	0.27	1.89E-05	6.18E-10	8.00E-04	800	2.15E-04	281
241-AP-106	0.004	0.000115	2.23E-07	23.94	111	175,657	0.00018	6.54E-03	5.92E-04	0.55	3.39E-05	1.48E-10	1.04E-04	104	5.72E-05	96
241-AP-107	0.062	0.001005	2.10E-07	23.81	342	57,616	0.00031	1.16E-03	1.71E-03	0.18	3.28E-05	1.25E-09	9.09E-04	909	1.64E-04	151
241-AP-108	0.047	0.000951	1.11E-06	23.96	129	138,761	0.00131	3.14E-03	3.43E-03	0.43	2.99E-05	1.06E-09	8.52E-04	852	3.69E-04	188
241-AW-101	0.001	0.000091	2.17E-07	23.70	100	37,564	0.00003	3.92E-02	5.15E-04	0.12	1.63E-04	6.13E-10	8.92E-05	89	1.05E-05	22
241-AW-102	0.004	0.000084	1.04E-07	24.55	292	177,394	0.00013	7.16E-03	7.44E-04	0.55	5.44E-05	1.76E-10	7.96E-05	80	4.41E-05	95
241-AW-103	0.030	0.000439	5.59E-06	24.62	134	119,912	0.00942	3.63E-02	1.85E-02	0.37	5.13E-04	9.10E-09	4.37E-04	437	1.64E-04	13
241-AW-104	0.010	0.000145	2.45E-07	24.46	141	38,500	0.00041	3.64E-03	8.46E-04	0.12	1.61E-04	9.37E-10	1.42E-04	142	1.71E-05	25
241-AW-105	0.059	0.000643	1.70E-06	25.10	194	130,740	0.00394	5.97E-03	8.30E-03	0.41	1.09E-04	2.71E-09	6.25E-04	625	2.55E-04	43
241-AW-106	0.021	0.001295	1.11E-06	25.10	158	124,858	0.00045	8.59E-03	4.40E-03	0.39	3.09E-05	1.43E-09	1.16E-03	1164	4.54E-04	184
241-AY-101	0.007	0.000324	2.01E-07	24.87	250	167,502	0.00010	7.69E-03	1.25E-03	0.52	2.65E-05	3.05E-10	2.86E-04	286	1.50E-04	188
241-AY-102	0.004	0.000224	1.78E-07	24.12	250	104,939	0.00008	1.05E-02	1.07E-03	0.33	4.97E-05	4.32E-10	2.09E-04	209	6.87E-05	129
241-AZ-101	0.007	0.000683	4.06E-08	24.61	150	75,129	0.00001	8.32E-04	1.50E-04	0.23	6.05E-06	8.12E-11	3.30E-04	330	7.76E-05	680
241-AZ-102	0.026	0.001936	2.31E-07	23.96	112	63,632	0.00007	1.01E-03	6.19E-04	0.20	8.16E-06	4.07E-10	1.19E-03	1195	2.38E-04	681
241-SY-101	0.061	0.003883	1.61E-05	24.86	486	57,834	0.00632	1.42E-01	1.94E-01	0.18	9.68E-04	1.51E-07	3.87E-03	3870	6.99E-04	8
241-SY-102	0.068	0.002055	4.95E-07	23.59	363	106,276	0.00038	2.67E-03	4.24E-03	0.33	2.26E-05	1.70E-09	1.77E-03	1771	5.88E-04	256

Table C-3. Calculation of Mass Transport Product of h and A from Normal Ventilation Condition and Prediction for Off-Normal Condition. (3 sheets)

Tanks	Liquid NH ₃ Cl (M/L)	Ammonia Partial P _{NH₃} (atm)	Steady State NH ₃ Co (M)	Molar Volume (L/mole)	Normal Vent Q (cfm)	Headspace Volume V (ft ³)	Equiv (NH ₃)ss in Liquid (mole/L)	Product hA from Normal Condition (cfm)	Normal Steady-State Release Rate (cfm)	Off-Normal Barometric Vent Q (cfm)	Off-normal const. k1 (min ⁻¹)	Off-normal const. k2 (mole/L-min)	Off-Normal (NH ₃)ss (atm)	(NH ₃)ss at off-Normal Vent (ppm)	Off-Normal Steady-State Release Rate (cfm)	Time t to reach steady state (day)
241-SY-103	0.076	0.007169	2.50E-06	23.74	116	88,630	0.00063	3.88E-03	6.92E-03	0.28	1.41E-05	3.32E-09	5.58E-03	5581	1.55E-03	487
241-A-101	0.031	0.011934	1.56E-05	25.32	10	48,793	0.00103	5.17E-03	3.94E-03	0.15	1.01E-05	3.30E-09	8.25E-03	8253	1.26E-03	709
241-A-103	0.031	0.006640	1.03E-05	25.32	8	126,596	0.00122	2.61E-03	1.98E-03	0.40	5.58E-06	6.44E-10	2.92E-03	2922	1.16E-03	1058
241-AX-101	0.032	0.009580	1.67E-06	24.77	10	80,208	0.00014	5.29E-04	4.15E-04	0.25	3.67E-06	2.10E-10	1.42E-03	1416	3.55E-04	1668
241-B-203	0.006	0.000077	2.14E-07	23.40	0	1,069	0.00038	1.10E-05	1.41E-06	0.00	2.15E-05	6.03E-11	6.57E-05	66	2.20E-07	187
241-B-204	0.006	0.000083	2.12E-07	23.54	0	1,203	0.00035	1.05E-05	1.36E-06	0.00	1.76E-05	5.10E-11	6.83E-05	68	2.57E-07	171
241-BY-106	0.060	0.007449	3.23E-06	24.46	6	64,969	0.00064	3.18E-04	4.66E-04	0.20	4.10E-06	2.96E-10	1.77E-03	1769	3.59E-04	470
241-C-103	0.071	0.004182	1.27E-05	25.48	10	87,026	0.00550	1.94E-03	3.24E-03	0.27	1.28E-05	1.58E-09	3.16E-03	3159	8.59E-04	470
241-S-101	0.071	0.008203	3.07E-05	24.93	6	83,283	0.00662	2.94E-03	4.72E-03	0.26	1.07E-05	2.51E-09	5.82E-03	5817	1.51E-03	720
241-S-102	0.100	0.015269	2.39E-05	24.64	2	71,653	0.00384	5.47E-04	1.29E-03	0.22	4.35E-06	7.62E-10	4.31E-03	4312	9.66E-04	1450
241-S-103	0.083	0.006203	6.11E-06	24.32	15	107,212	0.00198	1.16E-03	2.28E-03	0.34	6.63E-06	8.95E-10	3.28E-03	3281	1.10E-03	921
241-S-106	0.014	0.001096	5.72E-07	24.08	9	83,417	0.00018	3.78E-04	1.27E-04	0.26	4.53E-06	6.38E-11	3.40E-04	340	8.85E-05	1549
241-S-111	0.088	0.005938	4.94E-06	24.30	5	68,177	0.00178	3.09E-04	6.49E-04	0.21	4.76E-06	4.00E-10	2.04E-03	2041	4.35E-04	1316
241-SX-101	0.008	0.003619	1.48E-07	25.53	40	113,228	0.00001	7.62E-04	1.51E-04	0.35	3.49E-06	5.22E-11	3.81E-04	381	1.35E-04	1206
241-SX-102	0.080	0.018726	1.99E-07	25.10	40	104,405	0.00002	9.91E-05	2.00E-04	0.33	3.23E-06	7.63E-11	5.94E-04	594	1.94E-04	1696
241-SX-103	0.106	0.034140	1.23E-06	24.93	53	88,363	0.00009	6.11E-04	1.61E-03	0.28	3.66E-06	7.30E-10	4.98E-03	4977	1.37E-03	1660
241-SX-104	0.047	0.007472	2.02E-07	24.75	30	110,688	0.00003	1.30E-04	1.50E-04	0.35	3.31E-06	5.48E-11	4.10E-04	410	1.42E-04	1360
241-SX-105	0.071	0.021446	1.07E-06	25.19	40	87,962	0.00009	6.11E-04	1.09E-03	0.27	3.71E-06	4.94E-10	3.36E-03	3358	9.23E-04	1789
241-SX-106	0.147	0.016198	7.22E-06	24.53	39	116,570	0.00160	1.93E-03	6.86E-03	0.36	6.80E-06	2.43E-09	8.75E-03	8752	3.19E-03	962
241-SX-108	0.076	0.017030	1.87E-07	26.76	455	161,486	0.00002	1.11E-03	2.28E-03	0.50	3.95E-06	5.27E-10	3.57E-03	3565	1.80E-03	1463
241-T-110	0.088	0.001651	4.51E-06	23.69	7	61,761	0.00570	3.83E-04	7.48E-04	0.19	1.10E-05	5.47E-10	1.18E-03	1181	2.28E-04	573
241-T-203	0.006	0.000110	2.12E-07	23.59	6	3,208	0.00027	2.28E-04	3.02E-05	0.01	9.27E-05	4.18E-10	1.06E-04	106	1.07E-06	36
241-U-102	0.044	0.002842	2.67E-05	24.36	2	63,365	0.01002	1.66E-03	1.37E-03	0.20	1.30E-05	1.15E-09	2.16E-03	2157	4.27E-04	432
241-U-103	0.082	0.007383	2.95E-05	24.45	2	50,932	0.00804	9.56E-04	1.73E-03	0.16	8.24E-06	1.54E-09	4.58E-03	4582	7.29E-04	838

Table C-3. Calculation of Mass Transport Product of h and A from Normal Ventilation Condition and Prediction for Off-Normal Condition. (3 sheets)

Tanks	Liquid NH ₃ Cl (M/L)	Ammonia Partial P _{NH₃} (atm)	Steady State NH ₃ Co (M)	Molar Volume (L/mole)	Normal Vent Q (cfm)	Headspace Volume V (ft ³)	Equiv (NH ₃)ss in Liquid (mole/L)	Product hA from Normal Condition (cfm)	Normal Steady- State Release Rate (cfm)	Off- Normal Barometric Vent Q (cfm)	Off-normal const. k1 (min-1)	Off-normal const. k2 (mole/L- min)	Off- Normal (NH ₃)ss (atm)	(NH ₃)ss at off- Normal Vent (ppm)	Off-Normal Steady-State Release Rate (cfm)	Time t to reach steady state (day)
241-U-105	0.094	0.007642	7.91E-05	24.47	5	57,616	0.02379	5.64E-03	9.68E-03	0.18	3.26E-05	9.19E-09	6.91E-03	6909	1.24E-03	199
241-U-106	0.062	0.002931	3.86E-05	24.33	1	83,283	0.01977	1.20E-03	1.22E-03	0.26	1.05E-05	8.88E-10	2.06E-03	2058	5.36E-04	521
241-U-107	0.024	0.001428	1.85E-05	24.26	12	58,953	0.00743	1.34E-02	5.27E-03	0.18	9.45E-05	5.37E-09	1.38E-03	1380	2.54E-04	52
241-U-108	0.062	0.005764	2.81E-05	24.36	4	50,932	0.00732	1.87E-03	2.47E-03	0.16	1.27E-05	2.26E-09	4.34E-03	4345	6.92E-04	538
241-U-109	0.065	0.004469	2.06E-07	24.28	4	51,333	0.00007	1.37E-05	2.14E-05	0.16	3.22E-06	1.72E-11	1.30E-04	130	2.08E-05	1423

This page intentionally left blank.

APPENDIX D

**CALCULATION RESULTS OF STEADY-STATE FLAMMABILITY EVALUATIONS
IN TANK DOME SPACES FOR 177 HANFORD TANKS**

This page intentionally left blank.

CONTENTS

Table D-1	Steady-State Gas Concentrations, Release Rates and Flammability Levels Under Normal Ventilation Conditions.....	D-1
Table D-2	Steady-State Gas Concentrations and Flammability Levels Under Barometric Breathing Ventilation Conditions	D-6
Table D-3	Time to Reach 25% of the LFL and Flammability Distribution Among Gases Under Barometric Breathing Ventilation.....	D-11
Table D-4	Time to Reach 100% of the LFL and Flammability Distribution Among Gases Under Barometric Breathing Ventilation.....	D-16
Table D-5	Flammability and Time to LFL at Zero Ventilation Under DSA Conditions.....	D-21

This page intentionally left blank.

Table D-1. Steady-State Gas Concentrations, Release Rates and Flammability Levels Under Normal Ventilation Conditions. (5 sheets)

Tank	Ammonia headspace concn. [NH ₃] (%)	Methane headspace concn. [CH ₄] (%)	N ₂ O headspace concn. [N ₂ O] (%)	Waste volume Vw (kgal)	Headspace volume Vh (ft ³)	Normal ventilation rate (Vr)norm (cfm)	Steady-state flammability at normal condition (% LFL)	Ammonia release rate Rr(NH ₃) (cfm)	N ₂ O release rate Rr(N ₂ O) (cfm)	Model hydrogen release rate Rr(H ₂) (cfm)	Methane release rate Rr(CH ₄) (cfm)
241-AN-101	0.0011	0.0002	0.0011	1153	33,988	113.0	0.07%	1.28E-03	1.20E-03	2.55E-03	1.92E-04
241-AN-102	0.0300	0.0003	0.0053	1,075	44,440	119.0	0.50%	3.57E-02	6.31E-03	1.41E-02	3.19E-04
241-AN-103	0.0007	0.0002	0.0007	968	58,671	100.0	0.10%	6.65E-04	6.50E-04	3.58E-03	2.05E-04
241-AN-104	0.0021	0.0002	0.0007	1,062	46,100	100.0	0.13%	2.10E-03	7.09E-04	4.34E-03	1.95E-04
241-AN-105	0.0015	0.0002	0.0013	1,136	36,283	100.0	0.08%	1.51E-03	1.28E-03	2.68E-03	2.20E-04
241-AN-106	0.0000	0.0000	0.0002	717	92,289	117.0	0.15%	0.00E+00	2.32E-04	7.06E-03	7.06E-04
241-AN-107	0.0400	0.0005	0.0053	1,111	39,532	129.0	0.48%	5.16E-02	6.84E-03	1.05E-02	6.29E-04
241-AP-101	0.0125	0.0003	0.0061	1,165	32,293	108.0	0.10%	1.35E-02	6.63E-03	5.77E-04	1.15E-04
241-AP-102	0.0075	0.0002	0.0048	1,103	40,662	135.0	0.08%	1.02E-02	6.50E-03	1.55E-03	3.09E-04
241-AP-103	0.0000	0.0000	0.0008	770	85,191	200.0	0.03%	0.00E+00	1.70E-03	2.26E-03	8.58E-05
241-AP-104	0.0003	0.00001	0.0002	1,108	40,026	71.0	0.07%	2.23E-04	1.43E-04	1.84E-03	7.23E-06
241-AP-105	0.0007	0.0001	0.0026	1,146	34,835	176.0	0.02%	1.29E-03	4.55E-03	9.71E-04	1.94E-04
241-AP-106	0.0005	0.00003	0.0005	1,146	34,871	111.0	0.04%	5.92E-04	5.53E-04	1.67E-03	2.80E-05
241-AP-107	0.0005	0.0001	0.0017	1,139	35,824	342.0	0.01%	1.71E-03	5.81E-03	6.59E-04	1.32E-04
241-AP-108	0.0027	0.0000	0.0017	1,257	20,075	129.0	0.05%	3.43E-03	2.20E-03	1.56E-03	1.11E-05
241-AW-101	0.0005	0.0002	0.0007	1,137	36,036	100.0	0.10%	5.15E-04	7.29E-04	3.63E-03	1.56E-04
241-AW-102	0.0003	0.0000	0.0002	1,090	42,357	292.0	0.01%	7.44E-04	4.76E-04	1.15E-03	2.41E-05
241-AW-103	0.0138	0.0004	0.0009	1,106	40,238	134.0	0.12%	1.85E-02	1.23E-03	9.85E-04	1.97E-04
241-AW-104	0.0006	0.0007	0.0009	1,079	43,805	141.0	0.06%	8.46E-04	1.30E-03	2.39E-03	4.79E-04
241-AW-105	0.0043	0.0002	0.0009	427	131,027	194.0	0.04%	8.30E-03	1.78E-03	7.03E-04	1.41E-04
241-AW-106	0.0028	0.0001	0.0018	1,142	35,365	158.0	0.04%	4.40E-03	2.81E-03	1.50E-03	1.42E-04
241-AY-101	0.0005	0.0001	0.0009	842	75,551	250.0	0.06%	1.25E-03	2.21E-03	5.49E-03	1.42E-04
241-AY-102	0.0004	0.0001	0.0010	1,009	53,162	250.0	0.27%	1.07E-03	2.50E-03	2.66E-02	3.61E-04
241-AZ-101	0.0001	0.0005	0.0010	852	74,173	150.0	0.29%	1.88E-04	1.50E-03	1.65E-02	7.79E-04
241-AZ-102	0.0006	0.0008	0.0010	963	59,342	112.0	0.81%	6.19E-04	1.12E-03	3.56E-02	8.58E-04
241-SY-101	0.0200	0.0001	0.0005	1,114	39,143	461.0	0.14%	9.22E-02	2.46E-03	7.37E-04	1.47E-04
241-SY-102	0.0012	0.0004	0.0005	483	123,505	363.0	0.02%	4.24E-03	1.95E-03	1.15E-03	2.30E-04
241-SY-103	0.0059	0.0003	0.0016	749	87,981	116.4	0.13%	6.92E-03	1.87E-03	3.81E-03	3.15E-04
241-A-101*	0.0394	0.0006	0.0134	335	131,294	10.0	0.62%	3.94E-03	1.34E-03	1.39E-03	5.51E-05
241-A-102	0.0254	0.0002	0.0224	50	169,386	7.6	0.30%	1.93E-03	1.71E-03	3.76E-04	1.31E-05
241-A-103*	0.0261	0.0004	0.0220	389	124,080	10.0	0.54%	2.61E-03	2.20E-03	1.42E-03	3.92E-05
241-A-104	0.0005	0.0003	0.0040	38	170,975	10.0	0.07%	5.00E-05	4.02E-04	2.32E-04	2.58E-05
241-A-105	na	na	na	na	na	na	na	na	na	na	na
241-A-106	0.0275	0.0012	0.0198	89	164,160	10.0	0.70%	2.75E-03	1.98E-03	1.98E-03	1.15E-04
241-AX-101*	0.0041	0.0002	0.0006	367	129,213	28.3	0.12%	1.17E-03	1.81E-04	1.03E-03	5.95E-05
241-AX-102	0.0034	0.0001	0.0050	40	173,001	16.5	0.12%	5.55E-04	8.23E-04	6.68E-04	9.04E-06

Table D-1. Steady-State Gas Concentrations, Release Rates and Flammability Levels Under Normal Ventilation Conditions. (5 sheets)

Tank	Ammonia headspace concn. [NH ₃] (%)	Methane headspace concn. [CH ₄] (%)	N ₂ O headspace concn. [N ₂ O] (%)	Waste volume V _w (kgal)	Headspace volume V _h (ft ³)	Normal ventilation rate (V _r)norm (cfm)	Steady-state flammability at normal condition (% LFL)	Ammonia release rate R _r (NH ₃) (cfm)	N ₂ O release rate R _r (N ₂ O) (cfm)	Model hydrogen release rate R _r (H ₂) (cfm)	Methane release rate R _r (CH ₄) (cfm)
241-AX-103	0.0041	0.0002	0.0024	116	162,760	24.7	0.12%	1.02E-03	5.85E-04	8.96E-04	4.94E-05
241-AX-104	0.0007	0.0001	0.0016	17	176,002	7.0	1.84%	5.18E-05	1.15E-04	5.12E-03	7.37E-06
241-B-101	0.0013	0.0004	0.0086	119	97,777	7.8	0.15%	9.81E-05	6.72E-04	4.14E-04	3.40E-05
241-B-102	0.0005	0.0001	0.0063	42	108,018	7.0	0.09%	3.28E-05	4.40E-04	2.41E-04	9.64E-06
241-B-103	0.0008	0.0003	0.0061	66	104,839	7.0	0.10%	5.82E-05	4.26E-04	2.40E-04	1.78E-05
241-B-104	0.0005	0.0049	0.0076	384	62,253	7.0	0.23%	3.50E-05	5.31E-04	3.60E-04	7.19E-05
241-B-105	0.0012	0.0005	0.0092	300	73,517	7.0	0.13%	8.40E-05	6.45E-04	3.19E-04	3.27E-05
241-B-106	0.0005	0.0015	0.0240	133	95,905	7.0	0.14%	3.50E-05	1.68E-03	3.08E-04	6.15E-05
241-B-107	0.0021	0.0007	0.0017	171	90,714	7.0	0.13%	1.47E-04	1.19E-04	2.85E-04	4.95E-05
241-B-108	0.0034	0.0004	0.0087	102	99,931	7.0	0.12%	2.40E-04	6.08E-04	2.55E-04	3.00E-05
241-B-109	0.0042	0.0006	0.0117	135	95,517	7.0	0.13%	2.92E-04	8.21E-04	2.63E-04	4.05E-05
241-B-110	0.0050	0.0032	0.0050	255	79,485	7.0	0.29%	3.50E-04	3.49E-04	5.39E-04	1.08E-04
241-B-111	0.0025	0.0058	0.0090	251	80,015	3.5	0.78%	8.79E-05	3.15E-04	9.12E-04	1.82E-04
241-B-112	0.0031	0.0004	0.0068	45	107,629	7.0	0.13%	2.14E-04	4.74E-04	2.83E-04	3.04E-05
241-B-201	0.0005	0.0004	0.0006	30	3,887	7.0	0.03%	3.50E-05	4.16E-05	5.92E-05	1.18E-05
241-B-202	0.0003	0.0003	0.0017	30	3,993	7.2	0.03%	1.92E-05	1.23E-04	5.60E-05	1.12E-05
241-B-203*	0.0005	0.0007	0.0105	51	1,097	0.3	1.77%	1.41E-06	2.95E-05	1.98E-04	1.89E-06
241-B-204*	0.0005	0.0007	0.0103	50	1,203	0.3	1.87%	1.36E-06	2.79E-05	2.02E-04	1.79E-06
241-BX-101	0.0050	0.0006	0.0088	58	105,800	7.0	0.15%	3.50E-04	6.17E-04	2.92E-04	3.96E-05
241-BX-102	0.0003	0.0013	0.0017	89	101,634	7.0	0.17%	1.79E-05	1.19E-04	3.93E-04	7.85E-05
241-BX-103	0.0090	0.0009	0.0079	85	102,093	7.0	0.36%	6.27E-04	5.52E-04	7.88E-04	6.54E-05
241-BX-104	0.0212	0.0010	0.0130	110	98,738	8.7	0.27%	1.85E-03	1.14E-03	3.71E-04	7.42E-05
241-BX-105	0.0145	0.0006	0.0116	82	102,552	8.5	0.19%	1.23E-03	9.76E-04	2.93E-04	4.70E-05
241-BX-106	0.0047	0.0005	0.0043	48	107,107	7.0	0.17%	3.26E-04	3.02E-04	3.71E-04	3.50E-05
241-BX-107	0.0082	0.0004	0.0012	357	65,791	7.0	0.21%	5.74E-04	8.34E-05	4.05E-04	2.75E-05
241-BX-108	0.0024	0.0003	0.0053	41	107,955	7.0	0.12%	1.68E-04	3.73E-04	2.61E-04	2.40E-05
241-BX-109	0.0020	0.0025	0.0396	203	86,379	7.0	0.25%	1.40E-04	2.77E-03	5.27E-04	1.05E-04
241-BX-110	0.0063	0.0008	0.0017	224	83,483	7.0	0.20%	4.40E-04	1.19E-04	3.93E-04	5.57E-05
241-BX-111	0.0062	0.0002	0.0017	198	86,979	7.0	0.15%	4.35E-04	1.19E-04	2.91E-04	1.15E-05
241-BX-112	0.0122	0.0022	0.0339	174	90,192	7.0	0.24%	8.51E-04	2.37E-03	3.37E-04	6.74E-05
241-BY-101	0.0059	0.0010	0.0056	380	89,455	7.0	0.28%	4.15E-04	3.91E-04	6.25E-04	6.80E-05
241-BY-102	0.0173	0.0004	0.0017	288	101,673	7.0	0.25%	1.21E-03	1.22E-04	3.50E-04	2.75E-05
241-BY-103	0.0029	0.0002	0.0017	423	83,664	14.4	0.10%	4.12E-04	2.43E-04	4.32E-04	2.75E-05
241-BY-104	0.0259	0.0007	0.0250	415	84,758	7.6	0.41%	1.98E-03	1.92E-03	6.98E-04	5.41E-05
241-BY-105	0.0083	0.0004	0.0076	491	74,588	15.9	0.15%	1.32E-03	1.21E-03	5.44E-04	6.93E-05
241-BY-106*	0.0079	0.0005	0.0132	439	81,580	5.9	0.41%	4.64E-04	7.75E-04	8.28E-04	2.89E-05

Table D-1. Steady-State Gas Concentrations, Release Rates and Flammability Levels Under Normal Ventilation Conditions. (5 sheets)

Tank	Ammonia headspace concn. [NH ₃] (%)	Methane headspace concn. [CH ₄] (%)	N ₂ O headspace concn. [N ₂ O] (%)	Waste volume Vw (kgal)	Headspace volume Vh (ft ³)	Normal ventilation rate (Vr)norm (cfm)	Steady-state flammability at normal condition (% LFL)	Ammonia release rate Rr(NH ₃) (cfm)	N ₂ O release rate Rr(N ₂ O) (cfm)	Model hydrogen release rate Rr(H ₂) (cfm)	Methane release rate Rr(CH ₄) (cfm)
241-BY-107	0.0962	0.0010	0.0704	282	102,591	5.2	0.91%	5.03E-03	3.68E-03	5.27E-04	5.20E-05
241-BY-108	0.0870	0.0008	0.0553	232	109,195	6.8	0.79%	5.88E-03	3.74E-03	5.15E-04	5.16E-05
241-BY-109	0.0045	0.0002	0.0011	297	100,543	14.7	0.09%	6.57E-04	1.57E-04	3.45E-04	3.11E-05
241-BY-110	0.0397	0.0003	0.0102	376	90,020	13.3	0.53%	5.30E-03	1.37E-03	1.39E-03	4.36E-05
241-BY-111	0.0059	0.0003	0.0082	412	85,112	6.0	0.20%	3.51E-04	4.93E-04	3.82E-04	1.65E-05
241-BY-112	0.0063	0.0001	0.0039	296	100,649	13.6	0.11%	8.55E-04	5.34E-04	3.51E-04	1.72E-05
241-C-101	0.0098	0.0012	0.0636	98	100,531	3.6	0.32%	3.52E-04	2.29E-03	3.38E-04	4.30E-05
241-C-102	0.0187	0.0008	0.0141	326	70,057	11.8	0.24%	2.20E-03	1.66E-03	4.84E-04	9.69E-05
241-C-103*	0.0324	0.0016	0.0737	13	111,952	10.0	0.39%	3.24E-03	7.37E-03	5.75E-04	1.15E-04
241-C-104	0.0044	0.0004	0.0063	269	77,684	67.1	0.10%	2.96E-03	4.24E-03	1.63E-03	2.72E-04
241-C-105	0.0002	0.0000	0.0005	142	94,634	535.0	0.01%	1.29E-03	2.81E-03	9.06E-04	1.24E-04
241-C-106	0.0002	0.0001	0.0004	13	111,920	176.1	0.02%	4.38E-04	6.49E-04	9.93E-04	9.86E-05
241-C-107	0.0066	0.0010	0.0096	257	79,273	1.1	6.81%	7.24E-05	1.05E-04	2.97E-03	1.08E-05
241-C-108	0.0003	0.0000	0.0178	35	108,936	7.0	0.10%	1.84E-05	1.25E-03	2.80E-04	2.17E-06
241-C-109	0.0010	0.0001	0.0365	73	103,815	13.0	0.16%	1.30E-04	4.76E-03	7.95E-04	1.19E-05
241-C-110	0.0123	0.0031	0.0014	188	88,490	7.9	0.38%	9.69E-04	1.08E-04	7.32E-04	1.46E-04
241-C-111	0.0004	0.0001	0.0053	67	104,628	7.0	0.55%	2.74E-05	3.73E-04	1.53E-03	3.54E-06
241-C-112	0.0023	0.0001	0.0538	114	98,413	11.2	0.35%	2.52E-04	6.02E-03	1.48E-03	1.12E-05
241-C-201	0.0001	0.0000	0.0007	1.14	7,788	3.9	0.03%	4.02E-06	2.87E-05	4.48E-05	1.84E-06
241-C-202	0.0001	0.0000	0.0004	1.15	7,787	3.6	0.03%	2.48E-06	1.44E-05	4.54E-05	9.22E-07
241-C-203	0.0005	0.0001	0.0010	1.14	7,788	7.0	0.02%	3.23E-05	7.18E-05	4.26E-05	4.61E-06
241-C-204	0.0001	0.0001	0.0014	1	7,789	3.0	0.04%	2.18E-06	4.31E-05	4.29E-05	2.76E-06
241-S-101*	0.0765	0.0007	0.0197	362	91,990	6.2	0.93%	4.72E-03	1.21E-03	9.98E-04	4.36E-05
241-S-102*	0.0588	0.0008	0.0394	70	130,940	2.2	0.76%	1.29E-03	8.68E-04	3.07E-04	1.83E-05
241-S-103*	0.0149	0.0005	0.0135	247	107,386	15.3	0.19%	2.28E-03	2.06E-03	4.90E-04	6.96E-05
241-S-104	0.0025	0.0047	0.0073	298	100,536	5.6	0.38%	1.40E-04	4.10E-04	6.13E-04	1.23E-04
241-S-105	0.0036	0.0002	0.0008	416	84,786	16.7	0.08%	6.00E-04	1.25E-04	3.73E-04	3.84E-05
241-S-106*	0.0014	0.0016	0.0006	465	78,183	9.2	0.18%	1.27E-04	5.11E-05	5.24E-04	1.05E-04
241-S-107	0.0181	0.0010	0.0184	368	91,142	4.4	0.55%	7.93E-04	8.08E-04	7.16E-04	4.45E-05
241-S-108	0.0025	0.0001	0.0003	560	65,506	7.0	0.17%	1.77E-04	2.08E-05	4.30E-04	7.66E-06
241-S-109	0.0025	0.0196	0.0021	543	67,801	7.0	0.56%	1.74E-04	1.48E-04	4.28E-04	8.55E-05
241-S-110	0.0146	0.0005	0.0039	399	87,011	10.4	0.25%	1.52E-03	4.07E-04	5.89E-04	5.19E-05
241-S-111*	0.0120	0.0003	0.0021	411	85,457	5.4	0.38%	6.49E-04	1.14E-04	6.41E-04	1.50E-05
241-S-112	0.0088	0.0003	0.0006	12	138,707	4.0	0.48%	3.52E-04	2.53E-05	6.58E-04	1.05E-05
241-SX-101*	0.0004	0.0002	0.0007	428	116,110	40.0	0.05%	1.51E-04	2.74E-04	6.78E-04	6.57E-05
241-SX-102*	0.0000	0.0002	0.0006	351	126,421	40.0	0.09%	0.00E+00	2.40E-04	1.45E-03	8.00E-05

Table D-1. Steady-State Gas Concentrations, Release Rates and Flammability Levels Under Normal Ventilation Conditions. (5 sheets)

Tank	Ammonia headspace concn. [NH ₃] (%)	Methane headspace concn. [CH ₄] (%)	N ₂ O headspace concn. [N ₂ O] (%)	Waste volume Vw (kgal)	Headspace volume Vh (ft ³)	Normal ventilation rate (Vr)norm (cfm)	Steady-state flammability at normal condition (% LFL)	Ammonia release rate Rr(NH ₃) (cfm)	N ₂ O release rate Rr(N ₂ O) (cfm)	Model hydrogen release rate Rr(H ₂) (cfm)	Methane release rate Rr(CH ₄) (cfm)
241-SX-103*	0.0031	0.0005	0.0010	519	104,033	52.5	0.29%	1.61E-03	5.41E-04	5.39E-03	2.38E-04
241-SX-104*	0.0005	0.0002	0.0007	456	112,437	30.0	0.15%	1.50E-04	2.00E-04	1.71E-03	6.53E-05
241-SX-105*	0.0027	0.0002	0.0008	386	121,831	40.5	0.40%	1.09E-03	3.38E-04	6.09E-03	7.38E-05
241-SX-106*	0.0177	0.0003	0.0023	407	119,041	38.8	0.17%	6.86E-03	9.10E-04	7.48E-04	1.07E-04
241-SX-107	0.0002	0.0000	0.0004	104	159,474	387.0	0.01%	6.73E-04	1.49E-03	1.49E-03	9.58E-05
241-SX-108*	0.0001	0.0000	0.0003	84	162,157	455.0	0.01%	5.63E-04	1.25E-03	1.06E-03	8.02E-05
241-SX-109	0.0017	0.0001	0.0009	251	139,805	30.0	0.23%	5.05E-04	2.72E-04	2.58E-03	3.75E-05
241-SX-110	0.0001	0.0000	0.0003	66	164,559	293.0	0.03%	4.01E-04	8.90E-04	3.05E-03	5.71E-05
241-SX-111	0.0003	0.0000	0.0007	125	156,649	264.0	0.03%	7.89E-04	1.75E-03	2.62E-03	1.12E-04
241-SX-112	0.0003	0.0000	0.0007	85	162,052	225.0	0.02%	6.99E-04	1.55E-03	1.15E-03	9.95E-05
241-SX-113	0.0029	0.0004	0.0064	29	169,502	7.0	0.12%	2.01E-04	4.45E-04	2.48E-04	2.86E-05
241-SX-114	0.0004	0.0001	0.0008	165	151,281	325.0	0.02%	1.17E-03	2.60E-03	2.54E-03	1.67E-04
241-SX-115	0.0003	0.0002	0.0025	14	171,480	7.0	0.64%	1.75E-05	1.72E-04	1.77E-03	1.11E-05
241-T-101	0.0022	0.0004	0.0050	109	99,013	7.0	0.13%	1.52E-04	3.47E-04	2.97E-04	2.76E-05
241-T-102	0.0005	0.0004	0.0066	42	108,053	7.0	0.22%	3.50E-05	4.59E-04	5.91E-04	2.95E-05
241-T-103	0.0005	0.0004	0.0055	37	108,689	7.0	0.09%	3.50E-05	3.88E-04	2.33E-04	2.49E-05
241-T-104	0.0104	0.0004	0.0008	327	69,951	7.0	0.21%	7.30E-04	5.26E-05	3.60E-04	2.75E-05
241-T-105	0.0094	0.0013	0.0201	108	99,189	7.0	0.20%	6.60E-04	1.41E-03	3.18E-04	6.37E-05
241-T-106	0.0100	0.0003	0.0043	32	109,395	7.0	0.15%	7.00E-04	3.01E-04	2.31E-04	1.94E-05
241-T-107	0.0123	0.0023	0.0041	183	89,161	6.4	0.30%	7.85E-04	2.62E-04	4.32E-04	8.65E-05
241-T-108	0.0020	0.0002	0.0041	26	110,172	7.0	0.10%	1.40E-04	2.85E-04	2.27E-04	1.40E-05
241-T-109	0.0005	0.0002	0.0049	72	103,992	7.0	0.09%	3.50E-05	3.45E-04	2.41E-04	1.75E-05
241-T-110*	0.0107	0.0002	0.0015	380	62,853	7.0	0.39%	7.48E-04	1.02E-04	8.72E-04	1.70E-05
241-T-111	0.0223	0.0058	0.0013	457	52,577	6.0	0.44%	1.35E-03	7.64E-05	4.22E-04	8.45E-05
241-T-112	0.0029	0.0009	0.0137	77	103,392	7.0	0.13%	2.01E-04	9.62E-04	2.47E-04	4.94E-05
241-T-201	0.0001	0.0004	0.0059	31	3,746	7.0	0.06%	7.00E-06	4.16E-04	1.43E-04	2.67E-05
241-T-202	0.0002	0.0003	0.0043	21	5,088	7.0	0.02%	1.60E-05	3.01E-04	4.44E-05	8.88E-06
241-T-203*	0.0000	0.0085	0.1318	37	3,004	0.4	0.60%	0.00E+00	5.02E-04	6.53E-05	1.31E-05
241-T-204	0.0001	0.0005	0.0078	37	3,004	7.0	0.03%	8.75E-06	5.45E-04	6.54E-05	1.31E-05
241-TX-101	0.0014	0.0011	0.0050	101	126,745	7.0	0.17%	9.65E-05	3.47E-04	3.88E-04	7.76E-05
241-TX-102	0.0168	0.0002	0.0054	227	109,901	11.5	0.19%	1.93E-03	6.28E-04	3.39E-04	2.24E-05
241-TX-103	0.0107	0.0003	0.0086	155	119,541	7.0	0.18%	7.49E-04	6.05E-04	3.00E-04	2.20E-05
241-TX-104	0.0028	0.0006	0.0050	79	129,641	3.5	0.25%	9.83E-05	1.73E-04	3.11E-04	2.07E-05
241-TX-105	0.0020	0.0001	0.0013	586	61,876	14.4	0.10%	2.83E-04	1.82E-04	4.75E-04	1.98E-05
241-TX-106	0.0252	0.0007	0.0050	358	92,351	7.0	0.33%	1.77E-03	3.47E-04	4.18E-04	4.69E-05
241-TX-107	0.0204	0.0002	0.0031	40	134,938	7.0	0.23%	1.43E-03	2.14E-04	2.46E-04	1.08E-05

Table D-1. Steady-State Gas Concentrations, Release Rates and Flammability Levels Under Normal Ventilation Conditions. (5 sheets)

Tank	Ammonia headspace concn. [NH ₃] (%)	Methane headspace concn. [CH ₄] (%)	N ₂ O headspace concn. [N ₂ O] (%)	Waste volume V _w (kgal)	Headspace volume V _h (ft ³)	Normal ventilation rate (V _r)norm (cfm)	Steady-state flammability at normal condition (% LFL)	Ammonia release rate Rr(NH ₃) (cfm)	N ₂ O release rate Rr(N ₂ O) (cfm)	Model hydrogen release rate Rr(H ₂) (cfm)	Methane release rate Rr(CH ₄) (cfm)
241-TX-108	0.0025	0.0001	0.0022	136	122,013	9.0	0.10%	2.21E-04	1.99E-04	2.78E-04	1.01E-05
241-TX-109	0.0400	0.0043	0.0668	373	90,338	7.0	0.55%	2.80E-03	4.68E-03	5.43E-04	1.09E-04
241-TX-110	0.0974	0.0003	0.0129	477	76,425	7.0	0.80%	6.82E-03	9.01E-04	4.17E-04	2.12E-05
241-TX-111	0.0605	0.0002	0.0175	375	90,126	9.7	0.50%	5.88E-03	1.70E-03	3.77E-04	1.87E-05
241-TX-112	0.0112	0.0007	0.0050	643	54,213	7.0	0.26%	7.84E-04	3.47E-04	4.75E-04	4.57E-05
241-TX-113	0.0021	0.0004	0.0050	648	53,578	9.3	0.14%	1.99E-04	4.61E-04	4.50E-04	3.46E-05
241-TX-114	0.0160	0.0002	0.0040	541	67,844	12.0	0.20%	1.93E-03	4.79E-04	4.12E-04	2.43E-05
241-TX-115	0.0014	0.0002	0.0046	563	64,983	10.0	0.12%	1.38E-04	4.58E-04	4.36E-04	2.32E-05
241-TX-116	0.0014	0.0012	0.0050	608	58,945	3.1	0.38%	4.34E-05	1.55E-04	4.28E-04	3.69E-05
241-TX-117	0.0014	0.0003	0.0050	490	74,730	6.5	0.16%	8.97E-05	3.22E-04	3.88E-04	1.87E-05
241-TX-118	0.0036	0.0022	0.0018	257	105,875	10.0	0.19%	3.57E-04	1.80E-04	4.75E-04	9.50E-05
241-TY-101	0.0016	0.0003	0.0097	128	123,242	3.2	0.22%	5.23E-05	3.15E-04	2.62E-04	8.38E-06
241-TY-102	0.0004	0.0003	0.0066	79	129,774	7.0	0.10%	2.84E-05	4.65E-04	2.51E-04	1.93E-05
241-TY-103	0.0045	0.0015	0.0198	165	118,368	8.2	0.18%	3.73E-04	1.63E-03	3.82E-04	7.64E-05
241-TY-104	0.0059	0.0003	0.0097	54	133,094	13.4	0.10%	7.87E-04	1.30E-03	2.80E-04	4.24E-05
241-TY-105	0.0003	0.0023	0.0051	241	108,163	7.0	0.23%	1.75E-05	3.54E-04	5.11E-04	1.02E-04
241-TY-106	0.0019	0.0003	0.0043	26	136,837	7.0	0.11%	1.36E-04	3.01E-04	2.57E-04	1.94E-05
241-U-101	0.0100	0.0003	0.0051	33	109,218	7.0	0.19%	7.00E-04	3.59E-04	3.26E-04	2.30E-05
241-U-102*	0.0651	0.0012	0.0805	337	68,574	2.1	1.51%	1.37E-03	1.69E-03	8.87E-04	2.47E-05
241-U-103*	0.0722	0.0014	0.0761	427	56,567	2.4	1.66%	1.73E-03	1.83E-03	1.10E-03	3.37E-05
241-U-104	0.0001	0.0006	0.0085	64	105,051	7.0	0.12%	4.88E-06	5.96E-04	3.07E-04	3.89E-05
241-U-105*	0.1936	0.0039	0.1324	363	65,113	5.0	1.83%	9.68E-03	6.62E-03	9.14E-04	1.83E-04
241-U-106*	0.0940	0.0052	0.0554	180	89,549	1.3	2.44%	1.22E-03	7.20E-04	8.88E-04	6.81E-05
241-U-107*	0.0448	0.0010	0.0445	304	72,988	11.8	0.42%	5.27E-03	5.23E-03	4.97E-04	9.94E-05
241-U-108*	0.0684	0.0011	0.0485	443	54,343	3.6	1.11%	2.47E-03	1.75E-03	9.11E-04	3.94E-05
241-U-109*	0.0005	0.0010	0.0499	411	58,686	4.3	0.41%	2.14E-05	2.14E-03	6.59E-04	4.45E-05
241-U-110	0.0225	0.0091	0.1418	186	88,808	1.9	1.00%	4.24E-04	2.67E-03	5.01E-04	1.00E-04
241-U-111	0.0669	0.0012	0.0324	232	82,628	1.9	1.08%	1.27E-03	6.15E-04	4.65E-04	2.27E-05
241-U-112	0.0301	0.0035	0.0203	55	106,217	1.3	0.88%	3.85E-04	2.60E-04	3.10E-04	4.52E-05
241-U-201	0.0005	0.0001	0.0010	5	7,277	7.0	0.01%	3.23E-05	7.18E-05	2.57E-05	4.61E-06
241-U-202	0.0005	0.0001	0.0010	5	7,312	7.0	0.01%	3.23E-05	7.18E-05	2.16E-05	4.33E-06
241-U-203	0.0001	0.0001	0.0021	4	7,348	2.1	0.03%	1.77E-06	4.31E-05	2.52E-05	2.76E-06
241-U-204	0.0000	0.0000	0.0004	4	7,418	10.2	0.01%	1.35E-06	4.31E-05	5.13E-05	2.76E-06

Notes:

¹DSA conditions are current waste plus water additions of 10 kgal to 100-series or 1 kgal to 200-series tanks, and a 5 °C temperature increase for DSTs.²For all DSTs and SSTs with "*" the ammonia was analyzed with equilibrium model.

Table D-2. Steady-State Gas Concentrations and Flammability Levels Under Barometric Breathing Ventilation Conditions. (5 sheets)

Tank	Off-Normal Barometric Breathing Rate (Vr)bb (cfm)	Steady State Hydrogen Concen. [H ₂] (%)	Steady State Ammonia Concen. [NH ₃] (%)	Steady State Methane Concen. [CH ₄] (%)	Steady State N ₂ O Concen. [N ₂ O] (%)	Steady State Hydrogen Flammability (%)	Steady State Ammonia Flammability (%)	Steady State Methane Flammability (%)	Steady State Total Flammability (%)
241-AN-101	0.11	2.40	0.01	0.18	1.13	60	0.04	3.61	63.7
241-AN-102	0.14	10.13	0.09	0.23	4.54	253	0.58	4.60	258.4
241-AN-103	0.18	1.95	0.20	0.11	0.35	49	1.36	2.23	52.3
241-AN-104	0.14	3.01	0.20	0.14	0.49	75	1.34	2.71	79.3
241-AN-105	0.11	2.36	0.15	0.19	1.13	59	1.02	3.88	63.9
241-AN-106	0.29	2.45	0.01	0.24	0.08	61	0.08	4.90	66.2
241-AN-107	0.12	8.46	0.08	0.51	5.53	212	0.51	10.18	222.3
241-AP-101	0.10	0.57	0.08	0.11	6.57	14	0.55	2.29	17.1
241-AP-102	0.13	1.22	0.07	0.24	5.11	30	0.49	4.87	35.8
241-AP-103	0.27	0.85	0.02	0.03	0.64	21	0.17	0.64	22.0
241-AP-104	0.13	1.47	0.01	0.01	0.11	37	0.09	0.12	36.9
241-AP-105	0.11	0.89	0.08	0.18	4.18	22	0.53	3.57	26.4
241-AP-106	0.11	1.53	0.01	0.03	0.51	38	0.07	0.51	38.9
241-AP-107	0.11	0.59	0.09	0.12	5.19	15	0.61	2.36	17.7
241-AP-108	0.06	2.49	0.09	0.02	3.50	62	0.57	0.35	63.1
241-AW-101	0.11	3.23	0.01	0.14	0.65	81	0.06	2.76	83.5
241-AW-102	0.13	0.87	0.01	0.02	0.36	22	0.05	0.36	22.1
241-AW-103	0.13	0.78	0.04	0.16	0.98	20	0.29	3.13	23.0
241-AW-104	0.14	1.75	0.01	0.35	0.95	44	0.09	7.00	50.8
241-AW-105	0.41	0.17	0.06	0.03	0.44	4	0.42	0.69	5.4
241-AW-106	0.11	1.36	0.12	0.13	2.55	34	0.78	2.58	37.3
241-AY-101	0.24	2.33	0.03	0.06	0.94	58	0.19	1.20	59.6
241-AY-102	0.17	15.99	0.02	0.22	1.50	400	0.14	4.35	404.2
241-AZ-101	0.23	7.10	0.03	0.34	0.65	178	0.22	6.72	184.5
241-AZ-102	0.19	19.21	0.12	0.46	0.60	480	0.80	9.25	490.3
241-SY-101	0.12	0.60	0.39	0.12	2.01	15	2.58	2.41	20.0
241-SY-102	0.39	0.30	0.18	0.06	0.51	7	1.18	1.19	9.8
241-SY-103	0.27	1.39	0.56	0.11	0.68	35	3.72	2.29	40.7
241-A-101*	0.41	0.34	0.83	0.01	0.33	8.48	5.50	0.27	14.3
241-A-102	0.53	0.07	0.36	0.00	0.32	1.78	2.43	0.05	4.3
241-A-103*	0.39	0.37	0.29	0.01	0.57	9	1.95	0.20	11.3
241-A-104	0.53	0.04	0.01	0.00	0.08	1.09	0.06	0.10	1.2
241-A-105	na	na	na	na	na	na	na	na	na
241-A-106	0.51	0.39	0.54	0.02	0.39	10	3.57	0.45	13.7
241-AX-101*	0.40	0.26	0.14	0.01	0.04	6.38	0.94	0.29	7.6
241-AX-102	0.54	0.12	0.10	0.00	0.15	3.09	0.68	0.03	3.8

Table D-2. Steady-State Gas Concentrations and Flammability Levels Under Barometric Breathing Ventilation Conditions. (5 sheets)

Tank	Off-Normal Barometric Breathing Rate (Vr)bb (cfm)	Steady State Hydrogen Concen. [H ₂] (%)	Steady State Ammonia Concen. [NH ₃] (%)	Steady State Methane Concen. [CH ₄] (%)	Steady State N ₂ O Concen. [N ₂ O] (%)	Steady State Hydrogen Flammability (%)	Steady State Ammonia Flammability (%)	Steady State Methane Flammability (%)	Steady State Total Flammability (%)
241-AX-103	0.51	0.18	0.20	0.01	0.11	4	1.33	0.19	5.9
241-AX-104	0.55	0.93	0.01	0.00	0.02	23.28	0.06	0.03	23.4
241-B-101	0.31	0.14	0.03	0.01	0.22	3.39	0.21	0.22	3.8
241-B-102	0.34	0.07	0.01	0.00	0.13	2	0.06	0.06	1.9
241-B-103	0.33	0.07	0.02	0.01	0.13	1.83	0.12	0.11	2.1
241-B-104	0.19	0.18	0.02	0.04	0.27	4.62	0.12	0.74	5.5
241-B-105	0.23	0.14	0.04	0.01	0.28	3	0.24	0.28	4.0
241-B-106	0.30	0.10	0.01	0.02	0.56	2.57	0.08	0.41	3.1
241-B-107	0.28	0.10	0.05	0.02	0.04	2.52	0.35	0.35	3.2
241-B-108	0.31	0.08	0.08	0.01	0.19	2	0.51	0.19	2.7
241-B-109	0.30	0.09	0.10	0.01	0.28	2.20	0.65	0.27	3.1
241-B-110	0.25	0.22	0.14	0.04	0.14	5.43	0.94	0.87	7.2
241-B-111	0.25	0.36	0.04	0.07	0.13	9	0.23	1.46	10.8
241-B-112	0.34	0.08	0.06	0.01	0.14	2.11	0.42	0.18	2.7
241-B-201	0.01	0.49	0.29	0.10	0.34	12.18	1.92	1.95	16.0
241-B-202	0.01	0.45	0.15	0.09	0.98	11	1.02	1.80	14.0
241-B-203*	0.00	5.78	0.01	0.06	0.86	144.61	0.04	1.10	145.8
241-B-204*	0.00	5.37	0.01	0.05	0.74	134.15	0.05	0.95	135.1
241-BX-101	0.33	0.09	0.11	0.01	0.19	2	0.71	0.24	3.2
241-BX-102	0.32	0.12	0.01	0.02	0.04	3.09	0.04	0.49	3.6
241-BX-103	0.32	0.25	0.20	0.02	0.17	6.17	1.31	0.41	7.9
241-BX-104	0.31	0.12	0.60	0.02	0.37	3	3.99	0.48	7.5
241-BX-105	0.32	0.09	0.38	0.01	0.30	2.28	2.55	0.29	5.1
241-BX-106	0.33	0.11	0.10	0.01	0.09	2.77	0.65	0.21	3.6
241-BX-107	0.21	0.20	0.28	0.01	0.04	5	1.86	0.27	7.0
241-BX-108	0.34	0.08	0.05	0.01	0.11	1.93	0.33	0.14	2.4
241-BX-109	0.27	0.20	0.05	0.04	1.03	4.88	0.35	0.78	6.0
241-BX-110	0.26	0.15	0.17	0.02	0.05	4	1.13	0.43	5.3
241-BX-111	0.27	0.11	0.16	0.00	0.04	2.67	1.07	0.08	3.8
241-BX-112	0.28	0.12	0.30	0.02	0.84	2.99	2.01	0.48	5.5
241-BY-101	0.28	0.22	0.15	0.02	0.14	6	0.99	0.49	7.1
241-BY-102	0.32	0.11	0.38	0.01	0.04	2.76	2.54	0.17	5.5
241-BY-103	0.26	0.17	0.16	0.01	0.09	4.13	1.05	0.21	5.4
241-BY-104	0.26	0.26	0.75	0.02	0.72	7	4.98	0.41	12.0
241-BY-105	0.23	0.23	0.57	0.03	0.52	5.84	3.78	0.59	10.2
241-BY-106*	0.25	0.32	0.18	0.01	0.30	8.12	1.18	0.23	9.5

Table D-2. Steady-State Gas Concentrations and Flammability Levels Under Barometric Breathing Ventilation Conditions. (5 sheets)

Tank	Off-Normal Barometric Breathing Rate (Vr)bb (cfm)	Steady State Hydrogen Concen. [H ₂] (%)	Steady State Ammonia Concen. [NH ₃] (%)	Steady State Methane Concen. [CH ₄] (%)	Steady State N ₂ O Concen. [N ₂ O] (%)	Steady State Hydrogen Flammability (%)	Steady State Ammonia Flammability (%)	Steady State Methane Flammability (%)	Steady State Total Flammability (%)
241-BY-107	0.32	0.16	1.00	0.02	1.15	4	6.67	0.32	11.1
241-BY-108	0.34	0.15	1.00	0.02	1.10	3.77	6.67	0.30	10.7
241-BY-109	0.31	0.11	0.21	0.01	0.05	2.74	1.39	0.20	4.3
241-BY-110	0.28	0.49	1.00	0.02	0.49	12	6.67	0.31	19.3
241-BY-111	0.27	0.14	0.13	0.01	0.19	3.59	0.88	0.12	4.6
241-BY-112	0.31	0.11	0.27	0.01	0.17	2.79	1.81	0.11	4.7
241-C-101	0.31	0.11	0.11	0.01	0.73	3	0.75	0.27	3.7
241-C-102	0.22	0.22	1.00	0.04	0.76	5.53	6.67	0.88	13.1
241-C-103*	0.35	0.16	0.32	0.03	2.11	4.11	2.11	0.66	6.9
241-C-104	0.24	0.67	1.00	0.11	1.75	17	6.67	2.24	25.7
241-C-105	0.30	0.31	0.44	0.04	0.95	7.66	2.91	0.84	11.4
241-C-106	0.35	0.28	0.13	0.03	0.19	7.10	0.83	0.56	8.5
241-C-107	0.25	1.20	0.03	0.00	0.04	30	0.19	0.09	30.3
241-C-108	0.34	0.08	0.01	0.00	0.37	2.06	0.04	0.01	2.1
241-C-109	0.32	0.24	0.04	0.00	1.47	6.12	0.27	0.07	6.5
241-C-110	0.28	0.26	0.35	0.05	0.04	7	2.34	1.06	10.0
241-C-111	0.33	0.47	0.01	0.00	0.11	11.71	0.06	0.02	11.8
241-C-112	0.31	0.48	0.08	0.00	1.96	12.01	0.55	0.07	12.6
241-C-201	0.02	0.18	0.02	0.01	0.12	5	0.11	0.15	4.9
241-C-202	0.02	0.19	0.01	0.00	0.06	4.67	0.07	0.08	4.8
241-C-203	0.02	0.17	0.13	0.02	0.29	4.37	0.89	0.38	5.6
241-C-204	0.02	0.18	0.01	0.01	0.18	4	0.06	0.23	4.7
241-S-101*	0.29	0.35	0.58	0.02	0.42	8.68	3.88	0.30	12.9
241-S-102*	0.41	0.08	0.43	0.00	0.21	1.88	2.87	0.09	4.8
241-S-103*	0.34	0.15	0.33	0.02	0.61	4	2.19	0.41	6.3
241-S-104	0.31	0.19	0.04	0.04	0.13	4.87	0.30	0.78	6.0
241-S-105	0.26	0.14	0.23	0.01	0.05	3.52	1.51	0.29	5.3
241-S-106*	0.24	0.21	0.03	0.04	0.02	5	0.23	0.86	6.4
241-S-107	0.28	0.25	0.28	0.02	0.28	6.29	1.86	0.31	8.5
241-S-108	0.20	0.21	0.09	0.00	0.01	5.26	0.58	0.07	5.9
241-S-109	0.21	0.20	0.08	0.04	0.07	5	0.55	0.81	6.4
241-S-110	0.27	0.22	0.56	0.02	0.15	5.41	3.71	0.38	9.5
241-S-111*	0.27	0.24	0.20	0.01	0.04	6.00	1.36	0.11	7.5
241-S-112	0.43	0.15	0.08	0.00	0.01	4	0.54	0.05	4.4
241-SX-101*	0.36	0.19	0.04	0.02	0.08	4.67	0.25	0.36	5.3
241-SX-102*	0.40	0.37	0.06	0.02	0.06	9.20	0.40	0.40	10.0

Table D-2. Steady-State Gas Concentrations and Flammability Levels Under Barometric Breathing Ventilation Conditions. (5 sheets)

Tank	Off-Normal Barometric Breathing Rate (Vr)bb (cfm)	Steady State Hydrogen Concen. [H ₂] (%)	Steady State Ammonia Concen. [NH ₃] (%)	Steady State Methane Concen. [CH ₄] (%)	Steady State N ₂ O Concen. [N ₂ O] (%)	Steady State Hydrogen Flammability (%)	Steady State Ammonia Flammability (%)	Steady State Methane Flammability (%)	Steady State Total Flammability (%)
241-SX-103*	0.33	1.66	0.50	0.07	0.17	41	3.32	1.46	46.3
241-SX-104*	0.35	0.49	0.04	0.02	0.06	12.16	0.27	0.37	12.8
241-SX-105*	0.38	1.60	0.34	0.02	0.09	39.96	2.24	0.39	42.6
241-SX-106*	0.37	0.20	0.88	0.03	0.24	5	5.83	0.57	11.4
241-SX-107	0.50	0.30	0.14	0.02	0.30	7.47	0.90	0.38	8.8
241-SX-108*	0.51	0.21	0.36	0.02	0.25	5.22	2.38	0.32	7.9
241-SX-109	0.44	0.59	0.12	0.01	0.06	15	0.77	0.17	15.7
241-SX-110	0.51	0.59	0.08	0.01	0.17	14.83	0.52	0.22	15.6
241-SX-111	0.49	0.54	0.16	0.02	0.36	13.38	1.07	0.46	14.9
241-SX-112	0.51	0.23	0.14	0.02	0.31	6	0.92	0.39	7.0
241-SX-113	0.53	0.05	0.04	0.01	0.08	1.17	0.25	0.11	1.5
241-SX-114	0.47	0.54	0.25	0.04	0.55	13.45	1.65	0.71	15.8
241-SX-115	0.54	0.33	0.00	0.00	0.03	8	0.02	0.04	8.3
241-T-101	0.31	0.10	0.05	0.01	0.11	2.40	0.33	0.18	2.9
241-T-102	0.34	0.18	0.01	0.01	0.14	4.38	0.07	0.17	4.6
241-T-103	0.34	0.07	0.01	0.01	0.11	2	0.07	0.15	1.9
241-T-104	0.22	0.16	0.33	0.01	0.02	4.11	2.23	0.25	6.6
241-T-105	0.31	0.10	0.21	0.02	0.45	2.57	1.42	0.41	4.4
241-T-106	0.34	0.07	0.20	0.01	0.09	2	1.37	0.11	3.2
241-T-107	0.28	0.16	0.28	0.03	0.09	3.88	1.88	0.62	6.4
241-T-108	0.34	0.07	0.04	0.00	0.08	1.65	0.27	0.08	2.0
241-T-109	0.32	0.07	0.01	0.01	0.11	2	0.07	0.11	2.0
241-T-110*	0.20	0.44	0.12	0.01	0.05	11.10	0.79	0.17	12.1
241-T-111	0.16	0.26	0.82	0.05	0.05	6.43	5.48	1.03	12.9
241-T-112	0.32	0.08	0.06	0.02	0.30	2	0.42	0.31	2.6
241-T-201	0.01	1.22	0.06	0.23	3.56	30.53	0.40	4.57	35.5
241-T-202	0.02	0.28	0.10	0.06	1.90	6.98	0.67	1.12	8.8
241-T-203*	0.01	0.70	0.01	0.14	5.35	17	0.07	2.78	20.2
241-T-204	0.01	0.70	0.09	0.14	5.81	17.41	0.62	2.79	20.8
241-TX-101	0.40	0.10	0.02	0.02	0.09	2.45	0.16	0.39	3.0
241-TX-102	0.34	0.10	0.56	0.01	0.18	2	3.75	0.13	6.4
241-TX-103	0.37	0.08	0.20	0.01	0.16	2.01	1.34	0.12	3.5
241-TX-104	0.41	0.08	0.02	0.01	0.04	1.92	0.16	0.10	2.2
241-TX-105	0.19	0.25	0.15	0.01	0.09	6	0.98	0.20	7.3
241-TX-106	0.29	0.14	0.61	0.02	0.12	3.62	4.08	0.32	8.0
241-TX-107	0.42	0.06	0.34	0.00	0.05	1.46	2.25	0.05	3.8

Table D-2. Steady-State Gas Concentrations and Flammability Levels Under Barometric Breathing Ventilation Conditions. (5 sheets)

Tank	Off-Normal Barometric Breathing Rate (Vr)bb (cfm)	Steady State Hydrogen Concen. [H ₂] (%)	Steady State Ammonia Concen. [NH ₃] (%)	Steady State Methane Concen. [CH ₄] (%)	Steady State N ₂ O Concen. [N ₂ O] (%)	Steady State Hydrogen Flammability (%)	Steady State Ammonia Flammability (%)	Steady State Methane Flammability (%)	Steady State Total Flammability (%)
241-TX-108	0.38	0.07	0.06	0.00	0.05	2	0.39	0.05	2.3
241-TX-109	0.28	0.19	0.99	0.04	1.66	4.81	6.61	0.77	12.2
241-TX-110	0.24	0.17	1.00	0.01	0.38	4.36	6.67	0.18	11.2
241-TX-111	0.28	0.13	1.00	0.01	0.60	3	6.67	0.13	10.1
241-TX-112	0.17	0.28	0.46	0.03	0.20	7.01	3.08	0.54	10.6
241-TX-113	0.17	0.27	0.12	0.02	0.28	6.72	0.79	0.41	7.9
241-TX-114	0.21	0.19	0.91	0.01	0.23	5	6.06	0.23	11.1
241-TX-115	0.20	0.21	0.07	0.01	0.23	5.37	0.45	0.23	6.0
241-TX-116	0.18	0.23	0.02	0.02	0.08	5.81	0.16	0.40	6.4
241-TX-117	0.23	0.17	0.04	0.01	0.14	4	0.26	0.16	4.6
241-TX-118	0.33	0.14	0.11	0.03	0.05	3.59	0.72	0.57	4.9
241-TY-101	0.39	0.07	0.01	0.00	0.08	1.70	0.09	0.04	1.8
241-TY-102	0.41	0.06	0.01	0.00	0.11	2	0.05	0.10	1.7
241-TY-103	0.37	0.10	0.10	0.02	0.44	2.58	0.67	0.41	3.7
241-TY-104	0.42	0.07	0.19	0.01	0.31	1.68	1.26	0.20	3.2
241-TY-105	0.34	0.15	0.01	0.03	0.10	4	0.03	0.60	4.4
241-TY-106	0.43	0.06	0.03	0.00	0.07	1.50	0.21	0.09	1.8
241-U-101	0.34	0.10	0.21	0.01	0.11	2.39	1.37	0.13	3.9
241-U-102*	0.21	0.41	0.22	0.01	0.79	10	1.44	0.23	12.0
241-U-103*	0.18	0.62	0.46	0.02	1.03	15.59	3.05	0.38	19.0
241-U-104	0.33	0.09	0.00	0.01	0.18	2.34	0.01	0.24	2.6
241-U-105*	0.20	0.45	0.69	0.09	3.25	11	4.61	1.80	17.6
241-U-106*	0.28	0.32	0.21	0.02	0.26	7.93	1.37	0.49	9.8
241-U-107*	0.23	0.22	0.14	0.04	2.29	5.45	0.92	0.87	7.2
241-U-108*	0.17	0.54	0.43	0.02	1.03	13	2.90	0.46	16.8
241-U-109*	0.18	0.36	0.01	0.02	1.17	8.98	0.09	0.49	9.5
241-U-110	0.28	0.18	0.15	0.04	0.96	4.52	1.02	0.72	6.3
241-U-111	0.26	0.18	0.49	0.01	0.24	4	3.28	0.18	8.0
241-U-112	0.33	0.09	0.12	0.01	0.08	2.33	0.77	0.27	3.4
241-U-201	0.02	0.11	0.14	0.02	0.32	2.83	0.95	0.41	4.2
241-U-202	0.023	0.09	0.14	0.02	0.31	2	0.94	0.38	3.7
241-U-203	0.023	0.11	0.01	0.01	0.19	2.74	0.05	0.24	3.0
241-U-204	0.023	0.22	0.01	0.01	0.19	5.53	0.04	0.24	5.8

Notes:

¹DSA conditions are current waste plus water additions of 10 kgal to 100-series or 1 kgal to 200-series tanks, and a 5 °C temperature increase for DSTs.²For all DSTs and SSTs with "*" the ammonia was analyzed with equilibrium model.

Table D-3. Time to Reach 25% of the LFL and Flammability Distribution Among Gases Under Barometric Breathing Ventilation. (5 sheets)

Tank	Time to Reach 25% LFL t25% (day)	Minimum Vent rate to prevent 25% LFL (cfm)	Hydrogen Concentration at time t25% [H2](t) (%)	Ammonia Concentration at Time t25% [NH3](t) (%)	Methane Concentration at time t25% [CH4](t) (%)	N2O Concentration at Time t25% [N2O](t) (%)	Hydrogen Flammability at Time t25% (%)	Ammonia Flammability at Time t25% (%)	Methane Flammability at Time t25% (%)
241-AN-101	110	0.28	0.94	0.01	0.07	0.44	23.46	0.04	1.41
241-AN-102	21	1.50	0.96	0.09	0.02	0.43	23.96	0.58	0.44
241-AN-103	141	0.39	0.92	0.14	0.05	0.17	22.94	0.91	1.05
241-AN-104	80	0.48	0.91	0.19	0.04	0.15	22.79	1.24	0.82
241-AN-105	106	0.30	0.90	0.15	0.07	0.43	22.46	1.00	1.47
241-AN-106	104	0.78	0.92	0.01	0.09	0.03	23.06	0.05	1.84
241-AN-107	25	1.14	0.90	0.08	0.05	0.59	22.56	0.51	1.09
241-AP-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AP-102	263	0.19	0.84	0.07	0.17	3.54	21.10	0.49	3.37
241-AP-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AP-104	250	0.19	0.99	0.01	0.00	0.08	24.81	0.09	0.08
241-AP-105	646	0.12	0.84	0.08	0.17	3.95	21.09	0.53	3.37
241-AP-106	228	0.17	0.98	0.01	0.02	0.33	24.57	0.07	0.33
241-AP-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AP-108	110	0.16	0.97	0.08	0.01	1.37	24.30	0.56	0.14
241-AW-101	78	0.38	0.96	0.01	0.04	0.19	24.09	0.06	0.82
241-AW-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AW-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AW-104	149	0.28	0.86	0.01	0.17	0.46	21.38	0.09	3.41
241-AW-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AW-106	241	0.17	0.90	0.12	0.09	1.69	22.50	0.78	1.71
241-AY-101	120	0.58	0.97	0.03	0.03	0.39	24.28	0.19	0.50
241-AY-102	13	2.75	0.98	0.01	0.01	0.09	24.46	0.09	0.27
241-AZ-101	31	1.75	0.96	0.01	0.05	0.09	23.90	0.05	0.91
241-AZ-102	11	3.72	0.94	0.01	0.02	0.03	23.40	0.10	0.46
241-SY-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SY-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SY-103	191	0.48	0.80	0.55	0.07	0.39	20.02	3.64	1.32
241-A-101*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-A-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-A-103*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-A-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-A-105	na	na	na	na	na	na	na	na	na
241-A-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AX-101*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AX-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur

Table D-3. Time to Reach 25% of the LFL and Flammability Distribution Among Gases Under Barometric Breathing Ventilation. (5 sheets)

Tank	Time to Reach 25% LFL t25% (day)	Minimum Vent rate to prevent 25% LFL (cfm)	Hydrogen Concentration at time t25% [H2](t) (%)	Ammonia Concentration at Time t25% [NH3](t) (%)	Methane Concentration at time t25% [CH4](t) (%)	N2O Concentration at Time t25% [N2O](t) (%)	Hydrogen Flammability at Time t25% (%)	Ammonia Flammability at Time t25% (%)	Methane Flammability at Time t25% (%)
241-AX-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AX-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-201	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-202	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-203*	39	0.02	0.99	0.01	0.01	0.15	24.75	0.05	0.20
241-B-204*	42	0.02	0.99	0.01	0.01	0.14	24.77	0.05	0.19
241-BX-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-106*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur

Table D-3. Time to Reach 25% of the LFL and Flammability Distribution Among Gases Under Barometric Breathing Ventilation. (5 sheets)

Tank	Time to Reach 25% LFL t25% (day)	Minimum Vent rate to prevent 25% LFL (cfm)	Hydrogen Concentration at time t25% [H2](t) (%)	Ammonia Concentration at Time t25% [NH3](t) (%)	Methane Concentration at time t25% [CH4](t) (%)	N2O Concentration at Time t25% [N2O](t) (%)	Hydrogen Flammability at Time t25% (%)	Ammonia Flammability at Time t25% (%)	Methane Flammability at Time t25% (%)
241-BY-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-103*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-104	728	0.27	0.65	1.00	0.11	1.68	16.18	6.67	2.17
241-C-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-107	332	0.31	0.99	0.03	0.00	0.04	24.76	0.17	0.08
241-C-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-201	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-202	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-203	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-204	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-101*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-102*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-103*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-106*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-111*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-101*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-102*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur

Table D-3. Time to Reach 25% of the LFL and Flammability Distribution Among Gases Under Barometric Breathing Ventilation. (5 sheets)

Tank	Time to Reach 25% LFL t25% (day)	Minimum Vent rate to prevent 25% LFL (cfm)	Hydrogen Concentration at time t25% [H2](t) (%)	Ammonia Concentration at Time t25% [NH3](t) (%)	Methane Concentration at time t25% [CH4](t) (%)	N2O Concentration at Time t25% [N2O](t) (%)	Hydrogen Flammability at Time t25% (%)	Ammonia Flammability at Time t25% (%)	Methane Flammability at Time t25% (%)
241-SX-103*	169	0.59	0.89	0.30	0.04	0.09	22.19	1.97	0.79
241-SX-104*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-105*	192	0.66	0.95	0.17	0.01	0.05	23.63	1.14	0.23
241-SX-106*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-108*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-113	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-114	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-115	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-110*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-201	270	0.02	0.86	0.04	0.16	2.50	21.51	0.28	3.24
241-T-202	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-203*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-204	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur

Table D-3. Time to Reach 25% of the LFL and Flammability Distribution Among Gases Under Barometric Breathing Ventilation. (5 sheets)

Tank	Time to Reach 25% LFL t25% (day)	Minimum Vent rate to prevent 25% LFL (cfm)	Hydrogen Concentration at time t25% [H ₂](t) (%)	Ammonia Concentration at Time t25% [NH ₃](t) (%)	Methane Concentration at time t25% [CH ₄](t) (%)	N ₂ O Concentration at Time t25% [N ₂ O](t) (%)	Hydrogen Flammability at Time t25% (%)	Ammonia Flammability at Time t25% (%)	Methane Flammability at Time t25% (%)
241-TX-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-113	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-114	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-115	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-116	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-117	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-118	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TY-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TY-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TY-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TY-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TY-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TY-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-102*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-103*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-105*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-106*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-107*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-108*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-109*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-201	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-202	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-203	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-204	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur

Notes:

¹DSA conditions are current waste plus water additions of 10 kgal to 100-series or 1 kgal to 200-series tanks, and a 5 °C temperature increase for DSTs.²For all DSTs and SSTs with "*" the ammonia was analyzed with equilibrium model.

Table D-4 Time to Reach 100% of the LFL and Flammability Distribution Among Gases Under Barometric Breathing Ventilation. (5 sheets)

Tank	Time to Reach 100% LFL t100% (day)	Minimum vent rate to prevent reaching 100% LFL (cfm)	Hydrogen Concentration at time t100% [H ₂](t) (%)	Ammonia Concentration at Time t100% [NH ₃](t) (%)	Methane Concentration at time t100% [CH ₄](t) (%)	N ₂ O Concentration at Time t100% [N ₂ O](t) (%)	Hydrogen Flammability at Time t100% (%)	Ammonia Flammability at Time t100% (%)	Methane Flammability at Time t100% (%)
241-AN-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AN-102	107	0.36	3.90	0.09	0.09	1.75	97.54	0.58	1.77
241-AN-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AN-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AN-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AN-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AN-107	132	0.28	3.79	0.08	0.23	2.48	94.80	0.51	4.57
241-AP-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AP-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AP-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AP-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AP-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AP-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AP-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AP-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AW-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AW-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AW-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AW-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AW-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AW-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AY-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AY-102	62	0.67	3.95	0.02	0.05	0.37	98.71	0.14	1.08
241-AZ-101	173	0.43	3.84	0.03	0.18	0.35	96.08	0.17	3.64
241-AZ-102	50	0.91	3.88	0.05	0.09	0.12	96.94	0.36	1.88
241-SY-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SY-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SY-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-A-101*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-A-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-A-103*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-A-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-A-105	na	na	na	na	na	na	na	na	na
241-A-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AX-101*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AX-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur

Table D-4 Time to Reach 100% of the LFL and Flammability Distribution Among Gases Under Barometric Breathing Ventilation. (5 sheets)

Tank	Time to Reach 100% LFL t100% (day)	Minimum vent rate to prevent reaching 100% LFL (cfm)	Hydrogen Concentration at time t100% [H ₂](t) (%)	Ammonia Concentration at Time t100% [NH ₃](t) (%)	Methane Concentration at time t100% [CH ₄](t) (%)	N ₂ O Concentration at Time t100% [N ₂ O](t) (%)	Hydrogen Flammability at Time t100% (%)	Ammonia Flammability at Time t100% (%)	Methane Flammability at Time t100% (%)
241-AX-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-AX-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-201	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-202	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-B-203*	254	0.005	3.96	0.03	0.04	0.59	99.05	0.19	0.78
241-B-204*	296	0.005	3.96	0.03	0.04	0.55	99.11	0.18	0.73
241-BX-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BX-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-106*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur

Table D-4 Time to Reach 100% of the LFL and Flammability Distribution Among Gases Under Barometric Breathing Ventilation. (5 sheets)

Tank	Time to Reach 100% LFL t100% (day)	Minimum vent rate to prevent reaching 100% LFL (cfm)	Hydrogen Concentration at time t100% [H ₂](t) (%)	Ammonia Concentration at Time t100% [NH ₃](t) (%)	Methane Concentration at time t100% [CH ₄](t) (%)	N ₂ O Concentration at Time t100% [N ₂ O](t) (%)	Hydrogen Flammability at Time t100% (%)	Ammonia Flammability at Time t100% (%)	Methane Flammability at Time t100% (%)
241-BY-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-BY-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-103*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-201	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-202	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-203	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-C-204	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-101*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-102*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-103*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-106*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-111*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-S-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-101*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-102*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur

Table D-4 Time to Reach 100% of the LFL and Flammability Distribution Among Gases Under Barometric Breathing Ventilation. (5 sheets)

Tank	Time to Reach 100% LFL t100% (day)	Minimum vent rate to prevent reaching 100% LFL (cfm)	Hydrogen Concentration at time t100% [H ₂](t) (%)	Ammonia Concentration at Time t100% [NH ₃](t) (%)	Methane Concentration at time t100% [CH ₄](t) (%)	N ₂ O Concentration at Time t100% [N ₂ O](t) (%)	Hydrogen Flammability at Time t100% (%)	Ammonia Flammability at Time t100% (%)	Methane Flammability at Time t100% (%)
241-SX-103*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-104*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-105*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-106*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-108*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-113	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-114	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-SX-115	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-110*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-201	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-202	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-203*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-T-204	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-107	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur

Table D-4 Time to Reach 100% of the LFL and Flammability Distribution Among Gases Under Barometric Breathing Ventilation. (5 sheets)

Tank	Time to Reach 100% LFL t100% (day)	Minimum vent rate to prevent reaching 100% LFL (cfm)	Hydrogen Concentration at time t100% [H ₂](t) (%)	Ammonia Concentration at Time t100% [NH ₃](t) (%)	Methane Concentration at time t100% [CH ₄](t) (%)	N ₂ O Concentration at Time t100% [N ₂ O](t) (%)	Hydrogen Flammability at Time t100% (%)	Ammonia Flammability at Time t100% (%)	Methane Flammability at Time t100% (%)
241-TX-108	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-109	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-113	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-114	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-115	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-116	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-117	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TX-118	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TY-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TY-102	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TY-103	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TY-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TY-105	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-TY-106	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-101	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-102*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-103*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-104	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-105*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-106*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-107*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-108*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-109*	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-110	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-111	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-112	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-201	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-202	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-203	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur
241-U-204	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur	not occur

Notes:

¹DSA conditions are current waste plus water additions of 10 gal to 100-series or 1 gal to 200-series tanks, and a 5 °C temperature increase for DSTs.²For all DSTs and SSTs with "*" the ammonia was analyzed with equilibrium model.

Table D-5. Flammability and Time to LFL at Zero Ventilation Under DSA Conditions. (4 sheets)

Tank Name	Hydrogen Diffusion Rate (Dr) H ₂ (cfm)	Methane Diffusion Rate (Dr) CH ₄ (cfm)	Steady State Total Flammability (%)	Time to Reach 25% of the LFL (Days)	Time to Reach 100% of the LFL (Days)	Minimum Vent Rate to Keep below 25% LFL (cfm)	Minimum Vent Rate to Keep below 100% LFL (cfm)
241-AN-101	na	na	na	83	300	0.27	0.07
241-AN-102	na	na	na	17	50	1.46	0.36
241-AN-103	na	na	na	97	328	0.39	0.10
241-AN-104	na	na	na	63	221	0.47	0.11
241-AN-105	na	na	na	80	293	0.30	0.07
241-AN-106	na	na	na	82	294	0.76	0.19
241-AN-107	na	na	na	23	90	1.12	0.28
241-AP-101	na	na	na	317	270	0.07	0.02
241-AP-102	na	na	na	147	347	0.18	0.05
241-AP-103	na	na	na	249	963	0.23	0.06
241-AP-104	na	na	na	139	451	0.19	0.05
241-AP-105	na	na	na	206	425	0.12	0.03
241-AP-106	na	na	na	135	465	0.17	0.04
241-AP-107	na	na	na	301	342	0.08	0.02
241-AP-108	na	na	na	84	322	0.16	0.04
241-AW-101	na	na	na	63	228	0.38	0.09
241-AW-102	na	na	na	251	1006	0.12	0.03
241-AW-103	na	na	na	241	977	0.12	0.03
241-AW-104	na	na	na	105	387	0.28	0.07
241-AW-105	na	na	na	1312	1500	0.08	0.02
241-AW-106	na	na	na	142	532	0.17	0.04
241-AY-101	na	na	na	90	309	0.57	0.14
241-AY-102	na	na	na	13	47	2.70	0.67
241-AZ-101	na	na	na	26	79	1.71	0.43
241-AZ-102	na	na	na	10	40	3.65	0.91
241-SY-101	na	na	na	285	884	0.10	0.02
241-SY-102	na	na	na	611	1500	0.14	0.03
241-SY-103	na	na	na	120	447	0.47	0.11
241-A-101*	7.25E-03	7.09E-03	501	496	1500	0.16	0.04
241-A-102	7.25E-03	7.09E-03	136	1500	1500	0.09	0.02
241-A-103*	7.25E-03	7.09E-03	504	551	1500	0.16	0.04
241-A-104	7.25E-03	7.09E-03	88	1500	not occur	0.03	0.01
241-A-105	7.25E-03	7.09E-03	na	na	na	na	na
241-A-106	7.25E-03	7.09E-03	720	400	1500	0.28	0.07
241-AX-101*	7.11E-01	2.23E-01	5	not occur	not occur	0.11	0.03
241-AX-102	7.11E-01	2.23E-01	3	not occur	not occur	0.08	0.02
241-AX-103	7.11E-01	2.23E-01	5	not occur	not occur	0.12	0.03
241-AX-104	7.11E-01	2.23E-01	18	not occur	not occur	0.51	0.13
241-B-101	4.89E-03	4.82E-03	226	1500	1500	0.05	0.01
241-B-102	4.89E-03	4.82E-03	127	1500	1500	0.03	0.01
241-B-103	4.89E-03	4.82E-03	130	1500	1500	0.03	0.01
241-B-104	4.89E-03	4.82E-03	214	1067	1500	0.04	0.01
241-B-105	4.89E-03	4.82E-03	177	1486	1500	0.04	0.01
241-B-106	4.89E-03	4.82E-03	183	1500	1500	0.04	0.01
241-B-107	4.89E-03	4.82E-03	167	1500	1500	0.04	0.01
241-B-108	4.89E-03	4.82E-03	143	1500	1500	0.03	0.01
241-B-109	4.89E-03	4.82E-03	152	1500	1500	0.04	0.01

Table D-5. Flammability and Time to LFL at Zero Ventilation Under DSA Conditions. (4 sheets)

Tank Name	Hydrogen Diffusion Rate (Dr) H ₂ (cfm)	Methane Diffusion Rate (Dr) CH ₄ (cfm)	Steady State Total Flammability (%)	Time to Reach 25% of the LFL (Days)	Time to Reach 100% of the LFL (Days)	Minimum Vent Rate to Keep below 25% LFL (cfm)	Minimum Vent Rate to Keep below 100% LFL (cfm)
241-B-110	4.89E-03	4.82E-03	321	786	1500	0.07	0.02
241-B-111	4.89E-03	4.82E-03	542	510	1500	0.11	0.03
241-B-112	4.89E-03	4.82E-03	158	1500	1500	0.04	0.01
241-B-201	1.61E-04	1.60E-04	1066	349	1500	0.01	0.002
241-B-202	1.61E-04	1.60E-04	1009	400	1500	0.01	0.00
241-B-203*	1.61E-04	1.60E-04	3095	35	154	0.02	0.005
241-B-204*	1.61E-04	1.60E-04	3147	38	166	0.02	0.005
241-BX-101	4.89E-03	4.82E-03	167	1500	1500	0.04	0.01
241-BX-102	4.89E-03	4.82E-03	233	1500	1500	0.05	0.01
241-BX-103	4.89E-03	4.82E-03	431	712	1500	0.10	0.03
241-BX-104	4.89E-03	4.82E-03	224	1211	1500	0.09	0.02
241-BX-105	4.89E-03	4.82E-03	172	1500	1500	0.07	0.02
241-BX-106	4.89E-03	4.82E-03	205	1500	1500	0.05	0.01
241-BX-107	4.89E-03	4.82E-03	220	817	1500	0.06	0.01
241-BX-108	4.89E-03	4.82E-03	144	1500	1500	0.03	0.01
241-BX-109	4.89E-03	4.82E-03	313	952	1500	0.06	0.02
241-BX-110	4.89E-03	4.82E-03	225	1086	1500	0.06	0.01
241-BX-111	4.89E-03	4.82E-03	154	1500	1500	0.04	0.01
241-BX-112	4.89E-03	4.82E-03	202	1223	1500	0.06	0.02
241-BY-101	4.84E-03	4.76E-03	352	803	1500	0.08	0.02
241-BY-102	4.84E-03	4.76E-03	195	1452	1500	0.07	0.02
241-BY-103	4.84E-03	4.76E-03	236	1072	1500	0.06	0.01
241-BY-104	4.84E-03	4.76E-03	388	589	1500	0.13	0.03
241-BY-105	4.84E-03	4.76E-03	314	650	1500	0.10	0.02
241-BY-106*	4.84E-03	4.76E-03	441	643	1500	0.09	0.02
241-BY-107	4.84E-03	4.76E-03	301	934	1500	0.19	0.05
241-BY-108	4.84E-03	4.76E-03	295	1021	1500	0.21	0.05
241-BY-109	4.84E-03	4.76E-03	193	1452	1500	0.05	0.01
241-BY-110	4.84E-03	4.76E-03	743	322	1500	0.28	0.07
241-BY-111	4.84E-03	4.76E-03	205	1264	1500	0.05	0.01
241-BY-112	4.84E-03	4.76E-03	191	1472	1500	0.06	0.01
241-C-101	4.89E-03	4.82E-03	191	1500	1500	0.05	0.01
241-C-102	4.89E-03	4.82E-03	294	652	1500	0.11	0.03
241-C-103*	4.89E-03	4.82E-03	344	859	859	0.07	0.02
241-C-104	4.89E-03	4.82E-03	954	215	1068	0.26	0.07
241-C-105	4.89E-03	4.82E-03	518	495	1500	0.14	0.03
241-C-106	4.89E-03	4.82E-03	549	667	1500	0.12	0.03
241-C-107	4.89E-03	4.82E-03	1523	135	709	0.30	0.07
241-C-108	4.89E-03	4.82E-03	144	1500	1500	0.03	0.01
241-C-109	4.89E-03	4.82E-03	411	880	1259	0.08	0.02
241-C-110	4.89E-03	4.82E-03	437	559	1500	0.11	0.03
241-C-111	4.89E-03	4.82E-03	784	469	1500	0.15	0.04
241-C-112	4.89E-03	4.82E-03	760	441	934	0.16	0.04
241-C-201	1.61E-04	1.60E-04	717	1161	1500	0.005	0.001
241-C-202	1.61E-04	1.60E-04	715	1174	1500	0.005	0.001
241-C-203	1.61E-04	1.60E-04	718	1000	1500	0.005	0.001
241-C-204	1.61E-04	1.60E-04	699	1204	1500	0.00	0.001

Table D-5. Flammability and Time to LFL at Zero Ventilation Under DSA Conditions. (4 sheets)

Tank Name	Hydrogen Diffusion Rate (Dr) H ₂ (cfm)	Methane Diffusion Rate (Dr) CH ₄ (cfm)	Steady State Total Flammability (%)	Time to Reach 25% of the LFL (Days)	Time to Reach 100% of the LFL (Days)	Minimum Vent Rate to Keep below 25% LFL (cfm)	Minimum Vent Rate to Keep below 100% LFL (cfm)
241-S-101*	4.84E-03	4.76E-03	538	523	1500	0.13	0.03
241-S-102*	4.84E-03	4.76E-03	169	1500	1500	0.04	0.01
241-S-103*	4.84E-03	4.76E-03	285	1296	1500	0.05	0.01
241-S-104	4.84E-03	4.76E-03	368	951	1500	0.07	0.02
241-S-105	4.84E-03	4.76E-03	211	1115	1500	0.06	0.01
241-S-106*	4.84E-03	4.76E-03	315	916	1500	0.06	0.02
241-S-107	4.84E-03	4.76E-03	391	660	1500	0.10	0.02
241-S-108	4.84E-03	4.76E-03	226	984	1500	0.05	0.01
241-S-109	4.84E-03	4.76E-03	258	889	1500	0.05	0.01
241-S-110	4.84E-03	4.76E-03	330	718	1500	0.10	0.03
241-S-111*	4.84E-03	4.76E-03	339	880	1500	0.07	0.02
241-S-112	4.84E-03	4.76E-03	345	1285	1500	0.08	0.02
241-SX-101*	7.11E-01	2.23E-01	3	not occur	not occur	0.07	0.02
241-SX-102*	7.11E-01	2.23E-01	6	not occur	not occur	0.15	0.04
241-SX-103*	7.11E-01	2.23E-01	24	not occur	not occur	0.58	0.14
241-SX-104*	7.11E-01	2.23E-01	7	not occur	not occur	0.18	0.04
241-SX-105*	7.11E-01	2.23E-01	24	not occur	not occur	0.61	0.15
241-SX-106*	7.11E-01	2.23E-01	9	not occur	not occur	0.08	0.02
241-SX-107	7.11E-01	2.23E-01	7	not occur	not occur	0.17	0.04
241-SX-108*	7.11E-01	2.23E-01	7	not occur	not occur	0.11	0.03
241-SX-109	7.11E-01	2.23E-01	10	not occur	not occur	0.27	0.07
241-SX-110	7.11E-01	2.23E-01	12	not occur	not occur	0.32	0.08
241-SX-111	7.11E-01	2.23E-01	11	not occur	not occur	0.29	0.07
241-SX-112	7.11E-01	2.23E-01	6	not occur	not occur	0.14	0.04
241-SX-113	7.11E-01	2.23E-01	1	not occur	not occur	0.03	0.01
241-SX-114	7.11E-01	2.23E-01	12	not occur	not occur	0.30	0.07
241-SX-115	7.11E-01	2.23E-01	6	not occur	not occur	0.18	0.04
241-T-101	4.89E-03	4.82E-03	163	1500	1500	0.04	0.01
241-T-102	4.89E-03	4.82E-03	315	1241	1500	0.06	0.02
241-T-103	4.89E-03	4.82E-03	129	1500	1500	0.03	0.01
241-T-104	4.89E-03	4.82E-03	197	973	1500	0.06	0.01
241-T-105	4.89E-03	4.82E-03	191	1429	1500	0.05	0.01
241-T-106	4.89E-03	4.82E-03	128	1500	1500	0.04	0.01
241-T-107	4.89E-03	4.82E-03	259	929	1500	0.07	0.02
241-T-108	4.89E-03	4.82E-03	122	1500	1500	0.03	0.01
241-T-109	4.89E-03	4.82E-03	130	1500	1500	0.03	0.01
241-T-110*	4.89E-03	4.82E-03	454	484	1500	0.09	0.02
241-T-111	4.89E-03	4.82E-03	256	559	1500	0.08	0.02
241-T-112	4.89E-03	4.82E-03	147	1500	1500	0.03	0.01
241-T-201	1.61E-04	1.60E-04	2549	157	508	0.02	0.004
241-T-202	1.61E-04	1.60E-04	800	642	958	0.01	0.001
241-T-203*	1.61E-04	1.60E-04	1175	270	331	0.01	0.002
241-T-204	1.61E-04	1.60E-04	1177	269	309	0.01	0.002
241-TX-101	4.84E-03	4.76E-03	233	1500	1500	0.05	0.01
241-TX-102	4.84E-03	4.76E-03	189	1500	1500	0.09	0.02
241-TX-103	4.84E-03	4.76E-03	166	1500	1500	0.05	0.01
241-TX-104	4.84E-03	4.76E-03	170	1500	1500	0.04	0.01

Table D-5. Flammability and Time to LFL at Zero Ventilation Under DSA Conditions. (4 sheets)

Tank Name	Hydrogen Diffusion Rate (Dr) H ₂ (cfm)	Methane Diffusion Rate (Dr) CH ₄ (cfm)	Steady State Total Flammability (%)	Time to Reach 25% of the LFL (Days)	Time to Reach 100% of the LFL (Days)	Minimum Vent Rate to Keep below 25% LFL (cfm)	Minimum Vent Rate to Keep below 100% LFL (cfm)
241-TX-105	4.84E-03	4.76E-03	255	790	1500	0.06	0.01
241-TX-106	4.84E-03	4.76E-03	240	1065	1500	0.09	0.02
241-TX-107	4.84E-03	4.76E-03	134	1500	1500	0.06	0.02
241-TX-108	4.84E-03	4.76E-03	148	1500	1500	0.03	0.01
241-TX-109	4.84E-03	4.76E-03	333	741	1111	0.14	0.03
241-TX-110	4.84E-03	4.76E-03	231	929	1500	0.23	0.06
241-TX-111	4.84E-03	4.76E-03	209	1220	1500	0.20	0.05
241-TX-112	4.84E-03	4.76E-03	268	554	1500	0.07	0.02
241-TX-113	4.84E-03	4.76E-03	248	731	1500	0.05	0.01
241-TX-114	4.84E-03	4.76E-03	229	831	1500	0.09	0.02
241-TX-115	4.84E-03	4.76E-03	235	963	1500	0.05	0.01
241-TX-116	4.84E-03	4.76E-03	237	908	1500	0.05	0.01
241-TX-117	4.84E-03	4.76E-03	208	1284	1500	0.04	0.01
241-TX-118	4.84E-03	4.76E-03	286	1174	1500	0.06	0.02
241-TY-101	4.84E-03	4.76E-03	139	1500	1500	0.03	0.01
241-TY-102	4.84E-03	4.76E-03	138	1500	1500	0.03	0.01
241-TY-103	4.84E-03	4.76E-03	230	1500	1500	0.05	0.01
241-TY-104	4.84E-03	4.76E-03	164	1500	1500	0.05	0.01
241-TY-105	4.84E-03	4.76E-03	307	1299	1500	0.06	0.01
241-TY-106	4.84E-03	4.76E-03	141	1500	1500	0.03	0.01
241-U-101	4.89E-03	4.82E-03	177	1500	1500	0.05	0.01
241-U-102*	4.89E-03	4.82E-03	465	485	1500	0.10	0.02
241-U-103*	4.89E-03	4.82E-03	580	296	1457	0.13	0.03
241-U-104	4.89E-03	4.82E-03	173	1500	1500	0.03	0.01
241-U-105*	4.89E-03	4.82E-03	547	345	554	0.13	0.03
241-U-106*	4.89E-03	4.82E-03	484	591	1500	0.09	0.02
241-U-107*	4.89E-03	4.82E-03	296	801	801	0.06	0.01
241-U-108*	4.89E-03	4.82E-03	485	351	1500	0.11	0.02
241-U-109*	4.89E-03	4.82E-03	355	597	1500	0.07	0.02
241-U-110	4.89E-03	4.82E-03	299	885	1500	0.07	0.02
241-U-111	4.89E-03	4.82E-03	250	875	1500	0.08	0.02
241-U-112	4.89E-03	4.82E-03	178	1500	1500	0.04	0.01
241-U-201	1.61E-04	1.60E-04	457	1357	1500	0.00	0.001
241-U-202	1.61E-04	1.60E-04	390	1500	1500	0.00	0.001
241-U-203	1.61E-04	1.60E-04	425	1500	1500	0.00	0.001
241-U-204	1.61E-04	1.60E-04	829	971	1500	0.005	0.001

Notes: ¹The diffusion mechanism only applies to SSTs.²DSTs are treated as closed systems under the zero ventilation condition.

APPENDIX E

**EQUATIONS TO CALCULATE THE MASS TRANSPORT
COEFFICIENT h FOR SOLUBLE GAS**

This page intentionally left blank.

APPENDIX E

EQUATIONS TO CALCULATE THE MASS TRANSPORT
COEFFICIENT h FOR SOLUBLE GAS

As described in RPP-4941, *Methodology for Predicting Flammable Gas Mixtures in Double-Contained Receiver Tanks*, the overall mass transport coefficient for steady state can be written in terms of the mass transport coefficient in vapor phase, h_g , and in liquid, h_l , as:

$$h = \frac{1}{\frac{1}{h_l} + \frac{K_H RT}{h_g}}$$

with

$$h_g = 0.15 \cdot \frac{D_g}{L_c} \cdot (S_c \cdot G_r)^{1/3}$$

$$h_l = 0.15 \cdot D_L \cdot \left(\frac{\mu_L}{D_L \cdot \rho_L} \right)^{1/3} \cdot \left(\frac{g \cdot \beta_L \cdot \rho_L^2 \cdot \Delta T}{\mu_L^2} \right)^{1/3}$$

and

$$S_c = \frac{\mu_g}{D_g \cdot \rho_g} \quad G_r = \frac{g \cdot \beta_g \cdot \rho_g^2 \cdot L_c^3 \cdot \Delta T}{\mu_g^2}$$

where

ρ_g = density of gas	kg/m ³	1.17
D_g = diffusion coefficient in gas phase	m ² /s	2.50 E-05
μ_g = viscosity of gas	kg/m-s	2.0 E-05
S_c = Schmidt number	(none)	6.84 E-01
G = gravitational constant	m/s ²	9.8
ΔT = delta temperature between waste surface and gas	K	1.00
β_g = thermal expansion coefficient of gas	(K) ⁻¹	3.30 E-03
L_c = characteristic length (1/4 of diameter)	m	5.7825
G_r = Grashoff number	(none)	2.14 E+10
h_g = vapor film coefficient	m/s	0.001586
D_L = diffusion coefficient in liquid phase	m ² /s	2.8 E-09
ρ_L = density of liquid	kg/m ³	1,300
μ_L = viscosity of liquid	kg/m-s	6.82 E-04
β_L = thermal expansion coefficient of liquid	(K) ⁻¹	3.02 E-04

h_L = liquid film coefficient. m/s 5.3047 E-06

The last column lists the typical values used in the calculation of h.

Reference

RPP-4941, 2000, *Methodology for Predicting Flammable Gas Mixtures in Double-Contained Receiver Tanks*, Rev 0B, CH2M HILL Hanford Group, Inc., Richland, Washington.

APPENDIX F

**CALCULATIONS OF THE GAS DIFFUSION COEFFICIENTS FOR THE CONCRETE
DOME OF SINGLE-SHELL TANKS**

PREPARED BY JOE MEACHAM

This page intentionally left blank.

CONTENTS

Table F-1	The Thickness of Dome Coating for 149 Single-Shell Tanks and Diffusion Coefficients of Hydrogen and Methane.....	F-1
Table F-2	The Diffusion Resistance and Gas Diffusion Rate of Hydrogen and Methane for 149 Single-Shell Tanks.	F-7

This page intentionally left blank.

Table F-1. The Thickness of Dome Coating for 149 Single-Shell Tanks and Diffusion Coefficients of Hydrogen and Methane. (6 sheets)

Tank	Dome Area (cm ²)	Coatings of the Tank Dome	Concrete Thick (cm)	Asphatic Thick (cm)	Gunitite Thick (cm)	Soil Thick (cm)	Concrete De of H ₂ (cm ² /sec)	Asphatic De of H ₂ (cm ² /sec)	Gunitite De of H ₂ (cm ² /sec)	Soil De of H ₂ (cm ² /sec)	Concrete De of CH ₄ (cm ² /sec)	Asphatic De of CH ₄ (cm ² /sec)	Gunitite De of CH ₄ (cm ² /sec)	Soil De of CH ₄ (cm ² /sec)
A-101	4.39E+06	2-Ply	38.1	0.6350	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
A-102	4.39E+06	2-Ply	38.1	0.6350	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
A-103	4.39E+06	2-Ply	38.1	0.6350	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
A-104	4.39E+06	2-Ply	38.1	0.6350	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
A-105	4.39E+06	2-Ply	38.1	0.6350	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
A-106	4.39E+06	2-Ply	38.1	0.6350	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
AX-101	4.39E+06	No Coatings	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
AX-102	4.39E+06	No Coatings	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
AX-103	4.39E+06	No Coatings	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
AX-104	4.39E+06	No Coatings	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-101	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-102	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-103	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-104	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-105	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-106	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-107	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-108	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-109	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-110	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-111	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-112	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-201	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-202	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-203	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
B-204	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-101	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037

Table F-1. The Thickness of Dome Coating for 149 Single-Shell Tanks and Diffusion Coefficients of Hydrogen and Methane. (6 sheets)

Tank	Dome Area (cm ²)	Coatings of the Tank Dome	Concrete Thick (cm)	Asphatic Thick (cm)	Gunite Thick (cm)	Soil Thick (cm)	Concrete De of H ₂ (cm ² /sec)	Asphatic De of H ₂ (cm ² /sec)	Gunite De of H ₂ (cm ² /sec)	Soil De of H ₂ (cm ² /sec)	Concrete De of CH ₄ (cm ² /sec)	Asphatic De of CH ₄ (cm ² /sec)	Gunite De of CH ₄ (cm ² /sec)	Soil De of CH ₄ (cm ² /sec)
BX-102	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-103	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-104	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-105	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-106	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-107	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-108	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-109	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-110	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-111	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BX-112	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-101	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-102	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-103	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-104	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-105	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-106	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-107	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-108	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-109	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-110	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-111	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
BY-112	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-101	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-102	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-103	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-104	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037

Table F-1. The Thickness of Dome Coating for 149 Single-Shell Tanks and Diffusion Coefficients of Hydrogen and Methane. (6 sheets)

Tank	Dome Area (cm ²)	Coatings of the Tank Dome	Concrete Thick (cm)	Asphatic Thick (cm)	Gunite Thick (cm)	Soil Thick (cm)	Concrete De of H ₂ (cm ² /sec)	Asphatic De of H ₂ (cm ² /sec)	Gunite De of H ₂ (cm ² /sec)	Soil De of H ₂ (cm ² /sec)	Concrete De of CH ₄ (cm ² /sec)	Asphatic De of CH ₄ (cm ² /sec)	Gunite De of CH ₄ (cm ² /sec)	Soil De of CH ₄ (cm ² /sec)
C-105	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-106	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-107	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-108	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-109	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-110	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-111	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-112	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-201	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-202	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-203	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
C-204	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-101	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-102	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-103	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-104	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-105	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-106	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-107	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-108	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-109	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-110	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-111	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
S-112	4.38E+06	Hardner + 3-Ply + ¼ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-101	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-102	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-103	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037

Table F-1. The Thickness of Dome Coating for 149 Single-Shell Tanks and Diffusion Coefficients of Hydrogen and Methane. (6 sheets)

Tank	Dome Area (cm ²)	Coatings of the Tank Dome	Concrete Thick (cm)	Asphatic Thick (cm)	Gunitite Thick (cm)	Soil Thick (cm)	Concrete De of H ₂ (cm ² /sec)	Asphatic De of H ₂ (cm ² /sec)	Gunitite De of H ₂ (cm ² /sec)	Soil De of H ₂ (cm ² /sec)	Concrete De of CH ₄ (cm ² /sec)	Asphatic De of CH ₄ (cm ² /sec)	Gunitite De of CH ₄ (cm ² /sec)	Soil De of CH ₄ (cm ² /sec)
SX-104	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-105	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-106	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-107	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-108	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-109	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-110	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-111	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-112	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-113	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-114	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
SX-115	4.39E+06	Hardner	38.1	0.0000	0.000	366	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-101	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-102	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-103	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-104	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-105	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-106	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-107	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-108	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-109	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-110	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-111	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-112	4.43E+06	3-Ply + ¼ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-201	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-202	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
T-203	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037

Table F-1. The Thickness of Dome Coating for 149 Single-Shell Tanks and Diffusion Coefficients of Hydrogen and Methane. (6 sheets)

Tank	Dome Area (cm ²)	Coatings of the Tank Dome	Concrete Thick (cm)	Asphatic Thick (cm)	Gunite Thick (cm)	Soil Thick (cm)	Concrete De of H ₂ (cm ² /sec)	Asphatic De of H ₂ (cm ² /sec)	Gunite De of H ₂ (cm ² /sec)	Soil De of H ₂ (cm ² /sec)	Concrete De of CH ₄ (cm ² /sec)	Asphatic De of CH ₄ (cm ² /sec)	Gunite De of CH ₄ (cm ² /sec)	Soil De of CH ₄ (cm ² /sec)
T-204	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-101	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-102	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-103	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-104	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-105	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-106	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-107	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-108	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-109	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-110	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-111	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-112	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-113	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-114	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-115	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-116	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-117	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TX-118	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TY-101	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TY-102	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TY-103	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TY-104	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TY-105	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
TY-106	4.38E+06	Hardner + 3-Ply + ¾ Gunite	38.1	0.9525	1.905	427	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-101	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-102	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037

Table F-1. The Thickness of Dome Coating for 149 Single-Shell Tanks and Diffusion Coefficients of Hydrogen and Methane. (6 sheets)

Tank	Dome Area (cm ²)	Coatings of the Tank Dome	Concrete Thick (cm)	Asphatic Thick (cm)	Gunitite Thick (cm)	Soil Thick (cm)	Concrete De of H ₂ (cm ² /sec)	Asphatic De of H ₂ (cm ² /sec)	Gunitite De of H ₂ (cm ² /sec)	Soil De of H ₂ (cm ² /sec)	Concrete De of CH ₄ (cm ² /sec)	Asphatic De of CH ₄ (cm ² /sec)	Gunitite De of CH ₄ (cm ² /sec)	Soil De of CH ₄ (cm ² /sec)
U-103	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-104	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-105	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-106	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-107	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-108	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-109	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-110	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-111	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-112	4.43E+06	3-Ply + ¾ Mortar	38.1	0.9525	1.905	404	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-201	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-202	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-203	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037
U-204	1.46E+05	Hardner + 3-Ply	30.48	0.9525	0.000	335	3.80E-03	5.00E-07	3.80E-03	0.12	1.20E-03	5.00E-07	1.20E-03	0.037

Table F-2. The Diffusion Resistance and Gas Diffusion Rates of Hydrogen and Methane for 149 Single-Shell Tanks. (6 sheets)

Tank	Concrete Resist of H ₂ (sec/cm)	Asphatic Resist of H ₂ (sec/cm)	Gunite Resist of H ₂ (sec/cm)	Soil Resist of H ₂ (sec/cm)	Concrete Resist of CH ₄ (sec/cm)	Asphatic Resist of CH ₄ (sec/cm)	Gunite Resist of CH ₄ (sec/cm)	Soil Resist of CH ₄ (sec/cm)	Total Resist of H ₂ (sec/cm)	Total Resist of CH ₄ (sec/cm)	H ₂ Diff Rate Ai/Ri (cfm)	CH ₄ Diff Rate Ai/Ri (cfm)
A-101	1.00E+04	1.27E+06	0.00E+00	3.05E+03	3.18E+04	1.27E+06	0.00E+00	9.89E+03	1.28E+06	1.31E+06	7.25E-03	7.09E-03
A-102	1.00E+04	1.27E+06	0.00E+00	3.05E+03	3.18E+04	1.27E+06	0.00E+00	9.89E+03	1.28E+06	1.31E+06	7.25E-03	7.09E-03
A-103	1.00E+04	1.27E+06	0.00E+00	3.05E+03	3.18E+04	1.27E+06	0.00E+00	9.89E+03	1.28E+06	1.31E+06	7.25E-03	7.09E-03
A-104	1.00E+04	1.27E+06	0.00E+00	3.05E+03	3.18E+04	1.27E+06	0.00E+00	9.89E+03	1.28E+06	1.31E+06	7.25E-03	7.09E-03
A-105	1.00E+04	1.27E+06	0.00E+00	3.05E+03	3.18E+04	1.27E+06	0.00E+00	9.89E+03	1.28E+06	1.31E+06	7.25E-03	7.09E-03
A-106	1.00E+04	1.27E+06	0.00E+00	3.05E+03	3.18E+04	1.27E+06	0.00E+00	9.89E+03	1.28E+06	1.31E+06	7.25E-03	7.09E-03
AX-101	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
AX-102	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
AX-103	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
AX-104	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
B-101	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-102	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-103	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-104	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-105	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-106	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-107	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-108	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-109	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-110	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-111	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-112	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
B-201	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
B-202	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
B-203	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
B-204	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
BX-101	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03

Table F-2. The Diffusion Resistance and Gas Diffusion Rates of Hydrogen and Methane for 149 Single-Shell Tanks. (6 sheets)

Tank	Concrete Resist of H ₂ (sec/cm)	Asphatic Resist of H ₂ (sec/cm)	Gunitite Resist of H ₂ (sec/cm)	Soil Resist of H ₂ (sec/cm)	Concrete Resist of CH ₄ (sec/cm)	Asphatic Resist of CH ₄ (sec/cm)	Gunitite Resist of CH ₄ (sec/cm)	Soil Resist of CH ₄ (sec/cm)	Total Resist of H ₂ (sec/cm)	Total Resist of CH ₄ (sec/cm)	H ₂ Diff Rate Ai/Ri (cfm)	CH ₄ Diff Rate Ai/Ri (cfm)
BX-102	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-103	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-104	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-105	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-106	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-107	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-108	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-109	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-110	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-111	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BX-112	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
BY-101	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-102	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-103	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-104	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-105	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-106	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-107	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-108	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-109	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-110	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-111	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
BY-112	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
C-101	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-102	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-103	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-104	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03

Table F-2. The Diffusion Resistance and Gas Diffusion Rates of Hydrogen and Methane for 149 Single-Shell Tanks. (6 sheets)

Tank	Concrete Resist of H ₂ (sec/cm)	Asphatic Resist of H ₂ (sec/cm)	Gunitite Resist of H ₂ (sec/cm)	Soil Resist of H ₂ (sec/cm)	Concrete Resist of CH ₄ (sec/cm)	Asphatic Resist of CH ₄ (sec/cm)	Gunitite Resist of CH ₄ (sec/cm)	Soil Resist of CH ₄ (sec/cm)	Total Resist of H ₂ (sec/cm)	Total Resist of CH ₄ (sec/cm)	H ₂ Diff Rate Ai/Ri (cfm)	CH ₄ Diff Rate Ai/Ri (cfm)
C-105	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-106	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-107	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-108	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-109	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-110	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-111	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-112	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
C-201	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
C-202	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
C-203	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
C-204	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
S-101	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-102	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-103	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-104	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-105	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-106	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-107	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-108	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-109	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-110	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-111	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
S-112	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
SX-101	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-102	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-103	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01

Table F-2. The Diffusion Resistance and Gas Diffusion Rates of Hydrogen and Methane for 149 Single-Shell Tanks. (6 sheets)

Tank	Concrete Resist of H ₂ (sec/cm)	Asphatic Resist of H ₂ (sec/cm)	Gunite Resist of H ₂ (sec/cm)	Soil Resist of H ₂ (sec/cm)	Concrete Resist of CH ₄ (sec/cm)	Asphatic Resist of CH ₄ (sec/cm)	Gunite Resist of CH ₄ (sec/cm)	Soil Resist of CH ₄ (sec/cm)	Total Resist of H ₂ (sec/cm)	Total Resist of CH ₄ (sec/cm)	H ₂ Diff Rate Ai/Ri (cfm)	CH ₄ Diff Rate Ai/Ri (cfm)
SX-104	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-105	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-106	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-107	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-108	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-109	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-110	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-111	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-112	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-113	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-114	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
SX-115	1.00E+04	0.00E+00	0.00E+00	3.05E+03	3.18E+04	0.00E+00	0.00E+00	9.89E+03	1.31E+04	4.16E+04	7.11E-01	2.23E-01
T-101	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-102	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-103	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-104	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-105	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-106	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-107	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-108	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-109	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-110	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-111	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-112	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
T-201	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
T-202	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
T-203	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04

Table F-2. The Diffusion Resistance and Gas Diffusion Rates of Hydrogen and Methane for 149 Single-Shell Tanks. (6 sheets)

Tank	Concrete Resist of H ₂ (sec/cm)	Asphatic Resist of H ₂ (sec/cm)	Gunite Resist of H ₂ (sec/cm)	Soil Resist of H ₂ (sec/cm)	Concrete Resist of CH ₄ (sec/cm)	Asphatic Resist of CH ₄ (sec/cm)	Gunite Resist of CH ₄ (sec/cm)	Soil Resist of CH ₄ (sec/cm)	Total Resist of H ₂ (sec/cm)	Total Resist of CH ₄ (sec/cm)	H ₂ Diff Rate Ai/Ri (cfm)	CH ₄ Diff Rate Ai/Ri (cfm)
T-204	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
TX-101	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-102	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-103	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-104	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-105	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-106	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-107	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-108	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-109	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-110	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-111	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-112	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-113	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-114	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-115	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-116	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-117	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TX-118	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TY-101	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TY-102	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TY-103	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TY-104	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TY-105	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
TY-106	1.00E+04	1.91E+06	5.01E+02	3.56E+03	3.18E+04	1.91E+06	1.59E+03	1.15E+04	1.92E+06	1.95E+06	4.84E-03	4.76E-03
U-101	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-102	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03

Table F-2. The Diffusion Resistance and Gas Diffusion Rates of Hydrogen and Methane for 149 Single-Shell Tanks. (6 sheets)

Tank	Concrete Resist of H ₂ (sec/cm)	Asphatic Resist of H ₂ (sec/cm)	Gunite Resist of H ₂ (sec/cm)	Soil Resist of H ₂ (sec/cm)	Concrete Resist of CH ₄ (sec/cm)	Asphatic Resist of CH ₄ (sec/cm)	Gunite Resist of CH ₄ (sec/cm)	Soil Resist of CH ₄ (sec/cm)	Total Resist of H ₂ (sec/cm)	Total Resist of CH ₄ (sec/cm)	H ₂ Diff Rate Ai/Ri (cfm)	CH ₄ Diff Rate Ai/Ri (cfm)
U-103	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-104	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-105	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-106	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-107	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-108	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-109	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-110	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-111	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-112	1.00E+04	1.91E+06	5.01E+02	3.37E+03	3.18E+04	1.91E+06	1.59E+03	1.09E+04	1.92E+06	1.95E+06	4.89E-03	4.82E-03
U-201	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
U-202	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
U-203	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04
U-204	8.02E+03	1.91E+06	0.00E+00	2.79E+03	2.54E+04	1.91E+06	0.00E+00	9.05E+03	1.92E+06	1.94E+06	1.61E-04	1.60E-04

APPENDIX G

**FLAMMABILITY EVALUATION OF TIME TO 25% OF THE LOWER
FLAMMABILITY LIMIT TO SUPPORT THE VACUUM RETRIEVAL PROJECT**

This page intentionally left blank.

CONTENTS

G1.0	OBJECTIVE.....	G-1
G2.0	SUMMARY OF RESULTS AND CONCLUSIONS	G-1
G3.0	BACKGROUND.....	G-1
G4.0	INPUT DATA	G-2
G5.0	ASSUMPTIONS	G-2
G6.0	METHOD OF ANALYSIS	G-2
G7.0	USE OF COMPUTER SOFTWARE.....	G-3
G8.0	RESULTS.....	G-3
G9.0	CONCLUSIONS	G-3
G10.0	REFERENCES.....	G-4

LIST OF TABLES

Table G1-A.	Input Data for Hydrogen Generation Rate Model Calculations.	G-5
Table G1-B.	Derived Data for Hydrogen Generation Rate Model Calculations.....	G-5
Table G1-C.	Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume	G-6
Table G1-D.	Calculated Total Hydrogen Generation Rate In Dome Space	G-6
Table G2-A.	Steady-State Gas Concentrations, Release Rates and Flammability Levels Under Normal Ventilation Conditions.	G-7
Table G2-B.	Steady-State Flammability Under Barometric Breathing and Time to 25% of the LFL under Zero Vent	G-7

This page intentionally left blank.

G1.0 OBJECTIVE

This case study provides an evaluation to support the determination that the potential risk associated with using the single-shell tank (SST) waste retrieval system vacuum system for retrieval of the 241-C Tank Farm 200-series SSTs is adequately addressed for steady-state gas accumulation by the current tank farm safety basis. The evaluation provides an upper limit for water additions to the designated SST receiver tank to ensure that the time to 25% of the lower flammability limit (LFL) is 365 days or greater.

The following calculation is issued in Rev. 3-A and updated in Rev. 4 of the document using the new hydrogen generation rate (HGR) model. The evaluation assumed the total waste of the 241-C Tank Farm 200-series SSTs put on the receiver tank. Since then, retrieval of tank 241-C-201, 241-C-202 and 241-C-203 has been completed. The total waste of 241-C Tank Farm 200-series is reduced by more than 50%. The total HGR of the source waste has been decreased. Thus, the maximum water addition determined below is bounding and there is no intention to update this calculation in Appendix G, Rev. 6 of this document.

G2.0 SUMMARY OF RESULTS AND CONCLUSIONS

The evaluation shows that the maximum water addition to the SST receiver is equal to 112 kL or 29.6 kgal. This is the water volume that would cause the time to 25% of the LFL in the dome space of the designated SST receiver to be 365 days, as specified for this case study.

G3.0 BACKGROUND

Waste from the 241-C Tank Farm 200-series tanks is planned to be transferred in to the double-shell tank (DST) system after accumulation in one of the four SSTs. A description of the system design and overall process can be found in RPP-17190, *Safety Evaluation of the Waste Retrieval System Vacuum System for 241-C Tank Farm 200-Series Tanks*. During the retrieval of the 241-C Tank Farm 200-series SSTs, the retrieval solution will be routinely drained to the designated SST receiver tank; in this case, SST 241-C-203. The retrieval solution is essentially water in the water separator with small amounts of entrained tank waste.

For the bounding case study, the time to 25% of the LFL for the SST receiver tank is 365 days, a limit specified by Retrieval/Closure Nuclear Safety. Currently, the 241-C 200-series SSTs contain very little waste. The time to 25% of the LFL is over 1,500 days for SSTs 241-C-201, 241-C-202, 241-C-203, and 241-C-204, respectively, under zero ventilation condition (see Table 4-5 of the main text). These times to 25% of the LFL are much longer than 365 days. This evaluation of steady-state flammable gas accumulation analyzes how much water could be added to the designated SST receiver tank before the time to 25% of the LFL would decrease to 365 days.

G4.0 INPUT DATA

The bounding case evaluation assumes that all the solid waste in the four 241-C 200-series SSTs is accumulated in one of the tanks. Also as the bounding case, the HGR calculations and flammability evaluations assume the waste condition of SST 241-C-204 represents all the waste. SST 241-C-204 is used because it has the waste that contains the highest HGR per unit volume.

The steady-state HGR input data for SST 241-C-204 is documented in Appendix B, Table B-5. The volume of all the waste is the sum of the solid waste in each tank. These data are used in Table F-1A. For the time to LFL calculations, the required data are taken from Appendix D, Table D-1. Because a verified spreadsheet is used, only input data needs to be checked for accuracy.

G5.0 ASSUMPTIONS

All of the waste from the four 241-C 200-series tanks is assumed to have the characteristics of SST 241-C-204 waste. This evaluation assumes a hypothetical 1,000-gal water addition, documented in Table B-5, has been made to the SST 241-C-204 prior accumulation in the SST receiver and prior to those tanks receiving any retrieval waste or water. The 1,000-gal water addition to SST 241-C-204 waste is assumed to form a thin liquid layer and has the waste composition of the interstitial liquid.

The additional water used for retrieval is assumed to be well mixed with the hypothetical liquid layer in the SST receiver.

G6.0 METHOD OF ANALYSIS

The methodology and equations for the flammability evaluation used in this study is discussed in Chapter 3.0 and 4.0 of the main text of this document. This methodology is developed to calculate the gas release rate, gas generation rate, flammability level, and time to 25% and 100% of the LFL for a given ventilation rate.

Given the calculated HGRs along with historical gas release rates of ammonia and methane from the identified waste, the time to 25% of the LFL are calculated. Note that water additions will decrease the volume of the dome space, and therefore, the time to reach 25% of the LFL for a given ventilation rate will decrease. In order to find the upper limit of water addition, the volume of water is gradually increased until the time to 25% of the LFL is 365 days.

G7.0 USE OF COMPUTER SOFTWARE

This case study uses a validated Excel⁸ spreadsheet, documented in RPP-5926, Rev. 4, to conduct the calculations (RPP-5926-8050-R3-LFL-CAL-T2-1102004.xls). Refer to the spreadsheet verification form in Appendix I, page I-3. This spreadsheet used the input data to calculate the gas generation rates, then calculates the flammability and time to LFL for a given ventilation rate.

G8.0 RESULTS

Appendix B, Table B-1 shows that the total waste volume of the four 241-C 200-series SST is 17 kL. The waste composition, physical properties, and waste temperature for SST 241-C-204, along with the total waste volume of 17 kL, is used to calculate the HGR and flammability for the solid waste layer in the SST receiver.

For the liquid layer, the volume of water added is used to calculate the dilution factor, and then the dilution factor is used to recalculate the waste composition and physical properties based on the input data for the liquid layer listed in Table B-5 of Appendix B, which includes a hypothetical 1,000 gal of water addition to the waste. The dilution factor is determined by the ratio of total water addition and supernatant volume of 1,000 gal. Details of the input data and HGR calculation results are given in Table G-1A to Table G-1D. Note that in Table G-1D, note that HGR is primarily coming from the corrosion (about 99%) for both liquid and solid layers. So in this case it will make not much difference whether we treat the liquid layer as pure water or assume the added water is well mixed with waste.

It is found that when total water additions are 112 kL or 29.6 kgal including the hypothetical supernatant of 1,000 gal, the time to 25% of the LFL is 365 days. Also, note that the steady-state flammability of the system, which is 17 kL of solid waste and 112 kL of water, under barometric breathing condition is 15.4%. Details of calculated input data and time to 25% of the LFL under zero ventilation are given in Table G-2A to Table G-2B.

G9.0 CONCLUSIONS

For the given maximum solid waste volume of 17 kL, as long as the total water additions to the SST receiver tank are less than 112 kL or 29.6 kgal, the time to 25% of the LFL will not reach 365 days during the waste retrieval activities.

⁸ Excel is a registered trademark of Microsoft Corporation, Redmond, Washington.

G10.0 REFERENCES

RPP-17190, 2003, *Safety Evaluation of the Waste Retrieval System Vacuum System for 241-C Tank Farm 200-Series Tanks*, Rev 0, CH2M HILL Hanford Group, Inc., Richland, Washington.

Table G1-A. Input Data for Hydrogen Generation Rate Model Calculations.

Tank	Volume of Water Addition (kL) and Dilution factor	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Al in liquid [Al] (μg/mL)	Na in liquid [Na] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume V (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
Supernatant	111.9	2.98E+03	3.60E+04	7.96E+04	8.20E+04	4.94E+03	1.09E+01	4.72E+00	1.17	1.17	112	75%	75%	17	16
Solid Layer		2.98E+03	3.60E+04	7.96E+04	8.20E+04	4.94E+03	1.09E+01	4.72E+00	1.62	1.17	17	41%	75%	17	16

Table G1-B. Derived Data for Hydrogen Generation Rate Model Calculations

Tank	Waste level D _w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A _{wet} (ft ²)	Heat load per kg H _L B/γ (watt/kg)	Tank heat load H _L ^{alpha} (wattKg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/L)	OH in liquid [NO ₂] _M (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency H ₂ by corrosion	Total G values GB/γ _{TOT} (H ₂ /100eV)	Total G values G ^a _{TOT} (H ₂ /100eV)
Supernatant	150.8	1.31E+05	100%	789	9.52E-05	2.63E-07	1.28	0.78	1.50	1.00	0.26	0.42	0.20	0.063	0.230
Solid Layer	22.2	2.67E+04	55%	431	9.52E-05	2.63E-07	1.28	0.78	1.50	1.00	0.26	0.42	0.20	0.063	0.230

Table G1-C. Calculated Hydrogen Generation Rate as Mole Per Unit Waste Weight and Volume

Tank	HGR from radiolysis $RC_{B/\gamma_{rad}}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{α} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{B/\gamma_{rad}}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{α} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
Supernatant	5.36E-08	5.42E-10	1.64E-08	4.84E-07	5.55E-07	7.26E-10	7.34E-12	2.23E-10	6.55E-09	7.51E-09
Solid Layer	2.94E-08	2.98E-10	9.03E-09	1.29E-06	1.33E-06	5.52E-10	5.58E-12	1.69E-10	2.42E-08	2.50E-08

Table G1-D. Calculated Total Hydrogen Generation Rate In Dome Space

Tank	HGR from radiolysis $G_{rad_{B/\gamma}}$ (cfm)	HGR from radiolysis G_{rad}^{α} (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis ($G_{rad_{B/\gamma}}\%$)	Percent of HGR from radiolysis ($G_{rad}^{\alpha}\%$)	Percent of HGR from thermolysis ($G_{therm}\%$)	Percent of HGR from corrosion ($G_{corr}\%$)	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
Supernatant	4.07E-06	4.12E-08	1.25E-06	3.68E-05	9.7%	0.10%	3.0%	87.3%	4.21E-05	2
Solid Layer	4.57E-07	4.62E-09	1.40E-07	2.01E-05	2.2%	0.02%	0.7%	97.1%	2.07E-05	1

Table G2-A. Steady-State Gas Concentrations, Release Rates and Flammability Levels Under Normal Ventilation Conditions.

Tank	Ammonia headspace concn. [NH ₃] (%)	Methane headspace concn. [CH ₄] (%)	N ₂ O headspace concn. [N ₂ O] (%)	Waste volume V _w (kgal)	Headspace volume V _h (ft ³)	Normal ventilation rate (Vr) _{norm} (cfm)	Steady-state flammability at normal condition (% LFL)	Ammonia release rate Rr(NH ₃) (cfm)	N ₂ O release rate Rr(N ₂ O) (cfm)	Model hydrogen release rate Rr(H ₂) (cfm)	Methane release rate Rr(CH ₄) (cfm)
241-C-204	0.0001	0.0001	0.0014	34	3,408	3	0.05%	2.18E-06	4.31E-05	6.28E-05	2.76E-06

Table G2-B. Steady-State Flammability Under Barometric Breathing and Time to 25% of the LFL under Zero Vent

Tank	Off-Normal Barometric Breathing Rate (Vr) _{bb} (cfm)	Steady State Hydrogen Concn. [H ₂] (%)	Steady State Ammonia Concn. [NH ₃] (%)	Steady State Methane Concn. [CH ₄] (%)	Steady State N ₂ O Concn. [N ₂ O] (%)	Steady State Hydrogen Flammab. (%)	Steady State Ammonia Flammab. (%)	Steady State Methane Flammab. (%)	Steady State Total Flammab (%)	Time to Reach 25% of the LFL under Diffusion (days)	Time to Reach 100% of the LFL under diffusion (days)
241-C-204	0.01	0.59	0.02	0.03	0.40	14.7	0.14	0.52	15.4	365	1,500

This page intentionally left blank.

APPENDIX H

**FLAMMABILITY EVALUATION OF TIME TO REACH 25% AND 100% OF THE
LOWER FLAMMABILITY LIMIT FOR DOUBLE-SHELL TANK 241-AY-102 AT
VARIOUS WASTE LEVELS WHILE RECEIVING EXHAUSTER CONDENSATE
COLLECTED FROM CATCH TANK 241-AZ-151**

This page intentionally left blank.

CONTENTS

H1.0	OBJECTIVE.....	H-1
H2.0	SUMMARY OF RESULTS AND CONCLUSIONS	H-1
H3.0	BACKGROUND.....	H-1
H4.0	INPUT DATA	H-2
H5.0	ASSUMPTIONS	H-2
H6.0	METHOD OF ANALYSIS	H-2
H7.0	USE OF COMPUTER SOFTWARE.....	H-3
H8.0	RESULTS.....	H-3
H.09	CONCLUSIONS.....	H-4
H10.0	REFERENCES.....	H-4

LIST OF TABLES

Table H1-A. Input Data for Hydrogen Generation Rate Model Calculations for 241-AY-102 Condensate Addition.....	H-5
Table H1-B. Derived Data for Hydrogen Generation Rate Model Calculations for 241-AY-102 on Condensate Addition.....	H-6
Table H1-C. Calculated Hydrogen Generation Unit Rate for 241-AY-102 Condensate Addition.....	H-7
Table H1-D. Calculated Total Hydrogen Generation Rate In Dome Space for 241-AY-102 Condensate Addition.....	H-8
Table H2-A. Steady-State Gas Concentrations, Release Rates and Flammability Levels Under Normal Ventilation Conditions.	H-9
Table H2-B. Steady-State Flammability Under Barometric Breathing and Time to 25% of the LFL under Zero Vent.	H-10

This page intentionally left blank.

APPENDIX H

FLAMMABILITY EVALUATION OF TIME TO REACH 25% AND 100% OF THE LOWER FLAMMABILITY LIMIT FOR DOUBLE-SHELL TANK 241-AY-102 AT VARIOUS WASTE LEVELS WHILE RECEIVING EXHAUSTER CONDENSATE COLLECTED FROM CATCH TANK 241-AZ-151

H1.0 OBJECTIVE

This calculation provides the technical basis for an amendment to the HNF-SD-WM-TSR-006, *Technical Safety Requirements*, LCO 3.2.1, "DST Primary Ventilation Systems, Surveillance Requirement 3.2.1.4." The amendment is needed because DST 241-AY-102 will continue receiving condensate. The calculation provides the time to reach 25% and 100% of the lower flammability limit (LFL) as function of waste level. The evaluation determines the hydrogen generation rate (HGR) and the minimum ventilation rate required to keep below 25% and 100% of the LFL for the given waste level.

The following calculation was issued in Rev. 3-D and updated in Rev. 4 of this document. In Table B-4, Appendix B, Rev. 6 of this document, it is found that HGR has dropped by 30% from Rev. 4 calculation based on latest core sample results (August 2005). So the following evaluation is bounding and there is no intention to update the calculation for Rev. 6 of this document.

H2.0 SUMMARY OF RESULTS AND CONCLUSIONS

The evaluation shows that the times required to reach 25% of the LFL are 12, 10, 8 and 6 days for the waste levels of 313.8 in. (current waste level), 333.0 in., 366.3 in., and 399.1 in., respectively, under zero ventilation. For all calculated waste level cases, the HGR is $3.93 \text{ E-2 ft}^3/\text{min}$, and the minimum ventilation rates to stay within 25% and 100% of the LFL level are around 4.0 and 1.0 ft^3/min , respectively, for all waste levels calculated.

H3.0 BACKGROUND

Condensate from tanks in the 241-AY/AZ Tank Farms is collected in catch tank 241-AZ-151 and directed to DST 241-AY-102. Currently, the waste level of DST 241-AY-102 is about 313.8 in., and it will increase approximately 3 in. per month because of condensate received from DST 241-AZ-151. LCO 3.2.1, "Surveillance Requirement 3.2.1.4," specifies that the surveillance time for flammable gas in the 241-AY tanks is 5 days. Surveillance times plus the time needed to complete Actions described in LCO 3.2.1 must be equal to or less than the time it takes the flammable gas concentration in the tank to reach 25% of the LFL. At the current waste level in DST 241-AY-102, the combined Surveillance time and Action time is equal to the time

to 25% of the LFL. To continue receiving condensate in DST 241-AY-102, the Surveillance time must be changed to reflect the changes in the time to reach 25% of the LFL.

This appendix calculation determines the corresponding time for DST 241-AY-102 to reach 25% of the LFL as condensate received from DST 241-AZ-151 increases the waste level in DST 241-AY-102. The results will be used for an amendment to RPP-13033, *Tank Farms Documented Safety Analysis*, that specifies a new surveillance requirement for the 241-AY Tank Farm such that the condensate can be added until the operational level limit of 364 in., documented in OSD-T-151-00007, *Operating Specifications for the Double-Shell Storage Tanks*, is reached.

H4.0 INPUT DATA

The input data for HGR calculation, such as waste compositions of total organic carbon (TOC), NO₃, NO₂, Al, Sr-90, Cs-137 and waste density, are exactly the same as the previous evaluation listed in Appendix B, Table B-1 of this document, except the condensate addition dilutes the composition and density of supernatant. The composition of condensate is treated as water although the condensate is slightly contaminated. The volume of condensate (Table H-1a, column 2) represents the amount of condensate added on top of the supernatant since the last evaluation (Appendix H, Table B-1). The condensate additions of 24, 200, 375, 548, 719, and 889 kL correspond to the final waste levels of 316.0, 333.0, 349.7, 366.3, 382.7 and 399.1 in., respectively, and are listed in Table H-2b. The waste compositions and temperatures after the condensate additions also are given in Table H-1a. The temperature is the same as the previous calculation, following the rule of using the maximum temperature from the past year. The temperature reflects 5 °C higher temperature than the baseline temperature for double-shell tanks (DST) as discussed in Chapters 3.0 and 4.0.

H5.0 ASSUMPTIONS

The condensate is treated as if it is contaminated water. The condensate addition is assumed to be well mixed with the supernatant layer of DST 241-AY-102. The waste composition and density of supernatant are corrected by the dilution factor.

H6.0 METHOD OF ANALYSIS

The methodology and equations for the flammability evaluation used in this study are discussed in Chapter 3.0. This methodology is developed to calculate the gas release rate, gas generation rate, flammability level, and times to reach 25% and 100% of the LFL for a given ventilation rate.

Given the calculated HGRs along with historical gas release rates of ammonia and methane from the identified waste, the time to reach 25% of the LFL is calculated. Note that condensate additions will decrease the volume of the dome space; and, therefore, the time to reach 25% of the LFL for a given ventilation rate will decrease. To find the waste level of water addition, the volume of condensate is gradually increased until the time to reach 25% of the LFL is 11, 10, 9, 8, 7 and 6 days. Also, the time to reach 25% of the LFL is calculated at the current waste level of 313.8 in. and the operational waste level of 364 in.

H7.0 USE OF COMPUTER SOFTWARE

This case study uses a validated Excel⁹ spreadsheet, documented in RPP-5926, Rev. 4, to conduct the calculations (RPP-5926-8050-R3-LFL-CAL-T2-102004.xls). Refer to the spreadsheet verification form in Appendix I, page I-3. This spreadsheet used the input data to calculate the gas generation rates and then calculate the flammability and time to reach the LFL for a given ventilation rate.

H8.0 RESULTS

Tables H-1b to H-1d provide the derived term for the HGR model calculation from input data (Table H-1a), the unit HGRs, and total HGRs, respectively. The HGRs are roughly $3.9 \text{ E-}02 \text{ ft}^3/\text{min}$ (about 1,598 L/day) for all calculated waste levels as shown in Table H-2B. The condensate addition increases the volume of supernatant and also slightly reduces concentrations, resulting in almost no change in the total HGR for the supernatant layer. All of the calculations include 5 °C higher temperature than the waste temperature as discussed in Chapter 3.0 and 4.0.

The times to reach 25% of the LFL at the current waste level of 313.8 in. and the operational waste level of 364 in. are 12 and 9 days, respectively. The condensate additions increasing the waste level to 316.0, 333.0, 349.7, 366.3, 382.7 and 399.1 i. result in 11, 10, 9, 8, 7, and 6 days, respectively, for the time to reach 25% of the LFL; and are 43, 40, 37, 33, 30, and 26 days, respectively, for the time to reach 100% of the LFL under zero ventilation. The minimum ventilation rates to keep the headspace below 25% and 100% of the LFL are about 4.0 and $1.0 \text{ ft}^3/\text{min}$, respectively.

The 241-AY Tank Farm tanks cannot be filled to 390 in. due to physical piping limitations. As part of the parametric study, times to LFL down to 7 days was calculated.

⁹ Excel is a registered trademark of Microsoft Corporation, Redmond, Washington.

H.09 CONCLUSIONS

The time to reach 25% of the LFL for the current waste level of 313.8 in. is 12 days, which is still within the current flammable gas surveillance requirement for the 241-AY Tank Farm given in HNF-SD-WM-TSR-006, LCO 3.2.1, "DST Primary Ventilation Systems." The time to reach 25% of the LFL is 9 days for the operational waste limit of 364 in. under zero ventilation.

H10.0 REFERENCES

HNF-SD-WM-TSR-006, *Tank Farms Technical Safety Requirements*, as amended, CH2M HILL Hanford Group, Inc., Richland, Washington.

OSD-T-151-00007, 2003, *Operating Specifications for the Double-Shell Storage Tanks*, Rev. I-7, CH2M HILL Hanford Group, Inc., Richland, Washington.

RPP-13033, *Tank Farms Documented Safety Analysis*, as amended, CH2M HILL Hanford Group, Inc., Richland, Washington.

Table H1-A. Input Data for Hydrogen Generation Rate Model Calculations for 241-AY-102 Condensate Addition.

Cases	Waste layer	Volume of water addition (kL) and Dilution factor	TOC in liquid [TOC] (μg/mL)	NO ₂ in liquid [NO ₂] (μg/mL)	NO ₃ in liquid [NO ₃] (μg/mL)	Al in liquid [Al] (μg/mL)	Na in liquid [Na] (μg/mL)	⁹⁰ Sr in waste [Sr] (μCi/g)	¹³⁷ Cs in waste [Cs] (μCi/g)	Bulk density D (g/mL)	Liquid Density D _L (g/ml)	Non-RGS waste volume V (kL)	Bulk water [H ₂ O] (wt%)	Liquid water [H ₂ O] (wt%)	Waste temp. T _w (°C)	Dome temp. T _d (°C)
1	Supernatant	0	8.67E+02	3.17E+04	4.15E+02	6.04E+04	1.22E+03	1.02E+00	1.80E+01	1.18	1.18	2700	82%	82%	53	49
	Solid Layer		1.66E+03	8.33E+02	3.81E+01	7.33E+04	2.69E+02	9.85E+03	2.70E+02	1.55	1.16	571	45%	79%	75	49
2	Supernatant	24	8.67E+02	3.15E+04	4.11E+02	5.98E+04	1.21E+03	1.01E+00	1.78E+01	1.18	1.18	2724	83%	83%	53	49
	Solid Layer		1.66E+03	8.33E+02	3.81E+01	7.33E+04	2.69E+02	9.85E+03	2.70E+02	1.55	1.16	571	45%	79%	75	49
3	Supernatant	200	8.67E+02	2.95E+04	3.86E+02	5.62E+04	1.14E+03	9.56E-01	1.69E+01	1.17	1.17	2900	83%	83%	53	49
	Solid Layer		1.66E+03	8.33E+02	3.81E+01	7.33E+04	2.69E+02	9.85E+03	2.70E+02	1.55	1.16	571	45%	79%	75	49
4	Supernatant	375	8.67E+02	2.79E+04	3.64E+02	5.30E+04	1.07E+03	9.09E-01	1.61E+01	1.16	1.16	3075	84%	84%	53	49
	Solid Layer		1.66E+03	8.33E+02	3.81E+01	7.33E+04	2.69E+02	9.85E+03	2.70E+02	1.55	1.16	571	45%	79%	75	49
5	Supernatant	524	7.26E+02	2.66E+04	3.47E+02	5.06E+04	1.02E+03	8.72E-01	1.54E+01	1.15	1.15	3224	85%	85%	53	49
	Solid Layer		1.66E+03	8.33E+02	3.81E+01	7.33E+04	2.69E+02	9.85E+03	2.70E+02	1.55	1.16	571	45%	79%	75	49
6	Supernatant	548	8.67E+02	2.64E+04	3.45E+02	5.02E+04	1.02E+03	8.67E-01	1.53E+01	1.15	1.15	3248	85%	85%	53	49
	Solid Layer		1.66E+03	8.33E+02	3.81E+01	7.33E+04	2.69E+02	9.85E+03	2.70E+02	1.55	1.16	571	45%	79%	75	49
7	Supernatant	719	8.67E+02	2.51E+04	3.28E+02	4.77E+04	9.65E+02	8.29E-01	1.46E+01	1.14	1.14	3419	86%	86%	53	49
	Solid Layer		1.66E+03	8.33E+02	3.81E+01	7.33E+04	2.69E+02	9.85E+03	2.70E+02	1.55	1.16	571	45%	79%	75	49
8	Supernatant	889	8.67E+02	2.39E+04	3.12E+02	4.54E+04	9.19E+02	7.94E-01	1.40E+01	1.13	1.13	3589	86%	86%	53	49
	Solid Layer		1.66E+03	8.33E+02	3.81E+01	7.33E+04	2.69E+02	9.85E+03	2.70E+02	1.55	1.16	571	45%	79%	75	49

Table H1-B. Derived Data for Hydrogen Generation Rate Model Calculations for 241-AY-102 on Condensate Addition.

Case	Waste layer	Waste level D_w (inch)	Total mass M (kg)	Liquid in waste (wt%)	Wetted area A_{wet} (ft ²)	Heat load per kg $H_{L-\beta/\gamma}$ (watt/kg)	Tank heat load $H_{L-\alpha}$ (watt/kg)	NO ₃ in liquid [NO ₃] _M (mole/L)	NO ₂ in liquid [NO ₂] _M (mole/L)	Excess Na in liquid [Na] _{ex} (mole/L)	OH in liquid [NO ₂] _M (mole/L)	TOC in liquid [TOC] _% (wt%)	Al in liquid [Al] _% (wt%)	E _{H2} Efficiency H2 by corrosion	Total G values $G_{tot-\beta/\gamma}$ (H ₂ /100eV)	Total G values $G_{tot-\alpha}$ (H ₂ /100eV)
1	Supernatant	259.0	3.18E+06	100%	5085	9.18E-05	6.65E-08	0.01	0.69	1.93	0.23	0.07	0.10	0.50	0.134	0.729
	Solid Layer	54.8	8.83E+05	57%	5493	6.71E-02	2.55E-04	0.00	0.02	3.17	0.23	0.14	0.02	0.50	0.184	1.092
2	Supernatant	261.3	3.20E+06	100%	5130	9.11E-05	6.60E-08	0.01	0.68	1.91	0.23	0.07	0.10	0.50	0.135	0.731
	Solid Layer	54.8	8.83E+05	57%	5493	6.71E-02	2.55E-04	0.00	0.02	3.17	0.23	0.14	0.02	0.50	0.184	1.092
3	Supernatant	278.2	3.38E+06	100%	5463	8.63E-05	6.25E-08	0.01	0.64	1.79	0.23	0.07	0.10	0.50	0.144	0.745
	Solid Layer	54.8	8.83E+05	57%	5493	6.71E-02	2.55E-04	0.00	0.02	3.17	0.23	0.14	0.02	0.50	0.184	1.092
4	Supernatant	295.0	3.55E+06	100%	5792	8.21E-05	5.95E-08	0.01	0.61	1.69	0.23	0.07	0.09	0.50	0.152	0.757
	Solid Layer	54.8	8.83E+05	57%	5493	6.71E-02	2.55E-04	0.00	0.02	3.17	0.23	0.14	0.02	0.50	0.184	1.092
5	Supernatant	309.2	3.70E+06	100%	6117	7.88E-05	5.71E-08	0.01	0.58	1.61	0.23	0.06	0.09	0.50	0.157	0.810
	Solid Layer	54.8	8.83E+05	57%	5493	6.71E-02	2.55E-04	0.00	0.02	3.17	0.23	0.14	0.02	0.50	0.184	1.092
6	Supernatant	311.5	3.73E+06	100%	6117	7.83E-05	5.67E-08	0.01	0.57	1.60	0.23	0.08	0.09	0.50	0.159	0.769
	Solid Layer	54.8	8.83E+05	57%	5493	6.71E-02	2.55E-04	0.00	0.02	3.17	0.23	0.14	0.02	0.50	0.184	1.092
7	Supernatant	328.0	3.90E+06	100%	6440	7.48E-05	5.42E-08	0.01	0.54	1.52	0.23	0.08	0.08	0.50	0.166	0.780
	Solid Layer	54.8	8.83E+05	57%	5493	6.71E-02	2.55E-04	0.00	0.02	3.17	0.23	0.14	0.02	0.50	0.184	1.092
8	Supernatant	344.3	4.07E+06	100%	6761	7.17E-05	5.19E-08	0.01	0.52	1.45	0.23	0.08	0.08	0.50	0.173	0.789
	Solid Layer	54.8	8.83E+05	57%	5493	6.71E-02	2.55E-04	0.00	0.02	3.17	0.23	0.14	0.02	0.50	0.184	1.092

Table H1-C. Calculated Hydrogen Generation Unit Rate for 241-AY-102 Condensate Addition.

Case	Waste layer	Waste level D_w (inch)	HGR from radiolysis $RC_{\beta/\gamma_{rad}}$ (mole/kg-d)	HGR from radiolysis RC_{rad}^{α} (mole/kg-d)	HGR from thermolysis RC_{therm} (mole/kg-d)	HGR from corrosion RC_{corr} (mole/kg-d)	Total HGR from model RC_{tot} (mole/kg-d)	HGR from radiolysis $RC_{\beta/\gamma_{rad}}$ (mole/m ³ -s)	HGR from radiolysis RC_{rad}^{α} (mole/m ³ -s)	HGR from thermolysis RC_{therm} (mole/m ³ -s)	HGR from corrosion RC_{corr} (mole/m ³ -s)	Total HGR from model RC_{tot} (mole/m ³ -s)
1	Supernatant	259.0	1.10E-07	4.34E-10	3.08E-07	8.01E-08	4.99E-07	1.50E-09	5.91E-12	4.20E-09	1.09E-09	6.80E-09
	Solid Layer	54.8	6.32E-05	1.42E-06	1.46E-06	3.11E-07	6.64E-05	1.13E-06	2.54E-08	2.61E-08	5.58E-09	1.19E-06
2	Supernatant	261.3	1.10E-07	4.32E-10	3.08E-07	8.02E-08	4.99E-07	1.50E-09	5.88E-12	4.19E-09	1.09E-09	6.79E-09
	Solid Layer	54.8	6.32E-05	1.42E-06	1.46E-06	3.11E-07	6.64E-05	1.13E-06	2.54E-08	2.61E-08	5.58E-09	1.19E-06
3	Supernatant	278.2	1.11E-07	4.17E-10	3.04E-07	8.10E-08	4.96E-07	1.50E-09	5.62E-12	4.10E-09	1.09E-09	6.69E-09
	Solid Layer	54.8	6.32E-05	1.42E-06	1.46E-06	3.11E-07	6.64E-05	1.13E-06	2.54E-08	2.61E-08	5.58E-09	1.19E-06
4	Supernatant	295.0	1.12E-07	4.03E-10	3.00E-07	8.16E-08	4.94E-07	1.49E-09	5.40E-12	4.02E-09	1.09E-09	6.61E-09
	Solid Layer	54.8	6.32E-05	1.42E-06	1.46E-06	3.11E-07	6.64E-05	1.13E-06	2.54E-08	2.61E-08	5.58E-09	1.19E-06
5	Supernatant	309.2	1.11E-07	3.92E-10	2.49E-07	8.21E-08	4.42E-07	1.47E-09	5.21E-12	3.31E-09	1.09E-09	5.88E-09
	Solid Layer	54.8	6.32E-05	1.42E-06	1.46E-06	3.11E-07	6.64E-05	1.13E-06	2.54E-08	2.61E-08	5.58E-09	1.19E-06
6	Supernatant	311.5	1.12E-07	3.91E-10	2.97E-07	8.22E-08	4.91E-07	1.48E-09	5.19E-12	3.94E-09	1.09E-09	6.52E-09
	Solid Layer	54.8	6.32E-05	1.42E-06	1.46E-06	3.11E-07	6.64E-05	1.13E-06	2.54E-08	2.61E-08	5.58E-09	1.19E-06
7	Supernatant	328.0	1.12E-07	3.79E-10	2.93E-07	8.27E-08	4.88E-07	1.47E-09	5.00E-12	3.87E-09	1.09E-09	6.44E-09
	Solid Layer	54.8	6.32E-05	1.42E-06	1.46E-06	3.11E-07	6.64E-05	1.13E-06	2.54E-08	2.61E-08	5.58E-09	1.19E-06
8	Supernatant	344.3	1.11E-07	3.67E-10	2.90E-07	8.32E-08	4.85E-07	1.46E-09	4.82E-12	3.80E-09	1.09E-09	6.36E-09
	Solid Layer	54.8	6.32E-05	1.42E-06	1.46E-06	3.11E-07	6.64E-05	1.13E-06	2.54E-08	2.61E-08	5.58E-09	1.19E-06

Table H1-D. Calculated Total Hydrogen Generation Rate In Dome Space for 241-AY-102 Condensate Addition.

Case	Waste layer	Waste level D_w (inch)	HGR from radiolysis $G_{rad \beta/\gamma}$ (cfm)	HGR from radiolysis $G_{rad \alpha}$ (cfm)	HGR from thermolysis G_{therm} (cfm)	HGR from corrosion G_{corr} (cfm)	Percent of HGR from radiolysis $(G_{rad \beta/\gamma})\%$	Percent of HGR from radiolysis $(G_{rad \alpha})\%$	Percent of HGR from thermolysis $(G_{therm})\%$	Percent of HGR from corrosion $(G_{corr})\%$	Total HGR from model G_{mod} (cfm)	Total HGR from model G_{mod} (L/day)
1	Supernatant	259.0	2.27E-04	8.93E-07	6.34E-04	1.65E-04	22.1%	8.70E-04	61.8%	16.1%	1.03E-03	42
	Solid Layer	54.8	3.61E-02	8.12E-04	8.34E-04	1.78E-04	95.2%	2.14E-02	2.2%	0.5%	3.80E-02	1548
2	Supernatant	261.3	2.29E-04	8.95E-07	6.38E-04	1.66E-04	22.1%	8.66E-04	61.7%	16.1%	1.03E-03	42
	Solid Layer	54.8	3.61E-02	8.12E-04	8.34E-04	1.78E-04	95.2%	2.14E-02	2.2%	0.5%	3.80E-02	1548
3	Supernatant	278.2	2.43E-04	9.13E-07	6.65E-04	1.77E-04	22.4%	8.40E-04	61.2%	16.3%	1.09E-03	44
	Solid Layer	54.8	3.61E-02	8.12E-04	8.34E-04	1.78E-04	95.2%	2.14E-02	2.2%	0.5%	3.80E-02	1548
4	Supernatant	295.0	2.57E-04	9.28E-07	6.91E-04	1.88E-04	22.6%	8.17E-04	60.8%	16.5%	1.14E-03	46
	Solid Layer	54.8	3.61E-02	8.12E-04	8.34E-04	1.78E-04	95.2%	2.14E-02	2.2%	0.5%	3.80E-02	1548
5	Supernatant	309.2	2.66E-04	9.40E-07	5.97E-04	1.97E-04	25.1%	8.86E-04	56.3%	18.6%	1.06E-03	43
	Solid Layer	54.8	3.61E-02	8.12E-04	8.34E-04	1.78E-04	95.2%	2.14E-02	2.2%	0.5%	3.80E-02	1548
6	Supernatant	311.5	2.70E-04	9.42E-07	7.16E-04	1.98E-04	22.7%	7.95E-04	60.4%	16.7%	1.18E-03	48
	Solid Layer	54.8	3.61E-02	8.12E-04	8.34E-04	1.78E-04	95.2%	2.14E-02	2.2%	0.5%	3.80E-02	1548
7	Supernatant	328.0	2.82E-04	9.55E-07	7.40E-04	2.09E-04	22.9%	7.76E-04	60.1%	17.0%	1.23E-03	50
	Solid Layer	54.8	3.61E-02	8.12E-04	8.34E-04	1.78E-04	95.2%	2.14E-02	2.2%	0.5%	3.80E-02	1548
8	Supernatant	344.3	2.93E-04	9.68E-07	7.64E-04	2.19E-04	22.9%	7.58E-04	59.8%	17.2%	1.28E-03	52
	Solid Layer	54.8	3.61E-02	8.12E-04	8.34E-04	1.78E-04	95.2%	2.14E-02	2.2%	0.5%	3.80E-02	1548

Table H2-A. Steady-State Gas Concentrations, Release Rates and Flammability Levels Under Normal Ventilation Conditions.

Case	Ammonia headspace concn. [NH ₃] (%)	Methane headspace concn. [CH ₄] (%)	N ₂ O headspace concn. [N ₂ O] (%)	Waste volume V _w (kgal)	Headspace volume V _h (ft ³)	Normal ventilation rate (Vr) _{norm} (cfm)	Steady-state flammability at normal condition (% LFL)	Ammonia release rate Rr(NH ₃) (cfm)	N ₂ O release rate Rr(N ₂ O) (cfm)	Model hydrogen release rate Rr(H ₂) (cfm)	Methane release rate Rr(CH ₄) (cfm)
1	0.0004	0.0001	0.0010	864	72,584	250	0.40%	1.07E-03	2.50E-03	3.90E-02	3.61E-04
2	0.0004	0.0001	0.0010	870	71,742	250	0.40%	1.07E-03	2.50E-03	3.90E-02	3.61E-04
3	0.0004	0.0001	0.0010	917	65,500	250	0.40%	1.07E-03	2.50E-03	3.91E-02	3.61E-04
4	0.0004	0.0001	0.0010	963	59,337	250	0.40%	1.07E-03	2.50E-03	3.91E-02	3.61E-04
5	0.0004	0.0001	0.0010	1,002	54,084	250	0.40%	1.07E-03	2.50E-03	3.90E-02	3.61E-04
6	0.0004	0.0001	0.0010	1,009	53,242	250	0.40%	1.07E-03	2.50E-03	3.92E-02	3.61E-04
7	0.0004	0.0001	0.0010	1,054	47,187	250	0.40%	1.07E-03	2.50E-03	3.92E-02	3.61E-04
8	0.0004	0.0001	0.0010	1,099	41,171	250	0.40%	1.07E-03	2.50E-03	3.93E-02	3.61E-04

Table H2-B. Steady-State Flammability Under Barometric Breathing and Time to 25% of the LFL under Zero Vent.

Case	Off-Normal Barometric Breathing Rate (Vr) _{bb} (cfm)	Steady State Hydrogen Concen. [H ₂] (%)	Steady State Ammonia Concen. [NH ₃] (%)	Steady State Methane Concen. [CH ₄] (%)	Steady State N ₂ O Concen. [N ₂ O] (%)	Steady State Total Flamma-bility (%)	Time to Reach 25% LFL (days)	Time to Reach 100% LFL (days)	Minimum Vent Rate to Keep below 25% LFL (cfm)	Minimum Vent Rate to Keep below 100% LFL (cfm)	Waste level D _w (inch)
1	0.23	17.19	0.02	0.16	1.10	433.2	12	43	3.94	0.98	313.8
2	0.22	17.40	0.02	0.16	1.12	438.3	11	43	3.94	0.98	316.0
3	0.20	19.08	0.02	0.18	1.22	480.7	10	40	3.95	0.98	333.0
4	0.19	21.09	0.02	0.19	1.35	531.3	9	37	3.95	0.99	349.7
5	0.17	23.10	0.02	0.21	1.48	577.4	9	38	3.95	0.99	364.0
6	0.17	23.54	0.02	0.22	1.50	592.9	8	33	3.96	0.99	366.3
7	0.15	26.59	0.02	0.24	1.70	669.7	7	30	3.96	0.99	382.7
8	0.13	30.51	0.02	0.28	1.94	768.4	6	26	3.97	0.99	399.1

APPENDIX I

PEER REVIEW CHECKLIST

This page intentionally left blank.

APPENDIX I

PEER REVIEW CHECKLIST

Calculation Review Checklist.

Calculation Reviewed: RPP-5926, Rev. 7 (Appendices A and B Input Data)Scope of Review: New/updated input data for flammability evaluations
(e.g., document section or portion of calculation)Engineer/Analyst: T. A. Hu Date: 10-25-07Organizational Manager: N. W. Kirch Date: 10-25-07This document consists of 277 pages and the following attachments (if applicable):

Yes	No	NA*	
☐	☐	☒	1. Analytical and technical approaches and results are reasonable and appropriate.
☐	☐	☒	2. Necessary assumptions are reasonable, explicitly stated, and supported.
☒	☐	☐	3. Ensure calculations that use software include a paper printout, microfiche, CD ROM, or other electronic file of the input data and identification to the computer codes and versions used, or provide alternate documentation to uniquely and clearly identify the exact coding and execution process.
☒	☐	☐	4. Input data were checked for consistency with original source information.
☐	☐	☒	5. Key input data (e.g., dimensions, performance characteristics) that may affect equipment design is identified.
☐	☐	☒	6. For both qualitative and quantitative data, uncertainties are recognized and discussed.
☐	☐	☒	7. Mathematical derivations were checked, including dimensional consistency of results.
☐	☐	☒	8. Calculations are sufficiently detailed such that a technically qualified person can understand the analysis without requiring outside information.
☐	☐	☒	9. Software verification and validation are addressed adequately.
☒	☐	☐	10. Limits/criteria/guidelines applied to the analysis results are appropriate and referenced.
☒	☐	☐	11. Conclusions are consistent with analytical results and applicable limits.
☒	☐	☐	12. Results and conclusions address all points in the purpose.
☐	☒	☐	13. Referenced documents are retrievable or otherwise available.
☒	☐	☐	14. The version or revision of each reference is cited, as appropriate.
☒	☐	☐	15. The document was prepared in accordance with TFC-ENG-DESIGN-C-10, Attachment A, "Calculation Format and Preparation Instructions."
☐	☐	☒	16. Impacts on requirements have been assessed and change documentation initiated to incorporate revisions to affected documents, as appropriate.
☐	☐	☒	17. The design media matches the calculations.
☒	☐	☐	18. All checker comments have been dispositioned.

K. D. Fowler
Checker (printed name and signature)10/25/07
Date

* If No or NA is chosen, an explanation must be provided on or attached to this form.

RPP-5926 REV 7

RPP-5926 REV 7

Calculation Reviewed: RPP-5926, Rev. 7

Item	Comment
1,2,	Review scope only includes new/revised input data as documented in Appendices A and B.
5,6	This evaluation is based on data for waste stored in the Hanford Tank Farms. It is not intended for equipment design. Best Basis Inventory data is used, where available, as reported and is considered representative of the tank waste.
7	Mathematical derivations were not included in the scope of this review; however, references to the documented formula derivations are included in the document.
8,9	Software verification and validation were not included in the review scope. Review does not have access to files.
13	TFC-ENG-CHEM-D-32 has been superseded as noted in the document.
16	This calculation supports the Tank Farms DSA. Results/conclusions used to support DSA changes are reviewed by NS&L. In accordance with TFC-ENG-SB-C-01, safety basis changes are prepared by NS&L.
17	Reviewer does not have access to electronic files used for calculation.
----	-----

CHECKLIST FOR TECHNICAL PEER REVIEW

Document Reviewed: RPP-5926, *Steady-State Flammable Gas Release Rate Calculation and Lower Flammability Level Evaluation for Hanford Tank Waste*, Rev 7

Scope of Review (e.g., document section or portion of calculation): Technical edit

Yes No NA*

☐	☐	☒	1. Previous reviews are complete and cover the analysis, up to the scope of this review, with no gaps.
☐	☐	☒	2. Problem is completely defined.
☐	☐	☒	3. Accident scenarios are developed in a clear and logical manner.
☐	☐	☒	4. Analytical and technical approaches and results are reasonable and appropriate. (ORP QAPP criterion 2.8)
☐	☐	☒	5. Necessary assumptions are reasonable, explicitly stated, and supported. (ORP QAPP criterion 2.2)
☐	☐	☒	6. Computer codes and data files are documented.
☐	☐	☒	7. Data used in calculations are explicitly stated.
☐	☐	☒	8. Bases for calculations, including assumptions and data, are consistent with the supported safety basis document (e.g., the Tank Farms Documented Safety Analysis).
☐	☐	☒	9. Data were checked for consistency with original source information as applicable. (ORP QAPP criterion 2.9)
☐	☐	☒	10. For both qualitative and quantitative data, uncertainties are recognized and discussed, as appropriate. (ORP QAPP criterion 2.17)
☐	☐	☒	11. Mathematical derivations were checked including dimensional consistency of results. (ORP QAPP criterion 2.16)
☐	☐	☒	12. Models are appropriate and were used within their established range of validity or adequate justification was provided for use outside their established range of validity.
☐	☐	☒	13. Spreadsheet results and all hand calculations were verified.
☐	☐	☒	14. Calculations are sufficiently detailed such that a technically qualified person can understand the analysis without requiring outside information. (ORP QAPP criterion 2.5)
☐	☐	☒	15. Software input is correct and consistent with the document reviewed.
☐	☐	☒	16. Software output is consistent with the input and with the results reported in the document reviewed.
☐	☐	☒	17. Software verification and validation are addressed adequately. (ORP QAPP criterion 2.6)
☐	☐	☒	18. Limits/criteria/guidelines applied to the analysis results are appropriate and referenced. Limits/criteria/guidelines were checked against references. (ORP QAPP criterion 2.9)
☐	☐	☒	19. Safety margins are consistent with good engineering practices.
☐	☐	☒	20. Conclusions are consistent with analytical results and applicable limits.

LMG
10-25-07

CHECKLIST FOR TECHNICAL PEER REVIEW

- ☐ ☐ ☒ 21. Results and conclusions address all points in the purpose. (*ORP QAPP criterion 2.3*)
- ☒ ☐ ☐ 22. All references cited in the text, figures, and tables are contained in the reference list.
- ☒ ☐ ☐ 23. Reference citations (e.g., title and number) are consistent between the text callout and the reference list.
- ☒ ☐ ☐ 24. Only released (i.e., not draft) references are cited. (*ORP QAPP criterion 2.1*)
- ☒ ☐ ☐ 25. Referenced documents are retrievable or otherwise available.
- ☒ ☐ ☐ 26. The most recent version of each reference is cited, as appropriate. (*ORP QAPP criterion 2.1*)
- ☒ ☐ ☐ 27. There are no duplicate citations in the reference list.
- ☒ ☐ ☐ 28. Referenced documents are spelled out (title and number) the first time they are cited.
- ☒ ☐ ☐ 29. All acronyms are spelled out the first time they are used.
- ☒ ☐ ☐ 30. The Table of Contents is correct.
- ☒ ☐ ☐ 31. All figure, table, and section callouts are correct.
- ☒ ☐ ☐ 32. Unit conversions are correct and consistent.
- ☒ ☐ ☐ 33. The number of significant digits is appropriate and consistent.
- ☐ ☐ ☒ 34. Chemical reactions are correct and balanced.
- ☒ ☐ ☐ 35. All tables are formatted consistently and are free of blank cells.
- ☒ ☐ ☐ 36. The document is complete (pages, attachments, and appendices) and in the proper order.
- ☒ ☐ ☐ 37. The document is free of typographical errors.
- ☒ ☐ ☐ 38. The tables are internally consistent.
- ☒ ☐ ☐ 39. The document was prepared in accordance with HNF-2353, Section 4.3, Attachment B, "Calculation Note Format and Preparation Instructions".
- ☐ ☐ ☒ 40. Impacted documents are appropriately identified in Blocks 7 and 25 of the Engineering Change Notice (form A-6003-563.1).
- ☒ ☐ ☐ 41. If more than one Technical Peer Reviewer was designated for this document, an overall review of the entire document was performed after resolution of all Technical Peer Review comments and confirmed that the document is self-consistent and complete.
- ☒ ☐ ☐ **Concurrence**

Leona Germain

Reviewer (Printed Name and Signature)

10-25-07

Date

* If No or NA is chosen, provide an explanation on this form.

Technical Edit